

Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

MAIRPOSA ELEMENTARY

7940 MARIPOSA AVE
CITRUS HEIGHTS, California 95610
United States

This site has been inspected and tested in compliance with applicable standards.

Completed
Thursday, July 31, 2025

Test Session :30 Jul 2025 06:19 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD
5320 HEMLOCK ST
SACRAMENTO, California
United States

TESTED BY

Riley Goyet
Western States Fire Protection-
Sacramento
188 Cirby Way
Roseville, CA 95678
United States



Inspection Summary

Building Information

PROPERTY	MAIRPOSA ELEMENTARY	CONTACT
ADDRESS	7940 MARIPOSA AVE	PHONE
CITY/STATE/ZIP	CITRUS HEIGHTS, California 95610	MOBILE
COUNTRY	United States	EMAIL

Inspector Information

COMPANY	Western States Fire Protection- Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us

Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Alarm Notification Appliance	74	74(100%)	74(100%)	0(0%)
Fire Control Panel	8	8(100%)	8(100%)	0(0%)
Initiating Device	185	182(98%)	182(98%)	0(0%)

Certification

The equipment specified herein was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Thursday, July 31, 2025

ACCEPTED BY 07/31/2025

Building Representative


TESTED BY 07/31/2025
Riley Goyet
Technician

System Details

Control Units

ADDRESS / SCAN ADDRESS	DESCRIPTION	Rooms 7-9 Bldg Telecom Rm by Rm 7
MANUFACTURER	S/W VERSION	
MODEL	LAST UPDATE	
SERIAL NUMBER	S/W LOCATION	
INSTALL DATE		

Resolved Corrective Action & Solution Summary

The following 6 corrective action(s) were resolved during the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
NAC Power Extender Panel		Restroom C Bldg Custodial Office - P.E. "F"

Created By: Riley Goyet
 Creation Date: 05/05/2022
 Corrective Action: Replace (2) 12V 8AH Batteries
 Resolution:
 Resolved By: Riley Goyet
 Resolved On: 07/30/2025
 Manufacturer:
 Model:

Created By: Riley Goyet
 Creation Date: 02/05/2024
 Corrective Action: Replace (2) 12V 8AH Batteries
 Resolution:
 Resolved By: Riley Goyet
 Resolved On: 07/30/2025
 Manufacturer:
 Model:

NAC Power Extender Panel		Rooms 19-22 Bldg Classroom 20 Closet - P.E. "C"
--------------------------	--	---

Created By: Riley Goyet
 Creation Date: 05/05/2022
 Corrective Action: Replace (2) 12V 8AH Batteries
 Resolution:
 Resolved By: Riley Goyet
 Resolved On: 07/30/2025
 Manufacturer:
 Model:

Created By: Riley Goyet
 Creation Date: 02/05/2024
 Corrective Action: Replace (2) 12V 8AH Batteries
 Resolution:
 Resolved By: Riley Goyet
 Resolved On: 07/30/2025
 Manufacturer:
 Model:

Fire Alarm Panel		Rooms 7-9 Bldg Telecom Rm by Rm 7
------------------	--	-----------------------------------

Created By: Riley Goyet
 Creation Date: 02/16/2023
 Corrective Action: Replace (2) 12V 55AH Batteries
 Resolution:
 Resolved By: Riley Goyet
 Resolved On: 07/30/2025
 Manufacturer:
 Model:

Created By: Riley Goyet
 Creation Date: 02/05/2024
 Corrective Action: Replace (2) 12V 55AH Batteries
 Resolution:
 Resolved By: Riley Goyet
 Resolved On: 07/30/2025
 Manufacturer:

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
----------------	---------	-------------

Model:

Testing Details

Alarm Notification Appliance

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible	013	Admin Bldg Copy Area	Manual	7/30/2025 6:21:51 AM
		Visual inspection	Passed (Manual)	
Visible	015	Admin Bldg Nurse Restroom	Manual	7/30/2025 6:21:48 AM
		Visual inspection	Passed (Manual)	
Visible	014	Admin Bldg Nurse Room	Manual	7/30/2025 6:21:50 AM
		Visual inspection	Passed (Manual)	
Visible	017	Admin Bldg Office Storage 1	Manual	7/30/2025 6:21:45 AM
		Visual inspection	Passed (Manual)	
Visible	018	Admin Bldg Office Storage 2	Manual	7/30/2025 6:21:44 AM
		Visual inspection	Passed (Manual)	
Visible	016	Admin Bldg Principals Office	Manual	7/30/2025 6:21:47 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	011	Admin Bldg Reception	Manual	7/30/2025 6:23:05 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	012	Admin Bldg Work Room	Manual	7/30/2025 6:23:04 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	253	Multi-Purpose Bldg Kitchen	Manual	7/30/2025 6:21:56 AM
		Visual inspection	Passed (Manual)	
Visible	255	Multi-Purpose Bldg MP Bridges Hall	Manual	7/30/2025 6:20:44 AM
		Visual inspection	Passed (Manual)	
Visible	256	Multi-Purpose Bldg MP Bridges Office	Manual	7/30/2025 6:20:37 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	250	Multi-Purpose Bldg MP Hall	Manual	7/30/2025 6:22:03 AM
		Visual inspection	Passed (Manual)	
Visible	259	Multi-Purpose Bldg MP Hall	Manual	7/30/2025 6:20:34 AM
		Visual inspection	Passed (Manual)	
Visible	254	Multi-Purpose Bldg MP Hall	Manual	7/30/2025 6:20:43 AM
		Visual inspection	Passed (Manual)	
Visible	258	Multi-Purpose Bldg MP Hall Public RR	Manual	7/30/2025 6:20:46 AM
		Visual inspection	Passed (Manual)	
Visible	257	Multi-Purpose Bldg MP Hall Staff RR	Manual	7/30/2025 6:20:36 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	252	Multi-Purpose Bldg MP Room	Manual	7/30/2025 6:21:58 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	251	Multi-Purpose Bldg MP Room	Manual	7/30/2025 6:22:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	260	Multi-Purpose Bldg MP Stage	Manual	7/30/2025 6:20:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	195	Portables Classroom 25	Manual	7/30/2025 6:22:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	196	Portables Classroom 26	Manual	7/30/2025 6:22:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	197	Portables Classroom 27	Manual	7/30/2025 6:22:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	198	Portables Classroom 28	Manual	7/30/2025 6:22:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	199	Portables Classroom 29	Manual	7/30/2025 6:22:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	194	Portables Computer Room 24	Manual	7/30/2025 6:22:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	193	Portables Library Room 23	Manual	7/30/2025 6:22:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	192	Portables Library Room 23	Manual	7/30/2025 6:22:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	189	Portables North Exterior	Manual	7/30/2025 6:21:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	191	Portables West Exterior	Manual	7/30/2025 6:21:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	190	Portables West Exterior	Manual	7/30/2025 6:21:20 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	205	Restroom A Bldg Boys Restroom	Manual	7/30/2025 6:20:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	204	Restroom A Bldg East Exterior	Manual	7/30/2025 6:21:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	206	Restroom A Bldg Girls Restroom	Manual	7/30/2025 6:20:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	211	Restroom B Bldg Boys Restroom	Manual	7/30/2025 6:20:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	210	Restroom B Bldg East Exterior	Manual	7/30/2025 6:20:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible	212	Restroom B Bldg Girls Restroom	Manual	7/30/2025 6:20:48 AM
		Visual inspection	Passed (Manual)	
Visible	219	Restroom C Bldg Boys Restroom	Manual	7/30/2025 6:20:40 AM
		Visual inspection	Passed (Manual)	
Audible	218	Restroom C Bldg East Exterior	Manual	7/30/2025 6:20:39 AM
		Visual inspection	Passed (Manual)	
Visible	220	Restroom C Bldg Girls Restroom	Manual	7/30/2025 6:20:41 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	082	Rooms 10-12 Bldg Classroom 11	Manual	7/30/2025 6:22:49 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	083	Rooms 10-12 Bldg Classroom 12	Manual	7/30/2025 6:22:48 AM
		Visual inspection	Passed (Manual)	
Audible	080	Rooms 10-12 Bldg South Exterior	Manual	7/30/2025 6:21:31 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	081	Rooms 10-12 Bldg Staff Room 10	Manual	7/30/2025 6:22:51 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	034	Rooms 1-2 Bldg Classroom 1	Manual	7/30/2025 6:21:55 AM
		Visual inspection	Passed (Manual)	
Visible	036	Rooms 1-2 Bldg Classroom 1 RR	Manual	7/30/2025 6:21:39 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	035	Rooms 1-2 Bldg Classroom 2	Manual	7/30/2025 6:21:53 AM
		Visual inspection	Passed (Manual)	
Visible	037	Rooms 1-2 Bldg Classroom 2 RR	Manual	7/30/2025 6:21:36 AM
		Visual inspection	Passed (Manual)	
Audible	033	Rooms 1-2 Bldg North Exterior	Manual	7/30/2025 6:21:41 AM
		Visual inspection	Passed (Manual)	
Audible	032	Rooms 1-2 Bldg South Exterior	Manual	7/30/2025 6:21:42 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	091	Rooms 13-15 Bldg Classroom 13	Manual	7/30/2025 6:22:46 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	092	Rooms 13-15 Bldg Classroom 14	Manual	7/30/2025 6:22:45 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	093	Rooms 13-15 Bldg Classroom 15	Manual	7/30/2025 6:22:43 AM
		Visual inspection	Passed (Manual)	
Audible	090	Rooms 13-15 Bldg South Exterior	Manual	7/30/2025 6:21:29 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	110	Rooms 16-18 Bldg Classroom 16	Manual	7/30/2025 6:22:42 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	111	Rooms 16-18 Bldg Classroom 17	Manual	7/30/2025 6:22:40 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	112	Rooms 16-18 Bldg Classroom 18	Manual	7/30/2025 6:22:39 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	109	Rooms 16-18 Bldg South Exterior	Manual	7/30/2025 6:21:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	144	Rooms 19-22 Bldg Classroom 19	Manual	7/30/2025 6:22:36 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	145	Rooms 19-22 Bldg Classroom 20	Manual	7/30/2025 6:22:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	146	Rooms 19-22 Bldg Classroom 21	Manual	7/30/2025 6:22:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	147	Rooms 19-22 Bldg Classroom 22	Manual	7/30/2025 6:22:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	143	Rooms 19-22 Bldg South Exterior	Manual	7/30/2025 6:21:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	142	Rooms 19-22 Bldg South Exterior	Manual	7/30/2025 6:21:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	055	Rooms 3-6 Bldg Classroom 3	Manual	7/30/2025 6:23:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	056	Rooms 3-6 Bldg Classroom 4	Manual	7/30/2025 6:23:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	057	Rooms 3-6 Bldg Classroom 5	Manual	7/30/2025 6:23:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	058	Rooms 3-6 Bldg Classroom 6	Manual	7/30/2025 6:22:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	054	Rooms 3-6 Bldg South Exterior	Manual	7/30/2025 6:21:35 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	069	Rooms 7-9 Bldg Classroom 7	Manual	7/30/2025 6:22:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	070	Rooms 7-9 Bldg Classroom 8	Manual	7/30/2025 6:22:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	071	Rooms 7-9 Bldg Classroom 9	Manual	7/30/2025 6:22:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	073	Rooms 7-9 Bldg Electrical Room	Manual	7/30/2025 6:22:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible	068	Rooms 7-9 Bldg South Exterior	Manual	7/30/2025 6:21:33 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	072	Rooms 7-9 Bldg Speech Room	Manual	7/30/2025 6:21:32 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Remote Annunciator	001	Admin Bldg Copy Area	Manual	7/30/2025 9:04:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Portables Classroom 26 Closet - P.E. "D"	Manual	7/30/2025 8:00:19 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Restroom C Bldg Custodial Office - P.E. "E"	Manual	7/30/2025 8:00:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Restroom C Bldg Custodial Office - P.E. "F"	Manual	7/30/2025 7:15:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Rooms 19-22 Bldg Classroom 20 Closet - P.E. "C"	Manual	7/30/2025 7:59:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Fire Alarm Panel		Rooms 7-9 Bldg Telecom Rm by Rm 7	Manual	7/30/2025 7:15:35 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Rooms 7-9 Bldg Telecom Rm by Rm 7 - P.E. "B"	Manual	7/30/2025 9:04:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Rooms 7-9 Bldg Telecom Rm by Rm 7 - P.E. "Master"	Manual	7/30/2025 9:04:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Manual Pull Station	2-141 002	Admin Bldg Copy Area	Manual	7/30/2025 6:44:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-008 004	Admin Bldg Copy Area	Manual	7/30/2025 6:42:39 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-009 006	Admin Bldg Nurse Restroom	Manual	7/30/2025 6:44:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-010 005	Admin Bldg Nurse Room	Manual	7/30/2025 6:44:35 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-006 009	Admin Bldg Office Storage 1	Manual	7/30/2025 6:40:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-007 010	Admin Bldg Office Storage 2	Manual	7/30/2025 6:41:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-005 007	Admin Bldg Principals Office	Manual	7/30/2025 6:43:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-012 003	Admin Bldg Reception	Manual	7/30/2025 6:42:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-013 008	Admin Bldg Work Room	Manual	7/30/2025 6:41:44 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-376 247	Multi-Purpose Bldg Attic O/S Bridges Off	Manual	7/30/2025 8:39:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-288 243	Multi-Purpose Bldg Kitchen	Manual	7/30/2025 8:26:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-287 242	Multi-Purpose Bldg Kitchen Storage	Manual	7/30/2025 7:06:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-144 223	Multi-Purpose Bldg Kitchen West	Manual	7/30/2025 7:07:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-281 227	Multi-Purpose Bldg MP Bridges Hallway	Manual	7/30/2025 6:46:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-282 228	Multi-Purpose Bldg MP Bridges Office	Manual	7/30/2025 6:47:32 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-142 221	Multi-Purpose Bldg MP Hall East Exit	Manual	7/30/2025 6:50:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-280 230	Multi-Purpose Bldg MP Hall Public RR	Manual	7/30/2025 6:48:38 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-279 229	Multi-Purpose Bldg MP Hall Staff RR	Manual	7/30/2025 6:46:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-283 224	Multi-Purpose Bldg MP Hallway	Manual	7/30/2025 6:45:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-284 225	Multi-Purpose Bldg MP Hallway	Manual	7/30/2025 6:49:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-285 226	Multi-Purpose Bldg MP Hallway	Manual	7/30/2025 6:49:28 AM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Manual Pull Station	2-143 222	Multi-Purpose Bldg MP Rm SE Exit	Manual	7/30/2025 7:01:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-380 249	Multi-Purpose Bldg MP Roof East AC-2	Manual	7/30/2025 6:58:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-379 248	Multi-Purpose Bldg MP Roof West AC-1	Manual	7/30/2025 6:58:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-291 231	Multi-Purpose Bldg MP Room	Manual	7/30/2025 6:59:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-293 234	Multi-Purpose Bldg MP Room	Manual	7/30/2025 7:00:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-294 235	Multi-Purpose Bldg MP Room	Manual	7/30/2025 7:00:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-295 236	Multi-Purpose Bldg MP Room	Manual	7/30/2025 7:04:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-292 233	Multi-Purpose Bldg MP Room	Manual	7/30/2025 7:04:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-290 232	Multi-Purpose Bldg MP Room	Manual	7/30/2025 7:05:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-286 241	Multi-Purpose Bldg MP Storage 1	Manual	7/30/2025 8:28:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-298 238	Multi-Purpose Bldg Stage	Manual	7/30/2025 7:02:42 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-297 239	Multi-Purpose Bldg Stage	Manual	7/30/2025 7:03:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-299 237	Multi-Purpose Bldg Stage Steps East	Manual	7/30/2025 7:01:42 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-296 240	Multi-Purpose Bldg Stage Wheelchair Lift W	Manual	7/30/2025 8:29:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-140 179	Portables Attic Classroom 25	Manual	7/30/2025 9:18:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-140 178	Portables Attic Classroom 25	Manual	7/30/2025 9:18:32 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-140 177	Portables Attic Classroom 25	Manual	7/30/2025 9:18:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-139 180	Portables Attic Classroom 26	Manual	7/30/2025 9:21:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-139 181	Portables Attic Classroom 26	Manual	7/30/2025 9:21:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-139 182	Portables Attic Classroom 26	Manual	7/30/2025 9:21:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-138 184	Portables Attic Classroom 27	Manual	7/30/2025 9:11:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-138 183	Portables Attic Classroom 27	Manual	7/30/2025 9:12:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-137 185	Portables Attic Classroom 28	Manual	7/30/2025 9:03:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-137 186	Portables Attic Classroom 28	Manual	7/30/2025 9:04:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-136 187	Portables Attic Classroom 29	Manual	7/30/2025 8:58:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-136 188	Portables Attic Classroom 29	Manual	7/30/2025 8:58:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-134 176	Portables Attic Computer Rm 24	Manual	7/30/2025 9:59:38 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-134 175	Portables Attic Computer Rm 24	Manual	7/30/2025 9:59:39 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-134 174	Portables Attic Computer Rm 24	Manual	7/30/2025 9:59:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-135 172	Portables Attic Library Rm 23	Manual	7/30/2025 9:53:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-135 171	Portables Attic Library Rm 23	Manual	7/30/2025 9:53:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-135 173	Portables Attic Library Rm 23	Manual	7/30/2025 9:53:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-099 156	Portables Classroom 25	Manual	7/30/2025 9:15:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-100 159	Portables Classroom 25	Manual	7/30/2025 9:16:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-101 158	Portables Classroom 25	Manual	7/30/2025 9:16:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-098 157	Portables Classroom 25	Manual	7/30/2025 9:16:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-094 162	Portables Classroom 26	Manual	7/30/2025 9:21:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-095 163	Portables Classroom 26	Manual	7/30/2025 9:21:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-097 161	Portables Classroom 26	Manual	7/30/2025 9:21:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-096 160	Portables Classroom 26	Manual	7/30/2025 9:21:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-093 164	Portables Classroom 26 Closet	Manual	7/30/2025 9:21:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-090 165	Portables Classroom 27	Manual	7/30/2025 9:06:54 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-091 166	Portables Classroom 27	Manual	7/30/2025 9:07:32 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-088 167	Portables Classroom 28	Manual	7/30/2025 9:01:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-089 168	Portables Classroom 28	Manual	7/30/2025 9:01:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-087 169	Portables Classroom 29	Manual	7/30/2025 7:32:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-086 170	Portables Classroom 29	Manual	7/30/2025 7:32:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-078 154	Portables Computer Room 24	Manual	7/30/2025 7:39:35 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-079 155	Portables Computer Room 24	Manual	7/30/2025 9:59:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-081 153	Portables Computer Room 24	Manual	7/30/2025 9:59:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-080 152	Portables Computer Room 24	Manual	7/30/2025 9:59:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-082 151	Portables Library Room 23	Manual	7/30/2025 9:53:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-085 150	Portables Library Room 23	Manual	7/30/2025 9:53:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-084 149	Portables Library Room 23	Manual	7/30/2025 9:53:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-083 148	Portables Library Room 23	Manual	7/30/2025 9:53:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-054 200	Restroom A Bldg Boys Restroom	Manual	7/30/2025 7:35:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-053 201	Restroom A Bldg Custodian Closet	Manual	7/30/2025 7:34:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-051 202	Restroom A Bldg Girls Restroom	Manual	7/30/2025 7:33:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-052 203	Restroom A Bldg RR Plumb Chase	Manual	7/30/2025 10:08:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-076 207	Restroom B Bldg Boys Restroom	Manual	7/30/2025 6:35:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-075 208	Restroom B Bldg Girls Restroom	Manual	7/30/2025 6:34:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-074 209	Restroom B Bldg RR Plumb Chase	Manual	7/30/2025 8:46:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-254 213	Restroom C Bldg Boys Restroom	Manual	7/30/2025 7:17:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-255 216	Restroom C Bldg Boys RR Plumb Chase	Manual	7/30/2025 8:56:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-256 214	Restroom C Bldg Custodial Office	Manual	7/30/2025 7:16:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-253 215	Restroom C Bldg Girls Restroom	Manual	7/30/2025 7:15:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-252 217	Restroom C Bldg Girls RR Plumb Chase	Manual	7/30/2025 9:37:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-303 076	Rooms 10-12 Bldg Classroom 11	Manual	7/30/2025 6:37:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-302 077	Rooms 10-12 Bldg Classroom 11	Manual	7/30/2025 6:38:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-300 079	Rooms 10-12 Bldg Classroom 12	Manual	7/30/2025 6:36:19 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-301 078	Rooms 10-12 Bldg Classroom 12	Manual	7/30/2025 6:36:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-305 074	Rooms 10-12 Bldg Staff Room 10	Manual	7/30/2025 6:39:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-304 075	Rooms 10-12 Bldg Staff Room 10	Manual	7/30/2025 6:39:54 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-032 019	Rooms 1-2 Bldg Classroom 1	Manual	7/30/2025 8:07:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-030 020	Rooms 1-2 Bldg Classroom 1	Manual	7/30/2025 8:08:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-033 022	Rooms 1-2 Bldg Classroom 1	Manual	7/30/2025 8:10:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-031 021	Rooms 1-2 Bldg Classroom 1	Manual	7/30/2025 8:10:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-029 023	Rooms 1-2 Bldg Classroom 1 RR	Manual	7/30/2025 8:11:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-021 026	Rooms 1-2 Bldg Classroom 2	Manual	7/30/2025 7:47:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-023 025	Rooms 1-2 Bldg Classroom 2	Manual	7/30/2025 8:04:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-024 027	Rooms 1-2 Bldg Classroom 2	Manual	7/30/2025 8:05:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-022 024	Rooms 1-2 Bldg Classroom 2	Manual	7/30/2025 8:07:35 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-026 030	Rooms 1-2 Bldg Classroom 2 Closet	Manual	7/30/2025 8:04:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-025 029	Rooms 1-2 Bldg Classroom 2 Closet	Manual	7/30/2025 8:04:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-028 028	Rooms 1-2 Bldg Classroom 2 RR	Manual	7/30/2025 8:04:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-027 031	Rooms 1-2 Bldg Outside Closet Rm 2	Manual	7/30/2025 10:14:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-277 084	Rooms 13-15 Bldg Classroom 13	Manual	7/30/2025 7:11:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-278 085	Rooms 13-15 Bldg Classroom 13	Manual	7/30/2025 7:11:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-275 086	Rooms 13-15 Bldg Classroom 14	Manual	7/30/2025 7:14:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-276 087	Rooms 13-15 Bldg Classroom 14	Manual	7/30/2025 7:14:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-273 088	Rooms 13-15 Bldg Classroom 15	Manual	7/30/2025 7:14:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-274 089	Rooms 13-15 Bldg Classroom 15	Manual	7/30/2025 7:14:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-270 097	Rooms 16-18 Bldg Classroom 16	Manual	7/30/2025 7:26:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-271 096	Rooms 16-18 Bldg Classroom 16	Manual	7/30/2025 7:26:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-268 095	Rooms 16-18 Bldg Classroom 16	Manual	7/30/2025 7:26:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-269 098	Rooms 16-18 Bldg Classroom 16	Manual	7/30/2025 7:27:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-267 094	Rooms 16-18 Bldg Classroom 16	Manual	7/30/2025 7:27:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-262 099	Rooms 16-18 Bldg Classroom 17	Manual	7/30/2025 7:23:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-265 102	Rooms 16-18 Bldg Classroom 17	Manual	7/30/2025 7:24:19 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-266 101	Rooms 16-18 Bldg Classroom 17	Manual	7/30/2025 7:24:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-264 103	Rooms 16-18 Bldg Classroom 17	Manual	7/30/2025 7:24:54 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-263 100	Rooms 16-18 Bldg Classroom 17	Manual	7/30/2025 7:25:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-260 107	Rooms 16-18 Bldg Classroom 18	Manual	7/30/2025 7:20:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-261 106	Rooms 16-18 Bldg Classroom 18	Manual	7/30/2025 7:20:36 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-258 105	Rooms 16-18 Bldg Classroom 18	Manual	7/30/2025 7:21:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-259 108	Rooms 16-18 Bldg Classroom 18	Manual	7/30/2025 7:21:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-257 104	Rooms 16-18 Bldg Classroom 18	Manual	7/30/2025 7:22:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-131 130	Rooms 19-22 Bldg Attic Classroom 19	Manual	7/30/2025 9:47:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-131 131	Rooms 19-22 Bldg Attic Classroom 19	Manual	7/30/2025 9:47:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-131 132	Rooms 19-22 Bldg Attic Classroom 19	Manual	7/30/2025 9:47:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-130 133	Rooms 19-22 Bldg Attic Classroom 20	Manual	7/30/2025 9:42:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-130 134	Rooms 19-22 Bldg Attic Classroom 20	Manual	7/30/2025 9:42:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-130 135	Rooms 19-22 Bldg Attic Classroom 20	Manual	7/30/2025 9:42:47 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-132 138	Rooms 19-22 Bldg Attic Classroom 21	Manual	7/30/2025 9:37:34 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-132 137	Rooms 19-22 Bldg Attic Classroom 21	Manual	7/30/2025 9:37:43 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-132 136	Rooms 19-22 Bldg Attic Classroom 21	Manual	7/30/2025 9:37:45 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-133 139	Rooms 19-22 Bldg Attic Classroom 22	Manual	7/30/2025 9:31:43 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-133 140	Rooms 19-22 Bldg Attic Classroom 22	Manual	7/30/2025 9:31:46 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-133 141	Rooms 19-22 Bldg Attic Classroom 22	Manual	7/30/2025 9:31:47 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-064 114	Rooms 19-22 Bldg Classroom 19	Manual	7/30/2025 9:47:52 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-065 115	Rooms 19-22 Bldg Classroom 19	Manual	7/30/2025 9:47:53 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-062 116	Rooms 19-22 Bldg Classroom 19	Manual	7/30/2025 9:47:55 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-063 113	Rooms 19-22 Bldg Classroom 19	Manual	7/30/2025 9:47:58 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-061 118	Rooms 19-22 Bldg Classroom 20	Manual	7/30/2025 9:42:49 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-058 119	Rooms 19-22 Bldg Classroom 20	Manual	7/30/2025 9:42:52 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-059 120	Rooms 19-22 Bldg Classroom 20	Manual	7/30/2025 9:42:53 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-060 117	Rooms 19-22 Bldg Classroom 20	Manual	7/30/2025 9:42:55 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-057 121	Rooms 19-22 Bldg Classroom 20 Closet	Manual	7/30/2025 9:42:51 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-067 125	Rooms 19-22 Bldg Classroom 21	Manual	7/30/2025 9:37:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-066 124	Rooms 19-22 Bldg Classroom 21	Manual	7/30/2025 9:38:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-069 123	Rooms 19-22 Bldg Classroom 21	Manual	7/30/2025 9:38:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-068 122	Rooms 19-22 Bldg Classroom 21	Manual	7/30/2025 9:38:16 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-071 126	Rooms 19-22 Bldg Classroom 22	Manual	7/30/2025 9:21:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-070 127	Rooms 19-22 Bldg Classroom 22	Manual	7/30/2025 9:31:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-072 129	Rooms 19-22 Bldg Classroom 22	Manual	7/30/2025 9:31:33 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-073 128	Rooms 19-22 Bldg Classroom 22	Manual	7/30/2025 9:31:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-038 040	Rooms 3-6 Bldg Classroom 3	Manual	7/30/2025 7:44:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-036 038	Rooms 3-6 Bldg Classroom 3	Manual	7/30/2025 7:44:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-035 039	Rooms 3-6 Bldg Classroom 3	Manual	7/30/2025 7:45:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-037 041	Rooms 3-6 Bldg Classroom 3	Manual	7/30/2025 7:45:32 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-042 042	Rooms 3-6 Bldg Classroom 4	Manual	7/30/2025 7:41:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-040 045	Rooms 3-6 Bldg Classroom 4	Manual	7/30/2025 7:42:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-039 044	Rooms 3-6 Bldg Classroom 4	Manual	7/30/2025 7:42:33 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-041 043	Rooms 3-6 Bldg Classroom 4	Manual	7/30/2025 7:43:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-044 046	Rooms 3-6 Bldg Classroom 5	Manual	7/30/2025 7:39:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-043 047	Rooms 3-6 Bldg Classroom 5	Manual	7/30/2025 7:40:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-045 048	Rooms 3-6 Bldg Classroom 5	Manual	7/30/2025 7:40:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-046 049	Rooms 3-6 Bldg Classroom 5	Manual	7/30/2025 8:16:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-050 053	Rooms 3-6 Bldg Classroom 6	Manual	7/30/2025 7:37:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-048 050	Rooms 3-6 Bldg Classroom 6	Manual	7/30/2025 7:37:20 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-047 051	Rooms 3-6 Bldg Classroom 6	Manual	7/30/2025 7:37:35 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-049 052	Rooms 3-6 Bldg Classroom 6	Manual	7/30/2025 7:38:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-015 059	Rooms 7-9 Bldg Classroom 7	Manual	7/30/2025 6:32:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-014 060	Rooms 7-9 Bldg Classroom 7	Manual	7/30/2025 6:32:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-017 061	Rooms 7-9 Bldg Classroom 8	Manual	7/30/2025 6:32:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-016 062	Rooms 7-9 Bldg Classroom 8	Manual	7/30/2025 6:32:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-019 064	Rooms 7-9 Bldg Classroom 9	Manual	7/30/2025 6:32:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-018 063	Rooms 7-9 Bldg Classroom 9	Manual	7/30/2025 6:32:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-003 066	Rooms 7-9 Bldg Electrical Room	Manual	7/30/2025 8:15:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-004 065	Rooms 7-9 Bldg Speech Room	Manual	7/30/2025 8:14:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-002 067	Rooms 7-9 Bldg Telecom Rm by Rm 7	Manual	7/30/2025 6:32:35 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-378 246	Multi-Purpose Bldg Attic MP Hall	Manual	7/30/2025 8:39:09 AM
	Comment:	No access		
Heat Detector - Restorable Spot	2-378 245	Multi-Purpose Bldg Attic MP Hall	Manual	7/30/2025 8:39:22 AM
	Comment:	No access		
Heat Detector - Restorable Spot	2-289 244	Multi-Purpose Bldg Kitchen	Manual	7/30/2025 10:00:09 AM

Device/Equipment Details

Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Audible					
054	Rooms 3-6 Bldg South Exterior				
068	Rooms 7-9 Bldg South Exterior				
080	Rooms 10-12 Bldg South Exterior				
090	Rooms 13-15 Bldg South Exterior				
109	Rooms 16-18 Bldg South Exterior				
142	Rooms 19-22 Bldg South Exterior				
143	Rooms 19-22 Bldg South Exterior				
189	Portables North Exterior				
190	Portables West Exterior				
191	Portables West Exterior				
204	Restroom A Bldg East Exterior				
210	Restroom B Bldg East Exterior				
218	Restroom C Bldg East Exterior				
032	Rooms 1-2 Bldg South Exterior				
033	Rooms 1-2 Bldg North Exterior				
Audible And Visible					
055	Rooms 3-6 Bldg Classroom 3				
056	Rooms 3-6 Bldg Classroom 4				
057	Rooms 3-6 Bldg Classroom 5				
058	Rooms 3-6 Bldg Classroom 6				
069	Rooms 7-9 Bldg Classroom 7				
070	Rooms 7-9 Bldg Classroom 8				
071	Rooms 7-9 Bldg Classroom 9				
073	Rooms 7-9 Bldg Electrical Room				
081	Rooms 10-12 Bldg Staff Room 10				
082	Rooms 10-12 Bldg Classroom 11				
083	Rooms 10-12 Bldg Classroom 12				
091	Rooms 13-15 Bldg Classroom 13				
092	Rooms 13-15 Bldg Classroom 14				
093	Rooms 13-15 Bldg Classroom 15				
110	Rooms 16-18 Bldg Classroom 16				
111	Rooms 16-18 Bldg Classroom 17				
112	Rooms 16-18 Bldg Classroom 18				
144	Rooms 19-22 Bldg Classroom 19				
145	Rooms 19-22 Bldg Classroom 20				
146	Rooms 19-22 Bldg Classroom 21				
147	Rooms 19-22 Bldg Classroom 22				
192	Portables Library Room 23				
193	Portables Library Room 23				
194	Portables Computer Room 24				
195	Portables Classroom 25				
196	Portables Classroom 26				
197	Portables Classroom 27				
198	Portables Classroom 28				
199	Portables Classroom 29				
250	Multi-Purpose Bldg MP Hall				
251	Multi-Purpose Bldg MP Room				
252	Multi-Purpose Bldg MP Room				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
253	Multi-Purpose Bldg Kitchen				
011	Admin Bldg Reception				
012	Admin Bldg Work Room				
034	Rooms 1-2 Bldg Classroom 1				
035	Rooms 1-2 Bldg Classroom 2				
Visible					
072	Rooms 7-9 Bldg Speech Room				
205	Restroom A Bldg Boys Restroom				
206	Restroom A Bldg Girls Restroom				
211	Restroom B Bldg Boys Restroom				
212	Restroom B Bldg Girls Restroom				
219	Restroom C Bldg Boys Restroom				
220	Restroom C Bldg Girls Restroom				
254	Multi-Purpose Bldg MP Hall				
255	Multi-Purpose Bldg MP Bridges Hall				
256	Multi-Purpose Bldg MP Bridges Office				
257	Multi-Purpose Bldg MP Hall Staff RR				
258	Multi-Purpose Bldg MP Hall Public RR				
259	Multi-Purpose Bldg MP Hall				
260	Multi-Purpose Bldg MP Stage				
013	Admin Bldg Copy Area				
014	Admin Bldg Nurse Room				
015	Admin Bldg Nurse Restroom				
016	Admin Bldg Principals Office				
017	Admin Bldg Office Storage 1				
018	Admin Bldg Office Storage 2				
036	Rooms 1-2 Bldg Classroom 1 RR				
037	Rooms 1-2 Bldg Classroom 2 RR				

Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Remote Annunciator					
001	Admin Bldg Copy Area				

NAC Power Extender Panel

	Portables Classroom 26 Closet - P.E. "D"				
	Restroom C Bldg Custodial Office - P.E. "E"				
	Restroom C Bldg Custodial Office - P.E. "F"				
	Rooms 19-22 Bldg Classroom 20 Closet - P.E. "C"				
	Rooms 7-9 Bldg Telecom Rm by Rm 7 - P.E. "Master"				
	Rooms 7-9 Bldg Telecom Rm by Rm 7 - P.E. "B"				

Fire Alarm Panel

	Rooms 7-9 Bldg Telecom Rm by Rm 7				
--	-----------------------------------	--	--	--	--

Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Smoke Detector - General					
2-047 051	Rooms 3-6 Bldg Classroom 6				
2-049 052	Rooms 3-6 Bldg Classroom 6				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-050 053	Rooms 3-6 Bldg Classroom 6				
2-015 059	Rooms 7-9 Bldg Classroom 7				
2-014 060	Rooms 7-9 Bldg Classroom 7				
2-017 061	Rooms 7-9 Bldg Classroom 8				
2-016 062	Rooms 7-9 Bldg Classroom 8				
2-018 063	Rooms 7-9 Bldg Classroom 9				
2-019 064	Rooms 7-9 Bldg Classroom 9				
2-004 065	Rooms 7-9 Bldg Speech Room				
2-003 066	Rooms 7-9 Bldg Electrical Room				
2-002 067	Rooms 7-9 Bldg Telecom Rm by Rm 7				
2-305 074	Rooms 10-12 Bldg Staff Room 10				
2-304 075	Rooms 10-12 Bldg Staff Room 10				
2-303 076	Rooms 10-12 Bldg Classroom 11				
2-302 077	Rooms 10-12 Bldg Classroom 11				
2-301 078	Rooms 10-12 Bldg Classroom 12				
2-300 079	Rooms 10-12 Bldg Classroom 12				
2-277 084	Rooms 13-15 Bldg Classroom 13				
2-278 085	Rooms 13-15 Bldg Classroom 13				
2-275 086	Rooms 13-15 Bldg Classroom 14				
2-276 087	Rooms 13-15 Bldg Classroom 14				
2-273 088	Rooms 13-15 Bldg Classroom 15				
2-274 089	Rooms 13-15 Bldg Classroom 15				
2-267 094	Rooms 16-18 Bldg Classroom 16				
2-268 095	Rooms 16-18 Bldg Classroom 16				
2-271 096	Rooms 16-18 Bldg Classroom 16				
2-270 097	Rooms 16-18 Bldg Classroom 16				
2-269 098	Rooms 16-18 Bldg Classroom 16				
2-262 099	Rooms 16-18 Bldg Classroom 17				
2-263 100	Rooms 16-18 Bldg Classroom 17				
2-266 101	Rooms 16-18 Bldg Classroom 17				
2-265 102	Rooms 16-18 Bldg Classroom 17				
2-264 103	Rooms 16-18 Bldg Classroom 17				
2-257 104	Rooms 16-18 Bldg Classroom 18				
2-258 105	Rooms 16-18 Bldg Classroom 18				
2-261 106	Rooms 16-18 Bldg Classroom 18				
2-260 107	Rooms 16-18 Bldg Classroom 18				
2-259 108	Rooms 16-18 Bldg Classroom 18				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-063 113	Rooms 19-22 Bldg Classroom 19				
2-064 114	Rooms 19-22 Bldg Classroom 19				
2-065 115	Rooms 19-22 Bldg Classroom 19				
2-062 116	Rooms 19-22 Bldg Classroom 19				
2-060 117	Rooms 19-22 Bldg Classroom 20				
2-061 118	Rooms 19-22 Bldg Classroom 20				
2-058 119	Rooms 19-22 Bldg Classroom 20				
2-059 120	Rooms 19-22 Bldg Classroom 20				
2-057 121	Rooms 19-22 Bldg Classroom 20 Closet				
2-068 122	Rooms 19-22 Bldg Classroom 21				
2-069 123	Rooms 19-22 Bldg Classroom 21				
2-066 124	Rooms 19-22 Bldg Classroom 21				
2-067 125	Rooms 19-22 Bldg Classroom 21				
2-071 126	Rooms 19-22 Bldg Classroom 22				
2-070 127	Rooms 19-22 Bldg Classroom 22				
2-073 128	Rooms 19-22 Bldg Classroom 22				
2-072 129	Rooms 19-22 Bldg Classroom 22				
2-083 148	Portables Library Room 23				
2-084 149	Portables Library Room 23				
2-085 150	Portables Library Room 23				
2-082 151	Portables Library Room 23				
2-080 152	Portables Computer Room 24				
2-081 153	Portables Computer Room 24				
2-078 154	Portables Computer Room 24				
2-079 155	Portables Computer Room 24				
2-099 156	Portables Classroom 25				
2-098 157	Portables Classroom 25				
2-101 158	Portables Classroom 25				
2-100 159	Portables Classroom 25				
2-096 160	Portables Classroom 26				
2-097 161	Portables Classroom 26				
2-094 162	Portables Classroom 26				
2-095 163	Portables Classroom 26				
2-093 164	Portables Classroom 26 Closet				
2-090 165	Portables Classroom 27				
2-091 166	Portables Classroom 27				
2-088 167	Portables Classroom 28				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-089 168	Portables Classroom 28				
2-087 169	Portables Classroom 29				
2-086 170	Portables Classroom 29				
2-054 200	Restroom A Bldg Boys Restroom				
2-053 201	Restroom A Bldg Custodian Closet				
2-051 202	Restroom A Bldg Girls Restroom				
2-076 207	Restroom B Bldg Boys Restroom				
2-075 208	Restroom B Bldg Girls Restroom				
2-254 213	Restroom C Bldg Boys Restroom				
2-256 214	Restroom C Bldg Custodial Office				
2-253 215	Restroom C Bldg Girls Restroom				
2-283 224	Multi-Purpose Bldg MP Hallway				
2-284 225	Multi-Purpose Bldg MP Hallway				
2-285 226	Multi-Purpose Bldg MP Hallway				
2-281 227	Multi-Purpose Bldg MP Bridges Hallway				
2-282 228	Multi-Purpose Bldg MP Bridges Office				
2-279 229	Multi-Purpose Bldg MP Hall Staff RR				
2-280 230	Multi-Purpose Bldg MP Hall Public RR				
2-291 231	Multi-Purpose Bldg MP Room				
2-290 232	Multi-Purpose Bldg MP Room				
2-292 233	Multi-Purpose Bldg MP Room				
2-293 234	Multi-Purpose Bldg MP Room				
2-294 235	Multi-Purpose Bldg MP Room				
2-295 236	Multi-Purpose Bldg MP Room				
2-299 237	Multi-Purpose Bldg Stage Steps East				
2-298 238	Multi-Purpose Bldg Stage				
2-297 239	Multi-Purpose Bldg Stage				
2-296 240	Multi-Purpose Bldg Stage Wheelchair Lift W				
2-286 241	Multi-Purpose Bldg MP Storage 1				
2-287 242	Multi-Purpose Bldg Kitchen Storage				
2-012 003	Admin Bldg Reception				
2-008 004	Admin Bldg Copy Area				
2-010 005	Admin Bldg Nurse Room				
2-009 006	Admin Bldg Nurse Restroom				
2-005 007	Admin Bldg Principals Office				
2-013 008	Admin Bldg Work Room				
2-006 009	Admin Bldg Office Storage 1				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-007 010	Admin Bldg Office Storage 2				
2-032 019	Rooms 1-2 Bldg Classroom 1				
2-030 020	Rooms 1-2 Bldg Classroom 1				
2-031 021	Rooms 1-2 Bldg Classroom 1				
2-033 022	Rooms 1-2 Bldg Classroom 1				
2-029 023	Rooms 1-2 Bldg Classroom 1 RR				
2-022 024	Rooms 1-2 Bldg Classroom 2				
2-023 025	Rooms 1-2 Bldg Classroom 2				
2-021 026	Rooms 1-2 Bldg Classroom 2				
2-024 027	Rooms 1-2 Bldg Classroom 2				
2-028 028	Rooms 1-2 Bldg Classroom 2 RR				
2-025 029	Rooms 1-2 Bldg Classroom 2 Closet				
2-026 030	Rooms 1-2 Bldg Classroom 2 Closet				
2-036 038	Rooms 3-6 Bldg Classroom 3				
2-035 039	Rooms 3-6 Bldg Classroom 3				
2-038 040	Rooms 3-6 Bldg Classroom 3				
2-037 041	Rooms 3-6 Bldg Classroom 3				
2-042 042	Rooms 3-6 Bldg Classroom 4				
2-041 043	Rooms 3-6 Bldg Classroom 4				
2-039 044	Rooms 3-6 Bldg Classroom 4				
2-040 045	Rooms 3-6 Bldg Classroom 4				
2-044 046	Rooms 3-6 Bldg Classroom 5				
2-043 047	Rooms 3-6 Bldg Classroom 5				
2-045 048	Rooms 3-6 Bldg Classroom 5				
2-046 049	Rooms 3-6 Bldg Classroom 5				
2-048 050	Rooms 3-6 Bldg Classroom 6				
Heat Detector - Restorable Spot					
2-131 130	Rooms 19-22 Bldg Attic Classroom 19				
2-131 131	Rooms 19-22 Bldg Attic Classroom 19				
2-131 132	Rooms 19-22 Bldg Attic Classroom 19				
2-130 133	Rooms 19-22 Bldg Attic Classroom 20				
2-130 134	Rooms 19-22 Bldg Attic Classroom 20				
2-130 135	Rooms 19-22 Bldg Attic Classroom 20				
2-132 136	Rooms 19-22 Bldg Attic Classroom 21				
2-132 137	Rooms 19-22 Bldg Attic Classroom 21				
2-132 138	Rooms 19-22 Bldg Attic Classroom 21				
2-133 139	Rooms 19-22 Bldg Attic Classroom 22				
2-133 140	Rooms 19-22 Bldg Attic Classroom 22				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-133 141	Rooms 19-22 Bldg Attic Classroom 22				
2-135 171	Portables Attic Library Rm 23				
2-135 172	Portables Attic Library Rm 23				
2-135 173	Portables Attic Library Rm 23				
2-134 174	Portables Attic Computer Rm 24				
2-134 175	Portables Attic Computer Rm 24				
2-134 176	Portables Attic Computer Rm 24				
2-140 177	Portables Attic Classroom 25				
2-140 178	Portables Attic Classroom 25				
2-140 179	Portables Attic Classroom 25				
2-139 180	Portables Attic Classroom 26				
2-139 181	Portables Attic Classroom 26				
2-139 182	Portables Attic Classroom 26				
2-138 183	Portables Attic Classroom 27				
2-138 184	Portables Attic Classroom 27				
2-137 185	Portables Attic Classroom 28				
2-137 186	Portables Attic Classroom 28				
2-136 187	Portables Attic Classroom 29				
2-136 188	Portables Attic Classroom 29				
2-052 203	Restroom A Bldg RR Plumb Chase				
2-074 209	Restroom B Bldg RR Plumb Chase				
2-255 216	Restroom C Bldg Boys RR Plumb Chase				
2-252 217	Restroom C Bldg Girls RR Plumb Chase				
2-288 243	Multi-Purpose Bldg Kitchen				
2-289 244	Multi-Purpose Bldg Kitchen				
2-378 245	Multi-Purpose Bldg Attic MP Hall				
2-378 246	Multi-Purpose Bldg Attic MP Hall				
2-376 247	Multi-Purpose Bldg Attic O/S Bridges Off				
2-027 031	Rooms 1-2 Bldg Outside Closet Rm 2				
Manual Pull Station					
2-142 221	Multi-Purpose Bldg MP Hall East Exit				
2-143 222	Multi-Purpose Bldg MP Rm SE Exit				
2-144 223	Multi-Purpose Bldg Kitchen West				
2-141 002	Admin Bldg Copy Area				
Smoke Detector - Duct					
2-379 248	Multi-Purpose Bldg MP Roof West AC-1				
2-380 249	Multi-Purpose Bldg MP Roof East AC-2				