

# Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

CARMICHAEL ELEMENTARY

6141 SUTTER AVE  
CARMICHAEL, California 95608  
United States

This site has been inspected and tested in compliance with applicable standards.

Completed

Thursday, August 07, 2025

Test Session :04 Aug 2025 06:10 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD  
5320 HEMLOCK ST  
SACRAMENTO, California  
United States

TESTED BY

Riley Goyet  
Western States Fire Protection-  
Sacramento  
188 Cirby Way  
Roseville, CA 95678  
United States



# Inspection Summary

## Building Information

|                |                              |         |
|----------------|------------------------------|---------|
| PROPERTY       | CARMICHAEL ELEMENTARY        | CONTACT |
| ADDRESS        | 6141 SUTTER AVE              | PHONE   |
| CITY/STATE/ZIP | CARMICHAEL, California 95608 | MOBILE  |
| COUNTRY        | United States                | EMAIL   |

## Inspector Information

|         |   |                |                     |
|---------|---|----------------|---------------------|
| COMPANY | Western States Fire Protection-Sacramento | CONTACT        | Riley Goyet         |
| ADDRESS | 188 Cirby Way<br>Roseville, CA 95678      | LICENSE NUMBER |                     |
| COUNTRY | United States                             | PHONE          | +1 916-200-9514     |
|         |   | EMAIL          | riley.goyet@wsfp.us |


## Testing Summary

| EQUIPMENT TYPE               | TOTAL | TESTED    | PASSED    | FAILED |
|------------------------------|-------|-----------|-----------|--------|
| Alarm Notification Appliance | 145   | 145(100%) | 145(100%) | 0(0%)  |
| Fire Control Panel           | 2     | 2(100%)   | 2(100%)   | 0(0%)  |
| Initiating Device            | 263   | 253(96%)  | 253(96%)  | 0(0%)  |
| Power Supplies               | 9     | 9(100%)   | 9(100%)   | 0(0%)  |

## Certification

The equipment specified herein was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Thursday, August 07, 2025

ACCEPTED BY      08/07/2025  
  
Building Representative

  
TESTED BY      08/07/2025  
Riley Goyet  
Technician

# System Details

## Control Units

|                        |            |              |                                     |
|------------------------|------------|--------------|-------------------------------------|
| ADDRESS / SCAN ADDRESS |            | DESCRIPTION  | Rooms 11 13 Bldg Teleco Rm by Rm 11 |
| MANUFACTURER           | EST        | S/W VERSION  |                                     |
| MODEL                  |            | LAST UPDATE  |                                     |
| SERIAL NUMBER          |            | S/W LOCATION |                                     |
| INSTALL DATE           | 10/04/2023 |              |                                     |

## Primary Power

|                        |               |             |                                   |
|------------------------|---------------|-------------|-----------------------------------|
| ADDRESS / SCAN ADDRESS | / 052         | DESCRIPTION | Rms K1 & K2 Bldg Room K2 O S Strg |
| TYPE                   | Primary Power | PROTECTION  |                                   |
| NOMINAL VOLTAGE        |               | AMPS        |                                   |
| NOMINAL AMPS           |               | DISCONNECT  |                                   |
| LOCATION               |               |             |                                   |

|                        |               |             |                                     |
|------------------------|---------------|-------------|-------------------------------------|
| ADDRESS / SCAN ADDRESS | / 134         | DESCRIPTION | Rooms 3 8 Bldg Hall by Room 8 (Top) |
| TYPE                   | Primary Power | PROTECTION  |                                     |
| NOMINAL VOLTAGE        |               | AMPS        |                                     |
| NOMINAL AMPS           |               | DISCONNECT  |                                     |
| LOCATION               |               |             |                                     |

|                        |               |             |  |
|------------------------|---------------|-------------|--|
| ADDRESS / SCAN ADDRESS | / 135         | DESCRIPTION | Rooms 3 8 Bldg Hall by Room 8 (Bottom) |
| TYPE                   | Primary Power | PROTECTION  |  |
| NOMINAL VOLTAGE        |               | AMPS        |  |
| NOMINAL AMPS           |               | DISCONNECT  |  |
| LOCATION               |               |             |  |

|                        |               |             |                                     |
|------------------------|---------------|-------------|-------------------------------------|
| ADDRESS / SCAN ADDRESS | / 176         | DESCRIPTION | Rooms 11 13 Bldg Teleco Rm by Rm 11 |
| TYPE                   | Primary Power | PROTECTION  |                                     |
| NOMINAL VOLTAGE        |               | AMPS        |                                     |
| NOMINAL AMPS           |               | DISCONNECT  |                                     |
| LOCATION               |               |             |                                     |

|                        |               |             |                                     |
|------------------------|---------------|-------------|-------------------------------------|
| ADDRESS / SCAN ADDRESS | / 177         | DESCRIPTION | Rooms 11 13 Bldg Teleco Rm by Rm 11 |
| TYPE                   | Primary Power | PROTECTION  |                                     |
| NOMINAL VOLTAGE        |               | AMPS        |                                     |
| NOMINAL AMPS           |               | DISCONNECT  |                                     |
| LOCATION               |               |             |                                     |

|                        |               |             |                          |
|------------------------|---------------|-------------|--------------------------|
| ADDRESS / SCAN ADDRESS | / 212         | DESCRIPTION | Rooms 14 16 Bldg Room 15 |
| TYPE                   | Primary Power | PROTECTION  |                          |
| NOMINAL VOLTAGE        |               | AMPS        |                          |
| NOMINAL AMPS           |               | DISCONNECT  |                          |
| LOCATION               |               |             |                          |

|                        |               |             |                                    |
|------------------------|---------------|-------------|------------------------------------|
| ADDRESS / SCAN ADDRESS | / 213         | DESCRIPTION | Rooms 14 16 Bldg Room 15           |
| TYPE                   | Primary Power | PROTECTION  |                                    |
| NOMINAL VOLTAGE        |               | AMPS        |                                    |
| NOMINAL AMPS           |               | DISCONNECT  |                                    |
| LOCATION               |               |             |                                    |
| ADDRESS / SCAN ADDRESS | / 260         | DESCRIPTION | Rooms 20 22 Bldg Cust Off By Rm 22 |
| TYPE                   | Primary Power | PROTECTION  |                                    |
| NOMINAL VOLTAGE        |               | AMPS        |                                    |
| NOMINAL AMPS           |               | DISCONNECT  |                                    |
| LOCATION               |               |             |                                    |
| ADDRESS / SCAN ADDRESS | / 438         | DESCRIPTION | White House Bldg Paint Room        |
| TYPE                   | Primary Power | PROTECTION  |                                    |
| NOMINAL VOLTAGE        |               | AMPS        |                                    |
| NOMINAL AMPS           |               | DISCONNECT  |                                    |
| LOCATION               |               |             |                                    |

# Open Corrective Action & Solution Summary

The following 8 corrective action(s) remain open following the system inspection, testing or maintenance activities

| EQUIPMENT TYPE           | ADDRESS            | DESCRIPTION                            |
|--------------------------|--------------------|--|
| Fire Alarm Control Panel |                    | Rooms 11 13 Bldg Teleco Rm by Rm 11    |
|                          | Created By:        | Riley Goyet                            |
|                          | Creation Date:     | 10/05/2023                             |
|                          | Corrective Action: | Replace (2) 12V 55AH Batteries         |
|                          | Proposed Solution: |  |
|                          | Manufacturer:      | EST                                    |
|                          | Model:             |  |
|                          | Created By:        | Riley Goyet                            |
|                          | Creation Date:     | 09/30/2024                             |
|                          | Corrective Action: | Buttons on the panel aren't working.   |
|                          | Proposed Solution: |  |
|                          | Manufacturer:      | EST                                    |
|                          | Model:             |  |
| Primary Power            | 134                | Rooms 3 8 Bldg Hall by Room 8 (Top)    |
|                          | Created By:        | Riley Goyet                            |
|                          | Creation Date:     | 10/01/2024                             |
|                          | Corrective Action: | Replace (2) 12V 8AH Batteries          |
|                          | Proposed Solution: |  |
|                          | Manufacturer:      |  |
|                          | Model:             |  |
|                          | Created By:        | Riley Goyet                            |
|                          | Creation Date:     | 08/04/2025                             |
|                          | Corrective Action: | Replace (2) 12V 8AH Batteries          |
|                          | Proposed Solution: |  |
|                          | Manufacturer:      |  |
|                          | Model:             |  |
| Primary Power            | 135                | Rooms 3 8 Bldg Hall by Room 8 (Bottom) |
|                          | Created By:        | Riley Goyet                            |
|                          | Creation Date:     | 10/01/2024                             |
|                          | Corrective Action: | Replace (2) 12V 8AH Batteries          |
|                          | Proposed Solution: |  |
|                          | Manufacturer:      |  |
|                          | Model:             |  |
|                          | Created By:        | Riley Goyet                            |
|                          | Creation Date:     | 08/04/2025                             |
|                          | Corrective Action: | Replace (2) 12V 8AH Batteries          |
|                          | Proposed Solution: |  |
|                          | Manufacturer:      |  |
|                          | Model:             |  |
| Primary Power            | 176                | Rooms 11 13 Bldg Teleco Rm by Rm 11    |
|                          | Created By:        | Riley Goyet                            |
|                          | Creation Date:     | 08/04/2025                             |
|                          | Corrective Action: | Replace (2) 12V 8AH Batteries          |
|                          | Proposed Solution: |  |
|                          | Manufacturer:      |  |
|                          | Model:             |  |
| Primary Power            | 177                | Rooms 11 13 Bldg Teleco Rm by Rm 11    |
|                          | Created By:        | Riley Goyet                            |
|                          | Creation Date:     | 08/04/2025                             |
|                          | Corrective Action: | Replace (2) 12V 8AH Batteries          |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION |
|----------------|---------|-------------|
|----------------|---------|-------------|

Proposed Solution:

Manufacturer:

Model:

# Testing Details

## Alarm Notification Appliance

Passed

| EQUIPMENT TYPE      | ADDRESS | DESCRIPTION                               | METHOD          | DATE/TIME           |
|---------------------|---------|---|-----------------|---------------------|
| Visible             | 024     | Admin Area Hall by Work Room              | Manual          | 8/4/2025 6:15:14 AM |
|                     |         | Visual inspection                         | Passed (Manual) |                     |
| Visible             | 026     | Admin Area Nurses Office                  | Manual          | 8/4/2025 6:15:11 AM |
|                     |         | Visual inspection                         | Passed (Manual) |                     |
| Audible And Visible | 020     | Admin Area Office North Entry             | Manual          | 8/4/2025 6:15:19 AM |
|                     |         | Functional Inspection                     | Passed          |                     |
| Visible             | 025     | Admin Area Office Staff Restroom          | Manual          | 8/4/2025 6:15:13 AM |
|                     |         | Visual inspection                         | Passed (Manual) |                     |
| Visible             | 023     | Admin Area Principals Office              | Manual          | 8/4/2025 6:15:16 AM |
|                     |         | Functional Inspection                     | Passed          |                     |
| Visible             | 022     | Admin Area Reception                      | Manual          | 8/4/2025 6:15:37 AM |
|                     |         | Visual inspection                         | Passed (Manual) |                     |
| Audible             | 018     | Admin Area South Exterior                 | Manual          | 8/4/2025 6:15:22 AM |
|                     |         | Functional Inspection                     | Passed          |                     |
| Audible And Visible | 021     | Admin Area Staff Break Room               | Manual          | 8/4/2025 6:15:17 AM |
|                     |         | Visual inspection                         | Passed (Manual) |                     |
| Audible And Visible | 019     | Admin Area Work Room                      | Manual          | 8/4/2025 6:15:20 AM |
|                     |         | Functional Inspection                     | Passed          |                     |
| Audible And Visible | 341     | Discovery Club Bldg Discovery Club        | Manual          | 8/4/2025 6:12:02 AM |
|                     |         | Visual inspection                         | Passed (Manual) |                     |
| Visible             | 342     | Discovery Club Bldg Discovery Club Office | Manual          | 8/4/2025 6:12:00 AM |
|                     |         | Functional Inspection                     | Passed          |                     |
| Visible             | 343     | Discovery Club Bldg Discovery Club RR     | Manual          | 8/4/2025 6:11:58 AM |
|                     |         | Visual inspection                         | Passed (Manual) |                     |
| Visible             | 344     | Discovery Club Bldg Discovery Club RR     | Manual          | 8/4/2025 6:15:36 AM |
|                     |         | Functional Inspection                     | Passed          |                     |
| Audible             | 340     | Discovery Club Bldg South Exterior        | Manual          | 8/4/2025 6:12:03 AM |
|                     |         | Visual inspection                         | Passed (Manual) |                     |
| Audible And Visible | 326     | Muti Purpose Bldg Kitchen                 | Manual          | 8/4/2025 6:12:06 AM |
|                     |         | Functional Inspection                     | Passed          |                     |
| Visible             | 327     | Muti Purpose Bldg Kitchen Office          | Manual          | 8/4/2025 6:12:05 AM |
|                     |         | Visual inspection                         | Passed (Manual) |                     |
|                     |         | Functional Inspection                     | Passed          |                     |

| EQUIPMENT TYPE      | ADDRESS | DESCRIPTION                       | METHOD          | DATE/TIME           |
|---------------------|---------|-----------------------------------|-----------------|---------------------|
| Audible And Visible | 325     | Muti Purpose Bldg MP Room         | Manual          | 8/4/2025 6:12:12 AM |
|                     |         | Visual inspection                 | Passed (Manual) |                     |
|                     |         | Functional Inspection             | Passed          |                     |
| Audible And Visible | 324     | Muti Purpose Bldg MP Room         | Manual          | 8/4/2025 6:12:13 AM |
|                     |         | Visual inspection                 | Passed (Manual) |                     |
|                     |         | Functional Inspection             | Passed          |                     |
| Audible And Visible | 323     | Muti Purpose Bldg MP Room         | Manual          | 8/4/2025 6:12:14 AM |
|                     |         | Visual inspection                 | Passed (Manual) |                     |
|                     |         | Functional Inspection             | Passed          |                     |
| Audible And Visible | 322     | Muti Purpose Bldg MP Room         | Manual          | 8/4/2025 6:12:16 AM |
|                     |         | Visual inspection                 | Passed (Manual) |                     |
|                     |         | Functional Inspection             | Passed          |                     |
| Audible And Visible | 288     | Portables Room 23                 | Manual          | 8/4/2025 6:12:26 AM |
|                     |         | Visual inspection                 | Passed (Manual) |                     |
|                     |         | Functional Inspection             | Passed          |                     |
| Audible And Visible | 289     | Portables Room 24                 | Manual          | 8/4/2025 6:12:24 AM |
|                     |         | Visual inspection                 | Passed (Manual) |                     |
|                     |         | Functional Inspection             | Passed          |                     |
| Audible And Visible | 290     | Portables Room 25                 | Manual          | 8/4/2025 6:12:23 AM |
|                     |         | Visual inspection                 | Passed (Manual) |                     |
|                     |         | Functional Inspection             | Passed          |                     |
| Audible And Visible | 292     | Portables Room 28                 | Manual          | 8/4/2025 6:12:20 AM |
|                     |         | Visual inspection                 | Passed (Manual) |                     |
|                     |         | Functional Inspection             | Passed          |                     |
| Audible And Visible | 291     | Portables Room 28                 | Manual          | 8/4/2025 6:12:21 AM |
|                     |         | Visual inspection                 | Passed (Manual) |                     |
|                     |         | Functional Inspection             | Passed          |                     |
| Visible             | 294     | Portables Room 28                 | Manual          | 8/4/2025 6:12:18 AM |
|                     |         | Visual inspection                 | Passed (Manual) |                     |
|                     |         | Functional Inspection             | Passed          |                     |
| Audible             | 287     | Portables West Exterior           | Manual          | 8/4/2025 6:12:27 AM |
|                     |         | Visual inspection                 | Passed (Manual) |                     |
|                     |         | Functional Inspection             | Passed          |                     |
| Audible             | 286     | Portables West Exterior           | Manual          | 8/4/2025 6:12:29 AM |
|                     |         | Visual inspection                 | Passed (Manual) |                     |
|                     |         | Functional Inspection             | Passed          |                     |
| Audible             | 285     | Portables West Exterior           | Manual          | 8/4/2025 6:12:31 AM |
|                     |         | Visual inspection                 | Passed (Manual) |                     |
|                     |         | Functional Inspection             | Passed          |                     |
| Audible And Visible | 045     | Rms K1 & K2 Bldg Room K1          | Manual          | 8/4/2025 6:15:08 AM |
|                     |         | Visual inspection                 | Passed (Manual) |                     |
|                     |         | Functional Inspection             | Passed          |                     |
| Visible             | 047     | Rms K1 & K2 Bldg Room K1 by RR    | Manual          | 8/4/2025 6:15:05 AM |
|                     |         | Visual inspection                 | Passed (Manual) |                     |
|                     |         | Functional Inspection             | Passed          |                     |
| Visible             | 048     | Rms K1 & K2 Bldg Room K1 Restroom | Manual          | 8/4/2025 6:15:03 AM |
|                     |         | Visual inspection                 | Passed (Manual) |                     |
|                     |         | Functional Inspection             | Passed          |                     |
| Audible And Visible | 046     | Rms K1 & K2 Bldg Room K2          | Manual          | 8/4/2025 6:15:06 AM |
|                     |         | Visual inspection                 | Passed (Manual) |                     |
|                     |         | Functional Inspection             | Passed          |                     |
| Visible             | 049     | Rms K1 & K2 Bldg Room K2 by RR    | Manual          | 8/4/2025 6:15:01 AM |
|                     |         | Visual inspection                 | Passed (Manual) |                     |
|                     |         | Functional Inspection             | Passed          |                     |

| EQUIPMENT TYPE      | ADDRESS | DESCRIPTION                           | METHOD          | DATE/TIME           |
|---------------------|---------|---------------------------------------|-----------------|---------------------|
| Visible             | 050     | Rms K1 & K2 Bldg Room K2 Restroom     | Manual          | 8/4/2025 6:15:00 AM |
|                     |         | Visual inspection                     | Passed (Manual) |                     |
|                     |         | Functional Inspection                 | Passed          |                     |
| Visible             | 051     | Rms K1 & K2 Bldg Room K2 Strg by RR   | Manual          | 8/4/2025 6:14:58 AM |
|                     |         | Visual inspection                     | Passed (Manual) |                     |
|                     |         | Functional Inspection                 | Passed          |                     |
| Audible             | 044     | Rms K1 & K2 Bldg South Exterior       | Manual          | 8/4/2025 6:15:09 AM |
|                     |         | Visual inspection                     | Passed (Manual) |                     |
|                     |         | Functional Inspection                 | Passed          |                     |
| Audible And Visible | 173     | Rooms 11 13 Bldg Room 11              | Manual          | 8/4/2025 6:13:52 AM |
|                     |         | Visual inspection                     | Passed (Manual) |                     |
|                     |         | Functional Inspection                 | Passed          |                     |
| Audible And Visible | 174     | Rooms 11 13 Bldg Room 12              | Manual          | 8/4/2025 6:13:48 AM |
|                     |         | Visual inspection                     | Passed (Manual) |                     |
|                     |         | Functional Inspection                 | Passed          |                     |
| Audible And Visible | 175     | Rooms 11 13 Bldg Room 13              | Manual          | 8/4/2025 6:13:47 AM |
|                     |         | Visual inspection                     | Passed (Manual) |                     |
|                     |         | Functional Inspection                 | Passed          |                     |
| Audible             | 171     | Rooms 11 13 Bldg Southeast Exterior   | Manual          | 8/4/2025 6:15:23 AM |
|                     |         | Visual inspection                     | Passed (Manual) |                     |
|                     |         | Functional Inspection                 | Passed          |                     |
| Audible             | 172     | Rooms 11 13 Bldg West Exterior        | Manual          | 8/4/2025 6:13:54 AM |
|                     |         | Visual inspection                     | Passed (Manual) |                     |
|                     |         | Functional Inspection                 | Passed          |                     |
| Visible             | 210     | Rooms 14 16 Bldg Boys RR by Room 14   | Manual          | 8/4/2025 6:13:28 AM |
|                     |         | Visual inspection                     | Passed (Manual) |                     |
|                     |         | Functional Inspection                 | Passed          |                     |
| Audible And Visible | 204     | Rooms 14 16 Bldg Computer Lab         | Manual          | 8/4/2025 6:13:40 AM |
|                     |         | Visual inspection                     | Passed (Manual) |                     |
|                     |         | Functional Inspection                 | Passed          |                     |
| Visible             | 211     | Rooms 14 16 Bldg Girls RR by Room 14  | Manual          | 8/4/2025 6:13:26 AM |
|                     |         | Visual inspection                     | Passed (Manual) |                     |
|                     |         | Functional Inspection                 | Passed          |                     |
| Audible And Visible | 205     | Rooms 14 16 Bldg Media Center Library | Manual          | 8/4/2025 6:13:39 AM |
|                     |         | Visual inspection                     | Passed (Manual) |                     |
|                     |         | Functional Inspection                 | Passed          |                     |
| Visible             | 208     | Rooms 14 16 Bldg Media Center Library | Manual          | 8/4/2025 6:13:35 AM |
|                     |         | Visual inspection                     | Passed (Manual) |                     |
|                     |         | Functional Inspection                 | Passed          |                     |
| Visible             | 209     | Rooms 14 16 Bldg Media Ctr Read Rm    | Manual          | 8/4/2025 6:13:34 AM |
|                     |         | Visual inspection                     | Passed (Manual) |                     |
|                     |         | Functional Inspection                 | Passed          |                     |
| Audible And Visible | 202     | Rooms 14 16 Bldg Room 14              | Manual          | 8/4/2025 6:13:44 AM |
|                     |         | Visual inspection                     | Passed (Manual) |                     |
|                     |         | Functional Inspection                 | Passed          |                     |
| Audible And Visible | 203     | Rooms 14 16 Bldg Room 15              | Manual          | 8/4/2025 6:13:42 AM |
|                     |         | Visual inspection                     | Passed (Manual) |                     |
|                     |         | Functional Inspection                 | Passed          |                     |
| Visible             | 206     | Rooms 14 16 Bldg Room 16              | Manual          | 8/4/2025 6:13:38 AM |
|                     |         | Visual inspection                     | Passed (Manual) |                     |
|                     |         | Functional Inspection                 | Passed          |                     |
| Visible             | 207     | Rooms 14 16 Bldg Room 16 Storage      | Manual          | 8/4/2025 6:13:36 AM |

| EQUIPMENT TYPE      | ADDRESS | DESCRIPTION                         | METHOD          | DATE/TIME           |
|---------------------|---------|-------------------------------------|-----------------|---------------------|
|                     |         | Visual inspection                   | Passed (Manual) |                     |
|                     |         | Functional Inspection               | Passed          |                     |
| Audible             | 201     | Rooms 14 16 Bldg Southwest Exterior | Manual          | 8/4/2025 6:13:46 AM |
|                     |         | Visual inspection                   | Passed (Manual) |                     |
|                     |         | Functional Inspection               | Passed          |                     |
| Visible             | 235     | Rooms 17 19 Bldg                    | Manual          | 8/4/2025 6:12:49 AM |
|                     |         | Visual inspection                   | Passed (Manual) |                     |
|                     |         | Functional Inspection               | Passed          |                     |
| Visible             | 234     | Rooms 17 19 Bldg                    | Manual          | 8/4/2025 6:12:50 AM |
|                     |         | Visual inspection                   | Passed (Manual) |                     |
|                     |         | Functional Inspection               | Passed          |                     |
| Audible             | 227     | Rooms 17 19 Bldg Northeast Exterior | Manual          | 8/4/2025 6:13:30 AM |
|                     |         | Visual inspection                   | Passed (Manual) |                     |
|                     |         | Functional Inspection               | Passed          |                     |
| Audible And Visible | 229     | Rooms 17 19 Bldg Room 17            | Manual          | 8/4/2025 6:13:23 AM |
|                     |         | Visual inspection                   | Passed (Manual) |                     |
|                     |         | Functional Inspection               | Passed          |                     |
| Visible             | 232     | Rooms 17 19 Bldg Room 17 Office     | Manual          | 8/4/2025 6:12:53 AM |
|                     |         | Visual inspection                   | Passed (Manual) |                     |
|                     |         | Functional Inspection               | Passed          |                     |
| Visible             | 233     | Rooms 17 19 Bldg Room 17 Storage    | Manual          | 8/4/2025 6:12:51 AM |
|                     |         | Visual inspection                   | Passed (Manual) |                     |
|                     |         | Functional Inspection               | Passed          |                     |
| Audible And Visible | 230     | Rooms 17 19 Bldg Room 18            | Manual          | 8/4/2025 6:13:21 AM |
|                     |         | Visual inspection                   | Passed (Manual) |                     |
|                     |         | Functional Inspection               | Passed          |                     |
| Audible And Visible | 231     | Rooms 17 19 Bldg Room 19            | Manual          | 8/4/2025 6:12:55 AM |
|                     |         | Visual inspection                   | Passed (Manual) |                     |
|                     |         | Functional Inspection               | Passed          |                     |
| Audible             | 228     | Rooms 17 19 Bldg Southeast Exterior | Manual          | 8/4/2025 6:13:25 AM |
|                     |         | Visual inspection                   | Passed (Manual) |                     |
|                     |         | Functional Inspection               | Passed          |                     |
| Audible And Visible | 256     | Rooms 20 22 Bldg Cust Off Rm 22     | Manual          | 8/4/2025 6:12:37 AM |
|                     |         | Visual inspection                   | Passed (Manual) |                     |
|                     |         | Functional Inspection               | Passed          |                     |
| Visible             | 258     | Rooms 20 22 Bldg Mens Staff RR      | Manual          | 8/4/2025 6:12:33 AM |
|                     |         | Visual inspection                   | Passed (Manual) |                     |
|                     |         | Functional Inspection               | Passed          |                     |
| Audible             | 249     | Rooms 20 22 Bldg Northeast Exterior | Manual          | 8/4/2025 6:12:47 AM |
|                     |         | Visual inspection                   | Passed (Manual) |                     |
|                     |         | Functional Inspection               | Passed          |                     |
| Audible             | 250     | Rooms 20 22 Bldg Northwest Exterior | Manual          | 8/4/2025 6:12:46 AM |
|                     |         | Visual inspection                   | Passed (Manual) |                     |
|                     |         | Functional Inspection               | Passed          |                     |
| Audible And Visible | 253     | Rooms 20 22 Bldg Room 20            | Manual          | 8/4/2025 6:12:41 AM |
|                     |         | Visual inspection                   | Passed (Manual) |                     |
|                     |         | Functional Inspection               | Passed          |                     |
| Audible And Visible | 254     | Rooms 20 22 Bldg Room 21            | Manual          | 8/4/2025 6:12:39 AM |
|                     |         | Visual inspection                   | Passed (Manual) |                     |
|                     |         | Functional Inspection               | Passed          |                     |
| Audible And Visible | 255     | Rooms 20 22 Bldg Room 22            | Manual          | 8/4/2025 6:12:38 AM |
|                     |         | Visual inspection                   | Passed (Manual) |                     |
|                     |         | Functional Inspection               | Passed          |                     |
| Audible             | 251     | Rooms 20 22 Bldg Southeast Exterior | Manual          | 8/4/2025 6:12:44 AM |
|                     |         | Visual inspection                   | Passed (Manual) |                     |
|                     |         | Functional Inspection               | Passed          |                     |

| EQUIPMENT TYPE      | ADDRESS | DESCRIPTION                         | METHOD          | DATE/TIME           |
|---------------------|---------|-------------------------------------|-----------------|---------------------|
| Audible             | 252     | Rooms 20 22 Bldg Southwest Exterior | Manual          | 8/4/2025 6:12:43 AM |
|                     |         | Visual inspection                   | Passed (Manual) |                     |
|                     |         | Functional Inspection               | Passed          |                     |
| Visible             | 259     | Rooms 20 22 Bldg Storage by Rm 20   | Manual          | 8/4/2025 6:12:32 AM |
|                     |         | Visual inspection                   | Passed (Manual) |                     |
|                     |         | Functional Inspection               | Passed          |                     |
| Visible             | 257     | Rooms 20 22 Bldg Womens Staff RR    | Manual          | 8/4/2025 6:12:35 AM |
|                     |         | Visual inspection                   | Passed (Manual) |                     |
|                     |         | Functional Inspection               | Passed          |                     |
| Audible             | 106     | Rooms 3 8 Bldg East Exterior        | Manual          | 8/4/2025 6:14:57 AM |
|                     |         | Visual inspection                   | Passed (Manual) |                     |
|                     |         | Functional Inspection               | Passed          |                     |
| Audible And Visible | 118     | Rooms 3 8 Bldg Hall S E by Room 8   | Manual          | 8/4/2025 6:14:42 AM |
|                     |         | Visual inspection                   | Passed (Manual) |                     |
|                     |         | Functional Inspection               | Passed          |                     |
| Audible And Visible | 115     | Rooms 3 8 Bldg Hallway by Room 3    | Manual          | 8/4/2025 6:14:45 AM |
|                     |         | Visual inspection                   | Passed (Manual) |                     |
|                     |         | Functional Inspection               | Passed          |                     |
| Audible And Visible | 116     | Rooms 3 8 Bldg Hallway by Room 6    | Manual          | 8/4/2025 6:14:44 AM |
|                     |         | Visual inspection                   | Passed (Manual) |                     |
|                     |         | Functional Inspection               | Passed          |                     |
| Audible And Visible | 117     | Rooms 3 8 Bldg Hallway by Room 7    | Manual          | 8/4/2025 6:15:26 AM |
|                     |         | Visual inspection                   | Passed (Manual) |                     |
|                     |         | Functional Inspection               | Passed          |                     |
| Visible             | 132     | Rooms 3 8 Bldg Hist Bldg Boys RR    | Manual          | 8/4/2025 6:14:16 AM |
|                     |         | Visual inspection                   | Passed (Manual) |                     |
|                     |         | Functional Inspection               | Passed          |                     |
| Visible             | 133     | Rooms 3 8 Bldg Hist Bldg Girls RR   | Manual          | 8/4/2025 6:14:15 AM |
|                     |         | Visual inspection                   | Passed (Manual) |                     |
|                     |         | Functional Inspection               | Passed          |                     |
| Visible             | 131     | Rooms 3 8 Bldg Hist Bldg Staff RR   | Manual          | 8/4/2025 6:14:18 AM |
|                     |         | Visual inspection                   | Passed (Manual) |                     |
|                     |         | Functional Inspection               | Passed          |                     |
| Audible And Visible | 109     | Rooms 3 8 Bldg Room 3               | Manual          | 8/4/2025 6:14:53 AM |
|                     |         | Visual inspection                   | Passed (Manual) |                     |
|                     |         | Functional Inspection               | Passed          |                     |
| Visible             | 120     | Rooms 3 8 Bldg Room 3               | Manual          | 8/4/2025 6:14:39 AM |
|                     |         | Visual inspection                   | Passed (Manual) |                     |
|                     |         | Functional Inspection               | Passed          |                     |
| Visible             | 119     | Rooms 3 8 Bldg Room 3               | Manual          | 8/4/2025 6:14:40 AM |
|                     |         | Visual inspection                   | Passed (Manual) |                     |
|                     |         | Functional Inspection               | Passed          |                     |
| Audible And Visible | 110     | Rooms 3 8 Bldg Room 4               | Manual          | 8/4/2025 6:14:51 AM |
|                     |         | Visual inspection                   | Passed (Manual) |                     |
|                     |         | Functional Inspection               | Passed          |                     |
| Visible             | 122     | Rooms 3 8 Bldg Room 4               | Manual          | 8/4/2025 6:14:36 AM |
|                     |         | Visual inspection                   | Passed (Manual) |                     |
|                     |         | Functional Inspection               | Passed          |                     |
| Visible             | 121     | Rooms 3 8 Bldg Room 4               | Manual          | 8/4/2025 6:14:37 AM |
|                     |         | Visual inspection                   | Passed (Manual) |                     |
|                     |         | Functional Inspection               | Passed          |                     |
| Audible And Visible | 111     | Rooms 3 8 Bldg Room 5               | Manual          | 8/4/2025 6:14:50 AM |
|                     |         | Visual inspection                   | Passed (Manual) |                     |
|                     |         | Functional Inspection               | Passed          |                     |
| Visible             | 124     | Rooms 3 8 Bldg Room 5               | Manual          | 8/4/2025 6:14:31 AM |

| EQUIPMENT TYPE      | ADDRESS | DESCRIPTION                           | METHOD          | DATE/TIME           |
|---------------------|---------|---------------------------------------|-----------------|---------------------|
|                     |         | Visual inspection                     | Passed (Manual) |                     |
|                     |         | Functional Inspection                 | Passed          |                     |
| Visible             | 123     | Rooms 3 8 Bldg Room 5                 | Manual          | 8/4/2025 6:14:34 AM |
|                     |         | Visual inspection                     | Passed (Manual) |                     |
|                     |         | Functional Inspection                 | Passed          |                     |
| Audible And Visible | 112     | Rooms 3 8 Bldg Room 6                 | Manual          | 8/4/2025 6:14:48 AM |
|                     |         | Visual inspection                     | Passed (Manual) |                     |
|                     |         | Functional Inspection                 | Passed          |                     |
| Visible             | 126     | Rooms 3 8 Bldg Room 6                 | Manual          | 8/4/2025 6:14:26 AM |
|                     |         | Visual inspection                     | Passed (Manual) |                     |
|                     |         | Functional Inspection                 | Passed          |                     |
| Visible             | 125     | Rooms 3 8 Bldg Room 6                 | Manual          | 8/4/2025 6:14:29 AM |
|                     |         | Visual inspection                     | Passed (Manual) |                     |
|                     |         | Functional Inspection                 | Passed          |                     |
| Audible And Visible | 113     | Rooms 3 8 Bldg Room 7                 | Manual          | 8/4/2025 6:15:24 AM |
|                     |         | Visual inspection                     | Passed (Manual) |                     |
|                     |         | Functional Inspection                 | Passed          |                     |
| Visible             | 128     | Rooms 3 8 Bldg Room 7                 | Manual          | 8/4/2025 6:15:29 AM |
|                     |         | Visual inspection                     | Passed (Manual) |                     |
|                     |         | Functional Inspection                 | Passed          |                     |
| Visible             | 127     | Rooms 3 8 Bldg Room 7                 | Manual          | 8/4/2025 6:15:32 AM |
|                     |         | Visual inspection                     | Passed (Manual) |                     |
|                     |         | Functional Inspection                 | Passed          |                     |
| Audible And Visible | 114     | Rooms 3 8 Bldg Room 8                 | Manual          | 8/4/2025 6:14:47 AM |
|                     |         | Visual inspection                     | Passed (Manual) |                     |
|                     |         | Functional Inspection                 | Passed          |                     |
| Visible             | 130     | Rooms 3 8 Bldg Room 8                 | Manual          | 8/4/2025 6:14:22 AM |
|                     |         | Visual inspection                     | Passed (Manual) |                     |
|                     |         | Functional Inspection                 | Passed          |                     |
| Visible             | 129     | Rooms 3 8 Bldg Room 8                 | Manual          | 8/4/2025 6:14:24 AM |
|                     |         | Visual inspection                     | Passed (Manual) |                     |
|                     |         | Functional Inspection                 | Passed          |                     |
| Audible             | 107     | Rooms 3 8 Bldg South Exterior         | Manual          | 8/4/2025 6:14:55 AM |
|                     |         | Visual inspection                     | Passed (Manual) |                     |
|                     |         | Functional Inspection                 | Passed          |                     |
| Audible             | 108     | Rooms 3 8 Bldg West Exterior          | Manual          | 8/4/2025 6:14:54 AM |
|                     |         | Visual inspection                     | Passed (Manual) |                     |
|                     |         | Functional Inspection                 | Passed          |                     |
| Visible             | 158     | Rooms 9 & 10 Area Art Room 9          | Manual          | 8/4/2025 6:14:00 AM |
|                     |         | Visual inspection                     | Passed (Manual) |                     |
|                     |         | Functional Inspection                 | Passed          |                     |
| Audible And Visible | 155     | Rooms 9 & 10 Area Hallway by Art Rm 9 | Manual          | 8/4/2025 6:14:05 AM |
|                     |         | Visual inspection                     | Passed (Manual) |                     |
|                     |         | Functional Inspection                 | Passed          |                     |
| Audible And Visible | 154     | Rooms 9 & 10 Area Hallway by Room 10  | Manual          | 8/4/2025 6:14:07 AM |
|                     |         | Visual inspection                     | Passed (Manual) |                     |
|                     |         | Functional Inspection                 | Passed          |                     |
| Visible             | 156     | Rooms 9 & 10 Area Reading Room 9      | Manual          | 8/4/2025 6:14:03 AM |
|                     |         | Visual inspection                     | Passed (Manual) |                     |
|                     |         | Functional Inspection                 | Passed          |                     |
| Visible             | 159     | Rooms 9 & 10 Area Restroom by Art Rm  | Manual          | 8/4/2025 6:13:56 AM |
|                     |         | Visual inspection                     | Passed (Manual) |                     |
|                     |         | Functional Inspection                 | Passed          |                     |
| Audible And Visible | 153     | Rooms 9 & 10 Area Room 10             | Manual          | 8/4/2025 6:14:09 AM |

| EQUIPMENT TYPE      | ADDRESS | DESCRIPTION                          | METHOD          | DATE/TIME           |
|---------------------|---------|--------------------------------------|-----------------|---------------------|
|                     |         | Visual inspection                    | Passed (Manual) |                     |
|                     |         | Functional Inspection                | Passed          |                     |
| Audible And Visible | 152     | Rooms 9 & 10 Area Room 9             | Manual          | 8/4/2025 6:14:11 AM |
|                     |         | Visual inspection                    | Passed (Manual) |                     |
|                     |         | Functional Inspection                | Passed          |                     |
| Audible             | 151     | Rooms 9 & 10 Area Southeast Exterior | Manual          | 8/4/2025 6:14:13 AM |
|                     |         | Visual inspection                    | Passed (Manual) |                     |
|                     |         | Functional Inspection                | Passed          |                     |
| Visible             | 157     | Rooms 9 & 10 Area Speech Room 9      | Manual          | 8/4/2025 6:14:02 AM |
|                     |         | Visual inspection                    | Passed (Manual) |                     |
|                     |         | Functional Inspection                | Passed          |                     |
| Visible             | 425     | White House Bldg Child Waiting Room  | Manual          | 8/4/2025 6:11:21 AM |
|                     |         | Visual inspection                    | Passed (Manual) |                     |
|                     |         | Functional Inspection                | Passed          |                     |
| Audible             | 403     | White House Bldg East Exterior       | Manual          | 8/4/2025 6:11:57 AM |
|                     |         | Visual inspection                    | Passed (Manual) |                     |
|                     |         | Functional Inspection                | Passed          |                     |
| Visible             | 436     | White House Bldg File Room by Recept | Manual          | 8/4/2025 6:15:30 AM |
|                     |         | Visual inspection                    | Passed (Manual) |                     |
|                     |         | Functional Inspection                | Passed          |                     |
| Visible             | 415     | White House Bldg Hall by MediCal Off | Manual          | 8/4/2025 6:11:36 AM |
|                     |         | Visual inspection                    | Passed (Manual) |                     |
|                     |         | Functional Inspection                | Passed          |                     |
| Audible And Visible | 405     | White House Bldg Hall by Office 10   | Manual          | 8/4/2025 6:11:54 AM |
|                     |         | Visual inspection                    | Passed (Manual) |                     |
|                     |         | Functional Inspection                | Passed          |                     |
| Audible And Visible | 411     | White House Bldg Hall by Office 2    | Manual          | 8/4/2025 6:11:45 AM |
|                     |         | Visual inspection                    | Passed (Manual) |                     |
|                     |         | Functional Inspection                | Passed          |                     |
| Audible And Visible | 410     | White House Bldg Hall by Office 4    | Manual          | 8/4/2025 6:11:47 AM |
|                     |         | Visual inspection                    | Passed (Manual) |                     |
|                     |         | Functional Inspection                | Passed          |                     |
| Visible             | 424     | White House Bldg Hall by Restroom    | Manual          | 8/4/2025 6:11:23 AM |
|                     |         | Visual inspection                    | Passed (Manual) |                     |
|                     |         | Functional Inspection                | Passed          |                     |
| Audible And Visible | 408     | White House Bldg Hall by Room 9      | Manual          | 8/4/2025 6:11:50 AM |
|                     |         | Visual inspection                    | Passed (Manual) |                     |
|                     |         | Functional Inspection                | Passed          |                     |
| Audible And Visible | 406     | White House Bldg Hallway by Storage  | Manual          | 8/4/2025 6:11:53 AM |
|                     |         | Visual inspection                    | Passed (Manual) |                     |
|                     |         | Functional Inspection                | Passed          |                     |
| Visible             | 417     | White House Bldg Hallway by Storage  | Manual          | 8/4/2025 6:11:32 AM |
|                     |         | Visual inspection                    | Passed (Manual) |                     |
|                     |         | Functional Inspection                | Passed          |                     |
| Audible And Visible | 409     | White House Bldg Kitchen             | Manual          | 8/4/2025 6:11:48 AM |
|                     |         | Visual inspection                    | Passed (Manual) |                     |
|                     |         | Functional Inspection                | Passed          |                     |
| Visible             | 416     | White House Bldg MediCal Office      | Manual          | 8/4/2025 6:11:34 AM |
|                     |         | Visual inspection                    | Passed (Manual) |                     |
|                     |         | Functional Inspection                | Passed          |                     |
| Visible             | 434     | White House Bldg Office 1            | Manual          | 8/4/2025 6:11:07 AM |
|                     |         | Visual inspection                    | Passed (Manual) |                     |
|                     |         | Functional Inspection                | Passed          |                     |
| Visible             | 413     | White House Bldg Office 10           | Manual          | 8/4/2025 6:11:41 AM |
|                     |         | Visual inspection                    | Passed (Manual) |                     |

| EQUIPMENT TYPE      | ADDRESS | DESCRIPTION                          | METHOD          | DATE/TIME           |
|---------------------|---------|--------------------------------------|-----------------|---------------------|
|                     |         | Functional Inspection                | Passed          |                     |
| Visible             | 414     | White House Bldg Office 11           | Manual          | 8/4/2025 6:11:38 AM |
|                     |         | Visual inspection                    | Passed (Manual) |                     |
|                     |         | Functional Inspection                | Passed          |                     |
| Visible             | 432     | White House Bldg Office 15           | Manual          | 8/4/2025 6:11:10 AM |
|                     |         | Visual inspection                    | Passed (Manual) |                     |
|                     |         | Functional Inspection                | Passed          |                     |
| Visible             | 431     | White House Bldg Office 16           | Manual          | 8/4/2025 6:11:12 AM |
|                     |         | Visual inspection                    | Passed (Manual) |                     |
|                     |         | Functional Inspection                | Passed          |                     |
| Visible             | 426     | White House Bldg Office 16           | Manual          | 8/4/2025 6:11:19 AM |
|                     |         | Visual inspection                    | Passed (Manual) |                     |
|                     |         | Functional Inspection                | Passed          |                     |
| Visible             | 433     | White House Bldg Office 2            | Manual          | 8/4/2025 6:11:08 AM |
|                     |         | Visual inspection                    | Passed (Manual) |                     |
|                     |         | Functional Inspection                | Passed          |                     |
| Visible             | 428     | White House Bldg Office 3            | Manual          | 8/4/2025 6:11:16 AM |
|                     |         | Visual inspection                    | Passed (Manual) |                     |
|                     |         | Functional Inspection                | Passed          |                     |
| Visible             | 427     | White House Bldg Office 4            | Manual          | 8/4/2025 6:11:18 AM |
|                     |         | Visual inspection                    | Passed (Manual) |                     |
|                     |         | Functional Inspection                | Passed          |                     |
| Visible             | 429     | White House Bldg Office 5            | Manual          | 8/4/2025 6:11:15 AM |
|                     |         | Visual inspection                    | Passed (Manual) |                     |
|                     |         | Functional Inspection                | Passed          |                     |
| Visible             | 412     | White House Bldg Paint Room          | Manual          | 8/4/2025 6:11:44 AM |
|                     |         | Visual inspection                    | Passed (Manual) |                     |
|                     |         | Functional Inspection                | Passed          |                     |
| Visible             | 435     | White House Bldg Reception           | Manual          | 8/4/2025 6:11:06 AM |
|                     |         | Visual inspection                    | Passed (Manual) |                     |
|                     |         | Functional Inspection                | Passed          |                     |
| Visible             | 423     | White House Bldg Restroom            | Manual          | 8/4/2025 6:11:25 AM |
|                     |         | Visual inspection                    | Passed (Manual) |                     |
|                     |         | Functional Inspection                | Passed          |                     |
| Visible             | 422     | White House Bldg Restroom by Kitchen | Manual          | 8/4/2025 6:11:26 AM |
|                     |         | Visual inspection                    | Passed (Manual) |                     |
|                     |         | Functional Inspection                | Passed          |                     |
| Visible             | 419     | White House Bldg Room 13             | Manual          | 8/4/2025 6:11:30 AM |
|                     |         | Visual inspection                    | Passed (Manual) |                     |
|                     |         | Functional Inspection                | Passed          |                     |
| Visible             | 421     | White House Bldg Room 14             | Manual          | 8/4/2025 6:11:28 AM |
|                     |         | Visual inspection                    | Passed (Manual) |                     |
|                     |         | Functional Inspection                | Passed          |                     |
| Visible             | 420     | White House Bldg Room 7              | Manual          | 8/4/2025 6:15:27 AM |
|                     |         | Visual inspection                    | Passed (Manual) |                     |
|                     |         | Functional Inspection                | Passed          |                     |
| Visible             | 418     | White House Bldg Room 8              | Manual          | 8/4/2025 6:11:31 AM |
|                     |         | Visual inspection                    | Passed (Manual) |                     |
|                     |         | Functional Inspection                | Passed          |                     |
| Visible             | 437     | White House Bldg Room 9              | Manual          | 8/4/2025 6:11:04 AM |
|                     |         | Visual inspection                    | Passed (Manual) |                     |
|                     |         | Functional Inspection                | Passed          |                     |
| Audible And Visible | 407     | White House Bldg Storage Room        | Manual          | 8/4/2025 6:11:51 AM |
|                     |         | Visual inspection                    | Passed (Manual) |                     |
|                     |         | Functional Inspection                | Passed          |                     |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION                    | METHOD          | DATE/TIME           |
|----------------|---------|--------------------------------|-----------------|---------------------|
| Visible        | 430     | White House Bldg Video Room    | Manual          | 8/4/2025 6:11:14 AM |
|                |         | Visual inspection              | Passed (Manual) |                     |
|                |         | Functional Inspection          | Passed          |                     |
| Audible        | 404     | White House Bldg West Exterior | Manual          | 8/4/2025 6:11:55 AM |
|                |         | Visual inspection              | Passed (Manual) |                     |
|                |         | Functional Inspection          | Passed          |                     |

**Fire Control Panel**

Passed

| EQUIPMENT TYPE           | ADDRESS | DESCRIPTION                         | METHOD          | DATE/TIME           |
|--------------------------|---------|-------------------------------------|-----------------|---------------------|
| Remote Annunciator       | 001     | Admin Area Reception                | Manual          | 8/4/2025 1:26:13 PM |
|                          |         | Visual inspection                   | Passed (Manual) |                     |
|                          |         | Functional Inspection               | Passed          |                     |
| Fire Alarm Control Panel |         | Rooms 11 13 Bldg Teleco Rm by Rm 11 | Manual          | 8/4/2025 1:25:29 PM |
|                          |         | Manufacturer                        | EST             |                     |
|                          |         | Visual inspection                   | Passed (Manual) |                     |
|                          |         | Functional Inspection               | Passed          |                     |

**Initiating Device**

Passed

| EQUIPMENT TYPE                  | ADDRESS      | DESCRIPTION                      | METHOD          | DATE/TIME           |
|---------------------------------|--------------|----------------------------------|-----------------|---------------------|
| Heat Detector - Restorable Spot | 2-010<br>013 | Admin Area Hall Off Cust Strg    | Manual          | 8/4/2025 8:09:11 AM |
|                                 |              | Visual inspection                | Passed (Manual) |                     |
|                                 |              | Functional Inspection            | Passed          |                     |
| Heat Detector - Restorable Spot | 2-011<br>015 | Admin Area Hallway Staff Room    | Manual          | 8/4/2025 8:07:55 AM |
|                                 |              | Visual inspection                | Passed (Manual) |                     |
|                                 |              | Functional Inspection            | Passed          |                     |
| Smoke Detector - General        | 2-008<br>009 | Admin Area Nurses Office         | Manual          | 8/4/2025 8:11:06 AM |
|                                 |              | Visual inspection                | Passed (Manual) |                     |
|                                 |              | Functional Inspection            | Passed          |                     |
| Heat Detector - Restorable Spot | 2-009<br>014 | Admin Area Office Cust Storage   | Manual          | 8/4/2025 8:14:37 AM |
|                                 |              | Visual inspection                | Passed (Manual) |                     |
|                                 |              | Functional Inspection            | Passed          |                     |
| Manual Pull Station             | 2-154<br>004 | Admin Area Office North Entry    | Manual          | 8/4/2025 8:00:03 AM |
|                                 |              | Visual inspection                | Passed (Manual) |                     |
|                                 |              | Functional Inspection            | Passed          |                     |
| Manual Pull Station             | 2-155<br>002 | Admin Area Office South Entry    | Manual          | 8/4/2025 8:01:55 AM |
|                                 |              | Visual inspection                | Passed (Manual) |                     |
|                                 |              | Functional Inspection            | Passed          |                     |
| Heat Detector - Restorable Spot | 2-002<br>012 | Admin Area Office Staff Restroom | Manual          | 8/4/2025 2:12:52 PM |
|                                 |              | Visual inspection                | Passed (Manual) |                     |
|                                 |              | Functional Inspection            | Passed          |                     |
| Heat Detector - Restorable Spot | 2-005<br>011 | Admin Area Office Storage        | Manual          | 8/4/2025 2:12:32 PM |
|                                 |              | Visual inspection                | Passed (Manual) |                     |
|                                 |              | Functional Inspection            | Passed          |                     |
| Smoke Detector - General        | 2-004<br>007 | Admin Area Principals Office     | Manual          | 8/4/2025 8:03:15 AM |
|                                 |              | Visual inspection                | Passed (Manual) |                     |
|                                 |              | Functional Inspection            | Passed          |                     |
| Manual Pull Station             | 2-126<br>003 | Admin Area Reception             | Manual          | 8/4/2025 8:06:04 AM |
|                                 |              | Visual inspection                | Passed (Manual) |                     |
|                                 |              | Functional Inspection            | Passed          |                     |

| EQUIPMENT TYPE                  | ADDRESS      | DESCRIPTION                               | METHOD          | DATE/TIME            |
|---------------------------------|--------------|---|-----------------|----------------------|
| Smoke Detector - General        | 2-003<br>006 | Admin Area Reception                      | Manual          | 8/4/2025 8:02:43 AM  |
|                                 |              | Visual inspection                         | Passed (Manual) |                      |
|                                 |              | Functional Inspection                     | Passed          |                      |
| Heat Detector - Restorable Spot | 2-013<br>017 | Admin Area Staff Break Room               | Manual          | 8/4/2025 8:09:12 AM  |
|                                 |              | Visual inspection                         | Passed (Manual) |                      |
|                                 |              | Functional Inspection                     | Passed          |                      |
| Heat Detector - Restorable Spot | 2-012<br>016 | Admin Area Staff Room Storage             | Manual          | 8/4/2025 8:08:27 AM  |
|                                 |              | Visual inspection                         | Passed (Manual) |                      |
|                                 |              | Functional Inspection                     | Passed          |                      |
| Smoke Detector - General        | 2-007<br>005 | Admin Area Waiting Area                   | Manual          | 8/4/2025 7:59:24 AM  |
|                                 |              | Visual inspection                         | Passed (Manual) |                      |
|                                 |              | Functional Inspection                     | Passed          |                      |
| Smoke Detector - General        | 2-006<br>010 | Admin Area Waiting Area                   | Manual          | 8/4/2025 8:01:29 AM  |
|                                 |              | Visual inspection                         | Passed (Manual) |                      |
|                                 |              | Functional Inspection                     | Passed          |                      |
| Smoke Detector - General        | 2-001<br>008 | Admin Area Work Room                      | Manual          | 8/4/2025 8:00:54 AM  |
|                                 |              | Visual inspection                         | Passed (Manual) |                      |
|                                 |              | Functional Inspection                     | Passed          |                      |
| Heat Detector - Restorable Spot | 2-383<br>336 | Discovery Club Bldg Attic Discovery Club  | Manual          | 8/4/2025 10:51:28 AM |
|                                 |              | Visual inspection                         | Passed (Manual) |                      |
|                                 |              | Functional Inspection                     | Passed          |                      |
| Heat Detector - Restorable Spot | 2-383<br>338 | Discovery Club Bldg Attic Discovery Club  | Manual          | 8/4/2025 10:51:30 AM |
|                                 |              | Visual inspection                         | Passed (Manual) |                      |
|                                 |              | Functional Inspection                     | Passed          |                      |
| Heat Detector - Restorable Spot | 2-383<br>337 | Discovery Club Bldg Attic Discovery Club  | Manual          | 8/4/2025 10:51:31 AM |
|                                 |              | Visual inspection                         | Passed (Manual) |                      |
|                                 |              | Functional Inspection                     | Passed          |                      |
| Heat Detector - Restorable Spot | 2-383<br>339 | Discovery Club Bldg Attic Discovery Club  | Manual          | 8/4/2025 10:51:32 AM |
|                                 |              | Visual inspection                         | Passed (Manual) |                      |
|                                 |              | Functional Inspection                     | Passed          |                      |
| Heat Detector - Restorable Spot | 2-349<br>332 | Discovery Club Bldg Discovery Club        | Manual          | 8/4/2025 10:46:09 AM |
|                                 |              | Visual inspection                         | Passed (Manual) |                      |
|                                 |              | Functional Inspection                     | Passed          |                      |
| Heat Detector - Restorable Spot | 2-284<br>333 | Discovery Club Bldg Discovery Club        | Manual          | 8/4/2025 10:46:41 AM |
|                                 |              | Visual inspection                         | Passed (Manual) |                      |
|                                 |              | Functional Inspection                     | Passed          |                      |
| Smoke Detector - General        | 2-283<br>331 | Discovery Club Bldg Discovery Club Office | Manual          | 8/4/2025 10:50:07 AM |
|                                 |              | Visual inspection                         | Passed (Manual) |                      |
|                                 |              | Functional Inspection                     | Passed          |                      |
| Heat Detector - Restorable Spot | 2-286<br>335 | Discovery Club Bldg Discovery Club RR     | Manual          | 8/4/2025 10:52:10 AM |
|                                 |              | Visual inspection                         | Passed (Manual) |                      |
|                                 |              | Functional Inspection                     | Passed          |                      |
| Heat Detector - Restorable Spot | 2-285<br>334 | Discovery Club Bldg Discovery Club RR     | Manual          | 8/4/2025 10:52:14 AM |
|                                 |              | Visual inspection                         | Passed (Manual) |                      |
|                                 |              | Functional Inspection                     | Passed          |                      |
| Manual Pull Station             | 2-184<br>329 | Discovery Club Bldg East Exit             | Manual          | 8/4/2025 10:47:45 AM |
|                                 |              | Visual inspection                         | Passed (Manual) |                      |
|                                 |              | Functional Inspection                     | Passed          |                      |

| EQUIPMENT TYPE                  | ADDRESS      | DESCRIPTION                            | METHOD          | DATE/TIME            |
|---------------------------------|--------------|--|-----------------|----------------------|
| Manual Pull Station             | 2-183<br>330 | Discovery Club Bldg West Exit          | Manual          | 8/4/2025 10:47:11 AM |
|                                 |              | Visual inspection                      | Passed (Manual) |                      |
|                                 |              | Functional Inspection                  | Passed          |                      |
| Heat Detector - Restorable Spot | 2-044<br>318 | Muti Purpose Bldg Kitch W H Tank Clst  | Manual          | 8/4/2025 1:29:25 PM  |
|                                 |              | Visual inspection                      | Passed (Manual) |                      |
|                                 |              | Functional Inspection                  | Passed          |                      |
| Heat Detector - Restorable Spot | 2-046<br>314 | Muti Purpose Bldg Kitchen              | Manual          | 8/4/2025 6:48:16 AM  |
|                                 |              | Visual inspection                      | Passed (Manual) |                      |
|                                 |              | Functional Inspection                  | Passed          |                      |
| Manual Pull Station             | 2-145<br>299 | Muti Purpose Bldg Kitchen              | Manual          | 8/4/2025 6:49:59 AM  |
|                                 |              | Visual inspection                      | Passed (Manual) |                      |
|                                 |              | Functional Inspection                  | Passed          |                      |
| Heat Detector - Restorable Spot | 2-045<br>319 | Muti Purpose Bldg Kitchen Equip Closet | Manual          | 8/4/2025 1:30:36 PM  |
|                                 |              | Visual inspection                      | Passed (Manual) |                      |
|                                 |              | Functional Inspection                  | Passed          |                      |
| Heat Detector - Restorable Spot | 2-047<br>315 | Muti Purpose Bldg Kitchen Office       | Manual          | 8/4/2025 6:50:55 AM  |
|                                 |              | Visual inspection                      | Passed (Manual) |                      |
|                                 |              | Functional Inspection                  | Passed          |                      |
| Heat Detector - Restorable Spot | 2-043<br>317 | Muti Purpose Bldg Kitchen Pump Closet  | Manual          | 8/4/2025 1:28:17 PM  |
|                                 |              | Visual inspection                      | Passed (Manual) |                      |
|                                 |              | Functional Inspection                  | Passed          |                      |
| Heat Detector - Restorable Spot | 2-042<br>313 | Muti Purpose Bldg MP Chair Storage     | Manual          | 8/4/2025 1:21:17 PM  |
|                                 |              | Visual inspection                      | Passed (Manual) |                      |
|                                 |              | Functional Inspection                  | Passed          |                      |
| Smoke Detector - General        | 2-040<br>311 | Muti Purpose Bldg MP Room              | Manual          | 8/4/2025 6:38:25 AM  |
|                                 |              | Visual inspection                      | Passed (Manual) |                      |
|                                 |              | Functional Inspection                  | Passed          |                      |
| Smoke Detector - General        | 2-039<br>310 | Muti Purpose Bldg MP Room              | Manual          | 8/4/2025 6:38:41 AM  |
|                                 |              | Visual inspection                      | Passed (Manual) |                      |
|                                 |              | Functional Inspection                  | Passed          |                      |
| Smoke Detector - General        | 2-038<br>309 | Muti Purpose Bldg MP Room              | Manual          | 8/4/2025 6:38:51 AM  |
|                                 |              | Visual inspection                      | Passed (Manual) |                      |
|                                 |              | Functional Inspection                  | Passed          |                      |
| Smoke Detector - General        | 2-037<br>306 | Muti Purpose Bldg MP Room              | Manual          | 8/4/2025 6:39:48 AM  |
|                                 |              | Visual inspection                      | Passed (Manual) |                      |
|                                 |              | Functional Inspection                  | Passed          |                      |
| Smoke Detector - General        | 2-036<br>307 | Muti Purpose Bldg MP Room              | Manual          | 8/4/2025 6:39:55 AM  |
|                                 |              | Visual inspection                      | Passed (Manual) |                      |
|                                 |              | Functional Inspection                  | Passed          |                      |
| Smoke Detector - General        | 2-035<br>308 | Muti Purpose Bldg MP Room              | Manual          | 8/4/2025 6:40:35 AM  |
|                                 |              | Visual inspection                      | Passed (Manual) |                      |
|                                 |              | Functional Inspection                  | Passed          |                      |
| Smoke Detector - General        | 2-032<br>303 | Muti Purpose Bldg MP Room              | Manual          | 8/4/2025 6:40:49 AM  |
|                                 |              | Visual inspection                      | Passed (Manual) |                      |
|                                 |              | Functional Inspection                  | Passed          |                      |
| Smoke Detector - General        | 2-033<br>304 | Muti Purpose Bldg MP Room              | Manual          | 8/4/2025 6:41:05 AM  |
|                                 |              | Visual inspection                      | Passed (Manual) |                      |
|                                 |              | Functional Inspection                  | Passed          |                      |

| EQUIPMENT TYPE                  | ADDRESS      | DESCRIPTION                   | METHOD          | DATE/TIME            |
|---------------------------------|--------------|-------------------------------|-----------------|----------------------|
| Smoke Detector - General        | 2-034<br>305 | Muti Purpose Bldg MP Room     | Manual          | 8/4/2025 6:42:18 AM  |
|                                 |              | Visual inspection             | Passed (Manual) |                      |
|                                 |              | Functional Inspection         | Passed          |                      |
| Smoke Detector - General        | 2-031<br>300 | Muti Purpose Bldg MP Room     | Manual          | 8/4/2025 6:42:57 AM  |
|                                 |              | Visual inspection             | Passed (Manual) |                      |
|                                 |              | Functional Inspection         | Passed          |                      |
| Smoke Detector - General        | 2-030<br>301 | Muti Purpose Bldg MP Room     | Manual          | 8/4/2025 6:43:40 AM  |
|                                 |              | Visual inspection             | Passed (Manual) |                      |
|                                 |              | Functional Inspection         | Passed          |                      |
| Smoke Detector - General        | 2-029<br>302 | Muti Purpose Bldg MP Room     | Manual          | 8/4/2025 6:43:56 AM  |
|                                 |              | Visual inspection             | Passed (Manual) |                      |
|                                 |              | Functional Inspection         | Passed          |                      |
| Manual Pull Station             | 2-144<br>297 | Muti Purpose Bldg MP Room N E | Manual          | 8/4/2025 6:37:26 AM  |
|                                 |              | Visual inspection             | Passed (Manual) |                      |
|                                 |              | Functional Inspection         | Passed          |                      |
| Manual Pull Station             | 2-143<br>298 | Muti Purpose Bldg MP Room N W | Manual          | 8/4/2025 2:23:03 PM  |
|                                 |              | Visual inspection             | Passed (Manual) |                      |
|                                 |              | Functional Inspection         | Passed          |                      |
| Manual Pull Station             | 2-146<br>296 | Muti Purpose Bldg MP Room S E | Manual          | 8/4/2025 6:53:37 AM  |
|                                 |              | Visual inspection             | Passed (Manual) |                      |
|                                 |              | Functional Inspection         | Passed          |                      |
| Heat Detector - Restorable Spot | 2-388<br>280 | Portables Attic Room 23       | Manual          | 8/4/2025 12:49:51 PM |
|                                 |              | Visual inspection             | Passed (Manual) |                      |
|                                 |              | Functional Inspection         | Passed          |                      |
| Heat Detector - Restorable Spot | 2-388<br>279 | Portables Attic Room 23       | Manual          | 8/4/2025 2:51:27 PM  |
|                                 |              | Visual inspection             | Passed (Manual) |                      |
|                                 |              | Functional Inspection         | Passed          |                      |
| Heat Detector - Restorable Spot | 2-387<br>281 | Portables Attic Room 24       | Manual          | 8/4/2025 8:46:12 AM  |
|                                 |              | Visual inspection             | Passed (Manual) |                      |
|                                 |              | Functional Inspection         | Passed          |                      |
| Heat Detector - Restorable Spot | 2-387<br>282 | Portables Attic Room 24       | Manual          | 8/4/2025 8:46:14 AM  |
|                                 |              | Visual inspection             | Passed (Manual) |                      |
|                                 |              | Functional Inspection         | Passed          |                      |
| Heat Detector - Restorable Spot | 2-386<br>283 | Portables Attic Room 25       | Manual          | 8/4/2025 8:33:27 AM  |
|                                 |              | Visual inspection             | Passed (Manual) |                      |
|                                 |              | Functional Inspection         | Passed          |                      |
| Heat Detector - Restorable Spot | 2-386<br>284 | Portables Attic Room 25       | Manual          | 8/4/2025 8:33:29 AM  |
|                                 |              | Visual inspection             | Passed (Manual) |                      |
|                                 |              | Functional Inspection         | Passed          |                      |
| Heat Detector - Restorable Spot | 2-347<br>269 | Portables Room 23             | Manual          | 8/4/2025 8:54:18 AM  |
|                                 |              | Visual inspection             | Passed (Manual) |                      |
|                                 |              | Functional Inspection         | Passed          |                      |
| Heat Detector - Restorable Spot | 2-346<br>270 | Portables Room 23             | Manual          | 8/4/2025 8:54:48 AM  |
|                                 |              | Visual inspection             | Passed (Manual) |                      |
|                                 |              | Functional Inspection         | Passed          |                      |
| Manual Pull Station             | 2-165<br>262 | Portables Room 23             | Manual          | 8/4/2025 8:52:51 AM  |
|                                 |              | Visual inspection             | Passed (Manual) |                      |
|                                 |              | Functional Inspection         | Passed          |                      |

| EQUIPMENT TYPE                  | ADDRESS      | DESCRIPTION                        | METHOD          | DATE/TIME            |
|---------------------------------|--------------|------------------------------------|-----------------|----------------------|
| Heat Detector - Restorable Spot | 2-345<br>271 | Portables Room 24                  | Manual          | 8/4/2025 8:40:41 AM  |
|                                 |              | Visual inspection                  | Passed (Manual) |                      |
|                                 |              | Functional Inspection              | Passed          |                      |
| Heat Detector - Restorable Spot | 2-344<br>272 | Portables Room 24                  | Manual          | 8/4/2025 8:41:17 AM  |
|                                 |              | Visual inspection                  | Passed (Manual) |                      |
|                                 |              | Functional Inspection              | Passed          |                      |
| Manual Pull Station             | 2-164<br>263 | Portables Room 24                  | Manual          | 8/4/2025 8:39:44 AM  |
|                                 |              | Visual inspection                  | Passed (Manual) |                      |
|                                 |              | Functional Inspection              | Passed          |                      |
| Heat Detector - Restorable Spot | 2-343<br>273 | Portables Room 25                  | Manual          | 8/4/2025 8:27:27 AM  |
|                                 |              | Visual inspection                  | Passed (Manual) |                      |
|                                 |              | Functional Inspection              | Passed          |                      |
| Heat Detector - Restorable Spot | 2-342<br>274 | Portables Room 25                  | Manual          | 8/4/2025 8:28:11 AM  |
|                                 |              | Visual inspection                  | Passed (Manual) |                      |
|                                 |              | Functional Inspection              | Passed          |                      |
| Manual Pull Station             | 2-163<br>264 | Portables Room 25                  | Manual          | 8/4/2025 8:29:07 AM  |
|                                 |              | Visual inspection                  | Passed (Manual) |                      |
|                                 |              | Functional Inspection              | Passed          |                      |
| Smoke Detector - General        | 2-287<br>034 | Rms K1 & K2 Bldg Custodial Storage | Manual          | 8/4/2025 2:27:51 PM  |
|                                 |              | Visual inspection                  | Passed (Manual) |                      |
|                                 |              | Functional Inspection              | Passed          |                      |
| Smoke Detector - General        | 2-297<br>030 | Rms K1 & K2 Bldg Room K1           | Manual          | 8/4/2025 12:45:04 PM |
|                                 |              | Visual inspection                  | Passed (Manual) |                      |
|                                 |              | Functional Inspection              | Passed          |                      |
| Heat Detector - Restorable Spot | 2-299<br>035 | Rms K1 & K2 Bldg Room K1 by RR     | Manual          | 8/4/2025 12:51:50 PM |
|                                 |              | Visual inspection                  | Passed (Manual) |                      |
|                                 |              | Functional Inspection              | Passed          |                      |
| Manual Pull Station             | 2-172<br>028 | Rms K1 & K2 Bldg Room K1 Entry     | Manual          | 8/4/2025 12:45:32 PM |
|                                 |              | Visual inspection                  | Passed (Manual) |                      |
|                                 |              | Functional Inspection              | Passed          |                      |
| Heat Detector - Restorable Spot | 2-296<br>038 | Rms K1 & K2 Bldg Room K1 O S Strg  | Manual          | 8/4/2025 2:34:13 PM  |
|                                 |              | Visual inspection                  | Passed (Manual) |                      |
|                                 |              | Functional Inspection              | Passed          |                      |
| Heat Detector - Restorable Spot | 2-300<br>036 | Rms K1 & K2 Bldg Room K1 Restroom  | Manual          | 8/4/2025 12:52:15 PM |
|                                 |              | Visual inspection                  | Passed (Manual) |                      |
|                                 |              | Functional Inspection              | Passed          |                      |
| Heat Detector - Restorable Spot | 2-295<br>037 | Rms K1 & K2 Bldg Room K1 Storage   | Manual          | 8/4/2025 12:51:10 PM |
|                                 |              | Visual inspection                  | Passed (Manual) |                      |
|                                 |              | Functional Inspection              | Passed          |                      |
| Smoke Detector - General        | 2-292<br>032 | Rms K1 & K2 Bldg Room K2           | Manual          | 8/4/2025 12:43:49 PM |
|                                 |              | Visual inspection                  | Passed (Manual) |                      |
|                                 |              | Functional Inspection              | Passed          |                      |
| Smoke Detector - General        | 2-291<br>033 | Rms K1 & K2 Bldg Room K2           | Manual          | 8/4/2025 12:44:06 PM |
|                                 |              | Visual inspection                  | Passed (Manual) |                      |
|                                 |              | Functional Inspection              | Passed          |                      |
| Heat Detector - Restorable Spot | 2-289<br>039 | Rms K1 & K2 Bldg Room K2 by RR     | Manual          | 8/4/2025 12:49:26 PM |
|                                 |              | Visual inspection                  | Passed (Manual) |                      |
|                                 |              | Functional Inspection              | Passed          |                      |

| EQUIPMENT TYPE                  | ADDRESS      | DESCRIPTION                         | METHOD          | DATE/TIME            |
|---------------------------------|--------------|-------------------------------------|-----------------|----------------------|
| Manual Pull Station             | 2-173<br>029 | Rms K1 & K2 Bldg Room K2 Entry      | Manual          | 8/4/2025 12:53:43 PM |
|                                 |              | Visual inspection                   | Passed (Manual) |                      |
|                                 |              | Functional Inspection               | Passed          |                      |
| Heat Detector - Restorable Spot | 2-293<br>043 | Rms K1 & K2 Bldg Room K2 O S Strg   | Manual          | 8/4/2025 12:48:39 PM |
|                                 |              | Visual inspection                   | Passed (Manual) |                      |
|                                 |              | Functional Inspection               | Passed          |                      |
| Heat Detector - Restorable Spot | 2-290<br>040 | Rms K1 & K2 Bldg Room K2 Restroom   | Manual          | 8/4/2025 12:49:58 PM |
|                                 |              | Visual inspection                   | Passed (Manual) |                      |
|                                 |              | Functional Inspection               | Passed          |                      |
| Heat Detector - Restorable Spot | 2-294<br>042 | Rms K1 & K2 Bldg Room K2 Storage    | Manual          | 8/4/2025 12:50:31 PM |
|                                 |              | Visual inspection                   | Passed (Manual) |                      |
|                                 |              | Functional Inspection               | Passed          |                      |
| Heat Detector - Restorable Spot | 2-288<br>041 | Rms K1 & K2 Bldg Room K2 Strg by RR | Manual          | 8/4/2025 2:40:57 PM  |
|                                 |              | Visual inspection                   | Passed (Manual) |                      |
|                                 |              | Functional Inspection               | Passed          |                      |
| Heat Detector - Restorable Spot | 2-132<br>170 | Rooms 11 13 Bldg Elect Rm by Rm 11  | Manual          | 8/4/2025 7:40:00 AM  |
|                                 |              | Visual inspection                   | Passed (Manual) |                      |
|                                 |              | Functional Inspection               | Passed          |                      |
| Heat Detector - Restorable Spot | 2-065<br>165 | Rooms 11 13 Bldg Room 11            | Manual          | 8/4/2025 7:50:51 AM  |
|                                 |              | Visual inspection                   | Passed (Manual) |                      |
|                                 |              | Functional Inspection               | Passed          |                      |
| Heat Detector - Restorable Spot | 2-066<br>166 | Rooms 11 13 Bldg Room 11            | Manual          | 8/4/2025 7:51:03 AM  |
|                                 |              | Visual inspection                   | Passed (Manual) |                      |
|                                 |              | Functional Inspection               | Passed          |                      |
| Manual Pull Station             | 2-153<br>161 | Rooms 11 13 Bldg Room 11            | Manual          | 8/4/2025 7:56:01 AM  |
|                                 |              | Visual inspection                   | Passed (Manual) |                      |
|                                 |              | Functional Inspection               | Passed          |                      |
| Heat Detector - Restorable Spot | 2-067<br>167 | Rooms 11 13 Bldg Room 11 Storage    | Manual          | 8/4/2025 7:51:54 AM  |
|                                 |              | Visual inspection                   | Passed (Manual) |                      |
|                                 |              | Functional Inspection               | Passed          |                      |
| Heat Detector - Restorable Spot | 2-064<br>168 | Rooms 11 13 Bldg Room 12            | Manual          | 8/4/2025 7:53:53 AM  |
|                                 |              | Visual inspection                   | Passed (Manual) |                      |
|                                 |              | Functional Inspection               | Passed          |                      |
| Manual Pull Station             | 2-152<br>162 | Rooms 11 13 Bldg Room 12            | Manual          | 8/4/2025 7:55:19 AM  |
|                                 |              | Visual inspection                   | Passed (Manual) |                      |
|                                 |              | Functional Inspection               | Passed          |                      |
| Heat Detector - Restorable Spot | 2-063<br>169 | Rooms 11 13 Bldg Room 13            | Manual          | 8/4/2025 7:57:46 AM  |
|                                 |              | Visual inspection                   | Passed (Manual) |                      |
|                                 |              | Functional Inspection               | Passed          |                      |
| Manual Pull Station             | 2-151<br>163 | Rooms 11 13 Bldg Room 13            | Manual          | 8/4/2025 7:56:44 AM  |
|                                 |              | Visual inspection                   | Passed (Manual) |                      |
|                                 |              | Functional Inspection               | Passed          |                      |
| Smoke Detector - General        | 2.068<br>164 | Rooms 11 13 Bldg Teleco Rm by Rm 11 | Manual          | 8/4/2025 7:41:17 AM  |
|                                 |              | Visual inspection                   | Passed (Manual) |                      |
|                                 |              | Functional Inspection               | Passed          |                      |
| Heat Detector - Restorable Spot | 2-128<br>200 | Rooms 14 16 Bldg Attic Media Center | Manual          | 8/4/2025 1:56:51 PM  |
|                                 |              | Visual inspection                   | Passed (Manual) |                      |
|                                 |              | Functional Inspection               | Passed          |                      |

| EQUIPMENT TYPE                  | ADDRESS      | DESCRIPTION                           | METHOD          | DATE/TIME            |
|---------------------------------|--------------|---------------------------------------|-----------------|----------------------|
| Heat Detector - Restorable Spot | 2-128<br>199 | Rooms 14 16 Bldg Attic Media Center   | Manual          | 8/4/2025 1:56:52 PM  |
|                                 |              | Visual inspection                     | Passed (Manual) |                      |
|                                 |              | Functional Inspection                 | Passed          |                      |
| Heat Detector - Restorable Spot | 197          | Rooms 14 16 Bldg Attic Room 16        | Manual          | 8/4/2025 12:58:30 PM |
|                                 |              | Visual inspection                     | Passed (Manual) |                      |
|                                 |              | Functional Inspection                 | Passed          |                      |
| Heat Detector - Restorable Spot | 198          | Rooms 14 16 Bldg Attic Room 16        | Manual          | 8/4/2025 12:58:44 PM |
|                                 |              | Visual inspection                     | Passed (Manual) |                      |
|                                 |              | Functional Inspection                 | Passed          |                      |
| Heat Detector - Restorable Spot | 2-061<br>195 | Rooms 14 16 Bldg Boys RR by Room 14   | Manual          | 8/4/2025 7:12:47 AM  |
|                                 |              | Visual inspection                     | Passed (Manual) |                      |
|                                 |              | Functional Inspection                 | Passed          |                      |
| Smoke Detector - General        | 2-058<br>186 | Rooms 14 16 Bldg Computer Lab         | Manual          | 8/4/2025 7:04:37 AM  |
|                                 |              | Visual inspection                     | Passed (Manual) |                      |
|                                 |              | Functional Inspection                 | Passed          |                      |
| Smoke Detector - General        | 2-057<br>185 | Rooms 14 16 Bldg Computer Lab         | Manual          | 8/4/2025 7:04:47 AM  |
|                                 |              | Visual inspection                     | Passed (Manual) |                      |
|                                 |              | Functional Inspection                 | Passed          |                      |
| Heat Detector - Restorable Spot | 2-062<br>196 | Rooms 14 16 Bldg Girls RR by Room 14  | Manual          | 8/4/2025 7:14:06 AM  |
|                                 |              | Visual inspection                     | Passed (Manual) |                      |
|                                 |              | Functional Inspection                 | Passed          |                      |
| Manual Pull Station             | 2-147<br>182 | Rooms 14 16 Bldg Library              | Manual          | 8/4/2025 2:16:07 PM  |
|                                 |              | Visual inspection                     | Passed (Manual) |                      |
|                                 |              | Functional Inspection                 | Passed          |                      |
| Smoke Detector - General        | 2-052<br>189 | Rooms 14 16 Bldg Media Center Library | Manual          | 8/4/2025 6:56:00 AM  |
|                                 |              | Visual inspection                     | Passed (Manual) |                      |
|                                 |              | Functional Inspection                 | Passed          |                      |
| Smoke Detector - General        | 2-051<br>190 | Rooms 14 16 Bldg Media Center Library | Manual          | 8/4/2025 6:56:09 AM  |
|                                 |              | Visual inspection                     | Passed (Manual) |                      |
|                                 |              | Functional Inspection                 | Passed          |                      |
| Smoke Detector - General        | 2-049<br>191 | Rooms 14 16 Bldg Media Center Library | Manual          | 8/4/2025 6:56:31 AM  |
|                                 |              | Visual inspection                     | Passed (Manual) |                      |
|                                 |              | Functional Inspection                 | Passed          |                      |
| Smoke Detector - General        | 2-050<br>192 | Rooms 14 16 Bldg Media Ctr Read Rm    | Manual          | 8/4/2025 6:58:14 AM  |
|                                 |              | Visual inspection                     | Passed (Manual) |                      |
|                                 |              | Functional Inspection                 | Passed          |                      |
| Heat Detector - Restorable Spot | 2-059<br>193 | Rooms 14 16 Bldg Room 14              | Manual          | 8/4/2025 7:10:17 AM  |
|                                 |              | Visual inspection                     | Passed (Manual) |                      |
|                                 |              | Functional Inspection                 | Passed          |                      |
| Heat Detector - Restorable Spot | 2-060<br>194 | Rooms 14 16 Bldg Room 14              | Manual          | 8/4/2025 7:10:36 AM  |
|                                 |              | Visual inspection                     | Passed (Manual) |                      |
|                                 |              | Functional Inspection                 | Passed          |                      |
| Manual Pull Station             | 2-150<br>179 | Rooms 14 16 Bldg Room 14              | Manual          | 8/4/2025 7:08:37 AM  |
|                                 |              | Visual inspection                     | Passed (Manual) |                      |
|                                 |              | Functional Inspection                 | Passed          |                      |
| Manual Pull Station             | 2-149<br>180 | Rooms 14 16 Bldg Room 15              | Manual          | 8/4/2025 7:03:57 AM  |
|                                 |              | Visual inspection                     | Passed (Manual) |                      |
|                                 |              | Functional Inspection                 | Passed          |                      |

| EQUIPMENT TYPE                  | ADDRESS      | DESCRIPTION                          | METHOD          | DATE/TIME           |
|---------------------------------|--------------|--------------------------------------|-----------------|---------------------|
| Smoke Detector - General        | 2-055<br>184 | Rooms 14 16 Bldg Room 15             | Manual          | 8/4/2025 7:02:01 AM |
|                                 |              | Visual inspection                    | Passed (Manual) |                     |
|                                 |              | Functional Inspection                | Passed          |                     |
| Smoke Detector - General        | 2-056<br>183 | Rooms 14 16 Bldg Room 15             | Manual          | 8/4/2025 7:02:15 AM |
|                                 |              | Visual inspection                    | Passed (Manual) |                     |
|                                 |              | Functional Inspection                | Passed          |                     |
| Manual Pull Station             | 2-148<br>181 | Rooms 14 16 Bldg Room 16             | Manual          | 8/4/2025 7:03:25 AM |
|                                 |              | Visual inspection                    | Passed (Manual) |                     |
|                                 |              | Functional Inspection                | Passed          |                     |
| Smoke Detector - General        | 2-054<br>187 | Rooms 14 16 Bldg Room 16             | Manual          | 8/4/2025 7:01:19 AM |
|                                 |              | Visual inspection                    | Passed (Manual) |                     |
|                                 |              | Functional Inspection                | Passed          |                     |
| Smoke Detector - General        | 2-053<br>188 | Rooms 14 16 Bldg Room 16 Storage     | Manual          | 8/4/2025 2:20:26 PM |
|                                 |              | Visual inspection                    | Passed (Manual) |                     |
|                                 |              | Functional Inspection                | Passed          |                     |
| Heat Detector - Restorable Spot | 2-077<br>225 | Rooms 17 19 Bldg Boys RR by Room 19  | Manual          | 8/4/2025 7:21:02 AM |
|                                 |              | Visual inspection                    | Passed (Manual) |                     |
|                                 |              | Functional Inspection                | Passed          |                     |
| Heat Detector - Restorable Spot | 2-078<br>224 | Rooms 17 19 Bldg Girls RR by Room 19 | Manual          | 8/4/2025 7:23:16 AM |
|                                 |              | Visual inspection                    | Passed (Manual) |                     |
|                                 |              | Functional Inspection                | Passed          |                     |
| Heat Detector - Restorable Spot | 2-082<br>220 | Rooms 17 19 Bldg Room 17             | Manual          | 8/4/2025 7:32:34 AM |
|                                 |              | Visual inspection                    | Passed (Manual) |                     |
|                                 |              | Functional Inspection                | Passed          |                     |
| Heat Detector - Restorable Spot | 2-083<br>219 | Rooms 17 19 Bldg Room 17             | Manual          | 8/4/2025 7:33:10 AM |
|                                 |              | Visual inspection                    | Passed (Manual) |                     |
|                                 |              | Functional Inspection                | Passed          |                     |
| Manual Pull Station             | 2-142<br>215 | Rooms 17 19 Bldg Room 17             | Manual          | 8/4/2025 7:31:39 AM |
|                                 |              | Visual inspection                    | Passed (Manual) |                     |
|                                 |              | Functional Inspection                | Passed          |                     |
| Heat Detector - Restorable Spot | 2-084<br>221 | Rooms 17 19 Bldg Room 17 Office      | Manual          | 8/4/2025 7:34:37 AM |
|                                 |              | Visual inspection                    | Passed (Manual) |                     |
|                                 |              | Functional Inspection                | Passed          |                     |
| Smoke Detector - General        | 2-085<br>218 | Rooms 17 19 Bldg Room 17 Storage     | Manual          | 8/4/2025 7:35:57 AM |
|                                 |              | Visual inspection                    | Passed (Manual) |                     |
|                                 |              | Functional Inspection                | Passed          |                     |
| Heat Detector - Restorable Spot | 2-081<br>222 | Rooms 17 19 Bldg Room 18             | Manual          | 8/4/2025 7:28:38 AM |
|                                 |              | Visual inspection                    | Passed (Manual) |                     |
|                                 |              | Functional Inspection                | Passed          |                     |
| Manual Pull Station             | 2-141<br>216 | Rooms 17 19 Bldg Room 18             | Manual          | 8/4/2025 7:29:33 AM |
|                                 |              | Visual inspection                    | Passed (Manual) |                     |
|                                 |              | Functional Inspection                | Passed          |                     |
| Heat Detector - Restorable Spot | 2-080<br>223 | Rooms 17 19 Bldg Room 19             | Manual          | 8/4/2025 7:25:54 AM |
|                                 |              | Visual inspection                    | Passed (Manual) |                     |
|                                 |              | Functional Inspection                | Passed          |                     |
| Manual Pull Station             | 2-140<br>217 | Rooms 17 19 Bldg Room 19             | Manual          | 8/4/2025 7:30:22 AM |
|                                 |              | Visual inspection                    | Passed (Manual) |                     |
|                                 |              | Functional Inspection                | Passed          |                     |

| EQUIPMENT TYPE                  | ADDRESS      | DESCRIPTION                          | METHOD          | DATE/TIME            |
|---------------------------------|--------------|--------------------------------------|-----------------|----------------------|
| Smoke Detector - General        | 2-086<br>240 | Rooms 20 22 Bldg Cust Off By Rm 22   | Manual          | 8/4/2025 1:33:01 PM  |
|                                 |              | Visual inspection                    | Passed (Manual) |                      |
|                                 |              | Functional Inspection                | Passed          |                      |
| Heat Detector - Restorable Spot | 2-075<br>248 | Rooms 20 22 Bldg Mens Staff RR       | Manual          | 8/4/2025 7:16:32 AM  |
|                                 |              | Visual inspection                    | Passed (Manual) |                      |
|                                 |              | Functional Inspection                | Passed          |                      |
| Heat Detector - Restorable Spot | 2-072<br>241 | Rooms 20 22 Bldg Room 20             | Manual          | 8/4/2025 1:40:38 PM  |
|                                 |              | Visual inspection                    | Passed (Manual) |                      |
|                                 |              | Functional Inspection                | Passed          |                      |
| Heat Detector - Restorable Spot | 2-071<br>242 | Rooms 20 22 Bldg Room 20             | Manual          | 8/4/2025 1:40:40 PM  |
|                                 |              | Visual inspection                    | Passed (Manual) |                      |
|                                 |              | Functional Inspection                | Passed          |                      |
| Manual Pull Station             | 2-139<br>237 | Rooms 20 22 Bldg Room 20             | Manual          | 8/4/2025 1:41:55 PM  |
|                                 |              | Visual inspection                    | Passed (Manual) |                      |
|                                 |              | Functional Inspection                | Passed          |                      |
| Heat Detector - Restorable Spot | 2-070<br>243 | Rooms 20 22 Bldg Room 21             | Manual          | 8/4/2025 1:39:05 PM  |
|                                 |              | Visual inspection                    | Passed (Manual) |                      |
|                                 |              | Functional Inspection                | Passed          |                      |
| Manual Pull Station             | 2-138<br>238 | Rooms 20 22 Bldg Room 21             | Manual          | 8/4/2025 1:38:10 PM  |
|                                 |              | Visual inspection                    | Passed (Manual) |                      |
|                                 |              | Functional Inspection                | Passed          |                      |
| Heat Detector - Restorable Spot | 2-069<br>244 | Rooms 20 22 Bldg Room 22             | Manual          | 8/4/2025 1:36:58 PM  |
|                                 |              | Visual inspection                    | Passed (Manual) |                      |
|                                 |              | Functional Inspection                | Passed          |                      |
| Manual Pull Station             | 2-137<br>239 | Rooms 20 22 Bldg Room 22             | Manual          | 8/4/2025 1:36:21 PM  |
|                                 |              | Visual inspection                    | Passed (Manual) |                      |
|                                 |              | Functional Inspection                | Passed          |                      |
| Heat Detector - Restorable Spot | 2-131<br>245 | Rooms 20 22 Bldg Storage by Cust Off | Manual          | 8/4/2025 1:34:26 PM  |
|                                 |              | Visual inspection                    | Passed (Manual) |                      |
|                                 |              | Functional Inspection                | Passed          |                      |
| Heat Detector - Restorable Spot | 2-076<br>247 | Rooms 20 22 Bldg Storage by Rm 20    | Manual          | 8/4/2025 7:17:29 AM  |
|                                 |              | Visual inspection                    | Passed (Manual) |                      |
|                                 |              | Functional Inspection                | Passed          |                      |
| Heat Detector - Restorable Spot | 2-073<br>246 | Rooms 20 22 Bldg Womens Staff RR     | Manual          | 8/4/2025 7:19:14 AM  |
|                                 |              | Visual inspection                    | Passed (Manual) |                      |
|                                 |              | Functional Inspection                | Passed          |                      |
| Heat Detector - Restorable Spot | 104          | Rooms 3 8 Bldg Attic Hall by Room 4  | Manual          | 8/4/2025 12:58:20 PM |
|                                 |              | Visual inspection                    | Passed (Manual) |                      |
|                                 |              | Functional Inspection                | Passed          |                      |
| Heat Detector - Restorable Spot | 2-382<br>105 | Rooms 3 8 Bldg Attic Hall by Room 5  | Manual          | 8/4/2025 10:06:17 AM |
|                                 |              | Visual inspection                    | Passed (Manual) |                      |
|                                 |              | Functional Inspection                | Passed          |                      |
| Heat Detector - Restorable Spot | 2-379<br>092 | Rooms 3 8 Bldg Attic Room 3          | Manual          | 8/4/2025 10:35:16 AM |
|                                 |              | Visual inspection                    | Passed (Manual) |                      |
|                                 |              | Functional Inspection                | Passed          |                      |
| Heat Detector - Restorable Spot | 2-379<br>093 | Rooms 3 8 Bldg Attic Room 3          | Manual          | 8/4/2025 10:35:17 AM |
|                                 |              | Visual inspection                    | Passed (Manual) |                      |
|                                 |              | Functional Inspection                | Passed          |                      |

| EQUIPMENT TYPE                  | ADDRESS      | DESCRIPTION                          | METHOD          | DATE/TIME            |
|---------------------------------|--------------|--------------------------------------|-----------------|----------------------|
| Heat Detector - Restorable Spot | 2-380<br>094 | Rooms 3 8 Bldg Attic Room 4          | Manual          | 8/4/2025 8:56:20 AM  |
|                                 |              | Visual inspection                    | Passed (Manual) |                      |
|                                 |              | Functional Inspection                | Passed          |                      |
| Heat Detector - Restorable Spot | 2-380<br>095 | Rooms 3 8 Bldg Attic Room 4          | Manual          | 8/4/2025 8:56:21 AM  |
|                                 |              | Visual inspection                    | Passed (Manual) |                      |
|                                 |              | Functional Inspection                | Passed          |                      |
| Heat Detector - Restorable Spot | 2-376<br>101 | Rooms 3 8 Bldg Attic Room 7          | Manual          | 8/4/2025 10:34:50 AM |
|                                 |              | Visual inspection                    | Passed (Manual) |                      |
|                                 |              | Functional Inspection                | Passed          |                      |
| Heat Detector - Restorable Spot | 2-389<br>103 | Rooms 3 8 Bldg Attic Room 8          | Manual          | 8/4/2025 10:25:50 AM |
|                                 |              | Visual inspection                    | Passed (Manual) |                      |
|                                 |              | Functional Inspection                | Passed          |                      |
| Heat Detector - Restorable Spot | 2-389<br>102 | Rooms 3 8 Bldg Attic Room 8          | Manual          | 8/4/2025 10:25:52 AM |
|                                 |              | Visual inspection                    | Passed (Manual) |                      |
|                                 |              | Functional Inspection                | Passed          |                      |
| Manual Pull Station             | 2-168<br>057 | Rooms 3 8 Bldg Boys RR by Room 7     | Manual          | 8/4/2025 10:01:53 AM |
|                                 |              | Visual inspection                    | Passed (Manual) |                      |
|                                 |              | Functional Inspection                | Passed          |                      |
| Manual Pull Station             | 2-166<br>054 | Rooms 3 8 Bldg Hall by Room 3        | Manual          | 8/4/2025 9:35:54 AM  |
|                                 |              | Visual inspection                    | Passed (Manual) |                      |
|                                 |              | Functional Inspection                | Passed          |                      |
| Manual Pull Station             | 2-169<br>059 | Rooms 3 8 Bldg Hall S E by Room 8    | Manual          | 8/4/2025 9:10:18 AM  |
|                                 |              | Visual inspection                    | Passed (Manual) |                      |
|                                 |              | Functional Inspection                | Passed          |                      |
| Heat Detector - Restorable Spot | 2-275<br>085 | Rooms 3 8 Bldg Hallway by Room 3     | Manual          | 8/4/2025 9:34:47 AM  |
|                                 |              | Visual inspection                    | Passed (Manual) |                      |
|                                 |              | Functional Inspection                | Passed          |                      |
| Heat Detector - Restorable Spot | 2-281<br>086 | Rooms 3 8 Bldg Hallway by Room 4     | Manual          | 8/4/2025 10:03:25 AM |
|                                 |              | Visual inspection                    | Passed (Manual) |                      |
|                                 |              | Functional Inspection                | Passed          |                      |
| Heat Detector - Restorable Spot | 2-282<br>087 | Rooms 3 8 Bldg Hallway by Room 8     | Manual          | 8/4/2025 9:09:52 AM  |
|                                 |              | Visual inspection                    | Passed (Manual) |                      |
|                                 |              | Functional Inspection                | Passed          |                      |
| Heat Detector - Restorable Spot | 2-272<br>089 | Rooms 3 8 Bldg Hist Bldg Boys RR     | Manual          | 8/4/2025 9:21:42 AM  |
|                                 |              | Visual inspection                    | Passed (Manual) |                      |
|                                 |              | Functional Inspection                | Passed          |                      |
| Heat Detector - Restorable Spot | 090          | Rooms 3 8 Bldg Hist Bldg Girls RR    | Manual          | 8/4/2025 12:58:22 PM |
|                                 |              | Visual inspection                    | Passed (Manual) |                      |
|                                 |              | Functional Inspection                | Passed          |                      |
| Heat Detector - Restorable Spot | 2-274<br>091 | Rooms 3 8 Bldg Hist bldg RR plbm chs | Manual          | 8/4/2025 9:11:23 AM  |
|                                 |              | Visual inspection                    | Passed (Manual) |                      |
|                                 |              | Functional Inspection                | Passed          |                      |
| Heat Detector - Restorable Spot | 2-277<br>088 | Rooms 3 8 Bldg Hist Bldg Staff RR    | Manual          | 8/4/2025 9:22:10 AM  |
|                                 |              | Visual inspection                    | Passed (Manual) |                      |
|                                 |              | Functional Inspection                | Passed          |                      |
| Heat Detector - Restorable Spot | 2-264<br>061 | Rooms 3 8 Bldg Room 3                | Manual          | 8/4/2025 9:37:16 AM  |
|                                 |              | Visual inspection                    | Passed (Manual) |                      |
|                                 |              | Functional Inspection                | Passed          |                      |

| EQUIPMENT TYPE                  | ADDRESS      | DESCRIPTION           | METHOD          | DATE/TIME           |
|---------------------------------|--------------|-----------------------|-----------------|---------------------|
| Heat Detector - Restorable Spot | 2-265<br>062 | Rooms 3 8 Bldg Room 3 | Manual          | 8/4/2025 9:37:52 AM |
|                                 |              | Visual inspection     | Passed (Manual) |                     |
|                                 |              | Functional Inspection | Passed          |                     |
| Heat Detector - Restorable Spot | 2-266<br>063 | Rooms 3 8 Bldg Room 3 | Manual          | 8/4/2025 9:38:08 AM |
|                                 |              | Visual inspection     | Passed (Manual) |                     |
|                                 |              | Functional Inspection | Passed          |                     |
| Heat Detector - Restorable Spot | 2-263<br>064 | Rooms 3 8 Bldg Room 3 | Manual          | 8/4/2025 9:40:06 AM |
|                                 |              | Visual inspection     | Passed (Manual) |                     |
|                                 |              | Functional Inspection | Passed          |                     |
| Manual Pull Station             | 2-167<br>055 | Rooms 3 8 Bldg Room 3 | Manual          | 8/4/2025 9:39:04 AM |
|                                 |              | Visual inspection     | Passed (Manual) |                     |
|                                 |              | Functional Inspection | Passed          |                     |
| Heat Detector - Restorable Spot | 2-270<br>065 | Rooms 3 8 Bldg Room 4 | Manual          | 8/4/2025 9:26:40 AM |
|                                 |              | Visual inspection     | Passed (Manual) |                     |
|                                 |              | Functional Inspection | Passed          |                     |
| Heat Detector - Restorable Spot | 2-268<br>067 | Rooms 3 8 Bldg Room 4 | Manual          | 8/4/2025 9:27:18 AM |
|                                 |              | Visual inspection     | Passed (Manual) |                     |
|                                 |              | Functional Inspection | Passed          |                     |
| Heat Detector - Restorable Spot | 2-267<br>068 | Rooms 3 8 Bldg Room 4 | Manual          | 8/4/2025 9:27:40 AM |
|                                 |              | Visual inspection     | Passed (Manual) |                     |
|                                 |              | Functional Inspection | Passed          |                     |
| Heat Detector - Restorable Spot | 2-269<br>066 | Rooms 3 8 Bldg Room 4 | Manual          | 8/4/2025 9:28:31 AM |
|                                 |              | Visual inspection     | Passed (Manual) |                     |
|                                 |              | Functional Inspection | Passed          |                     |
| Heat Detector - Restorable Spot | 2-260<br>069 | Rooms 3 8 Bldg Room 5 | Manual          | 8/4/2025 9:31:25 AM |
|                                 |              | Visual inspection     | Passed (Manual) |                     |
|                                 |              | Functional Inspection | Passed          |                     |
| Heat Detector - Restorable Spot | 2-261<br>070 | Rooms 3 8 Bldg Room 5 | Manual          | 8/4/2025 9:32:05 AM |
|                                 |              | Visual inspection     | Passed (Manual) |                     |
|                                 |              | Functional Inspection | Passed          |                     |
| Heat Detector - Restorable Spot | 2-262<br>071 | Rooms 3 8 Bldg Room 5 | Manual          | 8/4/2025 9:32:34 AM |
|                                 |              | Visual inspection     | Passed (Manual) |                     |
|                                 |              | Functional Inspection | Passed          |                     |
| Heat Detector - Restorable Spot | 2-259<br>072 | Rooms 3 8 Bldg Room 5 | Manual          | 8/4/2025 1:26:32 PM |
|                                 |              | Visual inspection     | Passed (Manual) |                     |
|                                 |              | Functional Inspection | Passed          |                     |
| Heat Detector - Restorable Spot | 2-255<br>075 | Rooms 3 8 Bldg Room 6 | Manual          | 8/4/2025 9:23:30 AM |
|                                 |              | Visual inspection     | Passed (Manual) |                     |
|                                 |              | Functional Inspection | Passed          |                     |
| Heat Detector - Restorable Spot | 2-256<br>074 | Rooms 3 8 Bldg Room 6 | Manual          | 8/4/2025 9:23:48 AM |
|                                 |              | Visual inspection     | Passed (Manual) |                     |
|                                 |              | Functional Inspection | Passed          |                     |
| Heat Detector - Restorable Spot | 2-257<br>076 | Rooms 3 8 Bldg Room 6 | Manual          | 8/4/2025 9:24:30 AM |
|                                 |              | Visual inspection     | Passed (Manual) |                     |
|                                 |              | Functional Inspection | Passed          |                     |
| Heat Detector - Restorable Spot | 2-258<br>073 | Rooms 3 8 Bldg Room 6 | Manual          | 8/4/2025 9:29:51 AM |
|                                 |              | Visual inspection     | Passed (Manual) |                     |
|                                 |              | Functional Inspection | Passed          |                     |

| EQUIPMENT TYPE                  | ADDRESS      | DESCRIPTION                           | METHOD          | DATE/TIME           |
|---------------------------------|--------------|---------------------------------------|-----------------|---------------------|
| Heat Detector - Restorable Spot | 2-251<br>077 | Rooms 3 8 Bldg Room 7                 | Manual          | 8/4/2025 8:59:13 AM |
|                                 |              | Visual inspection                     | Passed (Manual) |                     |
|                                 |              | Functional Inspection                 | Passed          |                     |
| Heat Detector - Restorable Spot | 2-253<br>078 | Rooms 3 8 Bldg Room 7                 | Manual          | 8/4/2025 8:59:46 AM |
|                                 |              | Visual inspection                     | Passed (Manual) |                     |
|                                 |              | Functional Inspection                 | Passed          |                     |
| Heat Detector - Restorable Spot | 2-254<br>079 | Rooms 3 8 Bldg Room 7                 | Manual          | 8/4/2025 9:00:15 AM |
|                                 |              | Visual inspection                     | Passed (Manual) |                     |
|                                 |              | Functional Inspection                 | Passed          |                     |
| Heat Detector - Restorable Spot | 2-252<br>080 | Rooms 3 8 Bldg Room 7                 | Manual          | 8/4/2025 9:01:19 AM |
|                                 |              | Visual inspection                     | Passed (Manual) |                     |
|                                 |              | Functional Inspection                 | Passed          |                     |
| Manual Pull Station             | 2-170<br>056 | Rooms 3 8 Bldg Room 7                 | Manual          | 8/4/2025 9:09:07 AM |
|                                 |              | Visual inspection                     | Passed (Manual) |                     |
|                                 |              | Functional Inspection                 | Passed          |                     |
| Heat Detector - Restorable Spot | 2-278<br>081 | Rooms 3 8 Bldg Room 8                 | Manual          | 8/4/2025 9:13:53 AM |
|                                 |              | Visual inspection                     | Passed (Manual) |                     |
|                                 |              | Functional Inspection                 | Passed          |                     |
| Heat Detector - Restorable Spot | 2-279<br>082 | Rooms 3 8 Bldg Room 8                 | Manual          | 8/4/2025 9:14:23 AM |
|                                 |              | Visual inspection                     | Passed (Manual) |                     |
|                                 |              | Functional Inspection                 | Passed          |                     |
| Heat Detector - Restorable Spot | 2-280<br>083 | Rooms 3 8 Bldg Room 8                 | Manual          | 8/4/2025 9:14:46 AM |
|                                 |              | Visual inspection                     | Passed (Manual) |                     |
|                                 |              | Functional Inspection                 | Passed          |                     |
| Manual Pull Station             | 2-171<br>058 | Rooms 3 8 Bldg Room 8                 | Manual          | 8/4/2025 9:13:15 AM |
|                                 |              | Visual inspection                     | Passed (Manual) |                     |
|                                 |              | Functional Inspection                 | Passed          |                     |
| Smoke Detector - General        | 2-276<br>060 | Rooms 3 8 Bldg Room 8                 | Manual          | 8/4/2025 9:50:17 AM |
|                                 |              | Visual inspection                     | Passed (Manual) |                     |
|                                 |              | Functional Inspection                 | Passed          |                     |
| Heat Detector - Restorable Spot | 2-041<br>084 | Rooms 3 8 Bldg Room 8 Cust Strg       | Manual          | 8/4/2025 1:26:00 PM |
|                                 | Comment:     | No access                             |                 |                     |
|                                 |              | Visual inspection                     | Passed (Manual) |                     |
|                                 |              | Functional Inspection                 | Passed          |                     |
| Heat Detector - Restorable Spot | 2-023<br>144 | Rooms 9 & 10 Area Art Room 9          | Manual          | 8/4/2025 1:49:25 PM |
|                                 |              | Visual inspection                     | Passed (Manual) |                     |
|                                 |              | Functional Inspection                 | Passed          |                     |
| Manual Pull Station             | 2-156<br>139 | Rooms 9 & 10 Area Art Room 9          | Manual          | 8/4/2025 1:56:24 PM |
|                                 |              | Visual inspection                     | Passed (Manual) |                     |
|                                 |              | Functional Inspection                 | Passed          |                     |
| Heat Detector - Restorable Spot | 2-022<br>149 | Rooms 9 & 10 Area Hallway by Art Rm 9 | Manual          | 8/4/2025 1:54:50 PM |
|                                 |              | Visual inspection                     | Passed (Manual) |                     |
|                                 |              | Functional Inspection                 | Passed          |                     |
| Heat Detector - Restorable Spot | 2-016<br>147 | Rooms 9 & 10 Area Hallway by Room 10  | Manual          | 8/4/2025 1:55:37 PM |
|                                 |              | Visual inspection                     | Passed (Manual) |                     |
|                                 |              | Functional Inspection                 | Passed          |                     |
| Heat Detector - Restorable Spot | 2-019<br>148 | Rooms 9 & 10 Area Hallway by Room 9   | Manual          | 8/4/2025 1:55:14 PM |
|                                 |              | Visual inspection                     | Passed (Manual) |                     |
|                                 |              | Functional Inspection                 | Passed          |                     |

| EQUIPMENT TYPE                  | ADDRESS      | DESCRIPTION                           | METHOD          | DATE/TIME            |
|---------------------------------|--------------|---------------------------------------|-----------------|----------------------|
| Manual Pull Station             | 2-157<br>137 | Rooms 9 & 10 Area Hallway East Exit   | Manual          | 8/4/2025 1:53:12 PM  |
|                                 |              | Visual inspection                     | Passed (Manual) |                      |
|                                 |              | Functional Inspection                 | Passed          |                      |
| Manual Pull Station             | 2-158<br>138 | Rooms 9 & 10 Area Hallway West Exit   | Manual          | 8/4/2025 1:48:41 PM  |
|                                 |              | Visual inspection                     | Passed (Manual) |                      |
|                                 |              | Functional Inspection                 | Passed          |                      |
| Heat Detector - Restorable Spot | 2-020<br>142 | Rooms 9 & 10 Area Reading Room 9      | Manual          | 8/4/2025 2:00:46 PM  |
|                                 |              | Visual inspection                     | Passed (Manual) |                      |
|                                 |              | Functional Inspection                 | Passed          |                      |
| Heat Detector - Restorable Spot | 2-024<br>150 | Rooms 9 & 10 Area Restroom by Art Rm  | Manual          | 8/4/2025 2:02:48 PM  |
|                                 |              | Visual inspection                     | Passed (Manual) |                      |
|                                 |              | Functional Inspection                 | Passed          |                      |
| Heat Detector - Restorable Spot | 2-014<br>146 | Rooms 9 & 10 Area Room 10             | Manual          | 8/4/2025 1:57:41 PM  |
|                                 |              | Visual inspection                     | Passed (Manual) |                      |
|                                 |              | Functional Inspection                 | Passed          |                      |
| Heat Detector - Restorable Spot | 2-015        | Rooms 9 & 10 Area Room 10             | Manual          | 8/4/2025 1:57:47 PM  |
|                                 |              | Visual inspection                     | Passed (Manual) |                      |
|                                 |              | Functional Inspection                 | Passed          |                      |
| Heat Detector - Restorable Spot | 2-017<br>141 | Rooms 9 & 10 Area Room 9              | Manual          | 8/4/2025 1:59:22 PM  |
|                                 |              | Visual inspection                     | Passed (Manual) |                      |
|                                 |              | Functional Inspection                 | Passed          |                      |
| Heat Detector - Restorable Spot | 2-018<br>140 | Rooms 9 & 10 Area Room 9              | Manual          | 8/4/2025 1:59:44 PM  |
|                                 |              | Visual inspection                     | Passed (Manual) |                      |
|                                 |              | Functional Inspection                 | Passed          |                      |
| Heat Detector - Restorable Spot | 2-021<br>143 | Rooms 9 & 10 Area Speech Room 9       | Manual          | 8/4/2025 2:02:05 PM  |
|                                 |              | Visual inspection                     | Passed (Manual) |                      |
|                                 |              | Functional Inspection                 | Passed          |                      |
| Heat Detector - Restorable Spot | 401          | White House Bldg Attic North          | Manual          | 8/4/2025 12:23:19 PM |
|                                 |              | Visual inspection                     | Passed (Manual) |                      |
|                                 |              | Functional Inspection                 | Passed          |                      |
| Heat Detector - Restorable Spot | 2-385<br>402 | White House Bldg Attic South Hall     | Manual          | 8/4/2025 12:48:23 PM |
|                                 |              | Visual inspection                     | Passed (Manual) |                      |
|                                 |              | Functional Inspection                 | Passed          |                      |
| Heat Detector - Restorable Spot | 2-324<br>395 | White House Bldg Child Waiting Closet | Manual          | 8/4/2025 12:48:07 PM |
|                                 |              | Visual inspection                     | Passed (Manual) |                      |
|                                 |              | Functional Inspection                 | Passed          |                      |
| Smoke Detector - General        | 2-325<br>356 | White House Bldg Child Waiting Room   | Manual          | 8/4/2025 12:36:59 PM |
|                                 |              | Visual inspection                     | Passed (Manual) |                      |
|                                 |              | Functional Inspection                 | Passed          |                      |
| Smoke Detector - General        | 2-311<br>387 | White House Bldg Copier Room          | Manual          | 8/4/2025 12:30:23 PM |
|                                 |              | Visual inspection                     | Passed (Manual) |                      |
|                                 |              | Functional Inspection                 | Passed          |                      |
| Smoke Detector - General        | 2-348<br>359 | White House Bldg File Room by Recept  | Manual          | 8/4/2025 12:48:06 PM |
|                                 |              | Visual inspection                     | Passed (Manual) |                      |
|                                 |              | Functional Inspection                 | Passed          |                      |
| Smoke Detector - General        | 393          | White House Bldg Hall by MediCal Off  | Manual          | 8/4/2025 12:22:57 PM |
|                                 |              | Visual inspection                     | Passed (Manual) |                      |
|                                 |              | Functional Inspection                 | Passed          |                      |
| Smoke Detector - General        | 2-303<br>383 | White House Bldg Hall by Office 10    | Manual          | 8/4/2025 12:18:23 PM |

| EQUIPMENT TYPE                  | ADDRESS      | DESCRIPTION                                | METHOD                    | DATE/TIME            |
|---------------------------------|--------------|--|---------------------------|----------------------|
|                                 |              | Visual inspection<br>Functional Inspection | Passed (Manual)<br>Passed |                      |
| Smoke Detector - General        | 2-328<br>361 | White House Bldg Hall by Office 2          | Manual                    | 8/4/2025 12:08:46 PM |
|                                 |              | Visual inspection<br>Functional Inspection | Passed (Manual)<br>Passed |                      |
| Smoke Detector - General        | 2-336<br>370 | White House Bldg Hall by Office 4          | Manual                    | 8/4/2025 12:04:30 PM |
|                                 |              | Visual inspection<br>Functional Inspection | Passed (Manual)<br>Passed |                      |
| Smoke Detector - General        | 2-323<br>373 | White House Bldg Hall by Restroom          | Manual                    | 8/4/2025 12:17:32 PM |
|                                 |              | Visual inspection<br>Functional Inspection | Passed (Manual)<br>Passed |                      |
| Smoke Detector - General        | 367          | White House Bldg Hall by Room 16           | Manual                    | 8/4/2025 12:23:11 PM |
|                                 |              | Visual inspection<br>Functional Inspection | Passed (Manual)<br>Passed |                      |
| Smoke Detector - General        | 2-317<br>379 | White House Bldg Hall by Room 7            | Manual                    | 8/4/2025 12:21:03 PM |
|                                 |              | Visual inspection<br>Functional Inspection | Passed (Manual)<br>Passed |                      |
| Smoke Detector - General        | 2-319<br>375 | White House Bldg Hall by Room 9            | Manual                    | 8/4/2025 12:20:42 PM |
|                                 |              | Visual inspection<br>Functional Inspection | Passed (Manual)<br>Passed |                      |
| Smoke Detector - General        | 2-332<br>363 | White House Bldg Hall by Video Room        | Manual                    | 8/4/2025 12:05:03 PM |
|                                 |              | Visual inspection<br>Functional Inspection | Passed (Manual)<br>Passed |                      |
| Manual Pull Station             | 2-175<br>354 | White House Bldg Hall North                | Manual                    | 8/4/2025 12:48:10 PM |
|                                 |              | Visual inspection<br>Functional Inspection | Passed (Manual)<br>Passed |                      |
| Manual Pull Station             | 2-180<br>348 | White House Bldg Hall Southwest            | Manual                    | 8/4/2025 12:48:02 PM |
|                                 |              | Visual inspection<br>Functional Inspection | Passed (Manual)<br>Passed |                      |
| Smoke Detector - General        | 2-310<br>388 | White House Bldg Hallway by Storage        | Manual                    | 8/4/2025 12:48:19 PM |
|                                 |              | Visual inspection<br>Functional Inspection | Passed (Manual)<br>Passed |                      |
| Heat Detector - Restorable Spot | 2-381<br>400 | White House Bldg Intern Building           | Manual                    | 8/4/2025 1:14:22 PM  |
|                                 |              | Visual inspection<br>Functional Inspection | Passed (Manual)<br>Passed |                      |
| Heat Detector - Restorable Spot | 2-381<br>399 | White House Bldg Intern Building           | Manual                    | 8/4/2025 1:14:24 PM  |
|                                 |              | Visual inspection<br>Functional Inspection | Passed (Manual)<br>Passed |                      |
| Heat Detector - Restorable Spot | 2-381<br>398 | White House Bldg Intern Building           | Manual                    | 8/4/2025 1:14:26 PM  |
|                                 |              | Visual inspection<br>Functional Inspection | Passed (Manual)<br>Passed |                      |
| Heat Detector - Restorable Spot | 2-320<br>396 | White House Bldg Kitchen                   | Manual                    | 8/4/2025 12:26:45 PM |
|                                 |              | Visual inspection<br>Functional Inspection | Passed (Manual)<br>Passed |                      |
| Smoke Detector - General        | 394          | White House Bldg MediCal Office            | Manual                    | 8/4/2025 12:23:02 PM |
|                                 |              | Visual inspection<br>Functional Inspection | Passed (Manual)<br>Passed |                      |
| Smoke Detector - General        | 2-338<br>360 | White House Bldg Office 1                  | Manual                    | 8/4/2025 12:03:25 PM |
|                                 |              | Visual inspection<br>Functional Inspection | Passed (Manual)<br>Passed |                      |

| EQUIPMENT TYPE           | ADDRESS      | DESCRIPTION                        | METHOD          | DATE/TIME            |
|--------------------------|--------------|------------------------------------|-----------------|----------------------|
| Manual Pull Station      | 2-179<br>350 | White House Bldg Office 10         | Manual          | 8/4/2025 12:21:48 PM |
|                          |              | Visual inspection                  | Passed (Manual) |                      |
|                          |              | Functional Inspection              | Passed          |                      |
| Smoke Detector - General | 2-302<br>384 | White House Bldg Office 10         | Manual          | 8/4/2025 12:22:46 PM |
|                          |              | Visual inspection                  | Passed (Manual) |                      |
|                          |              | Functional Inspection              | Passed          |                      |
| Smoke Detector - General | 2-304<br>385 | White House Bldg Office 11         | Manual          | 8/4/2025 12:22:48 PM |
|                          |              | Visual inspection                  | Passed (Manual) |                      |
|                          |              | Functional Inspection              | Passed          |                      |
| Manual Pull Station      | 2-176<br>351 | White House Bldg Office 12         | Manual          | 8/4/2025 12:32:39 PM |
|                          |              | Visual inspection                  | Passed (Manual) |                      |
|                          |              | Functional Inspection              | Passed          |                      |
| Smoke Detector - General | 364          | White House Bldg Office 15         | Manual          | 8/4/2025 12:23:12 PM |
|                          |              | Visual inspection                  | Passed (Manual) |                      |
|                          |              | Functional Inspection              | Passed          |                      |
| Smoke Detector - General | 2-326<br>365 | White House Bldg Office 16         | Manual          | 8/4/2025 12:09:51 PM |
|                          |              | Visual inspection                  | Passed (Manual) |                      |
|                          |              | Functional Inspection              | Passed          |                      |
| Manual Pull Station      | 2-182<br>347 | White House Bldg Office 2          | Manual          | 8/4/2025 12:14:44 PM |
|                          |              | Visual inspection                  | Passed (Manual) |                      |
|                          |              | Functional Inspection              | Passed          |                      |
| Smoke Detector - General | 2-337<br>362 | White House Bldg Office 2          | Manual          | 8/4/2025 12:04:42 PM |
|                          |              | Visual inspection                  | Passed (Manual) |                      |
|                          |              | Functional Inspection              | Passed          |                      |
| Smoke Detector - General | 2-329<br>368 | White House Bldg Office 3          | Manual          | 8/4/2025 12:08:58 PM |
|                          |              | Visual inspection                  | Passed (Manual) |                      |
|                          |              | Functional Inspection              | Passed          |                      |
| Smoke Detector - General | 2-327<br>371 | White House Bldg Office 4          | Manual          | 8/4/2025 12:09:29 PM |
|                          |              | Visual inspection                  | Passed (Manual) |                      |
|                          |              | Functional Inspection              | Passed          |                      |
| Smoke Detector - General | 2-330<br>369 | White House Bldg Office 5          | Manual          | 8/4/2025 12:10:14 PM |
|                          |              | Visual inspection                  | Passed (Manual) |                      |
|                          |              | Functional Inspection              | Passed          |                      |
| Smoke Detector - General | 372          | White House Bldg Office 6          | Manual          | 8/4/2025 12:23:04 PM |
|                          |              | Visual inspection                  | Passed (Manual) |                      |
|                          |              | Functional Inspection              | Passed          |                      |
| Smoke Detector - General | 2-301<br>386 | White House Bldg Paint Room        | Manual          | 8/4/2025 12:29:18 PM |
|                          |              | Visual inspection                  | Passed (Manual) |                      |
|                          |              | Functional Inspection              | Passed          |                      |
| Smoke Detector - General | 2-340<br>358 | White House Bldg Reception         | Manual          | 8/4/2025 12:03:11 PM |
|                          |              | Visual inspection                  | Passed (Manual) |                      |
|                          |              | Functional Inspection              | Passed          |                      |
| Smoke Detector - General | 2.333<br>357 | White House Bldg Reception Hall    | Manual          | 8/4/2025 12:03:04 PM |
|                          |              | Visual inspection                  | Passed (Manual) |                      |
|                          |              | Functional Inspection              | Passed          |                      |
| Smoke Detector - General | 2-341<br>355 | White House Bldg Reception Waiting | Manual          | 8/4/2025 12:02:31 PM |
|                          |              | Visual inspection                  | Passed (Manual) |                      |
|                          |              | Functional Inspection              | Passed          |                      |
| Smoke Detector - General | 2-322<br>374 | White House Bldg Restroom          | Manual          | 8/4/2025 12:17:39 PM |

| EQUIPMENT TYPE                     | ADDRESS      | DESCRIPTION                                | METHOD                    | DATE/TIME            |
|------------------------------------|--------------|--|---------------------------|----------------------|
|                                    |              | Visual inspection<br>Functional Inspection | Passed (Manual)<br>Passed |                      |
| Smoke Detector - General           | 2-321<br>382 | White House Bldg Restroom by<br>Kitchen    | Manual                    | 8/4/2025 12:18:07 PM |
|                                    |              | Visual inspection<br>Functional Inspection | Passed (Manual)<br>Passed |                      |
| Manual Pull Station                | 2-178<br>349 | White House Bldg Room 13                   | Manual                    | 8/4/2025 12:48:09 PM |
|                                    |              | Visual inspection<br>Functional Inspection | Passed (Manual)<br>Passed |                      |
| Smoke Detector - General           | 2-315<br>378 | White House Bldg Room 13                   | Manual                    | 8/4/2025 12:21:23 PM |
|                                    |              | Visual inspection<br>Functional Inspection | Passed (Manual)<br>Passed |                      |
| Smoke Detector - General           | 381          | White House Bldg Room 14                   | Manual                    | 8/4/2025 12:23:15 PM |
|                                    |              | Visual inspection<br>Functional Inspection | Passed (Manual)<br>Passed |                      |
| Smoke Detector - General           | 2-316<br>380 | White House Bldg Room 7                    | Manual                    | 8/4/2025 12:23:33 PM |
|                                    |              | Visual inspection<br>Functional Inspection | Passed (Manual)<br>Passed |                      |
| Smoke Detector - General           | 2-314<br>377 | White House Bldg Room 8                    | Manual                    | 8/4/2025 12:23:38 PM |
|                                    |              | Visual inspection<br>Functional Inspection | Passed (Manual)<br>Passed |                      |
| Smoke Detector - General           | 2-350<br>376 | White House Bldg Room 9                    | Manual                    | 8/4/2025 12:20:10 PM |
|                                    |              | Visual inspection<br>Functional Inspection | Passed (Manual)<br>Passed |                      |
| Smoke Detector - General           | 2-312<br>390 | White House Bldg Storage Hallway           | Manual                    | 8/4/2025 12:38:49 PM |
|                                    |              | Visual inspection<br>Functional Inspection | Passed (Manual)<br>Passed |                      |
| Smoke Detector - General           | 2-307<br>389 | White House Bldg Storage Hallway           | Manual                    | 8/4/2025 12:48:22 PM |
|                                    |              | Visual inspection<br>Functional Inspection | Passed (Manual)<br>Passed |                      |
| Smoke Detector - General           | 2-309<br>392 | White House Bldg Storage Room              | Manual                    | 8/4/2025 12:38:51 PM |
|                                    |              | Visual inspection<br>Functional Inspection | Passed (Manual)<br>Passed |                      |
| Smoke Detector - General           | 2-308<br>391 | White House Bldg Storage Room              | Manual                    | 8/4/2025 12:48:16 PM |
|                                    |              | Visual inspection<br>Functional Inspection | Passed (Manual)<br>Passed |                      |
| Heat Detector - Restorable<br>Spot | 2-313        | White House Bldg Storage Room by<br>12     | Manual                    | 8/4/2025 12:36:01 PM |
|                                    |              | Visual inspection<br>Functional Inspection | Passed (Manual)<br>Passed |                      |
| Manual Pull Station                | 2-177<br>352 | White House Bldg Storage South             | Manual                    | 8/4/2025 12:34:05 PM |
|                                    |              | Visual inspection<br>Functional Inspection | Passed (Manual)<br>Passed |                      |
| Manual Pull Station                | 2-174<br>353 | White House Bldg Storage West              | Manual                    | 8/4/2025 12:48:17 PM |
|                                    |              | Visual inspection<br>Functional Inspection | Passed (Manual)<br>Passed |                      |
| Heat Detector - Restorable<br>Spot | 397          | White House Bldg Strg by MediCal Off       | Manual                    | 8/4/2025 12:22:55 PM |
|                                    |              | Visual inspection<br>Functional Inspection | Passed (Manual)<br>Passed |                      |
| Smoke Detector - General           | 2-331<br>366 | White House Bldg Video Room                | Manual                    | 8/4/2025 12:48:04 PM |
|                                    |              | Visual inspection<br>Functional Inspection | Passed (Manual)<br>Passed |                      |

| EQUIPMENT TYPE      | ADDRESS      | DESCRIPTION                   | METHOD          | DATE/TIME            |
|---------------------|--------------|-------------------------------|-----------------|----------------------|
| Manual Pull Station | 2-181<br>346 | White House Bldg Waiting Room | Manual          | 8/4/2025 12:22:44 PM |
|                     |              | Visual inspection             | Passed (Manual) |                      |
|                     |              | Functional Inspection         | Passed          |                      |

Skipped

| EQUIPMENT TYPE                  | ADDRESS      | DESCRIPTION                            | METHOD | DATE/TIME            |
|---------------------------------|--------------|--|--------|----------------------|
| Heat Detector - Restorable Spot | 320          | Muti Purpose Bldg Attic Kitchen        | Manual | 8/4/2025 1:25:23 PM  |
| Heat Detector - Restorable Spot | 321          | Muti Purpose Bldg Attic Kitchen Office | Manual | 8/4/2025 12:18:12 PM |
| Heat Detector - Restorable Spot | 316          | Muti Purpose Bldg MP Cust Storage      | Manual | 8/4/2025 1:25:20 PM  |
| Heat Detector - Restorable Spot | 2-048<br>312 | Muti Purpose Bldg MP Room Foyer        | Manual | 8/4/2025 2:05:51 PM  |
| Heat Detector - Restorable Spot | 226          | Rooms 17 19 Bldg Plumb Chs by Rm 19    | Manual | 8/4/2025 1:25:13 PM  |
| Heat Detector - Restorable Spot | 2.378<br>097 | Rooms 3 8 Bldg Attic Room 5            | Manual | 8/4/2025 10:21:18 AM |
|                                 | Comment:     | No access                              |        |                      |
| Heat Detector - Restorable Spot | 2.378<br>096 | Rooms 3 8 Bldg Attic Room 5            | Manual | 8/4/2025 10:21:32 AM |
|                                 | Comment:     | No access                              |        |                      |
| Heat Detector - Restorable Spot | 2-377<br>099 | Rooms 3 8 Bldg Attic Room 6            | Manual | 8/4/2025 10:21:47 AM |
|                                 | Comment:     | No access                              |        |                      |
| Heat Detector - Restorable Spot | 2-377<br>098 | Rooms 3 8 Bldg Attic Room 6            | Manual | 8/4/2025 10:21:54 AM |
|                                 | Comment:     | No access                              |        |                      |
| Heat Detector - Restorable Spot | 100          | Rooms 3 8 Bldg Attic Room 7            | Manual | 8/4/2025 10:34:53 AM |

Power Supplies

Passed

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION                            | METHOD          | DATE/TIME           |
|----------------|---------|--|-----------------|---------------------|
| Primary Power  | 052     | Rms K1 & K2 Bldg Room K2 O S Strg      | Manual          | 8/4/2025 2:12:37 PM |
|                |         | Visual inspection                      | Passed (Manual) |                     |
|                |         | Functional Inspection                  | Passed          |                     |
| Primary Power  | 177     | Rooms 11 13 Bldg Teleco Rm by Rm 11    | Manual          | 8/4/2025 1:24:41 PM |
|                |         | Visual inspection                      | Passed (Manual) |                     |
|                |         | Functional Inspection                  | Passed          |                     |
| Primary Power  | 176     | Rooms 11 13 Bldg Teleco Rm by Rm 11    | Manual          | 8/4/2025 1:24:56 PM |
|                |         | Visual inspection                      | Passed (Manual) |                     |
|                |         | Functional Inspection                  | Passed          |                     |
| Primary Power  | 212     | Rooms 14 16 Bldg Room 15               | Manual          | 8/4/2025 2:12:39 PM |
|                |         | Visual inspection                      | Passed (Manual) |                     |
|                |         | Functional Inspection                  | Passed          |                     |
| Primary Power  | 213     | Rooms 14 16 Bldg Room 15               | Manual          | 8/4/2025 2:12:41 PM |
|                |         | Visual inspection                      | Passed (Manual) |                     |
|                |         | Functional Inspection                  | Passed          |                     |
| Primary Power  | 260     | Rooms 20 22 Bldg Cust Off By Rm 22     | Manual          | 8/4/2025 2:12:42 PM |
|                |         | Visual inspection                      | Passed (Manual) |                     |
|                |         | Functional Inspection                  | Passed          |                     |
| Primary Power  | 135     | Rooms 3 8 Bldg Hall by Room 8 (Bottom) | Manual          | 8/4/2025 9:53:37 AM |
|                |         | Visual inspection                      | Passed (Manual) |                     |
|                |         | Functional Inspection                  | Passed          |                     |
| Primary Power  | 134     | Rooms 3 8 Bldg Hall by Room 8 (Top)    | Manual          | 8/4/2025 9:52:43 AM |
|                |         | Visual inspection                      | Passed (Manual) |                     |
|                |         | Functional Inspection                  | Passed          |                     |
| Primary Power  | 438     | White House Bldg Paint Room            | Manual          | 8/4/2025 2:12:44 PM |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION           | METHOD          | DATE/TIME |
|----------------|---------|-----------------------|-----------------|-----------|
|                |         | Visual inspection     | Passed (Manual) |           |
|                |         | Functional Inspection | Passed          |           |

## Device/Equipment Details

### Alarm Notification Appliance

| ADDRESS             | DESCRIPTION                           | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
|---------------------|---------------------------------------|--------------|-------|--------|--------------|
| Audible             |                                       |              |       |        |              |
| 018                 | Admin Area South Exterior             |              |       |        |              |
| 044                 | Rms K1 & K2 Bldg South Exterior       |              |       |        |              |
| 106                 | Rooms 3 8 Bldg East Exterior          |              |       |        |              |
| 107                 | Rooms 3 8 Bldg South Exterior         |              |       |        |              |
| 108                 | Rooms 3 8 Bldg West Exterior          |              |       |        |              |
| 151                 | Rooms 9 & 10 Area Southeast Exterior  |              |       |        |              |
| 171                 | Rooms 11 13 Bldg Southeast Exterior   |              |       |        |              |
| 172                 | Rooms 11 13 Bldg West Exterior        |              |       |        |              |
| 201                 | Rooms 14 16 Bldg Southwest Exterior   |              |       |        |              |
| 227                 | Rooms 17 19 Bldg Northeast Exterior   |              |       |        |              |
| 228                 | Rooms 17 19 Bldg Southeast Exterior   |              |       |        |              |
| 249                 | Rooms 20 22 Bldg Northeast Exterior   |              |       |        |              |
| 250                 | Rooms 20 22 Bldg Northwest Exterior   |              |       |        |              |
| 251                 | Rooms 20 22 Bldg Southeast Exterior   |              |       |        |              |
| 252                 | Rooms 20 22 Bldg Southwest Exterior   |              |       |        |              |
| 285                 | Portables West Exterior               |              |       |        |              |
| 286                 | Portables West Exterior               |              |       |        |              |
| 287                 | Portables West Exterior               |              |       |        |              |
| 340                 | Discovery Club Bldg South Exterior    |              |       |        |              |
| 403                 | White House Bldg East Exterior        |              |       |        |              |
| 404                 | White House Bldg West Exterior        |              |       |        |              |
| Audible And Visible |                                       |              |       |        |              |
| 019                 | Admin Area Work Room                  |              |       |        |              |
| 020                 | Admin Area Office North Entry         |              |       |        |              |
| 021                 | Admin Area Staff Break Room           |              |       |        |              |
| 045                 | Rms K1 & K2 Bldg Room K1              |              |       |        |              |
| 046                 | Rms K1 & K2 Bldg Room K2              |              |       |        |              |
| 109                 | Rooms 3 8 Bldg Room 3                 |              |       |        |              |
| 110                 | Rooms 3 8 Bldg Room 4                 |              |       |        |              |
| 111                 | Rooms 3 8 Bldg Room 5                 |              |       |        |              |
| 112                 | Rooms 3 8 Bldg Room 6                 |              |       |        |              |
| 113                 | Rooms 3 8 Bldg Room 7                 |              |       |        |              |
| 114                 | Rooms 3 8 Bldg Room 8                 |              |       |        |              |
| 115                 | Rooms 3 8 Bldg Hallway by Room 3      |              |       |        |              |
| 116                 | Rooms 3 8 Bldg Hallway by Room 6      |              |       |        |              |
| 117                 | Rooms 3 8 Bldg Hallway by Room 7      |              |       |        |              |
| 118                 | Rooms 3 8 Bldg Hall S E by Room 8     |              |       |        |              |
| 152                 | Rooms 9 & 10 Area Room 9              |              |       |        |              |
| 153                 | Rooms 9 & 10 Area Room 10             |              |       |        |              |
| 154                 | Rooms 9 & 10 Area Hallway by Room 10  |              |       |        |              |
| 155                 | Rooms 9 & 10 Area Hallway by Art Rm 9 |              |       |        |              |

| ADDRESS | DESCRIPTION                           | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
|---------|---------------------------------------|--------------|-------|--------|--------------|
| 173     | Rooms 11 13 Bldg Room 11              |              |       |        |              |
| 174     | Rooms 11 13 Bldg Room 12              |              |       |        |              |
| 175     | Rooms 11 13 Bldg Room 13              |              |       |        |              |
| 202     | Rooms 14 16 Bldg Room 14              |              |       |        |              |
| 203     | Rooms 14 16 Bldg Room 15              |              |       |        |              |
| 204     | Rooms 14 16 Bldg Computer Lab         |              |       |        |              |
| 205     | Rooms 14 16 Bldg Media Center Library |              |       |        |              |
| 229     | Rooms 17 19 Bldg Room 17              |              |       |        |              |
| 230     | Rooms 17 19 Bldg Room 18              |              |       |        |              |
| 231     | Rooms 17 19 Bldg Room 19              |              |       |        |              |
| 253     | Rooms 20 22 Bldg Room 20              |              |       |        |              |
| 254     | Rooms 20 22 Bldg Room 21              |              |       |        |              |
| 255     | Rooms 20 22 Bldg Room 22              |              |       |        |              |
| 256     | Rooms 20 22 Bldg Cust Off Rm 22       |              |       |        |              |
| 288     | Portables Room 23                     |              |       |        |              |
| 289     | Portables Room 24                     |              |       |        |              |
| 290     | Portables Room 25                     |              |       |        |              |
| 291     | Portables Room 28                     |              |       |        |              |
| 292     | Portables Room 28                     |              |       |        |              |
| 322     | Muti Purpose Bldg MP Room             |              |       |        |              |
| 323     | Muti Purpose Bldg MP Room             |              |       |        |              |
| 324     | Muti Purpose Bldg MP Room             |              |       |        |              |
| 325     | Muti Purpose Bldg MP Room             |              |       |        |              |
| 326     | Muti Purpose Bldg Kitchen             |              |       |        |              |
| 341     | Discovery Club Bldg Discovery Club    |              |       |        |              |
| 405     | White House Bldg Hall by Office 10    |              |       |        |              |
| 406     | White House Bldg Hallway by Storage   |              |       |        |              |
| 407     | White House Bldg Storage Room         |              |       |        |              |
| 408     | White House Bldg Hall by Room 9       |              |       |        |              |
| 409     | White House Bldg Kitchen              |              |       |        |              |
| 410     | White House Bldg Hall by Office 4     |              |       |        |              |
| 411     | White House Bldg Hall by Office 2     |              |       |        |              |
| Visible |                                       |              |       |        |              |
| 022     | Admin Area Reception                  |              |       |        |              |
| 023     | Admin Area Principals Office          |              |       |        |              |
| 024     | Admin Area Hall by Work Room          |              |       |        |              |
| 025     | Admin Area Office Staff Restroom      |              |       |        |              |
| 026     | Admin Area Nurses Office              |              |       |        |              |
| 047     | Rms K1 & K2 Bldg Room K1 by RR        |              |       |        |              |
| 048     | Rms K1 & K2 Bldg Room K1 Restroom     |              |       |        |              |
| 049     | Rms K1 & K2 Bldg Room K2 by RR        |              |       |        |              |
| 050     | Rms K1 & K2 Bldg Room K2 Restroom     |              |       |        |              |
| 051     | Rms K1 & K2 Bldg Room K2 Strg by RR   |              |       |        |              |
| 119     | Rooms 3 8 Bldg Room 3                 |              |       |        |              |
| 120     | Rooms 3 8 Bldg Room 3                 |              |       |        |              |
| 121     | Rooms 3 8 Bldg Room 4                 |              |       |        |              |

| ADDRESS | DESCRIPTION                               | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
|---------|---|--------------|-------|--------|--------------|
| 122     | Rooms 3 8 Bldg Room 4                     |              |       |        |              |
| 123     | Rooms 3 8 Bldg Room 5                     |              |       |        |              |
| 124     | Rooms 3 8 Bldg Room 5                     |              |       |        |              |
| 125     | Rooms 3 8 Bldg Room 6                     |              |       |        |              |
| 126     | Rooms 3 8 Bldg Room 6                     |              |       |        |              |
| 127     | Rooms 3 8 Bldg Room 7                     |              |       |        |              |
| 128     | Rooms 3 8 Bldg Room 7                     |              |       |        |              |
| 129     | Rooms 3 8 Bldg Room 8                     |              |       |        |              |
| 130     | Rooms 3 8 Bldg Room 8                     |              |       |        |              |
| 131     | Rooms 3 8 Bldg Hist Bldg Staff RR         |              |       |        |              |
| 132     | Rooms 3 8 Bldg Hist Bldg Boys RR          |              |       |        |              |
| 133     | Rooms 3 8 Bldg Hist Bldg Girls RR         |              |       |        |              |
| 156     | Rooms 9 & 10 Area Reading Room 9          |              |       |        |              |
| 157     | Rooms 9 & 10 Area Speech Room 9           |              |       |        |              |
| 158     | Rooms 9 & 10 Area Art Room 9              |              |       |        |              |
| 159     | Rooms 9 & 10 Area Restroom by Art Rm      |              |       |        |              |
| 206     | Rooms 14 16 Bldg Room 16                  |              |       |        |              |
| 207     | Rooms 14 16 Bldg Room 16 Storage          |              |       |        |              |
| 208     | Rooms 14 16 Bldg Media Center Library     |              |       |        |              |
| 209     | Rooms 14 16 Bldg Media Ctr Read Rm        |              |       |        |              |
| 210     | Rooms 14 16 Bldg Boys RR by Room 14       |              |       |        |              |
| 211     | Rooms 14 16 Bldg Girls RR by Room 14      |              |       |        |              |
| 232     | Rooms 17 19 Bldg Room 17 Office           |              |       |        |              |
| 233     | Rooms 17 19 Bldg Room 17 Storage          |              |       |        |              |
| 234     | Rooms 17 19 Bldg                          |              |       |        |              |
| 235     | Rooms 17 19 Bldg                          |              |       |        |              |
| 257     | Rooms 20 22 Bldg Womens Staff RR          |              |       |        |              |
| 258     | Rooms 20 22 Bldg Mens Staff RR            |              |       |        |              |
| 259     | Rooms 20 22 Bldg Storage by Rm 20         |              |       |        |              |
| 294     | Portables Room 28                         |              |       |        |              |
| 327     | Muti Purpose Bldg Kitchen Office          |              |       |        |              |
| 342     | Discovery Club Bldg Discovery Club Office |              |       |        |              |
| 343     | Discovery Club Bldg Discovery Club RR     |              |       |        |              |
| 344     | Discovery Club Bldg Discovery Club RR     |              |       |        |              |
| 412     | White House Bldg Paint Room               |              |       |        |              |
| 413     | White House Bldg Office 10                |              |       |        |              |
| 414     | White House Bldg Office 11                |              |       |        |              |
| 415     | White House Bldg Hall by MediCal Off      |              |       |        |              |
| 416     | White House Bldg MediCal Office           |              |       |        |              |
| 417     | White House Bldg Hallway by Storage       |              |       |        |              |
| 418     | White House Bldg Room 8                   |              |       |        |              |
| 419     | White House Bldg Room 13                  |              |       |        |              |
| 420     | White House Bldg Room 7                   |              |       |        |              |

| ADDRESS | DESCRIPTION                          | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
|---------|--------------------------------------|--------------|-------|--------|--------------|
| 421     | White House Bldg Room 14             |              |       |        |              |
| 422     | White House Bldg Restroom by Kitchen |              |       |        |              |
| 423     | White House Bldg Restroom            |              |       |        |              |
| 424     | White House Bldg Hall by Restroom    |              |       |        |              |
| 425     | White House Bldg Child Waiting Room  |              |       |        |              |
| 426     | White House Bldg Office 16           |              |       |        |              |
| 427     | White House Bldg Office 4            |              |       |        |              |
| 428     | White House Bldg Office 3            |              |       |        |              |
| 429     | White House Bldg Office 5            |              |       |        |              |
| 430     | White House Bldg Video Room          |              |       |        |              |
| 431     | White House Bldg Office 16           |              |       |        |              |
| 432     | White House Bldg Office 15           |              |       |        |              |
| 433     | White House Bldg Office 2            |              |       |        |              |
| 434     | White House Bldg Office 1            |              |       |        |              |
| 435     | White House Bldg Reception           |              |       |        |              |
| 436     | White House Bldg File Room by Recept |              |       |        |              |
| 437     | White House Bldg Room 9              |              |       |        |              |

### Fire Control Panel

| ADDRESS                  | DESCRIPTION                         | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
|--------------------------|-------------------------------------|--------------|-------|--------|--------------|
| Remote Annunciator       |                                     |              |       |        |              |
| 001                      | Admin Area Reception                |              |       |        |              |
| Fire Alarm Control Panel |                                     |              |       |        |              |
|                          | Rooms 11 13 Bldg Teleco Rm by Rm 11 | EST          |       |        | 10/05/2023   |

### Initiating Device

| ADDRESS             | DESCRIPTION                         | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
|---------------------|-------------------------------------|--------------|-------|--------|--------------|
| Manual Pull Station |                                     |              |       |        |              |
| 2-155<br>002        | Admin Area Office South Entry       |              |       |        |              |
| 2-126<br>003        | Admin Area Reception                |              |       |        |              |
| 2-154<br>004        | Admin Area Office North Entry       |              |       |        |              |
| 2-172<br>028        | Rms K1 & K2 Bldg Room K1 Entry      |              |       |        |              |
| 2-173<br>029        | Rms K1 & K2 Bldg Room K2 Entry      |              |       |        |              |
| 2-166<br>054        | Rooms 3 8 Bldg Hall by Room 3       |              |       |        |              |
| 2-167<br>055        | Rooms 3 8 Bldg Room 3               |              |       |        |              |
| 2-170<br>056        | Rooms 3 8 Bldg Room 7               |              |       |        |              |
| 2-168<br>057        | Rooms 3 8 Bldg Boys RR by Room 7    |              |       |        |              |
| 2-171<br>058        | Rooms 3 8 Bldg Room 8               |              |       |        |              |
| 2-169<br>059        | Rooms 3 8 Bldg Hall S E by Room 8   |              |       |        |              |
| 2-157<br>137        | Rooms 9 & 10 Area Hallway East Exit |              |       |        |              |
| 2-158<br>138        | Rooms 9 & 10 Area Hallway West Exit |              |       |        |              |
| 2-156<br>139        | Rooms 9 & 10 Area Art Room 9        |              |       |        |              |
| 2-153<br>161        | Rooms 11 13 Bldg Room 11            |              |       |        |              |
| 2-152<br>162        | Rooms 11 13 Bldg Room 12            |              |       |        |              |
| 2-151<br>163        | Rooms 11 13 Bldg Room 13            |              |       |        |              |

| ADDRESS                  | DESCRIPTION                        | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
|--------------------------|------------------------------------|--------------|-------|--------|--------------|
| 2-150<br>179             | Rooms 14 16 Bldg Room 14           |              |       |        |              |
| 2-149<br>180             | Rooms 14 16 Bldg Room 15           |              |       |        |              |
| 2-148<br>181             | Rooms 14 16 Bldg Room 16           |              |       |        |              |
| 2-147<br>182             | Rooms 14 16 Bldg Library           |              |       |        |              |
| 2-142<br>215             | Rooms 17 19 Bldg Room 17           |              |       |        |              |
| 2-141<br>216             | Rooms 17 19 Bldg Room 18           |              |       |        |              |
| 2-140<br>217             | Rooms 17 19 Bldg Room 19           |              |       |        |              |
| 2-139<br>237             | Rooms 20 22 Bldg Room 20           |              |       |        |              |
| 2-138<br>238             | Rooms 20 22 Bldg Room 21           |              |       |        |              |
| 2-137<br>239             | Rooms 20 22 Bldg Room 22           |              |       |        |              |
| 2-165<br>262             | Portables Room 23                  |              |       |        |              |
| 2-164<br>263             | Portables Room 24                  |              |       |        |              |
| 2-163<br>264             | Portables Room 25                  |              |       |        |              |
| 2-146<br>296             | Muti Purpose Bldg MP Room S<br>E   |              |       |        |              |
| 2-144<br>297             | Muti Purpose Bldg MP Room N<br>E   |              |       |        |              |
| 2-143<br>298             | Muti Purpose Bldg MP Room N<br>W   |              |       |        |              |
| 2-145<br>299             | Muti Purpose Bldg Kitchen          |              |       |        |              |
| 2-184<br>329             | Discovery Club Bldg East Exit      |              |       |        |              |
| 2-183<br>330             | Discovery Club Bldg West Exit      |              |       |        |              |
| 2-181<br>346             | White House Bldg Waiting Room      |              |       |        |              |
| 2-182<br>347             | White House Bldg Office 2          |              |       |        |              |
| 2-180<br>348             | White House Bldg Hall<br>Southwest |              |       |        |              |
| 2-178<br>349             | White House Bldg Room 13           |              |       |        |              |
| 2-179<br>350             | White House Bldg Office 10         |              |       |        |              |
| 2-176<br>351             | White House Bldg Office 12         |              |       |        |              |
| 2-177<br>352             | White House Bldg Storage<br>South  |              |       |        |              |
| 2-174<br>353             | White House Bldg Storage West      |              |       |        |              |
| 2-175<br>354             | White House Bldg Hall North        |              |       |        |              |
| Smoke Detector - General |                                    |              |       |        |              |
| 2-007<br>005             | Admin Area Waiting Area            |              |       |        |              |
| 2-003<br>006             | Admin Area Reception               |              |       |        |              |
| 2-004<br>007             | Admin Area Principals Office       |              |       |        |              |
| 2-001<br>008             | Admin Area Work Room               |              |       |        |              |
| 2-008<br>009             | Admin Area Nurses Office           |              |       |        |              |
| 2-006<br>010             | Admin Area Waiting Area            |              |       |        |              |
| 2-297<br>030             | Rms K1 & K2 Bldg Room K1           |              |       |        |              |
| 2-292<br>032             | Rms K1 & K2 Bldg Room K2           |              |       |        |              |
| 2-291<br>033             | Rms K1 & K2 Bldg Room K2           |              |       |        |              |

| ADDRESS      | DESCRIPTION                               | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
|--------------|---|--------------|-------|--------|--------------|
| 2-287<br>034 | Rms K1 & K2 Bldg Custodial Storage        |              |       |        |              |
| 2-276<br>060 | Rooms 3 8 Bldg Room 8                     |              |       |        |              |
| 2.068<br>164 | Rooms 11 13 Bldg Teleco Rm by Rm 11       |              |       |        |              |
| 2-056<br>183 | Rooms 14 16 Bldg Room 15                  |              |       |        |              |
| 2-055<br>184 | Rooms 14 16 Bldg Room 15                  |              |       |        |              |
| 2-057<br>185 | Rooms 14 16 Bldg Computer Lab             |              |       |        |              |
| 2-058<br>186 | Rooms 14 16 Bldg Computer Lab             |              |       |        |              |
| 2-054<br>187 | Rooms 14 16 Bldg Room 16                  |              |       |        |              |
| 2-053<br>188 | Rooms 14 16 Bldg Room 16 Storage          |              |       |        |              |
| 2-052<br>189 | Rooms 14 16 Bldg Media Center Library     |              |       |        |              |
| 2-051<br>190 | Rooms 14 16 Bldg Media Center Library     |              |       |        |              |
| 2-049<br>191 | Rooms 14 16 Bldg Media Center Library     |              |       |        |              |
| 2-050<br>192 | Rooms 14 16 Bldg Media Ctr Read Rm        |              |       |        |              |
| 2-085<br>218 | Rooms 17 19 Bldg Room 17 Storage          |              |       |        |              |
| 2-086<br>240 | Rooms 20 22 Bldg Cust Off By Rm 22        |              |       |        |              |
| 2-031<br>300 | Muti Purpose Bldg MP Room                 |              |       |        |              |
| 2-030<br>301 | Muti Purpose Bldg MP Room                 |              |       |        |              |
| 2-029<br>302 | Muti Purpose Bldg MP Room                 |              |       |        |              |
| 2-032<br>303 | Muti Purpose Bldg MP Room                 |              |       |        |              |
| 2-033<br>304 | Muti Purpose Bldg MP Room                 |              |       |        |              |
| 2-034<br>305 | Muti Purpose Bldg MP Room                 |              |       |        |              |
| 2-037<br>306 | Muti Purpose Bldg MP Room                 |              |       |        |              |
| 2-036<br>307 | Muti Purpose Bldg MP Room                 |              |       |        |              |
| 2-035<br>308 | Muti Purpose Bldg MP Room                 |              |       |        |              |
| 2-038<br>309 | Muti Purpose Bldg MP Room                 |              |       |        |              |
| 2-039<br>310 | Muti Purpose Bldg MP Room                 |              |       |        |              |
| 2-040<br>311 | Muti Purpose Bldg MP Room                 |              |       |        |              |
| 2-283<br>331 | Discovery Club Bldg Discovery Club Office |              |       |        |              |
| 2-341<br>355 | White House Bldg Reception Waiting        |              |       |        |              |
| 2-325<br>356 | White House Bldg Child Waiting Room       |              |       |        |              |
| 2.333<br>357 | White House Bldg Reception Hall           |              |       |        |              |
| 2-340<br>358 | White House Bldg Reception                |              |       |        |              |
| 2-348<br>359 | White House Bldg File Room by Recept      |              |       |        |              |
| 2-338<br>360 | White House Bldg Office 1                 |              |       |        |              |
| 2-328<br>361 | White House Bldg Hall by Office 2         |              |       |        |              |
| 2-337<br>362 | White House Bldg Office 2                 |              |       |        |              |
| 2-332<br>363 | White House Bldg Hall by Video Room       |              |       |        |              |
| 364          | White House Bldg Office 15                |              |       |        |              |

| ADDRESS                         | DESCRIPTION                          | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
|---------------------------------|--------------------------------------|--------------|-------|--------|--------------|
| 2-326<br>365                    | White House Bldg Office 16           |              |       |        |              |
| 2-331<br>366                    | White House Bldg Video Room          |              |       |        |              |
| 367                             | White House Bldg Hall by Room 16     |              |       |        |              |
| 2-329<br>368                    | White House Bldg Office 3            |              |       |        |              |
| 2-330<br>369                    | White House Bldg Office 5            |              |       |        |              |
| 2-336<br>370                    | White House Bldg Hall by Office 4    |              |       |        |              |
| 2-327<br>371                    | White House Bldg Office 4            |              |       |        |              |
| 372                             | White House Bldg Office 6            |              |       |        |              |
| 2-323<br>373                    | White House Bldg Hall by Restroom    |              |       |        |              |
| 2-322<br>374                    | White House Bldg Restroom            |              |       |        |              |
| 2-319<br>375                    | White House Bldg Hall by Room 9      |              |       |        |              |
| 2-350<br>376                    | White House Bldg Room 9              |              |       |        |              |
| 2-314<br>377                    | White House Bldg Room 8              |              |       |        |              |
| 2-315<br>378                    | White House Bldg Room 13             |              |       |        |              |
| 2-317<br>379                    | White House Bldg Hall by Room 7      |              |       |        |              |
| 2-316<br>380                    | White House Bldg Room 7              |              |       |        |              |
| 381                             | White House Bldg Room 14             |              |       |        |              |
| 2-321<br>382                    | White House Bldg Restroom by Kitchen |              |       |        |              |
| 2-303<br>383                    | White House Bldg Hall by Office 10   |              |       |        |              |
| 2-302<br>384                    | White House Bldg Office 10           |              |       |        |              |
| 2-304<br>385                    | White House Bldg Office 11           |              |       |        |              |
| 2-301<br>386                    | White House Bldg Paint Room          |              |       |        |              |
| 2-311<br>387                    | White House Bldg Copier Room         |              |       |        |              |
| 2-310<br>388                    | White House Bldg Hallway by Storage  |              |       |        |              |
| 2-307<br>389                    | White House Bldg Storage Hallway     |              |       |        |              |
| 2-312<br>390                    | White House Bldg Storage Hallway     |              |       |        |              |
| 2-308<br>391                    | White House Bldg Storage Room        |              |       |        |              |
| 2-309<br>392                    | White House Bldg Storage Room        |              |       |        |              |
| 393                             | White House Bldg Hall by MediCal Off |              |       |        |              |
| 394                             | White House Bldg MediCal Office      |              |       |        |              |
| Heat Detector - Restorable Spot |                                      |              |       |        |              |
| 2-005<br>011                    | Admin Area Office Storage            |              |       |        |              |
| 2-002<br>012                    | Admin Area Office Staff Restroom     |              |       |        |              |
| 2-010<br>013                    | Admin Area Hall Off Cust Strg        |              |       |        |              |
| 2-009<br>014                    | Admin Area Office Cust Storage       |              |       |        |              |
| 2-011<br>015                    | Admin Area Hallway Staff Room        |              |       |        |              |
| 2-012<br>016                    | Admin Area Staff Room Storage        |              |       |        |              |
| 2-013<br>017                    | Admin Area Staff Break Room          |              |       |        |              |

| ADDRESS      | DESCRIPTION                            | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
|--------------|--|--------------|-------|--------|--------------|
| 2-299<br>035 | Rms K1 & K2 Bldg Room K1 by<br>RR      |              |       |        |              |
| 2-300<br>036 | Rms K1 & K2 Bldg Room K1<br>Restroom   |              |       |        |              |
| 2-295<br>037 | Rms K1 & K2 Bldg Room K1<br>Storage    |              |       |        |              |
| 2-296<br>038 | Rms K1 & K2 Bldg Room K1 O<br>S Strg   |              |       |        |              |
| 2-289<br>039 | Rms K1 & K2 Bldg Room K2 by<br>RR      |              |       |        |              |
| 2-290<br>040 | Rms K1 & K2 Bldg Room K2<br>Restroom   |              |       |        |              |
| 2-288<br>041 | Rms K1 & K2 Bldg Room K2<br>Strg by RR |              |       |        |              |
| 2-294<br>042 | Rms K1 & K2 Bldg Room K2<br>Storage    |              |       |        |              |
| 2-293<br>043 | Rms K1 & K2 Bldg Room K2 O<br>S Strg   |              |       |        |              |
| 2-264<br>061 | Rooms 3 8 Bldg Room 3                  |              |       |        |              |
| 2-265<br>062 | Rooms 3 8 Bldg Room 3                  |              |       |        |              |
| 2-266<br>063 | Rooms 3 8 Bldg Room 3                  |              |       |        |              |
| 2-263<br>064 | Rooms 3 8 Bldg Room 3                  |              |       |        |              |
| 2-270<br>065 | Rooms 3 8 Bldg Room 4                  |              |       |        |              |
| 2-269<br>066 | Rooms 3 8 Bldg Room 4                  |              |       |        |              |
| 2-268<br>067 | Rooms 3 8 Bldg Room 4                  |              |       |        |              |
| 2-267<br>068 | Rooms 3 8 Bldg Room 4                  |              |       |        |              |
| 2-260<br>069 | Rooms 3 8 Bldg Room 5                  |              |       |        |              |
| 2-261<br>070 | Rooms 3 8 Bldg Room 5                  |              |       |        |              |
| 2-262<br>071 | Rooms 3 8 Bldg Room 5                  |              |       |        |              |
| 2-259<br>072 | Rooms 3 8 Bldg Room 5                  |              |       |        |              |
| 2-258<br>073 | Rooms 3 8 Bldg Room 6                  |              |       |        |              |
| 2-256<br>074 | Rooms 3 8 Bldg Room 6                  |              |       |        |              |
| 2-255<br>075 | Rooms 3 8 Bldg Room 6                  |              |       |        |              |
| 2-257<br>076 | Rooms 3 8 Bldg Room 6                  |              |       |        |              |
| 2-251<br>077 | Rooms 3 8 Bldg Room 7                  |              |       |        |              |
| 2-253<br>078 | Rooms 3 8 Bldg Room 7                  |              |       |        |              |
| 2-254<br>079 | Rooms 3 8 Bldg Room 7                  |              |       |        |              |
| 2-252<br>080 | Rooms 3 8 Bldg Room 7                  |              |       |        |              |
| 2-278<br>081 | Rooms 3 8 Bldg Room 8                  |              |       |        |              |
| 2-279<br>082 | Rooms 3 8 Bldg Room 8                  |              |       |        |              |
| 2-280<br>083 | Rooms 3 8 Bldg Room 8                  |              |       |        |              |
| 2-041<br>084 | Rooms 3 8 Bldg Room 8 Cust<br>Strg     |              |       |        |              |
| 2-275<br>085 | Rooms 3 8 Bldg Hallway by<br>Room 3    |              |       |        |              |
| 2-281<br>086 | Rooms 3 8 Bldg Hallway by<br>Room 4    |              |       |        |              |
| 2-282<br>087 | Rooms 3 8 Bldg Hallway by<br>Room 8    |              |       |        |              |
| 2-277<br>088 | Rooms 3 8 Bldg Hist Bldg Staff<br>RR   |              |       |        |              |

| ADDRESS      | DESCRIPTION                           | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
|--------------|---------------------------------------|--------------|-------|--------|--------------|
| 2-272<br>089 | Rooms 3 8 Bldg Hist Bldg Boys RR      |              |       |        |              |
| 090          | Rooms 3 8 Bldg Hist Bldg Girls RR     |              |       |        |              |
| 2-274<br>091 | Rooms 3 8 Bldg Hist bldg RR plbm chs  |              |       |        |              |
| 2-379<br>092 | Rooms 3 8 Bldg Attic Room 3           |              |       |        |              |
| 2-379<br>093 | Rooms 3 8 Bldg Attic Room 3           |              |       |        |              |
| 2-380<br>094 | Rooms 3 8 Bldg Attic Room 4           |              |       |        |              |
| 2-380<br>095 | Rooms 3 8 Bldg Attic Room 4           |              |       |        |              |
| 2.378<br>096 | Rooms 3 8 Bldg Attic Room 5           |              |       |        |              |
| 2.378<br>097 | Rooms 3 8 Bldg Attic Room 5           |              |       |        |              |
| 2-377<br>098 | Rooms 3 8 Bldg Attic Room 6           |              |       |        |              |
| 2-377<br>099 | Rooms 3 8 Bldg Attic Room 6           |              |       |        |              |
| 100          | Rooms 3 8 Bldg Attic Room 7           |              |       |        |              |
| 2-376<br>101 | Rooms 3 8 Bldg Attic Room 7           |              |       |        |              |
| 2-389<br>102 | Rooms 3 8 Bldg Attic Room 8           |              |       |        |              |
| 2-389<br>103 | Rooms 3 8 Bldg Attic Room 8           |              |       |        |              |
| 104          | Rooms 3 8 Bldg Attic Hall by Room 4   |              |       |        |              |
| 2-382<br>105 | Rooms 3 8 Bldg Attic Hall by Room 5   |              |       |        |              |
| 2-018<br>140 | Rooms 9 & 10 Area Room 9              |              |       |        |              |
| 2-017<br>141 | Rooms 9 & 10 Area Room 9              |              |       |        |              |
| 2-020<br>142 | Rooms 9 & 10 Area Reading Room 9      |              |       |        |              |
| 2-021<br>143 | Rooms 9 & 10 Area Speech Room 9       |              |       |        |              |
| 2-023<br>144 | Rooms 9 & 10 Area Art Room 9          |              |       |        |              |
| 2-014<br>146 | Rooms 9 & 10 Area Room 10             |              |       |        |              |
| 2-016<br>147 | Rooms 9 & 10 Area Hallway by Room 10  |              |       |        |              |
| 2-019<br>148 | Rooms 9 & 10 Area Hallway by Room 9   |              |       |        |              |
| 2-022<br>149 | Rooms 9 & 10 Area Hallway by Art Rm 9 |              |       |        |              |
| 2-024<br>150 | Rooms 9 & 10 Area Restroom by Art Rm  |              |       |        |              |
| 2-065<br>165 | Rooms 11 13 Bldg Room 11              |              |       |        |              |
| 2-066<br>166 | Rooms 11 13 Bldg Room 11              |              |       |        |              |
| 2-067<br>167 | Rooms 11 13 Bldg Room 11 Storage      |              |       |        |              |
| 2-064<br>168 | Rooms 11 13 Bldg Room 12              |              |       |        |              |
| 2-063<br>169 | Rooms 11 13 Bldg Room 13              |              |       |        |              |
| 2-132<br>170 | Rooms 11 13 Bldg Elect Rm by Rm 11    |              |       |        |              |
| 2-059<br>193 | Rooms 14 16 Bldg Room 14              |              |       |        |              |
| 2-060<br>194 | Rooms 14 16 Bldg Room 14              |              |       |        |              |
| 2-061<br>195 | Rooms 14 16 Bldg Boys RR by Room 14   |              |       |        |              |
| 2-062<br>196 | Rooms 14 16 Bldg Girls RR by Room 14  |              |       |        |              |
| 197          | Rooms 14 16 Bldg Attic Room 16        |              |       |        |              |

| ADDRESS      | DESCRIPTION                           | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
|--------------|---------------------------------------|--------------|-------|--------|--------------|
| 198          | Rooms 14 16 Bldg Attic Room 16        |              |       |        |              |
| 2-128<br>199 | Rooms 14 16 Bldg Attic Media Center   |              |       |        |              |
| 2-128<br>200 | Rooms 14 16 Bldg Attic Media Center   |              |       |        |              |
| 2-083<br>219 | Rooms 17 19 Bldg Room 17              |              |       |        |              |
| 2-082<br>220 | Rooms 17 19 Bldg Room 17              |              |       |        |              |
| 2-084<br>221 | Rooms 17 19 Bldg Room 17 Office       |              |       |        |              |
| 2-081<br>222 | Rooms 17 19 Bldg Room 18              |              |       |        |              |
| 2-080<br>223 | Rooms 17 19 Bldg Room 19              |              |       |        |              |
| 2-078<br>224 | Rooms 17 19 Bldg Girls RR by Room 19  |              |       |        |              |
| 2-077<br>225 | Rooms 17 19 Bldg Boys RR by Room 19   |              |       |        |              |
| 226          | Rooms 17 19 Bldg Plumb Chs by Rm 19   |              |       |        |              |
| 2-072<br>241 | Rooms 20 22 Bldg Room 20              |              |       |        |              |
| 2-071<br>242 | Rooms 20 22 Bldg Room 20              |              |       |        |              |
| 2-070<br>243 | Rooms 20 22 Bldg Room 21              |              |       |        |              |
| 2-069<br>244 | Rooms 20 22 Bldg Room 22              |              |       |        |              |
| 2-131<br>245 | Rooms 20 22 Bldg Storage by Cust Off  |              |       |        |              |
| 2-073<br>246 | Rooms 20 22 Bldg Womens Staff RR      |              |       |        |              |
| 2-076<br>247 | Rooms 20 22 Bldg Storage by Rm 20     |              |       |        |              |
| 2-075<br>248 | Rooms 20 22 Bldg Mens Staff RR        |              |       |        |              |
| 2-347<br>269 | Portables Room 23                     |              |       |        |              |
| 2-346<br>270 | Portables Room 23                     |              |       |        |              |
| 2-345<br>271 | Portables Room 24                     |              |       |        |              |
| 2-344<br>272 | Portables Room 24                     |              |       |        |              |
| 2-343<br>273 | Portables Room 25                     |              |       |        |              |
| 2-342<br>274 | Portables Room 25                     |              |       |        |              |
| 2-388<br>279 | Portables Attic Room 23               |              |       |        |              |
| 2-388<br>280 | Portables Attic Room 23               |              |       |        |              |
| 2-387<br>281 | Portables Attic Room 24               |              |       |        |              |
| 2-387<br>282 | Portables Attic Room 24               |              |       |        |              |
| 2-386<br>283 | Portables Attic Room 25               |              |       |        |              |
| 2-386<br>284 | Portables Attic Room 25               |              |       |        |              |
| 2-048<br>312 | Muti Purpose Bldg MP Room Foyer       |              |       |        |              |
| 2-042<br>313 | Muti Purpose Bldg MP Chair Storage    |              |       |        |              |
| 2-046<br>314 | Muti Purpose Bldg Kitchen             |              |       |        |              |
| 2-047<br>315 | Muti Purpose Bldg Kitchen Office      |              |       |        |              |
| 316          | Muti Purpose Bldg MP Cust Storage     |              |       |        |              |
| 2-043<br>317 | Muti Purpose Bldg Kitchen Pump Closet |              |       |        |              |

| ADDRESS      | DESCRIPTION                                 | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
|--------------|---|--------------|-------|--------|--------------|
| 2-044<br>318 | Muti Purpose Bldg Kitch W H<br>Tank Clst    |              |       |        |              |
| 2-045<br>319 | Muti Purpose Bldg Kitchen Equip<br>Closet   |              |       |        |              |
| 320          | Muti Purpose Bldg Attic Kitchen             |              |       |        |              |
| 321          | Muti Purpose Bldg Attic Kitchen<br>Office   |              |       |        |              |
| 2-349<br>332 | Discovery Club Bldg Discovery<br>Club       |              |       |        |              |
| 2-284<br>333 | Discovery Club Bldg Discovery<br>Club       |              |       |        |              |
| 2-285<br>334 | Discovery Club Bldg Discovery<br>Club RR    |              |       |        |              |
| 2-286<br>335 | Discovery Club Bldg Discovery<br>Club RR    |              |       |        |              |
| 2-383<br>336 | Discovery Club Bldg Attic<br>Discovery Club |              |       |        |              |
| 2-383<br>337 | Discovery Club Bldg Attic<br>Discovery Club |              |       |        |              |
| 2-383<br>338 | Discovery Club Bldg Attic<br>Discovery Club |              |       |        |              |
| 2-383<br>339 | Discovery Club Bldg Attic<br>Discovery Club |              |       |        |              |
| 2-324<br>395 | White House Bldg Child Waiting<br>Closet    |              |       |        |              |
| 2-320<br>396 | White House Bldg Kitchen                    |              |       |        |              |
| 397          | White House Bldg Strg by<br>MediCal Off     |              |       |        |              |
| 2-381<br>398 | White House Bldg Intern<br>Building         |              |       |        |              |
| 2-381<br>399 | White House Bldg Intern<br>Building         |              |       |        |              |
| 2-381<br>400 | White House Bldg Intern<br>Building         |              |       |        |              |
| 401          | White House Bldg Attic North                |              |       |        |              |
| 2-385<br>402 | White House Bldg Attic South<br>Hall        |              |       |        |              |
| 2-015        | Rooms 9 & 10 Area Room 10                   |              |       |        |              |
| 2-313        | White House Bldg Storage<br>Room by 12      |              |       |        |              |

### Power Supplies

| ADDRESS       | DESCRIPTION                               | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
|---------------|---|--------------|-------|--------|--------------|
| Primary Power |   |              |       |        |              |
| 052           | Rms K1 & K2 Bldg Room K2 O<br>S Strg      |              |       |        |              |
| 134           | Rooms 3 8 Bldg Hall by Room 8<br>(Top)    |              |       |        |              |
| 135           | Rooms 3 8 Bldg Hall by Room 8<br>(Bottom) |              |       |        |              |
| 176           | Rooms 11 13 Bldg Teleco Rm by<br>Rm 11    |              |       |        |              |
| 177           | Rooms 11 13 Bldg Teleco Rm by<br>Rm 11    |              |       |        |              |
| 212           | Rooms 14 16 Bldg Room 15                  |              |       |        |              |
| 213           | Rooms 14 16 Bldg Room 15                  |              |       |        |              |
| 260           | Rooms 20 22 Bldg Cust Off By<br>Rm 22     |              |       |        |              |
| 438           | White House Bldg Paint Room               |              |       |        |              |