

# Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

WINSTON CHURCHILL MIDDLE

4900 WHINTEY AVE  
CARMICHAEL, California  
United States

This site has been inspected and tested in compliance with applicable standards.

Completed

Thursday, September 11, 2025

Test Session: 14 Aug 2025 14:33 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD  
5320 HEMLOCK ST  
SACRAMENTO, California  
United States

TESTED BY

Riley Goyet  
Western States Fire Protection-  
Sacramento  
188 Cirby Way  
Roseville, CA 95678  
United States



# Inspection Summary

## Building Information

PROPERTY	WINSTON CHURCHILL MIDDLE	CONTACT
ADDRESS	4900 WHINTEY AVE	PHONE
CITY/STATE	CARMICHAEL, California	MOBILE
COUNTRY	United States	EMAIL

## Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us

## Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Ventilation and Cooking Equipment	6	0(0%)	0(0%)	0(0%)
Alarm Notification Appliance	141	141(100%)	141(100%)	0(0%)
Supervising Station Transmitting Equipment	1	1(100%)	1(100%)	0(0%)
Fire Control Panel	10	10(100%)	3(30%)	7(70%)
Initiating Device	307	289(94%)	288(94%)	1(0%)

## Certification

The equipment specified here in was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Thursday, September 11, 2025

ACCEPTED BY      09/11/2025  
  
Building Representative

TESTED BY      09/11/2025  
Riley Goyet  
Technician



## System Details

### Control Units

ADDRESS/ SCAN ADDRESS		DESCRIPTION	A Wing Area Room 7 Headend
MANUFACTURER	EST	S/W VERSION	
MODEL	3	LAST UPDATE	
SERIAL NUMBER		S/W LOCATION	
INSTALL DATE			

### Monitoring Information

A Wing Area Room 7 Headend			
TYPE	Digital Alarm Communicator Transmitter	INSTALL DATE	
MANUFACTURER	Bosch	TEST START	08/14/2025
MODEL	B9512G	TEST COMPLETE	09/11/2025
SERIAL NUMBER		Time to Transmit to Supervising Station	
MONITORING ORGANIZATION	Central Station / SJUSD Dispatch	ALARM SIGNAL	
MONITORING ORGANIZATION PHONE	CS - 916-480-4836 / SJUSD Dispatch - 916-971-7000	ALARM RESTORE	
MONITORING ORGANIZATION EMAIL		TROUBLE SIGNAL	
MONITORING ORGANIZATION ACCOUNT NUMBER	Central Station # 881-8013	TROUBLE RESTORE	
MONITORING PHONE LINE 1		SUPERVISORY SIGNAL	
MONITORING PHONE LINE 2		SUPERVISORY RESTORE	
MONITORING RETRANSMISSION ENTITY			

# Open Corrective Action & Solution Summary

The following 9 corrective action(s) remain open following the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
Heat Detector - Restorable Spot	2-386 339	F Wing Area HVAC Rm F2 Closet
	Created By:	Riley Goyet
	Creation Date:	08/14/2025
	Corrective Action:	Covered
	Proposed Solution:	
	Manufacturer:	
	Model:	
NAC Power Extender Panel		Admin Area Office Work Rm Storage - P.E. "C"
	Created By:	Riley Goyet
	Creation Date:	09/23/2024
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
NAC Power Extender Panel		B Wing Area Room B12 - P.E. "B"
	Created By:	Riley Goyet
	Creation Date:	09/23/2024
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
NAC Power Extender Panel		B Wing Area Classroom 20 Storage - P.E. "D"
	Created By:	Riley Goyet
	Creation Date:	09/23/2024
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
NAC Power Extender Panel		C Wing Area Room 32 - P.E. "E"
	Created By:	Riley Goyet
	Creation Date:	09/23/2024
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
NAC Power Extender Panel		Multi-Purpose Bldg Storage W Stage Stair - P.E. "F"
	Created By:	Riley Goyet
	Creation Date:	09/23/2024
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
NAC Power Extender Panel		E Wing Area Equip Rm A10/Electrical Rm - P.E. "G"
	Created By:	Riley Goyet
	Creation Date:	09/23/2024
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
----------------	---------	-------------

NAC Power Extender Panel		F Wing Area Electrical Room D03 - P.E. "H"
	Created By:	Riley Goyet
	Creation Date:	09/23/2024
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	

[Other]	Fire Alarm Connection	
---------	-----------------------	--

	Created By:	Casey Smith
	Creation Date:	07/29/2025
	Corrective Action:	Fire alarm panel did not receive signal from suppression system when activated
	Proposed Solution:	Have alarm technician diagnose and fix problem
	Manufacturer:	
	Model:	

# Testing Details

## Alarm Notification Appliance

Passed				
EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	105	A Wing Area Classroom 1	Manual	8/14/2025 2:38:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	106	A Wing Area Classroom 2	Manual	8/14/2025 2:38:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	107	A Wing Area Classroom 3	Manual	8/14/2025 2:38:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	108	A Wing Area Classroom 4	Manual	8/14/2025 2:38:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	109	A Wing Area Classroom 5	Manual	8/14/2025 2:38:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	110	A Wing Area Classroom 8	Manual	8/14/2025 2:38:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	111	A Wing Area Classroom 9	Manual	8/14/2025 2:38:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	116	A Wing Area Girls RR by Classrm 1	Manual	8/14/2025 2:36:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	113	A Wing Area Hallway by Classrm 1	Manual	8/14/2025 2:38:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	112	A Wing Area Hallway by Classrm 1	Manual	8/14/2025 2:38:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	114	A Wing Area Hallway by Classrm 3	Manual	8/14/2025 2:37:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	115	A Wing Area Hallway by Room A-8	Manual	8/14/2025 2:38:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	104	A Wing Area South Exterior	Manual	8/14/2025 2:39:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	103	A Wing Area South Exterior	Manual	8/14/2025 2:39:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	118	A Wing Area Womens RR E Rm 9	Manual	8/14/2025 2:36:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	117	A Wing Area Womens RR E Rm 9	Manual	8/14/2025 2:36:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	059	Admin Area Conf Room 22	Manual	8/14/2025 2:36:13 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	057	Admin Area Conf Room Office	Manual	8/14/2025 2:36:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	061	Admin Area Counseling Rm 24	Manual	8/14/2025 2:36:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	060	Admin Area Counseling Rm 24	Manual	8/14/2025 2:36:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	043	Admin Area East Exterior	Manual	8/14/2025 2:39:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	056	Admin Area File/Copy Room	Manual	8/14/2025 2:36:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	047	Admin Area Front Office	Manual	8/14/2025 2:38:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	051	Admin Area Hallway by Front Off	Manual	8/14/2025 2:36:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	046	Admin Area Hallway by Library	Manual	8/14/2025 2:38:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	044	Admin Area Hallway by N Office	Manual	8/14/2025 2:38:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	045	Admin Area Hallway by Room 24	Manual	8/14/2025 2:38:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	050	Admin Area Library	Manual	8/14/2025 2:38:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	058	Admin Area Library	Manual	8/14/2025 2:36:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	042	Admin Area North Exterior	Manual	8/14/2025 2:39:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	041	Admin Area North Exterior	Manual	8/14/2025 2:39:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	052	Admin Area Office Work Rm RR	Manual	8/14/2025 2:36:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	048	Admin Area Office Work Room	Manual	8/14/2025 2:38:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	054	Admin Area Principals Office	Manual	8/14/2025 2:36:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	049	Admin Area SE Office	Manual	8/14/2025 2:38:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible	055	Admin Area Secretary Office	Manual	8/14/2025 2:36:19 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Visible	053	Admin Area VP Office	Manual	8/14/2025 2:36:23 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Visible	194	B Wing Area Boys RR by Room 18	Manual	8/14/2025 2:36:04 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	178	B Wing Area Classroom 10	Manual	8/14/2025 2:38:45 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	179	B Wing Area Classroom 11	Manual	8/14/2025 2:38:43 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	180	B Wing Area Classroom 14	Manual	8/14/2025 2:37:57 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	181	B Wing Area Classroom 15	Manual	8/14/2025 2:37:55 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	182	B Wing Area Classroom 16	Manual	8/14/2025 2:37:54 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	183	B Wing Area Classroom 17	Manual	8/14/2025 2:37:53 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	184	B Wing Area Classroom 18	Manual	8/14/2025 2:37:51 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	186	B Wing Area Classroom 19	Manual	8/14/2025 2:37:49 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	185	B Wing Area Classroom 19	Manual	8/14/2025 2:37:50 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	187	B Wing Area Classroom 20	Manual	8/14/2025 2:37:47 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	189	B Wing Area Hall by Classrm 20	Manual	8/14/2025 2:37:43 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	188	B Wing Area Hall by Classrm 20	Manual	8/14/2025 2:37:45 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	193	B Wing Area Hall by Room 14	Manual	8/14/2025 2:37:37 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	192	B Wing Area Hall by Room 16	Manual	8/14/2025 2:37:39 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	191	B Wing Area Hall by Room 17	Manual	8/14/2025 2:37:41 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	190	B Wing Area Hall by Room 18	Manual	8/14/2025 2:37:44 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	195	B Wing Area Mens Staff RR	Manual	8/14/2025 2:36:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	177	B Wing Area North Exterior	Manual	8/14/2025 2:39:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	176	B Wing Area North Exterior	Manual	8/14/2025 2:39:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	251	C Wing Area Classroom 28	Manual	8/14/2025 2:37:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	266	C Wing Area Classroom 28	Manual	8/14/2025 2:36:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	252	C Wing Area Classroom 30	Manual	8/14/2025 2:37:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	253	C Wing Area Classroom 31	Manual	8/14/2025 2:37:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	254	C Wing Area Classroom 34	Manual	8/14/2025 2:37:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	255	C Wing Area Classroom 35	Manual	8/14/2025 2:37:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	256	C Wing Area Classroom 36	Manual	8/14/2025 2:37:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	257	C Wing Area Classroom 37	Manual	8/14/2025 2:37:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	258	C Wing Area Classroom 38	Manual	8/14/2025 2:37:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	259	C Wing Area Classroom 40	Manual	8/14/2025 2:37:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	268	C Wing Area Girls RR W Rm 38	Manual	8/14/2025 2:35:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	261	C Wing Area Hall by Room 28	Manual	8/14/2025 2:37:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	262	C Wing Area Hall by Room 30	Manual	8/14/2025 2:37:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	263	C Wing Area Hall by Room 31	Manual	8/14/2025 2:37:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	264	C Wing Area Hall by Room 34	Manual	8/14/2025 2:37:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	265	C Wing Area Hall by Room 36	Manual	8/14/2025 2:37:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	260	C Wing Area Hall by Room 39	Manual	8/14/2025 2:37:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	269	C Wing Area Mens Staff RR	Manual	8/14/2025 2:35:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	249	C Wing Area North Exterior	Manual	8/14/2025 2:39:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	248	C Wing Area North Exterior	Manual	8/14/2025 2:39:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	267	C Wing Area Room 39	Manual	8/14/2025 2:35:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	250	C Wing Area South Exterior	Manual	8/14/2025 2:39:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	270	C Wing Area Womens Staff RR	Manual	8/14/2025 2:35:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	322	E Wing Area Boys Restroom R05	Manual	8/14/2025 2:35:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	311	E Wing Area Classroom E2	Manual	8/14/2025 2:37:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	312	E Wing Area Classroom E3	Manual	8/14/2025 2:37:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	313	E Wing Area Classroom E4	Manual	8/14/2025 2:37:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	314	E Wing Area Classroom E5	Manual	8/14/2025 2:37:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	315	E Wing Area Classroom E6	Manual	8/14/2025 2:37:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	316	E Wing Area Classroom E7	Manual	8/14/2025 2:37:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	308	E Wing Area East Exterior	Manual	8/14/2025 2:38:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	321	E Wing Area Girls Restroom R04	Manual	8/14/2025 2:35:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	310	E Wing Area Media Center	Manual	8/14/2025 2:37:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	306	E Wing Area North Exterior	Manual	8/14/2025 2:38:52 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	307	E Wing Area North Exterior	Manual	8/14/2025 2:38:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	305	E Wing Area North Exterior	Manual	8/14/2025 2:39:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	324	E Wing Area North Exterior - Electric Bell	Manual	8/14/2025 2:38:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	323	E Wing Area North Exterior - Electric Bell	Manual	8/14/2025 2:38:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	309	E Wing Area South Exterior	Manual	8/14/2025 2:38:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	320	E Wing Area Staff Restroom R01	Manual	8/14/2025 2:35:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	317	E Wing Area Workrm A04 E2A	Manual	8/14/2025 2:37:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	318	E Wing Area Workroom E4A	Manual	8/14/2025 2:35:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	319	E Wing Area Workroom E7A	Manual	8/14/2025 2:35:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	346	F Wing Area Classroom F1	Manual	8/14/2025 2:37:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	347	F Wing Area Classroom F2	Manual	8/14/2025 2:36:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	348	F Wing Area Classroom F3	Manual	8/14/2025 2:36:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	349	F Wing Area Classroom F4	Manual	8/14/2025 2:36:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	350	F Wing Area Classroom F5	Manual	8/14/2025 2:36:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	345	F Wing Area North Exterior	Manual	8/14/2025 2:38:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	353	F Wing Area West Exterior - Electric Bell	Manual	8/14/2025 2:38:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	351	F Wing Area Workrm F/A D04	Manual	8/14/2025 2:35:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	352	F Wing Area Workrm F4A	Manual	8/14/2025 2:35:42 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	440	Multi-Purpose Bldg Boys Locker Room	Manual	8/14/2025 2:36:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	439	Multi-Purpose Bldg Boys Locker Room	Manual	8/14/2025 2:36:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	449	Multi-Purpose Bldg Boys Locker Room	Manual	8/14/2025 2:35:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	448	Multi-Purpose Bldg Boys Locker Room	Manual	8/14/2025 2:35:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	435	Multi-Purpose Bldg Classroom D1	Manual	8/14/2025 2:36:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	436	Multi-Purpose Bldg Classroom D2	Manual	8/14/2025 2:36:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	432	Multi-Purpose Bldg Custodial Office	Manual	8/14/2025 2:36:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	425	Multi-Purpose Bldg East Exterior	Manual	8/14/2025 2:38:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	424	Multi-Purpose Bldg East Exterior	Manual	8/14/2025 2:38:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	423	Multi-Purpose Bldg East Exterior	Manual	8/14/2025 2:38:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	422	Multi-Purpose Bldg East Exterior	Manual	8/14/2025 2:38:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	441	Multi-Purpose Bldg Girls Locker Room	Manual	8/14/2025 2:36:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	442	Multi-Purpose Bldg Girls Locker Room	Manual	8/14/2025 2:36:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	451	Multi-Purpose Bldg Girls Locker Room	Manual	8/14/2025 2:35:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	450	Multi-Purpose Bldg Girls Locker Room	Manual	8/14/2025 2:35:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	434	Multi-Purpose Bldg Hall by Kitchen	Manual	8/14/2025 2:36:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	433	Multi-Purpose Bldg Hall by Kitchen	Manual	8/14/2025 2:36:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	438	Multi-Purpose Bldg Hall by Locker Rooms	Manual	8/14/2025 2:36:33 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Audible And Visible	437	Multi-Purpose Bldg Hall by Locker Rooms	Manual	8/14/2025 2:36:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	444	Multi-Purpose Bldg Hall Kitchen Mens RR	Manual	8/14/2025 2:35:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	445	Multi-Purpose Bldg Hall Kitchen Women RR	Manual	8/14/2025 2:35:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	431	Multi-Purpose Bldg Kitchen	Manual	8/14/2025 2:36:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	430	Multi-Purpose Bldg Kitchen	Manual	8/14/2025 2:36:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	447	Multi-Purpose Bldg Kitchen	Manual	8/14/2025 2:35:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	446	Multi-Purpose Bldg Kitchen	Manual	8/14/2025 2:35:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	427	Multi-Purpose Bldg MP Room	Manual	8/14/2025 2:36:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	426	Multi-Purpose Bldg MP Room	Manual	8/14/2025 2:36:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	452	Multi-Purpose Bldg North Exterior	Manual	8/14/2025 2:38:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	421	Multi-Purpose Bldg North Exterior	Manual	8/14/2025 2:38:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	429	Multi-Purpose Bldg Stage	Manual	8/14/2025 2:36:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	428	Multi-Purpose Bldg Stage	Manual	8/14/2025 2:36:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	443	Multi-Purpose Bldg Stage	Manual	8/14/2025 2:35:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

**Fire Control Panel**

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Fire Alarm Panel		A Wing Area Room 7 Headend	Manual	8/14/2025 5:55:55 PM
		Manufacturer	EST	
		Model	3	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		A Wing Area Room 7 Headend - P.E. "A"	Manual	8/14/2025 6:33:33 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Remote Annunciator	001	Admin Area Front Office	Manual	8/14/2025 5:31:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Failed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
NAC Power Extender Panel		Admin Area Office Work Rm Storage - P.E. "C"	Manual	8/15/2025 11:21:18 AM
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	
NAC Power Extender Panel		B Wing Area Classroom 20 Storage - P.E. "D"	Manual	8/15/2025 11:20:50 AM
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	
NAC Power Extender Panel		B Wing Area Room B12 - P.E. "B"	Manual	8/15/2025 11:21:00 AM
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	
NAC Power Extender Panel		C Wing Area Room 32 - P.E. "E"	Manual	8/15/2025 11:20:55 AM
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	
NAC Power Extender Panel		E Wing Area Equip Rm A10/Electrical Rm - P.E. "G"	Manual	8/15/2025 11:21:09 AM
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	
NAC Power Extender Panel		F Wing Area Electrical Room D03 - P.E. "H"	Manual	8/14/2025 7:29:39 PM
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	
NAC Power Extender Panel		Multi-Purpose Bldg Storage W Stage Stair - P.E. "F"	Manual	8/15/2025 11:21:05 AM
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	

Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-129 099	A Wing Area Attic Hall by Rm 4 5	Manual	8/14/2025 5:49:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-129 095	A Wing Area Attic Hall by Room 1	Manual	8/14/2025 5:49:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-129 094	A Wing Area Attic Hall by Room 1	Manual	8/14/2025 5:49:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-129 097	A Wing Area Attic Hall by Room 2	Manual	8/14/2025 5:49:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-129 096	A Wing Area Attic Hall by Room 2	Manual	8/14/2025 5:49:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-129 098	A Wing Area Attic Hall by Room 3	Manual	8/14/2025 5:49:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-129 093	A Wing Area Attic Hall by RRs	Manual	8/14/2025 5:49:36 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-144 089	A Wing Area Attic N Soffit by Rm 1	Manual	8/14/2025 6:05:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-145 090	A Wing Area Attic N Soffit by Rm 9	Manual	8/14/2025 6:05:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-126 100	A Wing Area Attic Room A8	Manual	8/14/2025 6:01:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-131 091	A Wing Area Attic RR by Room 1	Manual	8/14/2025 6:05:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-130 092	A Wing Area Attic RR by Room 9	Manual	8/14/2025 6:05:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-019 069	A Wing Area Classroom 1	Manual	8/14/2025 5:52:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-018 070	A Wing Area Classroom 1	Manual	8/14/2025 5:52:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-017 072	A Wing Area Classroom 2	Manual	8/14/2025 5:53:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-016 071	A Wing Area Classroom 2	Manual	8/14/2025 5:53:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-015 075	A Wing Area Classroom 3	Manual	8/14/2025 6:00:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-014 076	A Wing Area Classroom 3	Manual	8/14/2025 6:00:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-013 077	A Wing Area Classroom 4	Manual	8/14/2025 6:01:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-012 078	A Wing Area Classroom 4	Manual	8/14/2025 6:01:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-005 080	A Wing Area Classroom 5	Manual	8/14/2025 6:00:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-006 079	A Wing Area Classroom 5	Manual	8/14/2025 6:01:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-007 085	A Wing Area Classroom 8	Manual	8/14/2025 5:59:19 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	2-008 084	A Wing Area Classroom 8	Manual	8/14/2025 5:59:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-009 086	A Wing Area Classroom 9	Manual	8/14/2025 5:49:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-010 087	A Wing Area Classroom 9	Manual	8/14/2025 5:49:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-011 088	A Wing Area Classroom 9 Storage	Manual	8/14/2025 5:49:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-029 067	A Wing Area Girls RR by Classrm 1	Manual	8/14/2025 5:48:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-024 066	A Wing Area Hallway by Classrm 1	Manual	8/14/2025 5:48:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-023 068	A Wing Area Hallway by Classrm 1	Manual	8/14/2025 5:48:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-022 073	A Wing Area Hallway by Classrm 2	Manual	8/14/2025 5:54:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-021 074	A Wing Area Hallway by Classrm 3	Manual	8/14/2025 5:54:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-020 081	A Wing Area Hallway by Room A-8	Manual	8/14/2025 5:54:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-003 083	A Wing Area Room 7 Headend	Manual	8/14/2025 5:54:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-004 082	A Wing Area Room A8	Manual	8/14/2025 6:00:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-028 062	A Wing Area Storage by Room 1	Manual	8/14/2025 5:47:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-027 063	A Wing Area Storage by Room 1	Manual	8/14/2025 6:05:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-026 064	A Wing Area Womens RR E Rm 9	Manual	8/14/2025 4:20:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-025 065	A Wing Area Womens RR E Rm 9	Manual	8/14/2025 4:34:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-137 033	Admin Area Attic Conf Room	Manual	8/14/2025 6:37:57 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-135 038	Admin Area Attic E Soffit by Off	Manual	8/14/2025 6:56:55 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-132 035	Admin Area Attic Hall by Library	Manual	8/14/2025 6:30:52 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-132 036	Admin Area Attic Hall by Rm 19	Manual	8/14/2025 6:30:50 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-133 037	Admin Area Attic N Soffit by Off	Manual	8/14/2025 6:47:40 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-138 034	Admin Area Attic SE Office	Manual	8/14/2025 6:56:56 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-142 030	Admin Area Attic Work Room	Manual	8/14/2025 4:38:42 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-048 018	Admin Area Conf Room 24	Manual	8/14/2025 4:36:30 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-037	Admin Area Conf Room Office	Manual	8/14/2025 4:26:39 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-038 011	Admin Area Conf Room Office	Manual	8/14/2025 4:27:13 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-046 020	Admin Area Counseling Rm 24	Manual	8/14/2025 4:35:28 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-047 019	Admin Area Counseling Rm 24	Manual	8/14/2025 4:35:35 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-036 012	Admin Area File/Copy Room	Manual	8/14/2025 4:26:52 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Manual Pull Station	2-139 002	Admin Area Front Office	Manual	8/14/2025 4:29:29 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-034 004	Admin Area Front Office	Manual	8/14/2025 4:28:54 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-041 003	Admin Area Front Office	Manual	8/14/2025 4:29:01 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-033 021	Admin Area Hallway by Front Off	Manual	8/14/2025 4:26:17 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-032 022	Admin Area Hallway by Front Off	Manual	8/14/2025 4:33:14 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-051 026	Admin Area Hallway by Library	Manual	8/14/2025 4:37:07 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-052 027	Admin Area Hallway by Library	Manual	8/14/2025 4:37:14 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-050 025	Admin Area Hallway by Room 22	Manual	8/14/2025 4:36:54 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-031 023	Admin Area Hallway by Room 24	Manual	8/14/2025 4:33:55 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-049 024	Admin Area Hallway by Room 24	Manual	8/14/2025 4:33:59 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-057 014	Admin Area Library	Manual	8/14/2025 4:23:08 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-055 015	Admin Area Library	Manual	8/14/2025 4:23:15 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-056 016	Admin Area Library	Manual	8/14/2025 4:23:33 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-058 017	Admin Area Library	Manual	8/14/2025 4:23:41 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-044 006	Admin Area Office Work Rm RR	Manual	8/14/2025 4:31:26 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-043 007	Admin Area Office Work Rm Storage	Manual	8/14/2025 4:32:03 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-045 005	Admin Area Office Work Room	Manual	8/14/2025 4:30:57 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-040 009	Admin Area Principals Office	Manual	8/14/2025 4:30:19 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-039 013	Admin Area SE Office	Manual	8/14/2025 4:24:10 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-035 010	Admin Area Secretary Office	Manual	8/14/2025 4:26:29 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	2-042 008	Admin Area VP Office	Manual	8/14/2025 4:29:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-379 163	B Wing Area Attic Hall by Rm 10	Manual	8/14/2025 4:45:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-379 164	B Wing Area Attic Hall by Rm 10	Manual	8/14/2025 4:45:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-379 165	B Wing Area Attic Hall by Rm 10	Manual	8/14/2025 4:45:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-379 167	B Wing Area Attic Hall by Rm 11	Manual	8/14/2025 4:44:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-379 166	B Wing Area Attic Hall by Rm 11	Manual	8/14/2025 4:45:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-379 168	B Wing Area Attic Hall by Rm 14	Manual	8/14/2025 4:45:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-379 169	B Wing Area Attic Hall by Rm 16	Manual	8/14/2025 4:45:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-379 162	B Wing Area Attic Hall by RRs	Manual	8/14/2025 4:45:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-388 171	B Wing Area Attic Soffit by Rm 10	Manual	8/14/2025 7:10:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-262 121	B Wing Area Boys RR by Room 18	Manual	8/14/2025 2:55:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-261 120	B Wing Area Boys RR by Room 18	Manual	8/14/2025 6:05:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-272 127	B Wing Area Classroom 10	Manual	8/14/2025 4:45:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-271 128	B Wing Area Classroom 10	Manual	8/14/2025 4:45:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-265 129	B Wing Area Classroom 10 Storage	Manual	8/14/2025 4:46:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-269 132	B Wing Area Classroom 11	Manual	8/14/2025 4:48:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-270 133	B Wing Area Classroom 11	Manual	8/14/2025 4:49:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-268 138	B Wing Area Classroom 14	Manual	8/14/2025 4:53:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-267 139	B Wing Area Classroom 14	Manual	8/14/2025 4:53:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-273 141	B Wing Area Classroom 15	Manual	8/14/2025 4:52:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-274 140	B Wing Area Classroom 15	Manual	8/14/2025 4:52:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-276 142	B Wing Area Classroom 16	Manual	8/14/2025 4:50:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-275 143	B Wing Area Classroom 16	Manual	8/14/2025 4:51:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-278 144	B Wing Area Classroom 17	Manual	8/14/2025 4:47:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-277 145	B Wing Area Classroom 17	Manual	8/14/2025 4:47:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-280 146	B Wing Area Classroom 18	Manual	8/14/2025 4:44:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-279 147	B Wing Area Classroom 18	Manual	8/14/2025 4:44:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-283 150	B Wing Area Classroom 19	Manual	8/14/2025 2:52:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-284 149	B Wing Area Classroom 19	Manual	8/14/2025 4:38:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-282 152	B Wing Area Classroom 19	Manual	8/14/2025 4:38:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-281 151	B Wing Area Classroom 19	Manual	8/14/2025 4:38:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-286 153	B Wing Area Classroom 19	Manual	8/14/2025 4:39:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-285 154	B Wing Area Classroom 19	Manual	8/14/2025 4:39:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-023 155	B Wing Area Classroom 20	Manual	8/14/2025 4:40:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-022 156	B Wing Area Classroom 20	Manual	8/14/2025 4:41:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-021 157	B Wing Area Classroom 20	Manual	8/14/2025 4:41:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-020 158	B Wing Area Classroom 20 Storage	Manual	8/14/2025 4:20:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-053 119	B Wing Area Hall by Classrm 20	Manual	8/14/2025 3:57:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-054 148	B Wing Area Hall by Classrm 20	Manual	8/14/2025 4:37:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-266 136	B Wing Area Hall by Room 14	Manual	8/14/2025 5:45:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-255 135	B Wing Area Hall by Room 16	Manual	8/14/2025 4:50:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-256 131	B Wing Area Hall by Room 17	Manual	8/14/2025 4:48:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-258 122	B Wing Area Hall by Room 18	Manual	8/14/2025 4:42:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-257 126	B Wing Area Hall by Room 18	Manual	8/14/2025 4:43:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-263 125	B Wing Area Mens Staff RR	Manual	8/14/2025 4:42:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-264 130	B Wing Area Rm 10 Kiln Storage	Manual	8/14/2025 4:46:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-253 134	B Wing Area Room A11	Manual	8/14/2025 4:49:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-254 137	B Wing Area Room B12	Manual	8/14/2025 5:45:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-260 123	B Wing Area Storage by Room 18	Manual	8/14/2025 4:43:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-259 124	B Wing Area Storage by Room 18	Manual	8/14/2025 6:05:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-154 235	C Wing Area Attic Hall by Rm 34/35	Manual	8/14/2025 4:17:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-154 236	C Wing Area Attic Hall by Rm 36	Manual	8/14/2025 4:17:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-154 238	C Wing Area Attic Hall by Rm 37	Manual	8/14/2025 4:17:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-154 237	C Wing Area Attic Hall by Rm 37	Manual	8/14/2025 4:17:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-154 240	C Wing Area Attic Hall by Rm 38	Manual	8/14/2025 4:17:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-154 239	C Wing Area Attic Hall by Rm 38	Manual	8/14/2025 4:17:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-154 241	C Wing Area Attic Hall by RRs	Manual	8/14/2025 4:17:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-151 234	C Wing Area Attic Room A31	Manual	8/14/2025 4:06:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-156 243	C Wing Area Attic Storage by Rm 38	Manual	8/14/2025 6:47:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-027 198	C Wing Area Classroom 28	Manual	8/14/2025 4:19:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-026 199	C Wing Area Classroom 28	Manual	8/14/2025 4:20:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-025 200	C Wing Area Classroom 28	Manual	8/14/2025 4:20:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-024 201	C Wing Area Classroom 28 Storage	Manual	8/14/2025 4:20:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-037 209	C Wing Area Classroom 30	Manual	8/14/2025 4:14:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-036 210	C Wing Area Classroom 30	Manual	8/14/2025 4:15:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-039 213	C Wing Area Classroom 31	Manual	8/14/2025 4:09:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-038 214	C Wing Area Classroom 31	Manual	8/14/2025 4:09:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-041 220	C Wing Area Classroom 34	Manual	8/14/2025 4:03:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-040 219	C Wing Area Classroom 34	Manual	8/14/2025 4:03:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-028 221	C Wing Area Classroom 35	Manual	8/14/2025 4:06:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-029 222	C Wing Area Classroom 35	Manual	8/14/2025 4:06:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-031 223	C Wing Area Classroom 36	Manual	8/14/2025 4:07:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-030 224	C Wing Area Classroom 36	Manual	8/14/2025 4:07:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-033 225	C Wing Area Classroom 37	Manual	8/14/2025 4:11:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-032 226	C Wing Area Classroom 37	Manual	8/14/2025 4:11:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-035 227	C Wing Area Classroom 38	Manual	8/14/2025 4:12:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-034 228	C Wing Area Classroom 38	Manual	8/14/2025 4:12:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-287 230	C Wing Area Classroom 40	Manual	8/14/2025 4:21:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-288 231	C Wing Area Classroom 40	Manual	8/14/2025 4:22:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-015 203	C Wing Area Girls RR W Rm 38	Manual	8/14/2025 4:17:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-017 197	C Wing Area Hall by Room 28	Manual	8/14/2025 4:19:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-019 202	C Wing Area Hall by Room 28	Manual	8/14/2025 4:19:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-012 204	C Wing Area Hall by Room 30	Manual	8/14/2025 4:16:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-008 211	C Wing Area Hall by Room 30	Manual	8/14/2025 4:16:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-007 212	C Wing Area Hall by Room 31	Manual	8/14/2025 4:11:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-006 217	C Wing Area Hall by Room 34	Manual	8/14/2025 4:03:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-005 216	C Wing Area Hall by Room 36	Manual	8/14/2025 4:05:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-018 196	C Wing Area Hall by Room 39	Manual	8/14/2025 4:18:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-009 207	C Wing Area Mens Staff RR	Manual	8/14/2025 4:18:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-003 218	C Wing Area Room 32	Manual	8/14/2025 4:05:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-011 229	C Wing Area Room 39	Manual	8/14/2025 4:15:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-004 215	C Wing Area Room A31	Manual	8/14/2025 4:03:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-014 205	C Wing Area Storage by Room 38	Manual	8/14/2025 4:16:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-013 206	C Wing Area Storage by Room 38	Manual	8/14/2025 6:04:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-010 208	C Wing Area Womens Staff RR	Manual	8/14/2025 4:17:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-054 296	E Wing Area Boys Restroom R05	Manual	8/14/2025 4:37:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-069 273	E Wing Area Classroom E2	Manual	8/14/2025 3:22:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-068 274	E Wing Area Classroom E2	Manual	8/14/2025 3:22:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-066 276	E Wing Area Classroom E3	Manual	8/14/2025 3:37:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-067 277	E Wing Area Classroom E3	Manual	8/14/2025 3:37:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-062 281	E Wing Area Classroom E4	Manual	8/14/2025 3:47:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-064 278	E Wing Area Classroom E4	Manual	8/14/2025 3:47:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-065 279	E Wing Area Classroom E4	Manual	8/14/2025 3:47:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-063 280	E Wing Area Classroom E4	Manual	8/14/2025 3:47:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-060 283	E Wing Area Classroom E5	Manual	8/14/2025 3:48:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-061 284	E Wing Area Classroom E5	Manual	8/14/2025 3:49:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-048 286	E Wing Area Classroom E6	Manual	8/14/2025 3:51:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-047 285	E Wing Area Classroom E6	Manual	8/14/2025 3:51:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-045 288	E Wing Area Classroom E7	Manual	8/14/2025 3:50:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-046 287	E Wing Area Classroom E7	Manual	8/14/2025 3:51:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-050 297	E Wing Area Custodial Closet R02	Manual	8/14/2025 3:53:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-043 290	E Wing Area Equip Rm A10/Electrical Rm	Manual	8/14/2025 3:46:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-049 293	E Wing Area Equip Rm R03	Manual	8/14/2025 3:53:30 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-052 295	E Wing Area Girls Restroom R04	Manual	8/14/2025 3:56:13 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3-139 298	E Wing Area HVAC OS Rm A3 Closet	Manual	8/14/2025 3:40:52 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3-138 299	E Wing Area HVAC OS Rm E5 Closet	Manual	8/14/2025 5:30:32 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3-134 300	E Wing Area HVAC Rm E6 Closet	Manual	8/14/2025 4:02:00 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3-127 301	E Wing Area HVAC Rm E7 Closet	Manual	8/14/2025 4:03:33 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-071 291	E Wing Area IT Room A05	Manual	8/14/2025 3:38:41 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-073 271	E Wing Area Media Center Entry	Manual	8/14/2025 3:21:17 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - Duct	3-144	E Wing Area Media Library	Manual	8/14/2025 5:30:35 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-072 272	E Wing Area Media Library	Manual	8/14/2025 3:22:00 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Valve Tamper Switch	3-135 304	E Wing Area PIV Tamper	Manual	8/14/2025 5:30:34 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	3-136 302	E Wing Area Rooms E1-E5 Bldg	Manual	8/14/2025 5:30:31 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	3-132 303	E Wing Area Rooms E6-E7 Bldg	Manual	8/14/2025 3:46:40 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-051 294	E Wing Area Staff Restroom R01	Manual	8/14/2025 3:54:36 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-070 275	E Wing Area Workrm A04 E2A	Manual	8/14/2025 3:23:07 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-059 282	E Wing Area Workroom E4A	Manual	8/14/2025 3:48:09 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-044 289	E Wing Area Workroom E7A	Manual	8/14/2025 3:52:29 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-291 325	F Wing Area Classroom F1	Manual	8/14/2025 6:17:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-292 326	F Wing Area Classroom F1	Manual	8/14/2025 6:17:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-294 328	F Wing Area Classroom F2	Manual	8/14/2025 6:16:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-295 329	F Wing Area Classroom F2	Manual	8/14/2025 6:16:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-296 330	F Wing Area Classroom F3	Manual	8/14/2025 6:15:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-297 331	F Wing Area Classroom F3	Manual	8/14/2025 6:15:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-302 333	F Wing Area Classroom F4	Manual	8/14/2025 6:13:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-303 332	F Wing Area Classroom F4	Manual	8/14/2025 6:13:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-299 335	F Wing Area Classroom F5	Manual	8/14/2025 6:12:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-298 336	F Wing Area Classroom F5	Manual	8/14/2025 6:12:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-290 337	F Wing Area Electrical Room D03	Manual	8/14/2025 6:15:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	2-382 343	F Wing Area F Wing	Manual	8/14/2025 6:14:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-385 338	F Wing Area HVAC Rm F1 Closet	Manual	8/14/2025 7:17:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-389 340	F Wing Area HVAC Rm F3 Closet	Manual	8/14/2025 7:21:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-419 341	F Wing Area HVAC Rm F4 Closet	Manual	8/14/2025 7:23:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-418 342	F Wing Area HVAC Rm F5 Closet	Manual	8/14/2025 7:23:33 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Valve Tamper Switch	2-383	F Wing Area OS&Y	Manual	8/14/2025 6:07:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Valve Tamper Switch	2-383	F Wing Area OS&Y	Manual	8/14/2025 6:07:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Valve Tamper Switch	2-384 344	F Wing Area PIV	Manual	8/14/2025 7:07:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-293 327	F Wing Area Workrm F/A D04	Manual	8/14/2025 6:16:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-301 334	F Wing Area Workrm F4A	Manual	8/14/2025 6:12:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-385 410	Multi-Purpose Bldg Attic Boys Locker Rm	Manual	8/14/2025 6:04:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-384 411	Multi-Purpose Bldg Attic E Stage Stairs	Manual	8/14/2025 5:52:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-391 409	Multi-Purpose Bldg Attic Girls Locker Rm	Manual	8/14/2025 3:18:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-388 417	Multi-Purpose Bldg Attic Kitch Hose area	Manual	8/14/2025 2:56:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-387 416	Multi-Purpose Bldg Attic Kitchen	Manual	8/14/2025 6:04:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-389 419	Multi-Purpose Bldg Attic Kitchen W Soffit	Manual	8/14/2025 6:04:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-386 418	Multi-Purpose Bldg Attic MP Rm S Soffit	Manual	8/14/2025 5:52:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-393 408	Multi-Purpose Bldg Attic MP Room	Manual	8/14/2025 5:52:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-392 412	Multi-Purpose Bldg Attic Stage	Manual	8/14/2025 5:52:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-382 415	Multi-Purpose Bldg Attic W Stage Stairs	Manual	8/14/2025 5:30:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-289 373	Multi-Purpose Bldg Boys Locker Office	Manual	8/14/2025 5:30:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	3-292	Multi-Purpose Bldg Boys Locker Room	Manual	8/14/2025 3:14:59 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	3-288 403	Multi-Purpose Bldg Boys Locker Room	Manual	8/14/2025 4:22:01 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	3-291 404	Multi-Purpose Bldg Boys Locker Room	Manual	8/14/2025 5:52:37 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	3-290 374	Multi-Purpose Bldg Boys Locker Storage	Manual	8/14/2025 5:30:03 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	3-277 381	Multi-Purpose Bldg Classroom D1	Manual	8/14/2025 3:01:02 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	3-278 380	Multi-Purpose Bldg Classroom D1	Manual	8/14/2025 3:01:18 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	3-279 405	Multi-Purpose Bldg Classroom D1 Storage	Manual	8/14/2025 3:06:19 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	3-281 378	Multi-Purpose Bldg Classroom D2	Manual	8/14/2025 3:07:46 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	3-282 377	Multi-Purpose Bldg Classroom D2	Manual	8/14/2025 3:08:01 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	3-280 379	Multi-Purpose Bldg Classroom D2 Storage	Manual	8/14/2025 3:07:20 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	3-273 391	Multi-Purpose Bldg Custodial Office	Manual	8/14/2025 2:54:06 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	3-283 376	Multi-Purpose Bldg E Stair Hall by Stage	Manual	8/14/2025 2:51:24 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	3-284 375	Multi-Purpose Bldg E Stair Hall by Stage	Manual	8/14/2025 3:13:52 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	3-297 371	Multi-Purpose Bldg Girls Locker Office	Manual	8/14/2025 3:14:53 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	3-296 397	Multi-Purpose Bldg Girls Locker Room	Manual	8/14/2025 3:16:03 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	3-295 398	Multi-Purpose Bldg Girls Locker Room	Manual	8/14/2025 3:16:28 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	3-294 399	Multi-Purpose Bldg Girls Locker RR	Manual	8/14/2025 3:17:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-293 400	Multi-Purpose Bldg Girls Locker RR	Manual	8/14/2025 3:17:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-298 372	Multi-Purpose Bldg Girls Locker Storage	Manual	8/14/2025 3:15:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-286 369	Multi-Purpose Bldg Hall by Boys Locker	Manual	8/14/2025 3:13:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-285 370	Multi-Purpose Bldg Hall by Boys Locker	Manual	8/14/2025 4:39:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-287 368	Multi-Purpose Bldg Hall by Girls Locker	Manual	8/14/2025 4:21:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-263 396	Multi-Purpose Bldg Hall by Kitchen	Manual	8/14/2025 2:53:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-262 395	Multi-Purpose Bldg Hall by Kitchen	Manual	8/14/2025 2:55:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-261 394	Multi-Purpose Bldg Hall by Kitchen	Manual	8/14/2025 2:55:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-264 386	Multi-Purpose Bldg Hall by Kitchen Strg	Manual	8/14/2025 2:59:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-265 385	Multi-Purpose Bldg Hall Kitch Women RR	Manual	8/14/2025 2:55:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-275 384	Multi-Purpose Bldg Hall Kitchen Mens RR	Manual	8/14/2025 2:58:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-271 390	Multi-Purpose Bldg Kitch Hall by Freezer	Manual	8/14/2025 2:56:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-270 389	Multi-Purpose Bldg Kitch Strg by Freezer	Manual	8/14/2025 2:58:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-274 406	Multi-Purpose Bldg Kitchen	Manual	8/14/2025 2:55:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-272 407	Multi-Purpose Bldg Kitchen	Manual	8/14/2025 4:45:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-267 393	Multi-Purpose Bldg Kitchen Hall	Manual	8/14/2025 2:57:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-268 388	Multi-Purpose Bldg Kitchen N Storage	Manual	8/14/2025 2:56:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-269 387	Multi-Purpose Bldg Kitchen N Strg by RR	Manual	8/14/2025 2:57:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-266 392	Multi-Purpose Bldg Kitchen RR Hall	Manual	8/14/2025 2:55:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	3-427 420	Multi-Purpose Bldg MP Rm Hall Storage	Manual	8/14/2025 7:05:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-254 359	Multi-Purpose Bldg MP Room	Manual	8/14/2025 2:49:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-251 360	Multi-Purpose Bldg MP Room	Manual	8/14/2025 2:49:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-252 361	Multi-Purpose Bldg MP Room	Manual	8/14/2025 2:50:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-255 364	Multi-Purpose Bldg MP Room	Manual	8/14/2025 2:50:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-256 363	Multi-Purpose Bldg MP Room	Manual	8/14/2025 2:50:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-253 362	Multi-Purpose Bldg MP Room	Manual	8/14/2025 2:50:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-379 355	Multi-Purpose Bldg NE Exit	Manual	8/14/2025 2:52:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-377 354	Multi-Purpose Bldg NW Exit	Manual	8/14/2025 2:50:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-390 401	Multi-Purpose Bldg O/S Water Heater Closet	Manual	8/14/2025 5:52:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-390 402	Multi-Purpose Bldg O/S Water Heater Closet	Manual	8/14/2025 5:52:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-380 356	Multi-Purpose Bldg SE Exit	Manual	8/14/2025 2:51:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Manual Pull Station	3-376 357	Multi-Purpose Bldg South Exit	Manual	8/14/2025 2:51:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-260 367	Multi-Purpose Bldg Stage	Manual	8/14/2025 2:51:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-259 366	Multi-Purpose Bldg Stage	Manual	8/14/2025 2:51:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-258 365	Multi-Purpose Bldg Stage	Manual	8/14/2025 2:52:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-257 383	Multi-Purpose Bldg Storage W Stage Stair	Manual	8/14/2025 3:00:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-378 358	Multi-Purpose Bldg SW Exit	Manual	8/14/2025 2:49:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-276 382	Multi-Purpose Bldg W Stair Hall by Stage	Manual	8/14/2025 3:00:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-140 028	Admin Area Attic Front Office	Manual	8/14/2025 6:56:50 PM
Heat Detector - Restorable Spot	2-146 039	Admin Area Attic S Soffit by Off	Manual	8/14/2025 6:56:45 PM
Heat Detector - Restorable Spot	2-136 032	Admin Area Attic Small E Office	Manual	8/14/2025 6:56:41 PM
Heat Detector - Restorable Spot	3-165 040	Admin Area Attic Soffit by Library	Manual	8/14/2025 6:56:58 PM
Heat Detector - Restorable Spot	2-141 029	Admin Area Attic Work Room	Manual	8/14/2025 6:56:37 PM
Heat Detector - Restorable Spot	2-143 031	Admin Area Attic Work Room	Manual	8/14/2025 6:57:05 PM
Heat Detector - Restorable Spot	2-377 170	B Wing Area Attic Room B11	Manual	8/14/2025 7:22:03 PM
Heat Detector - Restorable Spot	2-147 173	B Wing Area Attic S Soffit by Rm 19	Manual	8/14/2025 7:22:00 PM
Heat Detector - Restorable Spot	2-387 172	B Wing Area Attic Soffit by Rm 18	Manual	8/14/2025 7:22:10 PM
Heat Detector - Restorable Spot	2-381 160	B Wing Area Attic Staff RR	Manual	8/14/2025 7:22:14 PM
Heat Detector - Restorable Spot	2-381 159	B Wing Area Attic Staff RR	Manual	8/14/2025 7:22:17 PM
Heat Detector - Restorable Spot	2-380 161	B Wing Area Attic Storage by Rm 18	Manual	8/14/2025 7:22:07 PM
Heat Detector - Restorable Spot	3-157 232	C Wing Area Attic Hall by Rm 28	Manual	8/14/2025 7:10:40 PM
Heat Detector - Restorable Spot	3-157 233	C Wing Area Attic Hall by Rm 28	Manual	8/14/2025 7:10:42 PM
Heat Detector - Restorable Spot	3-166 244	C Wing Area Attic Soffit by Rm 38	Manual	8/14/2025 7:10:22 PM
Heat Detector - Restorable Spot	3-155 242	C Wing Area Attic Staff RRs	Manual	8/14/2025 7:21:53 PM
Heat Detector - Restorable Spot	3-383 414	Multi-Purpose Bldg Attic Classroom D1	Manual	8/14/2025 6:04:15 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	3-392 413	Multi-Purpose Bldg Attic Stage	Manual	8/14/2025 5:52:57 PM

Failed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-386 339	F Wing Area HVAC Rm F2 Closet	Manual	8/14/2025 7:21:23 PM

Visual inspection  
Functional Inspection

Failed (Manual)  
Failed

### Supervising Station Transmitting Equipment

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Digital Alarm Communicator Transmitter		A Wing Area Room 7 Headend	Manual	8/14/2025 5:55:33 PM

Manufacturer  
Model  
Visual inspection  
Functional Inspection  
Monitoring Account Number  
Monitoring Organization  
Monitoring Organization Phone

Bosch  
B9512G  
Passed (Manual)  
Passed  
Central Station # 881-8013  
Central Station / SJUSD Dispatch  
CS - 916-480-4836 / SJUSD Dispatch - 916-971-7000

### Ventilation and Cooking Equipment

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
[Other]	Fire Alarm Connection		Manual	8/14/2025 2:41:17 PM
Cooking Equipment	Appliances		Manual	8/14/2025 2:41:21 PM
Fusible Links	Fusible Links 450 x 2		Manual	8/14/2025 2:41:33 PM
Range Hood	Hood		Manual	8/14/2025 2:41:24 PM
Range Suppression	Suppression		Manual	8/14/2025 2:41:30 PM
Range Suppression Tank	Cylinder		Manual	8/14/2025 2:41:26 PM

## Device/Equipment details

### Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Audible					
041	Admin Area North Exterior				
042	Admin Area North Exterior				
043	Admin Area East Exterior				
103	A Wing Area South Exterior				
104	A Wing Area South Exterior				
176	B Wing Area North Exterior				
177	B Wing Area North Exterior				
248	C Wing Area North Exterior				
249	C Wing Area North Exterior				
250	C Wing Area South Exterior				
305	E Wing Area North Exterior				
306	E Wing Area North Exterior				
307	E Wing Area North Exterior				
308	E Wing Area East Exterior				
309	E Wing Area South Exterior				
323	E Wing Area North Exterior - Electric Bell				
324	E Wing Area North Exterior - Electric Bell				
345	F Wing Area North Exterior				
353	F Wing Area West Exterior - Electric Bell				
421	Multi-Purpose Bldg North Exterior				
422	Multi-Purpose Bldg East Exterior				
423	Multi-Purpose Bldg East Exterior				
424	Multi-Purpose Bldg East Exterior				
425	Multi-Purpose Bldg East Exterior				
452	Multi-Purpose Bldg North Exterior				
Audible And Visible					
044	Admin Area Hallway by N Office				
045	Admin Area Hallway by Room 24				
046	Admin Area Hallway by Library				
047	Admin Area Front Office				
048	Admin Area Office Work Room				
049	Admin Area SE Office				
050	Admin Area Library				
105	A Wing Area Classroom 1				
106	A Wing Area Classroom 2				
107	A Wing Area Classroom 3				
108	A Wing Area Classroom 4				
109	A Wing Area Classroom 5				
110	A Wing Area Classroom 8				
111	A Wing Area Classroom 9				
112	A Wing Area Hallway by Classrm 1				
113	A Wing Area Hallway by Classrm 1				
114	A Wing Area Hallway by Classrm 3				
115	A Wing Area Hallway by Room A- 8				
178	B Wing Area Classroom 10				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
179	B Wing Area Classroom 11				
180	B Wing Area Classroom 14				
181	B Wing Area Classroom 15				
182	B Wing Area Classroom 16				
183	B Wing Area Classroom 17				
184	B Wing Area Classroom 18				
185	B Wing Area Classroom 19				
186	B Wing Area Classroom 19				
187	B Wing Area Classroom 20				
188	B Wing Area Hall by Classrm 20				
189	B Wing Area Hall by Classrm 20				
190	B Wing Area Hall by Room 18				
191	B Wing Area Hall by Room 17				
192	B Wing Area Hall by Room 16				
193	B Wing Area Hall by Room 14				
251	C Wing Area Classroom 28				
252	C Wing Area Classroom 30				
253	C Wing Area Classroom 31				
254	C Wing Area Classroom 34				
255	C Wing Area Classroom 35				
256	C Wing Area Classroom 36				
257	C Wing Area Classroom 37				
258	C Wing Area Classroom 38				
259	C Wing Area Classroom 40				
260	C Wing Area Hall by Room 39				
261	C Wing Area Hall by Room 28				
262	C Wing Area Hall by Room 30				
263	C Wing Area Hall by Room 31				
264	C Wing Area Hall by Room 34				
265	C Wing Area Hall by Room 36				
310	E Wing Area Media Center				
311	E Wing Area Classroom E2				
312	E Wing Area Classroom E3				
313	E Wing Area Classroom E4				
314	E Wing Area Classroom E5				
315	E Wing Area Classroom E6				
316	E Wing Area Classroom E7				
346	F Wing Area Classroom F1				
347	F Wing Area Classroom F2				
348	F Wing Area Classroom F3				
349	F Wing Area Classroom F4				
350	F Wing Area Classroom F5				
426	Multi-Purpose Bldg MP Room				
427	Multi-Purpose Bldg MP Room				
428	Multi-Purpose Bldg Stage				
429	Multi-Purpose Bldg Stage				
430	Multi-Purpose Bldg Kitchen				
431	Multi-Purpose Bldg Kitchen				
432	Multi-Purpose Bldg Custodial Office				
433	Multi-Purpose Bldg Hall by Kitchen				
434	Multi-Purpose Bldg Hall by Kitchen				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
435	Multi-Purpose Bldg Classroom D1				
436	Multi-Purpose Bldg Classroom D2				
437	Multi-Purpose Bldg Hall by Locker Rooms				
438	Multi-Purpose Bldg Hall by Locker Rooms				
439	Multi-Purpose Bldg Boys Locker Room				
440	Multi-Purpose Bldg Boys Locker Room				
441	Multi-Purpose Bldg Girls Locker Room				
442	Multi-Purpose Bldg Girls Locker Room				
Visible					
051	Admin Area Hallway by Front Off				
052	Admin Area Office Work Rm RR				
053	Admin Area VP Office				
054	Admin Area Principals Office				
055	Admin Area Secretary Office				
056	Admin Area File/Copy Room				
057	Admin Area Conf Room Office				
058	Admin Area Library				
059	Admin Area Conf Room 22				
060	Admin Area Counseling Rm 24				
061	Admin Area Counseling Rm 24				
116	A Wing Area Girls RR by Classrm 1				
117	A Wing Area Womens RR E Rm 9				
118	A Wing Area Womens RR E Rm 9				
194	B Wing Area Boys RR by Room 18				
195	B Wing Area Mens Staff RR				
266	C Wing Area Classroom 28				
267	C Wing Area Room 39				
268	C Wing Area Girls RR W Rm 38				
269	C Wing Area Mens Staff RR				
270	C Wing Area Womens Staff RR				
317	E Wing Area Workrm A04 E2A				
318	E Wing Area Workroom E4A				
319	E Wing Area Workroom E7A				
320	E Wing Area Staff Restroom R01				
321	E Wing Area Girls Restroom R04				
322	E Wing Area Boys Restroom R05				
351	F Wing Area Workrm F/A D04				
352	F Wing Area Workrm F4A				
443	Multi-Purpose Bldg Stage				
444	Multi-Purpose Bldg Hall Kitchen Mens RR				
445	Multi-Purpose Bldg Hall Kitchen Women RR				
446	Multi-Purpose Bldg Kitchen				
447	Multi-Purpose Bldg Kitchen				
448	Multi-Purpose Bldg Boys Locker Room				
449	Multi-Purpose Bldg Boys Locker Room				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
450	Multi-Purpose Bldg Girls Locker Room				
451	Multi-Purpose Bldg Girls Locker Room				

### Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Remote Annunciator					
001	Admin Area Front Office				
NAC Power Extender Panel					
	Admin Area Office Work Rm Storage - P.E. "C"				
	A Wing Area Room 7 Headend - P.E. "A"				
	B Wing Area Room B12 - P.E. "B"				
	B Wing Area Classroom 20 Storage - P.E. "D"				
	C Wing Area Room 32 - P.E. "E"				
	Multi-Purpose Bldg Storage W Stage Stair - P.E. "F"				
	E Wing Area Equip Rm A10/Electrical Rm - P.E. "G"				
	F Wing Area Electrical Room D03 - P.E. "H"				

### Fire Alarm Panel

	A Wing Area Room 7 Headend	EST		3	
--	----------------------------	-----	--	---	--

### Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Manual Pull Station					
2-139 002	Admin Area Front Office				
3-377 354	Multi-Purpose Bldg NW Exit				
3-379 355	Multi-Purpose Bldg NE Exit				
3-380 356	Multi-Purpose Bldg SE Exit				
3-376 357	Multi-Purpose Bldg South Exit				
3-378 358	Multi-Purpose Bldg SW Exit				
Smoke Detector - General					
2-041 003	Admin Area Front Office				
2-034 004	Admin Area Front Office				
2-045 005	Admin Area Office Work Room				
2-044 006	Admin Area Office Work Rm RR				
2-043 007	Admin Area Office Work Rm Storage				
2-042 008	Admin Area VP Office				
2-040 009	Admin Area Principals Office				
2-035 010	Admin Area Secretary Office				
2-038 011	Admin Area Conf Room Office				
2-036 012	Admin Area File/Copy Room				
2-039 013	Admin Area SE Office				
3-057 014	Admin Area Library				
3-055 015	Admin Area Library				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3-056 016	Admin Area Library				
3-058 017	Admin Area Library				
2-048 018	Admin Area Conf Room 24				
2-047 019	Admin Area Counseling Rm 24				
2-046 020	Admin Area Counseling Rm 24				
2-033 021	Admin Area Hallway by Front Off				
2-032 022	Admin Area Hallway by Front Off				
2-031 023	Admin Area Hallway by Room 24				
2-049 024	Admin Area Hallway by Room 24				
2-050 025	Admin Area Hallway by Room 22				
2-051 026	Admin Area Hallway by Library				
2-052 027	Admin Area Hallway by Library				
2-028 062	A Wing Area Storage by Room 1				
2-027 063	A Wing Area Storage by Room 1				
2-026 064	A Wing Area Womens RR E Rm 9				
2-025 065	A Wing Area Womens RR E Rm 9				
2-024 066	A Wing Area Hallway by Classrm 1				
2-029 067	A Wing Area Girls RR by Classrm 1				
2-023 068	A Wing Area Hallway by Classrm 1				
2-019 069	A Wing Area Classroom 1				
2-018 070	A Wing Area Classroom 1				
2-016 071	A Wing Area Classroom 2				
2-017 072	A Wing Area Classroom 2				
2-022 073	A Wing Area Hallway by Classrm 2				
2-021 074	A Wing Area Hallway by Classrm 3				
2-015 075	A Wing Area Classroom 3				
2-014 076	A Wing Area Classroom 3				
2-013 077	A Wing Area Classroom 4				
2-012 078	A Wing Area Classroom 4				
2-006 079	A Wing Area Classroom 5				
2-005 080	A Wing Area Classroom 5				
2-020 081	A Wing Area Hallway by Room A- 8				
2-004 082	A Wing Area Room A8				
2-003 083	A Wing Area Room 7 Headend				
2-008 084	A Wing Area Classroom 8				
2-007 085	A Wing Area Classroom 8				
2-009 086	A Wing Area Classroom 9				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-010 087	A Wing Area Classroom 9				
2-011 088	A Wing Area Classroom 9 Storage				
2-053 119	B Wing Area Hall by Classrm 20				
2-261 120	B Wing Area Boys RR by Room 18				
2-262 121	B Wing Area Boys RR by Room 18				
2-258 122	B Wing Area Hall by Room 18				
2-260 123	B Wing Area Storage by Room 18				
2-259 124	B Wing Area Storage by Room 18				
2-263 125	B Wing Area Mens Staff RR				
2-257 126	B Wing Area Hall by Room 18				
2-272 127	B Wing Area Classroom 10				
2-271 128	B Wing Area Classroom 10				
2-265 129	B Wing Area Classroom 10 Storage				
2-264 130	B Wing Area Rm 10 Kiln Storage				
2-256 131	B Wing Area Hall by Room 17				
2-269 132	B Wing Area Classroom 11				
2-270 133	B Wing Area Classroom 11				
2-253 134	B Wing Area Room A11				
2-255 135	B Wing Area Hall by Room 16				
2-266 136	B Wing Area Hall by Room 14				
2-254 137	B Wing Area Room B12				
2-268 138	B Wing Area Classroom 14				
2-267 139	B Wing Area Classroom 14				
2-274 140	B Wing Area Classroom 15				
2-273 141	B Wing Area Classroom 15				
2-276 142	B Wing Area Classroom 16				
2-275 143	B Wing Area Classroom 16				
2-278 144	B Wing Area Classroom 17				
2-277 145	B Wing Area Classroom 17				
2-280 146	B Wing Area Classroom 18				
2-279 147	B Wing Area Classroom 18				
2-054 148	B Wing Area Hall by Classrm 20				
2-284 149	B Wing Area Classroom 19				
2-283 150	B Wing Area Classroom 19				
2-281 151	B Wing Area Classroom 19				
2-282 152	B Wing Area Classroom 19				
2-286 153	B Wing Area Classroom 19				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-285 154	B Wing Area Classroom 19				
3-023 155	B Wing Area Classroom 20				
3-022 156	B Wing Area Classroom 20				
3-021 157	B Wing Area Classroom 20				
3-020 158	B Wing Area Classroom 20 Storage				
3-018 196	C Wing Area Hall by Room 39				
3-017 197	C Wing Area Hall by Room 28				
3-027 198	C Wing Area Classroom 28				
3-026 199	C Wing Area Classroom 28				
3-025 200	C Wing Area Classroom 28				
3-024 201	C Wing Area Classroom 28 Storage				
3-019 202	C Wing Area Hall by Room 28				
3-015 203	C Wing Area Girls RR W Rm 38				
3-012 204	C Wing Area Hall by Room 30				
3-014 205	C Wing Area Storage by Room 38				
3-013 206	C Wing Area Storage by Room 38				
3-009 207	C Wing Area Mens Staff RR				
3-010 208	C Wing Area Womens Staff RR				
3-037 209	C Wing Area Classroom 30				
3-036 210	C Wing Area Classroom 30				
3-008 211	C Wing Area Hall by Room 30				
3-007 212	C Wing Area Hall by Room 31				
3-039 213	C Wing Area Classroom 31				
3-038 214	C Wing Area Classroom 31				
3-004 215	C Wing Area Room A31				
3-005 216	C Wing Area Hall by Room 36				
3-006 217	C Wing Area Hall by Room 34				
3-003 218	C Wing Area Room 32				
3-040 219	C Wing Area Classroom 34				
3-041 220	C Wing Area Classroom 34				
3-028 221	C Wing Area Classroom 35				
3-029 222	C Wing Area Classroom 35				
3-031 223	C Wing Area Classroom 36				
3-030 224	C Wing Area Classroom 36				
3-033 225	C Wing Area Classroom 37				
3-032 226	C Wing Area Classroom 37				
3-035 227	C Wing Area Classroom 38				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3-034 228	C Wing Area Classroom 38				
3-011 229	C Wing Area Room 39				
2-287 230	C Wing Area Classroom 40				
2-288 231	C Wing Area Classroom 40				
3-073 271	E Wing Area Media Center Entry				
3-072 272	E Wing Area Media Library				
3-069 273	E Wing Area Classroom E2				
3-068 274	E Wing Area Classroom E2				
3-070 275	E Wing Area Workrm A04 E2A				
3-066 276	E Wing Area Classroom E3				
3-067 277	E Wing Area Classroom E3				
3-064 278	E Wing Area Classroom E4				
3-065 279	E Wing Area Classroom E4				
3-063 280	E Wing Area Classroom E4				
3-062 281	E Wing Area Classroom E4				
3-059 282	E Wing Area Workroom E4A				
3-060 283	E Wing Area Classroom E5				
3-061 284	E Wing Area Classroom E5				
3-047 285	E Wing Area Classroom E6				
3-048 286	E Wing Area Classroom E6				
3-046 287	E Wing Area Classroom E7				
3-045 288	E Wing Area Classroom E7				
3-044 289	E Wing Area Workroom E7A				
3-043 290	E Wing Area Equip Rm A10/Electrical Rm				
3-071 291	E Wing Area IT Room A05				
3-049 293	E Wing Area Equip Rm R03				
3-051 294	E Wing Area Staff Restroom R01				
3-052 295	E Wing Area Girls Restroom R04				
3-054 296	E Wing Area Boys Restroom R05				
2-291 325	F Wing Area Classroom F1				
2-292 326	F Wing Area Classroom F1				
2-293 327	F Wing Area Workrm F/A D04				
2-294 328	F Wing Area Classroom F2				
2-295 329	F Wing Area Classroom F2				
2-296 330	F Wing Area Classroom F3				
2-297 331	F Wing Area Classroom F3				
2-303 332	F Wing Area Classroom F4				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-302 333	F Wing Area Classroom F4				
2-301 334	F Wing Area Workrm F4A				
2-299 335	F Wing Area Classroom F5				
2-298 336	F Wing Area Classroom F5				
2-290 337	F Wing Area Electrical Room D03				
3-254 359	Multi-Purpose Bldg MP Room				
3-251 360	Multi-Purpose Bldg MP Room				
3-252 361	Multi-Purpose Bldg MP Room				
3-253 362	Multi-Purpose Bldg MP Room				
3-256 363	Multi-Purpose Bldg MP Room				
3-255 364	Multi-Purpose Bldg MP Room				
3-258 365	Multi-Purpose Bldg Stage				
3-259 366	Multi-Purpose Bldg Stage				
3-260 367	Multi-Purpose Bldg Stage				
3-287 368	Multi-Purpose Bldg Hall by Girls Locker				
3-286 369	Multi-Purpose Bldg Hall by Boys Locker				
3-285 370	Multi-Purpose Bldg Hall by Boys Locker				
3-297 371	Multi-Purpose Bldg Girls Locker Office				
3-298 372	Multi-Purpose Bldg Girls Locker Storage				
3-289 373	Multi-Purpose Bldg Boys Locker Office				
3-290 374	Multi-Purpose Bldg Boys Locker Storage				
3-284 375	Multi-Purpose Bldg E Stair Hall by Stage				
3-283 376	Multi-Purpose Bldg E Stair Hall by Stage				
3-282 377	Multi-Purpose Bldg Classroom D2				
3-281 378	Multi-Purpose Bldg Classroom D2				
3-280 379	Multi-Purpose Bldg Classroom D2 Storage				
3-278 380	Multi-Purpose Bldg Classroom D1				
3-277 381	Multi-Purpose Bldg Classroom D1				
3-276 382	Multi-Purpose Bldg W Stair Hall by Stage				
3-257 383	Multi-Purpose Bldg Storage W Stage Stair				
3-275 384	Multi-Purpose Bldg Hall Kitchen Mens RR				
3-265 385	Multi-Purpose Bldg Hall Kitch Women RR				
3-264 386	Multi-Purpose Bldg Hall by Kitchen Strg				
3-269 387	Multi-Purpose Bldg Kitchen N Strg by RR				
3-268 388	Multi-Purpose Bldg Kitchen N Storage				
3-270 389	Multi-Purpose Bldg Kitch Strg by Freezer				
3-271 390	Multi-Purpose Bldg Kitch Hall by Freezer				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3-273 391	Multi-Purpose Bldg Custodial Office				
3-266 392	Multi-Purpose Bldg Kitchen RR Hall				
3-267 393	Multi-Purpose Bldg Kitchen Hall				
3-261 394	Multi-Purpose Bldg Hall by Kitchen				
3-262 395	Multi-Purpose Bldg Hall by Kitchen				
3-263 396	Multi-Purpose Bldg Hall by Kitchen				
2-037	Admin Area Conf Room Office				
Heat Detector - Restorable Spot					
2-140 028	Admin Area Attic Front Office				
2-141 029	Admin Area Attic Work Room				
2-142 030	Admin Area Attic Work Room				
2-143 031	Admin Area Attic Work Room				
2-136 032	Admin Area Attic Small E Office				
2-137 033	Admin Area Attic Conf Room				
2-138 034	Admin Area Attic SE Office				
2-132 035	Admin Area Attic Hall by Library				
2-132 036	Admin Area Attic Hall by Rm 19				
2-133 037	Admin Area Attic N Soffit by Off				
2-135 038	Admin Area Attic E Soffit by Off				
2-146 039	Admin Area Attic S Soffit by Off				
3-165 040	Admin Area Attic Soffit by Library				
2-144 089	A Wing Area Attic N Soffit by Rm 1				
2-145 090	A Wing Area Attic N Soffit by Rm 9				
2-131 091	A Wing Area Attic RR by Room 1				
2-130 092	A Wing Area Attic RR by Room 9				
2-129 093	A Wing Area Attic Hall by RRs				
2-129 094	A Wing Area Attic Hall by Room 1				
2-129 095	A Wing Area Attic Hall by Room 1				
2-129 096	A Wing Area Attic Hall by Room 2				
2-129 097	A Wing Area Attic Hall by Room 2				
2-129 098	A Wing Area Attic Hall by Room 3				
2-129 099	A Wing Area Attic Hall by Rm 4 5				
2-126 100	A Wing Area Attic Room A8				
2-381 159	B Wing Area Attic Staff RR				
2-381 160	B Wing Area Attic Staff RR				
2-380 161	B Wing Area Attic Storage by Rm 18				
2-379 162	B Wing Area Attic Hall by RRs				
2-379 163	B Wing Area Attic Hall by Rm 10				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-379 164	B Wing Area Attic Hall by Rm 10				
2-379 165	B Wing Area Attic Hall by Rm 10				
2-379 166	B Wing Area Attic Hall by Rm 11				
2-379 167	B Wing Area Attic Hall by Rm 11				
2-379 168	B Wing Area Attic Hall by Rm 14				
2-379 169	B Wing Area Attic Hall by Rm 16				
2-377 170	B Wing Area Attic Room B11				
2-388 171	B Wing Area Attic Soffit by Rm 10				
2-387 172	B Wing Area Attic Soffit by Rm 18				
2-147 173	B Wing Area Attic S Soffit by Rm 19				
3-157 232	C Wing Area Attic Hall by Rm 28				
3-157 233	C Wing Area Attic Hall by Rm 28				
3-151 234	C Wing Area Attic Room A31				
3-154 235	C Wing Area Attic Hall by Rm 34/35				
3-154 236	C Wing Area Attic Hall by Rm 36				
3-154 237	C Wing Area Attic Hall by Rm 37				
3-154 238	C Wing Area Attic Hall by Rm 37				
3-154 239	C Wing Area Attic Hall by Rm 38				
3-154 240	C Wing Area Attic Hall by Rm 38				
3-154 241	C Wing Area Attic Hall by RRs				
3-155 242	C Wing Area Attic Staff RRs				
3-156 243	C Wing Area Attic Storage by Rm 38				
3-166 244	C Wing Area Attic Soffit by Rm 38				
3-050 297	E Wing Area Custodial Closet R02				
3-139 298	E Wing Area HVAC OS Rm A3 Closet				
3-138 299	E Wing Area HVAC OS Rm E5 Closet				
3-134 300	E Wing Area HVAC Rm E6 Closet				
3-127 301	E Wing Area HVAC Rm E7 Closet				
2-385 338	F Wing Area HVAC Rm F1 Closet				
2-386 339	F Wing Area HVAC Rm F2 Closet				
2-389 340	F Wing Area HVAC Rm F3 Closet				
2-419 341	F Wing Area HVAC Rm F4 Closet				
2-418 342	F Wing Area HVAC Rm F5 Closet				
3-296 397	Multi-Purpose Bldg Girls Locker Room				
3-295 398	Multi-Purpose Bldg Girls Locker Room				
3-294 399	Multi-Purpose Bldg Girls Locker RR				
3-293 400	Multi-Purpose Bldg Girls Locker RR				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3-390 401	Multi-Purpose Bldg O/S Water Heater Closet				
3-390 402	Multi-Purpose Bldg O/S Water Heater Closet				
3-288 403	Multi-Purpose Bldg Boys Locker Room				
3-291 404	Multi-Purpose Bldg Boys Locker Room				
3-279 405	Multi-Purpose Bldg Classroom D1 Storage				
3-274 406	Multi-Purpose Bldg Kitchen				
3-272 407	Multi-Purpose Bldg Kitchen				
3-393 408	Multi-Purpose Bldg Attic MP Room				
3-391 409	Multi-Purpose Bldg Attic Girls Locker Rm				
3-385 410	Multi-Purpose Bldg Attic Boys Locker Rm				
3-384 411	Multi-Purpose Bldg Attic E Stage Stairs				
3-392 412	Multi-Purpose Bldg Attic Stage				
3-392 413	Multi-Purpose Bldg Attic Stage				
3-383 414	Multi-Purpose Bldg Attic Classroom D1				
3-382 415	Multi-Purpose Bldg Attic W Stage Stairs				
3-387 416	Multi-Purpose Bldg Attic Kitchen				
3-388 417	Multi-Purpose Bldg Attic Kitch Hose area				
3-386 418	Multi-Purpose Bldg Attic MP Rm S Soffit				
3-389 419	Multi-Purpose Bldg Attic Kitchen W Soffit				
3-292	Multi-Purpose Bldg Boys Locker Room				
Mechanical, Electrosonic, or Pressure Waterflow Device					
3-136 302	E Wing Area Rooms E1-E5 Bldg				
3-132 303	E Wing Area Rooms E6-E7 Bldg				
2-382 343	F Wing Area F Wing				
3-427 420	Multi-Purpose Bldg MP Rm Hall Storage				
Valve Tamper Switch					
3-135 304	E Wing Area PIV Tamper				
2-384 344	F Wing Area PIV				
2-383	F Wing Area OS&Y				
2-383	F Wing Area OS&Y				
Smoke Detector - Duct					
3-144	E Wing Area Media Library				
<b>Supervising Station Transmitting Equipment</b>					
ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Digital Alarm Communicator Transmitter					
	A Wing Area Room 7 Headend	Bosch	B9512G		
<b>Ventilation and Cooking Equipment</b>					
ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Fusible Links					
	Fusible Links 450 x 2				07/29/2025
Range Suppression					

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
	Suppression				07/29/2025
	Range Suppression Tank				
	Cylinder				01/29/2015
	Range Hood				
	Hood				01/29/2015
	Cooking Equipment				
	Appliances				01/29/2015
	[Other]				
	Fire Alarm Connection				01/29/2015