

Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

HARRY DEWEY

7025 FALCON RD
FAIR OAKS, California
United States

This site has been inspected and tested in compliance with applicable standards.

Completed

Thursday, September 11, 2025

Test Session: 26 Aug 2025 15:29 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD
5320 HEMLOCK ST
SACRAMENTO, California
United States

TESTED BY

Riley Goyet
Western States Fire Protection-
Sacramento
188 Cirby Way
Roseville, CA 95678
United States



Inspection Summary

Building Information

PROPERTY	HARRY DEWEY	CONTACT
ADDRESS	7025 FALCON RD	PHONE
CITY/STATE	FAIR?OAKS, California	MOBILE
COUNTRY	United States	EMAIL

Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us

Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Alarm Notification Appliance	69	69(100%)	69(100%)	0(0%)
Fire Control Panel	5	5(100%)	1(20%)	4(80%)
Initiating Device	141	141(100%)	141(100%)	0(0%)

Certification

The equipment specified here in was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Thursday, September 11, 2025

ACCEPTED BY 09/11/2025

Building Representative

TESTED BY 09/11/2025


Riley Goyet
Technician

System Details

Control Units

ADDRESS/ SCAN ADDRESS		DESCRIPTION	Rms 9 13 22 Bldg Storage S by Rm 22
MANUFACTURER	Notifier	S/W VERSION	
MODEL	NFS-3030	LAST UPDATE	
SERIAL NUMBER		S/W LOCATION	
INSTALL DATE	03/17/2019		

Open Corrective Action & Solution Summary

The following 6 corrective action(s) remain open following the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
NAC Power Extender Panel	026	Admin Bldg Work Room
	Created By:	
	Creation Date:	04/17/2020
	Corrective Action:	Failed test
	Proposed Solution:	Replace
	Manufacturer:	
	Model:	
	Created By:	Riley Goyet
	Creation Date:	10/11/2023
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
NAC Power Extender Panel	090	Rooms 5-8 Bldg Art Rm W by Rm 5
	Created By:	Riley Goyet
	Creation Date:	10/11/2023
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
NAC Power Extender Panel	171	Rooms 14-20 Bldg Cust Rm by Rm 22
	Created By:	Riley Goyet
	Creation Date:	10/11/2023
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
	Created By:	Riley Goyet
	Creation Date:	09/11/2024
	Corrective Action:	
	Proposed Solution:	
	Manufacturer:	
	Model:	
Fire Alarm Panel		Rms 9 13 22 Bldg Storage S by Rm 22
	Created By:	Riley Goyet
	Creation Date:	10/11/2023
	Corrective Action:	Replace (2) 12V 55AH Batteries
	Proposed Solution:	
	Manufacturer:	Notifier
	Model:	NFS-3030

Testing Details

Alarm Notification Appliance

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	017	Admin Bldg Front Office	Manual	8/26/2025 3:30:12 PM
		Visual inspection	Passed (Manual)	
Visible	022	Admin Bldg Mens RR Hall	Manual	8/26/2025 3:30:18 PM
		Visual inspection	Passed (Manual)	
Visible	025	Admin Bldg Nurse Restroom	Manual	8/26/2025 3:30:21 PM
		Visual inspection	Passed (Manual)	
Visible	024	Admin Bldg Nurse Room	Manual	8/26/2025 3:30:23 PM
		Visual inspection	Passed (Manual)	
Visible	019	Admin Bldg Office Hall	Manual	8/26/2025 3:30:15 PM
		Visual inspection	Passed (Manual)	
Visible	020	Admin Bldg Office Hall	Manual	8/26/2025 3:30:17 PM
		Visual inspection	Passed (Manual)	
Visible	023	Admin Bldg Principals Office	Manual	8/26/2025 3:30:19 PM
		Visual inspection	Passed (Manual)	
Visible	021	Admin Bldg Womens RR Hall	Manual	8/26/2025 3:31:55 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	018	Admin Bldg Work Room	Manual	8/26/2025 3:30:14 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	215	Multi-Purpose Bldg Kitchen	Manual	8/26/2025 3:31:54 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	213	Multi-Purpose Bldg MP Room	Manual	8/26/2025 3:31:51 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	214	Multi-Purpose Bldg MP Room	Manual	8/26/2025 3:31:52 PM
		Visual inspection	Passed (Manual)	
Audible	210	Multi-Purpose Bldg North Exterior	Manual	8/26/2025 3:31:46 PM
		Visual inspection	Passed (Manual)	
Audible	211	Multi-Purpose Bldg South Exterior	Manual	8/26/2025 3:31:48 PM
		Visual inspection	Passed (Manual)	
Audible	212	Multi-Purpose Bldg West Exterior	Manual	8/26/2025 3:31:49 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	190	Portables Classroom 23	Manual	8/26/2025 3:31:40 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	191	Portables Classroom 24	Manual	8/26/2025 3:31:42 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	192	Portables Disc Club Boys RR	Manual	8/26/2025 3:31:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	193	Portables Disc Club Girls RR	Manual	8/26/2025 3:31:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	189	Portables Discovery Club	Manual	8/26/2025 3:31:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	188	Portables South Exterior	Manual	8/26/2025 3:31:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	117	Rms 9 13 22 Bldg Classroom 10	Manual	8/26/2025 3:31:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	116	Rms 9 13 22 Bldg Classroom 9	Manual	8/26/2025 3:31:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	114	Rms 9 13 22 Bldg East Exterior	Manual	8/26/2025 3:30:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	122	Rms 9 13 22 Bldg Girls RR by Rm 22	Manual	8/26/2025 3:31:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	123	Rms 9 13 22 Bldg Boys RR by Rm 22	Manual	8/26/2025 3:31:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	118	Rms 9 13 22 Bldg Classroom 11	Manual	8/26/2025 3:31:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	119	Rms 9 13 22 Bldg Classroom 12	Manual	8/26/2025 3:31:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	120	Rms 9 13 22 Bldg Classroom 13	Manual	8/26/2025 3:31:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	121	Rms 9 13 22 Bldg Classroom 22	Manual	8/26/2025 3:31:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	113	Rms 9 13 22 Bldg North Exterior	Manual	8/26/2025 3:30:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	115	Rms 9 13 22 Bldg West Exterior	Manual	8/26/2025 3:31:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	050	Rooms 1-4 Bldg Classroom 1	Manual	8/26/2025 3:30:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	051	Rooms 1-4 Bldg Classroom 2	Manual	8/26/2025 3:30:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	054	Rooms 1-4 Bldg Classroom 2 RR N	Manual	8/26/2025 3:30:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible	055	Rooms 1-4 Bldg Classroom 2 RR S	Manual	8/26/2025 3:30:34 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	052	Rooms 1-4 Bldg Classroom 3	Manual	8/26/2025 3:30:30 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Visible	056	Rooms 1-4 Bldg Classroom 3 RR E	Manual	8/26/2025 3:30:36 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Visible	057	Rooms 1-4 Bldg Classroom 3 RR W	Manual	8/26/2025 3:30:37 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	053	Rooms 1-4 Bldg Classroom 4	Manual	8/26/2025 3:30:31 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Visible	058	Rooms 1-4 Bldg Classroom 4 RR E	Manual	8/26/2025 3:30:38 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Visible	059	Rooms 1-4 Bldg Classroom 4 RR W	Manual	8/26/2025 3:30:40 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible	048	Rooms 1-4 Bldg South Exterior	Manual	8/26/2025 3:30:24 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible	049	Rooms 1-4 Bldg South Exterior	Manual	8/26/2025 3:30:26 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Visible	170	Rooms 14-20 Bldg Boys RR by Rm 17	Manual	8/26/2025 3:31:34 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	162	Rooms 14-20 Bldg Classroom 14	Manual	8/26/2025 3:31:24 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	163	Rooms 14-20 Bldg Classroom 15	Manual	8/26/2025 3:31:22 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	164	Rooms 14-20 Bldg Classroom 16	Manual	8/26/2025 3:31:27 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	165	Rooms 14-20 Bldg Classroom 17	Manual	8/26/2025 3:31:26 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	166	Rooms 14-20 Bldg Classroom 18	Manual	8/26/2025 3:31:29 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	167	Rooms 14-20 Bldg Classroom 19	Manual	8/26/2025 3:31:32 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	168	Rooms 14-20 Bldg Classroom 20	Manual	8/26/2025 3:31:31 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Visible	169	Rooms 14-20 Bldg Girls RR by Rm 17	Manual	8/26/2025 3:31:36 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	160	Rooms 14-20 Bldg Library	Manual	8/26/2025 3:31:19 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	161	Rooms 14-20 Bldg Nook	Manual	8/26/2025 3:31:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	157	Rooms 14-20 Bldg North Exterior	Manual	8/26/2025 3:31:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	159	Rooms 14-20 Bldg Staff Lounge	Manual	8/26/2025 3:31:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	158	Rooms 14-20 Bldg West Exterior	Manual	8/26/2025 3:31:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	089	Rooms 5-8 Bldg Boys RR W by Rm 5	Manual	8/26/2025 3:30:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	083	Rooms 5-8 Bldg Classroom 5	Manual	8/26/2025 3:30:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	084	Rooms 5-8 Bldg Classroom 6	Manual	8/26/2025 3:30:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	085	Rooms 5-8 Bldg Classroom 7	Manual	8/26/2025 3:30:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	086	Rooms 5-8 Bldg Classroom 8	Manual	8/26/2025 3:30:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	087	Rooms 5-8 Bldg Classroom 9	Manual	8/26/2025 3:30:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	080	Rooms 5-8 Bldg East Exterior	Manual	8/26/2025 3:30:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	081	Rooms 5-8 Bldg East Exterior	Manual	8/26/2025 3:30:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	088	Rooms 5-8 Bldg Girls RR W by Rm 5	Manual	8/26/2025 3:30:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	079	Rooms 5-8 Bldg North Exterior	Manual	8/26/2025 3:30:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	082	Rooms 5-8 Bldg West Exterior	Manual	8/26/2025 3:30:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Remote Annunciator	001	Admin Bldg Front Office	Manual	8/26/2025 5:38:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Failed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
NAC Power Extender Panel	026	Admin Bldg Work Room	Manual	8/26/2025 5:37:56 PM
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	
Fire Alarm Panel		Rms 9 13 22 Bldg Storage S by Rm 22	Manual	8/26/2025 5:38:26 PM
		Manufacturer	Notifier	
		Model	NFS-3030	
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	
NAC Power Extender Panel	171	Rooms 14-20 Bldg Cust Rm by Rm 22	Manual	8/26/2025 5:38:02 PM
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	
NAC Power Extender Panel	090	Rooms 5-8 Bldg Art Rm W by Rm 5	Manual	8/26/2025 5:38:22 PM
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	

Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-142 016	Admin Bldg Attic Nurse Closet	Manual	8/26/2025 5:41:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-143 015	Admin Bldg Attic Womens RR	Manual	8/26/2025 5:38:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-130 002	Admin Bldg Front Office	Manual	8/26/2025 5:41:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-040 006	Admin Bldg Mens RR Hall	Manual	8/26/2025 5:41:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-006 013	Admin Bldg Nurse Closet	Manual	8/26/2025 5:41:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-008 014	Admin Bldg Nurse Restroom	Manual	8/26/2025 5:41:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-007 012	Admin Bldg Nurse Room	Manual	8/26/2025 5:37:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-041 007	Admin Bldg Office East	Manual	8/26/2025 5:41:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-043 003	Admin Bldg Office Hall	Manual	8/26/2025 5:41:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-042 004	Admin Bldg Office Hall	Manual	8/26/2025 5:41:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-005 008	Admin Bldg Office West	Manual	8/26/2025 5:41:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-003 010	Admin Bldg Principals Off Storage	Manual	8/26/2025 5:41:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-004 009	Admin Bldg Principals Office	Manual	8/26/2025 5:41:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-039 005	Admin Bldg Womens RR Hall	Manual	8/26/2025 5:41:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-002 011	Admin Bldg Work Room	Manual	8/26/2025 5:41:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-131 204	Multi-Purpose Bldg Attic Storage Middle	Manual	8/26/2025 5:39:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-134 205	Multi-Purpose Bldg Attic Storage West	Manual	8/26/2025 5:39:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-012 202	Multi-Purpose Bldg Kitchen	Manual	8/26/2025 5:38:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-013 201	Multi-Purpose Bldg Kitchen Storage	Manual	8/26/2025 5:40:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-126 203	Multi-Purpose Bldg Kitchen Wtr Htr Clst	Manual	8/26/2025 5:38:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-009 199	Multi-Purpose Bldg MP Rm Storage East	Manual	8/26/2025 5:40:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-010 200	Multi-Purpose Bldg MP Rm Storage West	Manual	8/26/2025 5:40:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-132 206	Multi-Purpose Bldg MP Room 1	Manual	8/26/2025 5:38:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-133 207	Multi-Purpose Bldg MP Room 2	Manual	8/26/2025 5:38:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-011 198	Multi-Purpose Bldg MP Room Closet	Manual	8/26/2025 5:41:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Projected Beam	2-136 208	Multi-Purpose Bldg MP Room East	Manual	8/26/2025 5:40:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Projected Beam	2-138 209	Multi-Purpose Bldg MP Room West	Manual	8/26/2025 5:40:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Manual Pull Station	2-144 195	Multi-Purpose Bldg Northeast Exit	Manual	8/26/2025 5:41:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-145 194	Multi-Purpose Bldg Northwest Exit	Manual	8/26/2025 5:41:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-147 197	Multi-Purpose Bldg South Exit	Manual	8/26/2025 5:41:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-146 196	Multi-Purpose Bldg Southeast Exit	Manual	8/26/2025 5:37:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-382 185	Portables Attic Classroom 23	Manual	8/26/2025 5:39:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-382 184	Portables Attic Classroom 23	Manual	8/26/2025 5:39:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-385 186	Portables Attic Classroom 24	Manual	8/26/2025 5:39:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-385 187	Portables Attic Classroom 24	Manual	8/26/2025 5:39:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-381 182	Portables Attic Discovery Club	Manual	8/26/2025 5:39:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-381 183	Portables Attic Discovery Club	Manual	8/26/2025 5:39:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-310 178	Portables Classroom 23	Manual	8/26/2025 5:37:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-311 179	Portables Classroom 23	Manual	8/26/2025 5:37:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-313 181	Portables Classroom 24	Manual	8/26/2025 5:37:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-312 180	Portables Classroom 24	Manual	8/26/2025 5:37:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-305 176	Portables Disc Club Boys RR	Manual	8/26/2025 5:37:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-306 177	Portables Disc Club Girls RR	Manual	8/26/2025 5:37:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-308 173	Portables Discovery Club	Manual	8/26/2025 5:37:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-304 174	Portables Discovery Club	Manual	8/26/2025 5:37:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-309 175	Portables Discovery Club	Manual	8/26/2025 5:37:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-307 172	Portables Discovery Club	Manual	8/26/2025 5:37:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-261 095	Rms 9 13 22 Bldg Classroom 10	Manual	8/26/2025 5:39:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-263 097	Rms 9 13 22 Bldg Classroom 11	Manual	8/26/2025 5:39:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-270 102	Rms 9 13 22 Bldg Classroom 12	Manual	8/26/2025 5:39:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-267 104	Rms 9 13 22 Bldg Classroom 13	Manual	8/26/2025 5:39:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-260 092	Rms 9 13 22 Bldg Classroom 9	Manual	8/26/2025 5:39:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-256 106	Rms 9 13 22 Bldg Girls RR by Rm 22	Manual	8/26/2025 5:39:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-376 112	Rms 9 13 22 Bldg Attic Room 22	Manual	8/26/2025 5:39:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-258 110	Rms 9 13 22 Bldg Boys RR by Rm 22	Manual	8/26/2025 5:39:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-262 094	Rms 9 13 22 Bldg Classroom 10	Manual	8/26/2025 5:39:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-272 096	Rms 9 13 22 Bldg Classroom 10	Manual	8/26/2025 5:39:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-264 098	Rms 9 13 22 Bldg Classroom 11	Manual	8/26/2025 5:39:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-271 099	Rms 9 13 22 Bldg Classroom 11	Manual	8/26/2025 5:39:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-266 100	Rms 9 13 22 Bldg Classroom 12	Manual	8/26/2025 5:39:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-265 101	Rms 9 13 22 Bldg Classroom 12	Manual	8/26/2025 5:39:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-268 103	Rms 9 13 22 Bldg Classroom 13	Manual	8/26/2025 5:39:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-269 105	Rms 9 13 22 Bldg Classroom 13	Manual	8/26/2025 5:39:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-257 108	Rms 9 13 22 Bldg Classroom 22	Manual	8/26/2025 5:39:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-254 107	Rms 9 13 22 Bldg Classroom 22	Manual	8/26/2025 5:39:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-259 091	Rms 9 13 22 Bldg Classroom 9	Manual	8/26/2025 5:39:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-273 093	Rms 9 13 22 Bldg Classroom 9	Manual	8/26/2025 5:39:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-255 111	Rms 9 13 22 Bldg Cust Rm by Rm 22	Manual	8/26/2025 5:38:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-253 109	Rms 9 13 22 Bldg Storage S by Rm 22	Manual	8/26/2025 5:37:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-038 028	Rooms 1-4 Bldg Classroom 1	Manual	8/26/2025 5:40:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-037 029	Rooms 1-4 Bldg Classroom 1	Manual	8/26/2025 5:40:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-017 027	Rooms 1-4 Bldg Classroom 1	Manual	8/26/2025 5:40:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-019 031	Rooms 1-4 Bldg Classroom 1 Closet	Manual	8/26/2025 5:40:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-018 030	Rooms 1-4 Bldg Classroom 1 RR S	Manual	8/26/2025 5:40:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-022 032	Rooms 1-4 Bldg Classroom 2	Manual	8/26/2025 5:40:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-036 034	Rooms 1-4 Bldg Classroom 2	Manual	8/26/2025 5:40:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-035 033	Rooms 1-4 Bldg Classroom 2	Manual	8/26/2025 5:40:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-021 036	Rooms 1-4 Bldg Classroom 2 RR N	Manual	8/26/2025 5:40:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-020 035	Rooms 1-4 Bldg Classroom 2 RR S	Manual	8/26/2025 5:40:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-029 040	Rooms 1-4 Bldg Classroom 3	Manual	8/26/2025 5:40:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-033 041	Rooms 1-4 Bldg Classroom 3	Manual	8/26/2025 5:40:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-023 037	Rooms 1-4 Bldg Classroom 3	Manual	8/26/2025 5:40:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-034 038	Rooms 1-4 Bldg Classroom 3	Manual	8/26/2025 5:40:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-032 039	Rooms 1-4 Bldg Classroom 3	Manual	8/26/2025 5:40:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-025 042	Rooms 1-4 Bldg Classroom 3 RR E	Manual	8/26/2025 5:40:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-024 043	Rooms 1-4 Bldg Classroom 3 RR W	Manual	8/26/2025 5:40:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-031 045	Rooms 1-4 Bldg Classroom 4	Manual	8/26/2025 5:40:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-028 044	Rooms 1-4 Bldg Classroom 4	Manual	8/26/2025 5:40:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-027 046	Rooms 1-4 Bldg Classroom 4 RR E	Manual	8/26/2025 5:40:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-026 047	Rooms 1-4 Bldg Classroom 4 RR W	Manual	8/26/2025 5:40:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-377 153	Rooms 14-20 Bldg Attic Classroom 17	Manual	8/26/2025 5:38:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-378 154	Rooms 14-20 Bldg Attic Classroom 18	Manual	8/26/2025 5:38:45 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-379 155	Rooms 14-20 Bldg Attic Classroom 19	Manual	8/26/2025 5:38:47 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-380 156	Rooms 14-20 Bldg Attic Classroom 20	Manual	8/26/2025 5:38:48 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-384 152	Rooms 14-20 Bldg Attic Staff Lounge	Manual	8/26/2025 5:38:50 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-282 151	Rooms 14-20 Bldg Boys RR by Rm 17	Manual	8/26/2025 5:37:48 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-277 150	Rooms 14-20 Bldg Boys RR by Rm 17	Manual	8/26/2025 5:37:50 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-280 140	Rooms 14-20 Bldg Classrm 17 Strge W	Manual	8/26/2025 5:37:42 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-289 132	Rooms 14-20 Bldg Classroom 14	Manual	8/26/2025 5:38:42 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-290 131	Rooms 14-20 Bldg Classroom 14	Manual	8/26/2025 5:39:14 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-291 134	Rooms 14-20 Bldg Classroom 15	Manual	8/26/2025 5:38:39 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-292 133	Rooms 14-20 Bldg Classroom 15	Manual	8/26/2025 5:38:41 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-293 136	Rooms 14-20 Bldg Classroom 16	Manual	8/26/2025 5:38:35 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-294 135	Rooms 14-20 Bldg Classroom 16	Manual	8/26/2025 5:38:37 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-302 137	Rooms 14-20 Bldg Classroom 17	Manual	8/26/2025 5:37:39 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-301 138	Rooms 14-20 Bldg Classroom 17	Manual	8/26/2025 5:40:55 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-299 142	Rooms 14-20 Bldg Classroom 18	Manual	8/26/2025 5:37:37 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-300 141	Rooms 14-20 Bldg Classroom 18	Manual	8/26/2025 5:37:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-298 144	Rooms 14-20 Bldg Classroom 19	Manual	8/26/2025 5:37:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-297 143	Rooms 14-20 Bldg Classroom 19	Manual	8/26/2025 5:37:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-296 145	Rooms 14-20 Bldg Classroom 20	Manual	8/26/2025 5:37:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-295 146	Rooms 14-20 Bldg Classroom 20	Manual	8/26/2025 5:37:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-276 149	Rooms 14-20 Bldg Cust Off by Rm 17	Manual	8/26/2025 5:37:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-278 147	Rooms 14-20 Bldg Girls RR by Rm 17	Manual	8/26/2025 5:37:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-279 148	Rooms 14-20 Bldg Girls RR by Rm 17	Manual	8/26/2025 5:37:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-285 127	Rooms 14-20 Bldg Library	Manual	8/26/2025 5:39:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-286 128	Rooms 14-20 Bldg Library	Manual	8/26/2025 5:39:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-287 130	Rooms 14-20 Bldg Nook	Manual	8/26/2025 5:37:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-288 129	Rooms 14-20 Bldg Nook	Manual	8/26/2025 5:37:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-281 139	Rooms 14-20 Bldg Rm 17 Music/PE Rm	Manual	8/26/2025 5:37:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-284 125	Rooms 14-20 Bldg Staff Lounge	Manual	8/26/2025 5:37:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-283 126	Rooms 14-20 Bldg Staff Lounge	Manual	8/26/2025 5:39:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-046 076	Rooms 5-8 Bldg Art Rm W by Rm 5	Manual	8/26/2025 5:39:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-047 077	Rooms 5-8 Bldg Boys RR W by Rm 5	Manual	8/26/2025 5:39:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-053 062	Rooms 5-8 Bldg Classroom 5	Manual	8/26/2025 5:40:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-052 061	Rooms 5-8 Bldg Classroom 5	Manual	8/26/2025 5:40:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-063 060	Rooms 5-8 Bldg Classroom 5	Manual	8/26/2025 5:40:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-055 063	Rooms 5-8 Bldg Classroom 6	Manual	8/26/2025 5:40:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-054 064	Rooms 5-8 Bldg Classroom 6	Manual	8/26/2025 5:40:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-062 065	Rooms 5-8 Bldg Classroom 6	Manual	8/26/2025 5:40:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-057 068	Rooms 5-8 Bldg Classroom 7	Manual	8/26/2025 5:40:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-056 067	Rooms 5-8 Bldg Classroom 7	Manual	8/26/2025 5:40:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-061 066	Rooms 5-8 Bldg Classroom 7	Manual	8/26/2025 5:40:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-058 070	Rooms 5-8 Bldg Classroom 8	Manual	8/26/2025 5:40:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-059 069	Rooms 5-8 Bldg Classroom 8	Manual	8/26/2025 5:40:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-060 071	Rooms 5-8 Bldg Classroom 8	Manual	8/26/2025 5:40:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-051 074	Rooms 5-8 Bldg Cust Rm W by Rm 5	Manual	8/26/2025 5:40:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-048 072	Rooms 5-8 Bldg Girls RR W by Rm 5	Manual	8/26/2025 5:41:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-050 073	Rooms 5-8 Bldg Girls RR W by Rm 5	Manual	8/26/2025 5:41:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-140 078	Rooms 5-8 Bldg RR Plmb Chs by 5	Manual	8/26/2025 5:38:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-049 075	Rooms 5-8 Bldg Storage W by Rm 5	Manual	8/26/2025 5:39:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Device/Equipment details

Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Audible And Visible					
017	Admin Bldg Front Office				
018	Admin Bldg Work Room				
050	Rooms 1-4 Bldg Classroom 1				
051	Rooms 1-4 Bldg Classroom 2				
052	Rooms 1-4 Bldg Classroom 3				
053	Rooms 1-4 Bldg Classroom 4				
083	Rooms 5-8 Bldg Classroom 5				
084	Rooms 5-8 Bldg Classroom 6				
085	Rooms 5-8 Bldg Classroom 7				
086	Rooms 5-8 Bldg Classroom 8				
087	Rooms 5-8 Bldg Classroom 9				
116	Rms 9 13 22 Bldg Classroom 9				
117	Rms 9 13 22 Bldg Classroom 10				
118	Rms 9 13 22 Bldg Classroom 11				
119	Rms 9 13 22 Bldg Classroom 12				
120	Rms 9 13 22 Bldg Classroom 13				
121	Rms 9 13 22 Bldg Classroom 22				
159	Rooms 14-20 Bldg Staff Lounge				
160	Rooms 14-20 Bldg Library				
161	Rooms 14-20 Bldg Nook				
162	Rooms 14-20 Bldg Classroom 14				
163	Rooms 14-20 Bldg Classroom 15				
164	Rooms 14-20 Bldg Classroom 16				
165	Rooms 14-20 Bldg Classroom 17				
166	Rooms 14-20 Bldg Classroom 18				
167	Rooms 14-20 Bldg Classroom 19				
168	Rooms 14-20 Bldg Classroom 20				
189	Portables Discovery Club				
190	Portables Classroom 23				
191	Portables Classroom 24				
213	Multi-Purpose Bldg MP Room				
214	Multi-Purpose Bldg MP Room				
215	Multi-Purpose Bldg Kitchen				
Visible					
019	Admin Bldg Office Hall				
020	Admin Bldg Office Hall				
021	Admin Bldg Womens RR Hall				
022	Admin Bldg Mens RR Hall				
023	Admin Bldg Principals Office				
024	Admin Bldg Nurse Room				
025	Admin Bldg Nurse Restroom				
054	Rooms 1-4 Bldg Classroom 2 RR N				
055	Rooms 1-4 Bldg Classroom 2 RR S				
056	Rooms 1-4 Bldg Classroom 3 RR E				
057	Rooms 1-4 Bldg Classroom 3 RR W				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
058	Rooms 1-4 Bldg Classroom 4 RR E				
059	Rooms 1-4 Bldg Classroom 4 RR W				
088	Rooms 5-8 Bldg Girls RR W by Rm 5				
089	Rooms 5-8 Bldg Boys RR W by Rm 5				
122	Rms 9 13 22 Bldg Girls RR by Rm 22				
123	Rms 9 13 22 Bldg Boys RR by Rm 22				
169	Rooms 14-20 Bldg Girls RR by Rm 17				
170	Rooms 14-20 Bldg Boys RR by Rm 17				
192	Portables Disc Club Boys RR				
193	Portables Disc Club Girls RR				

Audible

048	Rooms 1-4 Bldg South Exterior				
049	Rooms 1-4 Bldg South Exterior				
079	Rooms 5-8 Bldg North Exterior				
080	Rooms 5-8 Bldg East Exterior				
081	Rooms 5-8 Bldg East Exterior				
082	Rooms 5-8 Bldg West Exterior				
113	Rms 9 13 22 Bldg North Exterior				
114	Rms 9 13 22 Bldg East Exterior				
115	Rms 9 13 22 Bldg West Exterior				
157	Rooms 14-20 Bldg North Exterior				
158	Rooms 14-20 Bldg West Exterior				
188	Portables South Exterior				
210	Multi-Purpose Bldg North Exterior				
211	Multi-Purpose Bldg South Exterior				
212	Multi-Purpose Bldg West Exterior				

Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Remote Annunciator					
001	Admin Bldg Front Office				
NAC Power Extender Panel					
026	Admin Bldg Work Room				
090	Rooms 5-8 Bldg Art Rm W by Rm 5				
171	Rooms 14-20 Bldg Cust Rm by Rm 22				
Fire Alarm Panel					
	Rms 9 13 22 Bldg Storage S by Rm 22	Notifier	NFS-3030		03/18/2019

Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Manual Pull Station					
2-130 002	Admin Bldg Front Office				
2-145 194	Multi-Purpose Bldg Northwest Exit				
2-144 195	Multi-Purpose Bldg Northeast Exit				
2-146 196	Multi-Purpose Bldg Southeast Exit				
2-147 197	Multi-Purpose Bldg South Exit				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Smoke Detector - General					
2-043 003	Admin Bldg Office Hall				
2-042 004	Admin Bldg Office Hall				
2-039 005	Admin Bldg Womens RR Hall				
2-040 006	Admin Bldg Mens RR Hall				
2-041 007	Admin Bldg Office East				
2-005 008	Admin Bldg Office West				
2-004 009	Admin Bldg Principals Office				
2-003 010	Admin Bldg Principals Off Storage				
2-002 011	Admin Bldg Work Room				
2-007 012	Admin Bldg Nurse Room				
2-006 013	Admin Bldg Nurse Closet				
2-008 014	Admin Bldg Nurse Restroom				
2-017 027	Rooms 1-4 Bldg Classroom 1				
2-038 028	Rooms 1-4 Bldg Classroom 1				
2-037 029	Rooms 1-4 Bldg Classroom 1				
2-018 030	Rooms 1-4 Bldg Classroom 1 RR S				
2-019 031	Rooms 1-4 Bldg Classroom 1 Closet				
2-022 032	Rooms 1-4 Bldg Classroom 2				
2-035 033	Rooms 1-4 Bldg Classroom 2				
2-036 034	Rooms 1-4 Bldg Classroom 2				
2-020 035	Rooms 1-4 Bldg Classroom 2 RR S				
2-021 036	Rooms 1-4 Bldg Classroom 2 RR N				
2-023 037	Rooms 1-4 Bldg Classroom 3				
2-034 038	Rooms 1-4 Bldg Classroom 3				
2-032 039	Rooms 1-4 Bldg Classroom 3				
2-029 040	Rooms 1-4 Bldg Classroom 3				
2-033 041	Rooms 1-4 Bldg Classroom 3				
2-025 042	Rooms 1-4 Bldg Classroom 3 RR E				
2-024 043	Rooms 1-4 Bldg Classroom 3 RR W				
2-028 044	Rooms 1-4 Bldg Classroom 4				
2-031 045	Rooms 1-4 Bldg Classroom 4				
2-027 046	Rooms 1-4 Bldg Classroom 4 RR E				
2-026 047	Rooms 1-4 Bldg Classroom 4 RR W				
2-063 060	Rooms 5-8 Bldg Classroom 5				
2-052 061	Rooms 5-8 Bldg Classroom 5				
2-053 062	Rooms 5-8 Bldg Classroom 5				
2-055 063	Rooms 5-8 Bldg Classroom 6				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-054 064	Rooms 5-8 Bldg Classroom 6				
2-062 065	Rooms 5-8 Bldg Classroom 6				
2-061 066	Rooms 5-8 Bldg Classroom 7				
2-056 067	Rooms 5-8 Bldg Classroom 7				
2-057 068	Rooms 5-8 Bldg Classroom 7				
2-059 069	Rooms 5-8 Bldg Classroom 8				
2-058 070	Rooms 5-8 Bldg Classroom 8				
2-060 071	Rooms 5-8 Bldg Classroom 8				
2-048 072	Rooms 5-8 Bldg Girls RR W by Rm 5				
2-050 073	Rooms 5-8 Bldg Girls RR W by Rm 5				
2-051 074	Rooms 5-8 Bldg Cust Rm W by Rm 5				
2-049 075	Rooms 5-8 Bldg Storage W by Rm 5				
2-046 076	Rooms 5-8 Bldg Art Rm W by Rm 5				
2-047 077	Rooms 5-8 Bldg Boys RR W by Rm 5				
2-259 091	Rms 9 13 22 Bldg Classroom 9				
2-260 092	Rms 9 13 22 Bldg Classroom 9				
2-273 093	Rms 9 13 22 Bldg Classroom 9				
2-262 094	Rms 9 13 22 Bldg Classroom 10				
2-261 095	Rms 9 13 22 Bldg Classroom 10				
2-272 096	Rms 9 13 22 Bldg Classroom 10				
2-263 097	Rms 9 13 22 Bldg Classroom 11				
2-264 098	Rms 9 13 22 Bldg Classroom 11				
2-271 099	Rms 9 13 22 Bldg Classroom 11				
2-266 100	Rms 9 13 22 Bldg Classroom 12				
2-265 101	Rms 9 13 22 Bldg Classroom 12				
2-270 102	Rms 9 13 22 Bldg Classroom 12				
2-268 103	Rms 9 13 22 Bldg Classroom 13				
2-267 104	Rms 9 13 22 Bldg Classroom 13				
2-269 105	Rms 9 13 22 Bldg Classroom 13				
2-256 106	Rms 9 13 22 Bldg Girls RR by Rm 22				
2-254 107	Rms 9 13 22 Bldg Classroom 22				
2-257 108	Rms 9 13 22 Bldg Classroom 22				
2-253 109	Rms 9 13 22 Bldg Storage S by Rm 22				
2-258 110	Rms 9 13 22 Bldg Boys RR by Rm 22				
2-284 125	Rooms 14-20 Bldg Staff Lounge				
2-283 126	Rooms 14-20 Bldg Staff Lounge				
2-285 127	Rooms 14-20 Bldg Library				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-286 128	Rooms 14-20 Bldg Library				
2-288 129	Rooms 14-20 Bldg Nook				
2-287 130	Rooms 14-20 Bldg Nook				
2-290 131	Rooms 14-20 Bldg Classroom 14				
2-289 132	Rooms 14-20 Bldg Classroom 14				
2-292 133	Rooms 14-20 Bldg Classroom 15				
2-291 134	Rooms 14-20 Bldg Classroom 15				
2-294 135	Rooms 14-20 Bldg Classroom 16				
2-293 136	Rooms 14-20 Bldg Classroom 16				
2-302 137	Rooms 14-20 Bldg Classroom 17				
2-301 138	Rooms 14-20 Bldg Classroom 17				
2-281 139	Rooms 14-20 Bldg Rm 17 Music/PE Rm				
2-280 140	Rooms 14-20 Bldg Classrm 17 Strge W				
2-300 141	Rooms 14-20 Bldg Classroom 18				
2-299 142	Rooms 14-20 Bldg Classroom 18				
2-297 143	Rooms 14-20 Bldg Classroom 19				
2-298 144	Rooms 14-20 Bldg Classroom 19				
2-296 145	Rooms 14-20 Bldg Classroom 20				
2-295 146	Rooms 14-20 Bldg Classroom 20				
2-278 147	Rooms 14-20 Bldg Girls RR by Rm 17				
2-279 148	Rooms 14-20 Bldg Girls RR by Rm 17				
2-276 149	Rooms 14-20 Bldg Cust Off by Rm 17				
2-277 150	Rooms 14-20 Bldg Boys RR by Rm 17				
2-282 151	Rooms 14-20 Bldg Boys RR by Rm 17				
2-307 172	Portables Discovery Club				
2-308 173	Portables Discovery Club				
2-304 174	Portables Discovery Club				
2-309 175	Portables Discovery Club				
2-305 176	Portables Disc Club Boys RR				
2-306 177	Portables Disc Club Girls RR				
2-310 178	Portables Classroom 23				
2-311 179	Portables Classroom 23				
2-312 180	Portables Classroom 24				
2-313 181	Portables Classroom 24				
2-011 198	Multi-Purpose Bldg MP Room Closet				
2-009 199	Multi-Purpose Bldg MP Rm Storage East				
2-010 200	Multi-Purpose Bldg MP Rm Storage West				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-013 201	Multi-Purpose Bldg Kitchen Storage				
Heat Detector - Restorable Spot					
2-143 015	Admin Bldg Attic Womens RR				
2-142 016	Admin Bldg Attic Nurse Closet				
2-140 078	Rooms 5-8 Bldg RR Plmb Chs by 5				
2-255 111	Rms 9 13 22 Bldg Cust Rm by Rm 22				
2-376 112	Rms 9 13 22 Bldg Attic Room 22				
2-384 152	Rooms 14-20 Bldg Attic Staff Lounge				
2-377 153	Rooms 14-20 Bldg Attic Classroom 17				
2-378 154	Rooms 14-20 Bldg Attic Classroom 18				
2-379 155	Rooms 14-20 Bldg Attic Classroom 19				
2-380 156	Rooms 14-20 Bldg Attic Classroom 20				
2-381 182	Portables Attic Discovery Club				
2-381 183	Portables Attic Discovery Club				
2-382 184	Portables Attic Classroom 23				
2-382 185	Portables Attic Classroom 23				
2-385 186	Portables Attic Classroom 24				
2-385 187	Portables Attic Classroom 24				
2-012 202	Multi-Purpose Bldg Kitchen				
2-126 203	Multi-Purpose Bldg Kitchen Wtr Htr Clst				
2-131 204	Multi-Purpose Bldg Attic Storage Middle				
2-134 205	Multi-Purpose Bldg Attic Storage West				
Smoke Detector - Duct					
2-132 206	Multi-Purpose Bldg MP Room 1				
2-133 207	Multi-Purpose Bldg MP Room 2				
Smoke Detector - Projected Beam					
2-136 208	Multi-Purpose Bldg MP Room East				
2-138 209	Multi-Purpose Bldg MP Room West				