

Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

THOMAS EDISON

2950 HURLEY WAY
SACRAMENTO, California
United States

This site has been inspected and tested in compliance with applicable standards.

Completed

Thursday, October 09, 2025

Test Session:01 Oct 2025 14:39 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD
5320 HEMLOCK ST
SACRAMENTO, California
United States

TESTED BY

Riley Goyet
Western States Fire Protection-
Sacramento
188 Cirby Way
Roseville, CA 95678
United States



Inspection Summary

Building Information

PROPERTY	THOMAS EDISON	CONTACT
ADDRESS	2950 HURLEY WAY	PHONE
CITY/STATE	SACRAMENTO, California	MOBILE
COUNTRY	United States	EMAIL

Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us

Testing Summary


EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Alarm Notification Appliance	108	108(100%)	108(100%)	0(0%)
Ventilation and Cooking Equipment	6	0(0%)	0(0%)	0(0%)
Fire Control Panel	9	9(100%)	9(100%)	0(0%)
Initiating Device	290	281(97%)	280(97%)	1(0%)

Certification

The equipment specified here in was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Thursday, October 09, 2025

ACCEPTED BY 10/09/2025

Building Representative


TESTED BY 10/09/2025
Riley Goyet
Technician

System Details

Control Units

ADDRESS/ SCAN ADDRESS		DESCRIPTION	Building A A1C Headend
MANUFACTURER	Edwards	S/W VERSION	
MODEL	EST-3	LAST UPDATE	
SERIAL NUMBER		S/W LOCATION	
INSTALL DATE			

Open Corrective Action & Solution Summary

The following 3 corrective action(s) remain open following the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
Smoke Detector - Duct	2-134 066	Building C Classroom C4
	Created By:	Riley Goyet
	Creation Date:	09/28/2023
	Corrective Action:	Device was in supervisory upon arrival.
	Proposed Solution:	
	Manufacturer:	
	Model:	
	Created By:	Riley Goyet
	Creation Date:	09/24/2024
	Corrective Action:	Was in supervisory prior to testing
	Proposed Solution:	
	Manufacturer:	
	Model:	

Range Suppression	101-20 Cartridge	
	Created By:	Casey Smith
	Creation Date:	07/29/2025
	Corrective Action:	Hydro tested test cartridge is installed in this system
	Proposed Solution:	Replace cartridge with Ansul certified cartridge
	Manufacturer:	
	Model:	



Testing Details

Alarm Notification Appliance

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	014	Building A A1 Reception	Manual	10/1/2025 2:42:36 PM
		Visual inspection	Passed (Manual)	
Visible	015	Building A A1A Office	Manual	10/1/2025 2:41:02 PM
		Visual inspection	Passed (Manual)	
Visible	016	Building A A1B Office	Manual	10/1/2025 2:41:01 PM
		Visual inspection	Passed (Manual)	
Visible	017	Building A A1D Office	Manual	10/1/2025 2:40:59 PM
		Visual inspection	Passed (Manual)	
Visible	018	Building A A1F Staff Restroom	Manual	10/1/2025 2:40:58 PM
		Visual inspection	Passed (Manual)	
Visible	020	Building A A2 Principals Office	Manual	10/1/2025 2:40:55 PM
		Visual inspection	Passed (Manual)	
Visible	019	Building A Hallway	Manual	10/1/2025 2:40:57 PM
		Visual inspection	Passed (Manual)	
Audible	013	Building A South Exterior	Manual	10/1/2025 2:42:35 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	040	Building B Classroom B1	Manual	10/1/2025 2:42:13 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	041	Building B Classroom B2	Manual	10/1/2025 2:42:12 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	042	Building B Classroom B3	Manual	10/1/2025 2:42:10 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	043	Building B Classroom B4	Manual	10/1/2025 2:42:09 PM
		Visual inspection	Passed (Manual)	
Audible	039	Building B East Exterior	Manual	10/1/2025 2:42:33 PM
		Visual inspection	Passed (Manual)	
Visible	074	Building C Boys Restroom	Manual	10/1/2025 2:40:54 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	068	Building C Classroom C1	Manual	10/1/2025 2:42:07 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	069	Building C Classroom C2	Manual	10/1/2025 2:42:06 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	070	Building C Classroom C3	Manual	10/1/2025 2:42:05 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	071	Building C Classroom C4	Manual	10/1/2025 2:42:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	067	Building C East Exterior	Manual	10/1/2025 2:42:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	075	Building C Girls Restroom	Manual	10/1/2025 2:40:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	073	Building C Hallway	Manual	10/1/2025 2:42:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	072	Building C Hallway	Manual	10/1/2025 2:42:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	086	Building D D1 Library	Manual	10/1/2025 2:42:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	087	Building D D1 Library	Manual	10/1/2025 2:41:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	088	Building D D2 Library	Manual	10/1/2025 2:41:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	105	Building E Classroom E1	Manual	10/1/2025 2:41:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	107	Building E Classroom E1C	Manual	10/1/2025 2:40:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	106	Building E Classroom E2	Manual	10/1/2025 2:41:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	108	Building E E1A Office	Manual	10/1/2025 2:40:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	109	Building E E1B Office	Manual	10/1/2025 2:40:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	104	Building E North Exterior	Manual	10/1/2025 2:42:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	121	Building F Classroom F1	Manual	10/1/2025 2:41:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	122	Building F Classroom F2	Manual	10/1/2025 2:41:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	120	Building F North Exterior	Manual	10/1/2025 2:42:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	140	Building G Classroom G1	Manual	10/1/2025 2:41:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	141	Building G Classroom G2	Manual	10/1/2025 2:41:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	142	Building G Classroom G3	Manual	10/1/2025 2:41:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	139	Building G North Exterior	Manual	10/1/2025 2:42:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	165	Building H Classroom H1	Manual	10/1/2025 2:41:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	166	Building H Classroom H2	Manual	10/1/2025 2:41:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	167	Building H Classroom H3	Manual	10/1/2025 2:41:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	168	Building H Classroom H4	Manual	10/1/2025 2:41:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	169	Building H Classroom H5	Manual	10/1/2025 2:41:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	164	Building H North Exterior	Manual	10/1/2025 2:42:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	202	Building I Classroom I-1	Manual	10/1/2025 2:41:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	203	Building I Classroom I-2	Manual	10/1/2025 2:41:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	204	Building I Classroom I-3	Manual	10/1/2025 2:41:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	205	Building I Classroom I-4	Manual	10/1/2025 2:41:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	206	Building I Classroom I-5	Manual	10/1/2025 2:41:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	200	Building I East Exterior	Manual	10/1/2025 2:42:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	210	Building I I-11 Girls Restroom	Manual	10/1/2025 2:40:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	207	Building I I-6 Boys Restroom	Manual	10/1/2025 2:40:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	208	Building I I-8 Girls Restroom	Manual	10/1/2025 2:40:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	209	Building I I-9 Boys Restroom	Manual	10/1/2025 2:40:44 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	199	Building I North Exterior	Manual	10/1/2025 2:42:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	201	Building I West Exterior	Manual	10/1/2025 2:42:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	239	Building J Classroom J1	Manual	10/1/2025 2:41:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	241	Building J Classroom J3	Manual	10/1/2025 2:41:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	242	Building J Classroom J4	Manual	10/1/2025 2:41:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	243	Building J Classroom J5	Manual	10/1/2025 2:41:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	245	Building J Copy Rm by J2	Manual	10/1/2025 2:40:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	247	Building J J10 Womens RR	Manual	10/1/2025 2:40:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	240	Building J J2A Staff Room	Manual	10/1/2025 2:41:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	246	Building J J8 Mens Restroom	Manual	10/1/2025 2:40:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	238	Building J North Exterior	Manual	10/1/2025 2:42:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	244	Building J Room J2	Manual	10/1/2025 2:40:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	337	Building K East Exterior	Manual	10/1/2025 2:42:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	339	Building K K1 MP Room	Manual	10/1/2025 2:41:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	338	Building K K1 MP Room	Manual	10/1/2025 2:41:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	347	Building K K1 MP Room	Manual	10/1/2025 2:40:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	346	Building K K1 MP Room	Manual	10/1/2025 2:40:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	363	Building K K11 Restroom	Manual	10/1/2025 2:40:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	345	Building K K12 Kitchen	Manual	10/1/2025 2:42:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	364	Building K K12 Kitchen	Manual	10/1/2025 2:40:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	348	Building K K2 MP Room Stage	Manual	10/1/2025 2:40:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	355	Building K K5 Boys Restroom	Manual	10/1/2025 2:40:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	356	Building K K5 Girls Restroom	Manual	10/1/2025 2:40:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	357	Building K K5 Storage Room	Manual	10/1/2025 2:40:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	358	Building K K5A Office	Manual	10/1/2025 2:40:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	359	Building K K7 Boys Restroom	Manual	10/1/2025 2:40:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	360	Building K K7 Girls Restroom	Manual	10/1/2025 2:40:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	361	Building K K7 Office	Manual	10/1/2025 2:40:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	362	Building K K7 Training Strg Rm	Manual	10/1/2025 2:40:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	344	Building K Room K11	Manual	10/1/2025 2:41:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	349	Building K Room K2A Hall	Manual	10/1/2025 2:40:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	340	Building K Room K3	Manual	10/1/2025 2:41:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	350	Building K Room K3 Hall	Manual	10/1/2025 2:40:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	351	Building K Room K3A Office	Manual	10/1/2025 2:40:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	352	Building K Room K3B Office	Manual	10/1/2025 2:40:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	353	Building K Room K3C Office	Manual	10/1/2025 2:40:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	341	Building K Room K4	Manual	10/1/2025 2:41:21 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	354	Building K Room K4	Manual	10/1/2025 2:40:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	342	Building K Room K5	Manual	10/1/2025 2:41:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	343	Building K Room K7	Manual	10/1/2025 2:41:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	384	Building L Boys Restroom	Manual	10/1/2025 2:40:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	381	Building L Classroom L1	Manual	10/1/2025 2:41:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	382	Building L Classroom L2	Manual	10/1/2025 2:41:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	383	Building L Classroom L3	Manual	10/1/2025 2:41:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	385	Building L Girls Restroom	Manual	10/1/2025 2:40:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	380	Building L North Exterior	Manual	10/1/2025 2:42:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	386	Building L Staff Restroom	Manual	10/1/2025 2:40:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	404	Building M Classroom M1	Manual	10/1/2025 2:41:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	405	Building M Classroom M2	Manual	10/1/2025 2:41:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	406	Building M Classroom M3	Manual	10/1/2025 2:41:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	407	Building M Classroom M4	Manual	10/1/2025 2:41:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	409	Building M Cust Storage M6	Manual	10/1/2025 2:41:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	403	Building M North Exterior	Manual	10/1/2025 2:42:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	408	Building M Work Room M5	Manual	10/1/2025 2:41:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Remote Annunciator	001	Building A A1 Reception	Manual	10/1/2025 8:47:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Fire Alarm Panel		Building A A1C Headend	Manual	10/1/2025 8:47:11 PM
		Manufacturer	Edwards	
		Model	EST-3	
NAC Power Extender Panel	021	Building A A1C Headend	Manual	10/1/2025 8:47:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	022	Building A A1C Headend	Manual	10/1/2025 8:47:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	076	Building C C6 Custodial Closet	Manual	10/1/2025 8:48:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	143	Building G Room G2A Telco Rm	Manual	10/1/2025 8:48:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	170	Building H Classroom H5	Manual	10/1/2025 8:48:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	250	Building J Book Strg Room J6	Manual	10/1/2025 8:48:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	365	Building K K9 Electrical Room	Manual	10/1/2025 8:48:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Manual Pull Station	2-138 002	Building A A1 Reception	Manual	10/1/2025 6:25:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-011 003	Building A A1 Reception	Manual	10/1/2025 4:55:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-006 004	Building A A1A Office	Manual	10/1/2025 8:43:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-004 005	Building A A1B Office	Manual	10/1/2025 8:43:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-003 011	Building A A1C Headend	Manual	10/1/2025 4:55:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-002 006	Building A A1C Headend	Manual	10/1/2025 8:43:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-007 008	Building A A1D Office	Manual	10/1/2025 8:43:49 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	2-010 010	Building A A1F Staff Restroom	Manual	10/1/2025 8:43:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-009 009	Building A A2 Principals Office	Manual	10/1/2025 8:43:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-008 007	Building A Hallway	Manual	10/1/2025 8:43:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-133 031	Building B Attic Classroom B1	Manual	10/1/2025 9:50:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-133 032	Building B Attic Classroom B1	Manual	10/1/2025 9:51:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-132 034	Building B Attic Classroom B2	Manual	10/1/2025 9:55:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-132 033	Building B Attic Classroom B2	Manual	10/1/2025 9:55:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-131 035	Building B Attic Classroom B3	Manual	10/1/2025 9:59:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-131 036	Building B Attic Classroom B3	Manual	10/1/2025 9:59:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-130 038	Building B Attic Classroom B4	Manual	10/1/2025 10:03:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-130 037	Building B Attic Classroom B4	Manual	10/1/2025 10:03:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-044 023	Building B Classroom B1	Manual	10/1/2025 7:12:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-045 024	Building B Classroom B1	Manual	10/1/2025 7:12:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-043 025	Building B Classroom B2	Manual	10/1/2025 7:18:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-042 026	Building B Classroom B2	Manual	10/1/2025 8:22:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-040 028	Building B Classroom B3	Manual	10/1/2025 7:16:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-039 027	Building B Classroom B3	Manual	10/1/2025 7:16:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-038 029	Building B Classroom B4	Manual	10/1/2025 7:14:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-037 030	Building B Classroom B4	Manual	10/1/2025 7:14:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-024 061	Building C Boys Restroom	Manual	10/1/2025 7:33:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-023 063	Building C C6 Custodial Closet	Manual	10/1/2025 7:34:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-033 044	Building C Classroom C1	Manual	10/1/2025 7:41:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-032 047	Building C Classroom C1	Manual	10/1/2025 7:41:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-034 046	Building C Classroom C1	Manual	10/1/2025 7:41:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-035 045	Building C Classroom C1	Manual	10/1/2025 7:41:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-020 051	Building C Classroom C2	Manual	10/1/2025 7:51:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-019 050	Building C Classroom C2	Manual	10/1/2025 7:52:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-021 049	Building C Classroom C2	Manual	10/1/2025 7:52:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-022 048	Building C Classroom C2	Manual	10/1/2025 7:53:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-017 065	Building C Classroom C3	Manual	10/1/2025 9:47:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-016 053	Building C Classroom C3	Manual	10/1/2025 7:57:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-014 054	Building C Classroom C3	Manual	10/1/2025 7:57:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-015 052	Building C Classroom C3	Manual	10/1/2025 7:57:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-029 058	Building C Classroom C4	Manual	10/1/2025 7:39:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-030 057	Building C Classroom C4	Manual	10/1/2025 7:39:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-028 056	Building C Classroom C4	Manual	10/1/2025 7:39:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-027 055	Building C Classroom C4	Manual	10/1/2025 7:40:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-026 062	Building C Girls Restroom	Manual	10/1/2025 8:01:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-018 059	Building C Hall by Room C3	Manual	10/1/2025 7:38:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-031 060	Building C Hall by Room C4	Manual	10/1/2025 7:37:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-025 064	Building C Utility Closet	Manual	10/1/2025 7:36:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-050 077	Building D D1 Library	Manual	10/1/2025 4:14:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-051 080	Building D D1 Library	Manual	10/1/2025 4:14:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-052 079	Building D D1 Library	Manual	10/1/2025 4:14:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-053 078	Building D D1 Library	Manual	10/1/2025 4:14:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-058 083	Building D D2 Library	Manual	10/1/2025 6:39:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-054 082	Building D D2 Library	Manual	10/1/2025 6:39:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-055 081	Building D D2 Library	Manual	10/1/2025 6:39:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-057 084	Building D D2A Library	Manual	10/1/2025 6:39:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-056 085	Building D D2B Library	Manual	10/1/2025 6:41:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-068 092	Building E Classroom E1	Manual	10/1/2025 4:21:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-073 089	Building E Classroom E1	Manual	10/1/2025 4:21:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-072 090	Building E Classroom E1	Manual	10/1/2025 4:21:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-069 091	Building E Classroom E1	Manual	10/1/2025 4:22:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-070 093	Building E Classroom E1C	Manual	10/1/2025 4:24:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-071 094	Building E Classroom E1C	Manual	10/1/2025 4:25:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-062 098	Building E Classroom E2	Manual	10/1/2025 4:31:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-061 099	Building E Classroom E2	Manual	10/1/2025 4:31:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-063 101	Building E Classroom E2	Manual	10/1/2025 4:32:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-060 100	Building E Classroom E2	Manual	10/1/2025 4:32:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-066 103	Building E Cust Wtr Htr Clst	Manual	10/1/2025 10:16:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-067 102	Building E Custodial Closet	Manual	10/1/2025 4:33:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-064 095	Building E E1A Office	Manual	10/1/2025 7:01:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-065 097	Building E E1B Office	Manual	10/1/2025 4:26:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-116 096	Building E E1B Office	Manual	10/1/2025 4:26:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-081 111	Building F Classroom F1	Manual	10/1/2025 4:35:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-082 110	Building F Classroom F1	Manual	10/1/2025 4:35:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-083 113	Building F Classroom F1	Manual	10/1/2025 4:35:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-084 112	Building F Classroom F1	Manual	10/1/2025 4:36:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-077 115	Building F Classroom F2	Manual	10/1/2025 4:44:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-078 116	Building F Classroom F2	Manual	10/1/2025 4:44:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-076 118	Building F Classroom F2	Manual	10/1/2025 4:44:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-079 117	Building F Classroom F2	Manual	10/1/2025 6:56:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-080 114	Building F Store Room F1A	Manual	10/1/2025 8:25:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-075 119	Building F Store Room F2A	Manual	10/1/2025 4:44:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-137 130	Building G Attic Classroom G1	Manual	10/1/2025 9:17:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-137 131	Building G Attic Classroom G1	Manual	10/1/2025 9:17:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-137 132	Building G Attic Classroom G1	Manual	10/1/2025 9:17:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-135 134	Building G Attic Classroom G2	Manual	10/1/2025 9:21:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-135 135	Building G Attic Classroom G2	Manual	10/1/2025 9:21:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-135 133	Building G Attic Classroom G2	Manual	10/1/2025 9:21:28 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-136 137	Building G Attic Classroom G3	Manual	10/1/2025 9:24:34 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-136 136	Building G Attic Classroom G3	Manual	10/1/2025 9:24:36 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-136 138	Building G Attic Classroom G3	Manual	10/1/2025 9:24:37 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-092 123	Building G Classroom G1	Manual	10/1/2025 4:44:58 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-093 124	Building G Classroom G1	Manual	10/1/2025 4:45:02 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-088 125	Building G Classroom G2	Manual	10/1/2025 4:45:59 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-089 126	Building G Classroom G2	Manual	10/1/2025 4:46:05 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-090 128	Building G Classroom G3	Manual	10/1/2025 4:47:18 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-091 129	Building G Classroom G3	Manual	10/1/2025 4:47:24 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-087 127	Building G Room G2A Telco Rm	Manual	10/1/2025 6:51:47 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-113 147	Building H Classroom H1	Manual	10/1/2025 3:06:00 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-114 146	Building H Classroom H1	Manual	10/1/2025 3:06:15 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-115 145	Building H Classroom H1	Manual	10/1/2025 3:07:13 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-112 144	Building H Classroom H1	Manual	10/1/2025 3:08:07 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-110 148	Building H Classroom H2	Manual	10/1/2025 3:10:14 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-111 151	Building H Classroom H2	Manual	10/1/2025 3:12:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-108 150	Building H Classroom H2	Manual	10/1/2025 3:12:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-109 149	Building H Classroom H2	Manual	10/1/2025 3:13:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-105 152	Building H Classroom H3	Manual	10/1/2025 3:15:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-106 153	Building H Classroom H3	Manual	10/1/2025 3:15:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-107 154	Building H Classroom H3	Manual	10/1/2025 3:16:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-104 155	Building H Classroom H3	Manual	10/1/2025 3:16:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-102 156	Building H Classroom H4	Manual	10/1/2025 3:17:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-100 158	Building H Classroom H4	Manual	10/1/2025 3:18:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-101 157	Building H Classroom H4	Manual	10/1/2025 3:18:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-103 159	Building H Classroom H4	Manual	10/1/2025 6:48:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-099 160	Building H Classroom H5	Manual	10/1/2025 3:19:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-098 161	Building H Classroom H5	Manual	10/1/2025 3:19:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-097 163	Building H Classroom H5	Manual	10/1/2025 3:21:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-096 162	Building H Classroom H5	Manual	10/1/2025 3:22:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-302 171	Building I Classroom I-1	Manual	10/1/2025 3:41:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-303 174	Building I Classroom I-1	Manual	10/1/2025 3:42:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-301 172	Building I Classroom I-1	Manual	10/1/2025 8:09:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-304 173	Building I Classroom I-1	Manual	10/1/2025 8:09:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-299 175	Building I Classroom I-2	Manual	10/1/2025 3:36:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-298 176	Building I Classroom I-2	Manual	10/1/2025 3:36:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-297 177	Building I Classroom I-2	Manual	10/1/2025 3:36:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-300 178	Building I Classroom I-2	Manual	10/1/2025 3:42:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-294 179	Building I Classroom I-3	Manual	10/1/2025 3:45:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-295 182	Building I Classroom I-3	Manual	10/1/2025 3:45:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-296 181	Building I Classroom I-3	Manual	10/1/2025 3:45:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-293 180	Building I Classroom I-3	Manual	10/1/2025 3:46:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-291 183	Building I Classroom I-4	Manual	10/1/2025 3:47:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-290 184	Building I Classroom I-4	Manual	10/1/2025 3:47:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-289 185	Building I Classroom I-4	Manual	10/1/2025 3:47:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-292 186	Building I Classroom I-4	Manual	10/1/2025 3:47:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-287 187	Building I Classroom I-5	Manual	10/1/2025 3:48:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-286 188	Building I Classroom I-5	Manual	10/1/2025 3:48:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-288 190	Building I Classroom I-5	Manual	10/1/2025 8:11:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-285 189	Building I Classroom I-5	Manual	10/1/2025 8:11:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-306 195	Building I I-10 Custodial Closet	Manual	10/1/2025 8:26:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-307 198	Building I I-10 RR Plumb Chase	Manual	10/1/2025 9:39:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-305 196	Building I I-11 Girls Restroom	Manual	10/1/2025 8:26:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-281 191	Building I I-6 Boys Restroom	Manual	10/1/2025 3:49:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-282 192	Building I I-7 Custodial Closet	Manual	10/1/2025 3:50:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-283 197	Building I I-7 RR Plumb Chase	Manual	10/1/2025 9:38:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-284 193	Building I I-8 Girls Restroom	Manual	10/1/2025 3:50:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-308 194	Building I I-9 Boys Restroom	Manual	10/1/2025 8:26:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-279 234	Building J AV Storage Rm J7	Manual	10/1/2025 8:06:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-277 232	Building J Book Strg Room J6	Manual	10/1/2025 3:52:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-278 233	Building J Book Strg Room J6	Manual	10/1/2025 3:53:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-258 211	Building J Classroom J1	Manual	10/1/2025 4:10:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-257 214	Building J Classroom J1	Manual	10/1/2025 4:10:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-256 213	Building J Classroom J1	Manual	10/1/2025 4:10:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-259 212	Building J Classroom J1	Manual	10/1/2025 4:10:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-267 220	Building J Classroom J3	Manual	10/1/2025 3:57:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-266 223	Building J Classroom J3	Manual	10/1/2025 3:57:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-265 222	Building J Classroom J3	Manual	10/1/2025 3:57:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-268 221	Building J Classroom J3	Manual	10/1/2025 3:57:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-270 224	Building J Classroom J4	Manual	10/1/2025 3:55:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-271 225	Building J Classroom J4	Manual	10/1/2025 3:55:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-269 227	Building J Classroom J4	Manual	10/1/2025 3:56:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-272 226	Building J Classroom J4	Manual	10/1/2025 3:56:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-274 228	Building J Classroom J5	Manual	10/1/2025 3:53:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-275 229	Building J Classroom J5	Manual	10/1/2025 3:54:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-276 230	Building J Classroom J5	Manual	10/1/2025 3:54:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-273 231	Building J Classroom J5	Manual	10/1/2025 3:54:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-253 237	Building J J10 Womens RR	Manual	10/1/2025 8:01:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-261 218	Building J J2A Staff Room	Manual	10/1/2025 4:00:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-262 219	Building J J2A Staff Room	Manual	10/1/2025 4:01:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-255 235	Building J J8 Mens Restroom	Manual	10/1/2025 8:03:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-254 236	Building J J9 Custodian Office	Manual	10/1/2025 8:02:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-263 216	Building J Room J2	Manual	10/1/2025 4:00:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-260 215	Building J Room J2 Hall	Manual	10/1/2025 3:59:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-264 217	Building J Room J2 Office	Manual	10/1/2025 4:07:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-376 329	Building K Attic K5 Restroom	Manual	10/1/2025 10:16:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-378 332	Building K Attic K7 Boys RR	Manual	10/1/2025 10:16:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-385 333	Building K Attic K7 Girls RR	Manual	10/1/2025 10:16:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-379 331	Building K Attic K7 Office	Manual	10/1/2025 3:52:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-320 301	Building K HVAC Room K6	Manual	10/1/2025 8:18:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-361 262	Building K K1 MP Room	Manual	10/1/2025 5:17:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-362 263	Building K K1 MP Room	Manual	10/1/2025 5:17:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-363 264	Building K K1 MP Room	Manual	10/1/2025 5:17:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-364 265	Building K K1 MP Room	Manual	10/1/2025 5:17:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-366 267	Building K K1 MP Room	Manual	10/1/2025 5:17:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-365 266	Building K K1 MP Room	Manual	10/1/2025 5:17:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-367 256	Building K K1 MP Room	Manual	10/1/2025 5:18:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-368 257	Building K K1 MP Room	Manual	10/1/2025 5:18:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-369 258	Building K K1 MP Room	Manual	10/1/2025 5:18:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-370 259	Building K K1 MP Room	Manual	10/1/2025 5:18:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-371 260	Building K K1 MP Room	Manual	10/1/2025 5:19:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-372 261	Building K K1 MP Room	Manual	10/1/2025 5:19:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-149 252	Building K K1 MP Room NE	Manual	10/1/2025 5:20:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-150 251	Building K K1 MP Room NW	Manual	10/1/2025 5:21:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-346 318	Building K K11A Restroom	Manual	10/1/2025 5:23:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-349 321	Building K K12 Kitchen	Manual	10/1/2025 9:34:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-348 322	Building K K12 Kitchen	Manual	10/1/2025 9:34:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-153 255	Building K K12 Kitchen	Manual	10/1/2025 5:24:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-347 319	Building K K12D Kitchen Strg	Manual	10/1/2025 5:23:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-373 268	Building K K2 MP Room Stage	Manual	10/1/2025 5:13:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-374 269	Building K K2 MP Room Stage	Manual	10/1/2025 5:13:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-360 270	Building K K2 MP Room Stage	Manual	10/1/2025 5:14:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-359 271	Building K K2 MP Room Stage	Manual	10/1/2025 5:14:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-151 253	Building K K2 Stage East Exit	Manual	10/1/2025 3:05:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-313 295	Building K K5 Boys Restroom	Manual	10/1/2025 5:03:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-252 296	Building K K5 Girls Restroom	Manual	10/1/2025 5:02:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-318 300	Building K K5 South Exit	Manual	10/1/2025 4:59:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-319 297	Building K K5 Storage Room	Manual	10/1/2025 5:00:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-317 298	Building K K5A Office	Manual	10/1/2025 4:59:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-316 299	Building K K5A Office Closet	Manual	10/1/2025 4:59:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-375 311	Building K K7 Boys Restroom	Manual	10/1/2025 8:24:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-325 312	Building K K7 Girls Restroom	Manual	10/1/2025 8:23:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-323 308	Building K K7 Office	Manual	10/1/2025 8:24:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-324 309	Building K K7 Office Closet	Manual	10/1/2025 8:24:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-328 307	Building K K7 Training Rm NE	Manual	10/1/2025 8:21:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-326 304	Building K K7 Training Rm SE	Manual	10/1/2025 8:22:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-327 303	Building K K7 Training Room	Manual	10/1/2025 8:21:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-329 305	Building K K7 Training Room	Manual	10/1/2025 8:22:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-330 306	Building K K7 Training Room	Manual	10/1/2025 8:22:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-321 310	Building K K7 Training Strg Rm	Manual	10/1/2025 8:22:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-331 313	Building K K8 PE Storage	Manual	10/1/2025 5:07:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-336 314	Building K K8 PE Storage	Manual	10/1/2025 5:07:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-341 315	Building K K9 Electrical Room	Manual	10/1/2025 8:27:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-342 316	Building K Room K10	Manual	10/1/2025 8:28:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-381 336	Building K Room K10 HVAC	Manual	10/1/2025 8:43:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-345 317	Building K Room K11	Manual	10/1/2025 8:33:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-343 272	Building K Room K2A	Manual	10/1/2025 5:15:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-152 254	Building K Room K2A Hall	Manual	10/1/2025 5:15:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-344 273	Building K Room K2A Hall	Manual	10/1/2025 5:14:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-382 334	Building K Room K2A HVAC	Manual	10/1/2025 8:43:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-353 274	Building K Room K3	Manual	10/1/2025 5:08:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-351 275	Building K Room K3	Manual	10/1/2025 5:09:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-352 276	Building K Room K3	Manual	10/1/2025 5:09:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-354 277	Building K Room K3	Manual	10/1/2025 5:09:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-358 278	Building K Room K3 Hall	Manual	10/1/2025 5:10:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-357 279	Building K Room K3A Office	Manual	10/1/2025 5:10:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-356 280	Building K Room K3B Office	Manual	10/1/2025 5:10:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-355 281	Building K Room K3C Office	Manual	10/1/2025 5:10:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-340 282	Building K Room K4	Manual	10/1/2025 5:04:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-335 283	Building K Room K4	Manual	10/1/2025 5:05:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-334 284	Building K Room K4	Manual	10/1/2025 5:05:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-339 285	Building K Room K4	Manual	10/1/2025 5:05:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-338 286	Building K Room K4	Manual	10/1/2025 5:05:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-333 287	Building K Room K4	Manual	10/1/2025 5:06:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-380 335	Building K Room K4 HVAC	Manual	10/1/2025 8:43:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-332 288	Building K Room K4 Storage	Manual	10/1/2025 5:06:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-337 289	Building K Room K4B Storage	Manual	10/1/2025 8:33:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-310 290	Building K Room K5	Manual	10/1/2025 4:58:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-315 291	Building K Room K5	Manual	10/1/2025 4:58:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-311 293	Building K Room K5	Manual	10/1/2025 5:01:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-312 294	Building K Room K5	Manual	10/1/2025 5:01:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-314 292	Building K Room K5	Manual	10/1/2025 8:33:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-322 302	Building K Room K7 South Exit	Manual	10/1/2025 8:08:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-127 379	Building L Attic Bldg L RRs	Manual	10/1/2025 8:57:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-127 376	Building L Attic Classroom L1	Manual	10/1/2025 8:57:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-127 377	Building L Attic Classroom L2	Manual	10/1/2025 8:57:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-127 378	Building L Attic Classroom L3	Manual	10/1/2025 8:57:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-003 373	Building L Boys Restroom	Manual	10/1/2025 4:55:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-006 367	Building L Classroom L1	Manual	10/1/2025 4:49:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-007 368	Building L Classroom L1	Manual	10/1/2025 4:49:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-008 369	Building L Classroom L2	Manual	10/1/2025 4:50:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-009 370	Building L Classroom L2	Manual	10/1/2025 4:50:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-010 371	Building L Classroom L3	Manual	10/1/2025 4:51:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-011 372	Building L Classroom L3	Manual	10/1/2025 4:52:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-005 375	Building L Girls Restroom	Manual	10/1/2025 4:53:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	4-004 374	Building L Staff Restroom	Manual	10/1/2025 4:54:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-128 397	Building M Attic Classroom M1	Manual	10/1/2025 9:03:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-128 398	Building M Attic Classroom M2	Manual	10/1/2025 9:03:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-128 399	Building M Attic Classroom M3	Manual	10/1/2025 9:03:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-128 400	Building M Attic Classroom M4	Manual	10/1/2025 9:03:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-128 402	Building M Attic Cust Strge M6	Manual	10/1/2025 9:03:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-128 401	Building M Attic Work Rm M5	Manual	10/1/2025 9:03:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-021 387	Building M Classroom M1	Manual	10/1/2025 3:32:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-022 388	Building M Classroom M1	Manual	10/1/2025 3:33:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-018 389	Building M Classroom M2	Manual	10/1/2025 3:31:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-019 390	Building M Classroom M2	Manual	10/1/2025 3:32:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-016 391	Building M Classroom M3	Manual	10/1/2025 3:29:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-017 392	Building M Classroom M3	Manual	10/1/2025 3:30:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-014 393	Building M Classroom M4	Manual	10/1/2025 3:27:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-015 394	Building M Classroom M4	Manual	10/1/2025 3:28:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-012 396	Building M Cust Storage M6	Manual	10/1/2025 4:56:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	4-013 395	Building M Work Room M5	Manual	10/1/2025 4:56:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - Duct	2-141 012	Building A A2 Principals Office	Manual	10/1/2025 8:44:53 PM
Heat Detector - Restorable Spot	2-383 325	Building K Attic Room K3	Manual	10/1/2025 10:16:20 PM
Heat Detector - Restorable Spot	2-383 326	Building K Attic Room K3	Manual	10/1/2025 10:16:22 PM
Heat Detector - Restorable Spot	2-383 324	Building K Attic Room K3	Manual	10/1/2025 10:16:25 PM
Heat Detector - Restorable Spot	2-383 323	Building K Attic Room K3	Manual	10/1/2025 10:16:28 PM
Heat Detector - Restorable Spot	2-384 328	Building K Attic Room K3 Office	Manual	10/1/2025 10:16:37 PM
Heat Detector - Restorable Spot	2-384 327	Building K Attic Room K3 Office	Manual	10/1/2025 10:16:39 PM
Heat Detector - Restorable Spot	2-377 330	Building K Attic Room K5A	Manual	10/1/2025 10:16:43 PM
Smoke Detector - General	2-350 320	Building K K12 Kitchen Office	Manual	10/1/2025 8:25:34 PM

Failed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - Duct	2-134 066	Building C Classroom C4	Manual	10/1/2025 8:43:32 PM
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	

Ventilation and Cooking Equipment

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Cooking Equipment	Appliances		Manual	10/1/2025 2:39:44 PM
Fusible Links	Fusible Links 450 x 3		Manual	10/1/2025 2:39:37 PM
Range Hood	Hood		Manual	10/1/2025 2:39:46 PM
Range Suppression	Suppression		Manual	10/1/2025 2:39:49 PM
Range Suppression	101-20 Cartridge		Manual	10/1/2025 2:39:54 PM
Range Suppression Tank	R102 1.5 Gallon Cylinder		Manual	10/1/2025 2:39:52 PM

Device/Equipment details

Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Audible					
013	Building A South Exterior				
039	Building B East Exterior				
067	Building C East Exterior				
086	Building D D1 Library				
104	Building E North Exterior				
120	Building F North Exterior				
139	Building G North Exterior				
164	Building H North Exterior				
199	Building I North Exterior				
200	Building I East Exterior				
201	Building I West Exterior				
238	Building J North Exterior				
337	Building K East Exterior				
380	Building L North Exterior				
403	Building M North Exterior				
Audible And Visible					
014	Building A A1 Reception				
040	Building B Classroom B1				
041	Building B Classroom B2				
042	Building B Classroom B3				
043	Building B Classroom B4				
068	Building C Classroom C1				
069	Building C Classroom C2				
070	Building C Classroom C3				
071	Building C Classroom C4				
072	Building C Hallway				
073	Building C Hallway				
087	Building D D1 Library				
088	Building D D2 Library				
105	Building E Classroom E1				
106	Building E Classroom E2				
121	Building F Classroom F1				
122	Building F Classroom F2				
140	Building G Classroom G1				
141	Building G Classroom G2				
142	Building G Classroom G3				
165	Building H Classroom H1				
166	Building H Classroom H2				
167	Building H Classroom H3				
168	Building H Classroom H4				
169	Building H Classroom H5				
202	Building I Classroom I-1				
203	Building I Classroom I-2				
204	Building I Classroom I-3				
205	Building I Classroom I-4				
206	Building I Classroom I-5				
239	Building J Classroom J1				
240	Building J J2A Staff Room				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
241	Building J Classroom J3				
242	Building J Classroom J4				
243	Building J Classroom J5				
338	Building K K1 MP Room				
339	Building K K1 MP Room				
340	Building K Room K3				
341	Building K Room K4				
342	Building K Room K5				
343	Building K Room K7				
344	Building K Room K11				
345	Building K K12 Kitchen				
381	Building L Classroom L1				
382	Building L Classroom L2				
383	Building L Classroom L3				
404	Building M Classroom M1				
405	Building M Classroom M2				
406	Building M Classroom M3				
407	Building M Classroom M4				
408	Building M Work Room M5				
409	Building M Cust Storage M6				
Visible					
015	Building A A1A Office				
016	Building A A1B Office				
017	Building A A1D Office				
018	Building A A1F Staff Restroom				
019	Building A Hallway				
020	Building A A2 Principals Office				
074	Building C Boys Restroom				
075	Building C Girls Restroom				
107	Building E Classroom E1C				
108	Building E E1A Office				
109	Building E E1B Office				
207	Building I I-6 Boys Restroom				
208	Building I I-8 Girls Restroom				
209	Building I I-9 Boys Restroom				
210	Building I I-11 Girls Restroom				
244	Building J Room J2				
245	Building J Copy Rm by J2				
246	Building J J8 Mens Restroom				
247	Building J J10 Womens RR				
346	Building K K1 MP Room				
347	Building K K1 MP Room				
348	Building K K2 MP Room Stage				
349	Building K Room K2A Hall				
350	Building K Room K3 Hall				
351	Building K Room K3A Office				
352	Building K Room K3B Office				
353	Building K Room K3C Office				
354	Building K Room K4				
355	Building K K5 Boys Restroom				
356	Building K K5 Girls Restroom				
357	Building K K5 Storage Room				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
358	Building K K5A Office				
359	Building K K7 Boys Restroom				
360	Building K K7 Girls Restroom				
361	Building K K7 Office				
362	Building K K7 Training Strg Rm				
363	Building K K11 Restroom				
364	Building K K12 Kitchen				
384	Building L Boys Restroom				
385	Building L Girls Restroom				
386	Building L Staff Restroom				

Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Remote Annunciator					
001	Building A A1 Reception				
NAC Power Extender Panel					
021	Building A A1C Headend				
022	Building A A1C Headend				
076	Building C C6 Custodial Closet				
143	Building G Room G2A Telco Rm				
170	Building H Classroom H5				
250	Building J Book Strg Room J6				
365	Building K K9 Electrical Room				

Fire Alarm Panel

	Building A A1C Headend	Edwards	EST-3		
--	------------------------	---------	-------	--	--

Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Manual Pull Station					
2-138 002	Building A A1 Reception				
2-150 251	Building K K1 MP Room NW				
2-149 252	Building K K1 MP Room NE				
2-151 253	Building K K2 Stage East Exit				
2-152 254	Building K Room K2A Hall				
2-153 255	Building K K12 Kitchen				
Smoke Detector - General					
2-011 003	Building A A1 Reception				
2-006 004	Building A A1A Office				
2-004 005	Building A A1B Office				
2-002 006	Building A A1C Headend				
2-008 007	Building A Hallway				
2-007 008	Building A A1D Office				
2-009 009	Building A A2 Principals Office				
2-010 010	Building A A1F Staff Restroom				
2-044 023	Building B Classroom B1				
2-045 024	Building B Classroom B1				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-043 025	Building B Classroom B2				
2-042 026	Building B Classroom B2				
2-039 027	Building B Classroom B3				
2-040 028	Building B Classroom B3				
2-038 029	Building B Classroom B4				
2-037 030	Building B Classroom B4				
2-033 044	Building C Classroom C1				
2-035 045	Building C Classroom C1				
2-034 046	Building C Classroom C1				
2-032 047	Building C Classroom C1				
2-022 048	Building C Classroom C2				
2-021 049	Building C Classroom C2				
2-019 050	Building C Classroom C2				
2-020 051	Building C Classroom C2				
2-015 052	Building C Classroom C3				
2-016 053	Building C Classroom C3				
2-014 054	Building C Classroom C3				
2-027 055	Building C Classroom C4				
2-028 056	Building C Classroom C4				
2-030 057	Building C Classroom C4				
2-029 058	Building C Classroom C4				
2-018 059	Building C Hall by Room C3				
2-031 060	Building C Hall by Room C4				
2-024 061	Building C Boys Restroom				
2-026 062	Building C Girls Restroom				
2-023 063	Building C C6 Custodial Closet				
2-025 064	Building C Utility Closet				
2-050 077	Building D D1 Library				
2-053 078	Building D D1 Library				
2-052 079	Building D D1 Library				
2-051 080	Building D D1 Library				
2-055 081	Building D D2 Library				
2-054 082	Building D D2 Library				
2-058 083	Building D D2 Library				
2-057 084	Building D D2A Library				
2-056 085	Building D D2B Library				
2-073 089	Building E Classroom E1				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-072 090	Building E Classroom E1				
2-069 091	Building E Classroom E1				
2-068 092	Building E Classroom E1				
2-070 093	Building E Classroom E1C				
2-071 094	Building E Classroom E1C				
2-064 095	Building E E1A Office				
2-116 096	Building E E1B Office				
2-065 097	Building E E1B Office				
2-062 098	Building E Classroom E2				
2-061 099	Building E Classroom E2				
2-060 100	Building E Classroom E2				
2-063 101	Building E Classroom E2				
2-067 102	Building E Custodial Closet				
2-082 110	Building F Classroom F1				
2-081 111	Building F Classroom F1				
2-084 112	Building F Classroom F1				
2-083 113	Building F Classroom F1				
2-080 114	Building F Store Room F1A				
2-077 115	Building F Classroom F2				
2-078 116	Building F Classroom F2				
2-079 117	Building F Classroom F2				
2-076 118	Building F Classroom F2				
2-075 119	Building F Store Room F2A				
2-092 123	Building G Classroom G1				
2-093 124	Building G Classroom G1				
2-088 125	Building G Classroom G2				
2-089 126	Building G Classroom G2				
2-087 127	Building G Room G2A Telco Rm				
2-090 128	Building G Classroom G3				
2-091 129	Building G Classroom G3				
2-112 144	Building H Classroom H1				
2-115 145	Building H Classroom H1				
2-114 146	Building H Classroom H1				
2-113 147	Building H Classroom H1				
2-110 148	Building H Classroom H2				
2-109 149	Building H Classroom H2				
2-108 150	Building H Classroom H2				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-111 151	Building H Classroom H2				
2-105 152	Building H Classroom H3				
2-106 153	Building H Classroom H3				
2-107 154	Building H Classroom H3				
2-104 155	Building H Classroom H3				
2-102 156	Building H Classroom H4				
2-101 157	Building H Classroom H4				
2-100 158	Building H Classroom H4				
2-103 159	Building H Classroom H4				
2-099 160	Building H Classroom H5				
2-098 161	Building H Classroom H5				
2-096 162	Building H Classroom H5				
2-097 163	Building H Classroom H5				
2-302 171	Building I Classroom I-1				
2-301 172	Building I Classroom I-1				
2-304 173	Building I Classroom I-1				
2-303 174	Building I Classroom I-1				
2-299 175	Building I Classroom I-2				
2-298 176	Building I Classroom I-2				
2-297 177	Building I Classroom I-2				
2-300 178	Building I Classroom I-2				
2-294 179	Building I Classroom I-3				
2-293 180	Building I Classroom I-3				
2-296 181	Building I Classroom I-3				
2-295 182	Building I Classroom I-3				
2-291 183	Building I Classroom I-4				
2-290 184	Building I Classroom I-4				
2-289 185	Building I Classroom I-4				
2-292 186	Building I Classroom I-4				
2-287 187	Building I Classroom I-5				
2-286 188	Building I Classroom I-5				
2-285 189	Building I Classroom I-5				
2-288 190	Building I Classroom I-5				
2-281 191	Building I I-6 Boys Restroom				
2-282 192	Building I I-7 Custodial Closet				
2-284 193	Building I I-8 Girls Restroom				
2-308 194	Building I I-9 Boys Restroom				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-306 195	Building I I-10 Custodial Closet				
2-305 196	Building I I-11 Girls Restroom				
2-258 211	Building J Classroom J1				
2-259 212	Building J Classroom J1				
2-256 213	Building J Classroom J1				
2-257 214	Building J Classroom J1				
2-260 215	Building J Room J2 Hall				
2-263 216	Building J Room J2				
2-264 217	Building J Room J2 Office				
2-261 218	Building J J2A Staff Room				
2-262 219	Building J J2A Staff Room				
2-267 220	Building J Classroom J3				
2-268 221	Building J Classroom J3				
2-265 222	Building J Classroom J3				
2-266 223	Building J Classroom J3				
2-270 224	Building J Classroom J4				
2-271 225	Building J Classroom J4				
2-272 226	Building J Classroom J4				
2-269 227	Building J Classroom J4				
2-274 228	Building J Classroom J5				
2-275 229	Building J Classroom J5				
2-276 230	Building J Classroom J5				
2-273 231	Building J Classroom J5				
2-277 232	Building J Book Strg Room J6				
2-278 233	Building J Book Strg Room J6				
2-279 234	Building J AV Storage Rm J7				
2-255 235	Building J J8 Mens Restroom				
2-254 236	Building J J9 Custodian Office				
2-253 237	Building J J10 Womens RR				
2-367 256	Building K K1 MP Room				
2-368 257	Building K K1 MP Room				
2-369 258	Building K K1 MP Room				
2-370 259	Building K K1 MP Room				
2-371 260	Building K K1 MP Room				
2-372 261	Building K K1 MP Room				
2-361 262	Building K K1 MP Room				
2-362 263	Building K K1 MP Room				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-363 264	Building K K1 MP Room				
2-364 265	Building K K1 MP Room				
2-365 266	Building K K1 MP Room				
2-366 267	Building K K1 MP Room				
2-373 268	Building K K2 MP Room Stage				
2-374 269	Building K K2 MP Room Stage				
2-360 270	Building K K2 MP Room Stage				
2-359 271	Building K K2 MP Room Stage				
2-343 272	Building K Room K2A				
2-344 273	Building K Room K2A Hall				
3-353 274	Building K Room K3				
3-351 275	Building K Room K3				
3-352 276	Building K Room K3				
3-354 277	Building K Room K3				
2-358 278	Building K Room K3 Hall				
2-357 279	Building K Room K3A Office				
2-356 280	Building K Room K3B Office				
2-355 281	Building K Room K3C Office				
2-340 282	Building K Room K4				
2-335 283	Building K Room K4				
2-334 284	Building K Room K4				
2-339 285	Building K Room K4				
2-338 286	Building K Room K4				
2-333 287	Building K Room K4				
2-332 288	Building K Room K4 Storage				
2-337 289	Building K Room K4B Storage				
2-310 290	Building K Room K5				
2-315 291	Building K Room K5				
2-314 292	Building K Room K5				
2-311 293	Building K Room K5				
2-312 294	Building K Room K5				
2-313 295	Building K K5 Boys Restroom				
2-252 296	Building K K5 Girls Restroom				
2-319 297	Building K K5 Storage Room				
2-317 298	Building K K5A Office				
2-316 299	Building K K5A Office Closet				
2-318 300	Building K K5 South Exit				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-320 301	Building K HVAC Room K6				
2-322 302	Building K Room K7 South Exit				
2-327 303	Building K K7 Training Room				
2-326 304	Building K K7 Training Rm SE				
2-329 305	Building K K7 Training Room				
2-330 306	Building K K7 Training Room				
2-328 307	Building K K7 Training Rm NE				
2-323 308	Building K K7 Office				
2-324 309	Building K K7 Office Closet				
2-321 310	Building K K7 Training Strg Rm				
2-375 311	Building K K7 Boys Restroom				
2-325 312	Building K K7 Girls Restroom				
2-331 313	Building K K8 PE Storage				
2-336 314	Building K K8 PE Storage				
2-341 315	Building K K9 Electrical Room				
2-342 316	Building K Room K10				
2-345 317	Building K Room K11				
2-346 318	Building K K11A Restroom				
2-347 319	Building K K12D Kitchen Strg				
2-350 320	Building K K12 Kitchen Office				
4-006 367	Building L Classroom L1				
4-007 368	Building L Classroom L1				
4-008 369	Building L Classroom L2				
4-009 370	Building L Classroom L2				
4-010 371	Building L Classroom L3				
4-011 372	Building L Classroom L3				
4-003 373	Building L Boys Restroom				
4-004 374	Building L Staff Restroom				
4-005 375	Building L Girls Restroom				
4-021 387	Building M Classroom M1				
4-022 388	Building M Classroom M1				
4-018 389	Building M Classroom M2				
4-019 390	Building M Classroom M2				
4-016 391	Building M Classroom M3				
4-017 392	Building M Classroom M3				
4-014 393	Building M Classroom M4				
4-015 394	Building M Classroom M4				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
4-013 395	Building M Work Room M5				
4-012 396	Building M Cust Storage M6				
Heat Detector - Restorable Spot					
2-003 011	Building A A1C Headend				
2-133 031	Building B Attic Classroom B1				
2-133 032	Building B Attic Classroom B1				
2-132 033	Building B Attic Classroom B2				
2-132 034	Building B Attic Classroom B2				
2-131 035	Building B Attic Classroom B3				
2-131 036	Building B Attic Classroom B3				
2-130 037	Building B Attic Classroom B4				
2-130 038	Building B Attic Classroom B4				
2-017 065	Building C Classroom C3				
2-066 103	Building E Cust Wtr Htr Clst				
2-137 130	Building G Attic Classroom G1				
2-137 131	Building G Attic Classroom G1				
2-137 132	Building G Attic Classroom G1				
2-135 133	Building G Attic Classroom G2				
2-135 134	Building G Attic Classroom G2				
2-135 135	Building G Attic Classroom G2				
2-136 136	Building G Attic Classroom G3				
2-136 137	Building G Attic Classroom G3				
2-136 138	Building G Attic Classroom G3				
2-283 197	Building I I-7 RR Plumb Chase				
2-307 198	Building I I-10 RR Plumb Chase				
2-349 321	Building K K12 Kitchen				
2-348 322	Building K K12 Kitchen				
2-383 323	Building K Attic Room K3				
2-383 324	Building K Attic Room K3				
2-383 325	Building K Attic Room K3				
2-383 326	Building K Attic Room K3				
2-384 327	Building K Attic Room K3 Office				
2-384 328	Building K Attic Room K3 Office				
2-376 329	Building K Attic K5 Restroom				
2-377 330	Building K Attic Room K5A				
2-379 331	Building K Attic K7 Office				
2-378 332	Building K Attic K7 Boys RR				
2-385 333	Building K Attic K7 Girls RR				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
4-127 376	Building L Attic Classroom L1				
4-127 377	Building L Attic Classroom L2				
4-127 378	Building L Attic Classroom L3				
4-127 379	Building L Attic Bldg L RRs				
4-128 397	Building M Attic Classroom M1				
4-128 398	Building M Attic Classroom M2				
4-128 399	Building M Attic Classroom M3				
4-128 400	Building M Attic Classroom M4				
4-128 401	Building M Attic Work Rm M5				
4-128 402	Building M Attic Cust Strge M6				

Smoke Detector - Duct

2-141 012	Building A A2 Principals Office				
2-134 066	Building C Classroom C4				
2-382 334	Building K Room K2A HVAC				
2-380 335	Building K Room K4 HVAC				
2-381 336	Building K Room K10 HVAC				

Ventilation and Cooking Equipment

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Range Suppression					
101-20	Cartridge				07/28/2025
	Suppression				07/28/2025
Range Suppression Tank					
R102	1.5 Gallon Cylinder				07/28/2025
Range Hood					
	Hood				07/28/2025
Cooking Equipment					
	Appliances				07/28/2025
Fusible Links					
	Fusible Links 450 x 3				07/28/2025