

Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

LICHEN ELEMENTARY

8319 LICHEN DR
CITRUS HEIGHTS, California
United States

This site has been inspected and tested in compliance with applicable standards.

Completed
Tuesday, September 30, 2025

Test Session: 16 Sep 2025 14:49 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD
5320 HEMLOCK ST
SACRAMENTO, California
United States

TESTED BY

Riley Goyet
Western States Fire Protection-
Sacramento
188 Cirby Way
Roseville, CA 95678
United States



Inspection Summary

Building Information

PROPERTY	LICHEN ELEMENTARY	CONTACT
ADDRESS	8319 LICHEN DR	PHONE
CITY/STATE	CITRUS HEIGHTS, California	MOBILE
COUNTRY	United States	EMAIL

Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us

Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Alarm Notification Appliance	78	78(100%)	78(100%)	0(0%)
Fire Control Panel	8	8(100%)	8(100%)	0(0%)
Initiating Device	179	179(100%)	179(100%)	0(0%)

Certification

The equipment specified here in was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Tuesday, September 30, 2025

ACCEPTED BY 09/30/2025

Building Representative

TESTED BY 09/30/2025



Riley Goyet
Technician

System Details

Control Units

ADDRESS/ SCAN ADDRESS		DESCRIPTION	Building A A4B Copy Rm - FACP
MANUFACTURER	EST	S/W VERSION	
MODEL	3	LAST UPDATE	
SERIAL NUMBER		S/W LOCATION	
INSTALL DATE			

Open Corrective Action & Solution Summary

The following 1 corrective action(s) remain open following the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
NAC Power Extender Panel	062	Building A A4B Copy Rm - P.E. "F"
	Created By:	Riley Goyet
	Creation Date:	09/16/2025
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	

Testing Details

Alarm Notification Appliance

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible	052	Building A A1A1 Office Restroom	Manual	9/16/2025 2:57:19 PM
		Visual inspection	Passed (Manual)	
Visible	053	Building A A1B Staff Kitchen	Manual	9/16/2025 2:57:18 PM
		Visual inspection	Passed (Manual)	
Visible	054	Building A A1C Principal Office	Manual	9/16/2025 2:57:13 PM
		Visual inspection	Passed (Manual)	
Visible	056	Building A A2 Admin Office	Manual	9/16/2025 2:57:09 PM
		Visual inspection	Passed (Manual)	
Visible	055	Building A A2 Staff Restroom	Manual	9/16/2025 2:57:11 PM
		Visual inspection	Passed (Manual)	
Visible	057	Building A A3 Staff Restroom	Manual	9/16/2025 2:57:08 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	045	Building A A4 MP Room	Manual	9/16/2025 2:56:15 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	044	Building A A4 MP Room	Manual	9/16/2025 2:56:17 PM
		Visual inspection	Passed (Manual)	
Visible	058	Building A A4 MP Room Hallway	Manual	9/16/2025 2:57:07 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	046	Building A A4 MP Room North	Manual	9/16/2025 2:56:14 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	047	Building A A4B Copy Rm/FACP	Manual	9/16/2025 2:56:12 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	048	Building A A5 Stage	Manual	9/16/2025 2:56:11 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	049	Building A A6 Kitchen	Manual	9/16/2025 2:56:08 PM
		Visual inspection	Passed (Manual)	
Visible	059	Building A A6A Staff Office	Manual	9/16/2025 2:57:05 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	050	Building A A7 Staff Lounge	Manual	9/16/2025 2:56:06 PM
		Visual inspection	Passed (Manual)	
Visible	060	Building A A7A Staff Office	Manual	9/16/2025 2:57:03 PM
		Visual inspection	Passed (Manual)	
Visible	051	Building A Admin Office A1	Manual	9/16/2025 2:57:21 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	043	Building A East Exterior	Manual	9/16/2025 2:56:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	042	Building A North Exterior	Manual	9/16/2025 2:56:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	071	Building B East Exterior	Manual	9/16/2025 2:56:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	072	Building B Room B1	Manual	9/16/2025 2:56:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	074	Building B Room B1B Restroom	Manual	9/16/2025 2:57:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	073	Building B Room B2	Manual	9/16/2025 2:56:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	075	Building B Room B2 Restroom	Manual	9/16/2025 2:57:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	102	Building C C10 Boys Restroom	Manual	9/16/2025 2:56:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	101	Building C C7 Girls Restroom	Manual	9/16/2025 2:56:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	094	Building C East Exterior	Manual	9/16/2025 2:56:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	095	Building C Room C1	Manual	9/16/2025 2:56:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	096	Building C Room C2	Manual	9/16/2025 2:56:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	097	Building C Room C3	Manual	9/16/2025 2:54:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	098	Building C Room C4	Manual	9/16/2025 2:54:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	099	Building C Room C5	Manual	9/16/2025 2:54:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	100	Building C Room C6	Manual	9/16/2025 2:54:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	093	Building C West Exterior	Manual	9/16/2025 2:56:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	152	Building D D12 Girls Restroom	Manual	9/16/2025 2:56:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible	151	Building D D9 Boys Restroom	Manual	9/16/2025 2:56:52 PM
		Visual inspection	Passed (Manual)	
Audible	138	Building D East Exterior	Manual	9/16/2025 2:56:36 PM
		Visual inspection	Passed (Manual)	
Audible	137	Building D East Exterior	Manual	9/16/2025 2:56:38 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	141	Building D Room D1	Manual	9/16/2025 2:54:34 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	142	Building D Room D2	Manual	9/16/2025 2:54:32 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	143	Building D Room D3	Manual	9/16/2025 2:54:30 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	144	Building D Room D4	Manual	9/16/2025 2:54:29 PM
		Visual inspection	Passed (Manual)	
Visible	149	Building D Room D4B Restroom	Manual	9/16/2025 2:56:55 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	145	Building D Room D5	Manual	9/16/2025 2:54:27 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	146	Building D Room D6	Manual	9/16/2025 2:54:26 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	147	Building D Room D7	Manual	9/16/2025 2:54:24 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	148	Building D Room D8	Manual	9/16/2025 2:54:23 PM
		Visual inspection	Passed (Manual)	
Visible	150	Building D Room D8A Restroom	Manual	9/16/2025 2:56:54 PM
		Visual inspection	Passed (Manual)	
Audible	140	Building D West Exterior	Manual	9/16/2025 2:56:34 PM
		Visual inspection	Passed (Manual)	
Audible	139	Building D West Exterior	Manual	9/16/2025 2:56:35 PM
		Visual inspection	Passed (Manual)	
Visible	182	Building E E10 Boys Restroom	Manual	9/16/2025 2:56:48 PM
		Visual inspection	Passed (Manual)	
Visible	183	Building E E11 Staff Restroom	Manual	9/16/2025 2:56:47 PM
		Visual inspection	Passed (Manual)	
Visible	181	Building E E7 Girls Restroom	Manual	9/16/2025 2:56:50 PM
		Visual inspection	Passed (Manual)	
Audible	173	Building E North Exterior	Manual	9/16/2025 2:56:32 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	175	Building E Room E1	Manual	9/16/2025 2:54:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	176	Building E Room E2	Manual	9/16/2025 2:54:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	177	Building E Room E3	Manual	9/16/2025 2:54:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	178	Building E Room E4	Manual	9/16/2025 2:54:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	179	Building E Room E5	Manual	9/16/2025 2:54:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	180	Building E Room E6	Manual	9/16/2025 2:54:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	174	Building E South Exterior	Manual	9/16/2025 2:56:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	198	Building F Room F1	Manual	9/16/2025 2:54:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	199	Building F Room F2	Manual	9/16/2025 2:54:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	197	Building F South Exterior	Manual	9/16/2025 2:56:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	214	Building G G1 Media Center	Manual	9/16/2025 2:54:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	215	Building G G2 Media Center	Manual	9/16/2025 2:54:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	213	Building G South Exterior	Manual	9/16/2025 2:56:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	238	Building H East Exterior	Manual	9/16/2025 2:56:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	240	Building H Room H1	Manual	9/16/2025 2:54:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	241	Building H Room H2	Manual	9/16/2025 2:54:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	242	Building H Room H3	Manual	9/16/2025 2:54:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	243	Building H Room H4	Manual	9/16/2025 2:54:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible	239	Building H West Exterior	Manual	9/16/2025 2:56:20 PM
		Visual inspection	Passed (Manual)	
Audible	247	Building I East Exterior	Manual	9/16/2025 2:56:21 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	248	Building I Room I-1	Manual	9/16/2025 2:54:00 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	264	Building J Room J1	Manual	9/16/2025 2:53:58 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	265	Building J Room J2	Manual	9/16/2025 2:53:57 PM
		Visual inspection	Passed (Manual)	
Audible	263	Building J South Exterior	Manual	9/16/2025 2:56:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Fire Alarm Panel		Building A A4B Copy Rm - FACP	Manual	9/16/2025 4:22:48 PM
		Manufacturer	EST	
		Model	3	
		Visual inspection	Passed (Manual)	
NAC Power Extender Panel	062	Building A A4B Copy Rm - P.E. "F"	Manual	9/16/2025 4:05:32 PM
		Visual inspection	Passed (Manual)	
NAC Power Extender Panel	061	Building A A4B Copy Rm - P.E. "Master"	Manual	9/16/2025 4:22:57 PM
		Visual inspection	Passed (Manual)	
Remote Annunciator	001	Building A Admin Office A1	Manual	9/16/2025 4:22:34 PM
		Visual inspection	Passed (Manual)	
NAC Power Extender Panel	153	Building D D10 Telecom Room - P.E. "E"	Manual	9/16/2025 4:23:18 PM
		Visual inspection	Passed (Manual)	
NAC Power Extender Panel	184	Building E E8 Storage - P.E. "G"	Manual	9/16/2025 4:23:23 PM
		Visual inspection	Passed (Manual)	
NAC Power Extender Panel	216	Building G G2 Media Center Closet - P.E. "C"	Manual	9/16/2025 4:23:20 PM
		Visual inspection	Passed (Manual)	
NAC Power Extender Panel	244	Building H Room H2 Closet - P.E. "B"	Manual	9/16/2025 4:23:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-006 007	Building A A1A Hallway	Manual	9/16/2025 4:28:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-005 008	Building A A1A1 Office Restroom	Manual	9/16/2025 4:28:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-007 009	Building A A1B Staff Kitchen	Manual	9/16/2025 4:28:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-009 010	Building A A1C Principal Office	Manual	9/16/2025 4:29:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-004 012	Building A A2 Admin Office	Manual	9/16/2025 4:31:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-003 011	Building A A2 Staff Restroom	Manual	9/16/2025 4:33:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-002 013	Building A A3 Staff Restroom	Manual	9/16/2025 4:33:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-017 015	Building A A4 MP Room	Manual	9/16/2025 4:09:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-020 016	Building A A4 MP Room	Manual	9/16/2025 4:09:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-023 017	Building A A4 MP Room	Manual	9/16/2025 4:09:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-026 018	Building A A4 MP Room	Manual	9/16/2025 4:09:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-029 019	Building A A4 MP Room	Manual	9/16/2025 4:10:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-018 024	Building A A4 MP Room	Manual	9/16/2025 4:10:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-027 021	Building A A4 MP Room	Manual	9/16/2025 4:10:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-030 020	Building A A4 MP Room	Manual	9/16/2025 4:11:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-031 029	Building A A4 MP Room	Manual	9/16/2025 4:11:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-028 028	Building A A4 MP Room	Manual	9/16/2025 4:12:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-025 027	Building A A4 MP Room	Manual	9/16/2025 4:13:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-022 026	Building A A4 MP Room	Manual	9/16/2025 4:13:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-019 025	Building A A4 MP Room	Manual	9/16/2025 4:13:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-021 023	Building A A4 MP Room	Manual	9/16/2025 4:14:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-024 022	Building A A4 MP Room	Manual	9/16/2025 4:14:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-016 014	Building A A4 MP Room Hallway	Manual	9/16/2025 4:17:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-015 038	Building A A4A Kitchen	Manual	9/16/2025 5:49:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-001 030	Building A A4B Copy Rm/FACP	Manual	9/16/2025 4:22:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-033 031	Building A A5 Stage	Manual	9/16/2025 4:16:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-034 032	Building A A5 Stage	Manual	9/16/2025 4:16:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-032 033	Building A A5 Stage Closet	Manual	9/16/2025 4:17:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-014 039	Building A A6 Kitchen	Manual	9/16/2025 5:49:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-013 034	Building A A6A Staff Office	Manual	9/16/2025 4:30:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-010 036	Building A A7 Staff Closet	Manual	9/16/2025 4:29:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-011 035	Building A A7 Staff Lounge	Manual	9/16/2025 4:29:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-012 037	Building A A7A Staff Office	Manual	9/16/2025 4:33:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Manual Pull Station	2-126 002	Building A Admin Office A1	Manual	9/16/2025 4:24:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-008 006	Building A Admin Office A1	Manual	9/16/2025 4:50:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-127 041	Building A Attic Admin Office	Manual	9/16/2025 5:40:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-127 040	Building A Attic Admin Office	Manual	9/16/2025 5:40:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-385 005	Building A MP Room North	Manual	9/16/2025 4:22:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-384 003	Building A MP Room SE	Manual	9/16/2025 4:22:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-386 004	Building A MP Room SW	Manual	9/16/2025 4:22:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-040 063	Building B Room B1	Manual	9/16/2025 3:00:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-039 064	Building B Room B1	Manual	9/16/2025 3:00:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-044 065	Building B Room B1 Closet	Manual	9/16/2025 4:15:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-041 066	Building B Room B1B Restroom	Manual	9/16/2025 3:01:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-038 067	Building B Room B2	Manual	9/16/2025 3:02:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-037 068	Building B Room B2	Manual	9/16/2025 3:02:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-043 069	Building B Room B2 Closet	Manual	9/16/2025 3:54:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-036 070	Building B Room B2 Restroom	Manual	9/16/2025 3:54:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-060 091	Building C C10 Boys Restroom	Manual	9/16/2025 3:54:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-061 092	Building C C11 Storage Closet	Manual	9/16/2025 4:50:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-057 088	Building C C7 Girls Restroom	Manual	9/16/2025 3:54:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-058 089	Building C C8 Storage	Manual	9/16/2025 3:54:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-059 090	Building C C9 Custodian Office	Manual	9/16/2025 3:54:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-045 076	Building C Room C1	Manual	9/16/2025 3:04:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-046 077	Building C Room C1	Manual	9/16/2025 3:04:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-047 078	Building C Room C2	Manual	9/16/2025 3:05:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-048 079	Building C Room C2	Manual	9/16/2025 3:54:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-049 080	Building C Room C3	Manual	9/16/2025 3:06:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-050 081	Building C Room C3	Manual	9/16/2025 3:06:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-055 082	Building C Room C4	Manual	9/16/2025 3:29:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-056 083	Building C Room C4	Manual	9/16/2025 3:30:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-053 084	Building C Room C5	Manual	9/16/2025 3:28:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-054 085	Building C Room C5	Manual	9/16/2025 3:29:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-051 086	Building C Room C6	Manual	9/16/2025 3:27:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-052 087	Building C Room C6	Manual	9/16/2025 3:28:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-136 136	Building D Attic D12 Girls RR	Manual	9/16/2025 5:24:45 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-137 134	Building D Attic D9 Boys RR	Manual	9/16/2025 5:24:49 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-128 126	Building D Attic Room D1	Manual	9/16/2025 5:00:07 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-129 127	Building D Attic Room D2	Manual	9/16/2025 4:58:10 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-130 128	Building D Attic Room D3	Manual	9/16/2025 5:04:01 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-131 129	Building D Attic Room D4	Manual	9/16/2025 5:08:16 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-135 130	Building D Attic Room D5	Manual	9/16/2025 5:24:42 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-134 131	Building D Attic Room D6	Manual	9/16/2025 5:20:52 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-133 132	Building D Attic Room D7	Manual	9/16/2025 5:17:30 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-132 133	Building D Attic Room D8	Manual	9/16/2025 5:11:07 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-066 123	Building D D10 Telecom Room	Manual	9/16/2025 3:24:33 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-065 124	Building D D11 Custodian Closet	Manual	9/16/2025 3:07:35 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-068 125	Building D D12 Girls Restroom	Manual	9/16/2025 3:26:02 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-067 122	Building D D9 Boys Restroom	Manual	9/16/2025 3:23:03 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-070 104	Building D Room D1	Manual	9/16/2025 3:08:20 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-069 103	Building D Room D1	Manual	9/16/2025 3:09:35 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-071 105	Building D Room D2	Manual	9/16/2025 3:12:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-072 106	Building D Room D2	Manual	9/16/2025 3:13:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-074 108	Building D Room D3	Manual	9/16/2025 3:14:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-073 107	Building D Room D3	Manual	9/16/2025 3:14:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-075 109	Building D Room D4	Manual	9/16/2025 3:15:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-076 110	Building D Room D4	Manual	9/16/2025 3:16:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-079 111	Building D Room D4A	Manual	9/16/2025 3:16:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-077 112	Building D Room D4B Restroom	Manual	9/16/2025 3:15:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-086 114	Building D Room D5	Manual	9/16/2025 3:21:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-087 113	Building D Room D5	Manual	9/16/2025 3:21:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-085 115	Building D Room D6	Manual	9/16/2025 3:20:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-084 116	Building D Room D6	Manual	9/16/2025 3:20:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-082 118	Building D Room D7	Manual	9/16/2025 3:19:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-083 117	Building D Room D7	Manual	9/16/2025 3:19:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-080 120	Building D Room D8	Manual	9/16/2025 3:17:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-081 119	Building D Room D8	Manual	9/16/2025 3:18:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-078 121	Building D Room D8A Restroom	Manual	9/16/2025 3:17:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-095 171	Building E E10 Boys Restroom	Manual	9/16/2025 3:38:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-096 172	Building E E11 Staff Restroom	Manual	9/16/2025 3:39:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-091 166	Building E E7 Girls Restroom	Manual	9/16/2025 3:34:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-090 167	Building E E8 Storage	Manual	9/16/2025 3:35:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-093 168	Building E E9 Storage	Manual	9/16/2025 3:37:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-094 169	Building E E9A Storage	Manual	9/16/2025 3:36:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-092 170	Building E E9B Storage	Manual	9/16/2025 3:37:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-103 154	Building E Room E1	Manual	9/16/2025 3:30:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-102 155	Building E Room E1	Manual	9/16/2025 3:31:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-100 156	Building E Room E2	Manual	9/16/2025 3:31:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-099 157	Building E Room E2	Manual	9/16/2025 3:32:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-098 158	Building E Room E3	Manual	9/16/2025 3:33:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-097 159	Building E Room E3	Manual	9/16/2025 3:33:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-109 161	Building E Room E4	Manual	9/16/2025 3:43:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-108 160	Building E Room E4	Manual	9/16/2025 3:43:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-107 163	Building E Room E5	Manual	9/16/2025 3:41:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-106 162	Building E Room E5	Manual	9/16/2025 3:42:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-105 165	Building E Room E6	Manual	9/16/2025 3:40:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-104 164	Building E Room E6	Manual	9/16/2025 3:41:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-147 192	Building F Attic Room F1	Manual	9/16/2025 5:32:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-147 191	Building F Attic Room F1	Manual	9/16/2025 5:32:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-147 193	Building F Attic Room F1	Manual	9/16/2025 5:32:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-148 195	Building F Attic Room F2	Manual	9/16/2025 5:36:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-148 196	Building F Attic Room F2	Manual	9/16/2025 5:36:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-148 194	Building F Attic Room F2	Manual	9/16/2025 5:36:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-387 185	Building F Room F1	Manual	9/16/2025 4:42:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-120 187	Building F Room F1	Manual	9/16/2025 3:47:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-121 188	Building F Room F1	Manual	9/16/2025 3:47:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-388 186	Building F Room F2	Manual	9/16/2025 4:42:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-122 189	Building F Room F2	Manual	9/16/2025 3:48:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-123 190	Building F Room F2	Manual	9/16/2025 3:48:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-146 208	Building G Attic G1 Media Center	Manual	9/16/2025 4:43:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-146 207	Building G Attic G1 Media Center	Manual	9/16/2025 4:43:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-146 209	Building G Attic G1 Media Center	Manual	9/16/2025 4:43:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-145 212	Building G Attic G2 Media Center	Manual	9/16/2025 4:43:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-145 210	Building G Attic G2 Media Center	Manual	9/16/2025 4:43:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-145 211	Building G Attic G2 Media Center	Manual	9/16/2025 4:43:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-390 200	Building G G1 Media Center	Manual	9/16/2025 4:42:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-117 202	Building G G1 Media Center	Manual	9/16/2025 3:44:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-116 203	Building G G1 Media Center	Manual	9/16/2025 3:44:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-389 201	Building G G2 Media Center	Manual	9/16/2025 4:42:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-119 205	Building G G2 Media Center	Manual	9/16/2025 3:45:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-118 204	Building G G2 Media Center	Manual	9/16/2025 3:45:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-251 206	Building G G2 Media Center Clst	Manual	9/16/2025 3:46:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-143 227	Building H Attic Room H1	Manual	9/16/2025 4:43:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-143 228	Building H Attic Room H1	Manual	9/16/2025 4:43:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-143 226	Building H Attic Room H1	Manual	9/16/2025 4:45:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-141 229	Building H Attic Room H2	Manual	9/16/2025 4:43:21 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-141 230	Building H Attic Room H2	Manual	9/16/2025 4:43:23 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-141 231	Building H Attic Room H2	Manual	9/16/2025 4:43:25 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-144 232	Building H Attic Room H3	Manual	9/16/2025 4:43:30 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-144 233	Building H Attic Room H3	Manual	9/16/2025 4:43:32 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-144 234	Building H Attic Room H3	Manual	9/16/2025 4:43:34 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-142 236	Building H Attic Room H4	Manual	9/16/2025 4:43:26 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-142 235	Building H Attic Room H4	Manual	9/16/2025 4:43:28 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-142 237	Building H Attic Room H4	Manual	9/16/2025 4:43:29 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Manual Pull Station	2-394 217	Building H Room H1	Manual	9/16/2025 4:42:46 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-114 221	Building H Room H1	Manual	9/16/2025 4:09:47 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Manual Pull Station	2-393 218	Building H Room H2	Manual	9/16/2025 4:42:47 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-112 222	Building H Room H2	Manual	9/16/2025 4:09:48 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-252 223	Building H Room H2 Closet	Manual	9/16/2025 4:09:43 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Manual Pull Station	2-392 219	Building H Room H3	Manual	9/16/2025 4:42:50 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-115 224	Building H Room H3	Manual	9/16/2025 4:06:07 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Manual Pull Station	2-391 220	Building H Room H4	Manual	9/16/2025 4:42:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-113 225	Building H Room H4	Manual	9/16/2025 4:06:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-035 246	Building I Room I-1	Manual	9/16/2025 5:40:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-042 245	Building I Room I-1	Manual	9/16/2025 5:45:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-140 259	Building J Attic Room J1	Manual	9/16/2025 5:40:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-140 257	Building J Attic Room J1	Manual	9/16/2025 5:42:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-140 258	Building J Attic Room J1	Manual	9/16/2025 5:42:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-152 261	Building J Attic Room J2	Manual	9/16/2025 5:40:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-152 260	Building J Attic Room J2	Manual	9/16/2025 5:40:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-152 262	Building J Attic Room J2	Manual	9/16/2025 5:40:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-088 249	Building J Room J1	Manual	9/16/2025 4:03:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-089 250	Building J Room J1	Manual	9/16/2025 4:03:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-063 252	Building J Room J1	Manual	9/16/2025 4:04:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-062 251	Building J Room J1	Manual	9/16/2025 4:04:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-124 253	Building J Room J2	Manual	9/16/2025 4:01:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-125 254	Building J Room J2	Manual	9/16/2025 4:01:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-111 255	Building J Room J2	Manual	9/16/2025 4:02:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-110 256	Building J Room J2	Manual	9/16/2025 4:02:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Device/Equipment details

Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Audible					
042	Building A North Exterior				
043	Building A East Exterior				
071	Building B East Exterior				
093	Building C West Exterior				
094	Building C East Exterior				
137	Building D East Exterior				
138	Building D East Exterior				
139	Building D West Exterior				
140	Building D West Exterior				
173	Building E North Exterior				
174	Building E South Exterior				
197	Building F South Exterior				
213	Building G South Exterior				
238	Building H East Exterior				
239	Building H West Exterior				
247	Building I East Exterior				
263	Building J South Exterior				
Audible And Visible					
044	Building A A4 MP Room				
045	Building A A4 MP Room				
046	Building A A4 MP Room North				
047	Building A A4B Copy Rm/FACP				
048	Building A A5 Stage				
049	Building A A6 Kitchen				
050	Building A A7 Staff Lounge				
072	Building B Room B1				
073	Building B Room B2				
095	Building C Room C1				
096	Building C Room C2				
097	Building C Room C3				
098	Building C Room C4				
099	Building C Room C5				
100	Building C Room C6				
141	Building D Room D1				
142	Building D Room D2				
143	Building D Room D3				
144	Building D Room D4				
145	Building D Room D5				
146	Building D Room D6				
147	Building D Room D7				
148	Building D Room D8				
175	Building E Room E1				
176	Building E Room E2				
177	Building E Room E3				
178	Building E Room E4				
179	Building E Room E5				
180	Building E Room E6				
198	Building F Room F1				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
199	Building F Room F2				
214	Building G G1 Media Center				
215	Building G G2 Media Center				
240	Building H Room H1				
241	Building H Room H2				
242	Building H Room H3				
243	Building H Room H4				
248	Building I Room I-1				
264	Building J Room J1				
265	Building J Room J2				

Visible

051	Building A Admin Office A1				
052	Building A A1A1 Office Restroom				
053	Building A A1B Staff Kitchen				
054	Building A A1C Principal Office				
055	Building A A2 Staff Restroom				
056	Building A A2 Admin Office				
057	Building A A3 Staff Restroom				
058	Building A A4 MP Room Hallway				
059	Building A A6A Staff Office				
060	Building A A7A Staff Office				
074	Building B Room B1B Restroom				
075	Building B Room B2 Restroom				
101	Building C C7 Girls Restroom				
102	Building C C10 Boys Restroom				
149	Building D Room D4B Restroom				
150	Building D Room D8A Restroom				
151	Building D D9 Boys Restroom				
152	Building D D12 Girls Restroom				
181	Building E E7 Girls Restroom				
182	Building E E10 Boys Restroom				
183	Building E E11 Staff Restroom				

Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
---------	-------------	--------------	-------	--------	--------------

Remote Annunciator

001	Building A Admin Office A1				
-----	----------------------------	--	--	--	--

NAC Power Extender Panel

061	Building A A4B Copy Rm - P.E. "Master"				
062	Building AA4B Copy Rm - P.E. "F"				
153	Building D D10 Telecom Room - P.E. "E"				
184	Building E E8 Storage - P.E. "G"				
216	Building G G2 Media Center Closet - P.E. "C"				
244	Building H Room H2 Closet - P.E. "B"				

Fire Alarm Panel

	Building A A4B Copy Rm - FACP EST		3		
--	-----------------------------------	--	---	--	--

Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
---------	-------------	--------------	-------	--------	--------------

Manual Pull Station

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-126 002	Building A Admin Office A1				
2-384 003	Building A MP Room SE				
2-386 004	Building A MP Room SW				
2-385 005	Building A MP Room North				
2-387 185	Building F Room F1				
2-388 186	Building F Room F2				
2-390 200	Building G G1 Media Center				
2-389 201	Building G G2 Media Center				
2-394 217	Building H Room H1				
2-393 218	Building H Room H2				
2-392 219	Building H Room H3				
2-391 220	Building H Room H4				
Smoke Detector - General					
2-008 006	Building A Admin Office A1				
2-006 007	Building A A1A Hallway				
2-005 008	Building A A1A1 Office Restroom				
2-007 009	Building A A1B Staff Kitchen				
2-009 010	Building A A1C Principal Office				
2-003 011	Building A A2 Staff Restroom				
2-004 012	Building A A2 Admin Office				
2-002 013	Building A A3 Staff Restroom				
2-016 014	Building A A4 MP Room Hallway				
2-017 015	Building A A4 MP Room				
2-020 016	Building A A4 MP Room				
2-023 017	Building A A4 MP Room				
2-026 018	Building A A4 MP Room				
2-029 019	Building A A4 MP Room				
2-030 020	Building A A4 MP Room				
2-027 021	Building A A4 MP Room				
2-024 022	Building A A4 MP Room				
2-021 023	Building A A4 MP Room				
2-018 024	Building A A4 MP Room				
2-019 025	Building A A4 MP Room				
2-022 026	Building A A4 MP Room				
2-025 027	Building A A4 MP Room				
2-028 028	Building A A4 MP Room				
2-031 029	Building A A4 MP Room				
2-001 030	Building A A4B Copy Rm/FACP				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-033 031	Building A A5 Stage				
2-034 032	Building A A5 Stage				
2-032 033	Building A A5 Stage Closet				
2-013 034	Building A A6A Staff Office				
2-011 035	Building A A7 Staff Lounge				
2-010 036	Building A A7 Staff Closet				
2-012 037	Building A A7A Staff Office				
2-040 063	Building B Room B1				
2-039 064	Building B Room B1				
2-044 065	Building B Room B1 Closet				
2-041 066	Building B Room B1B Restroom				
2-038 067	Building B Room B2				
2-037 068	Building B Room B2				
2-043 069	Building B Room B2 Closet				
2-036 070	Building B Room B2 Restroom				
2-045 076	Building C Room C1				
2-046 077	Building C Room C1				
2-047 078	Building C Room C2				
2-048 079	Building C Room C2				
2-049 080	Building C Room C3				
2-050 081	Building C Room C3				
2-055 082	Building C Room C4				
2-056 083	Building C Room C4				
2-053 084	Building C Room C5				
2-054 085	Building C Room C5				
2-051 086	Building C Room C6				
2-052 087	Building C Room C6				
2-057 088	Building C C7 Girls Restroom				
2-058 089	Building C C8 Storage				
2-059 090	Building C C9 Custodian Office				
2-060 091	Building C C10 Boys Restroom				
2-069 103	Building D Room D1				
2-070 104	Building D Room D1				
2-071 105	Building D Room D2				
2-072 106	Building D Room D2				
2-073 107	Building D Room D3				
2-074 108	Building D Room D3				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-075 109	Building D Room D4				
2-076 110	Building D Room D4				
2-079 111	Building D Room D4A				
2-077 112	Building D Room D4B Restroom				
2-087 113	Building D Room D5				
2-086 114	Building D Room D5				
2-085 115	Building D Room D6				
2-084 116	Building D Room D6				
2-083 117	Building D Room D7				
2-082 118	Building D Room D7				
2-081 119	Building D Room D8				
2-080 120	Building D Room D8				
2-078 121	Building D Room D8A Restroom				
2-067 122	Building D D9 Boys Restroom				
2-066 123	Building D D10 Telecom Room				
2-065 124	Building D D11 Custodian Closet				
2-068 125	Building D D12 Girls Restroom				
2-103 154	Building E Room E1				
2-102 155	Building E Room E1				
2-100 156	Building E Room E2				
2-099 157	Building E Room E2				
2-098 158	Building E Room E3				
2-097 159	Building E Room E3				
2-108 160	Building E Room E4				
2-109 161	Building E Room E4				
2-106 162	Building E Room E5				
2-107 163	Building E Room E5				
2-104 164	Building E Room E6				
2-105 165	Building E Room E6				
2-091 166	Building E E7 Girls Restroom				
2-090 167	Building E E8 Storage				
2-093 168	Building E E9 Storage				
2-094 169	Building E E9A Storage				
2-092 170	Building E E9B Storage				
2-095 171	Building E E10 Boys Restroom				
2-096 172	Building E E11 Staff Restroom				
2-120 187	Building F Room F1				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-121 188	Building F Room F1				
2-122 189	Building F Room F2				
2-123 190	Building F Room F2				
2-117 202	Building G G1 Media Center				
2-116 203	Building G G1 Media Center				
2-118 204	Building G G2 Media Center				
2-119 205	Building G G2 Media Center				
2-251 206	Building G G2 Media Center Clst				
2-114 221	Building H Room H1				
2-112 222	Building H Room H2				
2-252 223	Building H Room H2 Closet				
2-115 224	Building H Room H3				
2-113 225	Building H Room H4				
2-088 249	Building J Room J1				
2-089 250	Building J Room J1				
2-062 251	Building J Room J1				
2-063 252	Building J Room J1				
2-124 253	Building J Room J2				
2-125 254	Building J Room J2				
2-111 255	Building J Room J2				
2-110 256	Building J Room J2				
Heat Detector - Restorable Spot					
2-015 038	Building A A4A Kitchen				
2-014 039	Building A A6 Kitchen				
2-127 040	Building A Attic Admin Office				
2-127 041	Building A Attic Admin Office				
2-061 092	Building C C11 Storage Closet				
2-128 126	Building D Attic Room D1				
2-129 127	Building D Attic Room D2				
2-130 128	Building D Attic Room D3				
2-131 129	Building D Attic Room D4				
2-135 130	Building D Attic Room D5				
2-134 131	Building D Attic Room D6				
2-133 132	Building D Attic Room D7				
2-132 133	Building D Attic Room D8				
2-137 134	Building D Attic D9 Boys RR				
2-136 136	Building D Attic D12 Girls RR				
2-147 191	Building F Attic Room F1				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-147 192	Building F Attic Room F1				
2-147 193	Building F Attic Room F1				
2-148 194	Building F Attic Room F2				
2-148 195	Building F Attic Room F2				
2-148 196	Building F Attic Room F2				
2-146 207	Building G Attic G1 Media Center				
2-146 208	Building G Attic G1 Media Center				
2-146 209	Building G Attic G1 Media Center				
2-145 210	Building G Attic G2 Media Center				
2-145 211	Building G Attic G2 Media Center				
2-145 212	Building G Attic G2 Media Center				
2-143 226	Building H Attic Room H1				
2-143 227	Building H Attic Room H1				
2-143 228	Building H Attic Room H1				
2-141 229	Building H Attic Room H2				
2-141 230	Building H Attic Room H2				
2-141 231	Building H Attic Room H2				
2-144 232	Building H Attic Room H3				
2-144 233	Building H Attic Room H3				
2-144 234	Building H Attic Room H3				
2-142 235	Building H Attic Room H4				
2-142 236	Building H Attic Room H4				
2-142 237	Building H Attic Room H4				
2-042 245	Building I Room I-1				
2-035 246	Building I Room I-1				
2-140 257	Building J Attic Room J1				
2-140 258	Building J Attic Room J1				
2-140 259	Building J Attic Room J1				
2-152 260	Building J Attic Room J2				
2-152 261	Building J Attic Room J2				
2-152 262	Building J Attic Room J2				