

Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

THOMAS KELLY ELEMENTARY

6301 MORGARA DR
CARMICHAEL, California
United States

This site has been inspected and tested in compliance with applicable standards.

Completed

Thursday, October 09, 2025

Test Session:02 Oct 2025 14:45 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD
5320 HEMLOCK ST
SACRAMENTO, California
United States

TESTED BY

Riley Goyet
Western States Fire Protection-
Sacramento
188 Cirby Way
Roseville, CA 95678
United States



Inspection Summary

Building Information

PROPERTY	THOMAS KELLY ELEMENTARY	CONTACT
ADDRESS	6301 MORGARA DR	PHONE
CITY/STATE	CARMICHAEL, California	MOBILE
COUNTRY	United States	EMAIL

Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us

Testing Summary


EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Alarm Notification Appliance	71	71(100%)	71(100%)	0(0%)
Fire Control Panel	7	7(100%)	4(57%)	3(43%)
Initiating Device	194	192(99%)	192(99%)	0(0%)

Certification

The equipment specified here in was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Thursday, October 09, 2025

ACCEPTED BY 10/09/2025

Building Representative


TESTED BY 10/09/2025
Riley Goyet
Technician

System Details

Control Units

ADDRESS/ SCAN ADDRESS	DESCRIPTION	Building A Strge Rm W by Rm 3
MANUFACTURER	S/W VERSION	
MODEL	LAST UPDATE	
SERIAL NUMBER	S/W LOCATION	
INSTALL DATE	03/17/2019	

Open Corrective Action & Solution Summary

The following 4 corrective action(s) remain open following the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
Fire Alarm Panel		Building A Strge Rm W by Rm 3
	Created By:	Riley Goyet
	Creation Date:	12/01/2022
	Corrective Action:	Replace (2) 12V 55AH Batteries.
	Proposed Solution:	
	Manufacturer:	
	Model:	
	Created By:	Riley Goyet
	Creation Date:	11/21/2024
	Corrective Action:	
	Proposed Solution:	
	Manufacturer:	
	Model:	
NAC Power Extender Panel	137	Building A Strge Rm W by Rm 3 P/E B
	Created By:	Riley Goyet
	Creation Date:	10/02/2025
	Corrective Action:	Replace (2) 12V 8AH. Batteries Corroded
	Proposed Solution:	
	Manufacturer:	
	Model:	
NAC Power Extender Panel	184	Building B Custodial Office B4
	Created By:	Riley Goyet
	Creation Date:	10/02/2025
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	

Testing Details

Alarm Notification Appliance

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible	121	Building A Admin Office A1	Manual	10/2/2025 2:47:11 PM
		Visual inspection	Passed (Manual)	
Visible	131	Building A Boys RR A19	Manual	10/2/2025 2:46:56 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	101	Building A Break Room A1B	Manual	10/2/2025 2:47:42 PM
		Functional Inspection	Passed	
Visible	124	Building A Break Room A1B	Manual	10/2/2025 2:47:06 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	107	Building A Classroom A10	Manual	10/2/2025 2:47:34 PM
		Functional Inspection	Passed	
Audible And Visible	108	Building A Classroom A11	Manual	10/2/2025 2:47:32 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	109	Building A Classroom A12	Manual	10/2/2025 2:47:31 PM
		Functional Inspection	Passed	
Audible And Visible	110	Building A Classroom A13	Manual	10/2/2025 2:47:30 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	111	Building A Classroom A14	Manual	10/2/2025 2:47:28 PM
		Functional Inspection	Passed	
Audible And Visible	112	Building A Classroom A15	Manual	10/2/2025 2:47:27 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	113	Building A Classroom A20	Manual	10/2/2025 2:47:26 PM
		Functional Inspection	Passed	
Audible And Visible	114	Building A Classroom A21	Manual	10/2/2025 2:47:24 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	115	Building A Classroom A22	Manual	10/2/2025 2:47:21 PM
		Functional Inspection	Passed	
Audible And Visible	104	Building A Classroom A3	Manual	10/2/2025 2:47:38 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	105	Building A Classroom A8	Manual	10/2/2025 2:47:37 PM
		Functional Inspection	Passed	
Audible And Visible	106	Building A Classroom A9	Manual	10/2/2025 2:47:35 PM
		Visual inspection	Passed (Manual)	
Audible	099	Building A East Exterior	Manual	10/2/2025 2:47:45 PM
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	133	Building A Electrical Rm A23A	Manual	10/2/2025 2:46:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	130	Building A Girls RR A16	Manual	10/2/2025 2:46:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	123	Building A Hall O/S Principal Off	Manual	10/2/2025 2:47:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	120	Building A Hallway	Manual	10/2/2025 2:47:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	119	Building A Hallway	Manual	10/2/2025 2:47:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	118	Building A Hallway	Manual	10/2/2025 2:47:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	117	Building A Hallway	Manual	10/2/2025 2:47:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	116	Building A Hallway	Manual	10/2/2025 2:47:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	103	Building A Library A2	Manual	10/2/2025 2:47:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	127	Building A Library A2	Manual	10/2/2025 2:47:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	102	Building A Nurse Office A1C	Manual	10/2/2025 2:47:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	122	Building A Principals Office A1A	Manual	10/2/2025 2:47:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	126	Building A Staff Mens RR	Manual	10/2/2025 2:47:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	125	Building A Staff Womens RR	Manual	10/2/2025 2:47:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	128	Building A West Boys RR	Manual	10/2/2025 2:47:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	100	Building A West Exterior	Manual	10/2/2025 2:47:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	129	Building A West Girls RR	Manual	10/2/2025 2:46:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	132	Building A Workroom A23	Manual	10/2/2025 2:46:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible	182	Building B Custodial Office B4	Manual	10/2/2025 2:46:44 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	177	Building B Hallway O/S MP RR	Manual	10/2/2025 2:46:00 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	179	Building B Kitchen	Manual	10/2/2025 2:46:48 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Visible	183	Building B Kitchen	Manual	10/2/2025 2:46:42 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Visible	181	Building B Mens RR B1A	Manual	10/2/2025 2:46:46 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	173	Building B MP Room	Manual	10/2/2025 2:45:58 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	176	Building B MP Room	Manual	10/2/2025 2:46:01 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	175	Building B MP Room	Manual	10/2/2025 2:46:03 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	174	Building B MP Room	Manual	10/2/2025 2:46:04 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible	172	Building B North Exterior	Manual	10/2/2025 2:46:52 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	178	Building B Room B2	Manual	10/2/2025 2:46:51 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Visible	180	Building B Womens RR B1A	Manual	10/2/2025 2:46:47 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	197	Building C Classroom C2	Manual	10/2/2025 2:46:37 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	196	Building C Counseling C1	Manual	10/2/2025 2:46:39 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible	195	Building C North Exterior	Manual	10/2/2025 2:46:41 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	233	Building D Classroom D1	Manual	10/2/2025 2:46:30 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	234	Building D Classroom D2	Manual	10/2/2025 2:46:29 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	235	Building D Classroom D3	Manual	10/2/2025 2:46:27 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	236	Building D Classroom D4	Manual	10/2/2025 2:46:26 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	237	Building D Classroom D5	Manual	10/2/2025 2:46:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	238	Building D Classroom D6	Manual	10/2/2025 2:46:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	230	Building D Northeast Exterior	Manual	10/2/2025 2:46:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	229	Building D Northwest Exterior	Manual	10/2/2025 2:46:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	232	Building D Southeast Exterior	Manual	10/2/2025 2:46:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	231	Building D Southwest Exterior	Manual	10/2/2025 2:46:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	246	Building E Classroom E1	Manual	10/2/2025 2:46:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	247	Building E Classroom E1	Manual	10/2/2025 2:46:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	248	Building E Room E1 Boys RR	Manual	10/2/2025 2:46:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	249	Building E Room E1 Girls RR	Manual	10/2/2025 2:46:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	245	Building E Southeast Exterior	Manual	10/2/2025 2:46:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	268	Building F Classroom F1	Manual	10/2/2025 2:46:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	269	Building F Classroom F2	Manual	10/2/2025 2:46:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	270	Building F Classroom F3	Manual	10/2/2025 2:46:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	271	Building F Classroom F4	Manual	10/2/2025 2:46:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	266	Building F East Exterior	Manual	10/2/2025 2:46:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	267	Building F West Exterior	Manual	10/2/2025 2:46:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Remote Annunciator	001	Building A Admin Office A1	Manual	10/2/2025 2:52:56 PM
		Visual inspection	Passed (Manual)	
NAC Power Extender Panel	134	Building A Strge Rm W by Rm 3	Manual	10/2/2025 3:08:48 PM
		Visual inspection	Passed (Manual)	
NAC Power Extender Panel	135	Building A Strge Rm W by Rm 3	Manual	10/2/2025 3:08:50 PM
		Visual inspection	Passed (Manual)	
NAC Power Extender Panel	136	Building A Strge Rm W by Rm 3	Manual	10/2/2025 3:08:51 PM
		Visual inspection	Passed (Manual)	

Failed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Fire Alarm Panel		Building A Strge Rm W by Rm 3	Manual	10/2/2025 3:06:15 PM
		Visual inspection	Failed (Manual)	
NAC Power Extender Panel	137	Building A Strge Rm W by Rm 3 P/E B	Manual	10/2/2025 3:08:27 PM
		Visual inspection	Failed (Manual)	
NAC Power Extender Panel	184	Building B Custodial Office B4	Manual	10/2/2025 3:06:46 PM
		Visual inspection	Failed (Manual)	

Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Manual Pull Station	2-130 002	Building A Admin Office A1	Manual	10/2/2025 3:02:23 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-087 003	Building A Admin Office A1	Manual	10/2/2025 3:23:47 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-089 004	Building A Admin Office Storage	Manual	10/2/2025 3:33:46 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-055 066	Building A Boys RR A19	Manual	10/2/2025 3:33:14 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-080 009	Building A Break Room A1B	Manual	10/2/2025 3:25:37 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-079 008	Building A Break Room A1B	Manual	10/2/2025 3:25:49 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-083 007	Building A Break Room A1B	Manual	10/2/2025 3:26:19 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-014 041	Building A Classroom A10	Manual	10/2/2025 2:51:25 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-015 040	Building A Classroom A10	Manual	10/2/2025 2:51:28 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-017 043	Building A Classroom A10	Manual	10/2/2025 2:51:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-016 042	Building A Classroom A10	Manual	10/2/2025 2:51:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-019 044	Building A Classroom A11	Manual	10/2/2025 2:51:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-020 046	Building A Classroom A11	Manual	10/2/2025 2:51:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-018 045	Building A Classroom A11	Manual	10/2/2025 3:33:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-021 047	Building A Classroom A11	Manual	10/2/2025 3:33:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-023 048	Building A Classroom A12	Manual	10/2/2025 3:02:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-024 050	Building A Classroom A12	Manual	10/2/2025 3:02:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-025 051	Building A Classroom A12	Manual	10/2/2025 3:02:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-022 049	Building A Classroom A12	Manual	10/2/2025 3:33:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-026 053	Building A Classroom A13	Manual	10/2/2025 3:03:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-028 054	Building A Classroom A13	Manual	10/2/2025 3:03:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-029 055	Building A Classroom A13	Manual	10/2/2025 3:04:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-027 052	Building A Classroom A13	Manual	10/2/2025 3:07:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-033 059	Building A Classroom A14	Manual	10/2/2025 3:09:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-032 058	Building A Classroom A14	Manual	10/2/2025 3:09:03 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	2-030 057	Building A Classroom A14	Manual	10/2/2025 3:09:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-031 056	Building A Classroom A14	Manual	10/2/2025 3:09:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-034 061	Building A Classroom A15	Manual	10/2/2025 3:10:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-035 060	Building A Classroom A15	Manual	10/2/2025 3:10:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-037 063	Building A Classroom A15	Manual	10/2/2025 3:10:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-036 062	Building A Classroom A15	Manual	10/2/2025 3:33:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-102 068	Building A Classroom A20	Manual	10/2/2025 3:13:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-103 071	Building A Classroom A20	Manual	10/2/2025 3:13:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-100 070	Building A Classroom A20	Manual	10/2/2025 3:17:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-101 069	Building A Classroom A20	Manual	10/2/2025 3:17:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-096 075	Building A Classroom A21	Manual	10/2/2025 3:17:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-097 074	Building A Classroom A21	Manual	10/2/2025 3:18:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-099 073	Building A Classroom A21	Manual	10/2/2025 3:18:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-098 072	Building A Classroom A21	Manual	10/2/2025 3:18:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-095 077	Building A Classroom A22	Manual	10/2/2025 3:17:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-092 079	Building A Classroom A22	Manual	10/2/2025 3:17:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-093 078	Building A Classroom A22	Manual	10/2/2025 3:17:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-094 076	Building A Classroom A22	Manual	10/2/2025 3:17:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-067 024	Building A Classroom A3	Manual	10/2/2025 3:33:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-068 025	Building A Classroom A3	Manual	10/2/2025 3:33:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-066 026	Building A Classroom A3	Manual	10/2/2025 3:33:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-065 027	Building A Classroom A3	Manual	10/2/2025 3:33:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-006 032	Building A Classroom A8	Manual	10/2/2025 2:49:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-007 033	Building A Classroom A8	Manual	10/2/2025 2:50:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-008 034	Building A Classroom A8	Manual	10/2/2025 2:50:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-009 035	Building A Classroom A8	Manual	10/2/2025 2:50:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-010 036	Building A Classroom A9	Manual	10/2/2025 2:50:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-011 037	Building A Classroom A9	Manual	10/2/2025 2:50:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-012 038	Building A Classroom A9	Manual	10/2/2025 2:50:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-013 039	Building A Classroom A9	Manual	10/2/2025 2:50:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-004 031	Building A Custodial Closet	Manual	10/2/2025 3:33:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-091 081	Building A Electrical Room A23A	Manual	10/2/2025 3:17:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-058 065	Building A Girls RR A16	Manual	10/2/2025 3:33:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-043 086	Building A Hall A Wing A10/A11	Manual	10/2/2025 3:17:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-041 088	Building A Hall A Wing A9/A10	Manual	10/2/2025 3:17:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-046 083	Building A Hall A Wing by A1	Manual	10/2/2025 3:20:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-047 082	Building A Hall A Wing by A1	Manual	10/2/2025 3:21:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-042 087	Building A Hall A Wing by A10	Manual	10/2/2025 3:17:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-044 085	Building A Hall A Wing by A11	Manual	10/2/2025 3:33:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-049 093	Building A Hall A Wing by A13	Manual	10/2/2025 3:18:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-052 096	Building A Hall A Wing by A14	Manual	10/2/2025 3:18:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-051 095	Building A Hall A Wing by A14	Manual	10/2/2025 3:18:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-053 097	Building A Hall A Wing by A15	Manual	10/2/2025 3:18:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-038 091	Building A Hall A Wing by A15	Manual	10/2/2025 3:18:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-054 098	Building A Hall A Wing by A20	Manual	10/2/2025 3:18:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-050 094	Building A Hall A Wing by A22	Manual	10/2/2025 3:18:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-039 090	Building A Hall A Wing by A3	Manual	10/2/2025 3:18:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-040 089	Building A Hall A Wing by A9	Manual	10/2/2025 3:33:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-045 084	Building A Hall A Wing by Nurse	Manual	10/2/2025 3:22:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-048 092	Building A Hall A Wing Work Rm	Manual	10/2/2025 3:18:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-085 006	Building A Hall O/S Principal Off	Manual	10/2/2025 3:24:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-073 014	Building A Library A2	Manual	10/2/2025 3:29:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-074 015	Building A Library A2	Manual	10/2/2025 3:30:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-071 017	Building A Library A2	Manual	10/2/2025 3:30:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-072 016	Building A Library A2	Manual	10/2/2025 3:30:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-070 019	Building A Library A2	Manual	10/2/2025 3:30:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-069 018	Building A Library A2	Manual	10/2/2025 3:31:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-075 020	Building A Library A2	Manual	10/2/2025 3:31:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-076 021	Building A Library A2	Manual	10/2/2025 3:33:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-077 022	Building A Library A2	Manual	10/2/2025 3:33:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-078 023	Building A Library A2 Storage	Manual	10/2/2025 3:33:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-088 012	Building A Nurse Office A1C	Manual	10/2/2025 3:23:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-086 013	Building A Nurse Office Closet	Manual	10/2/2025 3:33:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-084 005	Building A Principals Office A1A	Manual	10/2/2025 3:24:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-081 011	Building A Staff Mens RR	Manual	10/2/2025 3:28:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-082 010	Building A Staff Womens RR	Manual	10/2/2025 3:28:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-057 064	Building A Storage O/S Rm 15	Manual	10/2/2025 3:33:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-056 067	Building A Storage O/S Rm 20	Manual	10/2/2025 3:33:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-002 028	Building A Strge Rm W by Rm 3	Manual	10/2/2025 2:48:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-003 029	Building A West Boys RR A4	Manual	10/2/2025 2:48:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-005 030	Building A West Girls RR A7	Manual	10/2/2025 3:33:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-090 080	Building A Workroom A23	Manual	10/2/2025 3:17:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-267 159	Building B Custodial Closet	Manual	10/2/2025 3:46:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-289 164	Building B Custodial Office B4	Manual	10/2/2025 3:55:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-268 158	Building B Hallway O/S MP RR	Manual	10/2/2025 3:46:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-286 168	Building B Kitchen	Manual	10/2/2025 2:52:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-287 169	Building B Kitchen	Manual	10/2/2025 2:52:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-288 163	Building B Kitchen Storage B3	Manual	10/2/2025 3:46:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-266 161	Building B Mens RR B1A	Manual	10/2/2025 3:46:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-269 143	Building B MP Room B1	Manual	10/2/2025 3:47:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-270 142	Building B MP Room B1	Manual	10/2/2025 3:48:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-271 141	Building B MP Room B1	Manual	10/2/2025 3:49:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-274 147	Building B MP Room B1	Manual	10/2/2025 3:50:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-273 146	Building B MP Room B1	Manual	10/2/2025 3:50:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-272 145	Building B MP Room B1	Manual	10/2/2025 3:50:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-300 144	Building B MP Room B1	Manual	10/2/2025 3:50:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-275 150	Building B MP Room B1	Manual	10/2/2025 3:51:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-276 149	Building B MP Room B1	Manual	10/2/2025 3:51:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-277 148	Building B MP Room B1	Manual	10/2/2025 3:51:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-280 154	Building B MP Room B1	Manual	10/2/2025 3:51:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-279 153	Building B MP Room B1	Manual	10/2/2025 3:52:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-278 151	Building B MP Room B1	Manual	10/2/2025 3:52:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-299 152	Building B MP Room B1	Manual	10/2/2025 3:53:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-281 157	Building B MP Room B1	Manual	10/2/2025 3:53:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-282 156	Building B MP Room B1	Manual	10/2/2025 3:53:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-283 155	Building B MP Room B1	Manual	10/2/2025 3:54:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-285 166	Building B MP Room Chase B1	Manual	10/2/2025 2:52:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-284 165	Building B MP Room Chase B1	Manual	10/2/2025 2:52:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-134 138	Building B MP Room Northeast	Manual	10/2/2025 3:02:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-135 140	Building B MP Room Northwest	Manual	10/2/2025 3:02:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-133 139	Building B MP Room Southeast	Manual	10/2/2025 2:48:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-264 162	Building B Room B2	Manual	10/2/2025 3:46:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-301 167	Building B Water Heater Closet	Manual	10/2/2025 2:52:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-265 160	Building B Womens RR B1A	Manual	10/2/2025 3:46:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-385 191	Building C Attic Classroom C1	Manual	10/2/2025 2:48:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-385 190	Building C Attic Classroom C1	Manual	10/2/2025 2:48:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-385 189	Building C Attic Classroom C1	Manual	10/2/2025 2:48:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-384 193	Building C Attic Classroom C2	Manual	10/2/2025 2:47:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-384 192	Building C Attic Classroom C2	Manual	10/2/2025 2:47:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-384 194	Building C Attic Classroom C2	Manual	10/2/2025 2:48:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-293 186	Building C Classroom C1	Manual	10/2/2025 2:48:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-292 185	Building C Classroom C1	Manual	10/2/2025 2:48:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-291 187	Building C Classroom C2	Manual	10/2/2025 2:48:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-290 188	Building C Classroom C2	Manual	10/2/2025 2:48:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-383 213	Building D Attic Classroom D1	Manual	10/2/2025 2:50:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-383 212	Building D Attic Classroom D1	Manual	10/2/2025 2:50:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-383 211	Building D Attic Classroom D1	Manual	10/2/2025 2:50:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-382 216	Building D Attic Classroom D2	Manual	10/2/2025 2:50:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-382 215	Building D Attic Classroom D2	Manual	10/2/2025 2:50:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-382 214	Building D Attic Classroom D2	Manual	10/2/2025 2:50:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-381 219	Building D Attic Classroom D3	Manual	10/2/2025 2:50:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-381 218	Building D Attic Classroom D3	Manual	10/2/2025 2:50:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-381 217	Building D Attic Classroom D3	Manual	10/2/2025 2:50:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-380 222	Building D Attic Classroom D4	Manual	10/2/2025 2:49:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-380 221	Building D Attic Classroom D4	Manual	10/2/2025 2:49:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-380 220	Building D Attic Classroom D4	Manual	10/2/2025 2:49:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-379 225	Building D Attic Classroom D5	Manual	10/2/2025 2:49:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-379 224	Building D Attic Classroom D5	Manual	10/2/2025 2:49:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-379 223	Building D Attic Classroom D5	Manual	10/2/2025 2:49:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-378 228	Building D Attic Classroom D6	Manual	10/2/2025 2:49:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-378 227	Building D Attic Classroom D6	Manual	10/2/2025 2:49:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-378 226	Building D Attic Classroom D6	Manual	10/2/2025 2:49:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-262 199	Building D Classroom D1	Manual	10/2/2025 3:05:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-263 198	Building D Classroom D1	Manual	10/2/2025 3:05:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-261 200	Building D Classroom D2	Manual	10/2/2025 3:05:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-260 201	Building D Classroom D2	Manual	10/2/2025 3:05:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-258 202	Building D Classroom D3	Manual	10/2/2025 2:51:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-259 203	Building D Classroom D3	Manual	10/2/2025 2:51:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-257 204	Building D Classroom D4	Manual	10/2/2025 2:51:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-256 205	Building D Classroom D4	Manual	10/2/2025 2:51:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-254 206	Building D Classroom D5	Manual	10/2/2025 2:51:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-255 207	Building D Classroom D5	Manual	10/2/2025 2:51:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-302 208	Building D Classroom D5 Closet	Manual	10/2/2025 2:51:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-253 209	Building D Classroom D6	Manual	10/2/2025 2:50:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-252 210	Building D Classroom D6	Manual	10/2/2025 2:50:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-061 239	Building E Classroom E1	Manual	10/2/2025 3:38:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-062 242	Building E Classroom E1	Manual	10/2/2025 3:38:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-064 240	Building E Classroom E1	Manual	10/2/2025 3:38:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-063 241	Building E Classroom E1	Manual	10/2/2025 3:38:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-060 243	Building E Room E1 Boys RR	Manual	10/2/2025 3:39:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-059 244	Building E Room E1 Girls RR	Manual	10/2/2025 3:39:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-138 259	Building F Attic Classroom F1	Manual	10/2/2025 2:52:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-138 258	Building F Attic Classroom F1	Manual	10/2/2025 2:52:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-139 261	Building F Attic Classroom F2	Manual	10/2/2025 2:48:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-139 260	Building F Attic Classroom F2	Manual	10/2/2025 2:48:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-140 263	Building F Attic Classroom F3	Manual	10/2/2025 2:48:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-140 262	Building F Attic Classroom F3	Manual	10/2/2025 2:48:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-141 265	Building F Attic Classroom F4	Manual	10/2/2025 2:49:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-141 264	Building F Attic Classroom F4	Manual	10/2/2025 2:49:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-110 251	Building F Classroom F1	Manual	10/2/2025 2:48:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-109 250	Building F Classroom F1	Manual	10/2/2025 3:17:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-111 252	Building F Classroom F2	Manual	10/2/2025 2:48:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-112 253	Building F Classroom F2	Manual	10/2/2025 3:17:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-114 255	Building F Classroom F3	Manual	10/2/2025 2:49:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-113 254	Building F Classroom F3	Manual	10/2/2025 2:49:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-115 256	Building F Classroom F4	Manual	10/2/2025 2:49:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-116 257	Building F Classroom F4	Manual	10/2/2025 2:49:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - Duct	2-386 170	Building B MP Room East	Manual	10/2/2025 3:06:22 PM
Smoke Detector - Duct	2-387 171	Building B MP Room West	Manual	10/2/2025 3:06:24 PM

Device/Equipment details

Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Audible					
099	Building A East Exterior				
100	Building A West Exterior				
172	Building B North Exterior				
195	Building C North Exterior				
229	Building D Northwest Exterior				
230	Building D Northeast Exterior				
231	Building D Southwest Exterior				
232	Building D Southeast Exterior				
245	Building E Southeast Exterior				
266	Building F East Exterior				
267	Building F West Exterior				
Audible And Visible					
101	Building A Break Room A1B				
102	Building A Nurse Office A1C				
103	Building A Library A2				
104	Building A Classroom A3				
105	Building A Classroom A8				
106	Building A Classroom A9				
107	Building A Classroom A10				
108	Building A Classroom A11				
109	Building A Classroom A12				
110	Building A Classroom A13				
111	Building A Classroom A14				
112	Building A Classroom A15				
113	Building A Classroom A20				
114	Building A Classroom A21				
115	Building A Classroom A22				
116	Building A Hallway				
117	Building A Hallway				
118	Building A Hallway				
119	Building A Hallway				
120	Building A Hallway				
173	Building B MP Room				
174	Building B MP Room				
175	Building B MP Room				
176	Building B MP Room				
177	Building B Hallway O/S MP RR				
178	Building B Room B2				
179	Building B Kitchen				
196	Building C Counseling C1				
197	Building C Classroom C2				
233	Building D Classroom D1				
234	Building D Classroom D2				
235	Building D Classroom D3				
236	Building D Classroom D4				
237	Building D Classroom D5				
238	Building D Classroom D6				
246	Building E Classroom E1				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
268	Building F Classroom F1				
269	Building F Classroom F2				
270	Building F Classroom F3				
271	Building F Classroom F4				

Visible

121	Building A Admin Office A1				
122	Building A Principals Office A1A				
123	Building A Hall O/S Principal Off				
124	Building A Break Room A1B				
125	Building A Staff Womens RR				
126	Building A Staff Mens RR				
127	Building A Library A2				
128	Building A West Boys RR				
129	Building A West Girls RR				
130	Building A Girls RR A16				
131	Building A Boys RR A19				
132	Building A Workroom A23				
133	Building A Electrical Rm A23A				
180	Building B Womens RR B1A				
181	Building B Mens RR B1A				
182	Building B Custodial Office B4				
183	Building B Kitchen				
247	Building E Classroom E1				
248	Building E Room E1 Boys RR				
249	Building E Room E1 Girls RR				

Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
NAC Power Extender Panel					
134	Building A Strge Rm W by Rm 3				
135	Building A Strge Rm W by Rm 3				
136	Building A Strge Rm W by Rm 3				
137	Building A Strge Rm W by Rm 3 P/E B				
184	Building B Custodial Office B4				

Remote Annunciator

001	Building A Admin Office A1				
-----	----------------------------	--	--	--	--

Fire Alarm Panel

	Building A Strge Rm W by Rm 3				03/18/2019
--	-------------------------------	--	--	--	------------

Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Smoke Detector - General					
2-022 049	Building A Classroom A12				
2-024 050	Building A Classroom A12				
2-025 051	Building A Classroom A12				
2-027 052	Building A Classroom A13				
2-026 053	Building A Classroom A13				
2-028 054	Building A Classroom A13				
2-029 055	Building A Classroom A13				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-031 056	Building A Classroom A14				
2-030 057	Building A Classroom A14				
2-032 058	Building A Classroom A14				
2-033 059	Building A Classroom A14				
2-035 060	Building A Classroom A15				
2-034 061	Building A Classroom A15				
2-036 062	Building A Classroom A15				
2-037 063	Building A Classroom A15				
2-057 064	Building A Storage O/S Rm 15				
2-058 065	Building A Girls RR A16				
2-055 066	Building A Boys RR A19				
2-056 067	Building A Storage O/S Rm 20				
2-102 068	Building A Classroom A20				
2-101 069	Building A Classroom A20				
2-100 070	Building A Classroom A20				
2-103 071	Building A Classroom A20				
2-098 072	Building A Classroom A21				
2-099 073	Building A Classroom A21				
2-097 074	Building A Classroom A21				
2-096 075	Building A Classroom A21				
2-094 076	Building A Classroom A22				
2-095 077	Building A Classroom A22				
2-093 078	Building A Classroom A22				
2-092 079	Building A Classroom A22				
2-090 080	Building A Workroom A23				
2-091 081	Building A Electrical Room A23A				
2-047 082	Building A Hall A Wing by A1				
2-046 083	Building A Hall A Wing by A1				
2-045 084	Building A Hall A Wing by Nurse				
2-044 085	Building A Hall A Wing by A11				
2-043 086	Building A Hall A Wing A10/A11				
2-042 087	Building A Hall A Wing by A10				
2-041 088	Building A Hall A Wing A9/A10				
2-040 089	Building A Hall A Wing by A9				
2-039 090	Building A Hall A Wing by A3				
2-038 091	Building A Hall A Wing by A15				
2-048 092	Building A Hall A Wing Work Rm				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-049 093	Building A Hall A Wing by A13				
2-050 094	Building A Hall A Wing by A22				
2-051 095	Building A Hall A Wing by A14				
2-052 096	Building A Hall A Wing by A14				
2-053 097	Building A Hall A Wing by A15				
2-054 098	Building A Hall A Wing by A20				
2-271 141	Building B MP Room B1				
2-270 142	Building B MP Room B1				
2-269 143	Building B MP Room B1				
2-300 144	Building B MP Room B1				
2-272 145	Building B MP Room B1				
2-273 146	Building B MP Room B1				
2-274 147	Building B MP Room B1				
2-277 148	Building B MP Room B1				
2-276 149	Building B MP Room B1				
2-275 150	Building B MP Room B1				
2-278 151	Building B MP Room B1				
2-299 152	Building B MP Room B1				
2-279 153	Building B MP Room B1				
2-280 154	Building B MP Room B1				
2-283 155	Building B MP Room B1				
2-282 156	Building B MP Room B1				
2-281 157	Building B MP Room B1				
2-268 158	Building B Hallway O/S MP RR				
2-267 159	Building B Custodial Closet				
2-265 160	Building B Womens RR B1A				
2-266 161	Building B Mens RR B1A				
2-264 162	Building B Room B2				
2-288 163	Building B Kitchen Storage B3				
2-289 164	Building B Custodial Office B4				
2-292 185	Building C Classroom C1				
2-293 186	Building C Classroom C1				
2-291 187	Building C Classroom C2				
2-290 188	Building C Classroom C2				
2-263 198	Building D Classroom D1				
2-262 199	Building D Classroom D1				
2-261 200	Building D Classroom D2				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-260 201	Building D Classroom D2				
2-258 202	Building D Classroom D3				
2-259 203	Building D Classroom D3				
2-257 204	Building D Classroom D4				
2-256 205	Building D Classroom D4				
2-254 206	Building D Classroom D5				
2-255 207	Building D Classroom D5				
2-302 208	Building D Classroom D5 Closet				
2-253 209	Building D Classroom D6				
2-252 210	Building D Classroom D6				
2-061 239	Building E Classroom E1				
2-064 240	Building E Classroom E1				
2-063 241	Building E Classroom E1				
2-062 242	Building E Classroom E1				
2-060 243	Building E Room E1 Boys RR				
2-059 244	Building E Room E1 Girls RR				
2-109 250	Building F Classroom F1				
2-110 251	Building F Classroom F1				
2-111 252	Building F Classroom F2				
2-112 253	Building F Classroom F2				
2-113 254	Building F Classroom F3				
2-114 255	Building F Classroom F3				
2-115 256	Building F Classroom F4				
2-116 257	Building F Classroom F4				
2-087 003	Building A Admin Office A1				
2-089 004	Building A Admin Office Storage				
2-084 005	Building A Principals Office A1A				
2-085 006	Building A Hall O/S Principal Off				
2-083 007	Building A Break Room A1B				
2-079 008	Building A Break Room A1B				
2-080 009	Building A Break Room A1B				
2-082 010	Building A Staff Womens RR				
2-081 011	Building A Staff Mens RR				
2-088 012	Building A Nurse Office A1C				
2-086 013	Building A Nurse Office Closet				
2-073 014	Building A Library A2				
2-074 015	Building A Library A2				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-072 016	Building A Library A2				
2-071 017	Building A Library A2				
2-069 018	Building A Library A2				
2-070 019	Building A Library A2				
2-075 020	Building A Library A2				
2-076 021	Building A Library A2				
2-077 022	Building A Library A2				
2-078 023	Building A Library A2 Storage				
2-067 024	Building A Classroom A3				
2-068 025	Building A Classroom A3				
2-066 026	Building A Classroom A3				
2-065 027	Building A Classroom A3				
2-002 028	Building A Strge Rm W by Rm 3				
2-003 029	Building A West Boys RR A4				
2-005 030	Building A West Girls RR A7				
2-004 031	Building A Custodial Closet				
2-006 032	Building A Classroom A8				
2-007 033	Building A Classroom A8				
2-008 034	Building A Classroom A8				
2-009 035	Building A Classroom A8				
2-010 036	Building A Classroom A9				
2-011 037	Building A Classroom A9				
2-012 038	Building A Classroom A9				
2-013 039	Building A Classroom A9				
2-015 040	Building A Classroom A10				
2-014 041	Building A Classroom A10				
2-016 042	Building A Classroom A10				
2-017 043	Building A Classroom A10				
2-019 044	Building A Classroom A11				
2-018 045	Building A Classroom A11				
2-020 046	Building A Classroom A11				
2-021 047	Building A Classroom A11				
2-023 048	Building A Classroom A12				
Manual Pull Station					
2-134 138	Building B MP Room Northeast				
2-133 139	Building B MP Room Southeast				
2-135 140	Building B MP Room Northwest				
2-130 002	Building A Admin Office A1				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Heat Detector - Restorable Spot					
2-284 165	Building B MP Room Chase B1				
2-285 166	Building B MP Room Chase B1				
2-301 167	Building B Water Heater Closet				
2-286 168	Building B Kitchen				
2-287 169	Building B Kitchen				
2-385 189	Building C Attic Classroom C1				
2-385 190	Building C Attic Classroom C1				
2-385 191	Building C Attic Classroom C1				
2-384 192	Building C Attic Classroom C2				
2-384 193	Building C Attic Classroom C2				
2-384 194	Building C Attic Classroom C2				
2-383 211	Building D Attic Classroom D1				
2-383 212	Building D Attic Classroom D1				
2-383 213	Building D Attic Classroom D1				
2-382 214	Building D Attic Classroom D2				
2-382 215	Building D Attic Classroom D2				
2-382 216	Building D Attic Classroom D2				
2-381 217	Building D Attic Classroom D3				
2-381 218	Building D Attic Classroom D3				
2-381 219	Building D Attic Classroom D3				
2-380 220	Building D Attic Classroom D4				
2-380 221	Building D Attic Classroom D4				
2-380 222	Building D Attic Classroom D4				
2-379 223	Building D Attic Classroom D5				
2-379 224	Building D Attic Classroom D5				
2-379 225	Building D Attic Classroom D5				
2-378 226	Building D Attic Classroom D6				
2-378 227	Building D Attic Classroom D6				
2-378 228	Building D Attic Classroom D6				
2-138 258	Building F Attic Classroom F1				
2-138 259	Building F Attic Classroom F1				
2-139 260	Building F Attic Classroom F2				
2-139 261	Building F Attic Classroom F2				
2-140 262	Building F Attic Classroom F3				
2-140 263	Building F Attic Classroom F3				
2-141 264	Building F Attic Classroom F4				
2-141 265	Building F Attic Classroom F4				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Smoke Detector - Duct					
2-386 170	Building B MP Room East				
2-387 171	Building B MP Room West				