

Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

NORTHRIDGE ELEMENTARY

5150 COCOA PALM WAY
FAIR OAKS, California 95628
United States

This site has been inspected and tested in compliance with applicable standards.

Completed
Tuesday, September 30, 2025

Test Session:23 Sep 2025 15:34 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD
5320 HEMLOCK ST
SACRAMENTO, California
United States

TESTED BY

Riley Goyet
Western States Fire Protection-
Sacramento
188 Cirby Way
Roseville, CA 95678
United States



Inspection Summary

Building Information

PROPERTY	NORTHRIDGE ELEMENTARY	CONTACT
ADDRESS	5150 COCOA PALM WAY	PHONE
CITY/STATE	FAIR OAKS, California 95628	MOBILE
COUNTRY	United States	EMAIL

Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us

Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Alarm Notification Appliance	84	84(100%)	84(100%)	0(0%)
Fire Control Panel	8	8(100%)	3(38%)	5(63%)
Initiating Device	169	166(98%)	163(96%)	3(2%)

Certification

The equipment specified here in was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Tuesday, September 30, 2025

			
ACCEPTED BY	09/30/2025	TESTED BY	09/30/2025
	Building Representative		Riley Goyet Technician

System Details

Control Units

ADDRESS/ SCAN ADDRESS		DESCRIPTION	Building A Electrical Room
MANUFACTURER	EST	S/W VERSION	
MODEL	3	LAST UPDATE	
SERIAL NUMBER		S/W LOCATION	
INSTALL DATE			

Open Corrective Action & Solution Summary

The following 10 corrective action(s) remain open following the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
Valve Tamper Switch	2-392 232	Multi-Purpose Bldg OS&Y
	Created By:	Riley Goyet
	Creation Date:	10/07/2024
	Corrective Action:	Did not activate
	Proposed Solution:	
	Manufacturer:	System sensor
	Model:	OSY2
	Created By:	Riley Goyet
	Creation Date:	09/23/2025
	Corrective Action:	OSY 2 potter
	Proposed Solution:	
	Manufacturer:	System sensor
	Model:	OSY2
Valve Tamper Switch	2-392 233	Multi-Purpose Bldg OS&Y
	Created By:	Riley Goyet
	Creation Date:	10/07/2024
	Corrective Action:	Failed to activate
	Proposed Solution:	
	Manufacturer:	Potter
	Model:	OSYSU2
	Created By:	Riley Goyet
	Creation Date:	09/23/2025
	Corrective Action:	System sensor Osy2
	Proposed Solution:	
	Manufacturer:	Potter
	Model:	OSYSU2
NAC Power Extender Panel		Building B Art Room/Storage - P.E. "D"
	Created By:	Riley Goyet
	Creation Date:	10/07/2024
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
NAC Power Extender Panel		Building C Work Room - P.E. "E"
	Created By:	Riley Goyet
	Creation Date:	10/07/2024
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
NAC Power Extender Panel		Rms 17-20 Bldg Classroom 20 - P.E. "C"
	Created By:	Riley Goyet
	Creation Date:	10/10/2024
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
NAC Power Extender Panel		Multi-Purpose Bldg Electrical Room - P.E. "F"
	Created By:	Riley Goyet

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
	Creation Date:	10/10/2024
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
NAC Power Extender Panel		Multi-Purpose Bldg Electrical Room - P.E. "G"
	Created By:	Riley Goyet
	Creation Date:	10/10/2024
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
Valve Tamper Switch	2-392 231	Multi-Purpose Bldg PIV
	Created By:	Riley Goyet
	Creation Date:	09/23/2025
	Corrective Action:	System sensor PIBV2
	Proposed Solution:	
	Manufacturer:	
	Model:	

Testing Details

Alarm Notification Appliance

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	035	Building A A Pod Work Room	Manual	9/23/2025 3:37:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	037	Building A Admin Nurse RR	Manual	9/23/2025 3:36:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	029	Building A Admin Office	Manual	9/23/2025 3:38:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	032	Building A Admin Principal Office	Manual	9/23/2025 3:38:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	030	Building A Admin Storage W	Manual	9/23/2025 3:36:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	038	Building A Boys RR in Work Rm	Manual	9/23/2025 3:36:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	033	Building A Classroom A1	Manual	9/23/2025 3:37:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	034	Building A Classroom A2	Manual	9/23/2025 3:37:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	036	Building A Custodial Closet	Manual	9/23/2025 3:37:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	027	Building A East Exterior	Manual	9/23/2025 3:38:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	039	Building A Girls RR in Work Rm	Manual	9/23/2025 3:36:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	026	Building A North Exterior	Manual	9/23/2025 3:38:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	031	Building A Nurse Office	Manual	9/23/2025 3:38:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	028	Building A South Exterior	Manual	9/23/2025 3:38:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	066	Building B Boys Restroom	Manual	9/23/2025 3:36:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	058	Building B Classroom B1	Manual	9/23/2025 3:37:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	059	Building B Classroom B2	Manual	9/23/2025 3:37:52 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	060	Building B Classroom B3	Manual	9/23/2025 3:37:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	061	Building B Classroom B4	Manual	9/23/2025 3:37:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	062	Building B Classroom B5	Manual	9/23/2025 3:37:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	063	Building B Classroom B6	Manual	9/23/2025 3:37:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	056	Building B East Exterior	Manual	9/23/2025 3:38:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	065	Building B Girls Restroom	Manual	9/23/2025 3:36:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	064	Building B Learning Center	Manual	9/23/2025 3:37:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	057	Building B Outside Room B5	Manual	9/23/2025 3:38:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	055	Building B South Exterior	Manual	9/23/2025 3:38:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	093	Building C Boys Restroom	Manual	9/23/2025 3:36:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	088	Building C Classroom C10	Manual	9/23/2025 3:37:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	089	Building C Classroom C11	Manual	9/23/2025 3:37:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	090	Building C Classroom C12	Manual	9/23/2025 3:37:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	085	Building C Classroom C7	Manual	9/23/2025 3:37:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	086	Building C Classroom C8	Manual	9/23/2025 3:37:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	087	Building C Classroom C9	Manual	9/23/2025 3:37:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	082	Building C East Exterior	Manual	9/23/2025 3:38:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	092	Building C Girls Restroom	Manual	9/23/2025 3:36:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible	084	Building C Outside Room C10	Manual	9/23/2025 3:38:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	091	Building C Speech Room	Manual	9/23/2025 3:37:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	095	Building C Staff RR by Rm C12	Manual	9/23/2025 3:36:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	094	Building C Staff RR by Rm C9	Manual	9/23/2025 3:36:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	083	Building C West Exterior	Manual	9/23/2025 3:38:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	243	Multi-Purpose Bldg Cust Office Hall	Manual	9/23/2025 3:36:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	235	Multi-Purpose Bldg East Exterior	Manual	9/23/2025 3:38:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	244	Multi-Purpose Bldg Kitchen	Manual	9/23/2025 3:36:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	247	Multi-Purpose Bldg Mens Restroom	Manual	9/23/2025 3:36:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	238	Multi-Purpose Bldg MP Room	Manual	9/23/2025 3:36:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	240	Multi-Purpose Bldg MP Room	Manual	9/23/2025 3:36:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	239	Multi-Purpose Bldg MP Room	Manual	9/23/2025 3:36:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	237	Multi-Purpose Bldg MP Room	Manual	9/23/2025 3:36:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	234	Multi-Purpose Bldg North Exterior	Manual	9/23/2025 3:38:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	245	Multi-Purpose Bldg Restroom Hallway	Manual	9/23/2025 3:36:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	248	Multi-Purpose Bldg South Exterior	Manual	9/23/2025 3:38:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	242	Multi-Purpose Bldg Stage	Manual	9/23/2025 3:36:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	241	Multi-Purpose Bldg Stage Hall East	Manual	9/23/2025 3:36:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	236	Multi-Purpose Bldg West Exterior	Manual	9/23/2025 3:38:10 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	246	Multi-Purpose Bldg Womens Restroom	Manual	9/23/2025 3:36:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	182	Portables Classroom 21	Manual	9/23/2025 3:37:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	183	Portables Classroom 21A	Manual	9/23/2025 3:37:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	184	Portables Classroom 22A	Manual	9/23/2025 3:37:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	185	Portables Classroom 22B	Manual	9/23/2025 3:37:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	186	Portables Classroom 23	Manual	9/23/2025 3:36:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	187	Portables Classroom 24	Manual	9/23/2025 3:37:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	188	Portables Classroom 25	Manual	9/23/2025 3:37:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	189	Portables Classroom 26	Manual	9/23/2025 3:37:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	178	Portables Outside Classrm 22B	Manual	9/23/2025 3:38:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	179	Portables Outside Classrm 23	Manual	9/23/2025 3:38:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	180	Portables Outside Classrm 24	Manual	9/23/2025 3:38:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	181	Portables Outside Classrm 26	Manual	9/23/2025 3:38:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	108	Rms 13 & 14 Bldg Classroom 13	Manual	9/23/2025 3:37:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	109	Rms 13 & 14 Bldg Classroom 14	Manual	9/23/2025 3:37:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	107	Rms 13 & 14 Bldg West Exterior	Manual	9/23/2025 3:38:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	122	Rms 15 & 16 Bldg Classroom 15	Manual	9/23/2025 3:37:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	123	Rms 15 & 16 Bldg Classroom 16	Manual	9/23/2025 3:37:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible	121	Rms 15 & 16 Bldg East Exterior	Manual	9/23/2025 3:38:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	149	Rms 17-20 Bldg Classroom 17	Manual	9/23/2025 3:37:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	150	Rms 17-20 Bldg Classroom 18	Manual	9/23/2025 3:37:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	151	Rms 17-20 Bldg Classroom 19	Manual	9/23/2025 3:37:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	152	Rms 17-20 Bldg Classroom 20	Manual	9/23/2025 3:37:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	146	Rms 17-20 Bldg East Exterior	Manual	9/23/2025 3:38:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	145	Rms 17-20 Bldg North Exterior	Manual	9/23/2025 3:38:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	147	Rms 17-20 Bldg South Exterior	Manual	9/23/2025 3:38:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	148	Rms 17-20 Bldg West Exterior	Manual	9/23/2025 3:38:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	254	Snack Shack Bldg Boys Restroom	Manual	9/23/2025 3:36:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	253	Snack Shack Bldg East Exterior	Manual	9/23/2025 3:38:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	255	Snack Shack Bldg Girls Restroom	Manual	9/23/2025 3:36:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Remote Annunciator	001	Building A Admin Office	Manual	9/23/2025 5:01:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Fire Alarm Panel		Building A Electrical Room	Manual	9/23/2025 5:01:14 PM
		Manufacturer	EST	
		Model	3	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Building A Electrical Room - P.E. "B"	Manual	9/23/2025 5:01:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Failed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
NAC Power Extender Panel		Building B Art Room/Storage - P.E. "D"	Manual	9/23/2025 5:00:39 PM
		Visual inspection	Failed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Failed	
NAC Power Extender Panel		Building C Work Room - P.E. "E"	Manual	9/23/2025 5:00:20 PM
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	
NAC Power Extender Panel		Multi-Purpose Bldg Electrical Room - P.E. "F"	Manual	9/23/2025 5:00:12 PM
		Visual inspection	Failed (Manual)	
NAC Power Extender Panel		Multi-Purpose Bldg Electrical Room - P.E. "G"	Manual	9/23/2025 5:00:04 PM
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	
NAC Power Extender Panel		Rms 17-20 Bldg Classroom 20 - P.E. "C"	Manual	9/23/2025 4:59:59 PM
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	

Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-007 015	Building A A Pod Work Room	Manual	9/23/2025 3:50:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-012 007	Building A Admin Nurse RR	Manual	9/23/2025 3:56:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-139 002	Building A Admin Office	Manual	9/23/2025 3:55:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-015 003	Building A Admin Office	Manual	9/23/2025 3:53:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-016 008	Building A Admin Principal Office	Manual	9/23/2025 4:59:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-011 022	Building A Admin Storage N	Manual	9/23/2025 5:40:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-014 004	Building A Admin Storage W	Manual	9/23/2025 3:54:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-140 024	Building A Attic Classroom A1	Manual	9/23/2025 3:50:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-141 025	Building A Attic Classroom A2	Manual	9/23/2025 5:40:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-005 016	Building A Boys RR in Work Rm	Manual	9/23/2025 3:50:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-003 013	Building A Classroom A1	Manual	9/23/2025 3:49:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-004 012	Building A Classroom A1	Manual	9/23/2025 3:49:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-090 014	Building A Classroom A1	Manual	9/23/2025 3:49:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-008 019	Building A Classroom A2	Manual	9/23/2025 3:50:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-009 018	Building A Classroom A2	Manual	9/23/2025 3:51:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-091 020	Building A Classroom A2	Manual	9/23/2025 3:51:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-138 023	Building A Custodial Closet	Manual	9/23/2025 5:40:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-002 011	Building A Electrical Room	Manual	9/23/2025 4:59:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-001 010	Building A Electrical Room	Manual	9/23/2025 4:59:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-081 009	Building A Electrical Room	Manual	9/23/2025 5:32:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-006 017	Building A Girls RR in Work Rm	Manual	9/23/2025 3:50:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-080 006	Building A Nurse Office	Manual	9/23/2025 3:56:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-013 005	Building A Nurse Office	Manual	9/23/2025 3:56:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-071 021	Building A Nurse Storage	Manual	9/23/2025 5:40:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-035 051	Building B Art Room/Storage	Manual	9/23/2025 4:06:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-047 047	Building B Boys Restroom	Manual	9/23/2025 4:03:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-038 040	Building B Classroom B1	Manual	9/23/2025 3:59:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-041 043	Building B Classroom B2	Manual	9/23/2025 4:02:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-044 046	Building B Classroom B3	Manual	9/23/2025 4:03:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-045 049	Building B Classroom B4	Manual	9/23/2025 4:05:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-049 050	Building B Classroom B5	Manual	9/23/2025 4:06:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-036 052	Building B Classroom B6	Manual	9/23/2025 4:08:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-039 041	Building B Cust Closet by B1	Manual	9/23/2025 4:00:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-046 048	Building B Custodial Closet	Manual	9/23/2025 4:04:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-040 042	Building B Girls Restroom	Manual	9/23/2025 4:02:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-043 045	Building B Learning Center	Manual	9/23/2025 4:02:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-127 054	Building B NE Hall Exit	Manual	9/23/2025 5:20:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-042 044	Building B Staff Restroom	Manual	9/23/2025 4:02:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-126 053	Building B SW Hall Exit	Manual	9/23/2025 4:02:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-053 077	Building C Boys Restroom	Manual	9/23/2025 4:15:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-063 074	Building C Classroom C10	Manual	9/23/2025 4:13:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-052 076	Building C Classroom C11	Manual	9/23/2025 4:15:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-054 079	Building C Classroom C12	Manual	9/23/2025 4:16:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-056 067	Building C Classroom C7	Manual	9/23/2025 4:09:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-059 070	Building C Classroom C8	Manual	9/23/2025 5:03:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-075 073	Building C Classroom C9	Manual	9/23/2025 4:13:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-057 068	Building C Custodial Closet	Manual	9/23/2025 4:10:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-129 080	Building C East Hall Exit	Manual	9/23/2025 5:16:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-058 069	Building C Girls Restroom	Manual	9/23/2025 4:11:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-061 072	Building C Speech Room	Manual	9/23/2025 4:12:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-076 078	Building C Staff RR by Rm C12	Manual	9/23/2025 4:16:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-060 071	Building C Staff RR by Rm C9	Manual	9/23/2025 5:03:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-128 081	Building C West Hall Exit	Manual	9/23/2025 5:15:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-051 075	Building C Work Room	Manual	9/23/2025 4:14:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-384 225	Multi-Purpose Bldg Attic Mens RR	Manual	9/23/2025 5:16:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-385 223	Multi-Purpose Bldg Attic Restroom Hall	Manual	9/23/2025 5:16:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-390 221	Multi-Purpose Bldg Attic Stage Hall East	Manual	9/23/2025 5:15:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-388 222	Multi-Purpose Bldg Attic Stage Hall West	Manual	9/23/2025 5:15:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-383 224	Multi-Purpose Bldg Attic Womens RR	Manual	9/23/2025 5:16:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-310 212	Multi-Purpose Bldg Cust Office Hall	Manual	9/23/2025 4:33:55 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-277 217	Multi-Purpose Bldg Custodial Storage	Manual	9/23/2025 4:37:25 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	2-391 230	Multi-Purpose Bldg Custodian Office	Manual	9/23/2025 5:14:32 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-311 213	Multi-Purpose Bldg Custodian Office	Manual	9/23/2025 4:34:18 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-271 207	Multi-Purpose Bldg Electrical Room	Manual	9/23/2025 4:59:02 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-275 219	Multi-Purpose Bldg Kitchen	Manual	9/23/2025 5:03:21 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Manual Pull Station	2-411 193	Multi-Purpose Bldg Kitchen	Manual	9/23/2025 5:23:36 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-273 216	Multi-Purpose Bldg Mens Restroom	Manual	9/23/2025 4:36:40 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-287 206	Multi-Purpose Bldg MP Room	Manual	9/23/2025 4:31:39 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-280 195	Multi-Purpose Bldg MP Room	Manual	9/23/2025 4:39:01 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-281 200	Multi-Purpose Bldg MP Room	Manual	9/23/2025 4:39:27 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-286 201	Multi-Purpose Bldg MP Room	Manual	9/23/2025 4:39:50 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-278 197	Multi-Purpose Bldg MP Room	Manual	9/23/2025 4:43:12 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-285 202	Multi-Purpose Bldg MP Room	Manual	9/23/2025 4:58:55 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-282 199	Multi-Purpose Bldg MP Room	Manual	9/23/2025 4:58:57 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-279 196	Multi-Purpose Bldg MP Room	Manual	9/23/2025 4:58:59 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-283 198	Multi-Purpose Bldg MP Room	Manual	9/23/2025 4:59:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-284 203	Multi-Purpose Bldg MP Room	Manual	9/23/2025 4:59:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-288 205	Multi-Purpose Bldg MP Room	Manual	9/23/2025 4:59:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-289 204	Multi-Purpose Bldg MP Room	Manual	9/23/2025 4:59:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-413 191	Multi-Purpose Bldg MP Room NE	Manual	9/23/2025 4:30:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-409 190	Multi-Purpose Bldg MP Room NW	Manual	9/23/2025 4:40:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-412 192	Multi-Purpose Bldg MP Room SE	Manual	9/23/2025 4:30:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-377 228	Multi-Purpose Bldg MP Room West	Manual	9/23/2025 5:30:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-410 194	Multi-Purpose Bldg Restroom Hallway	Manual	9/23/2025 4:38:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-274 214	Multi-Purpose Bldg Restroom Hallway	Manual	9/23/2025 4:35:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-313 209	Multi-Purpose Bldg Stage	Manual	9/23/2025 4:33:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-312 210	Multi-Purpose Bldg Stage	Manual	9/23/2025 4:58:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-378 227	Multi-Purpose Bldg Stage East	Manual	9/23/2025 5:30:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-315 211	Multi-Purpose Bldg Stage East Storage	Manual	9/23/2025 4:32:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-314 208	Multi-Purpose Bldg Stage Hall East	Manual	9/23/2025 4:32:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-387 220	Multi-Purpose Bldg Subfloor Stage	Manual	9/23/2025 5:15:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-272 215	Multi-Purpose Bldg Womens Restroom	Manual	9/23/2025 4:36:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-414 167	Portables Attic Classroom 21	Manual	9/23/2025 4:39:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-414 166	Portables Attic Classroom 21	Manual	9/23/2025 4:39:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-415 168	Portables Attic Classroom 22A	Manual	9/23/2025 4:31:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-415 169	Portables Attic Classroom 22B	Manual	9/23/2025 4:31:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-376 170	Portables Attic Classroom 23	Manual	9/23/2025 4:28:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-376 171	Portables Attic Classroom 23	Manual	9/23/2025 4:28:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-381 172	Portables Attic Classroom 24	Manual	9/23/2025 5:37:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-381 173	Portables Attic Classroom 24	Manual	9/23/2025 5:37:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-380 175	Portables Attic Classroom 25	Manual	9/23/2025 4:51:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-380 174	Portables Attic Classroom 25	Manual	9/23/2025 4:51:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-379 176	Portables Attic Classroom 26	Manual	9/23/2025 4:58:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-379 177	Portables Attic Classroom 26	Manual	9/23/2025 4:58:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-316 153	Portables Classroom 21	Manual	9/23/2025 4:20:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-317 154	Portables Classroom 21	Manual	9/23/2025 4:20:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-318 155	Portables Classroom 21A	Manual	9/23/2025 5:14:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-320 156	Portables Classroom 22A	Manual	9/23/2025 4:19:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-319 157	Portables Classroom 22B	Manual	9/23/2025 4:19:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-253 158	Portables Classroom 23	Manual	9/23/2025 4:17:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-254 159	Portables Classroom 23	Manual	9/23/2025 4:18:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-269 160	Portables Classroom 24	Manual	9/23/2025 4:22:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-268 161	Portables Classroom 24	Manual	9/23/2025 4:23:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-267 162	Portables Classroom 25	Manual	9/23/2025 4:24:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-266 163	Portables Classroom 25	Manual	9/23/2025 4:25:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-264 164	Portables Classroom 26	Manual	9/23/2025 4:26:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-265 165	Portables Classroom 26	Manual	9/23/2025 4:26:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-135 103	Rms 13 & 14 Bldg Attic Classroom 13	Manual	9/23/2025 4:20:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-135 102	Rms 13 & 14 Bldg Attic Classroom 13	Manual	9/23/2025 4:20:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-135 101	Rms 13 & 14 Bldg Attic Classroom 13	Manual	9/23/2025 4:20:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-134 106	Rms 13 & 14 Bldg Attic Classroom 14	Manual	9/23/2025 4:15:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-134 105	Rms 13 & 14 Bldg Attic Classroom 14	Manual	9/23/2025 4:15:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-134 104	Rms 13 & 14 Bldg Attic Classroom 14	Manual	9/23/2025 4:15:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-025 100	Rms 13 & 14 Bldg Classrm 14 Storage	Manual	9/23/2025 4:48:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-027 096	Rms 13 & 14 Bldg Classroom 13	Manual	9/23/2025 4:47:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-077 097	Rms 13 & 14 Bldg Classroom 13	Manual	9/23/2025 4:47:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-026 099	Rms 13 & 14 Bldg Classroom 14	Manual	9/23/2025 4:48:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-078 098	Rms 13 & 14 Bldg Classroom 14	Manual	9/23/2025 4:48:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-136 117	Rms 15 & 16 Bldg Attic Classroom 15	Manual	9/23/2025 4:23:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-136 116	Rms 15 & 16 Bldg Attic Classroom 15	Manual	9/23/2025 4:23:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-136 115	Rms 15 & 16 Bldg Attic Classroom 15	Manual	9/23/2025 4:23:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-137 118	Rms 15 & 16 Bldg Attic Classroom 16	Manual	9/23/2025 5:30:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-137 119	Rms 15 & 16 Bldg Attic Classroom 16	Manual	9/23/2025 5:30:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-137 120	Rms 15 & 16 Bldg Attic Classroom 16	Manual	9/23/2025 5:30:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-030 112	Rms 15 & 16 Bldg Classrm 15 Storage	Manual	9/23/2025 4:46:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-031 110	Rms 15 & 16 Bldg Classroom 15	Manual	9/23/2025 4:45:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-079 111	Rms 15 & 16 Bldg Classroom 15	Manual	9/23/2025 4:46:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-032 113	Rms 15 & 16 Bldg Classroom 16	Manual	9/23/2025 4:44:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-033 114	Rms 15 & 16 Bldg Classroom 16	Manual	9/23/2025 4:45:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-133 135	Rms 17-20 Bldg Attic Classroom 17	Manual	9/23/2025 3:55:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-133 134	Rms 17-20 Bldg Attic Classroom 17	Manual	9/23/2025 3:55:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-133 133	Rms 17-20 Bldg Attic Classroom 17	Manual	9/23/2025 3:55:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-132 138	Rms 17-20 Bldg Attic Classroom 18	Manual	9/23/2025 4:00:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-132 137	Rms 17-20 Bldg Attic Classroom 18	Manual	9/23/2025 4:00:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-132 136	Rms 17-20 Bldg Attic Classroom 18	Manual	9/23/2025 4:00:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-131 141	Rms 17-20 Bldg Attic Classroom 19	Manual	9/23/2025 4:11:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-131 140	Rms 17-20 Bldg Attic Classroom 19	Manual	9/23/2025 4:11:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-131 139	Rms 17-20 Bldg Attic Classroom 19	Manual	9/23/2025 4:11:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-130 142	Rms 17-20 Bldg Attic Classroom 20	Manual	9/23/2025 4:06:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-130 143	Rms 17-20 Bldg Attic Classroom 20	Manual	9/23/2025 4:06:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-130 144	Rms 17-20 Bldg Attic Classroom 20	Manual	9/23/2025 4:06:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-022 124	Rms 17-20 Bldg Classroom 17	Manual	9/23/2025 4:54:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-028 125	Rms 17-20 Bldg Classroom 17	Manual	9/23/2025 4:54:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-024 126	Rms 17-20 Bldg Classroom 18	Manual	9/23/2025 4:02:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-021 127	Rms 17-20 Bldg Classroom 18	Manual	9/23/2025 4:55:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-020 128	Rms 17-20 Bldg Classroom 19	Manual	9/23/2025 4:51:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-023 129	Rms 17-20 Bldg Classroom 19	Manual	9/23/2025 4:52:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-019 130	Rms 17-20 Bldg Classroom 20	Manual	9/23/2025 4:06:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-018 131	Rms 17-20 Bldg Classroom 20	Manual	9/23/2025 4:52:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-068 249	Snack Shack Bldg Boys Restroom	Manual	9/23/2025 5:07:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-069 250	Snack Shack Bldg Girls Restroom	Manual	9/23/2025 5:05:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-066 252	Snack Shack Bldg Storage North	Manual	9/23/2025 5:03:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-067 251	Snack Shack Bldg Storage South	Manual	9/23/2025 5:04:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-386 226	Multi-Purpose Bldg Attic Kitchen	Manual	9/23/2025 5:15:55 PM
Smoke Detector - General	2-276 218	Multi-Purpose Bldg Kitchen Storage	Manual	9/23/2025 4:56:58 PM
Smoke Detector - General	2-072 132	Rms 17-20 Bldg Classrm 20 Storage	Manual	9/23/2025 5:31:50 PM

Failed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Valve Tamper Switch	2-392 232	Multi-Purpose Bldg OS&Y	Manual	9/23/2025 5:21:34 PM
		Manufacturer	System sensor	
		Model	OSY2	
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	
Valve Tamper Switch	2-392 233	Multi-Purpose Bldg OS&Y	Manual	9/23/2025 5:22:21 PM
		Manufacturer	Potter	
		Model	OSYSU2	
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	
Valve Tamper Switch	2-392 231	Multi-Purpose Bldg PIV	Manual	9/23/2025 5:23:07 PM
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	

Device/Equipment details

Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Audible					
026	Building A North Exterior				
027	Building A East Exterior				
028	Building A South Exterior				
055	Building B South Exterior				
056	Building B East Exterior				
057	Building B Outside Room B5				
082	Building C East Exterior				
083	Building C West Exterior				
084	Building C Outside Room C10				
107	Rms 13 & 14 Bldg West Exterior				
121	Rms 15 & 16 Bldg East Exterior				
145	Rms 17-20 Bldg North Exterior				
146	Rms 17-20 Bldg East Exterior				
147	Rms 17-20 Bldg South Exterior				
148	Rms 17-20 Bldg West Exterior				
178	Portables Outside Classrm 22B				
179	Portables Outside Classrm 23				
180	Portables Outside Classrm 24				
181	Portables Outside Classrm 26				
234	Multi-Purpose Bldg North Exterior				
235	Multi-Purpose Bldg East Exterior				
236	Multi-Purpose Bldg West Exterior				
248	Multi-Purpose Bldg South Exterior				
253	Snack Shack Bldg East Exterior				
Audible And Visible					
029	Building A Admin Office				
030	Building A Admin Storage W				
031	Building A Nurse Office				
032	Building A Admin Principal Office				
033	Building A Classroom A1				
034	Building A Classroom A2				
035	Building A A Pod Work Room				
036	Building A Custodial Closet				
058	Building B Classroom B1				
059	Building B Classroom B2				
060	Building B Classroom B3				
061	Building B Classroom B4				
062	Building B Classroom B5				
063	Building B Classroom B6				
064	Building B Learning Center				
085	Building C Classroom C7				
086	Building C Classroom C8				
087	Building C Classroom C9				
088	Building C Classroom C10				
089	Building C Classroom C11				
090	Building C Classroom C12				
091	Building C Speech Room				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
108	Rms 13 & 14 Bldg Classroom 13				
109	Rms 13 & 14 Bldg Classroom 14				
122	Rms 15 & 16 Bldg Classroom 15				
123	Rms 15 & 16 Bldg Classroom 16				
149	Rms 17-20 Bldg Classroom 17				
150	Rms 17-20 Bldg Classroom 18				
151	Rms 17-20 Bldg Classroom 19				
152	Rms 17-20 Bldg Classroom 20				
182	Portables Classroom 21				
183	Portables Classroom 21A				
184	Portables Classroom 22A				
185	Portables Classroom 22B				
186	Portables Classroom 23				
187	Portables Classroom 24				
188	Portables Classroom 25				
189	Portables Classroom 26				
237	Multi-Purpose Bldg MP Room				
238	Multi-Purpose Bldg MP Room				
239	Multi-Purpose Bldg MP Room				
240	Multi-Purpose Bldg MP Room				
241	Multi-Purpose Bldg Stage Hall East				
242	Multi-Purpose Bldg Stage				
243	Multi-Purpose Bldg Cust Office Hall				
244	Multi-Purpose Bldg Kitchen				
245	Multi-Purpose Bldg Restroom Hallway				
Visible					
037	Building A Admin Nurse RR				
038	Building A Boys RR in Work Rm				
039	Building A Girls RR in Work Rm				
065	Building B Girls Restroom				
066	Building B Boys Restroom				
092	Building C Girls Restroom				
093	Building C Boys Restroom				
094	Building C Staff RR by Rm C9				
095	Building C Staff RR by Rm C12				
246	Multi-Purpose Bldg Womens Restroom				
247	Multi-Purpose Bldg Mens Restroom				
254	Snack Shack Bldg Boys Restroom				
255	Snack Shack Bldg Girls Restroom				
Fire Control Panel					
ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Remote Annunciator					
001	Building A Admin Office				
Fire Alarm Panel					
	Building A Electrical Room	EST		3	
NAC Power Extender Panel					
	Building A Electrical Room - P.E. "B"				
	Building B Art Room/Storage - P.E. "D"				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
	Building C Work Room - P.E. "E"				
	Rms 17-20 Bldg Classroom 20 - P.E. "C"				
	Multi-Purpose Bldg Electrical Room - P.E. "F"				
	Multi-Purpose Bldg Electrical Room - P.E. "G"				

Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Manual Pull Station					
2-139 002	Building A Admin Office				
2-409 190	Multi-Purpose Bldg MP Room NW				
2-413 191	Multi-Purpose Bldg MP Room NE				
2-412 192	Multi-Purpose Bldg MP Room SE				
2-411 193	Multi-Purpose Bldg Kitchen				
2-410 194	Multi-Purpose Bldg Restroom Hallway				
Smoke Detector - General					
2-015 003	Building A Admin Office				
2-014 004	Building A Admin Storage W				
2-013 005	Building A Nurse Office				
2-080 006	Building A Nurse Office				
2-012 007	Building A Admin Nurse RR				
2-016 008	Building A Admin Principal Office				
2-081 009	Building A Electrical Room				
2-001 010	Building A Electrical Room				
2-002 011	Building A Electrical Room				
2-004 012	Building A Classroom A1				
2-003 013	Building A Classroom A1				
2-090 014	Building A Classroom A1				
2-007 015	Building A A Pod Work Room				
2-005 016	Building A Boys RR in Work Rm				
2-006 017	Building A Girls RR in Work Rm				
2-009 018	Building A Classroom A2				
2-008 019	Building A Classroom A2				
2-091 020	Building A Classroom A2				
2-038 040	Building B Classroom B1				
2-039 041	Building B Cust Closet by B1				
2-040 042	Building B Girls Restroom				
2-041 043	Building B Classroom B2				
2-042 044	Building B Staff Restroom				
2-043 045	Building B Learning Center				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-044 046	Building B Classroom B3				
2-047 047	Building B Boys Restroom				
2-046 048	Building B Custodial Closet				
2-045 049	Building B Classroom B4				
2-049 050	Building B Classroom B5				
2-035 051	Building B Art Room/Storage				
2-036 052	Building B Classroom B6				
2-056 067	Building C Classroom C7				
2-057 068	Building C Custodial Closet				
2-058 069	Building C Girls Restroom				
2-059 070	Building C Classroom C8				
2-060 071	Building C Staff RR by Rm C9				
2-061 072	Building C Speech Room				
2-075 073	Building C Classroom C9				
2-063 074	Building C Classroom C10				
2-051 075	Building C Work Room				
2-052 076	Building C Classroom C11				
2-053 077	Building C Boys Restroom				
2-076 078	Building C Staff RR by Rm C12				
2-054 079	Building C Classroom C12				
2-027 096	Rms 13 & 14 Bldg Classroom 13				
2-077 097	Rms 13 & 14 Bldg Classroom 13				
2-078 098	Rms 13 & 14 Bldg Classroom 14				
2-026 099	Rms 13 & 14 Bldg Classroom 14				
2-025 100	Rms 13 & 14 Bldg Classrm 14 Storage				
2-031 110	Rms 15 & 16 Bldg Classroom 15				
2-079 111	Rms 15 & 16 Bldg Classroom 15				
2-030 112	Rms 15 & 16 Bldg Classrm 15 Storage				
2-032 113	Rms 15 & 16 Bldg Classroom 16				
2-033 114	Rms 15 & 16 Bldg Classroom 16				
2-022 124	Rms 17-20 Bldg Classroom 17				
2-028 125	Rms 17-20 Bldg Classroom 17				
2-024 126	Rms 17-20 Bldg Classroom 18				
2-021 127	Rms 17-20 Bldg Classroom 18				
2-020 128	Rms 17-20 Bldg Classroom 19				
2-023 129	Rms 17-20 Bldg Classroom 19				
2-019 130	Rms 17-20 Bldg Classroom 20				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-018 131	Rms 17-20 Bldg Classroom 20				
2-072 132	Rms 17-20 Bldg Classrm 20 Storage				
2-316 153	Portables Classroom 21				
2-317 154	Portables Classroom 21				
2-318 155	Portables Classroom 21A				
2-320 156	Portables Classroom 22A				
2-319 157	Portables Classroom 22B				
2-253 158	Portables Classroom 23				
2-254 159	Portables Classroom 23				
2-269 160	Portables Classroom 24				
2-268 161	Portables Classroom 24				
2-267 162	Portables Classroom 25				
2-266 163	Portables Classroom 25				
2-264 164	Portables Classroom 26				
2-265 165	Portables Classroom 26				
2-280 195	Multi-Purpose Bldg MP Room				
2-279 196	Multi-Purpose Bldg MP Room				
2-278 197	Multi-Purpose Bldg MP Room				
2-283 198	Multi-Purpose Bldg MP Room				
2-282 199	Multi-Purpose Bldg MP Room				
2-281 200	Multi-Purpose Bldg MP Room				
2-286 201	Multi-Purpose Bldg MP Room				
2-285 202	Multi-Purpose Bldg MP Room				
2-284 203	Multi-Purpose Bldg MP Room				
2-289 204	Multi-Purpose Bldg MP Room				
2-288 205	Multi-Purpose Bldg MP Room				
2-287 206	Multi-Purpose Bldg MP Room				
2-271 207	Multi-Purpose Bldg Electrical Room				
2-314 208	Multi-Purpose Bldg Stage Hall East				
2-313 209	Multi-Purpose Bldg Stage				
2-312 210	Multi-Purpose Bldg Stage				
2-315 211	Multi-Purpose Bldg Stage East Storage				
2-310 212	Multi-Purpose Bldg Cust Office Hall				
2-311 213	Multi-Purpose Bldg Custodian Office				
2-274 214	Multi-Purpose Bldg Restroom Hallway				
2-272 215	Multi-Purpose Bldg Womens Restroom				
2-273 216	Multi-Purpose Bldg Mens Restroom				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-277 217	Multi-Purpose Bldg Custodial Storage				
2-276 218	Multi-Purpose Bldg Kitchen Storage				
2-068 249	Snack Shack Bldg Boys Restroom				
2-069 250	Snack Shack Bldg Girls Restroom				
2-067 251	Snack Shack Bldg Storage South				
2-066 252	Snack Shack Bldg Storage North				
Heat Detector - Restorable Spot					
2-071 021	Building A Nurse Storage				
2-011 022	Building A Admin Storage N				
2-138 023	Building A Custodial Closet				
2-140 024	Building A Attic Classroom A1				
2-141 025	Building A Attic Classroom A2				
2-126 053	Building B SW Hall Exit				
2-127 054	Building B NE Hall Exit				
2-129 080	Building C East Hall Exit				
2-128 081	Building C West Hall Exit				
2-135 101	Rms 13 & 14 Bldg Attic Classroom 13				
2-135 102	Rms 13 & 14 Bldg Attic Classroom 13				
2-135 103	Rms 13 & 14 Bldg Attic Classroom 13				
2-134 104	Rms 13 & 14 Bldg Attic Classroom 14				
2-134 105	Rms 13 & 14 Bldg Attic Classroom 14				
2-134 106	Rms 13 & 14 Bldg Attic Classroom 14				
2-136 115	Rms 15 & 16 Bldg Attic Classroom 15				
2-136 116	Rms 15 & 16 Bldg Attic Classroom 15				
2-136 117	Rms 15 & 16 Bldg Attic Classroom 15				
2-137 118	Rms 15 & 16 Bldg Attic Classroom 16				
2-137 119	Rms 15 & 16 Bldg Attic Classroom 16				
2-137 120	Rms 15 & 16 Bldg Attic Classroom 16				
2-133 133	Rms 17-20 Bldg Attic Classroom 17				
2-133 134	Rms 17-20 Bldg Attic Classroom 17				
2-133 135	Rms 17-20 Bldg Attic Classroom 17				
2-132 136	Rms 17-20 Bldg Attic Classroom 18				
2-132 137	Rms 17-20 Bldg Attic Classroom 18				
2-132 138	Rms 17-20 Bldg Attic Classroom 18				
2-131 139	Rms 17-20 Bldg Attic Classroom 19				
2-131 140	Rms 17-20 Bldg Attic Classroom 19				
2-131 141	Rms 17-20 Bldg Attic Classroom 19				
2-130 142	Rms 17-20 Bldg Attic Classroom 20				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-130 143	Rms 17-20 Bldg Attic Classroom 20				
2-130 144	Rms 17-20 Bldg Attic Classroom 20				
2-414 166	Portables Attic Classroom 21				
2-414 167	Portables Attic Classroom 21				
2-415 168	Portables Attic Classroom 22A				
2-415 169	Portables Attic Classroom 22B				
2-376 170	Portables Attic Classroom 23				
2-376 171	Portables Attic Classroom 23				
2-381 172	Portables Attic Classroom 24				
2-381 173	Portables Attic Classroom 24				
2-380 174	Portables Attic Classroom 25				
2-380 175	Portables Attic Classroom 25				
2-379 176	Portables Attic Classroom 26				
2-379 177	Portables Attic Classroom 26				
2-275 219	Multi-Purpose Bldg Kitchen				
2-387 220	Multi-Purpose Bldg Subfloor Stage				
2-390 221	Multi-Purpose Bldg Attic Stage Hall East				
2-388 222	Multi-Purpose Bldg Attic Stage Hall West				
2-385 223	Multi-Purpose Bldg Attic Restroom Hall				
2-383 224	Multi-Purpose Bldg Attic Womens RR				
2-384 225	Multi-Purpose Bldg Attic Mens RR				
2-386 226	Multi-Purpose Bldg Attic Kitchen				
Smoke Detector - Duct					
2-378 227	Multi-Purpose Bldg Stage East				
2-377 228	Multi-Purpose Bldg MP Room West				
Mechanical, Electrosonic, or Pressure Waterflow Device					
2-391 230	Multi-Purpose Bldg Custodian Office				
Valve Tamper Switch					
2-392 231	Multi-Purpose Bldg PIV				
2-392 232	Multi-Purpose Bldg OS&Y	System sensor	OSY2		
2-392 233	Multi-Purpose Bldg OS&Y	Potter	OSYSU2		