

Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

DEL CAMPO HIGH

4925 Dewey Drive
CARMICHAEL, California
United States

This site has been inspected and tested in compliance with applicable standards.

Completed

Wednesday, November 19, 2025

Test Session: 10 Nov 2025 08:20 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD
5320 HEMLOCK ST
SACRAMENTO, California
United States

TESTED BY

Riley Goyet
Western States Fire Protection-
Sacramento
188 Cirby Way
Roseville, CA 95678
United States



Inspection Summary

Building Information

PROPERTY	DEL CAMPO HIGH	CONTACT
ADDRESS	4925 Dewey Drive	PHONE
CITY/STATE	CARMICHAEL, California	MOBILE
COUNTRY	United States	EMAIL

Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us

Testing Summary


EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
[Other]	1	0(0%)	0(0%)	0(0%)
Alarm Notification Appliance	281	281(100%)	281(100%)	0(0%)
Ventilation and Cooking Equipment	6	0(0%)	0(0%)	0(0%)
Fire Control Panel	15	15(100%)	15(100%)	0(0%)
Initiating Device	547	505(92%)	503(92%)	2(0%)

Certification

The equipment specified here in was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Wednesday, November 19, 2025

ACCEPTED BY 11/19/2025

Building Representative


TESTED BY 11/19/2025
Riley Goyet
Technician

System Details

Control Units

ADDRESS/ SCAN ADDRESS	DESCRIPTION	Admin Building Data Rm/Headend
MANUFACTURER	S/W VERSION	
MODEL	LAST UPDATE	
SERIAL NUMBER	S/W LOCATION	
INSTALL DATE		


Open Corrective Action & Solution Summary

The following 5 corrective action(s) remain open following the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
Smoke Detector - General	1-3-277 270	Rooms 44-53 Bldg Classroom 51
	Created By:	Riley Goyet
	Creation Date:	01/09/2025
	Corrective Action:	Covered
	Proposed Solution:	
	Manufacturer:	
	Model:	
	Created By:	Riley Goyet
	Creation Date:	11/10/2025
	Corrective Action:	Taped
	Proposed Solution:	
	Manufacturer:	
	Model:	

Smoke Detector - General	1-3-278 271	Rooms 44-53 Bldg Classroom 51
	Created By:	Riley Goyet
	Creation Date:	01/09/2025
	Corrective Action:	Covered
	Proposed Solution:	
	Manufacturer:	
	Model:	
	Created By:	Riley Goyet
	Creation Date:	11/10/2025
	Corrective Action:	Taped
	Proposed Solution:	
	Manufacturer:	
	Model:	

Range Suppression		101-20 Cartridge
	Created By:	Casey Smith
	Creation Date:	09/03/2025
	Corrective Action:	Cartridge is too small for flow points on system.
	Proposed Solution:	Replace 101-20 cartridge with LT30R cartridge
	Manufacturer:	
	Model:	



Resolved Corrective Action & Solution Summary

The following 12 corrective action(s) were resolved during the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
Smoke Detector - General	1-2-068 100	Rooms 9-15 Bldg Classroom 11
	Created By:	Riley Goyet
	Creation Date:	01/09/2025
	Corrective Action:	Covered
	Resolution:	
	Resolved By:	Riley Goyet
	Resolved On:	11/11/2025
	Manufacturer:	
	Model:	
Smoke Detector - General	1-2-067 101	Rooms 9-15 Bldg Classroom 11
	Created By:	Riley Goyet
	Creation Date:	01/09/2025
	Corrective Action:	Covered
	Resolution:	
	Resolved By:	Riley Goyet
	Resolved On:	11/11/2025
	Manufacturer:	
	Model:	
Smoke Detector - General	1-2-064 102	Rooms 9-15 Bldg Room 12
	Created By:	Riley Goyet
	Creation Date:	01/09/2025
	Corrective Action:	Covered
	Resolution:	
	Resolved By:	Riley Goyet
	Resolved On:	11/11/2025
	Manufacturer:	
	Model:	
Smoke Detector - General	1-2-063 103	Rooms 9-15 Bldg Room 12A Storage
	Created By:	Riley Goyet
	Creation Date:	01/09/2025
	Corrective Action:	Covered
	Resolution:	
	Resolved By:	Riley Goyet
	Resolved On:	11/11/2025
	Manufacturer:	
	Model:	
Smoke Detector - General	1-2-072 104	Rooms 9-15 Bldg Classroom 13
	Created By:	Riley Goyet
	Creation Date:	01/09/2025
	Corrective Action:	Covered
	Resolution:	
	Resolved By:	Riley Goyet
	Resolved On:	11/11/2025
	Manufacturer:	
	Model:	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
Smoke Detector - General	1-2-071 105	Rooms 9-15 Bldg Classroom 13
	Created By:	Riley Goyet
	Creation Date:	01/09/2025
	Corrective Action:	Covered
	Resolution:	
	Resolved By:	Riley Goyet
	Resolved On:	11/11/2025
	Manufacturer:	
	Model:	
Smoke Detector - General	1-3-269 259	Rooms 44-53 Bldg Dark Room 47
	Created By:	Riley Goyet
	Creation Date:	01/09/2025
	Corrective Action:	Covered
	Resolution:	
	Resolved By:	Riley Goyet
	Resolved On:	11/10/2025
	Manufacturer:	
	Model:	
Smoke Detector - General	1-3-270 260	Rooms 44-53 Bldg Dark Room 47
	Created By:	Riley Goyet
	Creation Date:	01/09/2025
	Corrective Action:	Covered
	Resolution:	
	Resolved By:	Riley Goyet
	Resolved On:	11/10/2025
	Manufacturer:	
	Model:	
Smoke Detector - General	1-3-088 374	Rooms 62-69 Bldg Classroom 64
	Created By:	Riley Goyet
	Creation Date:	01/09/2025
	Corrective Action:	Covered
	Resolution:	
	Resolved By:	Riley Goyet
	Resolved On:	11/10/2025
	Manufacturer:	
	Model:	
Smoke Detector - General	1-3-089 375	Rooms 62-69 Bldg Classroom 65
	Created By:	Riley Goyet
	Creation Date:	01/09/2025
	Corrective Action:	Covered
	Resolution:	
	Resolved By:	Riley Goyet
	Resolved On:	11/10/2025
	Manufacturer:	
	Model:	
Smoke Detector - General	1-3-093 378	Rooms 62-69 Bldg Classroom 67
	Created By:	Riley Goyet
	Creation Date:	01/09/2025
	Corrective Action:	Covered

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
	Resolution: Resolved By: Resolved On: Manufacturer: Model:	Riley Goyet 11/10/2025

Smoke Detector - General	1-3-092 379	Rooms 62-69 Bldg Classroom 68
	Created By: Creation Date: Corrective Action: Resolution: Resolved By: Resolved On: Manufacturer: Model:	Riley Goyet 01/09/2025 Covered Riley Goyet 11/10/2025

Testing Details

[Other]

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
[Other]	1-2-149 520	Cafeteria Building Kitchen Ansul System	Manual	11/12/2025 7:04:30 PM

Alarm Notification Appliance

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	051	Admin Building Classroom 3	Manual	11/11/2025 7:31:35 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	050	Admin Building Conference Room	Manual	11/11/2025 7:31:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	046	Admin Building East Exterior	Manual	11/11/2025 7:34:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	061	Admin Building Off NE Conf Office	Manual	11/11/2025 7:28:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	060	Admin Building Off NW Conf Office	Manual	11/11/2025 7:28:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	048	Admin Building Off Recept N Hall	Manual	11/11/2025 7:31:33 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	054	Admin Building Off Recept N Office	Manual	11/11/2025 7:27:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	069	Admin Building Off Recept Work Rm	Manual	11/11/2025 7:28:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	057	Admin Building Off Small Office 1	Manual	11/11/2025 7:34:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	056	Admin Building Off Small Office 2	Manual	11/11/2025 7:27:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	067	Admin Building Office Mens RR	Manual	11/11/2025 7:28:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	058	Admin Building Office Nurse	Manual	11/11/2025 7:27:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	059	Admin Building Office Nurse Restrm	Manual	11/11/2025 7:27:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	052	Admin Building Office Principal	Manual	11/11/2025 7:27:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	055	Admin Building Office Printer Room	Manual	11/11/2025 7:27:54 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	047	Admin Building Office Reception	Manual	11/11/2025 7:31:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	053	Admin Building Office Reception RR	Manual	11/11/2025 7:27:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	062	Admin Building Office S Conf Office	Manual	11/11/2025 7:28:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	063	Admin Building Office S Conf Office	Manual	11/11/2025 7:28:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	065	Admin Building Office S Conf Office	Manual	11/11/2025 7:28:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	064	Admin Building Office S Conf Office	Manual	11/11/2025 7:28:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	066	Admin Building Office South Hall	Manual	11/11/2025 7:28:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	049	Admin Building Office Staff Room	Manual	11/11/2025 7:31:32 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	068	Admin Building Office Womens RR	Manual	11/11/2025 7:28:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	528	Cafeteria Building Boys Restroom	Manual	11/11/2025 7:26:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	527	Cafeteria Building Boys Restroom	Manual	11/11/2025 7:26:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	521	Cafeteria Building Cafeteria	Manual	11/11/2025 7:26:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	522	Cafeteria Building Cafeteria	Manual	11/11/2025 7:26:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	529	Cafeteria Building Girls Restroom	Manual	11/11/2025 7:26:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	530	Cafeteria Building Girls Restroom	Manual	11/11/2025 7:26:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	525	Cafeteria Building Hallway	Manual	11/11/2025 7:26:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	524	Cafeteria Building Hallway	Manual	11/11/2025 7:26:54 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	523	Cafeteria Building Kitchen	Manual	11/11/2025 7:26:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible	531	Cafeteria Building Mens Restroom	Manual	11/11/2025 7:26:28 AM
		Visual inspection	Passed (Manual)	
Visible	539	Cafeteria Building VP Boys Restroom	Manual	11/11/2025 7:26:37 AM
		Visual inspection	Passed (Manual)	
Visible	540	Cafeteria Building VP Boys Restroom	Manual	11/11/2025 7:26:44 AM
		Visual inspection	Passed (Manual)	
Visible	541	Cafeteria Building VP Girls Restroom	Manual	11/11/2025 7:26:42 AM
		Visual inspection	Passed (Manual)	
Visible	542	Cafeteria Building VP Girls Restroom	Manual	11/11/2025 7:26:45 AM
		Visual inspection	Passed (Manual)	
Visible	533	Cafeteria Building VP Office	Manual	11/11/2025 7:26:30 AM
		Visual inspection	Passed (Manual)	
Visible	534	Cafeteria Building VP Office Room 1	Manual	11/11/2025 7:26:33 AM
		Visual inspection	Passed (Manual)	
Visible	535	Cafeteria Building VP Office Room 2	Manual	11/11/2025 7:26:34 AM
		Visual inspection	Passed (Manual)	
Visible	536	Cafeteria Building VP Office Room 3	Manual	11/11/2025 7:26:35 AM
		Visual inspection	Passed (Manual)	
Visible	537	Cafeteria Building VP Office Room 4	Manual	11/11/2025 7:26:40 AM
		Visual inspection	Passed (Manual)	
Visible	538	Cafeteria Building VP Office Room 5	Manual	11/11/2025 7:26:39 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	526	Cafeteria Building VP Reception	Manual	11/11/2025 7:26:55 AM
		Visual inspection	Passed (Manual)	
Visible	532	Cafeteria Building Womens Restroom	Manual	11/11/2025 7:26:31 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	186	Classroom 31 Area Classroom 31	Manual	11/11/2025 7:31:38 AM
		Visual inspection	Passed (Manual)	
Visible	187	Classroom 31 Area Mens RR by Rm 31	Manual	11/11/2025 7:28:15 AM
		Visual inspection	Passed (Manual)	
Audible	185	Classroom 31 Area South Exterior	Manual	11/11/2025 7:31:29 AM
		Visual inspection	Passed (Manual)	
Visible	188	Classroom 31 Area Unisex RR by Rm 31	Manual	11/11/2025 7:28:17 AM
		Visual inspection	Passed (Manual)	
Visible	189	Classroom 31 Area Wom RR by Rm 31	Manual	11/11/2025 7:28:18 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	366	Classroom 61 Bldg Classroom 61	Manual	11/11/2025 7:33:21 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	367	Classroom 61 Bldg Classroom 61 Office	Manual	11/11/2025 7:33:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	364	Classroom 61 Bldg West Exterior	Manual	11/11/2025 7:33:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	365	Classroom 61 Bldg West Exterior	Manual	11/11/2025 7:33:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	559	Custodial Building East Exterior	Manual	11/11/2025 7:31:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	562	Custodial Building Office	Manual	11/11/2025 7:28:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	563	Custodial Building Restroom	Manual	11/11/2025 7:28:33 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	561	Custodial Building Staff Room 1	Manual	11/11/2025 7:32:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	560	Custodial Building West Exterior	Manual	11/11/2025 7:31:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	827	Large Gym Boys Locker Rm Off	Manual	11/11/2025 7:29:33 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	805	Large Gym Boys Locker Room	Manual	11/11/2025 7:33:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	806	Large Gym Boys Locker Room	Manual	11/11/2025 7:33:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	821	Large Gym Boys Locker Room	Manual	11/11/2025 7:29:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	824	Large Gym Boys Locker Room	Manual	11/11/2025 7:29:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	822	Large Gym Boys Locker Room	Manual	11/11/2025 7:29:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	823	Large Gym Boys Locker Room	Manual	11/11/2025 7:29:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	826	Large Gym Boys Locker Room	Manual	11/11/2025 7:29:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	825	Large Gym Boys Locker Room	Manual	11/11/2025 7:29:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	820	Large Gym Coaches Off Shower	Manual	11/11/2025 7:29:20 AM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Visible	817	Large Gym Coaches Office	Manual	11/11/2025 7:29:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	816	Large Gym Coaches Office	Manual	11/11/2025 7:29:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	819	Large Gym Coaches Office RR	Manual	11/11/2025 7:29:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	818	Large Gym Coaches Office RR	Manual	11/11/2025 7:29:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	789	Large Gym East Exterior	Manual	11/11/2025 7:31:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	815	Large Gym Girls Locker Office	Manual	11/11/2025 7:29:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	804	Large Gym Girls Locker Room	Manual	11/11/2025 7:33:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	803	Large Gym Girls Locker Room	Manual	11/11/2025 7:33:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	810	Large Gym Girls Locker Room	Manual	11/11/2025 7:29:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	809	Large Gym Girls Locker Room	Manual	11/11/2025 7:29:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	814	Large Gym Girls Locker Room	Manual	11/11/2025 7:29:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	813	Large Gym Girls Locker Room	Manual	11/11/2025 7:29:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	812	Large Gym Girls Locker Room	Manual	11/11/2025 7:29:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	811	Large Gym Girls Locker Room	Manual	11/11/2025 7:29:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	801	Large Gym Gym Stage	Manual	11/11/2025 7:33:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	802	Large Gym Gym Stage	Manual	11/11/2025 7:33:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	799	Large Gym Large Gym	Manual	11/11/2025 7:32:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	798	Large Gym Large Gym	Manual	11/11/2025 7:33:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	797	Large Gym Large Gym	Manual	11/11/2025 7:33:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	800	Large Gym Large Gym	Manual	11/11/2025 7:33:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	796	Large Gym Locker Room Hall	Manual	11/11/2025 7:32:33 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	795	Large Gym Locker Room Hall	Manual	11/11/2025 7:32:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	794	Large Gym Locker Room Hall	Manual	11/11/2025 7:33:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	829	Large Gym Music Room 1	Manual	11/11/2025 7:29:32 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	830	Large Gym Music Room 2	Manual	11/11/2025 7:29:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	807	Large Gym Music Room 92	Manual	11/11/2025 7:33:16 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	808	Large Gym Music Room 93	Manual	11/11/2025 7:33:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	828	Large Gym Music Room Hall	Manual	11/11/2025 7:29:35 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	831	Large Gym Northeast Exterior	Manual	11/11/2025 7:31:20 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	791	Large Gym South Exterior	Manual	11/11/2025 7:31:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	790	Large Gym South Exterior	Manual	11/11/2025 7:31:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	792	Large Gym West Exterior	Manual	11/11/2025 7:31:19 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	793	Large Gym West Exterior	Manual	11/11/2025 7:31:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	224	Library Building Book Room	Manual	11/11/2025 7:27:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	225	Library Building Classroom 32	Manual	11/11/2025 7:27:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	226	Library Building Classroom 33	Manual	11/11/2025 7:27:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	227	Library Building Classroom 38	Manual	11/11/2025 7:27:45 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	228	Library Building Classroom 39	Manual	11/11/2025 7:27:44 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	222	Library Building Computer Lab	Manual	11/11/2025 7:27:39 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	217	Library Building East Exterior	Manual	11/11/2025 7:27:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	221	Library Building Library	Manual	11/11/2025 7:27:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	220	Library Building Library	Manual	11/11/2025 7:27:38 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	218	Library Building South Exterior	Manual	11/11/2025 7:27:35 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	219	Library Building West Exterior	Manual	11/11/2025 7:27:32 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	223	Library Building Work Room	Manual	11/11/2025 7:27:42 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	139	Rooms 16-23 Bldg Classroom 16	Manual	11/11/2025 7:26:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	140	Rooms 16-23 Bldg Classroom 17	Manual	11/11/2025 7:26:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	141	Rooms 16-23 Bldg Classroom 18	Manual	11/11/2025 7:26:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	142	Rooms 16-23 Bldg Classroom 19	Manual	11/11/2025 7:26:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	143	Rooms 16-23 Bldg Classroom 20	Manual	11/11/2025 7:26:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	144	Rooms 16-23 Bldg Classroom 21	Manual	11/11/2025 7:26:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	145	Rooms 16-23 Bldg Classroom 22	Manual	11/11/2025 7:26:16 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	146	Rooms 16-23 Bldg Classroom 23	Manual	11/11/2025 7:26:20 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	137	Rooms 16-23 Bldg Southeast Exterior	Manual	11/11/2025 7:26:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	136	Rooms 16-23 Bldg Southeast Exterior	Manual	11/11/2025 7:26:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible	138	Rooms 16-23 Bldg West Exterior	Manual	11/11/2025 7:26:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	090	Rooms 1-8 Bldg Classroom 1	Manual	11/11/2025 7:27:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	091	Rooms 1-8 Bldg Classroom 2	Manual	11/11/2025 7:27:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	092	Rooms 1-8 Bldg Classroom 3	Manual	11/11/2025 7:27:20 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	093	Rooms 1-8 Bldg Classroom 4	Manual	11/11/2025 7:27:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	094	Rooms 1-8 Bldg Classroom 5	Manual	11/11/2025 7:27:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	095	Rooms 1-8 Bldg Classroom 6	Manual	11/11/2025 7:27:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	096	Rooms 1-8 Bldg Classroom 7	Manual	11/11/2025 7:27:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	097	Rooms 1-8 Bldg Classroom 8	Manual	11/11/2025 7:27:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	087	Rooms 1-8 Bldg Northeast Exterior	Manual	11/11/2025 7:27:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	086	Rooms 1-8 Bldg Northeast Exterior	Manual	11/11/2025 7:27:16 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	088	Rooms 1-8 Bldg Southwest Exterior	Manual	11/11/2025 7:27:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	089	Rooms 1-8 Bldg Southwest Exterior	Manual	11/11/2025 7:27:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	167	Rooms 24-30 Bldg Classroom 24	Manual	11/11/2025 7:25:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	168	Rooms 24-30 Bldg Classroom 25	Manual	11/11/2025 7:25:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	169	Rooms 24-30 Bldg Classroom 26	Manual	11/11/2025 7:25:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	170	Rooms 24-30 Bldg Classroom 27	Manual	11/11/2025 7:25:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	171	Rooms 24-30 Bldg Classroom 27A	Manual	11/11/2025 7:25:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	172	Rooms 24-30 Bldg Classroom 28	Manual	11/11/2025 7:25:46 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	173	Rooms 24-30 Bldg Classroom 29	Manual	11/11/2025 7:25:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	174	Rooms 24-30 Bldg Classroom 30	Manual	11/11/2025 7:33:54 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	163	Rooms 24-30 Bldg Northwest Exterior	Manual	11/11/2025 7:25:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	164	Rooms 24-30 Bldg Northwest Exterior	Manual	11/11/2025 7:26:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	166	Rooms 24-30 Bldg Southeast Exterior	Manual	11/11/2025 7:25:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	165	Rooms 24-30 Bldg Southeast Exterior	Manual	11/11/2025 7:26:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	248	Rooms 40-43 Bldg Classroom 40	Manual	11/11/2025 7:33:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	249	Rooms 40-43 Bldg Classroom 41	Manual	11/11/2025 7:33:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	250	Rooms 40-43 Bldg Classroom 42	Manual	11/11/2025 7:33:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	251	Rooms 40-43 Bldg Classroom 43	Manual	11/11/2025 7:33:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	246	Rooms 40-43 Bldg East Exterior	Manual	11/11/2025 7:33:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	247	Rooms 40-43 Bldg West Exterior	Manual	11/11/2025 7:33:33 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	294	Rooms 44-53 Bldg Classroom 44	Manual	11/11/2025 7:31:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	295	Rooms 44-53 Bldg Classroom 45	Manual	11/11/2025 7:31:40 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	296	Rooms 44-53 Bldg Classroom 46	Manual	11/11/2025 7:31:44 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	298	Rooms 44-53 Bldg Classroom 49	Manual	11/11/2025 7:31:42 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	299	Rooms 44-53 Bldg Classroom 50	Manual	11/11/2025 7:31:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	300	Rooms 44-53 Bldg Classroom 51	Manual	11/11/2025 7:31:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	301	Rooms 44-53 Bldg Classroom 52	Manual	11/11/2025 7:31:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	302	Rooms 44-53 Bldg Classroom 53	Manual	11/11/2025 7:31:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	297	Rooms 44-53 Bldg Dark Room 47	Manual	11/11/2025 7:31:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	291	Rooms 44-53 Bldg Northeast Exterior	Manual	11/11/2025 7:29:42 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	290	Rooms 44-53 Bldg Northeast Exterior	Manual	11/11/2025 7:31:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	305	Rooms 44-53 Bldg Restrm by Rm 49	Manual	11/11/2025 7:28:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	304	Rooms 44-53 Bldg Room 48	Manual	11/11/2025 7:28:20 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	303	Rooms 44-53 Bldg ROTC Classrm 2	Manual	11/11/2025 7:31:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	306	Rooms 44-53 Bldg ROTC Office	Manual	11/11/2025 7:28:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	307	Rooms 44-53 Bldg ROTC Office	Manual	11/11/2025 7:28:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	308	Rooms 44-53 Bldg ROTC Rm 34 RR	Manual	11/11/2025 7:28:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	293	Rooms 44-53 Bldg Southwest Exterior	Manual	11/11/2025 7:29:44 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	292	Rooms 44-53 Bldg Southwest Exterior	Manual	11/11/2025 7:29:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	346	Rooms 54-60 Bldg Classrm 55 Finish Rm	Manual	11/11/2025 7:33:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	347	Rooms 54-60 Bldg Classrm 56 Finish Rm	Manual	11/11/2025 7:33:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	339	Rooms 54-60 Bldg Classroom 54	Manual	11/11/2025 7:33:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	340	Rooms 54-60 Bldg Classroom 55	Manual	11/11/2025 7:33:44 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	341	Rooms 54-60 Bldg Classroom 56	Manual	11/11/2025 7:33:40 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	342	Rooms 54-60 Bldg Classroom 57	Manual	11/11/2025 7:33:42 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	348	Rooms 54-60 Bldg Classroom 57 Tools	Manual	11/11/2025 7:33:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	343	Rooms 54-60 Bldg Classroom 58	Manual	11/11/2025 7:33:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	344	Rooms 54-60 Bldg Classroom 59	Manual	11/11/2025 7:33:36 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	345	Rooms 54-60 Bldg Classroom 60	Manual	11/11/2025 7:33:39 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	349	Rooms 54-60 Bldg Metal Shop Office	Manual	11/11/2025 7:33:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	336	Rooms 54-60 Bldg Northeast Exterior	Manual	11/11/2025 7:33:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	337	Rooms 54-60 Bldg Northeast Exterior	Manual	11/11/2025 7:33:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	338	Rooms 54-60 Bldg Southwest Exterior	Manual	11/11/2025 7:33:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	388	Rooms 62-69 Bldg Classroom 62	Manual	11/11/2025 7:31:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	396	Rooms 62-69 Bldg Classroom 62 Hall	Manual	11/11/2025 7:28:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	389	Rooms 62-69 Bldg Classroom 63	Manual	11/11/2025 7:31:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	390	Rooms 62-69 Bldg Classroom 64	Manual	11/11/2025 7:31:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	391	Rooms 62-69 Bldg Classroom 65	Manual	11/11/2025 7:31:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	392	Rooms 62-69 Bldg Classroom 66	Manual	11/11/2025 7:32:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	393	Rooms 62-69 Bldg Classroom 67	Manual	11/11/2025 7:32:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	394	Rooms 62-69 Bldg Classroom 68	Manual	11/11/2025 7:32:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	395	Rooms 62-69 Bldg Classroom 69	Manual	11/11/2025 7:32:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	385	Rooms 62-69 Bldg Northeast Exterior	Manual	11/11/2025 7:30:57 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	384	Rooms 62-69 Bldg Northeast Exterior	Manual	11/11/2025 7:30:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	386	Rooms 62-69 Bldg Southwest Exterior	Manual	11/11/2025 7:29:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	387	Rooms 62-69 Bldg Southwest Exterior	Manual	11/11/2025 7:30:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	416	Rooms 70-76 Bldg Classroom 70	Manual	11/11/2025 7:32:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	417	Rooms 70-76 Bldg Classroom 71	Manual	11/11/2025 7:32:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	418	Rooms 70-76 Bldg Classroom 72	Manual	11/11/2025 7:32:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	419	Rooms 70-76 Bldg Classroom 73	Manual	11/11/2025 7:32:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	420	Rooms 70-76 Bldg Classroom 74	Manual	11/11/2025 7:32:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	421	Rooms 70-76 Bldg Classroom 75	Manual	11/11/2025 7:32:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	422	Rooms 70-76 Bldg Classroom 76	Manual	11/11/2025 7:32:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	423	Rooms 70-76 Bldg Classroom 76A	Manual	11/11/2025 7:32:20 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	413	Rooms 70-76 Bldg Northeast Exterior	Manual	11/11/2025 7:30:44 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	412	Rooms 70-76 Bldg Northeast Exterior	Manual	11/11/2025 7:30:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	414	Rooms 70-76 Bldg Southwest Exterior	Manual	11/11/2025 7:29:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	415	Rooms 70-76 Bldg Southwest Exterior	Manual	11/11/2025 7:30:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	443	Rooms 77-83 Bldg Classroom 77	Manual	11/11/2025 7:32:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	444	Rooms 77-83 Bldg Classroom 77A	Manual	11/11/2025 7:32:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	445	Rooms 77-83 Bldg Classroom 78	Manual	11/11/2025 7:32:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	446	Rooms 77-83 Bldg Classroom 79	Manual	11/11/2025 7:32:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	447	Rooms 77-83 Bldg Classroom 80	Manual	11/11/2025 7:32:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	448	Rooms 77-83 Bldg Classroom 81	Manual	11/11/2025 7:32:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	449	Rooms 77-83 Bldg Classroom 82	Manual	11/11/2025 7:32:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	450	Rooms 77-83 Bldg Classroom 83	Manual	11/11/2025 7:32:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	440	Rooms 77-83 Bldg Northeast Exterior	Manual	11/11/2025 7:29:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	441	Rooms 77-83 Bldg Northeast Exterior	Manual	11/11/2025 7:30:54 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	442	Rooms 77-83 Bldg Southwest Exterior	Manual	11/11/2025 7:30:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	469	Rooms 84-91 Bldg Classroom 84	Manual	11/11/2025 7:32:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	470	Rooms 84-91 Bldg Classroom 85	Manual	11/11/2025 7:32:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	471	Rooms 84-91 Bldg Classroom 86	Manual	11/11/2025 7:32:40 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	472	Rooms 84-91 Bldg Classroom 87	Manual	11/11/2025 7:32:39 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	473	Rooms 84-91 Bldg Classroom 88	Manual	11/11/2025 7:33:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	474	Rooms 84-91 Bldg Classroom 89	Manual	11/11/2025 7:32:42 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	475	Rooms 84-91 Bldg Classroom 90	Manual	11/11/2025 7:32:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	476	Rooms 84-91 Bldg Classroom 91	Manual	11/11/2025 7:32:36 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	465	Rooms 84-91 Bldg Northeast Exterior	Manual	11/11/2025 7:30:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	466	Rooms 84-91 Bldg Northeast Exterior	Manual	11/11/2025 7:31:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	468	Rooms 84-91 Bldg Southwest Exterior	Manual	11/11/2025 7:31:04 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	467	Rooms 84-91 Bldg Southwest Exterior	Manual	11/11/2025 7:31:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	114	Rooms 9-15 Bldg Classroom 10	Manual	11/11/2025 7:27:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	115	Rooms 9-15 Bldg Classroom 11	Manual	11/11/2025 7:27:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	116	Rooms 9-15 Bldg Classroom 12	Manual	11/11/2025 7:27:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	117	Rooms 9-15 Bldg Classroom 13	Manual	11/11/2025 7:27:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	118	Rooms 9-15 Bldg Classroom 14	Manual	11/11/2025 7:27:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	119	Rooms 9-15 Bldg Classroom 15	Manual	11/11/2025 7:27:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	113	Rooms 9-15 Bldg Classroom 9	Manual	11/11/2025 7:27:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	112	Rooms 9-15 Bldg Southwest Exterior	Manual	11/11/2025 7:26:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	111	Rooms 9-15 Bldg Southwest Exterior	Manual	11/11/2025 7:26:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	667	Small Gym Boys Restroom	Manual	11/11/2025 7:28:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	668	Small Gym Boys Restroom	Manual	11/11/2025 7:29:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	660	Small Gym East Exterior	Manual	11/11/2025 7:31:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	670	Small Gym Girls Restroom	Manual	11/11/2025 7:29:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	669	Small Gym Girls Restroom	Manual	11/11/2025 7:29:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	659	Small Gym North Exterior	Manual	11/11/2025 7:31:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	666	Small Gym Small Gym	Manual	11/11/2025 7:32:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	663	Small Gym Small Gym	Manual	11/11/2025 7:32:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	665	Small Gym Small Gym	Manual	11/11/2025 7:32:54 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	664	Small Gym Small Gym	Manual	11/11/2025 7:32:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	661	Small Gym South Exterior	Manual	11/11/2025 7:31:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	662	Small Gym West Exterior	Manual	11/11/2025 7:31:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	865	Stadium Mens Restroom	Manual	11/11/2025 7:29:36 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	864	Stadium West Exterior	Manual	11/11/2025 7:31:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	866	Stadium Womens Restroom	Manual	11/11/2025 7:29:38 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	628	Theater Building Boys Restroom	Manual	11/11/2025 7:28:39 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	629	Theater Building Boys Restroom	Manual	11/11/2025 7:28:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	624	Theater Building Counseling	Manual	11/11/2025 7:32:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	639	Theater Building Counseling Boys RR	Manual	11/11/2025 7:28:54 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	640	Theater Building Counseling Girls RR	Manual	11/11/2025 7:28:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	632	Theater Building Counseling Office	Manual	11/11/2025 7:28:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	633	Theater Building Counseling Office 1	Manual	11/11/2025 7:28:44 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	634	Theater Building Counseling Office 2	Manual	11/11/2025 7:28:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	635	Theater Building Counseling Office 3	Manual	11/11/2025 7:28:42 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	636	Theater Building Counseling Office 4	Manual	11/11/2025 7:28:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	637	Theater Building Counseling Office 6	Manual	11/11/2025 7:28:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	638	Theater Building Counseling Office 7	Manual	11/11/2025 7:28:55 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	627	Theater Building Girls Restroom	Manual	11/11/2025 7:28:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	626	Theater Building Girls Restroom	Manual	11/11/2025 7:28:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	623	Theater Building Mens Restrm Hall	Manual	11/11/2025 7:32:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	625	Theater Building Mens Restroom	Manual	11/11/2025 7:28:35 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	621	Theater Building Theater	Manual	11/11/2025 7:32:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	622	Theater Building Theater	Manual	11/11/2025 7:32:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	630	Theater Building Womens Restrm Hall	Manual	11/11/2025 7:28:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	631	Theater Building Womens Restroom	Manual	11/11/2025 7:28:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Fire Alarm Panel		Admin Building Data Rm/Headend	Manual	11/19/2025 11:10:36 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	070	Admin Building Data Rm/Headend	Manual	11/19/2025 11:10:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Remote Annunciator	001	Admin Building Office Reception	Manual	11/12/2025 7:07:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	544	Cafeteria Building Data Room	Manual	11/19/2025 11:10:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	545	Cafeteria Building Data Room	Manual	11/19/2025 11:10:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	543	Cafeteria Building Data Room	Manual	11/19/2025 11:10:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	832	Large Gym Music Room	Manual	11/19/2025 11:10:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	229	Library Building Room 39 Workroom	Manual	11/19/2025 11:10:38 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	252	Rooms 40-43 Bldg Classroom 40	Manual	11/19/2025 11:12:33 AM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
NAC Power Extender Panel	309	Rooms 44-53 Bldg Classroom 53	Manual	11/19/2025 11:10:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	671	Small Gym Data Room	Manual	11/19/2025 11:10:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	867	Stadium Restroom Chase	Manual	11/19/2025 11:10:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	641	Theater Building Stage Storage 2	Manual	11/19/2025 11:10:32 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	642	Theater Building Stage Storage 2	Manual	11/19/2025 11:10:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	643	Theater Building Stage Storage 2	Manual	11/19/2025 11:11:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Initiating Device

Passed				
EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	1-2-380 042	Admin Building Attic N Off Conf Rm	Manual	11/19/2025 11:10:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1-2-380 041	Admin Building Attic N Off Conf Rm	Manual	11/19/2025 11:13:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1-2-381 043	Admin Building Attic S Off Conf Rm	Manual	11/19/2025 11:10:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1-2-381 044	Admin Building Attic S Off Conf Rm	Manual	11/19/2025 11:10:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-266 031	Admin Building Classroom 3	Manual	11/12/2025 4:20:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-265 032	Admin Building Classroom 3	Manual	11/12/2025 4:20:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-314 024	Admin Building Conference Room	Manual	11/12/2025 4:25:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-316 021	Admin Building Conference Room	Manual	11/12/2025 4:25:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-317 022	Admin Building Conference Room	Manual	11/12/2025 4:25:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-315 023	Admin Building Conference Room	Manual	11/12/2025 4:26:49 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-274 034	Admin Building Data Rm/Headend	Manual	11/19/2025 11:10:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-278 026	Admin Building Off NE Conf Office	Manual	11/12/2025 4:27:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-279 025	Admin Building Off NW Conf Office	Manual	11/12/2025 4:28:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-323 012	Admin Building Off Printer Rm Clst	Manual	11/12/2025 4:14:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-258 017	Admin Building Off Recept N Hall	Manual	11/12/2025 4:15:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-254 008	Admin Building Off Recept N Office	Manual	11/12/2025 5:10:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-268 040	Admin Building Off Recept Work Rm	Manual	11/12/2025 4:17:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-261 014	Admin Building Off Small Office 1	Manual	11/12/2025 4:14:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-262 013	Admin Building Off Small Office 2	Manual	11/19/2025 11:13:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	1-2-377 045	Admin Building Office	Manual	11/19/2025 11:12:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-270 039	Admin Building Office Cust Closet	Manual	11/12/2025 4:19:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-272 036	Admin Building Office Mens RR	Manual	11/12/2025 4:20:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-260 015	Admin Building Office Nurse	Manual	11/19/2025 11:12:42 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-259 016	Admin Building Office Nurse Restrm	Manual	11/12/2025 5:10:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-263 004	Admin Building Office Principal	Manual	11/12/2025 4:16:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-264 005	Admin Building Office Principal	Manual	11/12/2025 4:16:27 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	1-2-252 006	Admin Building Office Principal Closet	Manual	11/12/2025 4:17:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-256 011	Admin Building Office Printer Room	Manual	11/12/2025 4:15:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	1-2-376 002	Admin Building Office Reception	Manual	11/12/2025 7:14:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-255 009	Admin Building Office Reception	Manual	11/12/2025 4:15:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-253 003	Admin Building Office Reception	Manual	11/12/2025 4:15:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-257 010	Admin Building Office Reception RR	Manual	11/12/2025 5:41:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-283 030	Admin Building Office S Conf Office	Manual	11/12/2025 4:22:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-282 029	Admin Building Office S Conf Office	Manual	11/12/2025 4:22:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-281 027	Admin Building Office S Conf Office	Manual	11/12/2025 4:29:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-280 028	Admin Building Office S Conf Office	Manual	11/19/2025 11:10:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-267 037	Admin Building Office South Hall	Manual	11/12/2025 4:18:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-269 035	Admin Building Office South Hall	Manual	11/12/2025 4:19:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-275 020	Admin Building Office Staff Rm Strg	Manual	11/10/2025 9:19:38 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-277 018	Admin Building Office Staff Room	Manual	11/12/2025 4:14:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-276 019	Admin Building Office Staff Room	Manual	11/12/2025 4:14:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-251 007	Admin Building Office Tele Closet	Manual	11/19/2025 11:10:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	1-2-271 038	Admin Building Office Womens RR	Manual	11/12/2025 4:18:46 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1-2-273 033	Admin Building Telecom Room	Manual	11/12/2025 4:23:04 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2.3.150	Attic Fire Training Rm	Manual	11/19/2025 11:12:30 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-3-035	Broadcast Room	Manual	11/10/2025 10:02:54 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-3-041	Broadcast Room Control Room	Manual	11/10/2025 10:03:48 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-3-037	Broadcast Room North	Manual	11/10/2025 10:11:51 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-3-042	Broadcast Room Studio	Manual	11/10/2025 10:04:58 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-3-044	Broadcast Room Studio	Manual	11/10/2025 10:22:07 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	2-3-139	Building I	Manual	11/19/2025 11:13:18 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	1-2-135 514	Cafeteria Building Attic Kitchen	Manual	11/19/2025 11:12:58 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	1-2-135 515	Cafeteria Building Attic Kitchen	Manual	11/19/2025 11:13:00 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	1-2-136 517	Cafeteria Building Attic VP Office	Manual	11/19/2025 11:12:53 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	1-2-136 516	Cafeteria Building Attic VP Office	Manual	11/19/2025 11:12:55 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	1-2-151 518	Cafeteria Building Attic VP Office 4	Manual	11/19/2025 11:12:45 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1-2-007 491	Cafeteria Building Boys Restroom	Manual	11/12/2025 5:10:05 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1-2-008 490	Cafeteria Building Boys Restroom	Manual	11/12/2025 5:10:11 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1-2-098 485	Cafeteria Building Cafeteria	Manual	11/11/2025 9:29:15 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	1-2-101 486	Cafeteria Building Cafeteria	Manual	11/11/2025 9:29:32 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-097 484	Cafeteria Building Cafeteria	Manual	11/11/2025 9:30:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-096 481	Cafeteria Building Cafeteria	Manual	11/11/2025 9:30:42 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-099 482	Cafeteria Building Cafeteria	Manual	11/11/2025 9:31:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-100 483	Cafeteria Building Cafeteria	Manual	11/12/2025 5:03:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	1-2-132 478	Cafeteria Building Cafeteria NE Exit	Manual	11/12/2025 7:14:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	1-2-131 477	Cafeteria Building Cafeteria North Exit	Manual	11/12/2025 7:14:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	1-2-133 479	Cafeteria Building Cafeteria SE Exit	Manual	11/12/2025 7:14:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	1-2-134 480	Cafeteria Building Cafeteria South Exit	Manual	11/12/2025 7:14:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-005 487	Cafeteria Building Cafeteria Storage	Manual	11/11/2025 9:41:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-001 488	Cafeteria Building Data Room	Manual	11/11/2025 9:35:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-003 493	Cafeteria Building Girls Restroom	Manual	11/12/2025 8:40:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-002 492	Cafeteria Building Girls Restroom	Manual	11/12/2025 8:40:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-009 494	Cafeteria Building Hallway	Manual	11/11/2025 9:15:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-015 501	Cafeteria Building Hallway	Manual	11/11/2025 9:15:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1-2-004 512	Cafeteria Building Kitchen	Manual	11/19/2025 11:12:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	1-2-011 496	Cafeteria Building Mens Restrm Storage	Manual	11/11/2025 9:13:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-010 495	Cafeteria Building Mens Restroom	Manual	11/11/2025 9:13:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1-2-012 513	Cafeteria Building Snack Shack	Manual	11/12/2025 5:55:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-013 500	Cafeteria Building Tele Room	Manual	11/11/2025 9:14:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-025 510	Cafeteria Building VP Boys Restroom	Manual	11/11/2025 9:05:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-019 511	Cafeteria Building VP Girls Restroom	Manual	11/12/2025 5:10:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	1-2-150 519	Cafeteria Building VP Office	Manual	11/19/2025 11:10:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-014 504	Cafeteria Building VP Office	Manual	11/11/2025 9:12:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-027 505	Cafeteria Building VP Office Room 1	Manual	11/11/2025 9:05:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-022 506	Cafeteria Building VP Office Room 2	Manual	11/11/2025 9:05:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-026 507	Cafeteria Building VP Office Room 3	Manual	11/11/2025 9:05:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-020 508	Cafeteria Building VP Office Room 4	Manual	11/11/2025 9:05:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-021 509	Cafeteria Building VP Office Room 5	Manual	11/11/2025 9:05:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-024 502	Cafeteria Building VP Reception	Manual	11/11/2025 9:04:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-023 503	Cafeteria Building VP Reception	Manual	11/11/2025 9:05:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-017 499	Cafeteria Building Wom Restrm Strg	Manual	11/11/2025 9:18:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	1-2-018 498	Cafeteria Building Wom Restrm Strg	Manual	11/19/2025 11:13:42 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-016 497	Cafeteria Building Womens Restroom	Manual	11/11/2025 9:16:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-3-026	Comp Tech East	Manual	11/10/2025 9:37:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-3-027	Comp Tech North East	Manual	11/10/2025 9:38:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-3-024	Comp Tech South West	Manual	11/10/2025 9:37:44 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-3-023	Comp Tech West	Manual	11/10/2025 9:37:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1-2-146 557	Custodial Building Attic Custodial Office	Manual	11/19/2025 11:13:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	1-2-202 558	Custodial Building Custodial Office	Manual	11/19/2025 11:10:19 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-095 551	Custodial Building Hall	Manual	11/19/2025 11:13:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1-2-147 556	Custodial Building Mechanical Room	Manual	11/19/2025 11:13:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1-2-147 555	Custodial Building Mechanical Room	Manual	11/19/2025 11:13:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-077 549	Custodial Building Office	Manual	11/19/2025 11:10:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-079 553	Custodial Building Restroom	Manual	11/19/2025 11:13:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-075 546	Custodial Building Staff Room 1	Manual	11/19/2025 11:13:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-074 554	Custodial Building Storage	Manual	11/11/2025 11:09:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-076 547	Custodial Building Storage	Manual	11/12/2025 5:10:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-078 550	Custodial Building Storage	Manual	11/19/2025 11:13:44 AM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	1-2-073 548	Custodial Building Storage	Manual	11/19/2025 11:13:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-094 552	Custodial Building Washroom	Manual	11/19/2025 11:13:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-3-046	Edit Booth	Manual	11/10/2025 10:05:32 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-3-047	Edit Booth	Manual	11/10/2025 10:06:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-3-045	Edit Booth	Manual	11/10/2025 10:06:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-3-004	Fab Lab E.	Manual	11/10/2025 9:44:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-3-009	Fab Lab Storage	Manual	11/10/2025 9:45:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-3-021	Fire training storage	Manual	11/10/2025 9:58:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-3-014	Fire training storage N	Manual	11/10/2025 10:26:19 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-3-039	Hall	Manual	11/10/2025 10:03:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.3.152	I Building Attic Broadcast Rm I104	Manual	11/12/2025 6:52:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.3.151	I Building Attic Comp Tech Rm I103	Manual	11/12/2025 6:52:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.3.153	I Building Broadcast Rm I105	Manual	11/12/2025 6:52:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.3.015	I building Fire Training E Rm I102	Manual	11/12/2025 5:52:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.3.013	I Building Fire Training Rm I102	Manual	11/12/2025 5:54:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.3.011	I Building Fire Training Rm I102	Manual	11/12/2025 5:55:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.3.017	I Building Fire Training W Rm I102	Manual	11/12/2025 5:53:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-3-002	IDF/AV Room	Manual	11/10/2025 10:19:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-2-169 780	Large Gym Attic Music Clrm 92	Manual	11/12/2025 8:25:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-2-163 781	Large Gym Attic Music Clrm 93	Manual	11/12/2025 8:25:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-2-164 783	Large Gym Attic Music Storage	Manual	11/12/2025 8:25:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-2-164 782	Large Gym Attic Music Storage	Manual	11/12/2025 8:25:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	2-2-174 787	Large Gym Band Storage	Manual	11/19/2025 11:13:19 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Valve Tamper Switch	2-2-175 788	Large Gym Band Storage	Manual	11/19/2025 11:12:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-2-144 771	Large Gym Boys Locker Boiler	Manual	11/12/2025 9:33:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-2-031 742	Large Gym Boys Locker Rm Off	Manual	11/10/2025 2:31:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-2-036 745	Large Gym Boys Locker Rm Strg	Manual	11/10/2025 2:36:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-2-035 747	Large Gym Boys Locker Rm Strg	Manual	11/12/2025 5:02:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-2-034 744	Large Gym Boys Locker Rm Strg	Manual	11/12/2025 5:02:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-2-033 748	Large Gym Boys Locker Rm Strg	Manual	11/12/2025 5:02:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-2-145 772	Large Gym Boys Locker Room	Manual	11/12/2025 7:28:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-2-145 773	Large Gym Boys Locker Room	Manual	11/12/2025 7:28:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-2-146 774	Large Gym Boys Locker Room	Manual	11/12/2025 7:36:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-2-177 784	Large Gym Boys Locker Room	Manual	11/12/2025 9:33:10 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-2-028 738	Large Gym Boys Locker Room	Manual	11/10/2025 2:26:55 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-2-030 740	Large Gym Boys Locker Room	Manual	11/10/2025 2:27:22 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-2-032 743	Large Gym Boys Locker Room	Manual	11/10/2025 2:29:40 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-2-037 746	Large Gym Boys Locker Room	Manual	11/10/2025 2:36:32 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-2-026 741	Large Gym Boys Locker Room	Manual	11/12/2025 5:02:19 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-2-143 768	Large Gym Coaches Off Shower	Manual	11/12/2025 7:44:56 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-2-024 736	Large Gym Coaches Office	Manual	11/10/2025 2:22:56 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-2-025 737	Large Gym Coaches Office	Manual	11/10/2025 2:24:42 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-2-140 766	Large Gym Coaches Office RR	Manual	11/12/2025 7:42:06 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-2-141 765	Large Gym Coaches Office RR	Manual	11/12/2025 7:42:29 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-2-142 767	Large Gym Coaches Office RR	Manual	11/12/2025 7:44:30 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-2-139 769	Large Gym Girls Boiler Room E	Manual	11/12/2025 9:39:16 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-2-136 770	Large Gym Girls Boiler Room W	Manual	11/12/2025 8:19:07 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-2-023 735	Large Gym Girls Lock Hall Storge	Manual	11/10/2025 2:21:22 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-2-020 724	Large Gym Girls Locker Cust Clst	Manual	11/12/2025 5:02:34 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-2-013 730	Large Gym Girls Locker Office	Manual	11/12/2025 5:02:26 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	2-2-011 727	Large Gym Girls Locker Office	Manual	11/12/2025 5:02:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-2-137 762	Large Gym Girls Locker Room	Manual	11/12/2025 9:28:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-2-137 763	Large Gym Girls Locker Room	Manual	11/12/2025 9:28:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-2-138 764	Large Gym Girls Locker Room	Manual	11/12/2025 9:35:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-2-176 785	Large Gym Girls Locker Room	Manual	11/12/2025 9:36:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-2-019 723	Large Gym Girls Locker Room	Manual	11/12/2025 5:02:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-2-010 725	Large Gym Girls Locker Room	Manual	11/12/2025 5:02:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-2-018 731	Large Gym Girls Locker Room	Manual	11/12/2025 5:02:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-2-017 732	Large Gym Girls Locker Room	Manual	11/12/2025 5:02:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-2-022 726	Large Gym Girls Locker RR	Manual	11/12/2025 5:02:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-2-015 733	Large Gym Girls Locker Storage	Manual	11/12/2025 5:02:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-2-016 734	Large Gym Girls Locker Storage	Manual	11/12/2025 5:02:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-2-061 749	Large Gym Large Gym Boys RR	Manual	11/12/2025 5:02:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-2-009 750	Large Gym Large Gym Girls RR	Manual	11/12/2025 5:02:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-2-040 680	Large Gym Locker Room Hall	Manual	11/10/2025 2:17:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-2-039 681	Large Gym Locker Room Hall	Manual	11/10/2025 2:17:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-2-038 682	Large Gym Locker Room Hall	Manual	11/10/2025 2:17:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-2-041 683	Large Gym Locker Room Hall	Manual	11/10/2025 2:18:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-2-042 684	Large Gym Locker Room Hall	Manual	11/10/2025 2:18:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-2-155 672	Large Gym Lrg Gym E Hall Exit	Manual	11/12/2025 7:14:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-2-158 776	Large Gym Lrg Gym Trophy Case	Manual	11/12/2025 8:09:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-2-147 777	Large Gym Lrg Gym Under Stage	Manual	11/12/2025 9:45:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-2-147 778	Large Gym Lrg Gym Under Stage	Manual	11/12/2025 9:45:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-2-147 779	Large Gym Lrg Gym Under Stage	Manual	11/12/2025 9:45:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-2-156 679	Large Gym Lrg Gym W Hall Exit	Manual	11/12/2025 7:14:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-2-048 756	Large Gym Music Band Storage	Manual	11/12/2025 4:50:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-2-165 786	Large Gym Music Building	Manual	11/19/2025 11:12:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-2-050 758	Large Gym Music Room 1	Manual	11/12/2025 4:52:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-2-051 759	Large Gym Music Room 2	Manual	11/12/2025 4:51:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-2-053 751	Large Gym Music Room 92	Manual	11/12/2025 4:49:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-2-052 754	Large Gym Music Room 92	Manual	11/12/2025 4:50:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-2-054 752	Large Gym Music Room 92	Manual	11/12/2025 4:57:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-2-055 753	Large Gym Music Room 92	Manual	11/12/2025 4:57:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-2-046 760	Large Gym Music Room 93	Manual	11/12/2025 4:53:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-2-045 761	Large Gym Music Room 93	Manual	11/12/2025 4:53:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-2-049 757	Large Gym Music Room Hall	Manual	11/12/2025 4:51:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-2-047 755	Large Gym Music Storage	Manual	11/12/2025 4:50:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-2-159 674	Large Gym Northeast Exit	Manual	11/12/2025 7:14:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-2-160 675	Large Gym Northeast Exit	Manual	11/12/2025 7:14:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-2-161 676	Large Gym Northwest Exit	Manual	11/12/2025 7:14:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-2-162 677	Large Gym Northwest Exit	Manual	11/12/2025 7:14:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-2-008 775	Large Gym Snack Shack	Manual	11/12/2025 8:07:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-2-154 673	Large Gym Southeast Exit	Manual	11/12/2025 7:14:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-2-157 678	Large Gym Southwest Exit	Manual	11/12/2025 7:14:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1-2-386 215	Library Building Attic Library Book Rm	Manual	11/19/2025 11:13:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1-2-386 216	Library Building Attic Library Book Rm	Manual	11/19/2025 11:13:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-290 205	Library Building Book Room	Manual	11/11/2025 11:44:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-297 207	Library Building Classroom 32	Manual	11/11/2025 11:47:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	1-2-298 206	Library Building Classroom 32	Manual	11/11/2025 11:48:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-295 209	Library Building Classroom 33	Manual	11/11/2025 11:44:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-296 208	Library Building Classroom 33	Manual	11/11/2025 11:45:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-288 210	Library Building Classroom 38	Manual	11/11/2025 11:49:16 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-286 211	Library Building Classroom 38	Manual	11/12/2025 4:04:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-285 201	Library Building Computer Lab	Manual	11/11/2025 11:45:39 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-287 202	Library Building Computer Lab	Manual	11/11/2025 11:46:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-289 203	Library Building Computer Lab	Manual	11/11/2025 11:47:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-301 196	Library Building Library	Manual	11/11/2025 11:39:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-302 195	Library Building Library	Manual	11/11/2025 11:39:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-300 197	Library Building Library	Manual	11/11/2025 11:39:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-299 190	Library Building Library	Manual	11/11/2025 11:39:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-291 191	Library Building Library	Manual	11/11/2025 11:40:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-292 192	Library Building Library	Manual	11/11/2025 11:40:16 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-293 193	Library Building Library	Manual	11/11/2025 11:40:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-294 194	Library Building Library	Manual	11/11/2025 11:41:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	1-2-303 199	Library Building Library	Manual	11/11/2025 11:41:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-304 198	Library Building Library	Manual	11/11/2025 11:41:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-305 200	Library Building Library	Manual	11/11/2025 11:42:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-320 212	Library Building Room 38	Manual	11/11/2025 11:48:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-318 213	Library Building Room 39	Manual	11/11/2025 11:46:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-319 214	Library Building Room 39	Manual	11/11/2025 11:46:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-284 204	Library Building Work Room	Manual	11/11/2025 11:45:54 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	2.4.151	North Corridor R114	Manual	11/19/2025 11:12:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1-2-148 134	Rooms 16-23 Bldg Attic Classroom 16	Manual	11/19/2025 11:12:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1-2-148 133	Rooms 16-23 Bldg Attic Classroom 16	Manual	11/19/2025 11:12:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1-2-148 135	Rooms 16-23 Bldg Attic Classroom 20	Manual	11/19/2025 11:12:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-081 121	Rooms 16-23 Bldg Classroom 16	Manual	11/11/2025 10:49:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-080 120	Rooms 16-23 Bldg Classroom 16	Manual	11/11/2025 11:16:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-082 122	Rooms 16-23 Bldg Classroom 16 Strg	Manual	11/11/2025 10:50:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-092 123	Rooms 16-23 Bldg Classroom 17	Manual	11/11/2025 10:48:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-091 124	Rooms 16-23 Bldg Classroom 18	Manual	11/10/2025 1:51:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	1-2-090 126	Rooms 16-23 Bldg Classroom 19	Manual	11/11/2025 10:49:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-089 125	Rooms 16-23 Bldg Classroom 19	Manual	11/11/2025 10:52:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-084 127	Rooms 16-23 Bldg Classroom 20	Manual	11/11/2025 11:01:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-086 130	Rooms 16-23 Bldg Classroom 21	Manual	11/11/2025 11:01:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-085 129	Rooms 16-23 Bldg Classroom 21	Manual	11/11/2025 11:02:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-087 131	Rooms 16-23 Bldg Classroom 22	Manual	11/19/2025 11:13:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-088 132	Rooms 16-23 Bldg Classroom 23	Manual	11/19/2025 11:13:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-083 128	Rooms 16-23 Bldg Room 20A Storage	Manual	11/12/2025 5:07:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	1-2-137 085	Rooms 1-8 Bldg Classroom 1	Manual	11/12/2025 5:24:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-031 071	Rooms 1-8 Bldg Classroom 1	Manual	11/10/2025 2:54:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-034 073	Rooms 1-8 Bldg Classroom 2	Manual	11/11/2025 8:17:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-033 072	Rooms 1-8 Bldg Classroom 2	Manual	11/11/2025 8:17:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-032 075	Rooms 1-8 Bldg Classroom 3	Manual	11/11/2025 8:15:33 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-035 074	Rooms 1-8 Bldg Classroom 3	Manual	11/11/2025 8:15:54 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-037 077	Rooms 1-8 Bldg Classroom 4	Manual	11/11/2025 8:21:42 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-036 076	Rooms 1-8 Bldg Classroom 4	Manual	11/11/2025 8:21:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	1-2-030 078	Rooms 1-8 Bldg Classroom 5	Manual	11/10/2025 2:55:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-042 079	Rooms 1-8 Bldg Classroom 6	Manual	11/11/2025 8:23:16 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-043 080	Rooms 1-8 Bldg Classroom 6	Manual	11/11/2025 8:23:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-038 082	Rooms 1-8 Bldg Classroom 7	Manual	11/10/2025 2:56:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-041 081	Rooms 1-8 Bldg Classroom 7	Manual	11/10/2025 2:57:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-039 083	Rooms 1-8 Bldg Classroom 8	Manual	11/11/2025 8:19:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-040 084	Rooms 1-8 Bldg Classroom 8	Manual	11/11/2025 8:20:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-056 148	Rooms 24-30 Bldg Classroom 24	Manual	11/11/2025 10:38:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-057 147	Rooms 24-30 Bldg Classroom 24	Manual	11/19/2025 11:13:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-055 150	Rooms 24-30 Bldg Classroom 25	Manual	11/11/2025 10:40:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-052 149	Rooms 24-30 Bldg Classroom 25	Manual	11/11/2025 10:40:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-053 151	Rooms 24-30 Bldg Classroom 26	Manual	11/11/2025 10:41:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-054 152	Rooms 24-30 Bldg Classroom 26	Manual	11/11/2025 10:42:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	1-2-138 162	Rooms 24-30 Bldg Classroom 27	Manual	11/12/2025 5:24:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-045 153	Rooms 24-30 Bldg Classroom 27	Manual	11/11/2025 10:36:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-044 154	Rooms 24-30 Bldg Classroom 27A	Manual	11/11/2025 10:34:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	1-2-048 155	Rooms 24-30 Bldg Classroom 28	Manual	11/11/2025 10:31:10 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1-2-047 156	Rooms 24-30 Bldg Classroom 28	Manual	11/11/2025 10:34:00 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1-2-049 158	Rooms 24-30 Bldg Classroom 29	Manual	11/11/2025 10:35:28 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1-2-046 157	Rooms 24-30 Bldg Classroom 29	Manual	11/19/2025 11:13:26 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1-2-051 160	Rooms 24-30 Bldg Classroom 30	Manual	11/11/2025 10:37:16 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1-2-050 159	Rooms 24-30 Bldg Classroom 30	Manual	11/11/2025 10:37:27 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	1-2-139 161	Rooms 24-30 Bldg Cust Strg W Rm 27	Manual	11/19/2025 11:12:48 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	1-3-378 288	Rooms 44-53 Bldg Attic Dark Room 47	Manual	11/19/2025 11:13:16 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	1-3-376 289	Rooms 44-53 Bldg Attic Room 53	Manual	11/19/2025 11:12:40 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1-3-274 268	Rooms 44-53 Bldg Classrm 50 Storage	Manual	11/10/2025 8:27:23 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1-3-273 269	Rooms 44-53 Bldg Classrm 50 Storage	Manual	11/10/2025 9:05:01 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1-3-264 272	Rooms 44-53 Bldg Classrm 51 Storage	Manual	11/10/2025 8:24:08 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1-3-265 273	Rooms 44-53 Bldg Classrm 51 Storage	Manual	11/10/2025 9:00:39 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1-3-252 253	Rooms 44-53 Bldg Classroom 44	Manual	11/10/2025 8:22:04 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1-3-253 254	Rooms 44-53 Bldg Classroom 44	Manual	11/10/2025 8:22:23 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	1-3-254 255	Rooms 44-53 Bldg Classroom 45	Manual	11/10/2025 8:24:17 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	1-3-255 256	Rooms 44-53 Bldg Classroom 45	Manual	11/10/2025 8:24:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-256 258	Rooms 44-53 Bldg Classroom 46	Manual	11/10/2025 8:26:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-257 257	Rooms 44-53 Bldg Classroom 46	Manual	11/10/2025 8:26:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-282 263	Rooms 44-53 Bldg Classroom 49	Manual	11/10/2025 8:23:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-281 264	Rooms 44-53 Bldg Classroom 49	Manual	11/10/2025 8:33:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-280 267	Rooms 44-53 Bldg Classroom 50	Manual	11/10/2025 8:57:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-279 266	Rooms 44-53 Bldg Classroom 50	Manual	11/10/2025 8:57:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-275 274	Rooms 44-53 Bldg Classroom 52	Manual	11/10/2025 9:00:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-276 275	Rooms 44-53 Bldg Classroom 52	Manual	11/10/2025 9:19:20 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-251 276	Rooms 44-53 Bldg Classroom 53	Manual	11/10/2025 8:22:39 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-269 259	Rooms 44-53 Bldg Dark Room 47	Manual	11/10/2025 9:24:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-270 260	Rooms 44-53 Bldg Dark Room 47	Manual	11/10/2025 9:25:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1-3-379 287	Rooms 44-53 Bldg Kiln Room	Manual	11/19/2025 11:12:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-283 265	Rooms 44-53 Bldg Restrm by Rm 49	Manual	11/10/2025 9:26:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-272 261	Rooms 44-53 Bldg Room 48	Manual	11/10/2025 8:32:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-271 262	Rooms 44-53 Bldg Room 48 Storage	Manual	11/10/2025 8:31:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	1-3-263 278	Rooms 44-53 Bldg Room 53 Storage	Manual	11/10/2025 8:23:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-262 277	Rooms 44-53 Bldg Room 53 Wash Clst	Manual	11/10/2025 8:23:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-266 281	Rooms 44-53 Bldg ROTC Classrm 2	Manual	11/10/2025 9:29:16 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-259 283	Rooms 44-53 Bldg ROTC Cust Closet	Manual	11/10/2025 8:29:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-267 279	Rooms 44-53 Bldg ROTC Office	Manual	11/10/2025 8:27:42 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-268 280	Rooms 44-53 Bldg ROTC Office	Manual	11/10/2025 9:32:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-260 285	Rooms 44-53 Bldg ROTC Rm 34 Cust	Manual	11/10/2025 8:29:32 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-261 284	Rooms 44-53 Bldg ROTC Rm 34 RR	Manual	11/10/2025 8:30:40 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-258 282	Rooms 44-53 Bldg ROTC Storage	Manual	11/10/2025 8:32:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1-3-377 286	Rooms 44-53 Bldg ROTC Wtr Htr Clst	Manual	11/19/2025 11:10:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1-3-137 383	Rooms 62-69 Bldg Attic Classroom 66	Manual	11/19/2025 11:10:16 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1-3-137 382	Rooms 62-69 Bldg Attic Classroom 66	Manual	11/19/2025 11:10:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-086 368	Rooms 62-69 Bldg Classroom 62	Manual	11/10/2025 11:09:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-087 370	Rooms 62-69 Bldg Classroom 62	Manual	11/10/2025 11:09:20 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-084 369	Rooms 62-69 Bldg Classroom 62	Manual	11/10/2025 11:10:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-085 371	Rooms 62-69 Bldg Classroom 62 Hall	Manual	11/10/2025 11:08:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	1-3-091 372	Rooms 62-69 Bldg Classroom 63	Manual	11/10/2025 11:03:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-090 373	Rooms 62-69 Bldg Classroom 63	Manual	11/10/2025 11:04:40 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-088 374	Rooms 62-69 Bldg Classroom 64	Manual	11/10/2025 11:02:38 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-089 375	Rooms 62-69 Bldg Classroom 65	Manual	11/10/2025 10:59:38 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-082 376	Rooms 62-69 Bldg Classroom 66	Manual	11/10/2025 10:36:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-083 377	Rooms 62-69 Bldg Classroom 66	Manual	11/10/2025 11:07:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-093 378	Rooms 62-69 Bldg Classroom 67	Manual	11/10/2025 10:34:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-092 379	Rooms 62-69 Bldg Classroom 68	Manual	11/10/2025 10:32:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-095 381	Rooms 62-69 Bldg Classroom 69	Manual	11/10/2025 10:30:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-094 380	Rooms 62-69 Bldg Classroom 69	Manual	11/10/2025 10:30:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-056 397	Rooms 70-76 Bldg Classroom 70	Manual	11/10/2025 11:19:38 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-057 398	Rooms 70-76 Bldg Classroom 70	Manual	11/10/2025 11:19:54 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-055 399	Rooms 70-76 Bldg Classroom 71	Manual	11/10/2025 11:21:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-058 400	Rooms 70-76 Bldg Classroom 71	Manual	11/10/2025 11:22:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-060 402	Rooms 70-76 Bldg Classroom 72	Manual	11/10/2025 11:15:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-059 401	Rooms 70-76 Bldg Classroom 72	Manual	11/10/2025 11:27:36 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	1-3-065 404	Rooms 70-76 Bldg Classroom 73	Manual	11/12/2025 3:57:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-066 403	Rooms 70-76 Bldg Classroom 73	Manual	11/12/2025 3:57:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-061 406	Rooms 70-76 Bldg Classroom 74	Manual	11/10/2025 11:17:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-064 405	Rooms 70-76 Bldg Classroom 74	Manual	11/12/2025 3:56:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-062 408	Rooms 70-76 Bldg Classroom 75	Manual	11/10/2025 11:18:33 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-063 407	Rooms 70-76 Bldg Classroom 75	Manual	11/10/2025 11:18:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-054 409	Rooms 70-76 Bldg Classroom 76	Manual	11/10/2025 11:16:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	1-3-135 411	Rooms 70-76 Bldg Classroom 76A	Manual	11/12/2025 5:23:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-053 410	Rooms 70-76 Bldg Classroom 76A	Manual	11/10/2025 11:17:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	1-3-136 439	Rooms 77-83 Bldg Classroom 77	Manual	11/12/2025 5:23:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-067 426	Rooms 77-83 Bldg Classroom 77A	Manual	11/11/2025 11:16:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-081 428	Rooms 77-83 Bldg Classroom 78	Manual	11/11/2025 11:16:36 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-080 427	Rooms 77-83 Bldg Classroom 78	Manual	11/11/2025 11:16:40 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-079 429	Rooms 77-83 Bldg Classroom 79	Manual	11/11/2025 11:21:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-076 430	Rooms 77-83 Bldg Classroom 79	Manual	11/11/2025 11:21:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-078 432	Rooms 77-83 Bldg Classroom 80	Manual	11/11/2025 11:28:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	1-3-077 431	Rooms 77-83 Bldg Classroom 80	Manual	11/11/2025 11:28:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-071 433	Rooms 77-83 Bldg Classroom 81	Manual	11/11/2025 11:23:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-072 434	Rooms 77-83 Bldg Classroom 81	Manual	11/11/2025 11:24:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-073 435	Rooms 77-83 Bldg Classroom 82	Manual	11/11/2025 11:22:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-070 436	Rooms 77-83 Bldg Classroom 82	Manual	11/11/2025 11:22:42 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-075 438	Rooms 77-83 Bldg Classroom 83	Manual	11/12/2025 5:08:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-074 437	Rooms 77-83 Bldg Classroom 83	Manual	11/12/2025 5:08:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-068 424	Rooms 77-83 Bldg Room 77	Manual	11/11/2025 11:19:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-069 425	Rooms 77-83 Bldg Room 77	Manual	11/11/2025 11:20:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1-3-138 463	Rooms 84-91 Bldg Attic Classroom 87	Manual	11/19/2025 11:10:54 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1-3-138 464	Rooms 84-91 Bldg Attic Classroom 87	Manual	11/19/2025 11:10:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-107 452	Rooms 84-91 Bldg Classroom 84	Manual	11/10/2025 1:44:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-106 451	Rooms 84-91 Bldg Classroom 84	Manual	11/10/2025 1:45:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-104 453	Rooms 84-91 Bldg Classroom 85	Manual	11/10/2025 1:45:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-105 454	Rooms 84-91 Bldg Classroom 86	Manual	11/10/2025 1:39:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-096 455	Rooms 84-91 Bldg Classroom 87	Manual	11/10/2025 1:38:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	1-3-097 456	Rooms 84-91 Bldg Classroom 87	Manual	11/10/2025 1:38:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-101 457	Rooms 84-91 Bldg Classroom 88	Manual	11/10/2025 1:40:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-100 458	Rooms 84-91 Bldg Classroom 89	Manual	11/10/2025 1:41:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-102 459	Rooms 84-91 Bldg Classroom 90	Manual	11/10/2025 1:42:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-103 460	Rooms 84-91 Bldg Classroom 90	Manual	11/10/2025 1:43:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-099 461	Rooms 84-91 Bldg Classroom 91	Manual	11/10/2025 1:43:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-098 462	Rooms 84-91 Bldg Classroom 91 Strg	Manual	11/10/2025 1:51:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1-2-145 110	Rooms 9-15 Bldg Attic Classroom 15	Manual	11/19/2025 11:13:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1-2-145 109	Rooms 9-15 Bldg Attic Classroom 15	Manual	11/19/2025 11:13:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-066 099	Rooms 9-15 Bldg Classroom 10	Manual	11/11/2025 8:33:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-068 100	Rooms 9-15 Bldg Classroom 11	Manual	11/11/2025 8:28:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-067 101	Rooms 9-15 Bldg Classroom 11	Manual	11/11/2025 8:30:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-071 105	Rooms 9-15 Bldg Classroom 13	Manual	11/11/2025 8:39:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-072 104	Rooms 9-15 Bldg Classroom 13	Manual	11/11/2025 8:44:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-069 106	Rooms 9-15 Bldg Classroom 14	Manual	11/11/2025 8:35:36 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-070 107	Rooms 9-15 Bldg Classroom 14	Manual	11/11/2025 8:36:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	1-2-062 108	Rooms 9-15 Bldg Classroom 15	Manual	11/11/2025 8:32:32 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-065 098	Rooms 9-15 Bldg Classroom 9	Manual	11/11/2025 8:34:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-064 102	Rooms 9-15 Bldg Room 12	Manual	11/11/2025 8:46:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-2-063 103	Rooms 9-15 Bldg Room 12A Storage	Manual	11/11/2025 8:47:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-3-003	Secure Storage Rm	Manual	11/10/2025 10:08:38 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-2-148 655	Small Gym Attic Small Gym	Manual	11/19/2025 11:12:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Projected Beam	2-2-128 656	Small Gym Beam East	Manual	11/19/2025 11:12:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Projected Beam	2-2-130 657	Small Gym Beam Middle	Manual	11/19/2025 11:12:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Projected Beam	2-2-132 658	Small Gym Beam West	Manual	11/19/2025 11:12:16 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-2-003 649	Small Gym Boys Restroom	Manual	11/12/2025 5:10:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-2-004 648	Small Gym Boys Restroom	Manual	11/12/2025 8:13:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-2-021 652	Small Gym Custodial Room	Manual	11/10/2025 1:54:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-2-002 647	Small Gym Data Room	Manual	11/10/2025 1:55:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-2-005 650	Small Gym Girls Restroom	Manual	11/12/2025 5:02:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-2-006 651	Small Gym Girls Restroom	Manual	11/12/2025 5:10:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-2-147 654	Small Gym Mech Chase	Manual	11/19/2025 11:12:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-2-135 646	Small Gym Northeast Exit	Manual	11/12/2025 7:14:18 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-2-133 645	Small Gym Northwest Exit	Manual	11/12/2025 7:14:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-2-134 644	Small Gym Southwest Exit	Manual	11/12/2025 7:14:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-2-007 653	Small Gym Storage Room	Manual	11/10/2025 2:05:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-3-008	Smoke Fab Lab	Manual	11/10/2025 9:48:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-3-005	Smoke Fab Lab	Manual	11/10/2025 9:51:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-3-007	Smoke Fab Lab W	Manual	11/10/2025 9:44:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-3-018	Smoke fire training	Manual	11/10/2025 9:54:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-3-020	Smoke fire training	Manual	11/10/2025 9:57:40 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-3-010	Smoke fire training storage	Manual	11/10/2025 10:26:40 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-3-030	Smoke innovation	Manual	11/10/2025 9:35:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-3-031	Smoke innovation E	Manual	11/10/2025 9:36:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-3-033	Smoke innovation Entrance	Manual	11/10/2025 9:36:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-3-034	Smoke innovation entrance N	Manual	11/10/2025 9:36:19 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-3-032	Smoke innovation Entrance S	Manual	11/10/2025 9:35:44 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-3-028	Smoke innovation W	Manual	11/10/2025 9:34:44 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-3-002	Smoke innovations hall	Manual	11/10/2025 9:39:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-2-180 863	Stadium Attic Restrooms	Manual	11/19/2025 11:13:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-2-180 862	Stadium Attic Restrooms	Manual	11/19/2025 11:13:10 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-2-180 861	Stadium Attic Restrooms	Manual	11/19/2025 11:13:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-2-101 859	Stadium Mens Restroom	Manual	11/19/2025 11:10:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-2-100 860	Stadium Womens Restroom	Manual	11/19/2025 11:10:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1-3-130 618	Theater Building Attic Counseling Off 4	Manual	11/19/2025 11:12:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1-3-129 619	Theater Building Attic Counseling Off 5	Manual	11/19/2025 11:12:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1-3-127 617	Theater Building Attic Theater Workrm	Manual	11/19/2025 11:12:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-014 597	Theater Building Boys Restroom	Manual	11/12/2025 8:36:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-013 598	Theater Building Boys Restroom	Manual	11/12/2025 8:36:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-031 612	Theater Building Couns Office 4 Hall	Manual	11/10/2025 11:28:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-023 613	Theater Building Couns Office 5 Hall	Manual	11/10/2025 11:27:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-026 603	Theater Building Counseling	Manual	11/10/2025 11:27:40 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-025 604	Theater Building Counseling	Manual	11/10/2025 11:27:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-028 614	Theater Building Counseling Boys RR	Manual	11/12/2025 8:46:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-020 615	Theater Building Counseling Girls RR	Manual	11/12/2025 8:43:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-021 605	Theater Building Counseling Office	Manual	11/10/2025 11:28:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-032 606	Theater Building Counseling Office 1	Manual	11/10/2025 11:29:31 AM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	1-3-024 607	Theater Building Counseling Office 2	Manual	11/12/2025 8:56:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-030 608	Theater Building Counseling Office 3	Manual	11/10/2025 11:31:36 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-029 609	Theater Building Counseling Office 4	Manual	11/10/2025 11:30:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-022 610	Theater Building Counseling Office 6	Manual	11/12/2025 8:56:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-027 611	Theater Building Counseling Office 7	Manual	11/10/2025 11:32:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-001 580	Theater Building Data Room	Manual	11/10/2025 1:27:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-011 582	Theater Building Dressing Room	Manual	11/10/2025 1:24:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-010 581	Theater Building Dressing Room	Manual	11/10/2025 1:25:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-003 596	Theater Building Girls Restroom	Manual	11/12/2025 8:40:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-002 595	Theater Building Girls Restroom	Manual	11/12/2025 8:40:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-019 584	Theater Building Green Room	Manual	11/10/2025 1:12:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-008 583	Theater Building Green Room Hall	Manual	11/10/2025 11:32:42 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-004 594	Theater Building Mens Restrm Hall	Manual	11/10/2025 11:32:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-006 592	Theater Building Mens Restrm Storage	Manual	11/10/2025 1:09:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-005 593	Theater Building Mens Restroom	Manual	11/12/2025 8:15:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	1-3-134 565	Theater Building Northwest Exit	Manual	11/12/2025 7:14:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	1-3-049 616	Theater Building Snack Shack	Manual	11/19/2025 11:12:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-048 590	Theater Building Snack Storage	Manual	11/10/2025 1:30:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	1-3-133 566	Theater Building Southwest Exit	Manual	11/12/2025 7:14:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	1-3-132 564	Theater Building Stage North Exit	Manual	11/12/2025 7:14:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	1-3-131 567	Theater Building Stage South Exit	Manual	11/12/2025 7:14:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-007 591	Theater Building Tele Room	Manual	11/10/2025 1:10:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-040 571	Theater Building Theater	Manual	11/10/2025 1:20:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-046 570	Theater Building Theater	Manual	11/10/2025 1:20:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-045 573	Theater Building Theater	Manual	11/10/2025 1:21:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-044 574	Theater Building Theater	Manual	11/10/2025 1:21:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-043 577	Theater Building Theater	Manual	11/10/2025 1:21:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-042 578	Theater Building Theater	Manual	11/10/2025 1:21:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-036 579	Theater Building Theater	Manual	11/10/2025 1:22:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-037 576	Theater Building Theater	Manual	11/10/2025 1:23:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-038 575	Theater Building Theater	Manual	11/10/2025 1:23:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-039 572	Theater Building Theater	Manual	11/10/2025 1:23:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	1-3-041 568	Theater Building Theater	Manual	11/12/2025 5:10:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-047 569	Theater Building Theater	Manual	11/12/2025 5:10:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	1-3-128 620	Theater Building Theater Office 7	Manual	11/12/2025 8:56:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-015 586	Theater Building Theater Storage	Manual	11/10/2025 1:29:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-033 589	Theater Building Theater Storage	Manual	11/10/2025 1:32:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-034 588	Theater Building Theater Storage	Manual	11/10/2025 1:34:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-035 587	Theater Building Theater Storage	Manual	11/10/2025 1:35:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-012 599	Theater Building Womens Restrm Hall	Manual	11/10/2025 1:13:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-016 600	Theater Building Womens Restroom	Manual	11/10/2025 1:13:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-017 602	Theater Building Womens RR Storage	Manual	11/10/2025 1:14:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-018 601	Theater Building Womens RR Storage	Manual	11/10/2025 1:15:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1-3-009 585	Theater Building Work Room	Manual	11/10/2025 1:25:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-2-167 848	Weight Room Bldg Attic Weight Room	Manual	11/12/2025 6:57:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-2-167 849	Weight Room Bldg Attic Weight Room	Manual	11/12/2025 6:57:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-2-167 850	Weight Room Bldg Attic Weight Room	Manual	11/12/2025 6:57:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-2-167 847	Weight Room Bldg Attic Weight Room	Manual	11/12/2025 6:57:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-2-167 851	Weight Room Bldg Attic Weight Room	Manual	11/12/2025 6:57:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-2-167 855	Weight Room Bldg Attic Weight Room	Manual	11/12/2025 6:57:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-2-167 853	Weight Room Bldg Attic Weight Room	Manual	11/12/2025 6:57:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-2-167 852	Weight Room Bldg Attic Weight Room	Manual	11/12/2025 6:57:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-2-167 854	Weight Room Bldg Attic Weight Room	Manual	11/12/2025 6:57:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-2-167 856	Weight Room Bldg Attic Weight Room	Manual	11/12/2025 6:57:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-2-166 838	Weight Room Bldg Attic Weight Room	Manual	11/12/2025 7:01:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-2-166 839	Weight Room Bldg Attic Weight Room	Manual	11/12/2025 7:01:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-2-166 840	Weight Room Bldg Attic Weight Room	Manual	11/12/2025 7:01:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-2-166 841	Weight Room Bldg Attic Weight Room	Manual	11/12/2025 7:01:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-2-166 842	Weight Room Bldg Attic Weight Room	Manual	11/12/2025 7:01:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-2-166 843	Weight Room Bldg Attic Weight Room	Manual	11/12/2025 7:01:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-2-166 844	Weight Room Bldg Attic Weight Room	Manual	11/12/2025 7:01:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-2-166 845	Weight Room Bldg Attic Weight Room	Manual	11/12/2025 7:01:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-2-166 846	Weight Room Bldg Attic Weight Room	Manual	11/12/2025 7:01:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-2-168 858	Weight Room Bldg Attic Wght Rm Clsrm	Manual	11/12/2025 6:57:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-2-168 857	Weight Room Bldg Attic Wght Rm Clsrm	Manual	11/12/2025 6:57:59 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-2-060 837	Weight Room Bldg Weight Rm Classrm	Manual	11/10/2025 2:43:05 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-2-059 836	Weight Room Bldg Weight Rm Classrm	Manual	11/10/2025 2:43:22 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-2-056 833	Weight Room Bldg Weight Room	Manual	11/10/2025 2:44:15 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-2-057 834	Weight Room Bldg Weight Room	Manual	11/10/2025 2:44:36 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-2-058 835	Weight Room Bldg Weight Room	Manual	11/10/2025 2:44:55 PM
		Visual inspection	Passed (Manual)	

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	1-2-006 489	Cafeteria Building Kitchen Office	Manual	11/11/2025 9:48:49 AM
Smoke Detector - General	2-2-029 739	Large Gym Boys Locker Room	Manual	11/12/2025 4:46:07 PM
Smoke Detector - General	2-2-079 700	Large Gym Center Bay	Manual	11/12/2025 4:44:08 PM
Smoke Detector - General	2-2-087 708	Large Gym Center Bay	Manual	11/12/2025 4:44:40 PM
Smoke Detector - General	2-2-086 707	Large Gym Center Bay	Manual	11/12/2025 4:44:43 PM
Smoke Detector - General	2-2-084 706	Large Gym Center Bay	Manual	11/12/2025 4:44:49 PM
Smoke Detector - General	2-2-083 704	Large Gym Center Bay	Manual	11/12/2025 4:45:00 PM
Smoke Detector - General	2-2-081 701	Large Gym Center Bay	Manual	11/12/2025 4:45:03 PM
Smoke Detector - General	2-2-080 702	Large Gym Center Bay	Manual	11/12/2025 4:45:05 PM
Smoke Detector - General	2-2-082 703	Large Gym Center Bay	Manual	11/12/2025 4:45:08 PM
Smoke Detector - General	2-2-085 705	Large Gym Center Bay	Manual	11/12/2025 4:45:10 PM
Smoke Detector - General	2-2-076 698	Large Gym Center Bay	Manual	11/12/2025 4:45:13 PM
Smoke Detector - General	2-2-078 699	Large Gym Center Bay	Manual	11/12/2025 4:45:16 PM
Smoke Detector - General	2-2-077 697	Large Gym Center Bay	Manual	11/12/2025 4:45:24 PM
Smoke Detector - General	2-2-014 729	Large Gym Girls Lock Off Storage	Manual	11/12/2025 4:47:07 PM
Smoke Detector - General	2-2-012 728	Large Gym Girls Locker Room	Manual	11/12/2025 4:45:56 PM
Smoke Detector - General	2-2-043 722	Large Gym Gym Stage	Manual	11/12/2025 4:45:58 PM
Smoke Detector - General	2-2-044 721	Large Gym Gym Stage	Manual	11/12/2025 4:46:01 PM
Smoke Detector - General	2-2-098 695	Large Gym North Bay	Manual	11/12/2025 4:45:19 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-2-092 690	Large Gym North Bay	Manual	11/12/2025 4:45:21 PM
Smoke Detector - General	2-2-095 692	Large Gym North Bay	Manual	11/12/2025 4:45:27 PM
Smoke Detector - General	2-2-091 688	Large Gym North Bay	Manual	11/12/2025 4:45:29 PM
Smoke Detector - General	2-2-090 687	Large Gym North Bay	Manual	11/12/2025 4:45:35 PM
Smoke Detector - General	2-2-094 691	Large Gym North Bay	Manual	11/12/2025 4:45:38 PM
Smoke Detector - General	2-2-093 689	Large Gym North Bay	Manual	11/12/2025 4:45:40 PM
Smoke Detector - General	2-2-089 685	Large Gym North Bay	Manual	11/12/2025 4:45:43 PM
Smoke Detector - General	2-2-096 694	Large Gym North Bay	Manual	11/12/2025 4:45:45 PM
Smoke Detector - General	2-2-097 693	Large Gym North Bay	Manual	11/12/2025 4:45:47 PM
Smoke Detector - General	2-2-088 686	Large Gym North Bay	Manual	11/12/2025 4:45:50 PM
Smoke Detector - General	2-2-099 696	Large Gym North Bay	Manual	11/12/2025 4:45:53 PM
Smoke Detector - General	2-2-074 709	Large Gym South Bay	Manual	11/12/2025 4:44:05 PM
Smoke Detector - General	2-2-073 711	Large Gym South Bay	Manual	11/12/2025 4:44:11 PM
Smoke Detector - General	2-2-067 718	Large Gym South Bay	Manual	11/12/2025 4:44:13 PM
Smoke Detector - General	2-2-065 719	Large Gym South Bay	Manual	11/12/2025 4:44:16 PM
Smoke Detector - General	2-2-069 716	Large Gym South Bay	Manual	11/12/2025 4:44:18 PM
Smoke Detector - General	2-2-066 717	Large Gym South Bay	Manual	11/12/2025 4:44:21 PM
Smoke Detector - General	2-2-068 715	Large Gym South Bay	Manual	11/12/2025 4:44:25 PM
Smoke Detector - General	2-2-064 720	Large Gym South Bay	Manual	11/12/2025 4:44:29 PM
Smoke Detector - General	2-2-072 712	Large Gym South Bay	Manual	11/12/2025 4:44:32 PM
Smoke Detector - General	2-2-070 713	Large Gym South Bay	Manual	11/12/2025 4:44:35 PM
Smoke Detector - General	2-2-075 710	Large Gym South Bay	Manual	11/12/2025 4:44:38 PM
Smoke Detector - General	2-2-071 714	Large Gym South Bay	Manual	11/12/2025 4:44:45 PM

Failed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	1-3-277 270	Rooms 44-53 Bldg Classroom 51	Manual	11/10/2025 9:03:23 AM
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	
Smoke Detector - General	1-3-278 271	Rooms 44-53 Bldg Classroom 51	Manual	11/10/2025 9:03:47 AM
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	

Ventilation and Cooking Equipment

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Range Suppression Tank	Ansul R102 3 Gallon Cylinder		Manual	11/12/2025 3:52:54 PM
Range Suppression		101-20 Cartridge	Manual	11/12/2025 3:52:51 PM
Cooking Equipment		Appliances	Manual	11/12/2025 3:52:41 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Fusible Links		Fusible Links	Manual	11/12/2025 3:52:44 PM
Range Hood		Hood	Manual	11/12/2025 3:52:39 PM
Range Suppression		Suppression System	Manual	11/12/2025 3:52:48 PM

Device/Equipment details

[Other]

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
1-2-149 520	Cafeteria Building Kitchen Ansul System				

Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Audible					
046	Admin Building East Exterior				
086	Rooms 1-8 Bldg Northeast Exterior				
087	Rooms 1-8 Bldg Northeast Exterior				
088	Rooms 1-8 Bldg Southwest Exterior				
089	Rooms 1-8 Bldg Southwest Exterior				
111	Rooms 9-15 Bldg Southwest Exterior				
112	Rooms 9-15 Bldg Southwest Exterior				
136	Rooms 16-23 Bldg Southeast Exterior				
137	Rooms 16-23 Bldg Southeast Exterior				
138	Rooms 16-23 Bldg West Exterior				
163	Rooms 24-30 Bldg Northwest Exterior				
164	Rooms 24-30 Bldg Northwest Exterior				
165	Rooms 24-30 Bldg Southeast Exterior				
166	Rooms 24-30 Bldg Southeast Exterior				
185	Classroom 31 Area South Exterior				
217	Library Building East Exterior				
218	Library Building South Exterior				
219	Library Building West Exterior				
246	Rooms 40-43 Bldg East Exterior				
247	Rooms 40-43 Bldg West Exterior				
290	Rooms 44-53 Bldg Northeast Exterior				
291	Rooms 44-53 Bldg Northeast Exterior				
292	Rooms 44-53 Bldg Southwest Exterior				
293	Rooms 44-53 Bldg Southwest Exterior				
336	Rooms 54-60 Bldg Northeast Exterior				
337	Rooms 54-60 Bldg Northeast Exterior				
338	Rooms 54-60 Bldg Southwest Exterior				
364	Classroom 61 Bldg West Exterior				
365	Classroom 61 Bldg West Exterior				
384	Rooms 62-69 Bldg Northeast Exterior				
385	Rooms 62-69 Bldg Northeast Exterior				
386	Rooms 62-69 Bldg Southwest Exterior				
387	Rooms 62-69 Bldg Southwest Exterior				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
412	Rooms 70-76 Bldg Northeast Exterior				
413	Rooms 70-76 Bldg Northeast Exterior				
414	Rooms 70-76 Bldg Southwest Exterior				
415	Rooms 70-76 Bldg Southwest Exterior				
440	Rooms 77-83 Bldg Northeast Exterior				
441	Rooms 77-83 Bldg Northeast Exterior				
442	Rooms 77-83 Bldg Southwest Exterior				
465	Rooms 84-91 Bldg Northeast Exterior				
466	Rooms 84-91 Bldg Northeast Exterior				
467	Rooms 84-91 Bldg Southwest Exterior				
468	Rooms 84-91 Bldg Southwest Exterior				
559	Custodial Building East Exterior				
560	Custodial Building West Exterior				
659	Small Gym North Exterior				
660	Small Gym East Exterior				
661	Small Gym South Exterior				
662	Small Gym West Exterior				
789	Large Gym East Exterior				
790	Large Gym South Exterior				
791	Large Gym South Exterior				
792	Large Gym West Exterior				
793	Large Gym West Exterior				
831	Large Gym Northeast Exterior				
864	Stadium West Exterior				
Audible And Visible					
047	Admin Building Office Reception				
048	Admin Building Off Recept N Hall				
049	Admin Building Office Staff Room				
050	Admin Building Conference Room				
051	Admin Building Classroom 3				
090	Rooms 1-8 Bldg Classroom 1				
091	Rooms 1-8 Bldg Classroom 2				
092	Rooms 1-8 Bldg Classroom 3				
093	Rooms 1-8 Bldg Classroom 4				
094	Rooms 1-8 Bldg Classroom 5				
095	Rooms 1-8 Bldg Classroom 6				
096	Rooms 1-8 Bldg Classroom 7				
097	Rooms 1-8 Bldg Classroom 8				
113	Rooms 9-15 Bldg Classroom 9				
114	Rooms 9-15 Bldg Classroom 10				
115	Rooms 9-15 Bldg Classroom 11				
116	Rooms 9-15 Bldg Classroom 12				
117	Rooms 9-15 Bldg Classroom 13				
118	Rooms 9-15 Bldg Classroom 14				
119	Rooms 9-15 Bldg Classroom 15				
139	Rooms 16-23 Bldg Classroom 16				
140	Rooms 16-23 Bldg Classroom 17				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
141	Rooms 16-23 Bldg Classroom 18				
142	Rooms 16-23 Bldg Classroom 19				
143	Rooms 16-23 Bldg Classroom 20				
144	Rooms 16-23 Bldg Classroom 21				
145	Rooms 16-23 Bldg Classroom 22				
146	Rooms 16-23 Bldg Classroom 23				
167	Rooms 24-30 Bldg Classroom 24				
168	Rooms 24-30 Bldg Classroom 25				
169	Rooms 24-30 Bldg Classroom 26				
170	Rooms 24-30 Bldg Classroom 27				
171	Rooms 24-30 Bldg Classroom 27A				
172	Rooms 24-30 Bldg Classroom 28				
173	Rooms 24-30 Bldg Classroom 29				
174	Rooms 24-30 Bldg Classroom 30				
186	Classroom 31 Area Classroom 31				
220	Library Building Library				
221	Library Building Library				
222	Library Building Computer Lab				
223	Library Building Work Room				
224	Library Building Book Room				
225	Library Building Classroom 32				
226	Library Building Classroom 33				
227	Library Building Classroom 38				
228	Library Building Classroom 39				
248	Rooms 40-43 Bldg Classroom 40				
249	Rooms 40-43 Bldg Classroom 41				
250	Rooms 40-43 Bldg Classroom 42				
251	Rooms 40-43 Bldg Classroom 43				
294	Rooms 44-53 Bldg Classroom 44				
295	Rooms 44-53 Bldg Classroom 45				
296	Rooms 44-53 Bldg Classroom 46				
297	Rooms 44-53 Bldg Dark Room 47				
298	Rooms 44-53 Bldg Classroom 49				
299	Rooms 44-53 Bldg Classroom 50				
300	Rooms 44-53 Bldg Classroom 51				
301	Rooms 44-53 Bldg Classroom 52				
302	Rooms 44-53 Bldg Classroom 53				
303	Rooms 44-53 Bldg ROTC Classrm 2				
339	Rooms 54-60 Bldg Classroom 54				
340	Rooms 54-60 Bldg Classroom 55				
341	Rooms 54-60 Bldg Classroom 56				
342	Rooms 54-60 Bldg Classroom 57				
343	Rooms 54-60 Bldg Classroom 58				
344	Rooms 54-60 Bldg Classroom 59				
345	Rooms 54-60 Bldg Classroom 60				
366	Classroom 61 Bldg Classroom 61				
388	Rooms 62-69 Bldg Classroom 62				
389	Rooms 62-69 Bldg Classroom 63				
390	Rooms 62-69 Bldg Classroom 64				
391	Rooms 62-69 Bldg Classroom 65				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
392	Rooms 62-69 Bldg Classroom 66				
393	Rooms 62-69 Bldg Classroom 67				
394	Rooms 62-69 Bldg Classroom 68				
395	Rooms 62-69 Bldg Classroom 69				
416	Rooms 70-76 Bldg Classroom 70				
417	Rooms 70-76 Bldg Classroom 71				
418	Rooms 70-76 Bldg Classroom 72				
419	Rooms 70-76 Bldg Classroom 73				
420	Rooms 70-76 Bldg Classroom 74				
421	Rooms 70-76 Bldg Classroom 75				
422	Rooms 70-76 Bldg Classroom 76				
423	Rooms 70-76 Bldg Classroom 76A				
443	Rooms 77-83 Bldg Classroom 77				
444	Rooms 77-83 Bldg Classroom 77A				
445	Rooms 77-83 Bldg Classroom 78				
446	Rooms 77-83 Bldg Classroom 79				
447	Rooms 77-83 Bldg Classroom 80				
448	Rooms 77-83 Bldg Classroom 81				
449	Rooms 77-83 Bldg Classroom 82				
450	Rooms 77-83 Bldg Classroom 83				
469	Rooms 84-91 Bldg Classroom 84				
470	Rooms 84-91 Bldg Classroom 85				
471	Rooms 84-91 Bldg Classroom 86				
472	Rooms 84-91 Bldg Classroom 87				
473	Rooms 84-91 Bldg Classroom 88				
474	Rooms 84-91 Bldg Classroom 89				
475	Rooms 84-91 Bldg Classroom 90				
476	Rooms 84-91 Bldg Classroom 91				
521	Cafeteria Building Cafeteria				
522	Cafeteria Building Cafeteria				
523	Cafeteria Building Kitchen				
524	Cafeteria Building Hallway				
525	Cafeteria Building Hallway				
526	Cafeteria Building VP Reception				
561	Custodial Building Staff Room 1				
621	Theater Building Theater				
622	Theater Building Theater				
623	Theater Building Mens Restrm Hall				
624	Theater Building Counseling				
663	Small Gym Small Gym				
664	Small Gym Small Gym				
665	Small Gym Small Gym				
666	Small Gym Small Gym				
794	Large Gym Locker Room Hall				
795	Large Gym Locker Room Hall				
796	Large Gym Locker Room Hall				
797	Large Gym Large Gym				
798	Large Gym Large Gym				
799	Large Gym Large Gym				
800	Large Gym Large Gym				
801	Large Gym Gym Stage				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
802	Large Gym Gym Stage				
803	Large Gym Girls Locker Room				
804	Large Gym Girls Locker Room				
805	Large Gym Boys Locker Room				
806	Large Gym Boys Locker Room				
807	Large Gym Music Room 92				
808	Large Gym Music Room 93				
Visible					
052	Admin Building Office Principal				
053	Admin Building Office Reception RR				
054	Admin Building Off Recept N Office				
055	Admin Building Office Printer Room				
056	Admin Building Off Small Office 2				
057	Admin Building Off Small Office 1				
058	Admin Building Office Nurse				
059	Admin Building Office Nurse Restrm				
060	Admin Building Off NW Conf Office				
061	Admin Building Off NE Conf Office				
062	Admin Building Office S Conf Office				
063	Admin Building Office S Conf Office				
064	Admin Building Office S Conf Office				
065	Admin Building Office S Conf Office				
066	Admin Building Office South Hall				
067	Admin Building Office Mens RR				
068	Admin Building Office Womens RR				
069	Admin Building Off Recept Work Rm				
187	Classroom 31 Area Mens RR by Rm 31				
188	Classroom 31 Area Unisex RR by Rm 31				
189	Classroom 31 Area Wom RR by Rm 31				
304	Rooms 44-53 Bldg Room 48				
305	Rooms 44-53 Bldg Restrm by Rm 49				
306	Rooms 44-53 Bldg ROTC Office				
307	Rooms 44-53 Bldg ROTC Office				
308	Rooms 44-53 Bldg ROTC Rm 34 RR				
346	Rooms 54-60 Bldg Classrm 55 Finish Rm				
347	Rooms 54-60 Bldg Classrm 56 Finish Rm				
348	Rooms 54-60 Bldg Classroom 57 Tools				
349	Rooms 54-60 Bldg Metal Shop Office				
367	Classroom 61 Bldg Classroom 61 Office				
396	Rooms 62-69 Bldg Classroom 62 Hall				
527	Cafeteria Building Boys Restroom				
528	Cafeteria Building Boys Restroom				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
529	Cafeteria Building Girls Restroom				
530	Cafeteria Building Girls Restroom				
531	Cafeteria Building Mens Restroom				
532	Cafeteria Building Womens Restroom				
533	Cafeteria Building VP Office				
534	Cafeteria Building VP Office Room 1				
535	Cafeteria Building VP Office Room 2				
536	Cafeteria Building VP Office Room 3				
537	Cafeteria Building VP Office Room 4				
538	Cafeteria Building VP Office Room 5				
539	Cafeteria Building VP Boys Restroom				
540	Cafeteria Building VP Boys Restroom				
541	Cafeteria Building VP Girls Restroom				
542	Cafeteria Building VP Girls Restroom				
562	Custodial Building Office				
563	Custodial Building Restroom				
625	Theater Building Mens Restroom				
626	Theater Building Girls Restroom				
627	Theater Building Girls Restroom				
628	Theater Building Boys Restroom				
629	Theater Building Boys Restroom				
630	Theater Building Womens Restrm Hall				
631	Theater Building Womens Restroom				
632	Theater Building Counseling Office				
633	Theater Building Counseling Office 1				
634	Theater Building Counseling Office 2				
635	Theater Building Counseling Office 3				
636	Theater Building Counseling Office 4				
637	Theater Building Counseling Office 6				
638	Theater Building Counseling Office 7				
639	Theater Building Counseling Boys RR				
640	Theater Building Counseling Girls RR				
667	Small Gym Boys Restroom				
668	Small Gym Boys Restroom				
669	Small Gym Girls Restroom				
670	Small Gym Girls Restroom				
809	Large Gym Girls Locker Room				
810	Large Gym Girls Locker Room				
811	Large Gym Girls Locker Room				
812	Large Gym Girls Locker Room				
813	Large Gym Girls Locker Room				
814	Large Gym Girls Locker Room				
815	Large Gym Girls Locker Office				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
816	Large Gym Coaches Office				
817	Large Gym Coaches Office				
818	Large Gym Coaches Office RR				
819	Large Gym Coaches Office RR				
820	Large Gym Coaches Off Shower				
821	Large Gym Boys Locker Room				
822	Large Gym Boys Locker Room				
823	Large Gym Boys Locker Room				
824	Large Gym Boys Locker Room				
825	Large Gym Boys Locker Room				
826	Large Gym Boys Locker Room				
827	Large Gym Boys Locker Rm Off				
828	Large Gym Music Room Hall				
829	Large Gym Music Room 1				
830	Large Gym Music Room 2				
865	Stadium Mens Restroom				
866	Stadium Womens Restroom				

Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Remote Annunciator					
001	Admin Building Office Reception				
NAC Power Extender Panel					
070	Admin Building Data Rm/Headend				
229	Library Building Room 39 Workroom				
252	Rooms 40-43 Bldg Classroom 40				
309	Rooms 44-53 Bldg Classroom 53				
543	Cafeteria Building Data Room				
544	Cafeteria Building Data Room				
545	Cafeteria Building Data Room				
641	Theater Building Stage Storage 2				
642	Theater Building Stage Storage 2				
643	Theater Building Stage Storage 2				
671	Small Gym Data Room				
832	Large Gym Music Room				
867	Stadium Restroom Chase				

Fire Alarm Panel

	Admin Building Data Rm/Headend				
--	--------------------------------	--	--	--	--

Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Manual Pull Station					
1-2-376 002	Admin Building Office Reception				
1-2-131 477	Cafeteria Building Cafeteria North Exit				
1-2-132 478	Cafeteria Building Cafeteria NE Exit				
1-2-133 479	Cafeteria Building Cafeteria SE Exit				
1-2-134 480	Cafeteria Building Cafeteria South Exit				
1-3-132 564	Theater Building Stage North Exit				
1-3-134 565	Theater Building Northwest Exit				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
1-3-133 566	Theater Building Southwest Exit				
1-3-131 567	Theater Building Stage South Exit				
2-2-134 644	Small Gym Southwest Exit				
2-2-133 645	Small Gym Northwest Exit				
2-2-135 646	Small Gym Northeast Exit				
2-2-155 672	Large Gym Lrg Gym E Hall Exit				
2-2-154 673	Large Gym Southeast Exit				
2-2-159 674	Large Gym Northeast Exit				
2-2-160 675	Large Gym Northeast Exit				
2-2-161 676	Large Gym Northwest Exit				
2-2-162 677	Large Gym Northwest Exit				
2-2-157 678	Large Gym Southwest Exit				
2-2-156 679	Large Gym Lrg Gym W Hall Exit				
Smoke Detector - General					
1-2-253 003	Admin Building Office Reception				
1-2-263 004	Admin Building Office Principal				
1-2-264 005	Admin Building Office Principal				
1-2-252 006	Admin Building Office Principal Closet				
1-2-251 007	Admin Building Office Tele Closet				
1-2-254 008	Admin Building Off Recept N Office				
1-2-255 009	Admin Building Office Reception				
1-2-257 010	Admin Building Office Reception RR				
1-2-256 011	Admin Building Office Printer Room				
1-2-323 012	Admin Building Off Printer Rm Clst				
1-2-262 013	Admin Building Off Small Office 2				
1-2-261 014	Admin Building Off Small Office 1				
1-2-260 015	Admin Building Office Nurse				
1-2-259 016	Admin Building Office Nurse Restrm				
1-2-258 017	Admin Building Off Recept N Hall				
1-2-277 018	Admin Building Office Staff Room				
1-2-276 019	Admin Building Office Staff Room				
1-2-275 020	Admin Building Office Staff Rm Strg				
1-2-316 021	Admin Building Conference Room				
1-2-317 022	Admin Building Conference Room				
1-2-315 023	Admin Building Conference Room				
1-2-314 024	Admin Building Conference Room				
1-2-279 025	Admin Building Off NW Conf Office				
1-2-278 026	Admin Building Off NE Conf Office				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
1-2-281 027	Admin Building Office S Conf Office				
1-2-280 028	Admin Building Office S Conf Office				
1-2-282 029	Admin Building Office S Conf Office				
1-2-283 030	Admin Building Office S Conf Office				
1-2-266 031	Admin Building Classroom 3				
1-2-265 032	Admin Building Classroom 3				
1-2-273 033	Admin Building Telecom Room				
1-2-274 034	Admin Building Data Rm/Headend				
1-2-269 035	Admin Building Office South Hall				
1-2-272 036	Admin Building Office Mens RR				
1-2-267 037	Admin Building Office South Hall				
1-2-271 038	Admin Building Office Womens RR				
1-2-270 039	Admin Building Office Cust Closet				
1-2-268 040	Admin Building Off Receipt Work Rm				
1-2-031 071	Rooms 1-8 Bldg Classroom 1				
1-2-033 072	Rooms 1-8 Bldg Classroom 2				
1-2-034 073	Rooms 1-8 Bldg Classroom 2				
1-2-035 074	Rooms 1-8 Bldg Classroom 3				
1-2-032 075	Rooms 1-8 Bldg Classroom 3				
1-2-036 076	Rooms 1-8 Bldg Classroom 4				
1-2-037 077	Rooms 1-8 Bldg Classroom 4				
1-2-030 078	Rooms 1-8 Bldg Classroom 5				
1-2-042 079	Rooms 1-8 Bldg Classroom 6				
1-2-043 080	Rooms 1-8 Bldg Classroom 6				
1-2-041 081	Rooms 1-8 Bldg Classroom 7				
1-2-038 082	Rooms 1-8 Bldg Classroom 7				
1-2-039 083	Rooms 1-8 Bldg Classroom 8				
1-2-040 084	Rooms 1-8 Bldg Classroom 8				
1-2-065 098	Rooms 9-15 Bldg Classroom 9				
1-2-066 099	Rooms 9-15 Bldg Classroom 10				
1-2-068 100	Rooms 9-15 Bldg Classroom 11				
1-2-067 101	Rooms 9-15 Bldg Classroom 11				
1-2-064 102	Rooms 9-15 Bldg Room 12				
1-2-063 103	Rooms 9-15 Bldg Room 12A Storage				
1-2-072 104	Rooms 9-15 Bldg Classroom 13				
1-2-071 105	Rooms 9-15 Bldg Classroom 13				
1-2-069 106	Rooms 9-15 Bldg Classroom 14				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
1-2-070 107	Rooms 9-15 Bldg Classroom 14				
1-2-062 108	Rooms 9-15 Bldg Classroom 15				
1-2-080 120	Rooms 16-23 Bldg Classroom 16				
1-2-081 121	Rooms 16-23 Bldg Classroom 16				
1-2-082 122	Rooms 16-23 Bldg Classroom 16 Strg				
1-2-092 123	Rooms 16-23 Bldg Classroom 17				
1-2-091 124	Rooms 16-23 Bldg Classroom 18				
1-2-089 125	Rooms 16-23 Bldg Classroom 19				
1-2-090 126	Rooms 16-23 Bldg Classroom 19				
1-2-084 127	Rooms 16-23 Bldg Classroom 20				
1-2-083 128	Rooms 16-23 Bldg Room 20A Storage				
1-2-085 129	Rooms 16-23 Bldg Classroom 21				
1-2-086 130	Rooms 16-23 Bldg Classroom 21				
1-2-087 131	Rooms 16-23 Bldg Classroom 22				
1-2-088 132	Rooms 16-23 Bldg Classroom 23				
1-2-057 147	Rooms 24-30 Bldg Classroom 24				
1-2-056 148	Rooms 24-30 Bldg Classroom 24				
1-2-052 149	Rooms 24-30 Bldg Classroom 25				
1-2-055 150	Rooms 24-30 Bldg Classroom 25				
1-2-053 151	Rooms 24-30 Bldg Classroom 26				
1-2-054 152	Rooms 24-30 Bldg Classroom 26				
1-2-045 153	Rooms 24-30 Bldg Classroom 27				
1-2-044 154	Rooms 24-30 Bldg Classroom 27A				
1-2-048 155	Rooms 24-30 Bldg Classroom 28				
1-2-047 156	Rooms 24-30 Bldg Classroom 28				
1-2-046 157	Rooms 24-30 Bldg Classroom 29				
1-2-049 158	Rooms 24-30 Bldg Classroom 29				
1-2-050 159	Rooms 24-30 Bldg Classroom 30				
1-2-051 160	Rooms 24-30 Bldg Classroom 30				
1-2-299 190	Library Building Library				
1-2-291 191	Library Building Library				
1-2-292 192	Library Building Library				
1-2-293 193	Library Building Library				
1-2-294 194	Library Building Library				
1-2-302 195	Library Building Library				
1-2-301 196	Library Building Library				
1-2-300 197	Library Building Library				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
1-2-304 198	Library Building Library				
1-2-303 199	Library Building Library				
1-2-305 200	Library Building Library				
1-2-285 201	Library Building Computer Lab				
1-2-287 202	Library Building Computer Lab				
1-2-289 203	Library Building Computer Lab				
1-2-284 204	Library Building Work Room				
1-2-290 205	Library Building Book Room				
1-2-298 206	Library Building Classroom 32				
1-2-297 207	Library Building Classroom 32				
1-2-296 208	Library Building Classroom 33				
1-2-295 209	Library Building Classroom 33				
1-2-288 210	Library Building Classroom 38				
1-2-286 211	Library Building Classroom 38				
1-2-320 212	Library Building Room 38				
1-2-318 213	Library Building Room 39				
1-2-319 214	Library Building Room 39				
1-3-252 253	Rooms 44-53 Bldg Classroom 44				
1-3-253 254	Rooms 44-53 Bldg Classroom 44				
1-3-254 255	Rooms 44-53 Bldg Classroom 45				
1-3-255 256	Rooms 44-53 Bldg Classroom 45				
1-3-257 257	Rooms 44-53 Bldg Classroom 46				
1-3-256 258	Rooms 44-53 Bldg Classroom 46				
1-3-269 259	Rooms 44-53 Bldg Dark Room 47				
1-3-270 260	Rooms 44-53 Bldg Dark Room 47				
1-3-272 261	Rooms 44-53 Bldg Room 48				
1-3-271 262	Rooms 44-53 Bldg Room 48 Storage				
1-3-282 263	Rooms 44-53 Bldg Classroom 49				
1-3-281 264	Rooms 44-53 Bldg Classroom 49				
1-3-283 265	Rooms 44-53 Bldg Restrm by Rm 49				
1-3-279 266	Rooms 44-53 Bldg Classroom 50				
1-3-280 267	Rooms 44-53 Bldg Classroom 50				
1-3-274 268	Rooms 44-53 Bldg Classrm 50 Storage				
1-3-273 269	Rooms 44-53 Bldg Classrm 50 Storage				
1-3-277 270	Rooms 44-53 Bldg Classroom 51				
1-3-278 271	Rooms 44-53 Bldg Classroom 51				
1-3-264 272	Rooms 44-53 Bldg Classrm 51 Storage				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
1-3-265 273	Rooms 44-53 Bldg Classrm 51 Storage				
1-3-275 274	Rooms 44-53 Bldg Classroom 52				
1-3-276 275	Rooms 44-53 Bldg Classroom 52				
1-3-251 276	Rooms 44-53 Bldg Classroom 53				
1-3-262 277	Rooms 44-53 Bldg Room 53 Wash Clst				
1-3-263 278	Rooms 44-53 Bldg Room 53 Storage				
1-3-267 279	Rooms 44-53 Bldg ROTC Office				
1-3-268 280	Rooms 44-53 Bldg ROTC Office				
1-3-266 281	Rooms 44-53 Bldg ROTC Classrm 2				
1-3-258 282	Rooms 44-53 Bldg ROTC Storage				
1-3-259 283	Rooms 44-53 Bldg ROTC Cust Closet				
1-3-261 284	Rooms 44-53 Bldg ROTC Rm 34 RR				
1-3-260 285	Rooms 44-53 Bldg ROTC Rm 34 Cust				
1-3-086 368	Rooms 62-69 Bldg Classroom 62				
1-3-084 369	Rooms 62-69 Bldg Classroom 62				
1-3-087 370	Rooms 62-69 Bldg Classroom 62				
1-3-085 371	Rooms 62-69 Bldg Classroom 62 Hall				
1-3-091 372	Rooms 62-69 Bldg Classroom 63				
1-3-090 373	Rooms 62-69 Bldg Classroom 63				
1-3-088 374	Rooms 62-69 Bldg Classroom 64				
1-3-089 375	Rooms 62-69 Bldg Classroom 65				
1-3-082 376	Rooms 62-69 Bldg Classroom 66				
1-3-083 377	Rooms 62-69 Bldg Classroom 66				
1-3-093 378	Rooms 62-69 Bldg Classroom 67				
1-3-092 379	Rooms 62-69 Bldg Classroom 68				
1-3-094 380	Rooms 62-69 Bldg Classroom 69				
1-3-095 381	Rooms 62-69 Bldg Classroom 69				
1-3-056 397	Rooms 70-76 Bldg Classroom 70				
1-3-057 398	Rooms 70-76 Bldg Classroom 70				
1-3-055 399	Rooms 70-76 Bldg Classroom 71				
1-3-058 400	Rooms 70-76 Bldg Classroom 71				
1-3-059 401	Rooms 70-76 Bldg Classroom 72				
1-3-060 402	Rooms 70-76 Bldg Classroom 72				
1-3-066 403	Rooms 70-76 Bldg Classroom 73				
1-3-065 404	Rooms 70-76 Bldg Classroom 73				
1-3-064 405	Rooms 70-76 Bldg Classroom 74				
1-3-061 406	Rooms 70-76 Bldg Classroom 74				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
1-3-063 407	Rooms 70-76 Bldg Classroom 75				
1-3-062 408	Rooms 70-76 Bldg Classroom 75				
1-3-054 409	Rooms 70-76 Bldg Classroom 76				
1-3-053 410	Rooms 70-76 Bldg Classroom 76A				
1-3-068 424	Rooms 77-83 Bldg Room 77				
1-3-069 425	Rooms 77-83 Bldg Room 77				
1-3-067 426	Rooms 77-83 Bldg Classroom 77A				
1-3-080 427	Rooms 77-83 Bldg Classroom 78				
1-3-081 428	Rooms 77-83 Bldg Classroom 78				
1-3-079 429	Rooms 77-83 Bldg Classroom 79				
1-3-076 430	Rooms 77-83 Bldg Classroom 79				
1-3-077 431	Rooms 77-83 Bldg Classroom 80				
1-3-078 432	Rooms 77-83 Bldg Classroom 80				
1-3-071 433	Rooms 77-83 Bldg Classroom 81				
1-3-072 434	Rooms 77-83 Bldg Classroom 81				
1-3-073 435	Rooms 77-83 Bldg Classroom 82				
1-3-070 436	Rooms 77-83 Bldg Classroom 82				
1-3-074 437	Rooms 77-83 Bldg Classroom 83				
1-3-075 438	Rooms 77-83 Bldg Classroom 83				
1-3-106 451	Rooms 84-91 Bldg Classroom 84				
1-3-107 452	Rooms 84-91 Bldg Classroom 84				
1-3-104 453	Rooms 84-91 Bldg Classroom 85				
1-3-105 454	Rooms 84-91 Bldg Classroom 86				
1-3-096 455	Rooms 84-91 Bldg Classroom 87				
1-3-097 456	Rooms 84-91 Bldg Classroom 87				
1-3-101 457	Rooms 84-91 Bldg Classroom 88				
1-3-100 458	Rooms 84-91 Bldg Classroom 89				
1-3-102 459	Rooms 84-91 Bldg Classroom 90				
1-3-103 460	Rooms 84-91 Bldg Classroom 90				
1-3-099 461	Rooms 84-91 Bldg Classroom 91				
1-3-098 462	Rooms 84-91 Bldg Classroom 91 Strg				
1-2-096 481	Cafeteria Building Cafeteria				
1-2-099 482	Cafeteria Building Cafeteria				
1-2-100 483	Cafeteria Building Cafeteria				
1-2-097 484	Cafeteria Building Cafeteria				
1-2-098 485	Cafeteria Building Cafeteria				
1-2-101 486	Cafeteria Building Cafeteria				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
1-2-005 487	Cafeteria Building Cafeteria Storage				
1-2-001 488	Cafeteria Building Data Room				
1-2-006 489	Cafeteria Building Kitchen Office				
1-2-008 490	Cafeteria Building Boys Restroom				
1-2-007 491	Cafeteria Building Boys Restroom				
1-2-002 492	Cafeteria Building Girls Restroom				
1-2-003 493	Cafeteria Building Girls Restroom				
1-2-009 494	Cafeteria Building Hallway				
1-2-010 495	Cafeteria Building Mens Restroom				
1-2-011 496	Cafeteria Building Mens Restrm Storage				
1-2-016 497	Cafeteria Building Womens Restroom				
1-2-018 498	Cafeteria Building Wom Restrm Strg				
1-2-017 499	Cafeteria Building Wom Restrm Strg				
1-2-013 500	Cafeteria Building Tele Room				
1-2-015 501	Cafeteria Building Hallway				
1-2-024 502	Cafeteria Building VP Reception				
1-2-023 503	Cafeteria Building VP Reception				
1-2-014 504	Cafeteria Building VP Office				
1-2-027 505	Cafeteria Building VP Office Room 1				
1-2-022 506	Cafeteria Building VP Office Room 2				
1-2-026 507	Cafeteria Building VP Office Room 3				
1-2-020 508	Cafeteria Building VP Office Room 4				
1-2-021 509	Cafeteria Building VP Office Room 5				
1-2-025 510	Cafeteria Building VP Boys Restroom				
1-2-019 511	Cafeteria Building VP Girls Restroom				
1-2-075 546	Custodial Building Staff Room 1				
1-2-076 547	Custodial Building Storage				
1-2-073 548	Custodial Building Storage				
1-2-077 549	Custodial Building Office				
1-2-078 550	Custodial Building Storage				
1-2-095 551	Custodial Building Hall				
1-2-094 552	Custodial Building Washroom				
1-2-079 553	Custodial Building Restroom				
1-2-074 554	Custodial Building Storage				
1-3-041 568	Theater Building Theater				
1-3-047 569	Theater Building Theater				
1-3-046 570	Theater Building Theater				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
1-3-040 571	Theater Building Theater				
1-3-039 572	Theater Building Theater				
1-3-045 573	Theater Building Theater				
1-3-044 574	Theater Building Theater				
1-3-038 575	Theater Building Theater				
1-3-037 576	Theater Building Theater				
1-3-043 577	Theater Building Theater				
1-3-042 578	Theater Building Theater				
1-3-036 579	Theater Building Theater				
1-3-001 580	Theater Building Data Room				
1-3-010 581	Theater Building Dressing Room				
1-3-011 582	Theater Building Dressing Room				
1-3-008 583	Theater Building Green Room Hall				
1-3-019 584	Theater Building Green Room				
1-3-009 585	Theater Building Work Room				
1-3-015 586	Theater Building Theater Storage				
1-3-035 587	Theater Building Theater Storage				
1-3-034 588	Theater Building Theater Storage				
1-3-033 589	Theater Building Theater Storage				
1-3-048 590	Theater Building Snack Storage				
1-3-007 591	Theater Building Tele Room				
1-3-006 592	Theater Building Mens Restrm Storage				
1-3-005 593	Theater Building Mens Restroom				
1-3-004 594	Theater Building Mens Restrm Hall				
1-3-002 595	Theater Building Girls Restroom				
1-3-003 596	Theater Building Girls Restroom				
1-3-014 597	Theater Building Boys Restroom				
1-3-013 598	Theater Building Boys Restroom				
1-3-012 599	Theater Building Womens Restrm Hall				
1-3-016 600	Theater Building Womens Restroom				
1-3-018 601	Theater Building Womens RR Storage				
1-3-017 602	Theater Building Womens RR Storage				
1-3-026 603	Theater Building Counseling				
1-3-025 604	Theater Building Counseling				
1-3-021 605	Theater Building Counseling Office				
1-3-032 606	Theater Building Counseling Office 1				
1-3-024 607	Theater Building Counseling Office 2				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
1-3-030 608	Theater Building Counseling Office 3				
1-3-029 609	Theater Building Counseling Office 4				
1-3-022 610	Theater Building Counseling Office 6				
1-3-027 611	Theater Building Counseling Office 7				
1-3-031 612	Theater Building Couns Office 4 Hall				
1-3-023 613	Theater Building Couns Office 5 Hall				
1-3-028 614	Theater Building Counseling Boys RR				
1-3-020 615	Theater Building Counseling Girls RR				
2-2-002 647	Small Gym Data Room				
2-2-004 648	Small Gym Boys Restroom				
2-2-003 649	Small Gym Boys Restroom				
2-2-005 650	Small Gym Girls Restroom				
2-2-006 651	Small Gym Girls Restroom				
2-2-021 652	Small Gym Custodial Room				
2-2-007 653	Small Gym Storage Room				
2-2-040 680	Large Gym Locker Room Hall				
2-2-039 681	Large Gym Locker Room Hall				
2-2-038 682	Large Gym Locker Room Hall				
2-2-041 683	Large Gym Locker Room Hall				
2-2-042 684	Large Gym Locker Room Hall				
2-2-089 685	Large Gym North Bay				
2-2-088 686	Large Gym North Bay				
2-2-090 687	Large Gym North Bay				
2-2-091 688	Large Gym North Bay				
2-2-093 689	Large Gym North Bay				
2-2-092 690	Large Gym North Bay				
2-2-094 691	Large Gym North Bay				
2-2-095 692	Large Gym North Bay				
2-2-097 693	Large Gym North Bay				
2-2-096 694	Large Gym North Bay				
2-2-098 695	Large Gym North Bay				
2-2-099 696	Large Gym North Bay				
2-2-077 697	Large Gym Center Bay				
2-2-076 698	Large Gym Center Bay				
2-2-078 699	Large Gym Center Bay				
2-2-079 700	Large Gym Center Bay				
2-2-081 701	Large Gym Center Bay				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-2-080 702	Large Gym Center Bay				
2-2-082 703	Large Gym Center Bay				
2-2-083 704	Large Gym Center Bay				
2-2-085 705	Large Gym Center Bay				
2-2-084 706	Large Gym Center Bay				
2-2-086 707	Large Gym Center Bay				
2-2-087 708	Large Gym Center Bay				
2-2-074 709	Large Gym South Bay				
2-2-075 710	Large Gym South Bay				
2-2-073 711	Large Gym South Bay				
2-2-072 712	Large Gym South Bay				
2-2-070 713	Large Gym South Bay				
2-2-071 714	Large Gym South Bay				
2-2-068 715	Large Gym South Bay				
2-2-069 716	Large Gym South Bay				
2-2-066 717	Large Gym South Bay				
2-2-067 718	Large Gym South Bay				
2-2-065 719	Large Gym South Bay				
2-2-064 720	Large Gym South Bay				
2-2-044 721	Large Gym Gym Stage				
2-2-043 722	Large Gym Gym Stage				
2-2-019 723	Large Gym Girls Locker Room				
2-2-020 724	Large Gym Girls Locker Cust Clst				
2-2-010 725	Large Gym Girls Locker Room				
2-2-022 726	Large Gym Girls Locker RR				
2-2-011 727	Large Gym Girls Locker Office				
2-2-012 728	Large Gym Girls Locker Room				
2-2-014 729	Large Gym Girls Lock Off Storage				
2-2-013 730	Large Gym Girls Locker Office				
2-2-018 731	Large Gym Girls Locker Room				
2-2-017 732	Large Gym Girls Locker Room				
2-2-015 733	Large Gym Girls Locker Storage				
2-2-016 734	Large Gym Girls Locker Storage				
2-2-023 735	Large Gym Girls Lock Hall Storage				
2-2-024 736	Large Gym Coaches Office				
2-2-025 737	Large Gym Coaches Office				
2-2-028 738	Large Gym Boys Locker Room				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-2-029 739	Large Gym Boys Locker Room				
2-2-030 740	Large Gym Boys Locker Room				
2-2-026 741	Large Gym Boys Locker Room				
2-2-031 742	Large Gym Boys Locker Rm Off				
2-2-032 743	Large Gym Boys Locker Room				
2-2-034 744	Large Gym Boys Locker Rm Strg				
2-2-036 745	Large Gym Boys Locker Rm Strg				
2-2-037 746	Large Gym Boys Locker Room				
2-2-035 747	Large Gym Boys Locker Rm Strg				
2-2-033 748	Large Gym Boys Locker Rm Strg				
2-2-061 749	Large Gym Large Gym Boys RR				
2-2-009 750	Large Gym Large Gym Girls RR				
2-2-053 751	Large Gym Music Room 92				
2-2-054 752	Large Gym Music Room 92				
2-2-055 753	Large Gym Music Room 92				
2-2-052 754	Large Gym Music Room 92				
2-2-047 755	Large Gym Music Storage				
2-2-048 756	Large Gym Music Band Storage				
2-2-049 757	Large Gym Music Room Hall				
2-2-050 758	Large Gym Music Room 1				
2-2-051 759	Large Gym Music Room 2				
2-2-046 760	Large Gym Music Room 93				
2-2-045 761	Large Gym Music Room 93				
2-2-056 833	Weight Room Bldg Weight Room				
2-2-057 834	Weight Room Bldg Weight Room				
2-2-058 835	Weight Room Bldg Weight Room				
2-2-059 836	Weight Room Bldg Weight Rm Classrm				
2-2-060 837	Weight Room Bldg Weight Rm Classrm				
2-2-101 859	Stadium Mens Restroom				
2-2-100 860	Stadium Womens Restroom				
2-3-002	Smoke innovations hall				
2-3-018	Smoke fire training				
2-3-020	Smoke fire training				
2-3-021	Fire training storage				
2-3-014	Fire training storage N				
2-3-010	Smoke fire training storage				
2-3-028	Smoke innovation W				
2-3-030	Smoke innovation				
2-3-031	Smoke innovation E				
2-3-032	Smoke innovation Entrance S				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-3-033	Smoke innovation Entrance				
2-3-034	Smoke innovation entrance N				
2-3-007	Smoke Fab Lab W				
2-3-008	Smoke Fab Lab				
2-3-005	Smoke Fab Lab				
2-3-004	Fab Lab E.				
2-3-002	IDF/AV Room				
2-3-035	Broadcast Room				
2-3-037	Broadcast Room North				
2-3-039	Hall				
2-3-041	Broadcast Room Control Room				
2-3-042	Broadcast Room Studio				
2-3-044	Broadcast Room Studio				
2-3-047	Edit Booth				
2-3-046	Edit Booth				
2-3-045	Edit Booth				
2-3-003	Secure Storage Rm				
2-3-009	Fab Lab Storage				
2-3-026	Comp Tech East				
2-3-023	Comp Tech West				
2-3-024	Comp Tech South West				
2-3-027	Comp Tech North East				
Heat Detector - Restorable Spot					
1-2-380 041	Admin Building Attic N Off Conf Rm				
1-2-380 042	Admin Building Attic N Off Conf Rm				
1-2-381 043	Admin Building Attic S Off Conf Rm				
1-2-381 044	Admin Building Attic S Off Conf Rm				
1-2-145 109	Rooms 9-15 Bldg Attic Classroom 15				
1-2-145 110	Rooms 9-15 Bldg Attic Classroom 15				
1-2-148 133	Rooms 16-23 Bldg Attic Classroom 16				
1-2-148 134	Rooms 16-23 Bldg Attic Classroom 16				
1-2-148 135	Rooms 16-23 Bldg Attic Classroom 20				
1-2-139 161	Rooms 24-30 Bldg Cust Strg W Rm 27				
1-2-386 215	Library Building Attic Library Book Rm				
1-2-386 216	Library Building Attic Library Book Rm				
1-3-377 286	Rooms 44-53 Bldg ROTC Wtr Htr Clst				
1-3-379 287	Rooms 44-53 Bldg Kiln Room				
1-3-378 288	Rooms 44-53 Bldg Attic Dark Room 47				
1-3-376 289	Rooms 44-53 Bldg Attic Room 53				
1-3-137 382	Rooms 62-69 Bldg Attic Classroom 66				
1-3-137 383	Rooms 62-69 Bldg Attic Classroom 66				
1-3-138 463	Rooms 84-91 Bldg Attic Classroom 87				
1-3-138 464	Rooms 84-91 Bldg Attic Classroom 87				
1-2-004 512	Cafeteria Building Kitchen				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
1-2-012 513	Cafeteria Building Snack Shack				
1-2-135 514	Cafeteria Building Attic Kitchen				
1-2-135 515	Cafeteria Building Attic Kitchen				
1-2-136 516	Cafeteria Building Attic VP Office				
1-2-136 517	Cafeteria Building Attic VP Office				
1-2-151 518	Cafeteria Building Attic VP Office 4				
1-2-147 555	Custodial Building Mechanical Room				
1-2-147 556	Custodial Building Mechanical Room				
1-2-146 557	Custodial Building Attic Custodial Office				
1-3-049 616	Theater Building Snack Shack				
1-3-127 617	Theater Building Attic Theater Workrm				
1-3-130 618	Theater Building Attic Counseling Off 4				
1-3-129 619	Theater Building Attic Counseling Off 5				
2-2-147 654	Small Gym Mech Chase				
2-2-148 655	Small Gym Attic Small Gym				
2-2-137 762	Large Gym Girls Locker Room				
2-2-137 763	Large Gym Girls Locker Room				
2-2-138 764	Large Gym Girls Locker Room				
2-2-141 765	Large Gym Coaches Office RR				
2-2-140 766	Large Gym Coaches Office RR				
2-2-142 767	Large Gym Coaches Office RR				
2-2-143 768	Large Gym Coaches Off Shower				
2-2-139 769	Large Gym Girls Boiler Room E				
2-2-136 770	Large Gym Girls Boiler Room W				
2-2-144 771	Large Gym Boys Locker Boiler				
2-2-145 772	Large Gym Boys Locker Room				
2-2-145 773	Large Gym Boys Locker Room				
2-2-146 774	Large Gym Boys Locker Room				
2-2-008 775	Large Gym Snack Shack				
2-2-158 776	Large Gym Lrg Gym Trophy Case				
2-2-147 777	Large Gym Lrg Gym Under Stage				
2-2-147 778	Large Gym Lrg Gym Under Stage				
2-2-147 779	Large Gym Lrg Gym Under Stage				
2-2-169 780	Large Gym Attic Music Clsm 92				
2-2-163 781	Large Gym Attic Music Clsm 93				
2-2-164 782	Large Gym Attic Music Storage				
2-2-164 783	Large Gym Attic Music Storage				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-2-166 838	Weight Room Bldg Attic Weight Room				
2-2-166 839	Weight Room Bldg Attic Weight Room				
2-2-166 840	Weight Room Bldg Attic Weight Room				
2-2-166 841	Weight Room Bldg Attic Weight Room				
2-2-166 842	Weight Room Bldg Attic Weight Room				
2-2-166 843	Weight Room Bldg Attic Weight Room				
2-2-166 844	Weight Room Bldg Attic Weight Room				
2-2-166 845	Weight Room Bldg Attic Weight Room				
2-2-166 846	Weight Room Bldg Attic Weight Room				
2-2-167 847	Weight Room Bldg Attic Weight Room				
2-2-167 848	Weight Room Bldg Attic Weight Room				
2-2-167 849	Weight Room Bldg Attic Weight Room				
2-2-167 850	Weight Room Bldg Attic Weight Room				
2-2-167 851	Weight Room Bldg Attic Weight Room				
2-2-167 852	Weight Room Bldg Attic Weight Room				
2-2-167 853	Weight Room Bldg Attic Weight Room				
2-2-167 854	Weight Room Bldg Attic Weight Room				
2-2-167 855	Weight Room Bldg Attic Weight Room				
2-2-167 856	Weight Room Bldg Attic Weight Room				
2-2-168 857	Weight Room Bldg Attic Wght Rm Clsm				
2-2-168 858	Weight Room Bldg Attic Wght Rm Clsm				
2-2-180 861	Stadium Attic Restrooms				
2-2-180 862	Stadium Attic Restrooms				
2-2-180 863	Stadium Attic Restrooms				
2.3.150	Attic Fire Training Rm				
2.3.015	I building Fire Training E Rm I102				
2.3.017	I Building Fire Training W Rm I102				
2.3.013	I Building Fire Training Rm I102				
2.3.011	I Building Fire Training Rm I102				
2.3.151	I Building Attic Comp Tech Rm I103				
2.3.152	I Building Attic Broadcast Rm I104				
2.3.153	I Building Broadcast Rm I105				
Smoke Detector - Duct					
1-2-377 045	Admin Building Office				
1-2-137 085	Rooms 1-8 Bldg Classroom 1				
1-2-138 162	Rooms 24-30 Bldg Classroom 27				
1-3-135 411	Rooms 70-76 Bldg Classroom 76A				
1-3-136 439	Rooms 77-83 Bldg Classroom 77				
1-2-150 519	Cafeteria Building VP Office				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
1-2-202 558	Custodial Building Custodial Office				
1-3-128 620	Theater Building Theater Office 7				
2-2-177 784	Large Gym Boys Locker Room				
2-2-176 785	Large Gym Girls Locker Room				
2-2-165 786	Large Gym Music Building				
Smoke Detector - Projected Beam					
2-2-128 656	Small Gym Beam East				
2-2-130 657	Small Gym Beam Middle				
2-2-132 658	Small Gym Beam West				
Mechanical, Electrosonic, or Pressure Waterflow Device					
2-2-174 787	Large Gym Band Storage				
2-3-139	Building I				
2.4.151	North Corridor R114				02/15/2023
Valve Tamper Switch					
2-2-175 788	Large Gym Band Storage				
Ventilation and Cooking Equipment					
ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Range Suppression Tank					
	Ansul R102 3 Gallon Cylinder				01/01/2014
Range Suppression					
	101-20 Cartridge				01/01/2014
	Suppression System				01/01/2014
Fusible Links					
	Fusible Links				09/03/2025
Cooking Equipment					
	Appliances				01/01/2014
Range Hood					
	Hood				01/01/2014