

Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

KENNETH AVENUE ADMIN

4825 KENNETH AVE
CARMICHAEL, California
United States

This site has been inspected and tested in compliance with applicable standards.

Completed

Thursday, October 30, 2025

Test Session:29 Oct 2025 10:02 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD
5320 HEMLOCK ST
SACRAMENTO, California
United States

TESTED BY

Riley Goyet
Western States Fire Protection-
Sacramento
188 Cirby Way
Roseville, CA 95678
United States



Inspection Summary

Building Information

PROPERTY	KENNETH AVENUE ADMIN	CONTACT
ADDRESS	4825 KENNETH AVE	PHONE
CITY/STATE	CARMICHAEL, California	MOBILE
COUNTRY	United States	EMAIL

Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us

Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Alarm Notification Appliance	48	48(100%)	48(100%)	0(0%)
Fire Control Panel	4	4(100%)	1(25%)	3(75%)
Initiating Device	98	98(100%)	98(100%)	0(0%)
Power Supplies	1	1(100%)	1(100%)	0(0%)

Certification

The equipment specified here in was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Thursday, October 30, 2025

ACCEPTED BY 10/30/2025

Building Representative

TESTED BY 10/30/2025
Riley Goyet
Technician



System Details

Control Units

ADDRESS/ SCAN ADDRESS	/ 056	DESCRIPTION	Rooms 4 5 Bldg Elect Rm By Rm 5
MANUFACTURER	Honeywell	S/W VERSION	
MODEL		LAST UPDATE	
SERIAL NUMBER		S/W LOCATION	
INSTALL DATE			

Primary Power

ADDRESS/ SCAN ADDRESS	/ 057	DESCRIPTION	Rooms 4 5 Bldg Elect Rm By Rm 5
TYPE	Primary Power	PROTECTION	
NOMINAL VOLTAGE		AMPS	
NOMINAL AMPS		DISCONNECT	
LOCATION			

Open Corrective Action & Solution Summary

The following 3 corrective action(s) remain open following the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
Fire Alarm Panel	056	Rooms 4 5 Bldg Elect Rm By Rm 5
	Created By:	
	Creation Date:	11/21/2022
	Corrective Action:	Replace (2) 12V 55AH Batteries
	Proposed Solution:	
	Manufacturer:	Honeywell
	Model:	
NAC Power Extender Panel		Panel A
	Created By:	Riley Goyet
	Creation Date:	11/07/2024
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
NAC Power Extender Panel		Panel B
	Created By:	Riley Goyet
	Creation Date:	11/07/2024
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	

Testing Details

Alarm Notification Appliance

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible	016	Admin Area Hall	Manual	10/29/2025 10:03:19 AM
		Visual inspection	Passed (Manual)	
Visible	018	Admin Area Mens Restroom North	Manual	10/29/2025 10:03:24 AM
		Visual inspection	Passed (Manual)	
Audible	013	Admin Area North Exterior	Manual	10/29/2025 10:03:40 AM
		Functional Inspection	Passed	
Visible	017	Admin Area Office	Manual	10/29/2025 10:03:23 AM
		Visual inspection	Passed (Manual)	
Visible	014	Admin Area Reception	Manual	10/29/2025 10:03:18 AM
		Functional Inspection	Passed	
Visible	015	Admin Area Reception Office	Manual	10/29/2025 10:03:21 AM
		Visual inspection	Passed (Manual)	
Visible	019	Admin Area Womens RR North	Manual	10/29/2025 10:03:26 AM
		Functional Inspection	Passed	
Audible And Visible	146	Multi-Purpose Bldg Classroom 15	Manual	10/29/2025 10:03:42 AM
		Visual inspection	Passed (Manual)	
Audible	141	Multi-Purpose Bldg East Exterior	Manual	10/29/2025 10:03:49 AM
		Functional Inspection	Passed	
Visible	147	Multi-Purpose Bldg IMC Hall	Manual	10/29/2025 10:03:30 AM
		Visual inspection	Passed (Manual)	
Visible	149	Multi-Purpose Bldg IMC Office	Manual	10/29/2025 10:03:27 AM
		Functional Inspection	Passed	
Visible	148	Multi-Purpose Bldg IMC Office	Manual	10/29/2025 10:03:29 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	145	Multi-Purpose Bldg Kitchen	Manual	10/29/2025 10:03:43 AM
		Functional Inspection	Passed	
Audible And Visible	144	Multi-Purpose Bldg MP Room	Manual	10/29/2025 10:03:45 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	143	Multi-Purpose Bldg MP Room	Manual	10/29/2025 10:03:46 AM
		Functional Inspection	Passed	
Audible	140	Multi-Purpose Bldg North Exterior	Manual	10/29/2025 10:03:51 AM
		Visual inspection	Passed (Manual)	
Audible	142	Multi-Purpose Bldg West Exterior	Manual	10/29/2025 10:03:48 AM
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	111	Rooms 10-14 Bldg Classroom 10	Manual	10/29/2025 10:03:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	112	Rooms 10-14 Bldg Classroom 11	Manual	10/29/2025 10:03:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	113	Rooms 10-14 Bldg Classroom 12	Manual	10/29/2025 10:03:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	114	Rooms 10-14 Bldg Classroom 13	Manual	10/29/2025 10:03:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	115	Rooms 10-14 Bldg Classroom 14	Manual	10/29/2025 10:03:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	110	Rooms 10-14 Bldg East Exterior	Manual	10/29/2025 10:04:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	117	Rooms 10-14 Bldg Mens RR by Rm 14	Manual	10/29/2025 10:03:32 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	109	Rooms 10-14 Bldg North Exterior	Manual	10/29/2025 10:04:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	108	Rooms 10-14 Bldg North Exterior	Manual	10/29/2025 10:04:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	107	Rooms 10-14 Bldg North Exterior	Manual	10/29/2025 10:04:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	116	Rooms 10-14 Bldg Womens RR by 14	Manual	10/29/2025 10:03:33 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	031	Rooms 1-3 Bldg Classroom 1	Manual	10/29/2025 10:04:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	032	Rooms 1-3 Bldg Classroom 2	Manual	10/29/2025 10:04:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	033	Rooms 1-3 Bldg Classroom 3	Manual	10/29/2025 10:04:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	029	Rooms 1-3 Bldg North Exterior	Manual	10/29/2025 10:04:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	030	Rooms 1-3 Bldg North Exterior	Manual	10/29/2025 10:04:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	052	Rooms 4 5 Bldg Classroom 4	Manual	10/29/2025 10:04:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	055	Rooms 4 5 Bldg Classroom 4 RR	Manual	10/29/2025 10:03:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible	054	Rooms 4 5 Bldg Classroom 4 RR	Manual	10/29/2025 10:03:39 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	053	Rooms 4 5 Bldg Classroom 5	Manual	10/29/2025 10:04:16 AM
		Visual inspection	Passed (Manual)	
Audible	051	Rooms 4 5 Bldg North Exterior	Manual	10/29/2025 10:04:19 AM
		Visual inspection	Passed (Manual)	
Audible	050	Rooms 4 5 Bldg North Exterior	Manual	10/29/2025 10:04:20 AM
		Visual inspection	Passed (Manual)	
Visible	083	Rooms 6-9 Bldg Boys RR by Rm 9	Manual	10/29/2025 10:03:36 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	079	Rooms 6-9 Bldg Classroom 6	Manual	10/29/2025 10:04:10 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	080	Rooms 6-9 Bldg Classroom 7	Manual	10/29/2025 10:04:07 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	081	Rooms 6-9 Bldg Classroom 8	Manual	10/29/2025 10:04:09 AM
		Visual inspection	Passed (Manual)	
Audible And Visible	082	Rooms 6-9 Bldg Classroom 9	Manual	10/29/2025 10:04:06 AM
		Visual inspection	Passed (Manual)	
Visible	084	Rooms 6-9 Bldg Girls RR by Rm 9	Manual	10/29/2025 10:03:34 AM
		Visual inspection	Passed (Manual)	
Audible	077	Rooms 6-9 Bldg North Exterior	Manual	10/29/2025 10:04:12 AM
		Visual inspection	Passed (Manual)	
Audible	078	Rooms 6-9 Bldg North Exterior	Manual	10/29/2025 10:04:13 AM
		Visual inspection	Passed (Manual)	
Audible	076	Rooms 6-9 Bldg North Exterior	Manual	10/29/2025 10:04:15 AM
		Visual inspection	Passed (Manual)	

Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Remote Annunciator	001	Admin Area Reception	Manual	10/30/2025 10:03:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Failed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
NAC Power Extender Panel		Panel A	Manual	10/30/2025 10:03:39 AM
		Visual inspection	Failed (Manual)	
NAC Power Extender Panel		Panel B	Manual	10/30/2025 10:03:34 AM
		Visual inspection	Failed (Manual)	
Fire Alarm Panel	056	Rooms 4 5 Bldg Elect Rm By Rm 5	Manual	10/30/2025 10:03:44 AM
		Manufacturer	Honeywell	
		Visual inspection	Failed (Manual)	

Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-150 012	Admin Area Attic Office Hall	Manual	10/30/2025 10:05:28 AM
		Visual inspection	Passed (Manual)	
Manual Pull Station	2-149 002	Admin Area Entry	Manual	10/30/2025 10:05:35 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-061 006	Admin Area Hall	Manual	10/30/2025 10:05:37 AM
		Functional Inspection	Passed	
Smoke Detector - General	2-058 009	Admin Area Mens Restroom North	Manual	10/30/2025 10:05:32 AM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	2-057 011	Admin Area Mens RR N Closet	Manual	10/30/2025 10:05:30 AM
		Functional Inspection	Passed	
Smoke Detector - General	2-060 007	Admin Area Office	Manual	10/30/2025 10:03:27 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-063 008	Admin Area Office	Manual	10/30/2025 10:05:40 AM
		Functional Inspection	Passed	
Smoke Detector - General	2-059 003	Admin Area Reception	Manual	10/30/2025 10:05:36 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-055 004	Admin Area Reception Office	Manual	10/30/2025 10:05:33 AM
		Functional Inspection	Passed	
Smoke Detector - General	2-056 005	Admin Area Reception Office Clst	Manual	10/30/2025 10:05:29 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-062 010	Admin Area Womens RR North	Manual	10/30/2025 10:05:39 AM
		Functional Inspection	Passed	
Smoke Detector - General	2-024 127	Multi-Purpose Bldg Classroom 15	Manual	10/30/2025 10:06:16 AM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	2-130 137	Multi-Purpose Bldg Cust Clst W OS Ktch	Manual	10/30/2025 10:04:44 AM
		Functional Inspection	Passed	
Smoke Detector - General	2-027 134	Multi-Purpose Bldg IMC Book Storage	Manual	10/30/2025 10:04:42 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-026 133	Multi-Purpose Bldg IMC Book Storage	Manual	10/30/2025 10:06:12 AM
		Functional Inspection	Passed	
Smoke Detector - General	2-023 132	Multi-Purpose Bldg IMC File Storage	Manual	10/30/2025 10:06:09 AM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-022 131	Multi-Purpose Bldg IMC Hall	Manual	10/30/2025 10:06:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-025 130	Multi-Purpose Bldg IMC Hall	Manual	10/30/2025 10:06:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-020 129	Multi-Purpose Bldg IMC Office	Manual	10/30/2025 10:04:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-021 128	Multi-Purpose Bldg IMC Office	Manual	10/30/2025 10:06:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-017 135	Multi-Purpose Bldg Kitchen	Manual	10/30/2025 10:06:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-016 136	Multi-Purpose Bldg Kitchen	Manual	10/30/2025 10:06:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-015 126	Multi-Purpose Bldg Kitchen Dry Storage	Manual	10/30/2025 10:06:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-131 121	Multi-Purpose Bldg Kitchen Entry	Manual	10/30/2025 10:06:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-028 123	Multi-Purpose Bldg MP Room	Manual	10/30/2025 10:06:19 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-019 122	Multi-Purpose Bldg MP Room	Manual	10/30/2025 10:06:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-018 125	Multi-Purpose Bldg MP Room	Manual	10/30/2025 10:06:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-029 124	Multi-Purpose Bldg MP Room	Manual	10/30/2025 10:06:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-158 138	Multi-Purpose Bldg MP Room Northwest	Manual	10/30/2025 10:04:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-159 139	Multi-Purpose Bldg MP Room Southeast	Manual	10/30/2025 10:04:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-132 119	Multi-Purpose Bldg NE Entry	Manual	10/30/2025 10:06:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-129 120	Multi-Purpose Bldg NW Entry	Manual	10/30/2025 10:06:20 AM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Manual Pull Station	2-133 118	Multi-Purpose Bldg SE Entry	Manual	10/30/2025 10:06:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-136 104	Rooms 10-14 Bldg Att Women RR by 14	Manual	10/30/2025 10:04:38 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-135 105	Rooms 10-14 Bldg Attic Mens RR by 14	Manual	10/30/2025 10:04:39 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-042 085	Rooms 10-14 Bldg Classroom 10 North	Manual	10/30/2025 10:04:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-043 086	Rooms 10-14 Bldg Classroom 10 South	Manual	10/30/2025 10:04:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-041 088	Rooms 10-14 Bldg Classroom 11	Manual	10/30/2025 10:05:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-040 087	Rooms 10-14 Bldg Classroom 11	Manual	10/30/2025 10:05:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-038 089	Rooms 10-14 Bldg Classroom 12	Manual	10/30/2025 10:05:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-039 090	Rooms 10-14 Bldg Classroom 12	Manual	10/30/2025 10:05:19 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-037 092	Rooms 10-14 Bldg Classroom 13	Manual	10/30/2025 10:05:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-036 091	Rooms 10-14 Bldg Classroom 13	Manual	10/30/2025 10:05:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-030 098	Rooms 10-14 Bldg Cust Clst by Rm 14	Manual	10/30/2025 10:05:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-141 099	Rooms 10-14 Bldg Lite Soffit Classrm 10	Manual	10/30/2025 10:04:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-140 100	Rooms 10-14 Bldg Lite Soffit Classrm 11	Manual	10/30/2025 10:04:32 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-139 101	Rooms 10-14 Bldg Lite Soffit Classrm 12	Manual	10/30/2025 10:04:33 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-138 102	Rooms 10-14 Bldg Lite Soffit Classrm 13	Manual	10/30/2025 10:04:35 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-137 103	Rooms 10-14 Bldg Lite Soffit Staff Rm 14	Manual	10/30/2025 10:04:36 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-031 097	Rooms 10-14 Bldg Mens RR by Rm 14	Manual	10/30/2025 10:05:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-134 106	Rooms 10-14 Bldg RR Chase by Rm 14	Manual	10/30/2025 10:04:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-034 095	Rooms 10-14 Bldg Staff Rm 14 Mtg Rm	Manual	10/30/2025 10:05:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-035 094	Rooms 10-14 Bldg Staff Room 14	Manual	10/30/2025 10:05:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-033 093	Rooms 10-14 Bldg Staff Room 14	Manual	10/30/2025 10:05:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-032 096	Rooms 10-14 Bldg Womens RR by 14	Manual	10/30/2025 10:05:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-064 020	Rooms 1-3 Bldg Classroom 1	Manual	10/30/2025 10:05:42 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-065 021	Rooms 1-3 Bldg Classroom 1	Manual	10/30/2025 10:05:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-066 022	Rooms 1-3 Bldg Classroom 2	Manual	10/30/2025 10:05:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-067 023	Rooms 1-3 Bldg Classroom 2	Manual	10/30/2025 10:05:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-069 025	Rooms 1-3 Bldg Classroom 3	Manual	10/30/2025 10:05:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-068 024	Rooms 1-3 Bldg Classroom 3	Manual	10/30/2025 10:05:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-151 026	Rooms 1-3 Bldg Lite Soffit Classrm 1	Manual	10/30/2025 10:05:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-152 027	Rooms 1-3 Bldg Lite Soffit Classrm 2	Manual	10/30/2025 10:03:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-153 028	Rooms 1-3 Bldg Lite Soffit Classrm 3	Manual	10/30/2025 10:03:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-127 048	Rooms 4 5 Bldg Attic Classrm 4 RR	Manual	10/30/2025 10:04:57 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-070 036	Rooms 4 5 Bldg Classroom 4	Manual	10/30/2025 10:04:50 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-007 035	Rooms 4 5 Bldg Classroom 4	Manual	10/30/2025 10:04:52 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-012 034	Rooms 4 5 Bldg Classroom 4	Manual	10/30/2025 10:04:55 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-008 038	Rooms 4 5 Bldg Classroom 4 Kitchen	Manual	10/30/2025 10:04:54 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-013 037	Rooms 4 5 Bldg Classroom 4 Office	Manual	10/30/2025 10:04:48 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-009 040	Rooms 4 5 Bldg Classroom 4 RR	Manual	10/30/2025 10:04:59 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-010 039	Rooms 4 5 Bldg Classroom 4 RR Hall	Manual	10/30/2025 10:05:21 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-004 041	Rooms 4 5 Bldg Classroom 5	Manual	10/30/2025 10:05:03 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-005 042	Rooms 4 5 Bldg Classroom 5	Manual	10/30/2025 10:05:04 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-011 044	Rooms 4 5 Bldg Classroom 5 RR	Manual	10/30/2025 10:05:00 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-006 043	Rooms 4 5 Bldg Classroom 5 RR Hall	Manual	10/30/2025 10:05:01 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-003 045	Rooms 4 5 Bldg Cust Office by Rm 5	Manual	10/30/2025 10:05:06 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-002 046	Rooms 4 5 Bldg Elect Rm By Rm 5	Manual	10/30/2025 10:06:26 AM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	2-128 047	Rooms 4 5 Bldg Lite Soffit Classrm 4	Manual	10/30/2025 10:04:26 AM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	2-126 049	Rooms 4 5 Bldg Lite Soffit Classrm 5	Manual	10/30/2025 10:04:25 AM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-146 073	Rooms 6-9 Bldg Attic Boys RR by 9	Manual	10/30/2025 10:04:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-148 074	Rooms 6-9 Bldg Attic Girls RR by 9	Manual	10/30/2025 10:04:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-052 066	Rooms 6-9 Bldg Boys RR by Rm 9	Manual	10/30/2025 10:04:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-045 059	Rooms 6-9 Bldg Classroom 6	Manual	10/30/2025 10:05:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-044 058	Rooms 6-9 Bldg Classroom 6	Manual	10/30/2025 10:06:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-046 060	Rooms 6-9 Bldg Classroom 7	Manual	10/30/2025 10:05:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-047 061	Rooms 6-9 Bldg Classroom 7	Manual	10/30/2025 10:05:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-049 063	Rooms 6-9 Bldg Classroom 8	Manual	10/30/2025 10:05:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-048 062	Rooms 6-9 Bldg Classroom 8	Manual	10/30/2025 10:05:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-050 064	Rooms 6-9 Bldg Classroom 9	Manual	10/30/2025 10:05:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-051 065	Rooms 6-9 Bldg Classroom 9	Manual	10/30/2025 10:05:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-053 067	Rooms 6-9 Bldg Cust Closet by Rm 9	Manual	10/30/2025 10:04:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-054 068	Rooms 6-9 Bldg Girls RR by Rm 9	Manual	10/30/2025 10:04:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-142 069	Rooms 6-9 Bldg Lite Soffit Classrm 6	Manual	10/30/2025 10:04:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-143 070	Rooms 6-9 Bldg Lite Soffit Classrm 7	Manual	10/30/2025 10:04:19 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-144 071	Rooms 6-9 Bldg Lite Soffit Classrm 8	Manual	10/30/2025 10:04:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-145 072	Rooms 6-9 Bldg Lite Soffit Classrm 9	Manual	10/30/2025 10:04:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-147 075	Rooms 6-9 Bldg RR Chase by Rm 9	Manual	10/30/2025 10:04:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Power Supplies

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Primary Power	057	Rooms 4 5 Bldg Elect Rm By Rm 5	Manual	10/30/2025 10:03:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Device/Equipment details

Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Audible					
013	Admin Area North Exterior				
029	Rooms 1-3 Bldg North Exterior				
030	Rooms 1-3 Bldg North Exterior				
050	Rooms 4 5 Bldg North Exterior				
051	Rooms 4 5 Bldg North Exterior				
076	Rooms 6-9 Bldg North Exterior				
077	Rooms 6-9 Bldg North Exterior				
078	Rooms 6-9 Bldg North Exterior				
107	Rooms 10-14 Bldg North Exterior				
108	Rooms 10-14 Bldg North Exterior				
109	Rooms 10-14 Bldg North Exterior				
110	Rooms 10-14 Bldg East Exterior				
140	Multi-Purpose Bldg North Exterior				
141	Multi-Purpose Bldg East Exterior				
142	Multi-Purpose Bldg West Exterior				
Visible					
014	Admin Area Reception				
015	Admin Area Reception Office				
016	Admin Area Hall				
017	Admin Area Office				
018	Admin Area Mens Restroom North				
019	Admin Area Womens RR North				
054	Rooms 4 5 Bldg Classroom 4 RR				
055	Rooms 4 5 Bldg Classroom 4 RR				
083	Rooms 6-9 Bldg Boys RR by Rm 9				
084	Rooms 6-9 Bldg Girls RR by Rm 9				
116	Rooms 10-14 Bldg Womens RR by 14				
117	Rooms 10-14 Bldg Mens RR by Rm 14				
147	Multi-Purpose Bldg IMC Hall				
148	Multi-Purpose Bldg IMC Office				
149	Multi-Purpose Bldg IMC Office				
Audible And Visible					
031	Rooms 1-3 Bldg Classroom 1				
032	Rooms 1-3 Bldg Classroom 2				
033	Rooms 1-3 Bldg Classroom 3				
052	Rooms 4 5 Bldg Classroom 4				
053	Rooms 4 5 Bldg Classroom 5				
079	Rooms 6-9 Bldg Classroom 6				
080	Rooms 6-9 Bldg Classroom 7				
081	Rooms 6-9 Bldg Classroom 8				
082	Rooms 6-9 Bldg Classroom 9				
111	Rooms 10-14 Bldg Classroom 10				
112	Rooms 10-14 Bldg Classroom 11				
113	Rooms 10-14 Bldg Classroom 12				
114	Rooms 10-14 Bldg Classroom 13				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
115	Rooms 10-14 Bldg Classroom 14				
143	Multi-Purpose Bldg MP Room				
144	Multi-Purpose Bldg MP Room				
145	Multi-Purpose Bldg Kitchen				
146	Multi-Purpose Bldg Classroom 15				

Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Remote Annunciator					
001	Admin Area Reception				
Fire Alarm Panel					
056	Rooms 4 5 Bldg Elect Rm By Rm 5	Honeywell			
NAC Power Extender Panel					
	Panel A				
	Panel B				

Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Manual Pull Station					
2-149 002	Admin Area Entry				
2-133 118	Multi-Purpose Bldg SE Entry				
2-132 119	Multi-Purpose Bldg NE Entry				
2-129 120	Multi-Purpose Bldg NW Entry				
2-131 121	Multi-Purpose Bldg Kitchen Entry				
Smoke Detector - General					
2-059 003	Admin Area Reception				
2-055 004	Admin Area Reception Office				
2-056 005	Admin Area Reception Office Clst				
2-061 006	Admin Area Hall				
2-060 007	Admin Area Office				
2-063 008	Admin Area Office				
2-058 009	Admin Area Mens Restroom North				
2-062 010	Admin Area Womens RR North				
2-064 020	Rooms 1-3 Bldg Classroom 1				
2-065 021	Rooms 1-3 Bldg Classroom 1				
2-066 022	Rooms 1-3 Bldg Classroom 2				
2-067 023	Rooms 1-3 Bldg Classroom 2				
2-068 024	Rooms 1-3 Bldg Classroom 3				
2-069 025	Rooms 1-3 Bldg Classroom 3				
2-012 034	Rooms 4 5 Bldg Classroom 4				
2-007 035	Rooms 4 5 Bldg Classroom 4				
2-070 036	Rooms 4 5 Bldg Classroom 4				
2-013 037	Rooms 4 5 Bldg Classroom 4 Office				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-008 038	Rooms 4 5 Bldg Classroom 4 Kitchen				
2-010 039	Rooms 4 5 Bldg Classroom 4 RR Hall				
2-009 040	Rooms 4 5 Bldg Classroom 4 RR				
2-004 041	Rooms 4 5 Bldg Classroom 5				
2-005 042	Rooms 4 5 Bldg Classroom 5				
2-006 043	Rooms 4 5 Bldg Classroom 5 RR Hall				
2-011 044	Rooms 4 5 Bldg Classroom 5 RR				
2-003 045	Rooms 4 5 Bldg Cust Office by Rm 5				
2-002 046	Rooms 4 5 Bldg Elect Rm By Rm 5				
2-044 058	Rooms 6-9 Bldg Classroom 6				
2-045 059	Rooms 6-9 Bldg Classroom 6				
2-046 060	Rooms 6-9 Bldg Classroom 7				
2-047 061	Rooms 6-9 Bldg Classroom 7				
2-048 062	Rooms 6-9 Bldg Classroom 8				
2-049 063	Rooms 6-9 Bldg Classroom 8				
2-050 064	Rooms 6-9 Bldg Classroom 9				
2-051 065	Rooms 6-9 Bldg Classroom 9				
2-052 066	Rooms 6-9 Bldg Boys RR by Rm 9				
2-053 067	Rooms 6-9 Bldg Cust Closet by Rm 9				
2-054 068	Rooms 6-9 Bldg Girls RR by Rm 9				
2-042 085	Rooms 10-14 Bldg Classroom 10 North				
2-043 086	Rooms 10-14 Bldg Classroom 10 South				
2-040 087	Rooms 10-14 Bldg Classroom 11				
2-041 088	Rooms 10-14 Bldg Classroom 11				
2-038 089	Rooms 10-14 Bldg Classroom 12				
2-039 090	Rooms 10-14 Bldg Classroom 12				
2-036 091	Rooms 10-14 Bldg Classroom 13				
2-037 092	Rooms 10-14 Bldg Classroom 13				
2-033 093	Rooms 10-14 Bldg Staff Room 14				
2-035 094	Rooms 10-14 Bldg Staff Room 14				
2-034 095	Rooms 10-14 Bldg Staff Rm 14 Mtg Rm				
2-032 096	Rooms 10-14 Bldg Womens RR by 14				
2-031 097	Rooms 10-14 Bldg Mens RR by Rm 14				
2-019 122	Multi-Purpose Bldg MP Room				
2-028 123	Multi-Purpose Bldg MP Room				
2-029 124	Multi-Purpose Bldg MP Room				
2-018 125	Multi-Purpose Bldg MP Room				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-015 126	Multi-Purpose Bldg Kitchen Dry Storage				
2-024 127	Multi-Purpose Bldg Classroom 15				
2-021 128	Multi-Purpose Bldg IMC Office				
2-020 129	Multi-Purpose Bldg IMC Office				
2-025 130	Multi-Purpose Bldg IMC Hall				
2-022 131	Multi-Purpose Bldg IMC Hall				
2-023 132	Multi-Purpose Bldg IMC File Storage				
2-026 133	Multi-Purpose Bldg IMC Book Storage				
2-027 134	Multi-Purpose Bldg IMC Book Storage				
Heat Detector - Restorable Spot					
2-057 011	Admin Area Mens RR N Closet				
2-150 012	Admin Area Attic Office Hall				
2-151 026	Rooms 1-3 Bldg Lite Soffit Classrm 1				
2-152 027	Rooms 1-3 Bldg Lite Soffit Classrm 2				
2-153 028	Rooms 1-3 Bldg Lite Soffit Classrm 3				
2-128 047	Rooms 4 5 Bldg Lite Soffit Classrm 4				
2-127 048	Rooms 4 5 Bldg Attic Classrm 4 RR				
2-126 049	Rooms 4 5 Bldg Lite Soffit Classrm 5				
2-142 069	Rooms 6-9 Bldg Lite Soffit Classrm 6				
2-143 070	Rooms 6-9 Bldg Lite Soffit Classrm 7				
2-144 071	Rooms 6-9 Bldg Lite Soffit Classrm 8				
2-145 072	Rooms 6-9 Bldg Lite Soffit Classrm 9				
2-146 073	Rooms 6-9 Bldg Attic Boys RR by 9				
2-148 074	Rooms 6-9 Bldg Attic Girls RR by 9				
2-147 075	Rooms 6-9 Bldg RR Chase by Rm 9				
2-030 098	Rooms 10-14 Bldg Cust Clst by Rm 14				
2-141 099	Rooms 10-14 Bldg Lite Soffit Classrm 10				
2-140 100	Rooms 10-14 Bldg Lite Soffit Classrm 11				
2-139 101	Rooms 10-14 Bldg Lite Soffit Classrm 12				
2-138 102	Rooms 10-14 Bldg Lite Soffit Classrm 13				
2-137 103	Rooms 10-14 Bldg Lite Soffit Staff Rm 14				
2-136 104	Rooms 10-14 Bldg Att Women RR by 14				
2-135 105	Rooms 10-14 Bldg Attic Mens RR by 14				
2-134 106	Rooms 10-14 Bldg RR Chase by Rm 14				
2-017 135	Multi-Purpose Bldg Kitchen				
2-016 136	Multi-Purpose Bldg Kitchen				
2-130 137	Multi-Purpose Bldg Cust Clst W OS Ktcn				
Smoke Detector - Duct					

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-158 138	Multi-Purpose Bldg MP Room Northwest				
2-159 139	Multi-Purpose Bldg MP Room Southeast				

Power Supplies

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Primary Power					
057	Rooms 4 5 Bldg Elect Rm By Rm 5				