

# Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

HOWE AVE ELEMENTARY

2404 HOWE AVE  
SACRAMENTO, California  
United States

This site has been inspected and tested in compliance with applicable standards.

Completed  
Tuesday, March 10, 2026

Test Session:10 Mar 2026 14:31 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD  
5320 HEMLOCK ST  
SACRAMENTO, California  
United States

TESTED BY

Riley Goyet  
Western States Fire Protection-  
Sacramento  
188 Cirby Way  
Roseville, CA 95678  
United States



# Inspection Summary

## Building Information

PROPERTY	HOWE AVE ELEMENTARY	CONTACT
ADDRESS	2404 HOWE AVE	PHONE
CITY/STATE	SACRAMENTO, California	MOBILE
COUNTRY	United States	EMAIL

## Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us


## Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Alarm Notification Appliance	114	114(100%)	114(100%)	0(0%)
Ventilation and Cooking Equipment	5	0(0%)	0(0%)	0(0%)
Fire Control Panel	9	9(100%)	9(100%)	0(0%)
Initiating Device	289	289(100%)	289(100%)	0(0%)

## Certification

The equipment specified herein was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Tuesday, March 10, 2026

ACCEPTED BY      03/10/2026  
  
Building Representative

  
TESTED BY      03/10/2026  
Riley Goyet  
Technician

# Testing Details

## Alarm Notification Appliance

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible		Admin Building East Exterior	Manual	3/10/2026 2:36:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Admin Building Mens Restroom	Manual	3/10/2026 2:36:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Admin Building Office A3	Manual	3/10/2026 2:36:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Admin Building Office Copy Rm A4	Manual	3/10/2026 2:36:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Admin Building Office Reception	Manual	3/10/2026 2:36:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Admin Building South Exterior	Manual	3/10/2026 2:36:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Admin Building West Exterior	Manual	3/10/2026 2:36:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Admin Building Womens Restroom	Manual	3/10/2026 2:36:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building B North Exterior	Manual	3/10/2026 2:37:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building B Room B1	Manual	3/10/2026 2:37:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Building B Room B1	Manual	3/10/2026 2:37:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Building B Room B1 Restroom	Manual	3/10/2026 2:37:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building B Room B2	Manual	3/10/2026 2:37:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Building B Room B2	Manual	3/10/2026 2:37:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Building B Room B2 Restroom	Manual	3/10/2026 2:37:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building B South Exterior	Manual	3/10/2026 2:36:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building B South Exterior	Manual	3/10/2026 2:36:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building C Room C1	Manual	3/10/2026 2:36:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building C Room C2	Manual	3/10/2026 2:36:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building C Room C3	Manual	3/10/2026 2:36:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building C Room C4	Manual	3/10/2026 2:36:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building C South Exterior	Manual	3/10/2026 2:36:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Building D Boys Restroom D9	Manual	3/10/2026 2:36:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building D East Exterior	Manual	3/10/2026 2:36:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Building D Girls Restroom D7	Manual	3/10/2026 2:36:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building D North Exterior	Manual	3/10/2026 2:36:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building D Room D1	Manual	3/10/2026 2:36:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building D Room D2	Manual	3/10/2026 2:36:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building D Room D3	Manual	3/10/2026 2:36:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building D Room D4	Manual	3/10/2026 2:36:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building D Room D5	Manual	3/10/2026 2:36:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building D Room D6	Manual	3/10/2026 2:36:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building D South Exterior	Manual	3/10/2026 2:36:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building D South Exterior	Manual	3/10/2026 2:36:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Building E Boys Restroom E8	Manual	3/10/2026 2:36:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible		Building E East Exterior	Manual	3/10/2026 2:36:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Building E Girls Restroom E7	Manual	3/10/2026 2:36:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building E Room E1	Manual	3/10/2026 2:36:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building E Room E2	Manual	3/10/2026 2:36:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building E Room E3	Manual	3/10/2026 2:36:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building E Room E4	Manual	3/10/2026 2:36:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building E Room E5	Manual	3/10/2026 2:36:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building E Room E6	Manual	3/10/2026 2:36:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building E South Exterior	Manual	3/10/2026 2:35:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building E South Exterior	Manual	3/10/2026 2:35:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building E South Exterior	Manual	3/10/2026 2:35:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building F East Exterior	Manual	3/10/2026 2:35:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building F Room F1	Manual	3/10/2026 2:35:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Building F Room F1	Manual	3/10/2026 2:35:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building F Room F2	Manual	3/10/2026 2:35:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building F Room F3	Manual	3/10/2026 2:35:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building F Room F4	Manual	3/10/2026 2:35:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building F Room F5	Manual	3/10/2026 2:35:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building F Room F6	Manual	3/10/2026 2:35:25 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building F South Middle Exterior	Manual	3/10/2026 2:35:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building F Southeast Exterior	Manual	3/10/2026 2:35:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building F Southwest Exterior	Manual	3/10/2026 2:35:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Building G Boys Restroom G8	Manual	3/10/2026 2:35:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building G East Exterior	Manual	3/10/2026 2:34:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Building G Girls Restroom G9	Manual	3/10/2026 2:35:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Building G Mens Restroom G10	Manual	3/10/2026 2:35:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building G Room G2	Manual	3/10/2026 2:35:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building G Room G3	Manual	3/10/2026 2:35:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building G Room G4	Manual	3/10/2026 2:35:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building G Room G5	Manual	3/10/2026 2:35:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building G Room G6	Manual	3/10/2026 2:35:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building G Room G7	Manual	3/10/2026 2:35:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building G South Exterior	Manual	3/10/2026 2:34:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building G South Exterior	Manual	3/10/2026 2:34:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building G South Exterior	Manual	3/10/2026 2:34:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building G South Exterior	Manual	3/10/2026 2:34:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building G Staff Room G1	Manual	3/10/2026 2:35:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible		Building G West Exterior	Manual	3/10/2026 2:34:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Building G Womens RR G12	Manual	3/10/2026 2:34:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building H East Exterior	Manual	3/10/2026 2:34:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building H Room H1	Manual	3/10/2026 2:34:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building H Room H2	Manual	3/10/2026 2:34:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building H Room H3	Manual	3/10/2026 2:34:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building H Room H4	Manual	3/10/2026 2:34:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building H Room H5	Manual	3/10/2026 2:34:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building H South Exterior	Manual	3/10/2026 2:34:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building H West Exterior	Manual	3/10/2026 2:34:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building I East Exterior	Manual	3/10/2026 2:34:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building I East Exterior	Manual	3/10/2026 2:34:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building I North Exterior	Manual	3/10/2026 2:34:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building I Room I-1	Manual	3/10/2026 2:37:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Building I Room I-1	Manual	3/10/2026 2:34:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building I Room I-2	Manual	3/10/2026 2:34:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Building I Room I-2 Restroom	Manual	3/10/2026 2:34:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building I Room I-3	Manual	3/10/2026 2:34:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Building I Room I-3 Restroom	Manual	3/10/2026 2:34:14 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building I South Exterior	Manual	3/10/2026 2:34:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building I West Exterior	Manual	3/10/2026 2:34:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building J East Exterior	Manual	3/10/2026 2:33:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building J East Exterior	Manual	3/10/2026 2:33:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building J Room J1	Manual	3/10/2026 2:34:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building J Room J2	Manual	3/10/2026 2:34:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building J Room J3	Manual	3/10/2026 2:34:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Building J Room J3	Manual	3/10/2026 2:33:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Building J Room J3	Manual	3/10/2026 2:33:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Building J Room J4 Boys RR	Manual	3/10/2026 2:33:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Building J Room J5 Girls RR	Manual	3/10/2026 2:37:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building J Room J6	Manual	3/10/2026 2:34:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building J Room J7	Manual	3/10/2026 2:33:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building J South Exterior	Manual	3/10/2026 2:33:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building J West Exterior	Manual	3/10/2026 2:33:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building J West Exterior	Manual	3/10/2026 2:33:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building K East Exterior	Manual	3/10/2026 2:35:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building K Kitchen K2	Manual	3/10/2026 2:35:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible		Building K MP Room K1	Manual	3/10/2026 2:35:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building K MP Room K1	Manual	3/10/2026 2:35:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building K South Exterior	Manual	3/10/2026 2:35:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building K Stage K3	Manual	3/10/2026 2:35:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building K West Exterior	Manual	3/10/2026 2:35:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

### Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Remote Annunciator		Admin Building Office Reception	Manual	3/10/2026 8:44:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Building C Room C2	Manual	3/10/2026 8:44:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Building D Janitors Room D8	Manual	3/10/2026 8:44:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Fire Alarm Panel		Building E Headend Room E10	Manual	3/10/2026 8:44:15 PM
		Manufacturer	Notifier	
		Model	NFS-3030	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Building E Headend Room E10	Manual	3/10/2026 8:44:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Building E Headend Room E10	Manual	3/10/2026 8:44:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Building F Janitors Room F9	Manual	3/10/2026 8:44:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Building G Janitors Room G11	Manual	3/10/2026 8:44:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Building I Room I-1 Cust Office	Manual	3/10/2026 8:44:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

### Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-007 009	Admin Building Mens Restroom	Manual	3/10/2026 6:48:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-013 004	Admin Building Office A2	Manual	3/10/2026 3:46:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-005 006	Admin Building Office A3	Manual	3/10/2026 3:44:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-006 007	Admin Building Office Copy Rm A4	Manual	3/10/2026 3:43:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-134 002	Admin Building Office Reception	Manual	3/10/2026 8:44:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-010 003	Admin Building Office Reception	Manual	3/10/2026 6:48:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-009 008	Admin Building Office Restroom	Manual	3/10/2026 3:45:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-012 005	Admin Building Principals Office	Manual	3/10/2026 3:46:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-008 010	Admin Building Womens Restroom	Manual	3/10/2026 6:48:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-138 031	Building B Attic Room B1	Manual	3/10/2026 7:05:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-138 032	Building B Attic Room B1 RR	Manual	3/10/2026 7:05:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-138 033	Building B Attic Room B2	Manual	3/10/2026 7:05:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-138 034	Building B Attic Room B2 RR	Manual	3/10/2026 7:05:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-017 022	Building B Room B1	Manual	3/10/2026 2:59:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-019 021	Building B Room B1	Manual	3/10/2026 3:00:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-018 019	Building B Room B1	Manual	3/10/2026 3:00:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-020 020	Building B Room B1	Manual	3/10/2026 3:00:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-016 023	Building B Room B1 Restroom	Manual	3/10/2026 2:58:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-015 024	Building B Room B1 Storage	Manual	3/10/2026 2:57:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-023 028	Building B Room B2	Manual	3/10/2026 3:03:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-024 027	Building B Room B2	Manual	3/10/2026 3:04:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-026 026	Building B Room B2	Manual	3/10/2026 3:04:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-025 025	Building B Room B2	Manual	3/10/2026 3:05:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-022 029	Building B Room B2 Restroom	Manual	3/10/2026 3:03:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-021 030	Building B Room B2 Storage	Manual	3/10/2026 3:02:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-130 053	Building C Attic Room C1	Manual	3/10/2026 7:04:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-130 052	Building C Attic Room C1	Manual	3/10/2026 7:04:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-128 054	Building C Attic Room C2	Manual	3/10/2026 7:04:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-128 055	Building C Attic Room C2	Manual	3/10/2026 7:04:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-129 057	Building C Attic Room C3	Manual	3/10/2026 7:04:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-129 056	Building C Attic Room C3	Manual	3/10/2026 7:04:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-130 059	Building C Attic Room C4	Manual	3/10/2026 7:04:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-130 058	Building C Attic Room C4	Manual	3/10/2026 7:04:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-029 044	Building C Room C1	Manual	3/10/2026 2:54:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-030 045	Building C Room C1	Manual	3/10/2026 2:54:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-006 047	Building C Room C2	Manual	3/10/2026 2:52:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-005 046	Building C Room C2	Manual	3/10/2026 2:52:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-007 049	Building C Room C3	Manual	3/10/2026 2:50:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-008 048	Building C Room C3	Manual	3/10/2026 2:51:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-009 051	Building C Room C4	Manual	3/10/2026 2:48:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-010 050	Building C Room C4	Manual	3/10/2026 2:49:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-034 093	Building D Boys Restroom D9	Manual	3/10/2026 6:49:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-033 091	Building D Girls Restroom D7	Manual	3/10/2026 6:49:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-032 092	Building D Janitors Room D8	Manual	3/10/2026 6:49:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-037 067	Building D Room D1	Manual	3/10/2026 3:07:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-035 066	Building D Room D1	Manual	3/10/2026 3:07:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-038 068	Building D Room D1	Manual	3/10/2026 3:08:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-036 069	Building D Room D1	Manual	3/10/2026 3:08:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-119 070	Building D Room D1 Storage	Manual	3/10/2026 6:48:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-041 073	Building D Room D2	Manual	3/10/2026 3:09:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-042 072	Building D Room D2	Manual	3/10/2026 3:10:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-040 071	Building D Room D2	Manual	3/10/2026 3:10:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-039 074	Building D Room D2	Manual	3/10/2026 3:11:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-046 078	Building D Room D3	Manual	3/10/2026 3:12:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-044 077	Building D Room D3	Manual	3/10/2026 3:12:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-043 076	Building D Room D3	Manual	3/10/2026 3:13:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-045 075	Building D Room D3	Manual	3/10/2026 3:13:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-047 079	Building D Room D4	Manual	3/10/2026 3:14:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-049 080	Building D Room D4	Manual	3/10/2026 3:15:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-050 081	Building D Room D4	Manual	3/10/2026 3:16:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-048 082	Building D Room D4	Manual	3/10/2026 3:16:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-053 083	Building D Room D5	Manual	3/10/2026 3:19:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-051 084	Building D Room D5	Manual	3/10/2026 3:19:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-052 085	Building D Room D5	Manual	3/10/2026 3:20:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-054 086	Building D Room D5	Manual	3/10/2026 3:20:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-055 087	Building D Room D6	Manual	3/10/2026 3:22:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-057 088	Building D Room D6	Manual	3/10/2026 3:22:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-058 089	Building D Room D6	Manual	3/10/2026 3:23:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-056 090	Building D Room D6	Manual	3/10/2026 3:23:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-139 094	Building D RR Plumb Chase D8	Manual	3/10/2026 7:06:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-118 133	Building E Boys Restroom E8	Manual	3/10/2026 3:25:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-090 136	Building E E9 Boiler Room	Manual	3/10/2026 4:08:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-091 134	Building E E9 Boiler Room	Manual	3/10/2026 4:09:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-092 135	Building E E9 Boiler Room	Manual	3/10/2026 4:10:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-117 131	Building E Girls Restroom E7	Manual	3/10/2026 3:25:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-003 138	Building E Headend Room E10	Manual	3/10/2026 7:06:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-002 137	Building E Headend Room E10	Manual	3/10/2026 4:07:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-116 132	Building E Janitors Room E7A	Manual	3/10/2026 3:25:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-093 108	Building E Room E1	Manual	3/10/2026 3:41:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-094 109	Building E Room E1	Manual	3/10/2026 3:41:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-095 110	Building E Room E1 Office	Manual	3/10/2026 6:49:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-096 112	Building E Room E2	Manual	3/10/2026 3:28:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-097 111	Building E Room E2	Manual	3/10/2026 3:37:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-099 113	Building E Room E2	Manual	3/10/2026 3:38:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-098 114	Building E Room E2	Manual	3/10/2026 3:39:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-101 118	Building E Room E3	Manual	3/10/2026 3:35:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-102 116	Building E Room E3	Manual	3/10/2026 3:35:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-100 117	Building E Room E3	Manual	3/10/2026 3:35:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-103 115	Building E Room E3	Manual	3/10/2026 3:36:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-104 122	Building E Room E4	Manual	3/10/2026 3:33:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-105 119	Building E Room E4	Manual	3/10/2026 3:33:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-106 120	Building E Room E4	Manual	3/10/2026 3:33:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-107 121	Building E Room E4	Manual	3/10/2026 3:35:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-108 125	Building E Room E5	Manual	3/10/2026 3:30:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-110 126	Building E Room E5	Manual	3/10/2026 3:30:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-111 123	Building E Room E5	Manual	3/10/2026 3:31:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-109 124	Building E Room E5	Manual	3/10/2026 3:31:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-114 129	Building E Room E6	Manual	3/10/2026 3:27:17 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-115 128	Building E Room E6	Manual	3/10/2026 3:27:23 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-112 130	Building E Room E6	Manual	3/10/2026 3:28:32 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-113 127	Building E Room E6	Manual	3/10/2026 3:28:58 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-137 139	Building E RR Plumb Chase E7	Manual	3/10/2026 7:06:16 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-136 140	Building E RR Plumb Chase E8	Manual	3/10/2026 7:06:14 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-388 179	Building F Attic Room F1	Manual	3/10/2026 7:06:09 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-387 180	Building F Attic Room F7	Manual	3/10/2026 7:06:10 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-255 160	Building F Classroom F1A	Manual	3/10/2026 4:12:44 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-254 178	Building F Janitors Room F9	Manual	3/10/2026 6:49:17 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-256 158	Building F Room F1	Manual	3/10/2026 4:14:58 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-257 156	Building F Room F1	Manual	3/10/2026 4:15:25 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-258 157	Building F Room F1	Manual	3/10/2026 4:16:02 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-259 155	Building F Room F1	Manual	3/10/2026 4:16:06 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-260 159	Building F Room F1 Office	Manual	3/10/2026 4:16:52 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-262 161	Building F Room F2	Manual	3/10/2026 4:18:22 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-261 162	Building F Room F2	Manual	3/10/2026 4:18:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-265 163	Building F Room F3	Manual	3/10/2026 4:22:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-267 164	Building F Room F3	Manual	3/10/2026 4:22:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-268 165	Building F Room F3	Manual	3/10/2026 4:23:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-266 166	Building F Room F3	Manual	3/10/2026 4:23:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-269 169	Building F Room F4	Manual	3/10/2026 4:25:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-270 168	Building F Room F4	Manual	3/10/2026 4:25:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-272 167	Building F Room F4	Manual	3/10/2026 4:25:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-271 170	Building F Room F4	Manual	3/10/2026 6:49:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-274 172	Building F Room F5	Manual	3/10/2026 4:26:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-273 171	Building F Room F5	Manual	3/10/2026 4:27:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-275 174	Building F Room F5	Manual	3/10/2026 4:27:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-276 173	Building F Room F5	Manual	3/10/2026 4:28:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-263 175	Building F Room F6	Manual	3/10/2026 4:19:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-264 176	Building F Room F6	Manual	3/10/2026 4:21:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-253 177	Building F Room F7 F8	Manual	3/10/2026 4:13:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-311 222	Building G Boys Restroom G8	Manual	3/10/2026 4:30:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-310 223	Building G Girls Restroom G9	Manual	3/10/2026 4:29:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-288 225	Building G Janitors Room G11	Manual	3/10/2026 4:47:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-287 224	Building G Mens Restroom G10	Manual	3/10/2026 4:45:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-380 231	Building G Room G2	Manual	3/10/2026 6:48:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-291 200	Building G Room G2	Manual	3/10/2026 4:42:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-290 201	Building G Room G2	Manual	3/10/2026 4:43:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-285 202	Building G Room G2 Office	Manual	3/10/2026 4:43:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-286 203	Building G Room G2 Office	Manual	3/10/2026 4:44:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-293 204	Building G Room G3	Manual	3/10/2026 4:41:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-292 205	Building G Room G3	Manual	3/10/2026 4:41:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-297 206	Building G Room G4	Manual	3/10/2026 4:38:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-296 207	Building G Room G4	Manual	3/10/2026 4:38:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-294 208	Building G Room G4	Manual	3/10/2026 6:49:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-295 209	Building G Room G4	Manual	3/10/2026 6:49:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-299 210	Building G Room G5	Manual	3/10/2026 4:35:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-300 212	Building G Room G5	Manual	3/10/2026 4:36:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-298 213	Building G Room G5	Manual	3/10/2026 4:37:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-301 211	Building G Room G5	Manual	3/10/2026 6:48:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-304 215	Building G Room G6	Manual	3/10/2026 4:33:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-305 214	Building G Room G6	Manual	3/10/2026 4:33:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-303 217	Building G Room G6	Manual	3/10/2026 4:34:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-302 216	Building G Room G6	Manual	3/10/2026 4:34:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-306 221	Building G Room G7	Manual	3/10/2026 4:31:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-308 220	Building G Room G7	Manual	3/10/2026 4:31:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-309 219	Building G Room G7	Manual	3/10/2026 4:32:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-307 218	Building G Room G7	Manual	3/10/2026 4:32:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-390 227	Building G RR Plumb Chase G8	Manual	3/10/2026 7:05:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-389 228	Building G RR Plumb Chase G9	Manual	3/10/2026 7:06:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	? 229	Building G RR Plumb G11/G12	Manual	3/10/2026 7:05:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-375 198	Building G Staff G1 Copy Rm	Manual	3/10/2026 5:01:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-283 197	Building G Staff G1 Copy Rm	Manual	3/10/2026 5:01:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - Duct	2-386 230	Building G Staff Room G1	Manual	3/10/2026 6:48:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-281 196	Building G Staff Room G1	Manual	3/10/2026 5:01:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-280 195	Building G Staff Room G1	Manual	3/10/2026 5:01:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-278 194	Building G Staff Room G1	Manual	3/10/2026 5:01:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-279 193	Building G Staff Room G1	Manual	3/10/2026 5:01:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-282 199	Building G Staff Room G1 Office	Manual	3/10/2026 5:01:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-289 226	Building G Womens RR G12	Manual	3/10/2026 4:47:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-376 259	Building H Attic Room H1	Manual	3/10/2026 7:22:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-376 260	Building H Attic Room H1	Manual	3/10/2026 7:22:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-377 262	Building H Attic Room H3	Manual	3/10/2026 7:27:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-377 261	Building H Attic Room H3	Manual	3/10/2026 7:27:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-378 263	Building H Attic Room H4	Manual	3/10/2026 7:30:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-378 264	Building H Attic Room H4	Manual	3/10/2026 7:30:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-379 265	Building H Attic Room H5	Manual	3/10/2026 7:32:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-379 266	Building H Attic Room H5	Manual	3/10/2026 7:32:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-317 250	Building H Room H1	Manual	3/10/2026 5:45:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-316 251	Building H Room H1	Manual	3/10/2026 5:45:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-315 252	Building H Room H2	Manual	3/10/2026 6:49:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-319 253	Building H Room H3	Manual	3/10/2026 5:44:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-318 254	Building H Room H3	Manual	3/10/2026 5:44:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-323 255	Building H Room H4	Manual	3/10/2026 5:43:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-322 256	Building H Room H4	Manual	3/10/2026 5:43:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-321 257	Building H Room H5	Manual	3/10/2026 5:42:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-320 258	Building H Room H5	Manual	3/10/2026 5:42:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-383 302	Building I Attic Rm I-1 Cust Off	Manual	3/10/2026 7:40:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-383 301	Building I Attic Rm I-1 Office	Manual	3/10/2026 7:40:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-383 300	Building I Attic Rm I-1 Office	Manual	3/10/2026 7:40:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-382 303	Building I Attic Rm I-3 Office	Manual	3/10/2026 7:40:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-381 298	Building I Attic Room I-1	Manual	3/10/2026 7:40:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-381 299	Building I Attic Room I-1	Manual	3/10/2026 7:40:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-358 275	Building I Room I-1	Manual	3/10/2026 5:11:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-356 278	Building I Room I-1	Manual	3/10/2026 5:21:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-355 277	Building I Room I-1	Manual	3/10/2026 5:21:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-357 276	Building I Room I-1	Manual	3/10/2026 5:22:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-352 281	Building I Room I-1 Cust Office	Manual	3/10/2026 6:48:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-353 280	Building I Room I-1 Office	Manual	3/10/2026 5:18:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-354 279	Building I Room I-1 Office	Manual	3/10/2026 5:19:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-361 282	Building I Room I-2	Manual	3/10/2026 5:25:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-360 284	Building I Room I-2	Manual	3/10/2026 5:25:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-359 283	Building I Room I-2	Manual	3/10/2026 5:26:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-365 287	Building I Room I-2 Office	Manual	3/10/2026 5:27:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-366 286	Building I Room I-2 Office	Manual	3/10/2026 5:28:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-364 288	Building I Room I-2 Restroom	Manual	3/10/2026 5:26:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-367 285	Building I Room I-2 Storage	Manual	3/10/2026 5:28:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-372 290	Building I Room I-3	Manual	3/10/2026 5:33:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-374 289	Building I Room I-3	Manual	3/10/2026 5:33:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-373 291	Building I Room I-3	Manual	3/10/2026 6:49:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-369 294	Building I Room I-3 Office	Manual	3/10/2026 6:48:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-371 292	Building I Room I-3 Restroom	Manual	3/10/2026 5:32:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-370 293	Building I Room I-3 Storage	Manual	3/10/2026 5:32:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-368 295	Building I Room I-3 Storage	Manual	3/10/2026 6:48:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-363 296	Building I Room I-4 Storage	Manual	3/10/2026 6:48:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-362 297	Building I Room I-5 Storage	Manual	3/10/2026 5:29:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-384 342	Building J Attic Rm J3 Office	Manual	3/10/2026 7:05:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-385 344	Building J Attic Rm J3 Storage	Manual	3/10/2026 7:05:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-385 345	Building J Attic Rm J3 Storage	Manual	3/10/2026 7:05:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-384 343	Building J Attic Rm J4 Boys RR	Manual	3/10/2026 7:05:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-332 318	Building J Room J1	Manual	3/10/2026 5:05:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-333 319	Building J Room J1	Manual	3/10/2026 5:05:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-330 317	Building J Room J1	Manual	3/10/2026 5:06:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-331 316	Building J Room J1	Manual	3/10/2026 5:07:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-328 320	Building J Room J2	Manual	3/10/2026 5:01:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-329 321	Building J Room J2	Manual	3/10/2026 5:02:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-327 323	Building J Room J2	Manual	3/10/2026 5:03:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-326 322	Building J Room J2	Manual	3/10/2026 5:03:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-337 325	Building J Room J3	Manual	3/10/2026 5:08:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-340 326	Building J Room J3	Manual	3/10/2026 5:08:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-339 327	Building J Room J3	Manual	3/10/2026 5:09:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-338 324	Building J Room J3	Manual	3/10/2026 6:48:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-349 330	Building J Room J3 Office	Manual	3/10/2026 5:12:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-334 329	Building J Room J3 Restroom	Manual	3/10/2026 5:11:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-336 328	Building J Room J3 Storage	Manual	3/10/2026 5:09:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-351 331	Building J Room J4 Boys RR	Manual	3/10/2026 5:04:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-350 332	Building J Room J5 Girls RR	Manual	3/10/2026 5:11:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-346 333	Building J Room J6	Manual	3/10/2026 5:11:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-347 336	Building J Room J6	Manual	3/10/2026 5:12:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-348 335	Building J Room J6	Manual	3/10/2026 5:12:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-345 334	Building J Room J6	Manual	3/10/2026 5:13:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-341 337	Building J Room J7	Manual	3/10/2026 5:14:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-344 338	Building J Room J7	Manual	3/10/2026 5:15:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-343 339	Building J Room J7	Manual	3/10/2026 5:15:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-342 340	Building J Room J7	Manual	3/10/2026 6:48:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-335 341	Building J Room J8 Storage	Manual	3/10/2026 6:48:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-135 397	Building K Attic Kitchen K2	Manual	3/10/2026 7:12:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-135 398	Building K Attic Kitchen K2	Manual	3/10/2026 7:12:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-141 399	Building K Attic Stage Upper Strg	Manual	3/10/2026 7:06:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-060 395	Building K Kitchen K2	Manual	3/10/2026 7:10:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-061 396	Building K Kitchen K2	Manual	3/10/2026 7:11:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-154 363	Building K Kitchen K2 NE	Manual	3/10/2026 8:44:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-155 364	Building K Kitchen K2 South	Manual	3/10/2026 8:44:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-062 389	Building K Kitchen K2 Storage	Manual	3/10/2026 6:49:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-064 387	Building K MP Rm K1 Chair Strg	Manual	3/10/2026 3:59:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-063 388	Building K MP Rm K1 Mech Clst	Manual	3/10/2026 4:03:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-132 401	Building K MP Room K1	Manual	3/10/2026 6:48:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-131 400	Building K MP Room K1	Manual	3/10/2026 6:48:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-066 367	Building K MP Room K1	Manual	3/10/2026 3:47:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-065 366	Building K MP Room K1	Manual	3/10/2026 3:48:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-067 368	Building K MP Room K1	Manual	3/10/2026 3:49:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-068 369	Building K MP Room K1	Manual	3/10/2026 3:49:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-076 377	Building K MP Room K1	Manual	3/10/2026 3:50:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-075 376	Building K MP Room K1	Manual	3/10/2026 3:50:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-074 375	Building K MP Room K1	Manual	3/10/2026 3:50:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-073 374	Building K MP Room K1	Manual	3/10/2026 3:51:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-077 378	Building K MP Room K1	Manual	3/10/2026 3:51:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-081 382	Building K MP Room K1	Manual	3/10/2026 3:52:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-082 383	Building K MP Room K1	Manual	3/10/2026 3:52:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-079 380	Building K MP Room K1	Manual	3/10/2026 3:55:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-084 385	Building K MP Room K1	Manual	3/10/2026 3:56:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-080 381	Building K MP Room K1	Manual	3/10/2026 3:56:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-069 370	Building K MP Room K1	Manual	3/10/2026 6:48:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-070 371	Building K MP Room K1	Manual	3/10/2026 6:49:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-071 372	Building K MP Room K1	Manual	3/10/2026 6:49:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-072 373	Building K MP Room K1	Manual	3/10/2026 6:49:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-078 379	Building K MP Room K1	Manual	3/10/2026 6:49:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-083 384	Building K MP Room K1	Manual	3/10/2026 6:49:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-153 361	Building K MP Room K1 East	Manual	3/10/2026 8:44:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-150 360	Building K MP Room K1 North	Manual	3/10/2026 8:44:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-120 386	Building K MP Room K1 Storage	Manual	3/10/2026 3:58:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-151 362	Building K MP Room K1 West	Manual	3/10/2026 8:44:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	2-133 402	Building K Stage K3	Manual	3/10/2026 8:44:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-089 394	Building K Stage K3	Manual	3/10/2026 4:00:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-085 390	Building K Stage K3	Manual	3/10/2026 4:00:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-086 391	Building K Stage K3	Manual	3/10/2026 4:01:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-087 392	Building K Stage K3	Manual	3/10/2026 4:01:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-088 393	Building K Stage K3	Manual	3/10/2026 4:02:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-152 365	Building K Stage K3 South	Manual	3/10/2026 8:44:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4.011	Portable Rm C5	Manual	3/10/2026 2:46:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4.012	Portable Rm C5	Manual	3/10/2026 2:46:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

**Ventilation and Cooking Equipment**

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Cooking Equipment	Appliances		Manual	3/10/2026 2:43:21 PM
Fusible Links	Fusible Links		Manual	3/10/2026 2:43:18 PM
Range Hood	Hood		Manual	3/10/2026 2:43:24 PM
Range Suppression	Suppression System		Manual	3/10/2026 2:43:28 PM
Range Suppression Tank	RG2.5G Cylinder		Manual	3/10/2026 2:43:32 PM

## Device/Equipment details

### Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Audible					
060	Building C South Exterior				
095	Building D North Exterior				
096	Building D East Exterior				
097	Building D South Exterior				
098	Building D South Exterior				
141	Building E East Exterior				
142	Building E South Exterior				
143	Building E South Exterior				
144	Building E South Exterior				
181	Building F East Exterior				
182	Building F Southeast Exterior				
183	Building F South Middle Exterior				
184	Building F Southwest Exterior				
232	Building G East Exterior				
233	Building G South Exterior				
234	Building G South Exterior				
235	Building G South Exterior				
236	Building G South Exterior				
237	Building G West Exterior				
267	Building H East Exterior				
268	Building H South Exterior				
269	Building H West Exterior				
304	Building I North Exterior				
305	Building I East Exterior				
306	Building I East Exterior				
307	Building I South Exterior				
308	Building I West Exterior				
346	Building J East Exterior				
347	Building J East Exterior				
348	Building J South Exterior				
349	Building J West Exterior				
350	Building J West Exterior				
403	Building K East Exterior				
404	Building K South Exterior				
405	Building K West Exterior				
011	Admin Building East Exterior				
012	Admin Building South Exterior				
013	Admin Building West Exterior				
035	Building B North Exterior				
036	Building B South Exterior				
037	Building B South Exterior				
Audible And Visible					
061	Building C Room C1				
062	Building C Room C2				
063	Building C Room C3				
064	Building C Room C4				
099	Building D Room D1				
100	Building D Room D2				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
101	Building D Room D3				
102	Building D Room D4				
103	Building D Room D5				
104	Building D Room D6				
145	Building E Room E1				
146	Building E Room E2				
147	Building E Room E3				
148	Building E Room E4				
149	Building E Room E5				
150	Building E Room E6				
185	Building F Room F1				
186	Building F Room F2				
187	Building F Room F3				
188	Building F Room F4				
189	Building F Room F5				
190	Building F Room F6				
238	Building G Staff Room G1				
239	Building G Room G2				
240	Building G Room G3				
241	Building G Room G4				
242	Building G Room G5				
243	Building G Room G6				
244	Building G Room G7				
270	Building H Room H1				
271	Building H Room H2				
272	Building H Room H3				
273	Building H Room H4				
274	Building H Room H5				
309	Building I Room I-1				
310	Building I Room I-2				
311	Building I Room I-3				
351	Building J Room J1				
352	Building J Room J2				
353	Building J Room J3				
354	Building J Room J6				
355	Building J Room J7				
406	Building K MP Room K1				
407	Building K MP Room K1				
408	Building K Kitchen K2				
409	Building K Stage K3				
014	Admin Building Office A3				
015	Admin Building Office Copy Rm A4				
038	Building B Room B1				
039	Building B Room B2				
Visible					
105	Building D Girls Restroom D7				
106	Building D Boys Restroom D9				
151	Building E Girls Restroom E7				
152	Building E Boys Restroom E8				
191	Building F Room F1				
245	Building G Boys Restroom G8				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
246	Building G Girls Restroom G9				
247	Building G Mens Restroom G10				
248	Building G Womens RR G12				
312	Building I Room I-1				
313	Building I Room I-2 Restroom				
314	Building I Room I-3 Restroom				
356	Building J Room J3				
357	Building J Room J3				
358	Building J Room J4 Boys RR				
359	Building J Room J5 Girls RR				
016	Admin Building Office Reception				
017	Admin Building Mens Restroom				
018	Admin Building Womens Restroom				
040	Building B Room B1				
041	Building B Room B2				
042	Building B Room B1 Restroom				
043	Building B Room B2 Restroom				

### Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
NAC Power Extender Panel					
065	Building C Room C2				
107	Building D Janitors Room D8				
153	Building E Headend Room E10				
154	Building E Headend Room E10				
192	Building F Janitors Room F9				
249	Building G Janitors Room G11				
315	Building I Room I-1 Cust Office				

### Remote Annunciator

001	Admin Building Office Reception				
-----	---------------------------------	--	--	--	--

### Fire Alarm Panel

	Building E Headend Room E10	Notifier		NFS-3030	03/18/2019
--	-----------------------------	----------	--	----------	------------

### Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Heat Detector - Restorable Spot					
2-130 052	Building C Attic Room C1				
2-130 053	Building C Attic Room C1				
4-128 054	Building C Attic Room C2				
4-128 055	Building C Attic Room C2				
4-129 056	Building C Attic Room C3				
4-129 057	Building C Attic Room C3				
4-130 058	Building C Attic Room C4				
4-130 059	Building C Attic Room C4				
2-139 094	Building D RR Plumb Chase D8				
2-003 138	Building E Headend Room E10				
2-137 139	Building E RR Plumb Chase E7				
2-136 140	Building E RR Plumb Chase E8				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-388 179	Building F Attic Room F1				
2-387 180	Building F Attic Room F7				
2-390 227	Building G RR Plumb Chase G8				
2-389 228	Building G RR Plumb Chase G9				
? 229	Building G RR Plumb G11/G12				
2-376 259	Building H Attic Room H1				
2-376 260	Building H Attic Room H1				
2-377 261	Building H Attic Room H3				
2-377 262	Building H Attic Room H3				
2-378 263	Building H Attic Room H4				
2-378 264	Building H Attic Room H4				
2-379 265	Building H Attic Room H5				
2-379 266	Building H Attic Room H5				
2-381 298	Building I Attic Room I-1				
2-381 299	Building I Attic Room I-1				
2-383 300	Building I Attic Rm I-1 Office				
2-383 301	Building I Attic Rm I-1 Office				
2-383 302	Building I Attic Rm I-1 Cust Off				
2-382 303	Building I Attic Rm I-3 Office				
2-384 342	Building J Attic Rm J3 Office				
2-384 343	Building J Attic Rm J4 Boys RR				
2-385 344	Building J Attic Rm J3 Storage				
2-385 345	Building J Attic Rm J3 Storage				
2-060 395	Building K Kitchen K2				
2-061 396	Building K Kitchen K2				
2-135 397	Building K Attic Kitchen K2				
2-135 398	Building K Attic Kitchen K2				
2-141 399	Building K Attic Stage Upper Strg				
2-138 031	Building B Attic Room B1				
2-138 032	Building B Attic Room B1 RR				
2-138 033	Building B Attic Room B2				
2-138 034	Building B Attic Room B2 RR				
Smoke Detector - General					
2-035 066	Building D Room D1				
2-037 067	Building D Room D1				
2-038 068	Building D Room D1				
2-036 069	Building D Room D1				
2-119 070	Building D Room D1 Storage				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-040 071	Building D Room D2				
2-042 072	Building D Room D2				
2-041 073	Building D Room D2				
2-039 074	Building D Room D2				
2-045 075	Building D Room D3				
2-043 076	Building D Room D3				
2-044 077	Building D Room D3				
2-046 078	Building D Room D3				
2-047 079	Building D Room D4				
2-049 080	Building D Room D4				
2-050 081	Building D Room D4				
2-048 082	Building D Room D4				
2-053 083	Building D Room D5				
2-051 084	Building D Room D5				
2-052 085	Building D Room D5				
2-054 086	Building D Room D5				
2-055 087	Building D Room D6				
2-057 088	Building D Room D6				
2-058 089	Building D Room D6				
2-056 090	Building D Room D6				
2-033 091	Building D Girls Restroom D7				
2-032 092	Building D Janitors Room D8				
2-034 093	Building D Boys Restroom D9				
2-093 108	Building E Room E1				
2-094 109	Building E Room E1				
2-095 110	Building E Room E1 Office				
2-097 111	Building E Room E2				
2-096 112	Building E Room E2				
2-099 113	Building E Room E2				
2-098 114	Building E Room E2				
2-103 115	Building E Room E3				
2-102 116	Building E Room E3				
2-100 117	Building E Room E3				
2-101 118	Building E Room E3				
2-105 119	Building E Room E4				
2-106 120	Building E Room E4				
2-107 121	Building E Room E4				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-104 122	Building E Room E4				
2-111 123	Building E Room E5				
2-109 124	Building E Room E5				
2-108 125	Building E Room E5				
2-110 126	Building E Room E5				
2-113 127	Building E Room E6				
2-115 128	Building E Room E6				
2-114 129	Building E Room E6				
2-112 130	Building E Room E6				
2-117 131	Building E Girls Restroom E7				
2-116 132	Building E Janitors Room E7A				
2-118 133	Building E Boys Restroom E8				
2-091 134	Building E E9 Boiler Room				
2-092 135	Building E E9 Boiler Room				
2-090 136	Building E E9 Boiler Room				
2-002 137	Building E Headend Room E10				
2-259 155	Building F Room F1				
2-257 156	Building F Room F1				
2-258 157	Building F Room F1				
2-256 158	Building F Room F1				
2-260 159	Building F Room F1 Office				
2-255 160	Building F Classroom F1A				
2-262 161	Building F Room F2				
2-261 162	Building F Room F2				
2-265 163	Building F Room F3				
2-267 164	Building F Room F3				
2-268 165	Building F Room F3				
2-266 166	Building F Room F3				
2-272 167	Building F Room F4				
2-270 168	Building F Room F4				
2-269 169	Building F Room F4				
2-271 170	Building F Room F4				
2-273 171	Building F Room F5				
2-274 172	Building F Room F5				
2-276 173	Building F Room F5				
2-275 174	Building F Room F5				
2-263 175	Building F Room F6				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-264 176	Building F Room F6				
2-253 177	Building F Room F7 F8				
2-254 178	Building F Janitors Room F9				
2-279 193	Building G Staff Room G1				
2-278 194	Building G Staff Room G1				
2-280 195	Building G Staff Room G1				
2-281 196	Building G Staff Room G1				
2-283 197	Building G Staff G1 Copy Rm				
2-375 198	Building G Staff G1 Copy Rm				
2-282 199	Building G Staff Room G1 Office				
2-291 200	Building G Room G2				
2-290 201	Building G Room G2				
2-285 202	Building G Room G2 Office				
2-286 203	Building G Room G2 Office				
2-293 204	Building G Room G3				
2-292 205	Building G Room G3				
2-297 206	Building G Room G4				
2-296 207	Building G Room G4				
2-294 208	Building G Room G4				
2-295 209	Building G Room G4				
2-299 210	Building G Room G5				
2-301 211	Building G Room G5				
2-300 212	Building G Room G5				
2-298 213	Building G Room G5				
2-305 214	Building G Room G6				
2-304 215	Building G Room G6				
2-302 216	Building G Room G6				
2-303 217	Building G Room G6				
2-307 218	Building G Room G7				
2-309 219	Building G Room G7				
2-308 220	Building G Room G7				
2-306 221	Building G Room G7				
2-311 222	Building G Boys Restroom G8				
2-310 223	Building G Girls Restroom G9				
2-287 224	Building G Mens Restroom G10				
2-288 225	Building G Janitors Room G11				
2-289 226	Building G Womens RR G12				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-317 250	Building H Room H1				
2-316 251	Building H Room H1				
2-315 252	Building H Room H2				
2-319 253	Building H Room H3				
2-318 254	Building H Room H3				
2-323 255	Building H Room H4				
2-322 256	Building H Room H4				
2-321 257	Building H Room H5				
2-320 258	Building H Room H5				
2-358 275	Building I Room I-1				
2-357 276	Building I Room I-1				
2-355 277	Building I Room I-1				
2-356 278	Building I Room I-1				
2-354 279	Building I Room I-1 Office				
2-353 280	Building I Room I-1 Office				
2-352 281	Building I Room I-1 Cust Office				
2-361 282	Building I Room I-2				
2-359 283	Building I Room I-2				
2-360 284	Building I Room I-2				
2-367 285	Building I Room I-2 Storage				
2-366 286	Building I Room I-2 Office				
2-365 287	Building I Room I-2 Office				
2-364 288	Building I Room I-2 Restroom				
2-374 289	Building I Room I-3				
2-372 290	Building I Room I-3				
2-373 291	Building I Room I-3				
3-371 292	Building I Room I-3 Restroom				
2-370 293	Building I Room I-3 Storage				
2-369 294	Building I Room I-3 Office				
2-368 295	Building I Room I-3 Storage				
2-363 296	Building I Room I-4 Storage				
2-362 297	Building I Room I-5 Storage				
2-331 316	Building J Room J1				
2-330 317	Building J Room J1				
2-332 318	Building J Room J1				
2-333 319	Building J Room J1				
2-328 320	Building J Room J2				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-329 321	Building J Room J2				
2-326 322	Building J Room J2				
2-327 323	Building J Room J2				
2-338 324	Building J Room J3				
2-337 325	Building J Room J3				
2-340 326	Building J Room J3				
2-339 327	Building J Room J3				
2-336 328	Building J Room J3 Storage				
2-334 329	Building J Room J3 Restroom				
2-349 330	Building J Room J3 Office				
2-351 331	Building J Room J4 Boys RR				
2-350 332	Building J Room J5 Girls RR				
2-346 333	Building J Room J6				
2-345 334	Building J Room J6				
2-348 335	Building J Room J6				
2-347 336	Building J Room J6				
2-341 337	Building J Room J7				
2-344 338	Building J Room J7				
2-343 339	Building J Room J7				
2-342 340	Building J Room J7				
2-335 341	Building J Room J8 Storage				
2-065 366	Building K MP Room K1				
2-066 367	Building K MP Room K1				
2-067 368	Building K MP Room K1				
2-068 369	Building K MP Room K1				
2-069 370	Building K MP Room K1				
2-070 371	Building K MP Room K1				
2-071 372	Building K MP Room K1				
2-072 373	Building K MP Room K1				
2-073 374	Building K MP Room K1				
2-074 375	Building K MP Room K1				
2-075 376	Building K MP Room K1				
2-076 377	Building K MP Room K1				
2-077 378	Building K MP Room K1				
2-078 379	Building K MP Room K1				
2-079 380	Building K MP Room K1				
2-080 381	Building K MP Room K1				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-081 382	Building K MP Room K1				
2-082 383	Building K MP Room K1				
2-083 384	Building K MP Room K1				
2-084 385	Building K MP Room K1				
2-120 386	Building K MP Room K1 Storage				
2-064 387	Building K MP Rm K1 Chair Strg				
2-063 388	Building K MP Rm K1 Mech Clst				
2-062 389	Building K Kitchen K2 Storage				
2-085 390	Building K Stage K3				
2-086 391	Building K Stage K3				
2-087 392	Building K Stage K3				
2-088 393	Building K Stage K3				
2-089 394	Building K Stage K3				
2-010 003	Admin Building Office Reception				
2-013 004	Admin Building Office A2				
2-012 005	Admin Building Principals Office				
2-005 006	Admin Building Office A3				
2-006 007	Admin Building Office Copy Rm A4				
2-009 008	Admin Building Office Restroom				
2-007 009	Admin Building Mens Restroom				
2-008 010	Admin Building Womens Restroom				
2-018 019	Building B Room B1				
2-020 020	Building B Room B1				
2-019 021	Building B Room B1				
2-017 022	Building B Room B1				
2-016 023	Building B Room B1 Restroom				
2-015 024	Building B Room B1 Storage				
2-025 025	Building B Room B2				
2-026 026	Building B Room B2				
2-024 027	Building B Room B2				
2-023 028	Building B Room B2				
2-022 029	Building B Room B2 Restroom				
2-021 030	Building B Room B2 Storage				
2-029 044	Building C Room C1				
2-030 045	Building C Room C1				
4-005 046	Building C Room C2				
4-006 047	Building C Room C2				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
4-008 048	Building C Room C3				
4-007 049	Building C Room C3				
4-010 050	Building C Room C4				
4-009 051	Building C Room C4				
4.011	Portable Rm C5				
4.012	Portable Rm C5				
Smoke Detector - Duct					
2-386 230	Building G Staff Room G1				
2-380 231	Building G Room G2				
2-131 400	Building K MP Room K1				
2-132 401	Building K MP Room K1				
Manual Pull Station					
2-150 360	Building K MP Room K1 North				
2-153 361	Building K MP Room K1 East				
2-151 362	Building K MP Room K1 West				
2-154 363	Building K Kitchen K2 NE				
2-155 364	Building K Kitchen K2 South				
2-152 365	Building K Stage K3 South				
2-134 002	Admin Building Office Reception				
Mechanical, Electrosonic, or Pressure Waterflow Device					
2-133 402	Building K Stage K3				

### Ventilation and Cooking Equipment

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Range Suppression Tank					
	RG2.5G Cylinder				01/01/2015
Range Suppression					
	Suppression System				01/01/2015
Range Hood					
	Hood				01/01/2015
Cooking Equipment					
	Appliances				01/01/2015
Fusible Links					
	Fusible Links				08/27/2025