

Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

GREEN OAKS ELEMENTARY

7145 FILBERT AVE
ORANGEVALE, California 95662
United States

This site has been inspected and tested in compliance with applicable standards.

Completed
Wednesday, March 18, 2026

Test Session: 18 Mar 2026 16:41 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD
5320 HEMLOCK ST
SACRAMENTO, California
United States

TESTED BY

Riley Goyet
Western States Fire Protection-
Sacramento
188 Cirby Way
Roseville, CA 95678
United States



Inspection Summary

Building Information

PROPERTY	GREEN OAKS ELEMENTARY	CONTACT
ADDRESS	7145 FILBERT AVE	PHONE
CITY/STATE	ORANGEVALE, California 95662	MOBILE
COUNTRY	United States	EMAIL

Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us

Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Alarm Notification Appliance	60	60(100%)	60(100%)	0(0%)
Power Supplies	16	16(100%)	16(100%)	0(0%)
Fire Control Panel	10	10(100%)	10(100%)	0(0%)
Initiating Device	152	152(100%)	151(99%)	1(1%)

Certification

The equipment specified herein was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Wednesday, March 18, 2026

ACCEPTED BY 03/18/2026

Building Representative

TESTED BY 03/18/2026

Riley
Riley Goyet
Technician

Open Corrective Action & Solution Summary

The following 2 corrective action(s) remain open following the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
Smoke Detector - General	2.054 8254	Admin Building - Nurse Office RR
	Created By:	Riley Goyet
	Creation Date:	02/02/2023
	Corrective Action:	Came in as 2.057
	Proposed Solution:	
	Manufacturer:	EST
	Model:	
	Created By:	Riley Goyet
	Creation Date:	02/01/2024
	Corrective Action:	Activated but came in as 2.057
	Proposed Solution:	
	Manufacturer:	EST
	Model:	

Testing Details

Alarm Notification Appliance

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible		Admin Building - Admin Reception	Manual	3/18/2026 9:10:34 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
Visible		Admin Building - Nurse Office	Manual	3/18/2026 9:11:10 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
Visible		Admin Building - Nurse Office RR	Manual	3/18/2026 9:11:09 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
Visible		Admin Building - Principals Office	Manual	3/18/2026 9:11:12 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
Visible		Admin Building - Staff Mens RR	Manual	3/18/2026 9:11:18 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
Visible		Admin Building - Staff Womens RR	Manual	3/18/2026 9:11:19 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
Visible		Admin Building - Staff Work Room	Manual	3/18/2026 4:45:11 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
Audible		Admin Building - West Exterior	Manual	3/18/2026 9:10:13 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
Audible		Kindergarten Bldg - East Exterior	Manual	3/18/2026 9:10:24 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
Audible And Visible		Kindergarten Bldg - Kindergarten Classroom	Manual	3/18/2026 9:11:00 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
Visible		Kindergarten Bldg - Kindergarten RR	Manual	3/18/2026 9:11:22 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
Audible		Multi Purpose Bldg - East Exterior	Manual	3/18/2026 9:10:31 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
Audible And Visible		Multi Purpose Bldg - Kitchen	Manual	3/18/2026 9:11:04 PM
		Manufacturer	Gentex	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Multi Purpose Bldg - Mens Restroom	Manual	3/18/2026 9:11:25 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Multi Purpose Bldg - MP Room	Manual	3/18/2026 9:10:56 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Multi Purpose Bldg - MP Room	Manual	3/18/2026 9:10:58 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Multi Purpose Bldg - MP Room	Manual	3/18/2026 9:11:01 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Multi Purpose Bldg - North Exterior	Manual	3/18/2026 9:10:26 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Multi Purpose Bldg - Restroom Hallway	Manual	3/18/2026 9:11:07 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Multi Purpose Bldg - South Exterior (Local Electric Bell)	Manual	3/18/2026 9:10:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Multi Purpose Bldg - Stage	Manual	3/18/2026 9:11:02 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Multi Purpose Bldg - Stage Corridor East	Manual	3/18/2026 4:45:10 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Multi Purpose Bldg - Stage Corridor West	Manual	3/18/2026 9:11:05 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Multi Purpose Bldg - West Exterior	Manual	3/18/2026 9:10:29 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Multi Purpose Bldg - Womens Restroom	Manual	3/18/2026 9:11:24 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Portables - Room 18	Manual	3/18/2026 4:45:06 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Portables - Room 19	Manual	3/18/2026 4:45:07 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Audible		Portables - South Exterior	Manual	3/18/2026 9:10:28 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 13 & 14 Bldg - Classroom 13	Manual	3/18/2026 4:46:00 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 13 & 14 Bldg - Classroom 14	Manual	3/18/2026 4:45:59 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 13 & 14 Bldg - Library Media Center	Manual	3/18/2026 4:46:02 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 13 & 14 Bldg - Library Media Center	Manual	3/18/2026 4:46:03 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 13 & 14 Bldg - South Exterior	Manual	3/18/2026 4:45:57 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 15 & 16 Bldg - Classroom 15	Manual	3/18/2026 4:42:42 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 15 & 16 Bldg - Classroom 16	Manual	3/18/2026 4:42:44 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 15 & 16 Bldg - South Exterior	Manual	3/18/2026 4:42:39 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Rooms 1-6 Bldg - Boys Restroom	Manual	3/18/2026 9:11:16 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 1-6 Bldg - Classroom 1	Manual	3/18/2026 9:10:38 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 1-6 Bldg - Classroom 2	Manual	3/18/2026 9:10:37 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 1-6 Bldg - Classroom 3	Manual	3/18/2026 9:10:36 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 1-6 Bldg - Classroom 4	Manual	3/18/2026 9:10:41 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible		Rooms 1-6 Bldg - Classroom 5	Manual	3/18/2026 9:10:40 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 1-6 Bldg - Classroom 6	Manual	3/18/2026 9:10:45 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Rooms 1-6 Bldg - Girls Restroom	Manual	3/18/2026 9:11:21 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 1-6 Bldg - North Exterior	Manual	3/18/2026 9:10:14 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 1-6 Bldg - Room A	Manual	3/18/2026 9:10:43 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 1-6 Bldg - Room B	Manual	3/18/2026 9:10:48 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 1-6 Bldg - South Exterior	Manual	3/18/2026 9:10:18 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 1-6 Bldg - West Exterior	Manual	3/18/2026 9:10:16 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Rooms 7-12 Bldg - Boys Restroom	Manual	3/18/2026 4:43:10 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 7-12 Bldg - Classroom 10	Manual	3/18/2026 9:10:51 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 7-12 Bldg - Classroom 11	Manual	3/18/2026 9:10:52 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 7-12 Bldg - Classroom 12	Manual	3/18/2026 9:10:55 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 7-12 Bldg - Classroom 7	Manual	3/18/2026 9:10:46 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 7-12 Bldg - Classroom 8	Manual	3/18/2026 9:10:49 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 7-12 Bldg - Classroom 9	Manual	3/18/2026 9:10:54 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Rooms 7-12 Bldg - Girls Restroom	Manual	3/18/2026 4:43:12 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 7-12 Bldg - North Exterior	Manual	3/18/2026 9:10:19 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 7-12 Bldg - South Exterior	Manual	3/18/2026 9:10:20 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 7-12 Bldg - West Exterior	Manual	3/18/2026 9:10:22 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Remote Annunciator		Admin Building - Admin Reception	Manual	3/18/2026 9:07:26 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Admin Building - Electrical Room - P.E. "C"	Manual	3/18/2026 9:09:05 PM
		Manufacturer	Fire-Lite	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Fire Alarm Panel		FACP Room	Manual	3/18/2026 9:07:38 PM
		Manufacturer	EST-3	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Multi Purpose Bldg - Electrical Closet - P.E. "E"	Manual	3/18/2026 9:09:19 PM
		Manufacturer	Fire-Lite	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Rooms 13 & 14 Bldg - Room 14 Data Closet - P.E. "B"	Manual	3/18/2026 4:45:38 PM
		Manufacturer	Fire-Lite	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Rooms 1-6 Bldg - Custodial Storage - P.E. "D"	Manual	3/18/2026 9:07:51 PM
		Manufacturer	Fire-Lite	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Fire Alarm Panel		Rooms 7-12 Bldg - Sci/Art Room D - FACP	Manual	3/18/2026 4:44:39 PM
		Manufacturer	EST	
		Model	3	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Rooms 7-12 Bldg - Sci/Art Room D - P.E. "A"	Manual	3/18/2026 4:44:40 PM
		Manufacturer	Fire-Lite	
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
NAC Power Extender Panel		Rooms 7-12 Bldg - Sci/Art Room D - P.E. "Master"	Manual	3/18/2026 4:44:38 PM
		Manufacturer	Fire-Lite	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Fire Alarm Panel		Rooms 7-12 Bldg - Sci/Art Room D - Voice EVAC Panel	Manual	3/18/2026 4:44:36 PM
		Manufacturer	EST	
		Model	3	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Alarm Verification Timer (s)	30_seconds	

Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Manual Pull Station	2.143 8250	Admin Building - Admin Reception	Manual	3/18/2026 9:09:08 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.060 8256	Admin Building - Closet	Manual	3/18/2026 9:09:13 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.065 8255	Admin Building - Electrical Room	Manual	3/18/2026 9:09:16 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.057 8253	Admin Building - Nurse Office	Manual	3/18/2026 9:09:10 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.059 8251	Admin Building - Office	Manual	3/18/2026 9:09:15 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.061 8252	Admin Building - Principals Office	Manual	3/18/2026 9:09:11 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.053 8257	Admin Building - Staff Mens RR	Manual	3/18/2026 9:07:48 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.055 8258	Admin Building - Staff Womens RR	Manual	3/18/2026 9:07:50 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.052 8248	Admin Building - Staff Work Room	Manual	3/18/2026 9:09:06 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.285 8383	Kindergarten Bldg - Kindergarten Classroom	Manual	3/18/2026 9:08:23 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.287 8385	Kindergarten Bldg - Kindergarten Classroom	Manual	3/18/2026 9:08:25 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.286 8384	Kindergarten Bldg - Kindergarten Classroom	Manual	3/18/2026 9:08:29 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.284 8382	Kindergarten Bldg - Kindergarten Classroom	Manual	3/18/2026 9:08:30 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.289 8386	Kindergarten Bldg - Kindergarten RR	Manual	3/18/2026 9:08:26 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.288 8387	Kindergarten Bldg - Kindergarten Storage	Manual	3/18/2026 9:08:28 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.298 8397	Multi Purpose Bldg - MP Room Storage	Manual	3/18/2026 9:09:48 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.392 8414	Multi Purpose Bldg - Attic Custodial Office	Manual	3/18/2026 9:09:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.393 8410	Multi Purpose Bldg - Attic Kitchen	Manual	3/18/2026 9:09:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.393 8412	Multi Purpose Bldg - Attic Mens Restroom	Manual	3/18/2026 9:09:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2.395 206	Multi Purpose Bldg - Attic MP Room	Manual	3/18/2026 9:07:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.391 196	Multi Purpose Bldg - Attic MP Room East	Manual	3/18/2026 9:09:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.394 197	Multi Purpose Bldg - Attic MP Room West	Manual	3/18/2026 9:09:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.393 8411	Multi Purpose Bldg - Attic RR Hallway	Manual	3/18/2026 9:09:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.393 8413	Multi Purpose Bldg - Attic Womens RR	Manual	3/18/2026 9:09:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2.332 8399	Multi Purpose Bldg - Custodial Office	Manual	3/18/2026 9:10:02 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.292 8393	Multi Purpose Bldg - Electrical Closet	Manual	3/18/2026 9:09:54 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.296 8403	Multi Purpose Bldg - Kitchen	Manual	3/18/2026 9:09:43 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2.151 8392	Multi Purpose Bldg - Kitchen Exit	Manual	3/18/2026 9:09:45 PM
		Manufacturer	Fire-Lite	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.297 188	Multi Purpose Bldg - Kitchen Office	Manual	3/18/2026 9:09:25 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2.384 208	Multi Purpose Bldg - Kitchen Roof	Manual	3/18/2026 9:07:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.294 8396	Multi Purpose Bldg - Mens Restroom	Manual	3/18/2026 9:09:51 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	2.396 8419	Multi Purpose Bldg - MP Room	Manual	3/18/2026 9:10:00 PM
		Manufacturer	System Sensor	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Projected Beam	2.388 8416	Multi Purpose Bldg - MP Room Middle	Manual	3/18/2026 9:09:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Projected Beam	2.386 8417	Multi Purpose Bldg - MP Room North	Manual	3/18/2026 4:45:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Projected Beam	2.390 8415	Multi Purpose Bldg - MP Room South	Manual	3/18/2026 9:09:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Valve Tamper Switch	2.397 8420	Multi Purpose Bldg - MP Room West Exterior	Manual	3/18/2026 9:07:04 PM
		Manufacturer	System Sensor	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Valve Tamper Switch	2.397 8421	Multi Purpose Bldg - MP Room West Exterior	Manual	3/18/2026 9:07:05 PM
		Manufacturer	System Sensor	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2.383 8418	Multi Purpose Bldg - MP Stage	Manual	3/18/2026 9:09:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Manual Pull Station	2.149 8388	Multi Purpose Bldg - Northeast Exit	Manual	3/18/2026 9:10:11 PM
		Manufacturer	Fire-Lite	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2.148 8390	Multi Purpose Bldg - Northwest Exit	Manual	3/18/2026 9:09:58 PM
		Manufacturer	Fire-Lite	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.295 8394	Multi Purpose Bldg - Restroom Hallway	Manual	3/18/2026 9:09:53 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2.150 8389	Multi Purpose Bldg - Southeast Exit	Manual	3/18/2026 9:10:10 PM
		Manufacturer	Fire-Lite	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.334 8400	Multi Purpose Bldg - Stage	Manual	3/18/2026 9:10:05 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.335 8401	Multi Purpose Bldg - Stage	Manual	3/18/2026 9:10:06 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.333 8402	Multi Purpose Bldg - Stage Corridor East	Manual	3/18/2026 9:10:08 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.331 8398	Multi Purpose Bldg - Stage Corridor West	Manual	3/18/2026 9:10:03 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.382 8406	Multi Purpose Bldg - Under Stage	Manual	3/18/2026 9:09:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.382 8407	Multi Purpose Bldg - Under Stage	Manual	3/18/2026 9:09:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.382 8405	Multi Purpose Bldg - Under Stage	Manual	3/18/2026 9:09:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.382 8404	Multi Purpose Bldg - Under Stage	Manual	3/18/2026 9:09:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.382 8408	Multi Purpose Bldg - Under Stage	Manual	3/18/2026 9:11:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.382 8409	Multi Purpose Bldg - Under Stage	Manual	3/18/2026 9:11:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Manual Pull Station	2.152 8391	Multi Purpose Bldg - West Hall Exit by RR	Manual	3/18/2026 9:09:50 PM
		Manufacturer	Fire-Lite	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.293 8395	Multi Purpose Bldg - Womens Restroom	Manual	3/18/2026 9:09:46 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.153 8378	Portables - Attic Room 18	Manual	3/18/2026 9:07:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.153 8379	Portables - Attic Room 18	Manual	3/18/2026 9:07:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.138 8380	Portables - Attic Room 19	Manual	3/18/2026 9:07:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.138 8381	Portables - Attic Room 19	Manual	3/18/2026 9:07:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.041 8374	Portables - Room 18	Manual	3/18/2026 9:07:12 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.042 8375	Portables - Room 18	Manual	3/18/2026 9:07:14 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.040 8377	Portables - Room 19	Manual	3/18/2026 9:07:22 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.039 8376	Portables - Room 19	Manual	3/18/2026 9:07:25 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.142 8360	Rooms 13 & 14 Bldg - Attic Classroom 13	Manual	3/18/2026 4:45:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.139 8361	Rooms 13 & 14 Bldg - Attic Classroom 14	Manual	3/18/2026 4:45:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.140 8362	Rooms 13 & 14 Bldg - Attic Library Media Center	Manual	3/18/2026 4:45:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.064 8353	Rooms 13 & 14 Bldg - Classroom 13	Manual	3/18/2026 4:45:30 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.048 8352	Rooms 13 & 14 Bldg - Classroom 13	Manual	3/18/2026 4:45:55 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.062 8355	Rooms 13 & 14 Bldg - Classroom 14	Manual	3/18/2026 4:45:52 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.045 8354	Rooms 13 & 14 Bldg - Classroom 14	Manual	3/18/2026 4:45:54 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.046 8357	Rooms 13 & 14 Bldg - Library Media Center	Manual	3/18/2026 4:45:41 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.047 8359	Rooms 13 & 14 Bldg - Library Media Center	Manual	3/18/2026 4:45:43 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.063 8358	Rooms 13 & 14 Bldg - Library Media Center	Manual	3/18/2026 4:45:44 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.044 8356	Rooms 13 & 14 Bldg - Room 14 Data Closet	Manual	3/18/2026 4:45:50 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.144 8363	Rooms 13 & 14 Bldg - Tuff Shed Outside Library	Manual	3/18/2026 4:45:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.137 8372	Rooms 15 & 16 Bldg - Attic Classroom 15	Manual	3/18/2026 4:42:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.136 8373	Rooms 15 & 16 Bldg - Attic Classroom 16	Manual	3/18/2026 4:42:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.037 8368	Rooms 15 & 16 Bldg - Classroom 15	Manual	3/18/2026 4:42:35 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.036 8367	Rooms 15 & 16 Bldg - Classroom 15	Manual	3/18/2026 4:42:37 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.035 8370	Rooms 15 & 16 Bldg - Classroom 16	Manual	3/18/2026 4:42:05 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.034 8369	Rooms 15 & 16 Bldg - Classroom 16	Manual	3/18/2026 4:42:08 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2.033 83%1	Rooms 15 & 16 Bldg - Room 16 Data Closet	Manual	3/18/2026 4:42:34 PM
		Manufacturer	EST	
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2.377 8291	Rooms 1-6 Bldg - Attic Classroom 1	Manual	3/18/2026 9:08:32 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2.379 8292	Rooms 1-6 Bldg - Attic Classroom 2	Manual	3/18/2026 9:08:39 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2.381 8293	Rooms 1-6 Bldg - Attic Classroom 3	Manual	3/18/2026 9:08:47 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2.376 8294	Rooms 1-6 Bldg - Attic Classroom 4	Manual	3/18/2026 9:08:15 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2.378 8295	Rooms 1-6 Bldg - Attic Classroom 5	Manual	3/18/2026 9:08:07 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2.380 8296	Rooms 1-6 Bldg - Attic Classroom 6	Manual	3/18/2026 9:07:59 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.280 8290	Rooms 1-6 Bldg - Boys Restroom	Manual	3/18/2026 9:07:55 PM
		Manufacturer	EST	
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.257 8262	Rooms 1-6 Bldg - Classroom 1	Manual	3/18/2026 9:08:33 PM
		Manufacturer	EST	
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.259 8264	Rooms 1-6 Bldg - Classroom 1	Manual	3/18/2026 9:08:35 PM
		Manufacturer	EST	
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.260 8265	Rooms 1-6 Bldg - Classroom 1	Manual	3/18/2026 9:08:36 PM
		Manufacturer	EST	
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.258 8263	Rooms 1-6 Bldg - Classroom 1	Manual	3/18/2026 9:08:38 PM
		Manufacturer	EST	
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.265 8266	Rooms 1-6 Bldg - Classroom 2	Manual	3/18/2026 9:08:41 PM
		Manufacturer	EST	
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.267 8268	Rooms 1-6 Bldg - Classroom 2	Manual	3/18/2026 9:08:42 PM
		Manufacturer	EST	
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2.268 8269	Rooms 1-6 Bldg - Classroom 2	Manual	3/18/2026 9:08:44 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.266 8267	Rooms 1-6 Bldg - Classroom 2	Manual	3/18/2026 9:08:45 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.273 8270	Rooms 1-6 Bldg - Classroom 3	Manual	3/18/2026 9:08:48 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.275 8272	Rooms 1-6 Bldg - Classroom 3	Manual	3/18/2026 9:08:50 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.276 8273	Rooms 1-6 Bldg - Classroom 3	Manual	3/18/2026 9:08:51 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.274 8271	Rooms 1-6 Bldg - Classroom 3	Manual	3/18/2026 9:08:52 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.254 8275	Rooms 1-6 Bldg - Classroom 4	Manual	3/18/2026 9:08:17 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.255 8276	Rooms 1-6 Bldg - Classroom 4	Manual	3/18/2026 9:08:18 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.256 8277	Rooms 1-6 Bldg - Classroom 4	Manual	3/18/2026 9:08:20 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.253 8274	Rooms 1-6 Bldg - Classroom 4	Manual	3/18/2026 9:08:21 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.261 8279	Rooms 1-6 Bldg - Classroom 5	Manual	3/18/2026 9:08:08 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.263 8280	Rooms 1-6 Bldg - Classroom 5	Manual	3/18/2026 9:08:10 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.264 8281	Rooms 1-6 Bldg - Classroom 5	Manual	3/18/2026 9:08:11 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2.262 8278	Rooms 1-6 Bldg - Classroom 5	Manual	3/18/2026 9:08:13 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.269 8282	Rooms 1-6 Bldg - Classroom 6	Manual	3/18/2026 9:08:00 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.271 8284	Rooms 1-6 Bldg - Classroom 6	Manual	3/18/2026 9:08:02 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.272 8285	Rooms 1-6 Bldg - Classroom 6	Manual	3/18/2026 9:08:03 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.270 8283	Rooms 1-6 Bldg - Classroom 6	Manual	3/18/2026 9:08:05 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.278 8288	Rooms 1-6 Bldg - Custodial Storage	Manual	3/18/2026 9:07:53 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.277 8289	Rooms 1-6 Bldg - Girls Restroom	Manual	3/18/2026 9:07:54 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.279 8286	Rooms 1-6 Bldg - Room A	Manual	3/18/2026 9:08:54 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.281 8287	Rooms 1-6 Bldg - Room B	Manual	3/18/2026 9:07:57 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.134 8332	Rooms 7-12 Bldg - Attic Classroom 10	Manual	3/18/2026 4:44:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.132 8333	Rooms 7-12 Bldg - Attic Classroom 11	Manual	3/18/2026 4:44:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.130 8334	Rooms 7-12 Bldg - Attic Classroom 12	Manual	3/18/2026 4:44:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.135 8329	Rooms 7-12 Bldg - Attic Classroom 7	Manual	3/18/2026 4:43:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.133 8330	Rooms 7-12 Bldg - Attic Classroom 8	Manual	3/18/2026 4:43:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2.131 8331	Rooms 7-12 Bldg - Attic Classroom 9	Manual	3/18/2026 4:43:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.004 8326	Rooms 7-12 Bldg - Boys Restroom	Manual	3/18/2026 4:43:51 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.026 8315	Rooms 7-12 Bldg - Classroom 10	Manual	3/18/2026 4:44:18 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.023 8312	Rooms 7-12 Bldg - Classroom 10	Manual	3/18/2026 4:44:19 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.024 8313	Rooms 7-12 Bldg - Classroom 10	Manual	3/18/2026 4:44:22 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.025 8314	Rooms 7-12 Bldg - Classroom 10	Manual	3/18/2026 4:44:25 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.018 8319	Rooms 7-12 Bldg - Classroom 11	Manual	3/18/2026 4:44:06 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.016 8317	Rooms 7-12 Bldg - Classroom 11	Manual	3/18/2026 4:44:08 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.015 8316	Rooms 7-12 Bldg - Classroom 11	Manual	3/18/2026 4:44:11 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.017 8318	Rooms 7-12 Bldg - Classroom 11	Manual	3/18/2026 4:44:12 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.010 8323	Rooms 7-12 Bldg - Classroom 12	Manual	3/18/2026 4:43:55 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.009 8322	Rooms 7-12 Bldg - Classroom 12	Manual	3/18/2026 4:43:59 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.007 8320	Rooms 7-12 Bldg - Classroom 12	Manual	3/18/2026 4:44:00 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2.008 8321	Rooms 7-12 Bldg - Classroom 12	Manual	3/18/2026 4:44:02 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.030 8301	Rooms 7-12 Bldg - Classroom 7	Manual	3/18/2026 4:43:16 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.028 8302	Rooms 7-12 Bldg - Classroom 7	Manual	3/18/2026 4:43:17 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.027 8303	Rooms 7-12 Bldg - Classroom 7	Manual	3/18/2026 4:43:19 PM
		Manufacturer	Gentex	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.029 8300	Rooms 7-12 Bldg - Classroom 7	Manual	3/18/2026 4:43:22 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.022 8307	Rooms 7-12 Bldg - Classroom 8	Manual	3/18/2026 4:43:26 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.020 8305	Rooms 7-12 Bldg - Classroom 8	Manual	3/18/2026 4:43:29 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.019 8304	Rooms 7-12 Bldg - Classroom 8	Manual	3/18/2026 4:43:31 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.021 8306	Rooms 7-12 Bldg - Classroom 8	Manual	3/18/2026 4:43:33 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.014 8311	Rooms 7-12 Bldg - Classroom 9	Manual	3/18/2026 4:43:37 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.012 8309	Rooms 7-12 Bldg - Classroom 9	Manual	3/18/2026 4:43:40 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.011 8308	Rooms 7-12 Bldg - Classroom 9	Manual	3/18/2026 4:43:41 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.013 8310	Rooms 7-12 Bldg - Classroom 9	Manual	3/18/2026 4:43:43 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2.005 8327	Rooms 7-12 Bldg - Girls Restroom	Manual	3/18/2026 4:43:46 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.003 8328	Rooms 7-12 Bldg - Sci/Art Room D - FACP Room	Manual	3/18/2026 4:43:54 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.002 8325	Rooms 7-12 Bldg - Sci/Art Room D - FACP Room	Manual	3/18/2026 4:43:52 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.006 8324	Rooms 7-12 Bldg - Supply Room C	Manual	3/18/2026 4:43:48 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Failed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2.054 8254	Admin Building - Nurse Office RR	Manual	3/18/2026 9:07:35 PM
		Manufacturer	EST	

Power Supplies

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Battery - Sealed Lead-acid		Admin Building - Electrical Room - P.E. "C" Battery Left	Manual	3/18/2026 9:07:47 PM
		Manufacturer	Duracell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	8	
		Nominal Voltage	12	
Battery - Sealed Lead-acid		Admin Building - Electrical Room - P.E. "C" Battery Right	Manual	3/18/2026 9:07:45 PM
		Manufacturer	Duracell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	8	
		Nominal Voltage	12	
Battery - Sealed Lead-acid		Multi Purpose Bldg - Electrical Closet - P.E. "E" Battery Left	Manual	3/18/2026 9:09:21 PM
		Manufacturer	Duracell	
		Model	Dura 12-8F	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	8	
		Nominal Voltage	12	
Battery - Sealed Lead-acid		Multi Purpose Bldg - Electrical Closet - P.E. "E" Battery Right	Manual	3/18/2026 9:09:22 PM
		Manufacturer	Duracell	
		Model	Dura 12-8F	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	8	
		Nominal Voltage	12	
Battery - Sealed Lead-acid		Rooms 13 & 14 Bldg - Room 14 Data Closet - P.E. "B" Battery Left	Manual	3/18/2026 4:45:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Amp Hours	8	
		Nominal Voltage	12	
Battery - Sealed Lead-acid		Rooms 13 & 14 Bldg - Room 14 Data Closet - P.E. "B" Battery Right	Manual	3/18/2026 4:45:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	8	
		Nominal Voltage	12	
Battery - Sealed Lead-acid		Rooms 1-6 Bldg - Custodial Storage - P.E. "D" Battery Left	Manual	3/18/2026 9:07:44 PM
		Manufacturer	Universal Battery	
		Model	UB1280	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	8	
		Nominal Voltage	12	
Battery - Sealed Lead-acid		Rooms 1-6 Bldg - Custodial Storage - P.E. "D" Battery Right	Manual	3/18/2026 9:07:40 PM
		Manufacturer	Duracell	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	8	
		Nominal Voltage	12	
Battery - Sealed Lead-acid		Rooms 7-12 Bldg - Sci/Art Room D - FACP Battery Left	Manual	3/18/2026 4:44:42 PM
		Manufacturer	Werker	
		Model	WKDC12-55PUS	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	18	
		Nominal Voltage	12	
Battery - Sealed Lead-acid		Rooms 7-12 Bldg - Sci/Art Room D - FACP Battery Right	Manual	3/18/2026 4:44:33 PM
		Manufacturer	Werker	
		Model	WKDC12-55PUS	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	55	
		Nominal Voltage	12	
Battery - Sealed Lead-acid		Rooms 7-12 Bldg - Sci/Art Room D - P.E. "A" Battery Left	Manual	3/18/2026 4:44:48 PM
		Manufacturer	Duracell	
		Model	Dura 12-8F	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	8	
		Nominal Voltage	12	
Battery - Sealed Lead-acid		Rooms 7-12 Bldg - Sci/Art Room D - P.E. "A" Battery Right	Manual	3/18/2026 4:44:51 PM
		Manufacturer	Duracell	
		Model	Dura 12-8F	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	8	
		Nominal Voltage	12	
Battery - Sealed Lead-acid		Rooms 7-12 Bldg - Sci/Art Room D - P.E. "Master" Battery Left	Manual	3/18/2026 4:44:45 PM
		Manufacturer	Duracell	
		Model	Dura 12-8F	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	8	
		Nominal Voltage	12	
Battery - Sealed Lead-acid		Rooms 7-12 Bldg - Sci/Art Room D - P.E. "Master" Battery Right	Manual	3/18/2026 4:44:43 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Manufacturer	Duracell	
		Model	Dura 12-8F	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	8	
		Nominal Voltage	12	
Battery - Sealed Lead-acid		Rooms 7-12 Bldg - Sci/Art Room D - Voice EVAC Battery Left	Manual	3/18/2026 4:44:50 PM
		Manufacturer	Interstate	
		Model	DCM0018	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	18	
		Nominal Voltage	12	
Battery - Sealed Lead-acid		Rooms 7-12 Bldg - Sci/Art Room D - Voice EVAC Battery Right	Manual	3/18/2026 4:44:47 PM
		Manufacturer	Interstate	
		Model	DCM0018	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	18	
		Nominal Voltage	12	

Device/Equipment details

Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Audible					
012	Admin Building - West Exterior	Gentex			
057	Rooms 1-6 Bldg - North Exterior	Gentex			
058	Rooms 1-6 Bldg - South Exterior	Gentex			
059	Rooms 1-6 Bldg - West Exterior	Gentex			
107	Rooms 7-12 Bldg - North Exterior	Gentex			
108	Rooms 7-12 Bldg - South Exterior	Gentex			
109	Rooms 7-12 Bldg - West Exterior	Gentex			
133	Rooms 13 & 14 Bldg - South Exterior	Gentex			
147	Rooms 15 & 16 Bldg - South Exterior	Gentex			
157	Kindergarten Bldg - East Exterior	Gentex			
169	Portables - South Exterior	EST			
211	Multi Purpose Bldg - North Exterior	Gentex			
212	Multi Purpose Bldg - East Exterior	Gentex			
213	Multi Purpose Bldg - West Exterior	Gentex			
224	Multi Purpose Bldg - South Exterior (Local Electric Bell)				
Audible And Visible					
013	Admin Building - Admin Reception	Gentex			
060	Rooms 1-6 Bldg - Classroom 1	Gentex			
061	Rooms 1-6 Bldg - Classroom 2	Gentex			
062	Rooms 1-6 Bldg - Classroom 3	Gentex			
063	Rooms 1-6 Bldg - Classroom 4	Gentex			
064	Rooms 1-6 Bldg - Classroom 5	Gentex			
065	Rooms 1-6 Bldg - Classroom 6	Gentex			
066	Rooms 1-6 Bldg - Room A	Gentex			
067	Rooms 1-6 Bldg - Room B	Gentex			
110	Rooms 7-12 Bldg - Classroom 7	Gentex			
111	Rooms 7-12 Bldg - Classroom 8	Gentex			
112	Rooms 7-12 Bldg - Classroom 9	Gentex			
113	Rooms 7-12 Bldg - Classroom 10	Gentex			
114	Rooms 7-12 Bldg - Classroom 11	Gentex			
115	Rooms 7-12 Bldg - Classroom 12	Gentex			
134	Rooms 13 & 14 Bldg - Classroom 13	Gentex			
135	Rooms 13 & 14 Bldg - Classroom 14	Gentex			
136	Rooms 13 & 14 Bldg - Library Media Center	Gentex			
137	Rooms 13 & 14 Bldg - Library Media Center	Gentex			
148	Rooms 15 & 16 Bldg - Classroom 15	Gentex			
149	Rooms 15 & 16 Bldg - Classroom 16	Gentex			
158	Kindergarten Bldg - Kindergarten Classroom	Gentex			
170	Portables - Room 18	EST			
171	Portables - Room 19	EST			
214	Multi Purpose Bldg - MP Room	Gentex			
215	Multi Purpose Bldg - MP Room	Gentex			

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
216	Multi Purpose Bldg - MP Room	Gentex			
217	Multi Purpose Bldg - Stage Corridor East	Gentex			
218	Multi Purpose Bldg - Stage	Gentex			
219	Multi Purpose Bldg - Stage Corridor West	Gentex			
220	Multi Purpose Bldg - Kitchen	Gentex			
221	Multi Purpose Bldg - Restroom Hallway	Gentex			

Visible

014	Admin Building - Principals Office	Gentex			
015	Admin Building - Nurse Office	Gentex			
016	Admin Building - Nurse Office RR	Gentex			
017	Admin Building - Staff Work Room	Gentex			
018	Admin Building - Staff Mens RR	Gentex			
019	Admin Building - Staff Womens RR	Gentex			
068	Rooms 1-6 Bldg - Boys Restroom	Gentex			
069	Rooms 1-6 Bldg - Girls Restroom	Gentex			
116	Rooms 7-12 Bldg - Boys Restroom	Gentex			
117	Rooms 7-12 Bldg - Girls Restroom	Gentex			
159	Kindergarten Bldg - Kindergarten RR	Gentex			
222	Multi Purpose Bldg - Mens Restroom	Gentex			
223	Multi Purpose Bldg - Womens Restroom	Gentex			

Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
---------	-------------	--------------	-------	--------	--------------

Remote Annunciator

8249	Admin Building - Admin Reception	EST			
------	----------------------------------	-----	--	--	--

NAC Power Extender Panel

8259	Admin Building - Electrical Room - P.E. "C"	Fire-Lite			
8297	Rooms 1-6 Bldg - Custodial Storage - P.E. "D"	Fire-Lite			
8341	Rooms 7-12 Bldg - Sci/Art Room D - P.E. "Master"	Fire-Lite			
8348	Rooms 7-12 Bldg - Sci/Art Room D - P.E. "A"	Fire-Lite			
8366	Rooms 13 & 14 Bldg - Room 14 Data Closet - P.E. "B"	Fire-Lite			
8422	Multi Purpose Bldg - Electrical Closet - P.E. "E"	Fire-Lite			

Fire Alarm Panel

8335	Rooms 7-12 Bldg - Sci/Art Room D - FACP	EST	3		
8338	Rooms 7-12 Bldg - Sci/Art Room D - Voice EVAC Panel	EST	3		
	FACP Room	EST-3			06/19/2020

Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
---------	-------------	--------------	-------	--------	--------------

Manual Pull Station

2.143 8250	Admin Building - Admin Reception	EST			
2.149 8388	Multi Purpose Bldg - Northeast Exit	Fire-Lite			
2.150 8389	Multi Purpose Bldg - Southeast Exit	Fire-Lite			
2.148 8390	Multi Purpose Bldg - Northwest Exit	Fire-Lite			

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2.152 8391	Multi Purpose Bldg - West Hall Exit by RR	Fire-Lite			
2.151 8392	Multi Purpose Bldg - Kitchen Exit	Fire-Lite			
Smoke Detector - General					
2.059 8251	Admin Building - Office	EST			
2.060 8256	Admin Building - Closet	EST			
2.061 8252	Admin Building - Principals Office	EST			
2.057 8253	Admin Building - Nurse Office	EST			
2.054 8254	Admin Building - Nurse Office RR	EST			
2.065 8255	Admin Building - Electrical Room	EST			
2.052 8248	Admin Building - Staff Work Room	EST			
2.053 8257	Admin Building - Staff Mens RR	EST			
2.055 8258	Admin Building - Staff Womens RR	EST			
2.257 8262	Rooms 1-6 Bldg - Classroom 1	EST			
2.258 8263	Rooms 1-6 Bldg - Classroom 1	EST			
2.259 8264	Rooms 1-6 Bldg - Classroom 1	EST			
2.260 8265	Rooms 1-6 Bldg - Classroom 1	EST			
2.265 8266	Rooms 1-6 Bldg - Classroom 2	EST			
2.266 8267	Rooms 1-6 Bldg - Classroom 2	EST			
2.267 8268	Rooms 1-6 Bldg - Classroom 2	EST			
2.268 8269	Rooms 1-6 Bldg - Classroom 2	EST			
2.273 8270	Rooms 1-6 Bldg - Classroom 3	EST			
2.274 8271	Rooms 1-6 Bldg - Classroom 3	EST			
2.275 8272	Rooms 1-6 Bldg - Classroom 3	EST			
2.276 8273	Rooms 1-6 Bldg - Classroom 3	EST			
2.253 8274	Rooms 1-6 Bldg - Classroom 4	EST			
2.254 8275	Rooms 1-6 Bldg - Classroom 4	EST			
2.255 8276	Rooms 1-6 Bldg - Classroom 4	EST			
2.256 8277	Rooms 1-6 Bldg - Classroom 4	EST			
2.262 8278	Rooms 1-6 Bldg - Classroom 5	EST			
2.261 8279	Rooms 1-6 Bldg - Classroom 5	EST			
2.263 8280	Rooms 1-6 Bldg - Classroom 5	EST			
2.264 8281	Rooms 1-6 Bldg - Classroom 5	EST			
2.269 8282	Rooms 1-6 Bldg - Classroom 6	EST			
2.270 8283	Rooms 1-6 Bldg - Classroom 6	EST			
2.271 8284	Rooms 1-6 Bldg - Classroom 6	EST			
2.272 8285	Rooms 1-6 Bldg - Classroom 6	EST			
2.279 8286	Rooms 1-6 Bldg - Room A	EST			
2.281 8287	Rooms 1-6 Bldg - Room B	EST			

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2.278 8288	Rooms 1-6 Bldg - Custodial Storage	EST			
2.277 8289	Rooms 1-6 Bldg - Girls Restroom	EST			
2.280 8290	Rooms 1-6 Bldg - Boys Restroom	EST			
2.029 8300	Rooms 7-12 Bldg - Classroom 7	EST			
2.030 8301	Rooms 7-12 Bldg - Classroom 7	EST			
2.028 8302	Rooms 7-12 Bldg - Classroom 7	EST			
2.027 8303	Rooms 7-12 Bldg - Classroom 7	Gentex			
2.019 8304	Rooms 7-12 Bldg - Classroom 8	EST			
2.020 8305	Rooms 7-12 Bldg - Classroom 8	EST			
2.021 8306	Rooms 7-12 Bldg - Classroom 8	EST			
2.022 8307	Rooms 7-12 Bldg - Classroom 8	EST			
2.011 8308	Rooms 7-12 Bldg - Classroom 9	EST			
2.012 8309	Rooms 7-12 Bldg - Classroom 9	EST			
2.013 8310	Rooms 7-12 Bldg - Classroom 9	EST			
2.014 8311	Rooms 7-12 Bldg - Classroom 9	EST			
2.023 8312	Rooms 7-12 Bldg - Classroom 10	EST			
2.024 8313	Rooms 7-12 Bldg - Classroom 10	EST			
2.025 8314	Rooms 7-12 Bldg - Classroom 10	EST			
2.026 8315	Rooms 7-12 Bldg - Classroom 10	EST			
2.015 8316	Rooms 7-12 Bldg - Classroom 11	EST			
2.016 8317	Rooms 7-12 Bldg - Classroom 11	EST			
2.017 8318	Rooms 7-12 Bldg - Classroom 11	EST			
2.018 8319	Rooms 7-12 Bldg - Classroom 11	EST			
2.007 8320	Rooms 7-12 Bldg - Classroom 12	EST			
2.008 8321	Rooms 7-12 Bldg - Classroom 12	EST			
2.009 8322	Rooms 7-12 Bldg - Classroom 12	EST			
2.010 8323	Rooms 7-12 Bldg - Classroom 12	EST			
2.006 8324	Rooms 7-12 Bldg - Supply Room C	EST			
2.004 8326	Rooms 7-12 Bldg - Boys Restroom	EST			
2.005 8327	Rooms 7-12 Bldg - Girls Restroom	EST			
2.002 8325	Rooms 7-12 Bldg - Sci/Art Room D - FACP Room	EST			
2.048 8352	Rooms 13 & 14 Bldg - Classroom 13	EST			
2.064 8353	Rooms 13 & 14 Bldg - Classroom 13	EST			
2.045 8354	Rooms 13 & 14 Bldg - Classroom 14	EST			
2.062 8355	Rooms 13 & 14 Bldg - Classroom 14	EST			
2.044 8356	Rooms 13 & 14 Bldg - Room 14 Data Closet	EST			
2.046 8357	Rooms 13 & 14 Bldg - Library Media Center	EST			

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2.063 8358	Rooms 13 & 14 Bldg - Library Media Center	EST			
2.047 8359	Rooms 13 & 14 Bldg - Library Media Center	EST			
2.036 8367	Rooms 15 & 16 Bldg - Classroom 15	EST			
2.037 8368	Rooms 15 & 16 Bldg - Classroom 15	EST			
2.034 8369	Rooms 15 & 16 Bldg - Classroom 16	EST			
2.035 8370	Rooms 15 & 16 Bldg - Classroom 16	EST			
2.033 83%1	Rooms 15 & 16 Bldg - Room 16 Data Closet	EST			
2.284 8382	Kindergarten Bldg - Kindergarten Classroom	EST			
2.285 8383	Kindergarten Bldg - Kindergarten Classroom	EST			
2.286 8384	Kindergarten Bldg - Kindergarten Classroom	EST			
2.287 8385	Kindergarten Bldg - Kindergarten Classroom	EST			
2.289 8386	Kindergarten Bldg - Kindergarten RR	EST			
2.288 8387	Kindergarten Bldg - Kindergarten Storage	EST			
2.041 8374	Portables - Room 18	EST			
2.042 8375	Portables - Room 18	EST			
2.039 8376	Portables - Room 19	EST			
2.040 8377	Portables - Room 19	EST			
2.292 8393	Multi Purpose Bldg - Electrical Closet	EST			
2.295 8394	Multi Purpose Bldg - Restroom Hallway	EST			
2.293 8395	Multi Purpose Bldg - Womens Restroom	EST			
2.294 8396	Multi Purpose Bldg - Mens Restroom	EST			
2.298 8397	Multi Purpose Bldg - MP Room Storage	EST			
2.331 8398	Multi Purpose Bldg - Stage Corridor West	EST			
2.332 8399	Multi Purpose Bldg - Custodial Office	EST			
2.334 8400	Multi Purpose Bldg - Stage	EST			
2.335 8401	Multi Purpose Bldg - Stage	EST			
2.333 8402	Multi Purpose Bldg - Stage Corridor East	EST			
2.297 188	Multi Purpose Bldg - Kitchen Office	EST			
Heat Detector - Restorable Spot					
2.377 8291	Rooms 1-6 Bldg - Attic Classroom 1				
2.379 8292	Rooms 1-6 Bldg - Attic Classroom 2				
2.381 8293	Rooms 1-6 Bldg - Attic Classroom 3				
2.376 8294	Rooms 1-6 Bldg - Attic Classroom 4				
2.378 8295	Rooms 1-6 Bldg - Attic Classroom 5				
2.380 8296	Rooms 1-6 Bldg - Attic Classroom 6				
2.003 8328	Rooms 7-12 Bldg - Sci/Art Room D - FACP Room	EST			
2.135 8329	Rooms 7-12 Bldg - Attic Classroom 7				
2.133 8330	Rooms 7-12 Bldg - Attic Classroom 8				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2.131 8331	Rooms 7-12 Bldg - Attic Classroom 9				
2.134 8332	Rooms 7-12 Bldg - Attic Classroom 10				
2.132 8333	Rooms 7-12 Bldg - Attic Classroom 11				
2.130 8334	Rooms 7-12 Bldg - Attic Classroom 12				
2.142 8360	Rooms 13 & 14 Bldg - Attic Classroom 13				
2.139 8361	Rooms 13 & 14 Bldg - Attic Classroom 14				
2.140 8362	Rooms 13 & 14 Bldg - Attic Library Media Center				
2.144 8363	Rooms 13 & 14 Bldg - Tuff Shed Outside Library				
2.137 8372	Rooms 15 & 16 Bldg - Attic Classroom 15				
2.136 8373	Rooms 15 & 16 Bldg - Attic Classroom 16				
2.153 8378	Portables - Attic Room 18				
2.153 8379	Portables - Attic Room 18				
2.138 8380	Portables - Attic Room 19				
2.138 8381	Portables - Attic Room 19				
2.296 8403	Multi Purpose Bldg - Kitchen	EST			
2.382 8404	Multi Purpose Bldg - Under Stage				
2.382 8405	Multi Purpose Bldg - Under Stage				
2.382 8406	Multi Purpose Bldg - Under Stage				
2.382 8407	Multi Purpose Bldg - Under Stage				
2.382 8408	Multi Purpose Bldg - Under Stage				
2.382 8409	Multi Purpose Bldg - Under Stage				
2.391 196	Multi Purpose Bldg - Attic MP Room East				
2.394 197	Multi Purpose Bldg - Attic MP Room West				
2.393 8410	Multi Purpose Bldg - Attic Kitchen				
2.393 8411	Multi Purpose Bldg - Attic RR Hallway				
2.393 8412	Multi Purpose Bldg - Attic Mens Restroom				
2.393 8413	Multi Purpose Bldg - Attic Womens RR				
2.392 8414	Multi Purpose Bldg - Attic Custodial Office				
Smoke Detector - Projected Beam					
2.390 8415	Multi Purpose Bldg - MP Room South				
2.388 8416	Multi Purpose Bldg - MP Room Middle				
2.386 8417	Multi Purpose Bldg - MP Room North				
Smoke Detector - Duct					
2.395 206	Multi Purpose Bldg - Attic MP Room				
2.383 8418	Multi Purpose Bldg - MP Stage				
2.384 208	Multi Purpose Bldg - Kitchen Roof				
Mechanical, Electrosonic, or Pressure Waterflow Device					
2.396 8419	Multi Purpose Bldg - MP Room	System Sensor			

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Valve Tamper Switch					
2.397 8420	Multi Purpose Bldg - MP Room West Exterior	System Sensor			
2.397 8421	Multi Purpose Bldg - MP Room West Exterior	System Sensor			

Power Supplies

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Battery - Sealed Lead-acid					
8260	Admin Building - Electrical Room - P.E. "C" Battery Left	Duracell			08/06/2015
8261	Admin Building - Electrical Room - P.E. "C" Battery Right	Duracell			08/06/2015
8298	Rooms 1-6 Bldg - Custodial Storage - P.E. "D" Battery Left	Universal Battery	UB1280		04/01/2014
8299	Rooms 1-6 Bldg - Custodial Storage - P.E. "D" Battery Right	Duracell			05/08/2019
8342	Rooms 7-12 Bldg - Sci/Art Room D - P.E. "Master" Battery Left	Duracell	Dura 12-8F		03/01/2018
8343	Rooms 7-12 Bldg - Sci/Art Room D - P.E. "Master" Battery Right	Duracell	Dura 12-8F		03/01/2018
8349	Rooms 7-12 Bldg - Sci/Art Room D - P.E. "A" Battery Left	Duracell	Dura 12-8F		03/01/2018
8350	Rooms 7-12 Bldg - Sci/Art Room D - P.E. "A" Battery Right	Duracell	Dura 12-8F		03/01/2018
8336	Rooms 7-12 Bldg - Sci/Art Room D - FACP Battery Left	Werker	WKDC12-55PUS		10/25/2012
8337	Rooms 7-12 Bldg - Sci/Art Room D - FACP Battery Right	Werker	WKDC12-55PUS		10/25/2012
8339	Rooms 7-12 Bldg - Sci/Art Room D - Voice EVAC Battery Left	Interstate	DCM0018		08/01/2015
8340	Rooms 7-12 Bldg - Sci/Art Room D - Voice EVAC Battery Right	Interstate	DCM0018		08/01/2015
8364	Rooms 13 & 14 Bldg - Room 14 Data Closet - P.E. "B" Battery Left				10/01/2012
8365	Rooms 13 & 14 Bldg - Room 14 Data Closet - P.E. "B" Battery Right				10/01/2012
8423	Multi Purpose Bldg - Electrical Closet - P.E. "E" Battery Left	Duracell	Dura 12-8F		01/13/2016
8424	Multi Purpose Bldg - Electrical Closet - P.E. "E" Battery Right	Duracell	Dura 12-8F		01/01/2016