

Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

GOLDEN VALLEY CHARTER

9601 LAKE NATOMAS DR
ORANGEVALE, California
United States

This site has been inspected and tested in compliance with applicable standards.

Completed

Thursday, September 11, 2025

Test Session:07 Aug 2025 09:21 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD
5320 HEMLOCK ST
SACRAMENTO, California
United States

TESTED BY

Riley Goyet
Western States Fire Protection-
Sacramento
188 Cirby Way
Roseville, CA 95678
United States



Inspection Summary

Building Information

PROPERTY	GOLDEN VALLEY CHARTER	CONTACT
ADDRESS	9601 LAKE NATOMAS DR	PHONE
CITY/STATE	ORANGEVALE, California	MOBILE
COUNTRY	United States	EMAIL

Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us

Testing Summary


EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
[Other]	1	0(0%)	0(0%)	0(0%)
Alarm Notification Appliance	62	62(100%)	62(100%)	0(0%)
Initiating Device	224	119(53%)	118(53%)	1(0%)
Power Supplies	2	0(0%)	0(0%)	0(0%)
Fire Control Panel	1	1(100%)	1(100%)	0(0%)

Certification

The equipment specified here in was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Thursday, September 11, 2025

ACCEPTED BY 09/11/2025

Building Representative


TESTED BY 09/11/2025
Riley Goyet
Technician

System Details

Primary Power

ADDRESS/ SCAN ADDRESS	/ 082	DESCRIPTION	Rooms 5-9 Bldg Cust Strge by Rm C
TYPE	Primary Power	PROTECTION	
NOMINAL VOLTAGE		AMPS	
NOMINAL AMPS		DISCONNECT	
LOCATION			

ADDRESS/ SCAN ADDRESS	/ 083	DESCRIPTION	Rooms 5-9 Bldg Cust Strge by Rm C
TYPE	Primary Power	PROTECTION	
NOMINAL VOLTAGE		AMPS	
NOMINAL AMPS		DISCONNECT	
LOCATION			

Open Corrective Action & Solution Summary

The following 1 corrective action(s) remain open following the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
Smoke Detector - General	2-056	MP Rm
	Created By:	Riley Goyet
	Creation Date:	08/07/2025
	Corrective Action:	Disabled on panel
	Proposed Solution:	
	Manufacturer:	
	Model:	

Testing Details

[Other]

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
[Other]	053	Admin Building	Manual	8/7/2025 10:26:43 AM

Alarm Notification Appliance

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible	154	Admin Building Kitchen	Manual	8/7/2025 10:33:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	024	Admin Building Library	Manual	8/7/2025 10:31:54 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	019	Admin Building North Exterior	Manual	8/7/2025 10:31:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	026	Admin Building Nurse Restroom	Manual	8/7/2025 10:31:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	022	Admin Building Nurse Room	Manual	8/7/2025 10:31:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	025	Admin Building Principals Office	Manual	8/7/2025 10:31:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	021	Admin Building Reception	Manual	8/7/2025 10:31:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	104	Admin Building Room 10	Manual	8/7/2025 10:32:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	027	Admin Building Room A	Manual	8/7/2025 10:32:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	028	Admin Building Room B	Manual	8/7/2025 10:32:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	079	Admin Building Room C	Manual	8/7/2025 10:32:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	023	Admin Building Staff Room	Manual	8/7/2025 10:31:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	029	Admin Building Staff RR by Library	Manual	8/7/2025 10:32:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	030	Admin Building Staff RR by Room B	Manual	8/7/2025 10:32:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	020	Admin Building West Exterior	Manual	8/7/2025 10:31:48 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	151	Multi-Purpose Bldg Kitchen	Manual	8/7/2025 10:33:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	155	Multi-Purpose Bldg Kitchen	Manual	8/7/2025 10:33:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	153	Multi-Purpose Bldg Kitchen	Manual	8/7/2025 10:33:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	148	Multi-Purpose Bldg MP Room	Manual	8/7/2025 10:33:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	147	Multi-Purpose Bldg MP Room	Manual	8/7/2025 10:33:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	149	Multi-Purpose Bldg Staff Break Room	Manual	8/7/2025 10:33:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	150	Multi-Purpose Bldg Stage	Manual	8/7/2025 10:33:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	152	Multi-Purpose Bldg Stage HC Lift Right	Manual	8/7/2025 10:33:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	146	Multi-Purpose Bldg West Exterior	Manual	8/7/2025 10:33:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	120	Room 15 Building East Exterior	Manual	8/7/2025 10:33:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	122	Room 15 Building Room 15	Manual	8/7/2025 10:33:16 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	123	Room 15 Building Room 15 Restroom	Manual	8/7/2025 10:33:19 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	121	Room 15 Building West Exterior	Manual	8/7/2025 10:33:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	111	Rooms 10-14 Bldg Boys RR by Rm 14	Manual	8/7/2025 10:32:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	112	Rooms 10-14 Bldg Girls RR by Rm 14	Manual	8/7/2025 10:32:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	105	Rooms 10-14 Bldg Room 11	Manual	8/7/2025 10:32:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	106	Rooms 10-14 Bldg Room 12	Manual	8/7/2025 10:32:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	107	Rooms 10-14 Bldg Room 13	Manual	8/7/2025 10:32:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	108	Rooms 10-14 Bldg Room 13A	Manual	8/7/2025 10:32:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	109	Rooms 10-14 Bldg Room 13B	Manual	8/7/2025 10:32:54 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	110	Rooms 10-14 Bldg Room 14	Manual	8/7/2025 10:32:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	113	Rooms 10-14 Bldg Room D by Room 10	Manual	8/7/2025 10:32:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	101	Rooms 10-14 Bldg South Exterior	Manual	8/7/2025 10:32:39 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	100	Rooms 10-14 Bldg South Exterior	Manual	8/7/2025 10:32:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	102	Rooms 10-14 Bldg South Exterior	Manual	8/7/2025 10:32:42 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	103	Rooms 10-14 Bldg West Exterior	Manual	8/7/2025 10:32:44 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	051	Rooms 1-4 Bldg Boys RR by Rm 4	Manual	8/7/2025 10:32:19 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	052	Rooms 1-4 Bldg Girls RR by Rm 4	Manual	8/7/2025 10:32:20 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	046	Rooms 1-4 Bldg Room 1	Manual	8/7/2025 10:32:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	047	Rooms 1-4 Bldg Room 2	Manual	8/7/2025 10:32:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	048	Rooms 1-4 Bldg Room 3	Manual	8/7/2025 10:32:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	049	Rooms 1-4 Bldg Room 4	Manual	8/7/2025 10:32:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	050	Rooms 1-4 Bldg Room E by Room 4	Manual	8/7/2025 10:32:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	043	Rooms 1-4 Bldg South Exterior	Manual	8/7/2025 10:32:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	044	Rooms 1-4 Bldg South Exterior	Manual	8/7/2025 10:32:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	045	Rooms 1-4 Bldg West Exterior	Manual	8/7/2025 10:32:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	080	Rooms 5-9 Bldg Boys RR by Rm 5	Manual	8/7/2025 10:32:36 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	081	Rooms 5-9 Bldg Girls RR by Rm 5	Manual	8/7/2025 10:32:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	074	Rooms 5-9 Bldg Room 5	Manual	8/7/2025 10:32:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	075	Rooms 5-9 Bldg Room 6	Manual	8/7/2025 10:32:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	076	Rooms 5-9 Bldg Room 7	Manual	8/7/2025 10:32:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	077	Rooms 5-9 Bldg Room 8	Manual	8/7/2025 10:32:32 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	078	Rooms 5-9 Bldg Room 9	Manual	8/7/2025 10:32:33 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	070	Rooms 5-9 Bldg South Exterior	Manual	8/7/2025 10:32:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	071	Rooms 5-9 Bldg South Exterior	Manual	8/7/2025 10:32:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	072	Rooms 5-9 Bldg South Exterior	Manual	8/7/2025 10:32:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	073	Rooms 5-9 Bldg West Exterior	Manual	8/7/2025 10:32:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Remote Annunciator	001	Admin Building Reception	Manual	8/7/2025 10:33:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-024 011	Admin Building Staff Office Closet	Manual	8/7/2025 10:18:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-026	Admin Office	Manual	8/7/2025 10:15:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-157	Admin Office	Manual	8/7/2025 10:35:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-028	Admin RR	Manual	8/7/2025 10:15:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-027	Admin Strg	Manual	8/7/2025 10:14:54 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-158	Attic Admin Office	Manual	8/7/2025 12:34:41 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-156	Attic Headend	Manual	8/7/2025 11:04:48 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-159	Attic HVAC Rm 5	Manual	8/7/2025 12:34:47 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2.143	Attic Rm 4	Manual	8/7/2025 12:34:42 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-148	Attic Rm 5	Manual	8/7/2025 12:34:44 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-021	Boys RR By rm 3B	Manual	8/7/2025 10:53:46 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-012	Cistodian Strg By Rm 1	Manual	8/7/2025 10:34:13 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-262	Cust Clst By Rm 12	Manual	8/7/2025 9:49:57 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-039	Cust Clst By Rm 8	Manual	8/7/2025 9:45:12 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-020	East Vestibule	Manual	8/7/2025 10:25:15 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-252	Elect Rm By Rm 9	Manual	8/7/2025 10:52:14 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-084	Emtry Office By Rm 6	Manual	8/7/2025 10:55:54 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-007	Entry By Rm 1	Manual	8/7/2025 10:17:08 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-008	Entry By Rm 2	Manual	8/7/2025 10:19:13 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-022	Girls RR By Rm 3B	Manual	8/7/2025 10:25:20 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-038	Girls RR by Rm 8	Manual	8/7/2025 9:45:10 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-009	Hallway By Rm 2-3B	Manual	8/7/2025 10:22:01 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-011	Hallway By Rm 2-3B	Manual	8/7/2025 10:23:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-023	Hallway By RR by Rm 3B	Manual	8/7/2025 10:25:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-006	headend	Manual	8/7/2025 10:40:20 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-377	HVAC Clst Rm 10	Manual	8/7/2025 12:34:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-376	HVAC Clst Rm 9	Manual	8/7/2025 12:34:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-058	Kitchen	Manual	8/7/2025 10:44:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-076	Kitchen Clst	Manual	8/7/2025 10:02:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-271	Kitchen Rm 13	Manual	8/7/2025 9:41:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-077	Kitchen RR Clst	Manual	8/7/2025 10:03:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-053	MP Rm	Manual	8/7/2025 9:52:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-055	MP Rm	Manual	8/7/2025 9:52:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-047	MP Rm	Manual	8/7/2025 9:53:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-046	MP Rm	Manual	8/7/2025 9:53:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-048	MP Rm	Manual	8/7/2025 9:53:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-049	MP Rm	Manual	8/7/2025 9:54:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-042	MP Rm	Manual	8/7/2025 9:51:42 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-043	MP Rm	Manual	8/7/2025 9:52:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-062	MP Rm Kitch RR	Manual	8/7/2025 9:58:02 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-061	MP Rm Kitch RR	Manual	8/7/2025 10:52:42 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-145	MP Rm NW	Manual	8/7/2025 10:33:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-147	MP Rm SE	Manual	8/7/2025 10:33:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-050	MP Rm Stage	Manual	8/7/2025 9:50:32 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-052	MP Rm Stage	Manual	8/7/2025 9:50:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-051	MP Rm Stage	Manual	8/7/2025 9:51:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-057	MP Rm Strg	Manual	8/7/2025 9:57:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-144	MP Rm SW	Manual	8/7/2025 10:39:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-146	MP Rm Under Flr Stage	Manual	8/7/2025 12:34:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-060	MP. rm Washdown	Manual	8/7/2025 9:57:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-042 137	Multi-Purpose Bldg Kitchen	Manual	8/7/2025 10:33:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-037 129	Multi-Purpose Bldg MP Room	Manual	8/7/2025 11:00:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-031	Office By Rm 6	Manual	8/7/2025 10:10:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-030	Office By RR By Rm 6	Manual	8/7/2025 10:10:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-005	Office Rm 1	Manual	8/7/2025 10:19:42 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-272	Office Rm 14	Manual	8/7/2025 9:38:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-073	OS MP Rm RR	Manual	8/7/2025 10:40:16 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-074	OS MP Rm RR	Manual	8/7/2025 10:44:19 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-154	Portable Rm 17-19	Manual	8/7/2025 10:06:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-029	Principals Office	Manual	8/7/2025 10:15:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-024	Rm 1	Manual	8/7/2025 10:18:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-025	Rm 1	Manual	8/7/2025 10:19:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-083	Rm 1 Office Clst	Manual	8/7/2025 10:59:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-256	Rm 10	Manual	8/7/2025 9:29:20 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-255	Rm 10	Manual	8/7/2025 9:29:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-258	Rm 11	Manual	8/7/2025 9:29:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-257	Rm 11	Manual	8/7/2025 9:29:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-259	Rm 12	Manual	8/7/2025 9:28:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-260	Rm 12	Manual	8/7/2025 9:30:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-266	Rm 13	Manual	8/7/2025 9:39:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-267	Rm 13	Manual	8/7/2025 9:39:32 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-264	Rm 13	Manual	8/7/2025 9:39:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-265	Rm 13	Manual	8/7/2025 9:40:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-269	Rm 13	Manual	8/7/2025 9:40:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-268	Rm 13	Manual	8/7/2025 10:53:35 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-274	Rm 14	Manual	8/7/2025 9:37:18 AM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	2-273	Rm 14	Manual	8/7/2025 9:37:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-276	Rm 14	Manual	8/7/2025 9:37:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-275	Rm 14	Manual	8/7/2025 9:38:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-278	Rm 15	Manual	8/7/2025 9:35:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-277	Rm 15	Manual	8/7/2025 9:35:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-279	Rm 15	Manual	8/7/2025 9:35:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-280	Rm 15	Manual	8/7/2025 9:36:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-281	Rm 16	Manual	8/7/2025 9:32:39 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-282	Rm 16	Manual	8/7/2025 9:32:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-284	Rm 16	Manual	8/7/2025 9:33:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-283	Rm 16	Manual	8/7/2025 9:33:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-014	Rm 2	Manual	8/7/2025 10:39:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-015	Rm 2	Manual	8/7/2025 10:39:19 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-018	Rm 3 B	Manual	8/7/2025 10:23:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-016	Rm 3A	Manual	8/7/2025 10:23:16 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-017	Rm 3A	Manual	8/7/2025 10:23:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-019	Rm 3B	Manual	8/7/2025 10:23:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-040	Rm 4	Manual	8/7/2025 10:26:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-041	Rm 4	Manual	8/7/2025 10:26:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-065	Rm 5	Manual	8/7/2025 9:46:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-063	Rm 5	Manual	8/7/2025 9:46:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-064	Rm 5	Manual	8/7/2025 9:46:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-068	Rm 5	Manual	8/7/2025 9:47:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-069	Rm 5	Manual	8/7/2025 9:47:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-067	Rm 5	Manual	8/7/2025 9:47:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-066	Rm 5	Manual	8/7/2025 11:02:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-070	Rm 5 Strg	Manual	8/7/2025 9:48:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-072	Rm 5 Strg	Manual	8/7/2025 9:48:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-071	Rm 5 Strg	Manual	8/7/2025 9:47:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-033	Rm 6	Manual	8/7/2025 10:11:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-032	Rm 6	Manual	8/7/2025 10:11:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-035	rm 7	Manual	8/7/2025 10:12:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-034	Rm 7	Manual	8/7/2025 10:12:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-036	Rm 8	Manual	8/7/2025 9:44:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-037	Rm 8	Manual	8/7/2025 9:44:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-253	Rm 9	Manual	8/7/2025 10:51:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-254	Rm 9	Manual	8/7/2025 10:51:44 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-263	RR by Rm 12	Manual	8/7/2025 9:31:36 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-261	RR By Rm 12	Manual	8/7/2025 9:30:04 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.013	Storage Rm	Manual	8/7/2025 11:00:25 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-013	Strg By Rm 2	Manual	8/7/2025 10:20:42 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-270	SW Entry Rm 13	Manual	8/7/2025 9:40:38 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-127 018	Admin Building Attic Staff Office	Manual	8/7/2025 10:26:04 AM
Smoke Detector - General	2-030 014	Admin Building Library	Manual	8/7/2025 10:25:53 AM
Smoke Detector - General	2-029 015	Admin Building Library	Manual	8/7/2025 10:25:56 AM
Smoke Detector - General	2-036 128	Admin Building MP Room	Manual	8/7/2025 10:30:35 AM
Smoke Detector - General	2-022 008	Admin Building Nurse Closet	Manual	8/7/2025 10:25:39 AM
Smoke Detector - General	2-023 007	Admin Building Nurse Restroom	Manual	8/7/2025 10:31:24 AM
Smoke Detector - General	2-020 006	Admin Building Nurse Room	Manual	8/7/2025 10:31:27 AM
Smoke Detector - General	2-027 004	Admin Building Principals Office	Manual	8/7/2025 10:31:32 AM
Smoke Detector - General	2-026 005	Admin Building Principals Office Clst	Manual	8/7/2025 10:31:29 AM
Manual Pull Station	2-126 002	Admin Building Reception	Manual	8/7/2025 10:31:37 AM
Smoke Detector - General	2-021 003	Admin Building Reception	Manual	8/7/2025 10:31:34 AM
Smoke Detector - General	2-031 012	Admin Building Room A	Manual	8/7/2025 10:25:47 AM
Smoke Detector - General	2-032 013	Admin Building Room B	Manual	8/7/2025 10:25:50 AM
Smoke Detector - General	2-028 009	Admin Building Staff Office	Manual	8/7/2025 10:25:42 AM
Smoke Detector - General	2-025 010	Admin Building Staff Office	Manual	8/7/2025 10:25:45 AM
Smoke Detector - General	2-033 016	Admin Building Staff RR by Library	Manual	8/7/2025 10:25:59 AM
Smoke Detector - General	2-034 017	Admin Building Staff RR by Room B	Manual	8/7/2025 10:26:02 AM
Smoke Detector - General	2-010	Hallway By Rm 2-3B	Manual	8/7/2025 10:37:37 AM
Heat Detector - Restorable Spot	2-139	HAVAC Clst Rm 1	Manual	8/7/2025 10:37:25 AM
Heat Detector - Restorable Spot	2-135	HAVAC Clst Rm 2	Manual	8/7/2025 10:37:35 AM
Heat Detector - Restorable Spot	2-136	HAVAC Clst Rm 2-3B	Manual	8/7/2025 10:37:32 AM
Heat Detector - Restorable Spot	2-137	HAVAC Clst Rm 3B	Manual	8/7/2025 10:37:29 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-143	HAVAC Clst Rm 4	Manual	8/7/2025 10:37:14 AM
Heat Detector - Restorable Spot	2-140	HAVAC Clst Rm 6	Manual	8/7/2025 10:37:19 AM
Heat Detector - Restorable Spot	2-141	HAVAC Clst Rm 7	Manual	8/7/2025 10:37:17 AM
Heat Detector - Restorable Spot	2-142	HAVAC Clst Rm 8	Manual	8/7/2025 10:37:40 AM
Heat Detector - Restorable Spot	2-138	HAVAC Clst Rm Rm 1	Manual	8/7/2025 10:37:27 AM
Heat Detector - Restorable Spot	2-378	HVAC Clst Rm 11	Manual	8/7/2025 10:38:04 AM
Heat Detector - Restorable Spot	2-379	HVAC Clst Rm 12	Manual	8/7/2025 10:38:02 AM
Heat Detector - Restorable Spot	2-381	HVAC Clst Rm 13	Manual	8/7/2025 10:37:56 AM
Heat Detector - Restorable Spot	2-380	HVAC Clst Rm 13	Manual	8/7/2025 10:37:59 AM
Heat Detector - Restorable Spot	2-384	HVAC Clst Rm 14	Manual	8/7/2025 10:37:51 AM
Heat Detector - Restorable Spot	2-382	HVAC Clst Rm 14	Manual	8/7/2025 10:37:54 AM
Heat Detector - Restorable Spot	2-385	HVAC Clst Rm 15	Manual	8/7/2025 10:37:49 AM
Heat Detector - Restorable Spot	2-388	HVAC Clst Rm 16	Manual	8/7/2025 10:37:46 AM
Smoke Detector - General	2-059	MP Rm Kitchen Strg	Manual	8/7/2025 10:36:04 AM
Heat Detector - Restorable Spot	2-040 139	Multi-Purpose Bldg Kitchen	Manual	8/7/2025 10:30:31 AM
Smoke Detector - General	2-041 136	Multi-Purpose Bldg Kitchen	Manual	8/7/2025 10:30:13 AM
Smoke Detector - General	2-043 138	Multi-Purpose Bldg Kitchen	Manual	8/7/2025 10:30:28 AM
Heat Detector - Restorable Spot	2-130 145	Multi-Purpose Bldg Kitchen W/H Closet	Manual	8/7/2025 10:28:47 AM
Smoke Detector - General	2-038 126	Multi-Purpose Bldg MP Room	Manual	8/7/2025 10:29:21 AM
Smoke Detector - General	2-035 127	Multi-Purpose Bldg MP Room	Manual	8/7/2025 10:29:49 AM
Manual Pull Station	2-129 124	Multi-Purpose Bldg SE Entry	Manual	8/7/2025 10:29:18 AM
Smoke Detector - General	2-039 130	Multi-Purpose Bldg Staff Break Room	Manual	8/7/2025 10:30:06 AM
Smoke Detector - General	2-047 133	Multi-Purpose Bldg Stage	Manual	8/7/2025 10:30:03 AM
Smoke Detector - General	2-045 132	Multi-Purpose Bldg Stage HC Lift Right	Manual	8/7/2025 10:30:00 AM
Heat Detector - Restorable Spot	2-048 141	Multi-Purpose Bldg Stage HVAC Loft Left	Manual	8/7/2025 10:30:20 AM
Heat Detector - Restorable Spot	2-046 140	Multi-Purpose Bldg Stage HVAC Loft Rt	Manual	8/7/2025 10:30:17 AM
Smoke Detector - General	2-050 135	Multi-Purpose Bldg Stage Stair Left	Manual	8/7/2025 10:30:11 AM
Smoke Detector - General	2-044 131	Multi-Purpose Bldg Stage Stair Right	Manual	8/7/2025 10:29:57 AM
Smoke Detector - General	2-049 134	Multi-Purpose Bldg Stage Storage Left	Manual	8/7/2025 10:30:08 AM
Manual Pull Station	2-128 125	Multi-Purpose Bldg SW Entry	Manual	8/7/2025 10:29:44 AM
Heat Detector - Restorable Spot	2-131 144	Multi-Purpose Bldg Under Stage	Manual	8/7/2025 10:28:50 AM
Heat Detector - Restorable Spot	2-131 142	Multi-Purpose Bldg Under Stage	Manual	8/7/2025 10:30:23 AM
Heat Detector - Restorable Spot	2-131 143	Multi-Purpose Bldg Under Stage	Manual	8/7/2025 10:30:25 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-266 116	Room 15 Building Room 15	Manual	8/7/2025 10:29:09 AM
Smoke Detector - General	2-265 114	Room 15 Building Room 15	Manual	8/7/2025 10:29:12 AM
Smoke Detector - General	2-267 115	Room 15 Building Room 15	Manual	8/7/2025 10:29:29 AM
Smoke Detector - General	2-270 117	Room 15 Building Room 15	Manual	8/7/2025 10:29:31 AM
Smoke Detector - General	2-269 118	Room 15 Building Room 15 Restroom	Manual	8/7/2025 10:29:39 AM
Smoke Detector - General	2-268 119	Room 15 Building Room 15 Storage	Manual	8/7/2025 10:29:42 AM
Smoke Detector - General	2-065 096	Rooms 10-14 Bldg Boys RR by Rm 14	Manual	8/7/2025 10:28:45 AM
Heat Detector - Restorable Spot	2-064 098	Rooms 10-14 Bldg Cust Clst by Rm 14	Manual	8/7/2025 10:29:01 AM
Smoke Detector - General	2-066 097	Rooms 10-14 Bldg Girls RR by Rm 14	Manual	8/7/2025 10:28:56 AM
Smoke Detector - General	2-054 084	Rooms 10-14 Bldg Room 10	Manual	8/7/2025 10:28:24 AM
Smoke Detector - General	2-053 085	Rooms 10-14 Bldg Room 10	Manual	8/7/2025 10:28:26 AM
Smoke Detector - General	2-056 086	Rooms 10-14 Bldg Room 11	Manual	8/7/2025 10:28:29 AM
Smoke Detector - General	2-055 087	Rooms 10-14 Bldg Room 11	Manual	8/7/2025 10:28:32 AM
Smoke Detector - General	2-057 088	Rooms 10-14 Bldg Room 12	Manual	8/7/2025 10:28:36 AM
Smoke Detector - General	2-058 089	Rooms 10-14 Bldg Room 12	Manual	8/7/2025 10:29:26 AM
Smoke Detector - General	2-060 090	Rooms 10-14 Bldg Room 13	Manual	8/7/2025 10:29:04 AM
Smoke Detector - General	2-061 091	Rooms 10-14 Bldg Room 13A	Manual	8/7/2025 10:28:59 AM
Smoke Detector - General	2-059 092	Rooms 10-14 Bldg Room 13B	Manual	8/7/2025 10:29:54 AM
Smoke Detector - General	2-062 093	Rooms 10-14 Bldg Room 14	Manual	8/7/2025 10:28:52 AM
Smoke Detector - General	2-063 094	Rooms 10-14 Bldg Room 14	Manual	8/7/2025 10:29:52 AM
Smoke Detector - General	2-051 095	Rooms 10-14 Bldg Room D by Room 10	Manual	8/7/2025 10:29:14 AM
Heat Detector - Restorable Spot	2-052 099	Rooms 10-14 Bldg Storage behind Rm 10	Manual	8/7/2025 10:29:34 AM
Smoke Detector - General	2-263 040	Rooms 1-4 Bldg Boys RR by Rm 4	Manual	8/7/2025 10:26:41 AM
Heat Detector - Restorable Spot	2-262 042	Rooms 1-4 Bldg Cust Closet by Rm 4	Manual	8/7/2025 10:27:18 AM
Smoke Detector - General	2-264 041	Rooms 1-4 Bldg Girls RR by Rm 4	Manual	8/7/2025 10:27:21 AM
Smoke Detector - General	2-253 031	Rooms 1-4 Bldg Room 1	Manual	8/7/2025 10:26:06 AM
Smoke Detector - General	2-254 032	Rooms 1-4 Bldg Room 1	Manual	8/7/2025 10:26:09 AM
Smoke Detector - General	2-256 033	Rooms 1-4 Bldg Room 2	Manual	8/7/2025 10:26:12 AM
Smoke Detector - General	2-255 034	Rooms 1-4 Bldg Room 2	Manual	8/7/2025 10:26:14 AM
Smoke Detector - General	2-257 035	Rooms 1-4 Bldg Room 3	Manual	8/7/2025 10:26:38 AM
Smoke Detector - General	2-258 036	Rooms 1-4 Bldg Room 3	Manual	8/7/2025 10:27:06 AM
Smoke Detector - General	2-259 037	Rooms 1-4 Bldg Room 4	Manual	8/7/2025 10:27:09 AM
Smoke Detector - General	2-260 038	Rooms 1-4 Bldg Room 4	Manual	8/7/2025 10:27:12 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-261 039	Rooms 1-4 Bldg Room E by Room 4	Manual	8/7/2025 10:27:15 AM
Smoke Detector - General	2-006 064	Rooms 5-9 Bldg Boys RR by Rm 5	Manual	8/7/2025 10:29:06 AM
Heat Detector - Restorable Spot	2-007 068	Rooms 5-9 Bldg Cust Closet by Rm 5	Manual	8/7/2025 10:27:47 AM
Smoke Detector - General	2-005 067	Rooms 5-9 Bldg Cust Strge by Rm C	Manual	8/7/2025 10:27:45 AM
Smoke Detector - General	2-008 065	Rooms 5-9 Bldg Girls RR by Rm 5	Manual	8/7/2025 10:28:42 AM
Heat Detector - Restorable Spot	2-132 069	Rooms 5-9 Bldg Plumb Chse by Rm 5	Manual	8/7/2025 10:27:51 AM
Smoke Detector - General	2-010 054	Rooms 5-9 Bldg Room 5	Manual	8/7/2025 10:26:46 AM
Smoke Detector - General	2-011 055	Rooms 5-9 Bldg Room 5	Manual	8/7/2025 10:27:03 AM
Smoke Detector - General	2-013 056	Rooms 5-9 Bldg Room 6	Manual	8/7/2025 10:27:24 AM
Smoke Detector - General	2-012 057	Rooms 5-9 Bldg Room 6	Manual	8/7/2025 10:27:27 AM
Smoke Detector - General	2-014 058	Rooms 5-9 Bldg Room 7	Manual	8/7/2025 10:27:33 AM
Smoke Detector - General	2-015 059	Rooms 5-9 Bldg Room 7	Manual	8/7/2025 10:28:39 AM
Smoke Detector - General	2-016 061	Rooms 5-9 Bldg Room 8	Manual	8/7/2025 10:27:30 AM
Smoke Detector - General	2-017 060	Rooms 5-9 Bldg Room 8	Manual	8/7/2025 10:27:35 AM
Smoke Detector - General	2-018 062	Rooms 5-9 Bldg Room 9	Manual	8/7/2025 10:27:38 AM
Smoke Detector - General	2-019 063	Rooms 5-9 Bldg Room 9	Manual	8/7/2025 10:27:41 AM
Smoke Detector - General	2-009 066	Rooms 5-9 Bldg Room C	Manual	8/7/2025 10:27:54 AM

Failed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-056	MP Rm	Manual	8/7/2025 10:36:18 AM
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	

Power Supplies

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Primary Power	082	Rooms 5-9 Bldg Cust Strge by Rm C	Manual	8/7/2025 10:27:56 AM
Primary Power	083	Rooms 5-9 Bldg Cust Strge by Rm C	Manual	8/7/2025 10:28:21 AM

Device/Equipment details

[Other]

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
[Other]					
053	Admin Building				

Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Audible					
019	Admin Building North Exterior				
020	Admin Building West Exterior				
043	Rooms 1-4 Bldg South Exterior				
044	Rooms 1-4 Bldg South Exterior				
045	Rooms 1-4 Bldg West Exterior				
070	Rooms 5-9 Bldg South Exterior				
071	Rooms 5-9 Bldg South Exterior				
072	Rooms 5-9 Bldg South Exterior				
073	Rooms 5-9 Bldg West Exterior				
100	Rooms 10-14 Bldg South Exterior				
101	Rooms 10-14 Bldg South Exterior				
102	Rooms 10-14 Bldg South Exterior				
103	Rooms 10-14 Bldg West Exterior				
120	Room 15 Building East Exterior				
121	Room 15 Building West Exterior				
146	Multi-Purpose Bldg West Exterior				

Audible And Visible

021	Admin Building Reception				
022	Admin Building Nurse Room				
023	Admin Building Staff Room				
024	Admin Building Library				
046	Rooms 1-4 Bldg Room 1				
047	Rooms 1-4 Bldg Room 2				
048	Rooms 1-4 Bldg Room 3				
049	Rooms 1-4 Bldg Room 4				
050	Rooms 1-4 Bldg Room E by Room 4				
051	Rooms 1-4 Bldg Boys RR by Rm 4				
052	Rooms 1-4 Bldg Girls RR by Rm 4				
074	Rooms 5-9 Bldg Room 5				
075	Rooms 5-9 Bldg Room 6				
076	Rooms 5-9 Bldg Room 7				
077	Rooms 5-9 Bldg Room 8				
078	Rooms 5-9 Bldg Room 9				
079	Admin Building Room C				
104	Admin Building Room 10				
105	Rooms 10-14 Bldg Room 11				
106	Rooms 10-14 Bldg Room 12				
107	Rooms 10-14 Bldg Room 13				
108	Rooms 10-14 Bldg Room 13A				
109	Rooms 10-14 Bldg Room 13B				
110	Rooms 10-14 Bldg Room 14				
111	Rooms 10-14 Bldg Boys RR by Rm 14				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
112	Rooms 10-14 Bldg Girls RR by Rm 14				
113	Rooms 10-14 Bldg Room D by Room 10				
122	Room 15 Building Room 15				
147	Multi-Purpose Bldg MP Room				
148	Multi-Purpose Bldg MP Room				
149	Multi-Purpose Bldg Staff Break Room				
150	Multi-Purpose Bldg Stage				
151	Multi-Purpose Bldg Kitchen				

Visible

025	Admin Building Principals Office				
026	Admin Building Nurse Restroom				
027	Admin Building Room A				
028	Admin Building Room B				
029	Admin Building Staff RR by Library				
030	Admin Building Staff RR by Room B				
080	Rooms 5-9 Bldg Boys RR by Rm 5				
081	Rooms 5-9 Bldg Girls RR by Rm 5				
123	Room 15 Building Room 15 Restroom				
152	Multi-Purpose Bldg Stage HC Lift Right				
153	Multi-Purpose Bldg Kitchen				
154	Admin Building Kitchen				
155	Multi-Purpose Bldg Kitchen				

Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Remote Annunciator					
001	Admin Building Reception				

Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Manual Pull Station					
2-126 002	Admin Building Reception				
2-129 124	Multi-Purpose Bldg SE Entry				
2-128 125	Multi-Purpose Bldg SW Entry				
2-144	MP Rm SW				
2-145	MP Rm NW				
2-147	MP Rm SE				
2-157	Admin Office				

Smoke Detector - General

2-021 003	Admin Building Reception				
2-027 004	Admin Building Principals Office				
2-026 005	Admin Building Principals Office Clst				
2-020 006	Admin Building Nurse Room				
2-023 007	Admin Building Nurse Restroom				
2-022 008	Admin Building Nurse Closet				
2-028 009	Admin Building Staff Office				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-025 010	Admin Building Staff Office				
2-024 011	Admin Building Staff Office Closet				
2-031 012	Admin Building Room A				
2-032 013	Admin Building Room B				
2-030 014	Admin Building Library				
2-029 015	Admin Building Library				
2-033 016	Admin Building Staff RR by Library				
2-034 017	Admin Building Staff RR by Room B				
2-253 031	Rooms 1-4 Bldg Room 1				
2-254 032	Rooms 1-4 Bldg Room 1				
2-256 033	Rooms 1-4 Bldg Room 2				
2-255 034	Rooms 1-4 Bldg Room 2				
2-257 035	Rooms 1-4 Bldg Room 3				
2-258 036	Rooms 1-4 Bldg Room 3				
2-259 037	Rooms 1-4 Bldg Room 4				
2-260 038	Rooms 1-4 Bldg Room 4				
2-261 039	Rooms 1-4 Bldg Room E by Room 4				
2-263 040	Rooms 1-4 Bldg Boys RR by Rm 4				
2-264 041	Rooms 1-4 Bldg Girls RR by Rm 4				
2-010 054	Rooms 5-9 Bldg Room 5				
2-011 055	Rooms 5-9 Bldg Room 5				
2-013 056	Rooms 5-9 Bldg Room 6				
2-012 057	Rooms 5-9 Bldg Room 6				
2-014 058	Rooms 5-9 Bldg Room 7				
2-015 059	Rooms 5-9 Bldg Room 7				
2-017 060	Rooms 5-9 Bldg Room 8				
2-016 061	Rooms 5-9 Bldg Room 8				
2-018 062	Rooms 5-9 Bldg Room 9				
2-019 063	Rooms 5-9 Bldg Room 9				
2-006 064	Rooms 5-9 Bldg Boys RR by Rm 5				
2-008 065	Rooms 5-9 Bldg Girls RR by Rm 5				
2-009 066	Rooms 5-9 Bldg Room C				
2-005 067	Rooms 5-9 Bldg Cust Strge by Rm C				
2-054 084	Rooms 10-14 Bldg Room 10				
2-053 085	Rooms 10-14 Bldg Room 10				
2-056 086	Rooms 10-14 Bldg Room 11				
2-055 087	Rooms 10-14 Bldg Room 11				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-057 088	Rooms 10-14 Bldg Room 12				
2-058 089	Rooms 10-14 Bldg Room 12				
2-060 090	Rooms 10-14 Bldg Room 13				
2-061 091	Rooms 10-14 Bldg Room 13A				
2-059 092	Rooms 10-14 Bldg Room 13B				
2-062 093	Rooms 10-14 Bldg Room 14				
2-063 094	Rooms 10-14 Bldg Room 14				
2-051 095	Rooms 10-14 Bldg Room D by Room 10				
2-065 096	Rooms 10-14 Bldg Boys RR by Rm 14				
2-066 097	Rooms 10-14 Bldg Girls RR by Rm 14				
2-265 114	Room 15 Building Room 15				
2-267 115	Room 15 Building Room 15				
2-266 116	Room 15 Building Room 15				
2-270 117	Room 15 Building Room 15				
2-269 118	Room 15 Building Room 15 Restroom				
2-268 119	Room 15 Building Room 15 Storage				
2-038 126	Multi-Purpose Bldg MP Room				
2-035 127	Multi-Purpose Bldg MP Room				
2-036 128	Admin Building MP Room				
2-037 129	Multi-Purpose Bldg MP Room				
2-039 130	Multi-Purpose Bldg Staff Break Room				
2-044 131	Multi-Purpose Bldg Stage Stair Right				
2-045 132	Multi-Purpose Bldg Stage HC Lift Right				
2-047 133	Multi-Purpose Bldg Stage				
2-049 134	Multi-Purpose Bldg Stage Storage Left				
2-050 135	Multi-Purpose Bldg Stage Stair Left				
2-041 136	Multi-Purpose Bldg Kitchen				
2-042 137	Multi-Purpose Bldg Kitchen				
2-043 138	Multi-Purpose Bldg Kitchen				
2-005	Office Rm 1				
2-006	headend				
2-007	Entry By Rm 1				
2-008	Entry By Rm 2				
2-009	Hallway By Rm 2-3B				
2-010	Hallway By Rm 2-3B				
2-011	Hallway By Rm 2-3B				
2-013	Strg By Rm 2				
2-016	Rm 3A				
2-017	Rm 3A				
2-018	Rm 3 B				
2-019	Rm 3B				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-020	East Vestibule				
2-021	Boys RR By rm 3B				
2-022	Girls RR By Rm 3B				
2-023	Hallway By RR by Rm 3B				
2-024	Rm 1				
2-025	Rm 1				
2-026	Admin Office				
2-027	Admin Strg				
2-028	Admin RR				
2-029	Principals Office				
2-030	Office By RR By Rm 6				
2-031	Office By Rm 6				
2-032	Rm 6				
2-033	Rm 6				
2-034	Rm 7				
2-035	rm 7				
2-036	Rm 8				
2-037	Rm 8				
2-038	Girls RR by Rm 8				
2-040	Rm 4				
2-041	Rm 4				
2-042	MP Rm				
2-043	MP Rm				
2-046	MP Rm				
2-047	MP Rm				
2-048	MP Rm				
2-049	MP Rm				
2-050	MP Rm Stage				
2-051	MP Rm Stage				
2-052	MP Rm Stage				
2-053	MP Rm				
2-055	MP Rm				
2-056	MP Rm				
2-057	MP Rm Strg				
2-059	MP Rm Kitchen Strg				
2-060	MP. rm Washdown				
2-061	MP Rm Kitch RR				
2-062	MP Rm Kitch RR				
2-063	Rm 5				
2-064	Rm 5				
2-065	Rm 5				
2-066	Rm 5				
2-067	Rm 5				
2-068	Rm 5				
2-069	Rm 5				
2-070	Rm 5 Strg				
2-071	Rm 5 Strg				
2-072	Rm 5 Strg				
2-073	OS MP Rm RR				
2-074	OS MP Rm RR				
2-076	Kitchen Clst				
2-077	Kitchen RR Clst				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-083	Rm 1 Office Clst				
2-084	Emtry Office By Rm 6				
2-252	Elect Rm By Rm 9				
2-253	Rm 9				
2-254	Rm 9				
2-255	Rm 10				
2-256	Rm 10				
2-257	Rm 11				
2-258	Rm 11				
2-259	Rm 12				
2-260	Rm 12				
2-261	RR By Rm 12				
2-263	RR by Rm 12				
2-264	Rm 13				
2-265	Rm 13				
2-266	Rm 13				
2-267	Rm 13				
2-268	Rm 13				
2-269	Rm 13				
2-270	SW Entry Rm 13				
2-271	Kitchen Rm 13				
2-272	Office Rm 14				
2-273	Rm 14				
2-274	Rm 14				
2-275	Rm 14				
2-276	Rm 14				
2-277	Rm 15				
2-278	Rm 15				
2-279	Rm 15				
2-280	Rm 15				
2-281	Rm 16				
2-282	Rm 16				
2-283	Rm 16				
2-284	Rm 16				
2.013	Storage Rm				09/21/2022
Heat Detector - Restorable Spot					
2-127 018	Admin Building Attic Staff Office				
2-262 042	Rooms 1-4 Bldg Cust Closet by Rm 4				
2-007 068	Rooms 5-9 Bldg Cust Closet by Rm 5				
2-132 069	Rooms 5-9 Bldg Plumb Chse by Rm 5				
2-064 098	Rooms 10-14 Bldg Cust Clst by Rm 14				
2-052 099	Rooms 10-14 Bldg Storage behind Rm 10				
2-040 139	Multi-Purpose Bldg Kitchen				
2-046 140	Multi-Purpose Bldg Stage HVAC Loft Rt				
2-048 141	Multi-Purpose Bldg Stage HVAC Loft Left				
2-131 142	Multi-Purpose Bldg Under Stage				
2-131 143	Multi-Purpose Bldg Under Stage				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-131 144	Multi-Purpose Bldg Under Stage				
2-130 145	Multi-Purpose Bldg Kitchen W/H Closet				
2-012	Cistodian Strg By Rm 1				
2-014	Rm 2				
2-015	Rm 2				
2-039	Cust Clst By Rm 8				
2-058	Kitchen				
2-135	HAVAC Clst Rm 2				
2-136	HAVAC Clst Rm 2-3B				
2-137	HAVAC Clst Rm 3B				
2-138	HAVAC Clst Rm Rm 1				
2-139	HAVAC Clst Rm 1				
2-140	HAVAC Clst Rm 6				
2-141	HAVAC Clst Rm 7				
2-142	HAVAC Clst Rm 8				
2-143	HAVAC Clst Rm 4				
2-146	MP Rm Under Flr Stage				
2-148	Attic Rm 5				
2-154	Portable Rm 17-19				
2-156	Attic Headend				
2-158	Attic Admin Office				
2-159	Attic HVAC Rm 5				
2-262	Cust Clst By Rm 12				
2-376	HVAC Clst Rm 9				
2-377	HVAC Clst Rm 10				
2-378	HVAC Clst Rm 11				
2-379	HVAC Clst Rm 12				
2-380	HVAC Clst Rm 13				
2-381	HVAC Clst Rm 13				
2-382	HVAC Clst Rm 14				
2-384	HVAC Clst Rm 14				
2-385	HVAC Clst Rm 15				
2-388	HVAC Clst Rm 16				
2.143	Attic Rm 4				09/21/2022

Power Supplies

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Primary Power					
082	Rooms 5-9 Bldg Cust Strge by Rm C				
083	Rooms 5-9 Bldg Cust Strge by Rm C				