

Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

ENCINA HIGH

1400 BELL ST
SACRAMENTO, California
United States

This site has been inspected and tested in compliance with applicable standards.

Completed
Friday, March 28, 2025

Test Session :11 Feb 2025 15:57 RJ5311 AFA

ACCEPTED BY

SAN JUAN USD
5320 HEMLOCK ST
SACRAMENTO, California
United States

TESTED BY

Riley Goyet
Western States Fire Protection-
Sacramento
188 Cirby Way
Roseville, CA 95678
United States



Inspection Summary

Building Information

PROPERTY	ENCINA HIGH	CONTACT
ADDRESS	1400 BELL ST	PHONE
CITY/STATE/ZIP	SACRAMENTO, California	MOBILE
COUNTRY	United States	EMAIL

Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us

Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Fire Control Panel	15	2(13%)	2(13%)	0(0%)
Initiating Device	662	651(98%)	651(98%)	0(0%)
Alarm Notification Appliance	264	264(100%)	264(100%)	0(0%)
[Other]	1	0(0%)	0(0%)	0(0%)

Certification

The equipment specified herein was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Friday, March 28, 2025

ACCEPTED BY 03/28/2025

Building Representative

TESTED BY 03/28/2025
Riley Goyet
Technician



System Details

Control Units

ADDRESS / SCAN ADDRESS		DESCRIPTION	Build A Room A12 Headend
MANUFACTURER	Notifier	S/W VERSION	
MODEL	NFS-3030	LAST UPDATE	
SERIAL NUMBER		S/W LOCATION	
INSTALL DATE	04/01/2020		

Testing Details

[Other]

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
[Other]	3-381 789	Building T Ansil Sys Kitchen S7	Manual	2/12/2025 8:07:24 PM

Alarm Notification Appliance

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	062	Building A Front Office A3	Manual	2/12/2025 6:33:44 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	067	Building A Main Hallway	Manual	2/12/2025 6:33:38 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	066	Building A Main Hallway	Manual	2/12/2025 6:33:39 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	088	Building A Main Hallway	Manual	2/12/2025 6:33:03 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	087	Building A Main Hallway	Manual	2/12/2025 6:33:04 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	059	Building A Office A1	Manual	2/12/2025 6:33:51 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	068	Building A Office A1A	Manual	2/12/2025 6:33:36 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	069	Building A Office A1B	Manual	2/12/2025 6:33:35 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	070	Building A Office A1C	Manual	2/12/2025 6:33:33 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	071	Building A Office A1D	Manual	2/12/2025 6:33:32 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	072	Building A Office A1E	Manual	2/12/2025 6:33:30 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	060	Building A Office A2	Manual	2/12/2025 6:33:49 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	073	Building A Office A2A	Manual	2/12/2025 6:33:28 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	061	Building A Office A2B	Manual	2/12/2025 6:33:45 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	074	Building A Office A2D	Manual	2/12/2025 6:33:27 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	063	Building A Office A2D Hall	Manual	2/12/2025 6:33:42 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	075	Building A Office A2D Hall	Manual	2/12/2025 6:33:25 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	076	Building A Office A2E	Manual	2/12/2025 6:33:24 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	077	Building A Office A3	Manual	2/12/2025 6:33:22 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	080	Building A Office A5	Manual	2/12/2025 6:33:16 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	064	Building A Office A8	Manual	2/12/2025 5:15:46 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	082	Building A Office A8A	Manual	2/12/2025 5:22:46 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	084	Building A Office A9B	Manual	2/12/2025 6:33:09 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	085	Building A Office A9C	Manual	2/12/2025 6:33:08 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	086	Building A Office A9D	Manual	2/12/2025 6:33:06 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	083	Building A Office Restroom A8A	Manual	2/12/2025 6:33:11 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	079	Building A Restroom A4	Manual	2/12/2025 6:33:18 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	078	Building A Restroom A4	Manual	2/12/2025 6:33:20 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	081	Building A Restroom A7	Manual	2/12/2025 6:33:14 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	065	Building A Staff Room A9	Manual	2/12/2025 6:33:41 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	111	Building B Classroom B2	Manual	2/12/2025 6:32:59 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	110	Building B Library B1	Manual	2/12/2025 6:33:02 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	114	Building B Library B1	Manual	2/12/2025 6:32:52 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible	113	Building B Library B1	Manual	2/12/2025 6:32:54 PM
		Visual Inspection	Passed (Manual)	
Visible	112	Building B Library B1	Manual	2/12/2025 6:33:00 PM
		Visual Inspection	Passed (Manual)	
Audible	109	Building B South Exterior	Manual	2/12/2025 5:48:28 PM
		Visual Inspection	Passed (Manual)	
Audible And Visible	130	Building C Classroom C1	Manual	2/12/2025 6:32:36 PM
		Visual Inspection	Passed (Manual)	
Audible And Visible	131	Building C Classroom C2	Manual	2/12/2025 6:32:35 PM
		Visual Inspection	Passed (Manual)	
Audible And Visible	132	Building C Classroom C3	Manual	2/12/2025 6:32:33 PM
		Visual Inspection	Passed (Manual)	
Audible And Visible	133	Building C Classroom C4	Manual	2/12/2025 6:32:30 PM
		Visual Inspection	Passed (Manual)	
Audible And Visible	134	Building C Classroom C5	Manual	2/12/2025 6:32:31 PM
		Visual Inspection	Passed (Manual)	
Audible And Visible	135	Building C Classroom C6	Manual	2/12/2025 6:32:28 PM
		Visual Inspection	Passed (Manual)	
Audible	129	Building C North Exterior	Manual	2/12/2025 6:32:41 PM
		Visual Inspection	Passed (Manual)	
Audible	128	Building C North Exterior	Manual	2/12/2025 6:32:43 PM
		Visual Inspection	Passed (Manual)	
Audible	127	Building C North Exterior	Manual	2/12/2025 6:32:44 PM
		Visual Inspection	Passed (Manual)	
Audible And Visible	149	Building D Classroom D1	Manual	2/12/2025 6:32:22 PM
		Visual Inspection	Passed (Manual)	
Audible And Visible	150	Building D Classroom D2	Manual	2/12/2025 6:32:21 PM
		Visual Inspection	Passed (Manual)	
Audible And Visible	151	Building D Classroom D3	Manual	2/12/2025 6:32:13 PM
		Visual Inspection	Passed (Manual)	
Audible And Visible	152	Building D Classroom D4	Manual	2/12/2025 6:32:11 PM
		Visual Inspection	Passed (Manual)	
Audible And Visible	153	Building D Classroom D5	Manual	2/12/2025 6:32:09 PM
		Visual Inspection	Passed (Manual)	
Audible	148	Building D South Exterior	Manual	2/12/2025 6:32:24 PM
		Visual Inspection	Passed (Manual)	
Audible	147	Building D South Exterior	Manual	2/12/2025 6:32:25 PM
		Visual Inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	146	Building D South Exterior	Manual	2/12/2025 6:32:27 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	190	Building E Classroom E1	Manual	2/12/2025 5:18:09 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	191	Building E Classroom E2	Manual	2/12/2025 6:32:04 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	193	Building E Classroom E3	Manual	2/12/2025 6:32:01 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	194	Building E Classroom E4	Manual	2/12/2025 6:32:00 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	196	Building E Dental Room 1	Manual	2/12/2025 6:31:56 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	197	Building E Dental Room 2	Manual	2/12/2025 6:31:54 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	198	Building E Dental Room 3	Manual	2/12/2025 6:31:53 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	192	Building E Hall by Classrm E2	Manual	2/12/2025 6:32:03 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	195	Building E Hall Next to Rm E2	Manual	2/12/2025 6:31:58 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	189	Building E North Exterior	Manual	2/12/2025 6:32:06 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	188	Building E North Exterior	Manual	2/12/2025 6:32:08 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	235	Building F Classroom F2	Manual	2/12/2025 6:31:44 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	236	Building F Classroom F2C	Manual	2/12/2025 6:31:42 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	237	Building F Classroom F3	Manual	2/12/2025 6:31:41 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	239	Building F Classroom F4	Manual	2/12/2025 6:31:37 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	240	Building F Classroom F5	Manual	2/12/2025 6:31:35 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	238	Building F Classroom F6	Manual	2/12/2025 6:31:39 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	234	Building F Custodial Office F1	Manual	2/12/2025 6:31:45 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	233	Building F Custodial Office F1	Manual	2/12/2025 6:31:48 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	232	Building F South Exterior	Manual	2/12/2025 6:31:50 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	231	Building F South Exterior	Manual	2/12/2025 6:31:51 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	284	Building G Art Room G1	Manual	2/12/2025 6:31:29 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	283	Building G Art Room G1	Manual	2/12/2025 6:31:30 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	288	Building G Art Room G1	Manual	2/12/2025 6:31:23 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	287	Building G Art Room G1	Manual	2/12/2025 6:31:26 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	285	Building G Art Room G2	Manual	2/12/2025 6:31:27 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	289	Building G Art Room G2	Manual	2/12/2025 6:31:21 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	286	Building G Medical Room G3	Manual	2/12/2025 6:31:24 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	290	Building G Medical Room G3	Manual	2/12/2025 6:31:20 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	281	Building G South Exterior	Manual	2/12/2025 6:31:31 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	282	Building G South Exterior	Manual	2/12/2025 6:31:33 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	313	Building H Classroom H1	Manual	2/12/2025 6:31:12 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	314	Building H Classroom H2	Manual	2/12/2025 6:31:11 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	316	Building H Classroom H2	Manual	2/12/2025 6:31:09 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	315	Building H Classroom H3	Manual	2/12/2025 5:28:50 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	317	Building H Classroom H3	Manual	2/12/2025 6:31:08 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	318	Building H Restroom H4	Manual	2/12/2025 6:31:05 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	319	Building H Restroom H6	Manual	2/12/2025 6:31:04 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	311	Building H South Exterior	Manual	2/12/2025 5:23:23 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	312	Building H South Exterior	Manual	2/12/2025 6:31:16 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	339	Building I Classroom i1	Manual	2/12/2025 6:31:01 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	340	Building I Classroom i2	Manual	2/12/2025 6:30:56 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	338	Building I South Exterior	Manual	2/12/2025 6:31:02 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	357	Building J Classroom J1	Manual	2/12/2025 6:30:51 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	358	Building J Classroom J2	Manual	2/12/2025 6:30:50 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	359	Building J Classroom J3	Manual	2/12/2025 6:30:48 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	360	Building J Classroom J4	Manual	2/12/2025 6:30:46 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	361	Building J Classroom J5	Manual	2/12/2025 6:30:45 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	356	Building J North Exterior	Manual	2/12/2025 6:30:53 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	355	Building J North Exterior	Manual	2/12/2025 6:30:55 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	354	Building J North Exterior	Manual	2/12/2025 6:30:58 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	381	Building K Classroom K1	Manual	2/12/2025 6:30:43 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	382	Building K Classroom K2	Manual	2/12/2025 6:30:42 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	380	Building K North Exterior	Manual	2/12/2025 6:21:41 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	402	Building L Classroom L1	Manual	2/12/2025 6:30:36 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	403	Building L Classroom L2	Manual	2/12/2025 6:30:34 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	404	Building L Classroom L3	Manual	2/12/2025 6:30:33 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	405	Building L Classroom L4	Manual	2/12/2025 6:30:32 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	406	Building L Classroom L5	Manual	2/12/2025 6:30:30 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	407	Building L Restroom L6	Manual	2/12/2025 6:30:29 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	408	Building L Restroom L8	Manual	2/12/2025 6:30:27 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	401	Building L South Exterior	Manual	2/12/2025 6:30:37 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	400	Building L South Exterior	Manual	2/12/2025 6:30:39 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	399	Building L South Exterior	Manual	2/12/2025 6:30:40 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	434	Building N Classroom N1	Manual	2/12/2025 6:30:21 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	435	Building N Classroom N2	Manual	2/12/2025 6:30:19 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	436	Building N Classroom N3	Manual	2/12/2025 6:30:18 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	437	Building N Classroom N4	Manual	2/12/2025 6:30:16 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	438	Building N Classroom N5	Manual	2/12/2025 6:30:10 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	433	Building N North Exterior	Manual	2/12/2025 6:30:23 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	432	Building N North Exterior	Manual	2/12/2025 6:30:25 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	431	Building N North Exterior	Manual	2/12/2025 6:30:26 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	439	Building N Restroom N6	Manual	2/12/2025 6:30:08 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	440	Building N Restroom N8	Manual	2/12/2025 6:30:06 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	457	Building O Classroom O-1	Manual	2/12/2025 6:29:59 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	458	Building O Classroom O-2	Manual	2/12/2025 6:29:58 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	459	Building O Classroom O-3	Manual	2/12/2025 6:29:56 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	460	Building O Classroom O-4	Manual	2/12/2025 6:29:53 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	461	Building O Classroom O-5	Manual	2/12/2025 6:29:52 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	462	Building O Classroom O-6	Manual	2/12/2025 6:29:50 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	456	Building O South Exterior	Manual	2/12/2025 6:30:01 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	455	Building O South Exterior	Manual	2/12/2025 6:30:02 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	454	Building O South Exterior	Manual	2/12/2025 6:30:04 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	490	Building P Classroom P1	Manual	2/12/2025 6:29:44 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	491	Building P Classroom P2	Manual	2/12/2025 6:29:43 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	492	Building P Classroom P3	Manual	2/12/2025 6:29:41 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	493	Building P Classroom P4	Manual	2/12/2025 6:29:40 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	494	Building P Classroom P5	Manual	2/12/2025 6:29:38 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	488	Building P Outside Classrm P1	Manual	2/12/2025 6:29:49 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	489	Building P Outside Classrm P5	Manual	2/12/2025 6:29:47 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	520	Building Q Boys Restroom Q8	Manual	2/12/2025 6:29:23 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	514	Building Q Classroom Q1	Manual	2/12/2025 6:29:32 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	515	Building Q Classroom Q2	Manual	2/12/2025 6:29:31 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	516	Building Q Classroom Q3	Manual	2/12/2025 6:29:29 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	517	Building Q Classroom Q4	Manual	2/12/2025 6:29:27 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	518	Building Q Classroom Q5	Manual	2/12/2025 6:29:25 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	519	Building Q Girls Restroom Q6	Manual	2/12/2025 6:29:24 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	513	Building Q North Exterior	Manual	2/12/2025 6:29:34 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	512	Building Q North Exterior	Manual	2/12/2025 6:29:36 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	511	Building Q North Exterior	Manual	2/12/2025 6:29:37 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	546	Building R Classroom R1	Manual	2/12/2025 6:29:19 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	547	Building R Classroom R2	Manual	2/12/2025 6:29:17 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	555	Building R Classroom R2	Manual	2/12/2025 6:36:34 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	548	Building R Classroom R2 Hall	Manual	2/12/2025 6:29:16 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	545	Building R East Exterior	Manual	2/12/2025 6:29:21 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	549	Building R Office R1A	Manual	2/12/2025 6:22:19 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	551	Building R Office R1B2	Manual	2/12/2025 6:22:15 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	550	Building R Room R1B1 Storage	Manual	2/12/2025 6:22:17 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	552	Building R Room R1B3 Storage	Manual	2/12/2025 6:36:38 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	553	Building R Room R1B4 Storage	Manual	2/12/2025 6:36:37 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	554	Building R Room R1B5 Storage	Manual	2/12/2025 6:36:36 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	654	Building S Boys Restroom S3	Manual	2/12/2025 6:36:08 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	642	Building S Cafeteria S1	Manual	2/12/2025 6:36:25 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	641	Building S Cafeteria S1	Manual	2/12/2025 6:36:27 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	651	Building S Cafeteria S1	Manual	2/12/2025 6:36:12 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	650	Building S Cafeteria S1	Manual	2/12/2025 6:36:14 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	649	Building S Cafeteria S1	Manual	2/12/2025 6:36:15 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	648	Building S Cafeteria S1	Manual	2/12/2025 6:36:16 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	646	Building S Classroom S9	Manual	2/12/2025 6:36:19 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	653	Building S Girls Restroom S2	Manual	2/12/2025 6:36:09 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	660	Building S Kitchen RR S7D	Manual	2/12/2025 6:35:58 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	661	Building S Kitchen RR S7D1	Manual	2/12/2025 6:35:56 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	645	Building S Kitchen S7	Manual	2/12/2025 6:36:21 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	644	Building S Kitchen S7	Manual	2/12/2025 6:36:22 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	659	Building S Kitchen S7	Manual	2/12/2025 6:36:00 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	639	Building S North Exterior	Manual	2/12/2025 6:36:30 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	638	Building S North Exterior	Manual	2/12/2025 6:36:31 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	637	Building S North Exterior	Manual	2/12/2025 6:36:33 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible	664	Building S Office S11	Manual	2/12/2025 6:35:53 PM
		Visual Inspection	Passed (Manual)	
Visible	665	Building S Office S12	Manual	2/12/2025 6:35:51 PM
		Visual Inspection	Passed (Manual)	
Visible	662	Building S Restroom S10	Manual	2/12/2025 6:35:55 PM
		Visual Inspection	Passed (Manual)	
Visible	663	Building S Restroom S10A	Manual	2/12/2025 6:35:52 PM
		Visual Inspection	Passed (Manual)	
Visible	656	Building S S4 Light Room	Manual	2/12/2025 6:36:05 PM
		Visual Inspection	Passed (Manual)	
Visible	655	Building S S4 Stage	Manual	2/12/2025 6:36:06 PM
		Visual Inspection	Passed (Manual)	
Visible	657	Building S S4 Stage Strg S4C	Manual	2/12/2025 6:36:03 PM
		Visual Inspection	Passed (Manual)	
Visible	658	Building S S4D Storage	Manual	2/12/2025 6:36:02 PM
		Visual Inspection	Passed (Manual)	
Audible And Visible	647	Building S Snack Stand Hall	Manual	2/12/2025 6:36:18 PM
		Visual Inspection	Passed (Manual)	
Visible	666	Building S Snack Stand S13	Manual	2/12/2025 6:35:48 PM
		Visual Inspection	Passed (Manual)	
Visible	652	Building S Snack Stand S1A	Manual	2/12/2025 6:36:11 PM
		Visual Inspection	Passed (Manual)	
Audible	667	Building S South Exterior	Manual	2/12/2025 6:35:47 PM
		Visual Inspection	Passed (Manual)	
Audible	640	Building S South Exterior	Manual	2/12/2025 6:36:29 PM
		Visual Inspection	Passed (Manual)	
Audible And Visible	643	Building S Theater S4	Manual	2/12/2025 6:36:24 PM
		Visual Inspection	Passed (Manual)	
Audible And Visible	803	Building T Classroom T3F	Manual	2/12/2025 6:35:25 PM
		Visual Inspection	Passed (Manual)	
Visible	818	Building T Dressing Room T2A	Manual	2/12/2025 6:35:01 PM
		Visual Inspection	Passed (Manual)	
Audible	792	Building T East Exterior	Manual	2/12/2025 6:35:42 PM
		Visual Inspection	Passed (Manual)	
Audible	791	Building T East Exterior	Manual	2/12/2025 6:35:44 PM
		Visual Inspection	Passed (Manual)	
Audible	790	Building T East Exterior	Manual	2/12/2025 6:35:45 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	798	Building T Large Gym T1 Foyer	Manual	2/12/2025 6:35:31 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	797	Building T Large Gym T1 Foyer	Manual	2/12/2025 6:35:34 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	811	Building T Large Gym T1 Foyer	Manual	2/12/2025 6:35:12 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	809	Building T Large Gym T6	Manual	2/12/2025 6:35:15 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	808	Building T Large Gym T6	Manual	2/12/2025 6:35:16 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	807	Building T Large Gym T6	Manual	2/12/2025 6:35:18 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	806	Building T Large Gym T6	Manual	2/12/2025 6:35:19 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	800	Building T Locker Room T2	Manual	2/12/2025 6:35:30 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	799	Building T Locker Room T2	Manual	2/12/2025 6:35:32 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	817	Building T Locker Room T2	Manual	2/12/2025 6:35:03 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	816	Building T Locker Room T2	Manual	2/12/2025 6:35:04 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	815	Building T Locker Room T2	Manual	2/12/2025 6:35:05 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	802	Building T Locker Room T3	Manual	2/12/2025 6:35:27 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	801	Building T Locker Room T3	Manual	2/12/2025 6:35:28 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	824	Building T Locker Room T3	Manual	2/12/2025 6:34:53 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	823	Building T Locker Room T3	Manual	2/12/2025 6:34:54 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	822	Building T Locker Room T3	Manual	2/12/2025 6:34:55 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	821	Building T Locker Room T3	Manual	2/12/2025 6:34:57 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible	813	Building T Lrg Gym RR T1G	Manual	2/12/2025 6:35:09 PM
		Visual Inspection	Passed (Manual)	
Visible	814	Building T Lrg Gym RR T1i	Manual	2/12/2025 6:35:07 PM
		Visual Inspection	Passed (Manual)	
Visible	819	Building T Office T2E	Manual	2/12/2025 6:35:00 PM
		Visual Inspection	Passed (Manual)	
Visible	820	Building T Office T2E1	Manual	2/12/2025 6:34:58 PM
		Visual Inspection	Passed (Manual)	
Visible	826	Building T Office T3C	Manual	2/12/2025 6:34:49 PM
		Visual Inspection	Passed (Manual)	
Visible	812	Building T Room T1D	Manual	2/12/2025 6:35:10 PM
		Visual Inspection	Passed (Manual)	
Visible	825	Building T Room T3B Storage	Manual	2/12/2025 6:34:51 PM
		Visual Inspection	Passed (Manual)	
Visible	827	Building T Room T3C1 Storage	Manual	2/12/2025 6:34:47 PM
		Visual Inspection	Passed (Manual)	
Audible And Visible	805	Building T Small Gym T5	Manual	2/12/2025 6:35:21 PM
		Visual Inspection	Passed (Manual)	
Audible And Visible	804	Building T Small Gym T5	Manual	2/12/2025 6:35:22 PM
		Visual Inspection	Passed (Manual)	
Visible	829	Building T Small Gym T5	Manual	2/12/2025 6:34:44 PM
		Visual Inspection	Passed (Manual)	
Visible	828	Building T Small Gym T5	Manual	2/12/2025 6:34:46 PM
		Visual Inspection	Passed (Manual)	
Audible	793	Building T South Exterior	Manual	2/12/2025 6:35:41 PM
		Visual Inspection	Passed (Manual)	
Visible	831	Building T Weight Rm T7A Off	Manual	2/12/2025 6:34:41 PM
		Visual Inspection	Passed (Manual)	
Audible And Visible	810	Building T Weight Room T7	Manual	2/12/2025 6:35:13 PM
		Visual Inspection	Passed (Manual)	
Visible	830	Building T Weight Room T7	Manual	2/12/2025 6:34:42 PM
		Visual Inspection	Passed (Manual)	
Audible	796	Building T West Exterior	Manual	2/12/2025 6:35:35 PM
		Visual Inspection	Passed (Manual)	
Audible	795	Building T West Exterior	Manual	2/12/2025 6:35:37 PM
		Visual Inspection	Passed (Manual)	
Audible	794	Building T West Exterior	Manual	2/12/2025 6:35:39 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	920	Encina SW Area Admin Office	Manual	2/12/2025 6:34:22 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	927	Encina SW Area Back Office	Manual	2/12/2025 6:34:10 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	933	Encina SW Area Changing Room	Manual	2/12/2025 6:34:00 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	916	Encina SW Area Classroom 1	Manual	2/12/2025 6:34:32 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	917	Encina SW Area Classroom 2	Manual	2/12/2025 6:34:30 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	918	Encina SW Area Classroom 3	Manual	2/12/2025 6:34:25 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	919	Encina SW Area Classroom 4	Manual	2/12/2025 6:34:23 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	922	Encina SW Area Daycare 1	Manual	2/12/2025 6:34:19 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	932	Encina SW Area Daycare 1	Manual	2/12/2025 6:34:02 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	934	Encina SW Area Daycare 1 Office	Manual	2/12/2025 6:33:58 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	923	Encina SW Area Daycare 2	Manual	2/12/2025 6:34:17 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	935	Encina SW Area Daycare Kitchen	Manual	2/12/2025 6:33:57 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	915	Encina SW Area East Exterior	Manual	2/12/2025 6:34:34 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	924	Encina SW Area ECE P1	Manual	2/12/2025 6:34:16 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	925	Encina SW Area ECE P2	Manual	2/12/2025 6:34:14 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	938	Encina SW Area ECE Restroom	Manual	2/12/2025 6:33:52 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	937	Encina SW Area ECE Restroom	Manual	2/12/2025 6:33:54 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	926	Encina SW Area Front Office	Manual	2/12/2025 6:34:12 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible	936	Encina SW Area Nap Room	Manual	2/12/2025 6:33:55 PM
		Visual Inspection	Passed (Manual)	
Audible	914	Encina SW Area North Exterior	Manual	2/12/2025 6:34:36 PM
		Visual Inspection	Passed (Manual)	
Audible	913	Encina SW Area North Exterior	Manual	2/12/2025 6:34:38 PM
		Visual Inspection	Passed (Manual)	
Audible	912	Encina SW Area North Exterior	Manual	2/12/2025 6:34:39 PM
		Visual Inspection	Passed (Manual)	
Visible	928	Encina SW Area Office Kitchen	Manual	2/12/2025 6:34:09 PM
		Visual Inspection	Passed (Manual)	
Visible	929	Encina SW Area Office Restroom	Manual	2/12/2025 6:34:07 PM
		Visual Inspection	Passed (Manual)	
Visible	931	Encina SW Area Staff Restroom	Manual	2/12/2025 6:34:03 PM
		Visual Inspection	Passed (Manual)	
Audible And Visible	921	Encina SW Area Staff Room	Manual	2/12/2025 6:34:20 PM
		Visual Inspection	Passed (Manual)	
Visible	930	Encina SW Area Staff Room	Manual	2/12/2025 6:34:05 PM
		Visual Inspection	Passed (Manual)	

Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Remote Annunciator	001	Building A Front Office A3	Manual	2/12/2025 7:03:06 PM
		Visual Inspection	Passed (Manual)	
NAC Power Extender Panel	833	Building T Electrical Room T1E	Manual	2/12/2025 8:07:19 PM
		Visual Inspection	Passed (Manual)	

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Fire Alarm Panel		Build A Room A12 Headend	Manual	2/12/2025 8:10:05 PM
		Manufacturer	Notifier	
		Model	NFS-3030	
NAC Power Extender Panel	090	Building A Room A12/Headend	Manual	2/12/2025 8:09:24 PM
NAC Power Extender Panel	089	Building A Room A12/Headend	Manual	2/12/2025 8:09:27 PM
NAC Power Extender Panel	321	Building H Room H5 Storage	Manual	2/12/2025 8:09:32 PM
NAC Power Extender Panel	320	Building H Room H5 Storage	Manual	2/12/2025 8:09:35 PM
NAC Power Extender Panel	410	Building L Room L7 Storage	Manual	2/12/2025 8:09:37 PM
NAC Power Extender Panel	409	Building L Room L7 Storage	Manual	2/12/2025 8:09:40 PM
NAC Power Extender Panel	441	Building N Room N7 Storage	Manual	2/12/2025 8:09:30 PM
NAC Power Extender Panel	521	Building Q Room Q7 Storage	Manual	2/12/2025 8:09:14 PM
NAC Power Extender Panel	668	Building S Storage S1B	Manual	2/12/2025 8:09:22 PM
NAC Power Extender Panel	834	Building T Room T1F Storage	Manual	2/12/2025 8:09:18 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
NAC Power Extender Panel	832	Building T Room T3A Storage	Manual	2/12/2025 8:09:16 PM
NAC Power Extender Panel	939	Encina Portables SW Area Office	Manual	2/12/2025 8:35:06 PM

Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-005 011	Building A A2A Storage	Manual	2/12/2025 5:13:00 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-015 018	Building A A2E Hall	Manual	2/12/2025 5:11:45 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-030 033	Building A A9A Storage	Manual	2/12/2025 5:04:42 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-003 037	Building A Admin Hall by A3	Manual	2/12/2025 5:15:14 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-022 038	Building A Admin Hall by A5	Manual	2/12/2025 5:16:03 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-026 039	Building A Admin Hall by A6 Strg	Manual	2/12/2025 5:16:27 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-039 040	Building A Admin Hall by A9	Manual	2/12/2025 5:01:39 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-141 053	Building A Attic A10	Manual	2/12/2025 8:53:57 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-141 054	Building A Attic A11	Manual	2/12/2025 8:53:55 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-130 043	Building A Attic Office A1A	Manual	2/12/2025 8:57:17 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-138 055	Building A Attic Office A1B	Manual	2/12/2025 8:47:47 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-132 046	Building A Attic Office A1E	Manual	2/12/2025 8:57:15 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-134 047	Building A Attic Office A2	Manual	2/12/2025 8:57:14 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-139 056	Building A Attic Office A2	Manual	2/12/2025 8:47:43 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-127 048	Building A Attic Office A2A-A5	Manual	2/12/2025 8:57:12 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-135 050	Building A Attic Office A8	Manual	2/12/2025 8:57:10 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-136 051	Building A Attic Staff Rm A9	Manual	2/12/2025 8:57:08 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-137 052	Building A Attic Staff Rm A9 Hall	Manual	2/12/2025 8:57:09 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-140 058	Building A Attic Staff Rm A9 Hall	Manual	2/12/2025 8:47:39 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-190 002	Building A Front Office A3	Manual	2/12/2025 5:18:08 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-031 032	Building A Hall A9A	Manual	2/12/2025 5:05:32 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-009 003	Building A Office A1	Manual	2/12/2025 5:18:30 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-007 004	Building A Office A1 Closet	Manual	2/12/2025 5:20:07 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-010 005	Building A Office A1A	Manual	2/12/2025 5:12:56 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-008 006	Building A Office A1B	Manual	2/12/2025 5:17:27 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-012 007	Building A Office A1C	Manual	2/12/2025 5:13:46 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-011 008	Building A Office A1D	Manual	2/12/2025 5:19:07 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-111 009	Building A Office A1E	Manual	2/12/2025 5:19:34 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-013 010	Building A Office A2	Manual	2/12/2025 5:13:15 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-023 013	Building A Office A2B	Manual	2/12/2025 5:09:24 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-016 012	Building A Office A2B	Manual	2/12/2025 5:11:33 PM
		Visual Inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	2-024 014	Building A Office A2B1	Manual	2/12/2025 5:09:27 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-018 015	Building A Office A2D	Manual	2/12/2025 5:10:43 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-017 016	Building A Office A2D Hall	Manual	2/12/2025 5:10:24 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-014 017	Building A Office A2E	Manual	2/12/2025 5:12:11 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-006 019	Building A Office A3	Manual	2/12/2025 5:14:20 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-004 020	Building A Office A3	Manual	2/12/2025 5:14:49 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-021 023	Building A Office A5	Manual	2/12/2025 5:09:58 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-028 026	Building A Office A8	Manual	2/12/2025 5:05:18 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-029 027	Building A Office A8 Hall	Manual	2/12/2025 5:06:41 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-033 028	Building A Office A8A	Manual	2/12/2025 5:05:42 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-034 030	Building A Office A8A1	Manual	2/12/2025 5:05:56 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-037 034	Building A Office A9B	Manual	2/12/2025 5:02:57 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-036 035	Building A Office A9C	Manual	2/12/2025 5:03:36 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-035 036	Building A Office A9D	Manual	2/12/2025 5:04:01 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-032 029	Building A Office Restroom A8A	Manual	2/12/2025 5:05:30 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-020 021	Building A Restroom A4	Manual	2/12/2025 5:07:32 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-019 022	Building A Restroom A4	Manual	2/12/2025 5:15:35 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-025 025	Building A Restroom A7	Manual	2/12/2025 5:08:31 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-002 041	Building A Room A12/Headend	Manual	2/11/2025 5:04:32 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-038 031	Building A Staff Room A9	Manual	2/12/2025 5:01:46 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-027 024	Building A Storage A6	Manual	2/12/2025 5:07:11 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-377 104	Building B Attic Library B1	Manual	2/12/2025 8:08:14 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-376 105	Building B Attic Office B1B	Manual	2/12/2025 8:08:08 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-376 106	Building B Attic Office B1B	Manual	2/12/2025 8:08:09 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-376 107	Building B Attic Office B1B	Manual	2/12/2025 8:08:11 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-436 108	Building B Attic Office B1B	Manual	2/12/2025 8:47:40 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-251 102	Building B Classroom B2	Manual	2/11/2025 5:06:29 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-252 103	Building B Classroom B2	Manual	2/11/2025 5:06:43 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-254 098	Building B Library B1	Manual	2/11/2025 5:09:00 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-255 097	Building B Library B1	Manual	2/11/2025 5:09:08 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-256 096	Building B Library B1	Manual	2/11/2025 5:09:44 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-257 095	Building B Library B1	Manual	2/11/2025 5:10:00 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-258 094	Building B Library B1	Manual	2/11/2025 5:10:32 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-259 093	Building B Library B1	Manual	2/11/2025 5:10:50 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-260 092	Building B Library B1	Manual	2/11/2025 5:11:25 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-261 091	Building B Library B1	Manual	2/11/2025 5:12:17 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-267 099	Building B Library B1	Manual	2/12/2025 6:37:58 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-266 100	Building B Office B1A	Manual	2/11/2025 5:12:50 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-253 101	Building B Office B1B	Manual	2/11/2025 5:08:02 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-280 116	Building C Classroom C1	Manual	2/11/2025 5:24:34 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-281 115	Building C Classroom C1	Manual	2/11/2025 5:25:08 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-278 118	Building C Classroom C2	Manual	2/11/2025 5:22:20 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-279 117	Building C Classroom C2	Manual	2/11/2025 5:23:24 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-276 119	Building C Classroom C3	Manual	2/11/2025 5:21:00 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-277 120	Building C Classroom C3	Manual	2/11/2025 5:21:28 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-274 121	Building C Classroom C4	Manual	2/11/2025 5:19:24 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-275 122	Building C Classroom C4	Manual	2/11/2025 5:19:53 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-272 123	Building C Classroom C5	Manual	2/11/2025 5:17:58 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-273 124	Building C Classroom C5	Manual	2/11/2025 5:18:28 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-270 125	Building C Classroom C6	Manual	2/11/2025 5:16:09 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-271 126	Building C Classroom C6	Manual	2/11/2025 5:16:39 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-290 137	Building D Classroom D1	Manual	2/11/2025 5:37:26 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-291 136	Building D Classroom D1	Manual	2/11/2025 5:39:12 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-288 138	Building D Classroom D2	Manual	2/11/2025 5:34:09 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-289 139	Building D Classroom D2	Manual	2/11/2025 5:36:05 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-286 140	Building D Classroom D3	Manual	2/11/2025 5:31:08 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-287 141	Building D Classroom D3	Manual	2/11/2025 5:31:30 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-285 143	Building D Classroom D4	Manual	2/12/2025 6:38:01 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-284 142	Building D Classroom D4	Manual	2/12/2025 6:38:03 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-282 145	Building D Classroom D5	Manual	2/11/2025 5:27:17 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-283 144	Building D Classroom D5	Manual	2/11/2025 5:27:50 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-127 186	Building E Attic Hall by Rm E2	Manual	2/12/2025 8:04:56 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-127 187	Building E Attic Hall by Rm E2	Manual	2/12/2025 8:04:58 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-126 185	Building E Attic Strg by Rm E2	Manual	2/12/2025 8:04:54 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-030 156	Building E Classroom E1	Manual	2/12/2025 5:04:40 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-029 157	Building E Classroom E1	Manual	2/12/2025 6:38:23 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-025 155	Building E Classroom E1	Manual	2/12/2025 6:38:25 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-024 154	Building E Classroom E1	Manual	2/12/2025 6:38:27 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-011 159	Building E Classroom E2	Manual	2/11/2025 5:53:46 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-012 162	Building E Classroom E2	Manual	2/11/2025 5:54:18 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-013 163	Building E Classroom E2	Manual	2/11/2025 5:54:28 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-018 164	Building E Classroom E2	Manual	2/11/2025 5:55:00 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-017 161	Building E Classroom E2	Manual	2/11/2025 5:55:38 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-016 160	Building E Classroom E2	Manual	2/11/2025 5:56:20 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-009 175	Building E Classroom E3	Manual	2/11/2025 5:45:58 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-010 176	Building E Classroom E3	Manual	2/11/2025 5:46:56 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-015 173	Building E Classroom E3	Manual	2/11/2025 5:47:07 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-014 174	Building E Classroom E3	Manual	2/11/2025 5:47:25 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-008 177	Building E Classroom E3 Closet	Manual	2/11/2025 5:49:46 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-006 184	Building E Classroom E4	Manual	2/11/2025 5:41:57 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-007 183	Building E Classroom E4	Manual	2/11/2025 5:43:10 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-002 182	Building E Classroom E4	Manual	2/11/2025 5:44:23 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-001 181	Building E Classroom E4	Manual	2/11/2025 5:44:34 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-023 168	Building E Dental Room 1	Manual	2/11/2025 5:57:37 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-026 169	Building E Dental Room 2	Manual	2/11/2025 5:58:20 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-028 170	Building E Dental Room 3	Manual	2/11/2025 5:58:18 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-021 172	Building E Doorway by Rm E2	Manual	2/11/2025 5:57:19 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-027 171	Building E Hall by Classrm E2	Manual	2/11/2025 5:58:15 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-022 165	Building E Hall Next to Rm E2	Manual	2/11/2025 5:57:22 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-031 158	Building E Storage by Room E1	Manual	2/11/2025 5:59:58 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-032 167	Building E Storage by Room E2	Manual	2/11/2025 5:59:31 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-019 166	Building E Storage by Room E2	Manual	2/12/2025 6:38:06 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-004 179	Building E Storage E3A	Manual	2/11/2025 5:52:01 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-003 180	Building E Storage E3A	Manual	2/11/2025 5:52:23 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-005 178	Building E Storage E3A	Manual	2/12/2025 6:40:21 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-037 210	Building F Classroom F2	Manual	2/11/2025 6:08:34 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-052 214	Building F Classroom F2	Manual	2/11/2025 6:09:11 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-053 213	Building F Classroom F2	Manual	2/11/2025 6:11:02 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-036 211	Building F Classroom F2	Manual	2/11/2025 6:11:07 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-054 212	Building F Classroom F2	Manual	2/11/2025 6:12:05 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-051 217	Building F Classroom F2C	Manual	2/12/2025 6:38:29 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-033 220	Building F Classroom F3	Manual	2/11/2025 6:05:40 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-034 219	Building F Classroom F3	Manual	2/11/2025 6:05:56 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-056 221	Building F Classroom F3	Manual	2/11/2025 6:06:19 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-055 222	Building F Classroom F3	Manual	2/11/2025 6:06:43 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-035 218	Building F Classroom F3	Manual	2/11/2025 6:11:35 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-063 223	Building F Classroom F4	Manual	2/11/2025 6:04:36 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-061 224	Building F Classroom F5	Manual	2/11/2025 6:02:41 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-062 225	Building F Classroom F5A	Manual	2/11/2025 6:03:23 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-060 226	Building F Classroom F6	Manual	2/12/2025 6:38:30 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-057 228	Building F Classroom F6	Manual	2/12/2025 6:38:31 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-058 229	Building F Classroom F6	Manual	2/12/2025 6:38:33 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-059 227	Building F Classroom F6	Manual	2/12/2025 6:40:31 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-045 207	Building F Custodial Off Storage	Manual	2/12/2025 7:11:49 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-046 206	Building F Custodial Off Storage	Manual	2/12/2025 7:12:13 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-042 202	Building F Custodial Office F1	Manual	2/12/2025 7:10:29 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-043 201	Building F Custodial Office F1	Manual	2/12/2025 7:10:53 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-044 205	Building F Custodial Office F1	Manual	2/12/2025 7:11:16 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-050 199	Building F Custodial Office F1	Manual	2/12/2025 7:12:42 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-049 200	Building F Custodial Office F1	Manual	2/12/2025 7:13:02 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-048 203	Building F Custodial Office F1	Manual	2/12/2025 7:13:26 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-047 204	Building F Custodial Office F1	Manual	2/12/2025 7:13:56 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-041 209	Building F Storage F1B	Manual	2/12/2025 6:01:02 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-039 215	Building F Storage F2A	Manual	2/11/2025 6:15:03 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-038 216	Building F Storage F2B	Manual	2/11/2025 6:13:21 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-072 265	Building G Art Rm G2A Storage	Manual	2/11/2025 6:31:57 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-091 266	Building G Art Rm G2B Storage	Manual	2/11/2025 6:31:52 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-079 267	Building G Art Rm G2C Storage	Manual	2/11/2025 6:31:56 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-080 268	Building G Art Rm G2D Storage	Manual	2/11/2025 6:32:56 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-064 241	Building G Art Room G1	Manual	2/11/2025 6:19:53 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-068 242	Building G Art Room G1	Manual	2/11/2025 6:20:18 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-069 243	Building G Art Room G1	Manual	2/11/2025 6:20:56 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-070 244	Building G Art Room G1	Manual	2/11/2025 6:21:25 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-098 245	Building G Art Room G1	Manual	2/11/2025 6:21:40 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-099 246	Building G Art Room G1	Manual	2/11/2025 6:22:03 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-100 247	Building G Art Room G1	Manual	2/11/2025 6:22:25 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-101 248	Building G Art Room G1	Manual	2/11/2025 6:22:55 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-096 259	Building G Art Room G2	Manual	2/11/2025 6:27:26 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-074 258	Building G Art Room G2	Manual	2/11/2025 6:28:03 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-075 257	Building G Art Room G2	Manual	2/11/2025 6:28:20 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-095 260	Building G Art Room G2	Manual	2/11/2025 6:28:49 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-094 261	Building G Art Room G2	Manual	2/11/2025 6:29:11 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-093 262	Building G Art Room G2	Manual	2/11/2025 6:31:45 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-092 263	Building G Art Room G2	Manual	2/11/2025 6:31:48 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-076 256	Building G Art Room G2	Manual	2/11/2025 6:31:59 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-077 255	Building G Art Room G2	Manual	2/11/2025 6:32:00 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-078 254	Building G Art Room G2	Manual	2/11/2025 6:32:02 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-097 264	Building G Art Room G2 Storage	Manual	2/11/2025 6:24:03 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-065 249	Building G Art Storage G1A	Manual	2/12/2025 6:38:34 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-066 250	Building G Art Storage G1B	Manual	2/12/2025 6:39:33 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-067 251	Building G Art Storage G1C	Manual	2/12/2025 6:39:31 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-073 252	Building G Art Storage G1D	Manual	2/11/2025 6:24:39 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-071 253	Building G Art Storage G1E	Manual	2/11/2025 6:26:24 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-128 279	Building G Attic Strge Rm G3B	Manual	2/12/2025 8:08:05 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-129 280	Building G Attic Strge Rm G3D	Manual	2/12/2025 8:08:04 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-081 275	Building G Medical Rm G3A Strg	Manual	2/12/2025 6:40:51 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-082 276	Building G Medical Rm G3B Strg	Manual	2/12/2025 5:22:49 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-089 277	Building G Medical Rm G3C Strg	Manual	2/12/2025 6:40:49 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-090 278	Building G Medical Rm G3D Strg	Manual	2/11/2025 6:31:51 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-087 270	Building G Medical Room G3	Manual	2/12/2025 6:15:13 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-083 272	Building G Medical Room G3	Manual	2/12/2025 6:38:36 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-084 273	Building G Medical Room G3	Manual	2/12/2025 6:38:37 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-085 274	Building G Medical Room G3	Manual	2/12/2025 6:38:38 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-088 269	Building G Medical Room G3	Manual	2/12/2025 6:38:40 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-086 271	Building G Medical Room G3	Manual	2/12/2025 6:38:42 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-063 308	Building H Classrm H5 Storage	Manual	2/11/2025 9:49:12 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-061 291	Building H Classroom H1	Manual	2/11/2025 6:48:14 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-052 292	Building H Classroom H1	Manual	2/11/2025 6:48:31 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-051 293	Building H Classroom H1	Manual	2/11/2025 6:49:04 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-062 299	Building H Classroom H2	Manual	2/11/2025 6:51:54 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-050 296	Building H Classroom H2	Manual	2/11/2025 6:52:14 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-049 297	Building H Classroom H2	Manual	2/11/2025 6:52:45 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-048 298	Building H Classroom H2	Manual	2/11/2025 6:52:58 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-046 300	Building H Classroom H2A	Manual	2/11/2025 6:54:26 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-043 303	Building H Classroom H3	Manual	2/11/2025 6:56:40 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-044 302	Building H Classroom H3	Manual	2/11/2025 6:56:43 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	4-045 301	Building H Classroom H3	Manual	2/11/2025 6:57:01 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-047 304	Building H Classroom H3A	Manual	2/11/2025 6:53:18 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-057 305	Building H Restroom H4	Manual	2/12/2025 5:31:11 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-056 306	Building H Restroom H4	Manual	2/12/2025 6:40:54 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-059 309	Building H Restroom H6	Manual	2/11/2025 9:50:29 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-058 310	Building H Restroom H6	Manual	2/11/2025 9:50:30 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-054 294	Building H Room H1A Storage	Manual	2/11/2025 6:49:28 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-053 295	Building H Room H1B Storage	Manual	2/11/2025 6:50:02 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-055 307	Building H Room H5 Storage	Manual	2/11/2025 9:49:15 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-162 335	Building I Attic Classroom i1	Manual	2/12/2025 8:08:20 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-162 334	Building I Attic Classroom i1	Manual	2/12/2025 8:08:21 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-163 337	Building I Attic Classroom i2	Manual	2/12/2025 8:08:23 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-163 336	Building I Attic Classroom i2	Manual	2/12/2025 8:08:25 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-031 322	Building I Classroom i1	Manual	2/11/2025 9:30:41 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-035 327	Building I Classroom i1	Manual	2/11/2025 9:30:44 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-036 326	Building I Classroom i1	Manual	2/11/2025 9:30:46 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	4-037 325	Building I Classroom i1	Manual	2/11/2025 9:30:55 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-033 324	Building I Classroom i1	Manual	2/11/2025 9:31:20 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-032 323	Building I Classroom i1	Manual	2/11/2025 9:31:34 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-038 329	Building I Classroom i2	Manual	2/11/2025 9:34:12 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-039 330	Building I Classroom i2	Manual	2/11/2025 9:34:14 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-042 331	Building I Classroom i2	Manual	2/11/2025 9:34:59 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-041 332	Building I Classroom i2	Manual	2/11/2025 9:35:24 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-034 328	Building I Room i1A Storage	Manual	2/11/2025 9:33:14 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-040 333	Building I Room i2A Storage	Manual	2/11/2025 9:36:30 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-029 341	Building J Classroom J1	Manual	2/11/2025 7:06:14 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-030 342	Building J Classroom J1	Manual	2/11/2025 7:06:49 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-026 345	Building J Classroom J2	Manual	2/11/2025 7:04:36 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-025 346	Building J Classroom J2	Manual	2/11/2025 7:04:38 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-023 347	Building J Classroom J3	Manual	2/11/2025 7:02:51 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-024 348	Building J Classroom J3	Manual	2/11/2025 7:03:25 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-020 349	Building J Classroom J4	Manual	2/11/2025 7:00:01 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	4-018 352	Building J Classroom J5	Manual	2/11/2025 6:58:25 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-019 353	Building J Classroom J5	Manual	2/11/2025 6:58:52 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-027 343	Building J Room J1A Storage	Manual	2/11/2025 7:05:12 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-028 344	Building J Room J1B Storage	Manual	2/11/2025 7:05:37 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-022 350	Building J Room J4A Storage	Manual	2/11/2025 7:00:35 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-021 351	Building J Room J4B Storage	Manual	2/11/2025 7:00:38 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-164 379	Building K Attic Classroom K1	Manual	2/12/2025 8:05:07 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-002 363	Building K Classroom K1	Manual	2/11/2025 9:18:10 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-001 364	Building K Classroom K1	Manual	2/11/2025 9:19:08 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-004 365	Building K Classroom K1	Manual	2/11/2025 9:19:12 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-005 366	Building K Classroom K1	Manual	2/11/2025 9:19:21 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-006 367	Building K Classroom K1	Manual	2/11/2025 9:19:46 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-003 362	Building K Classroom K1	Manual	2/12/2025 6:38:44 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-014 376	Building K Classroom K2	Manual	2/11/2025 9:22:56 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-013 375	Building K Classroom K2	Manual	2/11/2025 9:23:12 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-012 374	Building K Classroom K2	Manual	2/11/2025 9:24:05 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	4-015 373	Building K Classroom K2	Manual	2/11/2025 9:24:09 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-016 372	Building K Classroom K2	Manual	2/11/2025 9:24:33 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-017 371	Building K Classroom K2	Manual	2/11/2025 9:24:59 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-007 368	Building K Room K1A Storage	Manual	2/11/2025 9:20:33 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-008 369	Building K Room K1B Storage	Manual	2/11/2025 9:28:40 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-009 370	Building K Room K1C Storage	Manual	2/11/2025 9:21:43 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-011 377	Building K Room K2B Storage	Manual	2/11/2025 9:27:07 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-010 378	Building K Room K2C Storage	Manual	2/11/2025 9:25:55 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-378 398	Building L Attic Rm L7 Storage	Manual	2/12/2025 8:05:12 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-286 383	Building L Classroom L1	Manual	2/11/2025 7:10:06 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-287 384	Building L Classroom L1	Manual	2/11/2025 7:10:25 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-284 385	Building L Classroom L2	Manual	2/11/2025 7:12:51 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-285 386	Building L Classroom L2	Manual	2/11/2025 7:13:34 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-282 387	Building L Classroom L3	Manual	2/11/2025 7:14:49 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-283 388	Building L Classroom L3	Manual	2/11/2025 7:15:21 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-280 389	Building L Classroom L4	Manual	2/11/2025 7:17:31 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	4-281 390	Building L Classroom L4	Manual	2/11/2025 7:17:33 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-279 392	Building L Classroom L5	Manual	2/11/2025 7:18:40 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-278 391	Building L Classroom L5	Manual	2/12/2025 6:38:46 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-290 393	Building L Restroom L6	Manual	2/11/2025 7:07:51 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-291 394	Building L Restroom L6	Manual	2/11/2025 7:08:10 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-288 396	Building L Restroom L8	Manual	2/11/2025 6:46:29 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-289 397	Building L Restroom L8	Manual	2/11/2025 6:46:33 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-292 395	Building L Room L7 Storage	Manual	2/12/2025 6:37:26 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-377 413	Building M Attic Mech Room M1	Manual	2/12/2025 7:22:37 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-377 414	Building M Attic Mech Room M1	Manual	2/12/2025 7:22:51 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-377 411	Building M Attic Mech Room M1	Manual	2/12/2025 7:22:52 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-377 412	Building M Attic Mech Room M1	Manual	2/12/2025 7:22:57 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-276 415	Building N Classroom N1	Manual	2/12/2025 6:38:48 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-277 416	Building N Classroom N1	Manual	2/12/2025 6:38:49 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-274 417	Building N Classroom N2	Manual	2/12/2025 6:51:41 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-275 418	Building N Classroom N2	Manual	2/12/2025 6:51:42 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	4-273 420	Building N Classroom N3	Manual	2/12/2025 6:40:20 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-272 419	Building N Classroom N3	Manual	2/12/2025 6:51:44 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-270 421	Building N Classroom N4	Manual	2/12/2025 6:51:45 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-271 422	Building N Classroom N4	Manual	2/12/2025 6:51:46 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-268 423	Building N Classroom N5	Manual	2/12/2025 6:51:48 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-269 424	Building N Classroom N5	Manual	2/12/2025 6:51:49 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-267 425	Building N Restroom N6	Manual	2/11/2025 7:20:07 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-266 426	Building N Restroom N6	Manual	2/11/2025 7:20:28 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-265 428	Building N Restroom N8	Manual	2/11/2025 7:24:29 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-264 429	Building N Restroom N8	Manual	2/11/2025 7:24:51 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-263 427	Building N Room N7 Storage	Manual	2/11/2025 7:23:23 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-251 443	Building O Classroom O-1	Manual	2/11/2025 8:19:39 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-252 442	Building O Classroom O-1	Manual	2/11/2025 8:20:01 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-254 444	Building O Classroom O-2	Manual	2/11/2025 8:21:09 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-253 445	Building O Classroom O-2	Manual	2/11/2025 8:21:32 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-256 446	Building O Classroom O-3	Manual	2/11/2025 8:22:42 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	4-255 447	Building O Classroom O-3	Manual	2/11/2025 8:23:05 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-258 448	Building O Classroom O-4	Manual	2/11/2025 8:27:13 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-257 449	Building O Classroom O-4	Manual	2/11/2025 8:27:15 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-259 450	Building O Classroom O-5	Manual	2/11/2025 8:29:08 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-260 451	Building O Classroom O-5	Manual	2/11/2025 8:29:12 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-262 452	Building O Classroom O-6	Manual	2/11/2025 8:30:23 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-261 453	Building O Classroom O-6	Manual	2/11/2025 8:30:30 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-017 463	Building P Classroom P1	Manual	2/11/2025 8:46:49 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-018 464	Building P Classroom P1	Manual	2/11/2025 8:56:42 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-027 465	Building P Classroom P1	Manual	2/11/2025 8:56:47 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-026 466	Building P Classroom P1	Manual	2/11/2025 8:56:59 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-019 468	Building P Classroom P2	Manual	2/11/2025 8:59:58 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-020 469	Building P Classroom P2	Manual	2/11/2025 9:00:26 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-023 472	Building P Classroom P2	Manual	2/11/2025 9:00:40 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-022 471	Building P Classroom P2	Manual	2/11/2025 9:01:01 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-021 470	Building P Classroom P2	Manual	2/11/2025 9:01:25 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	5-035 477	Building P Classroom P4	Manual	2/11/2025 9:04:20 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-032 480	Building P Classroom P4	Manual	2/11/2025 9:04:34 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-033 479	Building P Classroom P4	Manual	2/11/2025 9:05:07 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-034 478	Building P Classroom P4	Manual	2/11/2025 9:05:29 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-031 481	Building P Classroom P4	Manual	2/12/2025 6:38:56 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-038 487	Building P Classroom P5	Manual	2/11/2025 9:07:24 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-041 484	Building P Classroom P5	Manual	2/11/2025 9:08:54 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-040 485	Building P Classroom P5	Manual	2/11/2025 9:09:29 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-039 486	Building P Classroom P5	Manual	2/11/2025 9:10:05 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-024 467	Building P Room P1A Storage	Manual	2/11/2025 8:58:31 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-025 473	Building P Room P2A Storage	Manual	2/11/2025 8:58:52 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-028 474	Building P Room P3 Storage	Manual	2/11/2025 9:02:17 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-029 475	Building P Room P3 Storage	Manual	2/11/2025 9:02:39 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-030 476	Building P Room P3 Storage	Manual	2/11/2025 9:10:11 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-037 483	Building P Room P4A Storage	Manual	2/11/2025 9:06:40 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-036 482	Building P Room P4A Storage	Manual	2/11/2025 9:06:42 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	5-126 510	Building Q Attic Rm Q7 Storage	Manual	2/12/2025 8:05:16 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-013 508	Building Q Boys Restroom Q8	Manual	2/11/2025 8:32:45 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-012 509	Building Q Boys Restroom Q8	Manual	2/11/2025 8:33:14 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-002 496	Building Q Classroom Q1	Manual	2/11/2025 8:41:22 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-001 495	Building Q Classroom Q1	Manual	2/11/2025 8:41:47 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-004 497	Building Q Classroom Q2	Manual	2/11/2025 8:39:41 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-003 498	Building Q Classroom Q2	Manual	2/11/2025 8:40:22 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-006 499	Building Q Classroom Q3	Manual	2/11/2025 8:37:13 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-005 500	Building Q Classroom Q3	Manual	2/11/2025 8:37:47 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-008 501	Building Q Classroom Q4	Manual	2/11/2025 8:36:07 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-007 502	Building Q Classroom Q4	Manual	2/11/2025 8:36:26 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-009 504	Building Q Classroom Q5	Manual	2/11/2025 8:41:24 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-010 503	Building Q Classroom Q5	Manual	2/11/2025 8:44:33 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-015 505	Building Q Girls Restroom Q6	Manual	2/12/2025 6:38:58 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-011 506	Building Q Girls Restroom Q6	Manual	2/12/2025 6:39:00 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-014 507	Building Q Plumbing Chase Q7	Manual	2/12/2025 6:38:54 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	5-127 542	Building R Attic Office R1A	Manual	2/12/2025 8:05:09 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-127 543	Building R Attic Office R1A	Manual	2/12/2025 8:05:10 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	5-170 544	Building R Attic R1B2	Manual	2/12/2025 8:47:42 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-045 525	Building R Classroom R1	Manual	2/12/2025 6:08:06 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-044 522	Building R Classroom R1	Manual	2/12/2025 6:08:32 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-053 523	Building R Classroom R1	Manual	2/12/2025 6:09:04 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-054 524	Building R Classroom R1	Manual	2/12/2025 6:09:31 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-055 537	Building R Classroom R2	Manual	2/12/2025 6:17:55 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-058 534	Building R Classroom R2	Manual	2/12/2025 6:18:21 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-059 535	Building R Classroom R2	Manual	2/12/2025 6:18:54 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-056 538	Building R Classroom R2	Manual	2/12/2025 6:19:35 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-057 539	Building R Classroom R2	Manual	2/12/2025 6:20:17 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-060 536	Building R Classroom R2	Manual	2/12/2025 6:20:34 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-051 540	Building R Classroom R2 Hall	Manual	2/12/2025 6:10:20 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-047 541	Building R Classroom R2 Hall	Manual	2/12/2025 6:15:45 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-061 526	Building R O/S Rm R1 Storage	Manual	2/12/2025 6:22:12 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	5-042 527	Building R Office R1A	Manual	2/12/2025 6:14:20 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-046 529	Building R Office R1B2	Manual	2/12/2025 6:14:59 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-052 528	Building R Room R1B1 Storage	Manual	2/12/2025 6:10:43 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-043 531	Building R Room R1B3 Storage	Manual	2/12/2025 6:14:07 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-048 530	Building R Room R1B3 Storage	Manual	2/12/2025 6:16:25 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-049 532	Building R Room R1B4 Storage	Manual	2/12/2025 6:12:57 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-050 533	Building R Room R1B5 Storage	Manual	2/12/2025 6:11:34 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-384 631	Building S Attic Office S12	Manual	2/12/2025 6:37:09 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-421 629	Building S Attic Room S7	Manual	2/12/2025 8:12:18 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-421 630	Building S Attic Room S7	Manual	2/12/2025 8:14:11 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-383 632	Building S Attic Snack Stand Hall	Manual	2/12/2025 8:14:12 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-383 633	Building S Attic Snack Stand Hall	Manual	2/12/2025 8:14:14 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-382 628	Building S Attic Snack Stnd S1A	Manual	2/12/2025 8:14:15 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-268 584	Building S Boys Restroom S3	Manual	2/12/2025 6:39:07 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-269 583	Building S Boys Restroom S3	Manual	2/12/2025 6:40:24 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-378 557	Building S Cafeteria S1	Manual	2/12/2025 6:20:00 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Manual Pull Station	3-379 556	Building S Cafeteria S1	Manual	2/12/2025 6:20:42 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-380 558	Building S Cafeteria S1	Manual	2/12/2025 6:21:42 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-277 578	Building S Cafeteria S1	Manual	2/12/2025 5:32:21 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-278 567	Building S Cafeteria S1	Manual	2/12/2025 5:33:11 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-289 566	Building S Cafeteria S1	Manual	2/12/2025 5:33:39 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-288 565	Building S Cafeteria S1	Manual	2/12/2025 5:34:00 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-279 568	Building S Cafeteria S1	Manual	2/12/2025 5:34:24 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-276 577	Building S Cafeteria S1	Manual	2/12/2025 5:34:47 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-275 576	Building S Cafeteria S1	Manual	2/12/2025 5:35:11 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-280 569	Building S Cafeteria S1	Manual	2/12/2025 5:35:45 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-286 563	Building S Cafeteria S1	Manual	2/12/2025 5:36:59 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-281 570	Building S Cafeteria S1	Manual	2/12/2025 5:37:13 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-274 575	Building S Cafeteria S1	Manual	2/12/2025 5:38:09 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-273 574	Building S Cafeteria S1	Manual	2/12/2025 5:38:18 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-272 573	Building S Cafeteria S1	Manual	2/12/2025 5:38:48 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-283 572	Building S Cafeteria S1	Manual	2/12/2025 5:39:28 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-282 571	Building S Cafeteria S1	Manual	2/12/2025 5:40:05 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-285 562	Building S Cafeteria S1	Manual	2/12/2025 5:40:47 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-284 561	Building S Cafeteria S1	Manual	2/12/2025 5:41:18 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-287 564	Building S Cafeteria S1	Manual	2/12/2025 6:40:57 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-305 610	Building S Classrm S9 Storage	Manual	2/12/2025 5:31:04 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-304 609	Building S Classroom S9	Manual	2/12/2025 5:30:05 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-303 608	Building S Classroom S9	Manual	2/12/2025 5:30:25 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-302 607	Building S Classroom S9	Manual	2/12/2025 5:30:47 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-319 614	Building S Closet S11	Manual	2/12/2025 5:26:35 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-266 581	Building S Girls Restroom S2	Manual	2/12/2025 6:13:32 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-267 582	Building S Girls Restroom S2	Manual	2/12/2025 6:39:09 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-320 619	Building S Hall Storage S15	Manual	2/12/2025 5:29:14 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-294 604	Building S Kitchen RR S7D	Manual	2/12/2025 6:40:27 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-292 605	Building S Kitchen RR S7D1	Manual	2/12/2025 6:40:25 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-296 626	Building S Kitchen S7	Manual	2/12/2025 8:12:16 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-295 622	Building S Kitchen S7	Manual	2/12/2025 8:12:22 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	3-316 624	Building S Kitchen S7	Manual	2/12/2025 8:12:24 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-291 625	Building S Kitchen S7	Manual	2/12/2025 8:12:26 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-290 623	Building S Kitchen S7	Manual	2/12/2025 8:12:27 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-301 627	Building S Kitchen S7A	Manual	2/12/2025 6:41:17 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-300 600	Building S Kitchen Storage S5	Manual	2/12/2025 5:48:10 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-298 601	Building S Kitchen Storage S6	Manual	2/12/2025 5:47:35 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-385 602	Building S Kitchen Storage S7B	Manual	2/12/2025 6:37:47 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-297 603	Building S Kitchen Storage S7C	Manual	2/12/2025 5:44:03 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-293 606	Building S Kitchen Storage S8	Manual	2/12/2025 5:45:18 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-313 613	Building S Office S11	Manual	2/12/2025 5:26:18 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-312 615	Building S Office S12	Manual	2/12/2025 5:23:48 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-314 611	Building S Restroom S10	Manual	2/12/2025 5:28:39 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-315 612	Building S Restroom S10A	Manual	2/12/2025 5:28:48 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-258 590	Building S Room S4	Manual	2/12/2025 5:57:29 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-260 591	Building S Room S4	Manual	2/12/2025 5:57:49 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-259 592	Building S Room S4	Manual	2/12/2025 5:59:35 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-261 593	Building S Room S4	Manual	2/12/2025 5:59:51 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-262 594	Building S S4 Light Room	Manual	2/12/2025 6:00:54 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-263 595	Building S S4 Light Room	Manual	2/12/2025 6:01:27 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-257 585	Building S S4 Stage	Manual	2/12/2025 5:56:03 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-255 586	Building S S4 Stage	Manual	2/12/2025 6:40:23 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-254 598	Building S S4 Stage Strg S4C	Manual	2/12/2025 6:39:28 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-256 588	Building S S4 Theater	Manual	2/12/2025 5:56:27 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-252 589	Building S S4 Theater	Manual	2/12/2025 5:56:35 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-271 587	Building S S4 Theater	Manual	2/12/2025 6:00:13 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-253 599	Building S S4D Storage	Manual	2/12/2025 6:05:38 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-311 620	Building S Snack Stand Hall	Manual	2/12/2025 5:23:20 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-310 621	Building S Snack Stand Hall	Manual	2/12/2025 5:28:02 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-307 616	Building S Snack Stand S13	Manual	2/12/2025 5:24:48 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-306 579	Building S Snack Stand S1A	Manual	2/12/2025 5:25:26 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-308 617	Building S Snack Stnd Strg S14	Manual	2/12/2025 5:27:29 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-309 618	Building S Snack Stnd Strg S15	Manual	2/12/2025 5:28:16 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Mechanical, Electrosonic, or Pressure Waterflow Device	3-422 635	Building S Storage S1B	Manual	2/12/2025 5:51:03 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-251 580	Building S Storage S1B	Manual	2/12/2025 5:54:03 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Valve Tamper Switch	3-423 636	Building S Storage S1B	Manual	2/12/2025 7:28:54 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-265 596	Building S Storage S4A	Manual	2/12/2025 6:02:48 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-270 597	Building S Storage S4B	Manual	2/12/2025 6:03:08 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-377 560	Building S Theater S4	Manual	2/12/2025 5:58:22 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-376 559	Building S Theater S4	Manual	2/12/2025 6:03:59 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-420 634	Building S Theater S4	Manual	2/12/2025 8:08:55 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-383 774	Building T Attic Lrg Gym Fyr T1	Manual	2/12/2025 8:06:48 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-377 776	Building T Attic Rm T1F Storage	Manual	2/12/2025 8:06:45 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-386 777	Building T Attic Rm T3F2 Strg	Manual	2/12/2025 8:06:50 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-382 775	Building T Attic Snack Stand T1A	Manual	2/12/2025 8:06:47 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-391 778	Building T Attic Storage Rm T7	Manual	2/12/2025 8:06:41 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-263 694	Building T Classroom T3F	Manual	2/12/2025 6:12:30 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-265 696	Building T Classroom T3F	Manual	2/12/2025 6:13:06 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-266 697	Building T Classroom T3F	Manual	2/12/2025 6:13:27 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	5-264 695	Building T Classroom T3F	Manual	2/12/2025 7:01:09 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-291 749	Building T Dressing Room T2A	Manual	2/12/2025 8:07:28 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	5-437 779	Building T Girls Locker T3 East	Manual	2/12/2025 8:07:06 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	5-436 780	Building T Girls Locker T3 West	Manual	2/12/2025 8:07:05 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-261 701	Building T Girls Restroom T5A	Manual	2/12/2025 6:22:30 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	5-384 669	Building T Large Gym T1 Foyer	Manual	2/12/2025 6:37:06 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	5-385 670	Building T Large Gym T1 Foyer	Manual	2/12/2025 6:37:45 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-297 677	Building T Large Gym T1 Foyer	Manual	2/12/2025 6:37:31 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-298 678	Building T Large Gym T1 Foyer	Manual	2/12/2025 6:37:35 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-348 676	Building T Large Gym T1 Foyer	Manual	2/12/2025 6:40:35 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-299 679	Building T Large Gym T1 Foyer	Manual	2/12/2025 6:41:23 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	5-389 675	Building T Large Gym T6	Manual	2/12/2025 6:41:52 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	5-390 674	Building T Large Gym T6	Manual	2/12/2025 6:42:23 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	5-388 785	Building T Large Gym T6	Manual	2/12/2025 8:04:25 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	5-387 784	Building T Large Gym T6	Manual	2/12/2025 8:04:27 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-305 720	Building T Large Gym T6	Manual	2/12/2025 5:31:13 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	5-310 718	Building T Large Gym T6	Manual	2/12/2025 8:03:00 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-309 719	Building T Large Gym T6	Manual	2/12/2025 8:03:01 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-317 716	Building T Large Gym T6	Manual	2/12/2025 8:03:03 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-318 717	Building T Large Gym T6	Manual	2/12/2025 8:03:05 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-326 714	Building T Large Gym T6	Manual	2/12/2025 8:03:06 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-325 715	Building T Large Gym T6	Manual	2/12/2025 8:03:08 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-335 713	Building T Large Gym T6	Manual	2/12/2025 8:03:09 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-329 710	Building T Large Gym T6	Manual	2/12/2025 8:03:11 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-320 708	Building T Large Gym T6	Manual	2/12/2025 8:03:13 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-312 706	Building T Large Gym T6	Manual	2/12/2025 8:03:14 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-304 705	Building T Large Gym T6	Manual	2/12/2025 8:03:16 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-303 704	Building T Large Gym T6	Manual	2/12/2025 8:03:17 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-334 712	Building T Large Gym T6	Manual	2/12/2025 8:03:19 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-306 728	Building T Large Gym T6	Manual	2/12/2025 8:03:21 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-315 730	Building T Large Gym T6	Manual	2/12/2025 8:03:22 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-314 731	Building T Large Gym T6	Manual	2/12/2025 8:03:24 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	5-332 734	Building T Large Gym T6	Manual	2/12/2025 8:03:25 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-323 733	Building T Large Gym T6	Manual	2/12/2025 8:03:26 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-322 732	Building T Large Gym T6	Manual	2/12/2025 8:03:28 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-307 729	Building T Large Gym T6	Manual	2/12/2025 8:03:29 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-316 726	Building T Large Gym T6	Manual	2/12/2025 8:03:31 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-331 735	Building T Large Gym T6	Manual	2/12/2025 8:03:33 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-324 725	Building T Large Gym T6	Manual	2/12/2025 8:03:35 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-333 724	Building T Large Gym T6	Manual	2/12/2025 8:03:37 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-308 727	Building T Large Gym T6	Manual	2/12/2025 8:04:13 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-321 722	Building T Large Gym T6	Manual	2/12/2025 8:04:15 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-328 711	Building T Large Gym T6	Manual	2/12/2025 8:04:16 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-330 723	Building T Large Gym T6	Manual	2/12/2025 8:04:19 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-311 707	Building T Large Gym T6	Manual	2/12/2025 8:04:20 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-319 709	Building T Large Gym T6	Manual	2/12/2025 8:04:22 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-313 721	Building T Large Gym T6	Manual	2/12/2025 8:04:24 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-269 689	Building T Lckr Rm T2 Wtr Htr	Manual	2/12/2025 7:01:11 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	5-268 688	Building T Locker Rm T2 Strg	Manual	2/12/2025 6:26:06 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-290 750	Building T Locker Rm T2B Strg	Manual	2/12/2025 7:48:32 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-289 751	Building T Locker Rm T2C Strg	Manual	2/12/2025 7:48:33 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-288 752	Building T Locker Rm T2D Strg	Manual	2/12/2025 7:48:34 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-259 759	Building T Locker Rm T3 RR	Manual	2/12/2025 7:48:30 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-284 746	Building T Locker Room T2	Manual	2/12/2025 7:48:40 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-283 747	Building T Locker Room T2 RR	Manual	2/12/2025 7:48:38 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-281 748	Building T Locker Room T2A	Manual	2/12/2025 7:48:36 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-252 758	Building T Locker Room T3	Manual	2/12/2025 7:42:10 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-254 757	Building T Locker Room T3	Manual	2/12/2025 7:47:40 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-260 756	Building T Locker Room T3	Manual	2/12/2025 7:48:28 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-327 736	Building T Lrg Gym Booth T6	Manual	2/12/2025 6:40:37 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-301 685	Building T Lrg Gym RR T1G	Manual	2/12/2025 6:41:19 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-300 686	Building T Lrg Gym RR T1i	Manual	2/12/2025 6:41:13 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-293 682	Building T Office Hall T1C	Manual	2/12/2025 7:00:47 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-294 683	Building T Office T1C	Manual	2/12/2025 7:00:48 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	5-287 753	Building T Office T2E	Manual	2/12/2025 8:06:59 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-286 754	Building T Office T2E1	Manual	2/12/2025 8:06:57 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-256 770	Building T Office T3C	Manual	2/12/2025 8:06:55 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-257 772	Building T Office T3D	Manual	2/12/2025 8:06:22 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-346 703	Building T Restroom T5C	Manual	2/12/2025 6:23:36 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-295 681	Building T Room T1B Storage	Manual	2/12/2025 6:37:16 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-282 684	Building T Room T1D1 Storage	Manual	2/12/2025 6:36:57 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-302 687	Building T Room T1F Storage	Manual	2/12/2025 6:41:29 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-292 690	Building T Room T21E Storage	Manual	2/12/2025 6:37:24 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-285 755	Building T Room T2F Storage	Manual	2/12/2025 8:06:51 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-251 691	Building T Room T3A Storage	Manual	2/12/2025 6:06:55 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-253 692	Building T Room T3B Storage	Manual	2/12/2025 6:05:40 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-255 771	Building T Room T3C1 Storage	Manual	2/12/2025 8:06:54 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-258 773	Building T Room T3E Storage	Manual	2/12/2025 8:06:20 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	5-438 781	Building T Room T3F	Manual	2/12/2025 8:07:00 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-270 693	Building T Room T3F Foyer	Manual	2/12/2025 6:15:15 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	5-262 698	Building T Room T3F1 Storage	Manual	2/12/2025 6:14:47 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-267 699	Building T Room T3F2 Storage	Manual	2/12/2025 7:01:10 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-345 700	Building T Room T4 Storage	Manual	2/12/2025 6:05:06 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-338 744	Building T Room T7A1 Storage	Manual	2/12/2025 7:01:07 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-376 760	Building T Shower Room T3A	Manual	2/12/2025 7:43:47 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-376 761	Building T Shower Room T3A	Manual	2/12/2025 7:43:49 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-376 762	Building T Shower Room T3A	Manual	2/12/2025 7:43:50 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-376 764	Building T Shower Room T3A	Manual	2/12/2025 7:43:52 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-376 763	Building T Shower Room T3A	Manual	2/12/2025 7:43:53 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-376 765	Building T Shower Room T3A	Manual	2/12/2025 7:43:55 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-376 766	Building T Shower Room T3A	Manual	2/12/2025 7:43:56 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-376 767	Building T Shower Room T3A	Manual	2/12/2025 7:43:59 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-376 768	Building T Shower Room T3A	Manual	2/12/2025 7:44:01 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-376 769	Building T Shower Room T3A	Manual	2/12/2025 7:44:03 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	5-381 745	Building T Shwer Rm T1D1 Strg	Manual	2/12/2025 8:07:26 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	5-379 672	Building T Small Gym T5	Manual	2/12/2025 6:20:40 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Manual Pull Station	5-380 673	Building T Small Gym T5	Manual	2/12/2025 6:21:38 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	5-378 671	Building T Small Gym T5	Manual	2/12/2025 8:06:53 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Projected Beam	5-430 787	Building T Small Gym T5	Manual	2/12/2025 6:18:58 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Projected Beam	5-428 788	Building T Small Gym T5	Manual	2/12/2025 6:19:06 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Projected Beam	5-432 786	Building T Small Gym T5	Manual	2/12/2025 6:19:28 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	5-435 782	Building T Small Gym T5 East	Manual	2/12/2025 8:07:02 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	5-434 783	Building T Small Gym T5 West	Manual	2/12/2025 8:07:03 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-296 680	Building T Snack Stand T1A	Manual	2/12/2025 7:00:53 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-347 702	Building T Storage T5B	Manual	2/12/2025 6:23:17 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-337 743	Building T Weight Rm T7A Off	Manual	2/12/2025 7:00:57 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-344 737	Building T Weight Room T7	Manual	2/12/2025 7:00:54 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-336 742	Building T Weight Room T7	Manual	2/12/2025 7:00:59 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-339 741	Building T Weight Room T7	Manual	2/12/2025 7:01:01 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-340 740	Building T Weight Room T7	Manual	2/12/2025 7:01:02 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-341 739	Building T Weight Room T7	Manual	2/12/2025 7:01:04 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	5-343 738	Building T Weight Room T7	Manual	2/12/2025 7:01:05 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Manual Pull Station	4-185 835	Encina SW Area Admin Office	Manual	2/12/2025 5:32:45 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-192 883	Encina SW Area Attic Classroom 1	Manual	2/12/2025 8:18:32 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-192 882	Encina SW Area Attic Classroom 1	Manual	2/12/2025 8:18:34 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-191 885	Encina SW Area Attic Classroom 2	Manual	2/12/2025 8:14:24 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-191 884	Encina SW Area Attic Classroom 2	Manual	2/12/2025 8:14:26 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-175 887	Encina SW Area Attic Classroom 3	Manual	2/12/2025 8:02:47 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-175 886	Encina SW Area Attic Classroom 3	Manual	2/12/2025 8:02:48 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-176 888	Encina SW Area Attic Classroom 4	Manual	2/12/2025 8:07:46 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-176 889	Encina SW Area Attic Classroom 4	Manual	2/12/2025 8:07:48 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-186 898	Encina SW Area Attic Daycare 1	Manual	2/12/2025 8:33:37 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-186 897	Encina SW Area Attic Daycare 1	Manual	2/12/2025 8:33:40 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-186 896	Encina SW Area Attic Daycare 1	Manual	2/12/2025 8:33:41 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-186 895	Encina SW Area Attic Daycare 1	Manual	2/12/2025 8:33:42 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-188 900	Encina SW Area Attic Daycare 2	Manual	2/12/2025 8:40:29 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-188 901	Encina SW Area Attic Daycare 2	Manual	2/12/2025 8:40:30 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-188 902	Encina SW Area Attic Daycare 2	Manual	2/12/2025 8:40:32 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	4-188 899	Encina SW Area Attic Daycare 2	Manual	2/12/2025 8:40:34 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-165 903	Encina SW Area Attic ECE P1	Manual	2/12/2025 7:55:04 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-165 904	Encina SW Area Attic ECE P1	Manual	2/12/2025 7:55:06 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-165 905	Encina SW Area Attic ECE P1	Manual	2/12/2025 7:55:09 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-193 906	Encina SW Area Attic ECE P2	Manual	2/12/2025 7:50:24 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-193 907	Encina SW Area Attic ECE P2	Manual	2/12/2025 7:50:27 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-193 908	Encina SW Area Attic ECE P2	Manual	2/12/2025 7:50:29 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-182 890	Encina SW Area Attic Office	Manual	2/12/2025 8:25:37 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-183 891	Encina SW Area Attic Office	Manual	2/12/2025 8:35:18 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-184 892	Encina SW Area Attic Office	Manual	2/12/2025 8:35:19 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-179 893	Encina SW Area Attic Office Storage	Manual	2/12/2025 8:08:38 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-187 894	Encina SW Area Attic Staff Room	Manual	2/12/2025 8:08:39 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-073 847	Encina SW Area Back Office	Manual	2/12/2025 5:34:35 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-084 860	Encina SW Area Changing Room	Manual	2/12/2025 5:21:25 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-099 837	Encina SW Area Classroom 1	Manual	2/12/2025 5:38:56 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-098 838	Encina SW Area Classroom 1	Manual	2/12/2025 5:39:37 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	4-097 839	Encina SW Area Classroom 2	Manual	2/12/2025 5:37:34 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-096 840	Encina SW Area Classroom 2	Manual	2/12/2025 5:37:58 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-065 841	Encina SW Area Classroom 3	Manual	2/12/2025 5:15:19 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-064 842	Encina SW Area Classroom 3	Manual	2/12/2025 5:15:45 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-067 843	Encina SW Area Classroom 4	Manual	2/12/2025 5:16:49 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-066 844	Encina SW Area Classroom 4	Manual	2/12/2025 5:16:53 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-075 858	Encina SW Area Daycare 1	Manual	2/12/2025 5:20:42 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-081 859	Encina SW Area Daycare 1	Manual	2/12/2025 5:20:52 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-113 856	Encina SW Area Daycare 1	Manual	2/12/2025 5:21:55 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-074 857	Encina SW Area Daycare 1	Manual	2/12/2025 5:23:53 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-092 863	Encina SW Area Daycare 1 Laundry	Manual	2/12/2025 6:40:29 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-080 862	Encina SW Area Daycare 1 Office	Manual	2/12/2025 5:20:54 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-079 861	Encina SW Area Daycare 1 Storage	Manual	2/12/2025 5:23:08 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	4.177 836	Encina SW Area Daycare 2	Manual	2/12/2025 5:25:49 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-090 866	Encina SW Area Daycare 2	Manual	2/12/2025 5:18:52 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-088 864	Encina SW Area Daycare 2	Manual	2/12/2025 5:19:10 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	4-087 867	Encina SW Area Daycare 2	Manual	2/12/2025 5:19:26 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-091 865	Encina SW Area Daycare 2	Manual	2/12/2025 5:20:02 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-085 881	Encina SW Area Daycare Kitchen	Manual	2/12/2025 8:08:42 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-107 872	Encina SW Area ECE P1	Manual	2/12/2025 5:48:01 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-109 873	Encina SW Area ECE P1	Manual	2/12/2025 5:48:26 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-108 870	Encina SW Area ECE P1	Manual	2/12/2025 5:48:47 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-110 871	Encina SW Area ECE P1	Manual	2/12/2025 5:49:12 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-102 877	Encina SW Area ECE P2	Manual	2/12/2025 5:43:46 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-103 874	Encina SW Area ECE P2	Manual	2/12/2025 5:44:10 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-100 876	Encina SW Area ECE P2	Manual	2/12/2025 5:44:25 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-101 875	Encina SW Area ECE P2	Manual	2/12/2025 5:44:48 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-105 878	Encina SW Area ECE P2 Hall	Manual	2/12/2025 5:45:37 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-106 879	Encina SW Area ECE Restroom	Manual	2/12/2025 5:45:47 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-104 880	Encina SW Area ECE Restroom	Manual	2/12/2025 5:46:12 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-071 846	Encina SW Area Front Office	Manual	2/12/2025 5:33:16 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-086 868	Encina SW Area Nap Room	Manual	2/12/2025 5:25:16 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	4-089 869	Encina SW Area Nap Room	Manual	2/12/2025 5:25:40 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-070 848	Encina SW Area Office Kitchen	Manual	2/12/2025 6:39:18 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-069 849	Encina SW Area Office Restroom	Manual	2/12/2025 5:29:06 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-068 850	Encina SW Area Office Storage	Manual	2/12/2025 5:30:13 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-072 845	Encina SW Area Reception	Manual	2/12/2025 5:31:25 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-077 855	Encina SW Area Staff Restroom	Manual	2/12/2025 5:22:10 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-082 852	Encina SW Area Staff Room	Manual	2/12/2025 5:22:42 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-076 851	Encina SW Area Staff Room	Manual	2/12/2025 6:39:14 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-083 853	Encina SW Area Staff Room	Manual	2/12/2025 6:39:16 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-078 854	Encina SW Area Staff Room Storage	Manual	2/12/2025 6:40:30 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-008	Office A1B	Manual	2/12/2025 5:17:25 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-004	Office A3	Manual	2/12/2025 5:14:47 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-131 042	Building A Attic Office A1	Manual	2/12/2025 8:57:05 PM
Heat Detector - Restorable Spot	2-129 044	Building A Attic Office A1B	Manual	2/12/2025 8:57:03 PM
Heat Detector - Restorable Spot	2-133 045	Building A Attic Office A1D	Manual	2/12/2025 8:56:52 PM
Heat Detector - Restorable Spot	2-128 049	Building A Attic Office A3	Manual	2/12/2025 8:57:00 PM
Smoke Detector - Duct	2-142 057	Building A Attic Office A8	Manual	2/12/2025 8:09:51 PM
Heat Detector - Restorable Spot	3-195 230	Building F Attic Classroom F6	Manual	2/12/2025 7:18:04 PM
Smoke Detector - General	3-040 208	Building F Storage F1A	Manual	2/12/2025 6:44:23 PM

Comment: No access

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	4-376 430	Building N Attic N7 Plumb Chase	Manual	2/12/2025 8:08:28 PM
Heat Detector - Restorable Spot	4-195 909	Encina SW Area Attic ECE P2 Hall	Manual	2/12/2025 8:47:29 PM
Heat Detector - Restorable Spot	4-195 911	Encina SW Area Attic ECE P2 Hall	Manual	2/12/2025 8:47:31 PM
Heat Detector - Restorable Spot	4-195 910	Encina SW Area Attic ECE P2 Hall	Manual	2/12/2025 8:47:36 PM

Device/Equipment Details

[Other]

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3-381 789	Building T Ansil Sys Kitchen S7				

Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Visible					
552	Building R Room R1B3 Storage				
553	Building R Room R1B4 Storage				
554	Building R Room R1B5 Storage				
555	Building R Classroom R2				
648	Building S Cafeteria S1				
649	Building S Cafeteria S1				
650	Building S Cafeteria S1				
651	Building S Cafeteria S1				
652	Building S Snack Stand S1A				
653	Building S Girls Restroom S2				
654	Building S Boys Restroom S3				
655	Building S S4 Stage				
656	Building S S4 Light Room				
657	Building S S4 Stage Strg S4C				
658	Building S S4D Storage				
659	Building S Kitchen S7				
660	Building S Kitchen RR S7D				
661	Building S Kitchen RR S7D1				
662	Building S Restroom S10				
663	Building S Restroom S10A				
664	Building S Office S11				
665	Building S Office S12				
666	Building S Snack Stand S13				
811	Building T Large Gym T1 Foyer				
812	Building T Room T1D				
813	Building T Lrg Gym RR T1G				
814	Building T Lrg Gym RR T1i				
815	Building T Locker Room T2				
816	Building T Locker Room T2				
817	Building T Locker Room T2				
818	Building T Dressing Room T2A				
819	Building T Office T2E				
820	Building T Office T2E1				
821	Building T Locker Room T3				
822	Building T Locker Room T3				
823	Building T Locker Room T3				
824	Building T Locker Room T3				
825	Building T Room T3B Storage				
826	Building T Office T3C				
827	Building T Room T3C1 Storage				
828	Building T Small Gym T5				
829	Building T Small Gym T5				
830	Building T Weight Room T7				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
831	Building T Weight Rm T7A Off				
926	Encina SW Area Front Office				
927	Encina SW Area Back Office				
928	Encina SW Area Office Kitchen				
929	Encina SW Area Office Restroom				
930	Encina SW Area Staff Room				
931	Encina SW Area Staff Restroom				
932	Encina SW Area Daycare 1				
933	Encina SW Area Changing Room				
934	Encina SW Area Daycare 1 Office				
935	Encina SW Area Daycare Kitchen				
936	Encina SW Area Nap Room				
937	Encina SW Area ECE Restroom				
938	Encina SW Area ECE Restroom				
068	Building A Office A1A				
069	Building A Office A1B				
070	Building A Office A1C				
071	Building A Office A1D				
072	Building A Office A1E				
073	Building A Office A2A				
074	Building A Office A2D				
075	Building A Office A2D Hall				
076	Building A Office A2E				
077	Building A Office A3				
078	Building A Restroom A4				
079	Building A Restroom A4				
080	Building A Office A5				
081	Building A Restroom A7				
082	Building A Office A8A				
083	Building A Office Restroom A8A				
084	Building A Office A9B				
085	Building A Office A9C				
086	Building A Office A9D				
087	Building A Main Hallway				
088	Building A Main Hallway				
112	Building B Library B1				
113	Building B Library B1				
114	Building B Library B1				
195	Building E Hall Next to Rm E2				
196	Building E Dental Room 1				
197	Building E Dental Room 2				
198	Building E Dental Room 3				
239	Building F Classroom F4				
240	Building F Classroom F5				
287	Building G Art Room G1				
288	Building G Art Room G1				
289	Building G Art Room G2				
290	Building G Medical Room G3				
316	Building H Classroom H2				
317	Building H Classroom H3				
318	Building H Restroom H4				
319	Building H Restroom H6				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
407	Building L Restroom L6				
408	Building L Restroom L8				
439	Building N Restroom N6				
440	Building N Restroom N8				
519	Building Q Girls Restroom Q6				
520	Building Q Boys Restroom Q8				
549	Building R Office R1A				
550	Building R Room R1B1 Storage				
551	Building R Office R1B2				
Audible					
637	Building S North Exterior				
638	Building S North Exterior				
639	Building S North Exterior				
640	Building S South Exterior				
667	Building S South Exterior				
790	Building T East Exterior				
791	Building T East Exterior				
792	Building T East Exterior				
793	Building T South Exterior				
794	Building T West Exterior				
795	Building T West Exterior				
796	Building T West Exterior				
912	Encina SW Area North Exterior				
913	Encina SW Area North Exterior				
914	Encina SW Area North Exterior				
915	Encina SW Area East Exterior				
109	Building B South Exterior				
127	Building C North Exterior				
128	Building C North Exterior				
129	Building C North Exterior				
146	Building D South Exterior				
147	Building D South Exterior				
148	Building D South Exterior				
188	Building E North Exterior				
189	Building E North Exterior				
231	Building F South Exterior				
232	Building F South Exterior				
281	Building G South Exterior				
282	Building G South Exterior				
311	Building H South Exterior				
312	Building H South Exterior				
338	Building I South Exterior				
354	Building J North Exterior				
355	Building J North Exterior				
356	Building J North Exterior				
380	Building K North Exterior				
399	Building L South Exterior				
400	Building L South Exterior				
401	Building L South Exterior				
431	Building N North Exterior				
432	Building N North Exterior				
433	Building N North Exterior				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
454	Building O South Exterior				
455	Building O South Exterior				
456	Building O South Exterior				
488	Building P Outside Classrm P1				
489	Building P Outside Classrm P5				
511	Building Q North Exterior				
512	Building Q North Exterior				
513	Building Q North Exterior				
545	Building R East Exterior				
Audible And Visible					
641	Building S Cafeteria S1				
642	Building S Cafeteria S1				
643	Building S Theater S4				
644	Building S Kitchen S7				
645	Building S Kitchen S7				
646	Building S Classroom S9				
647	Building S Snack Stand Hall				
797	Building T Large Gym T1 Foyer				
798	Building T Large Gym T1 Foyer				
799	Building T Locker Room T2				
800	Building T Locker Room T2				
801	Building T Locker Room T3				
802	Building T Locker Room T3				
803	Building T Classroom T3F				
804	Building T Small Gym T5				
805	Building T Small Gym T5				
806	Building T Large Gym T6				
807	Building T Large Gym T6				
808	Building T Large Gym T6				
809	Building T Large Gym T6				
810	Building T Weight Room T7				
916	Encina SW Area Classroom 1				
917	Encina SW Area Classroom 2				
918	Encina SW Area Classroom 3				
919	Encina SW Area Classroom 4				
920	Encina SW Area Admin Office				
921	Encina SW Area Staff Room				
922	Encina SW Area Daycare 1				
923	Encina SW Area Daycare 2				
924	Encina SW Area ECE P1				
925	Encina SW Area ECE P2				
059	Building A Office A1				
060	Building A Office A2				
061	Building A Office A2B				
062	Building A Front Office A3				
063	Building A Office A2D Hall				
064	Building A Office A8				
065	Building A Staff Room A9				
066	Building A Main Hallway				
067	Building A Main Hallway				
110	Building B Library B1				
111	Building B Classroom B2				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
130	Building C Classroom C1				
131	Building C Classroom C2				
132	Building C Classroom C3				
133	Building C Classroom C4				
134	Building C Classroom C5				
135	Building C Classroom C6				
149	Building D Classroom D1				
150	Building D Classroom D2				
151	Building D Classroom D3				
152	Building D Classroom D4				
153	Building D Classroom D5				
190	Building E Classroom E1				
191	Building E Classroom E2				
192	Building E Hall by Classrm E2				
193	Building E Classroom E3				
194	Building E Classroom E4				
233	Building F Custodial Office F1				
234	Building F Custodial Office F1				
235	Building F Classroom F2				
236	Building F Classroom F2C				
237	Building F Classroom F3				
238	Building F Classroom F6				
283	Building G Art Room G1				
284	Building G Art Room G1				
285	Building G Art Room G2				
286	Building G Medical Room G3				
313	Building H Classroom H1				
314	Building H Classroom H2				
315	Building H Classroom H3				
339	Building I Classroom i1				
340	Building I Classroom i2				
357	Building J Classroom J1				
358	Building J Classroom J2				
359	Building J Classroom J3				
360	Building J Classroom J4				
361	Building J Classroom J5				
381	Building K Classroom K1				
382	Building K Classroom K2				
402	Building L Classroom L1				
403	Building L Classroom L2				
404	Building L Classroom L3				
405	Building L Classroom L4				
406	Building L Classroom L5				
434	Building N Classroom N1				
435	Building N Classroom N2				
436	Building N Classroom N3				
437	Building N Classroom N4				
438	Building N Classroom N5				
457	Building O Classroom O-1				
458	Building O Classroom O-2				
459	Building O Classroom O-3				
460	Building O Classroom O-4				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
461	Building O Classroom O-5				
462	Building O Classroom O-6				
490	Building P Classroom P1				
491	Building P Classroom P2				
492	Building P Classroom P3				
493	Building P Classroom P4				
494	Building P Classroom P5				
514	Building Q Classroom Q1				
515	Building Q Classroom Q2				
516	Building Q Classroom Q3				
517	Building Q Classroom Q4				
518	Building Q Classroom Q5				
546	Building R Classroom R1				
547	Building R Classroom R2				
548	Building R Classroom R2 Hall				

Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
NAC Power Extender Panel					
668	Building S Storage S1B				
832	Building T Room T3A Storage				
833	Building T Electrical Room T1E				
834	Building T Room T1F Storage				
939	Encina Portables SW Area Office				
089	Building A Room A12/Headend				
090	Building A Room A12/Headend				
320	Building H Room H5 Storage				
321	Building H Room H5 Storage				
409	Building L Room L7 Storage				
410	Building L Room L7 Storage				
441	Building N Room N7 Storage				
521	Building Q Room Q7 Storage				
Remote Annunciator					
001	Building A Front Office A3				
Fire Alarm Panel					
	Build A Room A12 Headend	Notifier	NFS-3030		04/02/2020

Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Manual Pull Station					
3-379 556	Building S Cafeteria S1				
3-378 557	Building S Cafeteria S1				
3-380 558	Building S Cafeteria S1				
3-376 559	Building S Theater S4				
3-377 560	Building S Theater S4				
5-384 669	Building T Large Gym T1 Foyer				
5-385 670	Building T Large Gym T1 Foyer				
5-378 671	Building T Small Gym T5				
5-379 672	Building T Small Gym T5				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
5-380 673	Building T Small Gym T5				
5-390 674	Building T Large Gym T6				
5-389 675	Building T Large Gym T6				
4-185 835	Encina SW Area Admin Office				
4.177 836	Encina SW Area Daycare 2				
2-190 002	Building A Front Office A3				
Smoke Detector - General					
3-284 561	Building S Cafeteria S1				
3-285 562	Building S Cafeteria S1				
3-286 563	Building S Cafeteria S1				
3-287 564	Building S Cafeteria S1				
3-288 565	Building S Cafeteria S1				
3-289 566	Building S Cafeteria S1				
3-278 567	Building S Cafeteria S1				
3-279 568	Building S Cafeteria S1				
3-280 569	Building S Cafeteria S1				
3-281 570	Building S Cafeteria S1				
3-282 571	Building S Cafeteria S1				
3-283 572	Building S Cafeteria S1				
3-272 573	Building S Cafeteria S1				
3-273 574	Building S Cafeteria S1				
3-274 575	Building S Cafeteria S1				
3-275 576	Building S Cafeteria S1				
3-276 577	Building S Cafeteria S1				
3-277 578	Building S Cafeteria S1				
3-306 579	Building S Snack Stand S1A				
3-251 580	Building S Storage S1B				
3-266 581	Building S Girls Restroom S2				
3-267 582	Building S Girls Restroom S2				
3-269 583	Building S Boys Restroom S3				
3-268 584	Building S Boys Restroom S3				
3-257 585	Building S S4 Stage				
3-255 586	Building S S4 Stage				
3-271 587	Building S S4 Theater				
3-256 588	Building S S4 Theater				
3-252 589	Building S S4 Theater				
3-258 590	Building S Room S4				
3-260 591	Building S Room S4				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3-259 592	Building S Room S4				
3-261 593	Building S Room S4				
3-262 594	Building S S4 Light Room				
3-263 595	Building S S4 Light Room				
2-265 596	Building S Storage S4A				
3-270 597	Building S Storage S4B				
3-254 598	Building S S4 Stage Strg S4C				
3-253 599	Building S S4D Storage				
3-300 600	Building S Kitchen Storage S5				
3-298 601	Building S Kitchen Storage S6				
3-385 602	Building S Kitchen Storage S7B				
3-297 603	Building S Kitchen Storage S7C				
3-294 604	Building S Kitchen RR S7D				
3-292 605	Building S Kitchen RR S7D1				
3-293 606	Building S Kitchen Storage S8				
3-302 607	Building S Classroom S9				
3-303 608	Building S Classroom S9				
3-304 609	Building S Classroom S9				
3-305 610	Building S Classrm S9 Storage				
3-314 611	Building S Restroom S10				
3-315 612	Building S Restroom S10A				
3-313 613	Building S Office S11				
3-319 614	Building S Closet S11				
3-312 615	Building S Office S12				
3-307 616	Building S Snack Stand S13				
3-308 617	Building S Snack Stnd Strg S14				
3-309 618	Building S Snack Stnd Strg S15				
3-320 619	Building S Hall Storage S15				
3-311 620	Building S Snack Stand Hall				
3-310 621	Building S Snack Stand Hall				
5-348 676	Building T Large Gym T1 Foyer				
5-297 677	Building T Large Gym T1 Foyer				
5-298 678	Building T Large Gym T1 Foyer				
5-299 679	Building T Large Gym T1 Foyer				
5-296 680	Building T Snack Stand T1A				
5-295 681	Building T Room T1B Storage				
5-293 682	Building T Office Hall T1C				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
5-294 683	Building T Office T1C				
5-282 684	Building T Room T1D1 Storage				
5-301 685	Building T Lrg Gym RR T1G				
5-300 686	Building T Lrg Gym RR T1i				
5-302 687	Building T Room T1F Storage				
5-268 688	Building T Locker Rm T2 Strg				
5-269 689	Building T Lckr Rm T2 Wtr Htr				
5-292 690	Building T Room T21E Storage				
5-251 691	Building T Room T3A Storage				
5-253 692	Building T Room T3B Storage				
5-270 693	Building T Room T3F Foyer				
5-263 694	Building T Classroom T3F				
5-264 695	Building T Classroom T3F				
5-265 696	Building T Classroom T3F				
5-266 697	Building T Classroom T3F				
5-262 698	Building T Room T3F1 Storage				
5-267 699	Building T Room T3F2 Storage				
5-345 700	Building T Room T4 Storage				
5-261 701	Building T Girls Restroom T5A				
5-347 702	Building T Storage T5B				
5-346 703	Building T Restroom T5C				
5-303 704	Building T Large Gym T6				
5-304 705	Building T Large Gym T6				
5-312 706	Building T Large Gym T6				
5-311 707	Building T Large Gym T6				
5-320 708	Building T Large Gym T6				
5-319 709	Building T Large Gym T6				
5-329 710	Building T Large Gym T6				
5-328 711	Building T Large Gym T6				
5-334 712	Building T Large Gym T6				
5-335 713	Building T Large Gym T6				
5-326 714	Building T Large Gym T6				
5-325 715	Building T Large Gym T6				
5-317 716	Building T Large Gym T6				
5-318 717	Building T Large Gym T6				
5-310 718	Building T Large Gym T6				
5-309 719	Building T Large Gym T6				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
5-305 720	Building T Large Gym T6				
5-313 721	Building T Large Gym T6				
5-321 722	Building T Large Gym T6				
5-330 723	Building T Large Gym T6				
5-333 724	Building T Large Gym T6				
5-324 725	Building T Large Gym T6				
5-316 726	Building T Large Gym T6				
5-308 727	Building T Large Gym T6				
5-306 728	Building T Large Gym T6				
5-307 729	Building T Large Gym T6				
5-315 730	Building T Large Gym T6				
5-314 731	Building T Large Gym T6				
5-322 732	Building T Large Gym T6				
5-323 733	Building T Large Gym T6				
5-332 734	Building T Large Gym T6				
5-331 735	Building T Large Gym T6				
5-327 736	Building T Lrg Gym Booth T6				
5-344 737	Building T Weight Room T7				
5-343 738	Building T Weight Room T7				
5-341 739	Building T Weight Room T7				
5-340 740	Building T Weight Room T7				
5-339 741	Building T Weight Room T7				
5-336 742	Building T Weight Room T7				
5-337 743	Building T Weight Rm T7A Off				
5-338 744	Building T Room T7A1 Storage				
4-099 837	Encina SW Area Classroom 1				
4-098 838	Encina SW Area Classroom 1				
4-097 839	Encina SW Area Classroom 2				
4-096 840	Encina SW Area Classroom 2				
4-065 841	Encina SW Area Classroom 3				
4-064 842	Encina SW Area Classroom 3				
4-067 843	Encina SW Area Classroom 4				
4-066 844	Encina SW Area Classroom 4				
4-072 845	Encina SW Area Reception				
4-071 846	Encina SW Area Front Office				
4-073 847	Encina SW Area Back Office				
4-070 848	Encina SW Area Office Kitchen				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
4-069 849	Encina SW Area Office Restroom				
4-068 850	Encina SW Area Office Storage				
4-076 851	Encina SW Area Staff Room				
4-082 852	Encina SW Area Staff Room				
4-083 853	Encina SW Area Staff Room				
4-078 854	Encina SW Area Staff Room Storage				
4-077 855	Encina SW Area Staff Restroom				
4-113 856	Encina SW Area Daycare 1				
4-074 857	Encina SW Area Daycare 1				
4-075 858	Encina SW Area Daycare 1				
4-081 859	Encina SW Area Daycare 1				
2-084 860	Encina SW Area Changing Room				
4-079 861	Encina SW Area Daycare 1 Storage				
4-080 862	Encina SW Area Daycare 1 Office				
4-092 863	Encina SW Area Daycare 1 Laundry				
4-088 864	Encina SW Area Daycare 2				
4-091 865	Encina SW Area Daycare 2				
4-090 866	Encina SW Area Daycare 2				
4-087 867	Encina SW Area Daycare 2				
4-086 868	Encina SW Area Nap Room				
4-089 869	Encina SW Area Nap Room				
4-108 870	Encina SW Area ECE P1				
4-110 871	Encina SW Area ECE P1				
4-107 872	Encina SW Area ECE P1				
4-109 873	Encina SW Area ECE P1				
4-103 874	Encina SW Area ECE P2				
4-101 875	Encina SW Area ECE P2				
4-100 876	Encina SW Area ECE P2				
4-102 877	Encina SW Area ECE P2				
4-105 878	Encina SW Area ECE P2 Hall				
4-106 879	Encina SW Area ECE Restroom				
4-104 880	Encina SW Area ECE Restroom				
2-009 003	Building A Office A1				
2-007 004	Building A Office A1 Closet				
2-010 005	Building A Office A1A				
2-008 006	Building A Office A1B				
2-012 007	Building A Office A1C				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-011 008	Building A Office A1D				
2-111 009	Building A Office A1E				
2-013 010	Building A Office A2				
2-005 011	Building A A2A Storage				
2-016 012	Building A Office A2B				
2-023 013	Building A Office A2B				
2-024 014	Building A Office A2B1				
2-018 015	Building A Office A2D				
2-017 016	Building A Office A2D Hall				
2-014 017	Building A Office A2E				
2-015 018	Building A A2E Hall				
2-006 019	Building A Office A3				
2-004 020	Building A Office A3				
2-020 021	Building A Restroom A4				
2-019 022	Building A Restroom A4				
2-021 023	Building A Office A5				
2-027 024	Building A Storage A6				
2-025 025	Building A Restroom A7				
2-028 026	Building A Office A8				
2-029 027	Building A Office A8 Hall				
2-033 028	Building A Office A8A				
2-032 029	Building A Office Restroom A8A				
2-034 030	Building A Office A8A1				
2-038 031	Building A Staff Room A9				
2-031 032	Building A Hall A9A				
2-030 033	Building A A9A Storage				
2-037 034	Building A Office A9B				
2-036 035	Building A Office A9C				
2-035 036	Building A Office A9D				
2-003 037	Building A Admin Hall by A3				
2-022 038	Building A Admin Hall by A5				
2-026 039	Building A Admin Hall by A6 Strg				
2-039 040	Building A Admin Hall by A9				
2-002 041	Building A Room A12/Headend				
2-261 091	Building B Library B1				
2-260 092	Building B Library B1				
2-259 093	Building B Library B1				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-258 094	Building B Library B1				
2-257 095	Building B Library B1				
2-256 096	Building B Library B1				
2-255 097	Building B Library B1				
2-254 098	Building B Library B1				
2-267 099	Building B Library B1				
2-266 100	Building B Office B1A				
2-253 101	Building B Office B1B				
2-251 102	Building B Classroom B2				
2-252 103	Building B Classroom B2				
2-281 115	Building C Classroom C1				
2-280 116	Building C Classroom C1				
2-279 117	Building C Classroom C2				
2-278 118	Building C Classroom C2				
2-276 119	Building C Classroom C3				
2-277 120	Building C Classroom C3				
2-274 121	Building C Classroom C4				
2-275 122	Building C Classroom C4				
2-272 123	Building C Classroom C5				
2-273 124	Building C Classroom C5				
2-270 125	Building C Classroom C6				
2-271 126	Building C Classroom C6				
2-291 136	Building D Classroom D1				
2-290 137	Building D Classroom D1				
2-288 138	Building D Classroom D2				
2-289 139	Building D Classroom D2				
2-286 140	Building D Classroom D3				
2-287 141	Building D Classroom D3				
2-284 142	Building D Classroom D4				
2-285 143	Building D Classroom D4				
2-283 144	Building D Classroom D5				
2-282 145	Building D Classroom D5				
3-024 154	Building E Classroom E1				
3-025 155	Building E Classroom E1				
3-030 156	Building E Classroom E1				
3-029 157	Building E Classroom E1				
3-031 158	Building E Storage by Room E1				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3-011 159	Building E Classroom E2				
3-016 160	Building E Classroom E2				
3-017 161	Building E Classroom E2				
3-012 162	Building E Classroom E2				
3-013 163	Building E Classroom E2				
3-018 164	Building E Classroom E2				
3-022 165	Building E Hall Next to Rm E2				
3-019 166	Building E Storage by Room E2				
3-032 167	Building E Storage by Room E2				
3-023 168	Building E Dental Room 1				
3-026 169	Building E Dental Room 2				
3-028 170	Building E Dental Room 3				
3-027 171	Building E Hall by Classrm E2				
3-021 172	Building E Doorway by Rm E2				
3-015 173	Building E Classroom E3				
3-014 174	Building E Classroom E3				
3-009 175	Building E Classroom E3				
3-010 176	Building E Classroom E3				
3-008 177	Building E Classroom E3 Closet				
3-005 178	Building E Storage E3A				
3-004 179	Building E Storage E3A				
3-003 180	Building E Storage E3A				
3-001 181	Building E Classroom E4				
3-002 182	Building E Classroom E4				
3-007 183	Building E Classroom E4				
3-006 184	Building E Classroom E4				
3-040 208	Building F Storage F1A				
3-041 209	Building F Storage F1B				
3-037 210	Building F Classroom F2				
3-036 211	Building F Classroom F2				
3-054 212	Building F Classroom F2				
3-053 213	Building F Classroom F2				
3-052 214	Building F Classroom F2				
3-039 215	Building F Storage F2A				
3-038 216	Building F Storage F2B				
3-051 217	Building F Classroom F2C				
3-035 218	Building F Classroom F3				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3-034 219	Building F Classroom F3				
3-033 220	Building F Classroom F3				
3-056 221	Building F Classroom F3				
3-055 222	Building F Classroom F3				
3-063 223	Building F Classroom F4				
3-061 224	Building F Classroom F5				
3-062 225	Building F Classroom F5A				
3-060 226	Building F Classroom F6				
3-059 227	Building F Classroom F6				
3-057 228	Building F Classroom F6				
3-058 229	Building F Classroom F6				
3-064 241	Building G Art Room G1				
3-068 242	Building G Art Room G1				
3-069 243	Building G Art Room G1				
3-070 244	Building G Art Room G1				
3-098 245	Building G Art Room G1				
3-099 246	Building G Art Room G1				
3-100 247	Building G Art Room G1				
3-101 248	Building G Art Room G1				
3-065 249	Building G Art Storage G1A				
3-066 250	Building G Art Storage G1B				
3-067 251	Building G Art Storage G1C				
3-073 252	Building G Art Storage G1D				
3-071 253	Building G Art Storage G1E				
3-078 254	Building G Art Room G2				
3-077 255	Building G Art Room G2				
3-076 256	Building G Art Room G2				
3-075 257	Building G Art Room G2				
3-074 258	Building G Art Room G2				
3-096 259	Building G Art Room G2				
3-095 260	Building G Art Room G2				
3-094 261	Building G Art Room G2				
3-093 262	Building G Art Room G2				
3-092 263	Building G Art Room G2				
3-097 264	Building G Art Room G2 Storage				
3-072 265	Building G Art Rm G2A Storage				
3-091 266	Building G Art Rm G2B Storage				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3-079 267	Building G Art Rm G2C Storage				
3-080 268	Building G Art Rm G2D Storage				
3-088 269	Building G Medical Room G3				
3-087 270	Building G Medical Room G3				
3-086 271	Building G Medical Room G3				
3-083 272	Building G Medical Room G3				
3-084 273	Building G Medical Room G3				
3-085 274	Building G Medical Room G3				
3-081 275	Building G Medical Rm G3A Strg				
3-082 276	Building G Medical Rm G3B Strg				
3-089 277	Building G Medical Rm G3C Strg				
3-090 278	Building G Medical Rm G3D Strg				
4-061 291	Building H Classroom H1				
4-052 292	Building H Classroom H1				
4-051 293	Building H Classroom H1				
4-054 294	Building H Room H1A Storage				
4-053 295	Building H Room H1B Storage				
4-050 296	Building H Classroom H2				
4-049 297	Building H Classroom H2				
4-048 298	Building H Classroom H2				
4-062 299	Building H Classroom H2				
4-046 300	Building H Classroom H2A				
4-045 301	Building H Classroom H3				
4-044 302	Building H Classroom H3				
4-043 303	Building H Classroom H3				
4-047 304	Building H Classroom H3A				
4-057 305	Building H Restroom H4				
4-056 306	Building H Restroom H4				
4-055 307	Building H Room H5 Storage				
4-063 308	Building H Classrm H5 Storage				
4-059 309	Building H Restroom H6				
4-058 310	Building H Restroom H6				
4-031 322	Building I Classroom i1				
4-032 323	Building I Classroom i1				
4-033 324	Building I Classroom i1				
4-037 325	Building I Classroom i1				
4-036 326	Building I Classroom i1				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
4-035 327	Building I Classroom i1				
4-034 328	Building I Room i1A Storage				
4-038 329	Building I Classroom i2				
4-039 330	Building I Classroom i2				
4-042 331	Building I Classroom i2				
4-041 332	Building I Classroom i2				
4-040 333	Building I Room i2A Storage				
4-029 341	Building J Classroom J1				
4-030 342	Building J Classroom J1				
4-027 343	Building J Room J1A Storage				
4-028 344	Building J Room J1B Storage				
4-026 345	Building J Classroom J2				
4-025 346	Building J Classroom J2				
4-023 347	Building J Classroom J3				
4-024 348	Building J Classroom J3				
4-020 349	Building J Classroom J4				
4-022 350	Building J Room J4A Storage				
4-021 351	Building J Room J4B Storage				
4-018 352	Building J Classroom J5				
4-019 353	Building J Classroom J5				
4-003 362	Building K Classroom K1				
4-002 363	Building K Classroom K1				
4-001 364	Building K Classroom K1				
4-004 365	Building K Classroom K1				
4-005 366	Building K Classroom K1				
4-006 367	Building K Classroom K1				
4-007 368	Building K Room K1A Storage				
4-008 369	Building K Room K1B Storage				
4-009 370	Building K Room K1C Storage				
4-017 371	Building K Classroom K2				
4-016 372	Building K Classroom K2				
4-015 373	Building K Classroom K2				
4-012 374	Building K Classroom K2				
4-013 375	Building K Classroom K2				
4-014 376	Building K Classroom K2				
4-011 377	Building K Room K2B Storage				
4-010 378	Building K Room K2C Storage				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
4-286 383	Building L Classroom L1				
4-287 384	Building L Classroom L1				
4-284 385	Building L Classroom L2				
4-285 386	Building L Classroom L2				
4-282 387	Building L Classroom L3				
4-283 388	Building L Classroom L3				
4-280 389	Building L Classroom L4				
4-281 390	Building L Classroom L4				
4-278 391	Building L Classroom L5				
4-279 392	Building L Classroom L5				
4-290 393	Building L Restroom L6				
4-291 394	Building L Restroom L6				
4-292 395	Building L Room L7 Storage				
4-288 396	Building L Restroom L8				
4-289 397	Building L Restroom L8				
4-276 415	Building N Classroom N1				
4-277 416	Building N Classroom N1				
4-274 417	Building N Classroom N2				
4-275 418	Building N Classroom N2				
4-272 419	Building N Classroom N3				
4-273 420	Building N Classroom N3				
4-270 421	Building N Classroom N4				
4-271 422	Building N Classroom N4				
4-268 423	Building N Classroom N5				
4-269 424	Building N Classroom N5				
4-267 425	Building N Restroom N6				
4-266 426	Building N Restroom N6				
4-263 427	Building N Room N7 Storage				
4-265 428	Building N Restroom N8				
4-264 429	Building N Restroom N8				
4-252 442	Building O Classroom O-1				
4-251 443	Building O Classroom O-1				
4-254 444	Building O Classroom O-2				
4-253 445	Building O Classroom O-2				
4-256 446	Building O Classroom O-3				
4-255 447	Building O Classroom O-3				
4-258 448	Building O Classroom O-4				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
4-257 449	Building O Classroom O-4				
4-259 450	Building O Classroom O-5				
4-260 451	Building O Classroom O-5				
4-262 452	Building O Classroom O-6				
4-261 453	Building O Classroom O-6				
5-017 463	Building P Classroom P1				
5-018 464	Building P Classroom P1				
5-027 465	Building P Classroom P1				
5-026 466	Building P Classroom P1				
5-024 467	Building P Room P1A Storage				
5-019 468	Building P Classroom P2				
5-020 469	Building P Classroom P2				
5-021 470	Building P Classroom P2				
5-022 471	Building P Classroom P2				
5-023 472	Building P Classroom P2				
5-025 473	Building P Room P2A Storage				
5-028 474	Building P Room P3 Storage				
5-029 475	Building P Room P3 Storage				
5-030 476	Building P Room P3 Storage				
5-035 477	Building P Classroom P4				
5-034 478	Building P Classroom P4				
5-033 479	Building P Classroom P4				
5-032 480	Building P Classroom P4				
5-031 481	Building P Classroom P4				
5-036 482	Building P Room P4A Storage				
5-037 483	Building P Room P4A Storage				
5-041 484	Building P Classroom P5				
5-040 485	Building P Classroom P5				
5-039 486	Building P Classroom P5				
5-038 487	Building P Classroom P5				
5-001 495	Building Q Classroom Q1				
5-002 496	Building Q Classroom Q1				
5-004 497	Building Q Classroom Q2				
5-003 498	Building Q Classroom Q2				
5-006 499	Building Q Classroom Q3				
5-005 500	Building Q Classroom Q3				
5-008 501	Building Q Classroom Q4				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
5-007 502	Building Q Classroom Q4				
5-010 503	Building Q Classroom Q5				
5-009 504	Building Q Classroom Q5				
5-015 505	Building Q Girls Restroom Q6				
5-011 506	Building Q Girls Restroom Q6				
5-014 507	Building Q Plumbing Chase Q7				
5-013 508	Building Q Boys Restroom Q8				
5-012 509	Building Q Boys Restroom Q8				
5-044 522	Building R Classroom R1				
5-053 523	Building R Classroom R1				
5-054 524	Building R Classroom R1				
5-045 525	Building R Classroom R1				
5-061 526	Building R O/S Rm R1 Storage				
5-042 527	Building R Office R1A				
5-052 528	Building R Room R1B1 Storage				
5-046 529	Building R Office R1B2				
5-048 530	Building R Room R1B3 Storage				
5-043 531	Building R Room R1B3 Storage				
5-049 532	Building R Room R1B4 Storage				
5-050 533	Building R Room R1B5 Storage				
5-058 534	Building R Classroom R2				
5-059 535	Building R Classroom R2				
5-060 536	Building R Classroom R2				
5-055 537	Building R Classroom R2				
5-056 538	Building R Classroom R2				
5-057 539	Building R Classroom R2				
5-051 540	Building R Classroom R2 Hall				
5-047 541	Building R Classroom R2 Hall				
2-004	Office A3				
2-008	Office A1B				
Heat Detector - Restorable Spot					
3-295 622	Building S Kitchen S7				
3-290 623	Building S Kitchen S7				
3-316 624	Building S Kitchen S7				
3-291 625	Building S Kitchen S7				
3-296 626	Building S Kitchen S7				
3-301 627	Building S Kitchen S7A				
3-382 628	Building S Attic Snack Stnd S1A				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3-421 629	Building S Attic Room S7				
3-421 630	Building S Attic Room S7				
3-384 631	Building S Attic Office S12				
3-383 632	Building S Attic Snack Stand Hall				
3-383 633	Building S Attic Snack Stand Hall				
5-381 745	Building T Shwer Rm T1D1 Strg				
5-284 746	Building T Locker Room T2				
5-283 747	Building T Locker Room T2 RR				
5-281 748	Building T Locker Room T2A				
5-291 749	Building T Dressing Room T2A				
5-290 750	Building T Locker Rm T2B Strg				
5-289 751	Building T Locker Rm T2C Strg				
5-288 752	Building T Locker Rm T2D Strg				
5-287 753	Building T Office T2E				
5-286 754	Building T Office T2E1				
5-285 755	Building T Room T2F Storage				
5-260 756	Building T Locker Room T3				
5-254 757	Building T Locker Room T3				
5-252 758	Building T Locker Room T3				
5-259 759	Building T Locker Rm T3 RR				
5-376 760	Building T Shower Room T3A				
5-376 761	Building T Shower Room T3A				
5-376 762	Building T Shower Room T3A				
5-376 763	Building T Shower Room T3A				
5-376 764	Building T Shower Room T3A				
5-376 765	Building T Shower Room T3A				
5-376 766	Building T Shower Room T3A				
5-376 767	Building T Shower Room T3A				
5-376 768	Building T Shower Room T3A				
5-376 769	Building T Shower Room T3A				
5-256 770	Building T Office T3C				
5-255 771	Building T Room T3C1 Storage				
5-257 772	Building T Office T3D				
5-258 773	Building T Room T3E Storage				
5-383 774	Building T Attic Lrg Gym Fyr T1				
5-382 775	Building T Attic Snack Stand T1A				
5-377 776	Building T Attic Rm T1F Storage				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
5-386 777	Building T Attic Rm T3F2 Strg				
5-391 778	Building T Attic Storage Rm T7				
4-085 881	Encina SW Area Daycare Kitchen				
4-192 882	Encina SW Area Attic Classroom 1				
4-192 883	Encina SW Area Attic Classroom 1				
4-191 884	Encina SW Area Attic Classroom 2				
4-191 885	Encina SW Area Attic Classroom 2				
4-175 886	Encina SW Area Attic Classroom 3				
4-175 887	Encina SW Area Attic Classroom 3				
4-176 888	Encina SW Area Attic Classroom 4				
4-176 889	Encina SW Area Attic Classroom 4				
4-182 890	Encina SW Area Attic Office				
4-183 891	Encina SW Area Attic Office				
4-184 892	Encina SW Area Attic Office				
4-179 893	Encina SW Area Attic Office Storage				
4-187 894	Encina SW Area Attic Staff Room				
4-186 895	Encina SW Area Attic Daycare 1				
4-186 896	Encina SW Area Attic Daycare 1				
4-186 897	Encina SW Area Attic Daycare 1				
4-186 898	Encina SW Area Attic Daycare 1				
4-188 899	Encina SW Area Attic Daycare 2				
4-188 900	Encina SW Area Attic Daycare 2				
4-188 901	Encina SW Area Attic Daycare 2				
4-188 902	Encina SW Area Attic Daycare 2				
4-165 903	Encina SW Area Attic ECE P1				
4-165 904	Encina SW Area Attic ECE P1				
4-165 905	Encina SW Area Attic ECE P1				
4-193 906	Encina SW Area Attic ECE P2				
4-193 907	Encina SW Area Attic ECE P2				
4-193 908	Encina SW Area Attic ECE P2				
4-195 909	Encina SW Area Attic ECE P2 Hall				
4-195 910	Encina SW Area Attic ECE P2 Hall				
4-195 911	Encina SW Area Attic ECE P2 Hall				
2-131 042	Building A Attic Office A1				
2-130 043	Building A Attic Office A1A				
2-129 044	Building A Attic Office A1B				
2-133 045	Building A Attic Office A1D				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-132 046	Building A Attic Office A1E				
2-134 047	Building A Attic Office A2				
2-127 048	Building A Attic Office A2A-A5				
2-128 049	Building A Attic Office A3				
2-135 050	Building A Attic Office A8				
2-136 051	Building A Attic Staff Rm A9				
2-137 052	Building A Attic Staff Rm A9 Hall				
2-141 053	Building A Attic A10				
2-141 054	Building A Attic A11				
2-377 104	Building B Attic Library B1				
2-376 105	Building B Attic Office B1B				
2-376 106	Building B Attic Office B1B				
2-376 107	Building B Attic Office B1B				
3-126 185	Building E Attic Strg by Rm E2				
3-127 186	Building E Attic Hall by Rm E2				
3-127 187	Building E Attic Hall by Rm E2				
3-050 199	Building F Custodial Office F1				
3-049 200	Building F Custodial Office F1				
3-043 201	Building F Custodial Office F1				
3-042 202	Building F Custodial Office F1				
3-048 203	Building F Custodial Office F1				
3-047 204	Building F Custodial Office F1				
3-044 205	Building F Custodial Office F1				
3-046 206	Building F Custodial Off Storage				
3-045 207	Building F Custodial Off Storage				
3-195 230	Building F Attic Classroom F6				
3-128 279	Building G Attic Strge Rm G3B				
3-129 280	Building G Attic Strge Rm G3D				
4-162 334	Building I Attic Classroom i1				
4-162 335	Building I Attic Classroom i1				
4-163 336	Building I Attic Classroom i2				
4-163 337	Building I Attic Classroom i2				
4-164 379	Building K Attic Classroom K1				
4-378 398	Building L Attic Rm L7 Storage				
4-377 411	Building M Attic Mech Room M1				
4-377 412	Building M Attic Mech Room M1				
4-377 413	Building M Attic Mech Room M1				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
4-377 414	Building M Attic Mech Room M1				
4-376 430	Building N Attic N7 Plumb Chase				
5-126 510	Building Q Attic Rm Q7 Storage				
5-127 542	Building R Attic Office R1A				
5-127 543	Building R Attic Office R1A				
Smoke Detector - Duct					
3-420 634	Building S Theater S4				
5-437 779	Building T Girls Locker T3 East				
5-436 780	Building T Girls Locker T3 West				
5-438 781	Building T Room T3F				
5-435 782	Building T Small Gym T5 East				
5-434 783	Building T Small Gym T5 West				
5-387 784	Building T Large Gym T6				
5-388 785	Building T Large Gym T6				
2-138 055	Building A Attic Office A1B				
2-139 056	Building A Attic Office A2				
2-142 057	Building A Attic Office A8				
2-140 058	Building A Attic Staff Rm A9 Hall				
2-436 108	Building B Attic Office B1B				
5-170 544	Building R Attic R1B2				
Mechanical, Electrosonic, or Pressure Waterflow Device					
3-422 635	Building S Storage S1B				
Valve Tamper Switch					
3-423 636	Building S Storage S1B				
Smoke Detector - Projected Beam					
5-432 786	Building T Small Gym T5				
5-430 787	Building T Small Gym T5				
5-428 788	Building T Small Gym T5				