

Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

GREER ELEMENTARY

2301 HURLEY WAY
SACRAMENTO, California
United States

This site has been inspected and tested in compliance with applicable standards.

Completed
Thursday, May 28, 2026

Test Session:31 Jul 2025 09:40 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD
5320 HEMLOCK ST
SACRAMENTO, California
United States

TESTED BY

Riley Goyet
Western States Fire Protection-
Sacramento
188 Cirby Way
Roseville, CA 95678
United States



Inspection Summary

Building Information

PROPERTY	GREER ELEMENTARY	CONTACT
ADDRESS	2301 HURLEY WAY	PHONE
CITY/STATE	SACRAMENTO, California	MOBILE
COUNTRY	United States	EMAIL

Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us

Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Alarm Notification Appliance	77	49(64%)	49(64%)	0(0%)
Ventilation and Cooking Equipment	5	0(0%)	0(0%)	0(0%)
Initiating Device	431	237(55%)	237(55%)	0(0%)
Fire Control Panel	1	0(0%)	0(0%)	0(0%)

Certification

The equipment specified herein was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Thursday, May 28, 2026

ACCEPTED BY 05/28/2026

Building Representative

TESTED BY 05/28/2026


Riley Goyet
Technician

Testing Details

Alarm Notification Appliance

Passed				
EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Horn / Strobe	all A/V's		Manual	7/31/2025 5:39:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Multi-Purpose Bldg Custodial Office	Manual	7/31/2025 5:37:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Multi-Purpose Bldg East Exterior	Manual	7/31/2025 5:37:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Multi-Purpose Bldg Kitchen	Manual	7/31/2025 5:37:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Multi-Purpose Bldg Kitchen	Manual	7/31/2025 5:37:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Multi-Purpose Bldg MP Room	Manual	7/31/2025 5:37:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Multi-Purpose Bldg MP Room	Manual	7/31/2025 5:37:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Multi-Purpose Bldg Stage	Manual	7/31/2025 5:37:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Multi-Purpose Bldg West Exterior	Manual	7/31/2025 5:37:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Portables Classroom 14	Manual	7/31/2025 5:38:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Portables Classroom 15	Manual	7/31/2025 5:38:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Portables Classroom 15	Manual	7/31/2025 5:38:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Portables Classroom 16	Manual	7/31/2025 5:38:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Portables Classroom 16	Manual	7/31/2025 5:38:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Portables Classroom 17	Manual	7/31/2025 5:38:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Portables Classroom 17	Manual	7/31/2025 5:38:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Portables Classroom 18	Manual	7/31/2025 5:38:38 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	Portables Classroom 18		Manual	7/31/2025 5:38:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	Portables Classroom 19		Manual	7/31/2025 5:38:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	Portables Classroom 19		Manual	7/31/2025 5:38:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	Portables Classroom 20		Manual	7/31/2025 5:38:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	Portables Classroom 20		Manual	7/31/2025 5:38:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	Portables Classroom 21		Manual	7/31/2025 5:38:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	Portables Classroom 21		Manual	7/31/2025 5:38:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	Portables Classroom 23		Manual	7/31/2025 5:38:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	Portables Classroom 24		Manual	7/31/2025 5:38:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	Portables Classroom 24		Manual	7/31/2025 5:38:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	Portables Classroom 25		Manual	7/31/2025 5:38:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	Portables Classroom 25		Manual	7/31/2025 5:38:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	Rooms 26-29 Bldg Classroom 26		Manual	7/31/2025 5:38:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	Rooms 26-29 Bldg Classroom 27		Manual	7/31/2025 5:38:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	Rooms 26-29 Bldg Classroom 28		Manual	7/31/2025 5:38:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	Rooms 26-29 Bldg Classroom 29		Manual	7/31/2025 5:38:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	Rooms 26-29 Bldg Classroom 29 Office		Manual	7/31/2025 5:38:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	Rooms 26-29 Bldg South Exterior		Manual	7/31/2025 5:38:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible		Rooms 7-12 Bldg Boys RR by Rm 7	Manual	7/31/2025 5:38:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 7-12 Bldg Classroom 11	Manual	7/31/2025 5:38:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 7-12 Bldg Classroom 12	Manual	7/31/2025 5:38:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Rooms 7-12 Bldg Girls RR by Rm 7	Manual	7/31/2025 5:38:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Rooms C D Bldg Boys RR by Rm C	Manual	7/31/2025 5:37:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms C D Bldg Classroom C	Manual	7/31/2025 5:37:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms C D Bldg Classroom D	Manual	7/31/2025 5:37:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Rooms C D Bldg Girls RR by Staff Rm	Manual	7/31/2025 5:37:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms C D Bldg Northwest Exterior	Manual	7/31/2025 5:38:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms C D Bldg Staff Room	Manual	7/31/2025 5:37:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms C D Bldg West Exterior	Manual	7/31/2025 5:38:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms C D Bldg West Exterior	Manual	7/31/2025 5:38:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms C D Bldg Work Room	Manual	7/31/2025 5:37:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Rooms C D Bldg Work Room RR	Manual	7/31/2025 5:37:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-264	A01 Hallway	Manual	7/31/2025 10:04:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-267	A01 Hallway	Manual	7/31/2025 10:05:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-128	Attic HVAC OS Rm	Manual	7/31/2025 1:02:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	4-133	Attic HVAC OS Rm 26	Manual	7/31/2025 1:06:09 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	4-1286	Attic Library Rm 29	Manual	7/31/2025 5:37:24 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	4-131	Attic OS Rm 27	Manual	7/31/2025 5:37:23 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	4-132	Attic Rm 27	Manual	7/31/2025 12:49:44 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	4-130	Attic Rm 28	Manual	7/31/2025 12:54:34 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	4-127	Attic Rm 29A	Manual	7/31/2025 12:59:25 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-166	Attic Rm T1	Manual	7/31/2025 1:09:36 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-167	Attic Rm T2	Manual	7/31/2025 1:14:51 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-168	Attic Rm T3	Manual	7/31/2025 1:18:20 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-169	Attic Rm T4	Manual	7/31/2025 1:21:24 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-170	Attic Rm T5	Manual	7/31/2025 1:24:11 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-171	Attic Rm T6	Manual	7/31/2025 1:27:45 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Valve Tamper Switch	2-377	Bldg A	Manual	7/31/2025 5:37:14 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	2-376	Bldg A	Manual	7/31/2025 5:37:15 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Valve Tamper Switch	2-380	bldg B	Manual	7/31/2025 10:15:21 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	2-379	Bldg B	Manual	7/31/2025 10:17:09 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Manual Pull Station	2-381	Bldg B Admin	Manual	7/31/2025 10:11:08 AM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	2-282	Bldg B Custodial	Manual	7/31/2025 10:15:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-286	Bldg B East Hall	Manual	7/31/2025 10:10:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-289	Bldg B Hall	Manual	7/31/2025 10:10:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-300	Bldg B Lobby Hall	Manual	7/31/2025 10:52:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Valve Tamper Switch	2-134	Bldg B OSY	Manual	7/31/2025 9:52:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-294	Bldg B West Hall	Manual	7/31/2025 10:09:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Valve Tamper Switch	2-397	Bldg C	Manual	7/31/2025 10:29:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	2-396	Bldg C	Manual	7/31/2025 10:31:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-046	Bldg G hallway	Manual	7/31/2025 9:42:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-041	Bldg G Hallway	Manual	7/31/2025 9:42:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-049	Bldg G Hallway	Manual	7/31/2025 9:42:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-054	Bldg G Hallway	Manual	7/31/2025 9:42:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-053	Bldg G Hallway	Manual	7/31/2025 9:43:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-134	Bldg P Rm 1	Manual	7/31/2025 12:51:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-314	Boys RR C06	Manual	7/31/2025 10:23:40 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-061	Boys RR Rm E07	Manual	7/31/2025 10:03:54 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-037	Boys RR Rm G17	Manual	7/31/2025 9:41:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-012	Classroom 28	Manual	7/31/2025 10:38:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	4-011	Classroom 28	Manual	7/31/2025 10:38:34 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-010	Classroom 28	Manual	7/31/2025 10:39:08 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-014	Classroom 28	Manual	7/31/2025 10:39:38 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-013	Classroom 28	Manual	7/31/2025 10:40:27 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-302	Closet B19	Manual	7/31/2025 10:08:42 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-007	Custodial Rm F08	Manual	7/31/2025 9:41:59 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-312	East Hallway MP Rm	Manual	7/31/2025 10:23:25 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-006	Elec Rm F08	Manual	7/31/2025 10:01:02 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-345	Elect Rm C09	Manual	7/31/2025 10:20:08 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-313	Girls RR C05	Manual	7/31/2025 10:26:25 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-064	Girls RR E10	Manual	7/31/2025 10:07:30 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-036	Girls RR Rm G16	Manual	7/31/2025 9:41:40 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	4-129	HVAC Attic OS Rm 28	Manual	7/31/2025 1:03:09 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-311	IDF Rm C08	Manual	7/31/2025 10:25:25 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-320	Kitchen C02	Manual	7/31/2025 12:49:03 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-319	Kitchen C02	Manual	7/31/2025 12:49:24 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-321	Kitchen C02.2	Manual	7/31/2025 12:48:49 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-315	Kitchen Hall	Manual	7/31/2025 5:37:09 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	4-004	Library Rm 29	Manual	7/31/2025 10:41:54 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-005	Library Rm 29	Manual	7/31/2025 10:44:51 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-003	Library Rm 29	Manual	7/31/2025 10:45:47 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-002	Library Rm 29	Manual	7/31/2025 10:46:12 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-006	Library Rm 29	Manual	7/31/2025 10:47:00 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-008	Library Rm 29	Manual	7/31/2025 10:47:42 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-007	Library Rm 29	Manual	7/31/2025 10:48:29 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-009	Library Rm 29 A	Manual	7/31/2025 10:49:13 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-009	Library Rm 29A	Manual	7/31/2025 10:42:20 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-298	Lobby B01	Manual	7/31/2025 10:08:18 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-299	Lobby B01	Manual	7/31/2025 10:08:26 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-329	MP Rm C01	Manual	7/31/2025 10:19:04 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-331	MP Rm C01	Manual	7/31/2025 10:20:02 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-332	MP Rm C01	Manual	7/31/2025 10:20:57 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-335	MP Rm C01	Manual	7/31/2025 10:21:14 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-338	MP Rm C01	Manual	7/31/2025 10:21:52 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-341	MP Rm C01	Manual	7/31/2025 10:22:12 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-342	MP Rm C01	Manual	7/31/2025 10:25:09 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-339	MP Rm C01	Manual	7/31/2025 10:25:21 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-336	MP Rm C01	Manual	7/31/2025 10:25:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-333	MP Rm C01	Manual	7/31/2025 10:25:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-340	MP Rm C01	Manual	7/31/2025 10:26:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-343	MP Rm C01	Manual	7/31/2025 10:27:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-337	MP RM C01	Manual	7/31/2025 10:26:32 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-328	MP Rm C10	Manual	7/31/2025 10:19:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-327	MP Rm C10	Manual	7/31/2025 10:21:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-325	MP Rm C10	Manual	7/31/2025 10:22:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-394	MP Rm East	Manual	7/31/2025 10:24:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-330	MP Rm Hallway	Manual	7/31/2025 10:19:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-403	MP Rm North	Manual	7/31/2025 10:27:44 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-408	MP Rm South	Manual	7/31/2025 10:52:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-405	MP Rm South East	Manual	7/31/2025 10:18:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-407	MP Rm South West	Manual	7/31/2025 10:32:36 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-344	MP Rm Stage	Manual	7/31/2025 10:19:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-326	MP Rm Stage C10	Manual	7/31/2025 10:20:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-324	MP Rm Stage Ramp	Manual	7/31/2025 10:23:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-293	Nurse Rm B17	Manual	7/31/2025 10:09:19 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-291 136	Portables Classroom 19	Manual	7/31/2025 10:09:43 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-261 141	Portables Classroom 23	Manual	7/31/2025 10:03:40 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	2-140	Riser E	Manual	7/31/2025 5:37:17 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Valve Tamper Switch	2-141	Riser E	Manual	7/31/2025 5:37:11 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Valve Tamper Switch	2-157	Riser E	Manual	7/31/2025 5:37:21 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	2-156	Riser F	Manual	7/31/2025 5:37:20 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	2-149	Riser G	Manual	7/31/2025 9:54:33 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Valve Tamper Switch	2-150	Riser G	Manual	7/31/2025 5:37:12 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-021	Rm 26	Manual	7/31/2025 10:29:53 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-024	Rm 26	Manual	7/31/2025 10:30:38 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-023	Rm 26	Manual	7/31/2025 10:31:43 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-022	Rm 26	Manual	7/31/2025 10:32:25 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-020	Rm 26	Manual	7/31/2025 10:32:44 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-019	Rm 27	Manual	7/31/2025 10:34:23 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-017	Rm 27	Manual	7/31/2025 10:34:27 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-016	Rm 27	Manual	7/31/2025 10:34:44 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-015	Rm 27	Manual	7/31/2025 10:35:27 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-018	Rm 27	Manual	7/31/2025 10:36:23 AM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	2-272	Rm A02	Manual	7/31/2025 10:05:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-271	Rm A02	Manual	7/31/2025 10:06:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-270	Rm A02	Manual	7/31/2025 10:06:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-269	Rm A02	Manual	7/31/2025 10:06:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-268	Rm A02	Manual	7/31/2025 10:06:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-275	Rm A03	Manual	7/31/2025 10:04:20 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-278	Rm A03	Manual	7/31/2025 10:04:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-277	Rm A03	Manual	7/31/2025 10:04:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-274	Rm A03	Manual	7/31/2025 10:05:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-273	Rm A03	Manual	7/31/2025 10:05:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-276	Rm A03	Manual	7/31/2025 5:37:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-258	Rm A04	Manual	7/31/2025 10:03:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-256	Rm A04	Manual	7/31/2025 10:03:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-257	Rm A04	Manual	7/31/2025 10:03:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-255	Rm A04	Manual	7/31/2025 10:03:35 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-266	Rm A05	Manual	7/31/2025 10:02:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-265	Rm A05	Manual	7/31/2025 10:02:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-262	Rm A05	Manual	7/31/2025 10:02:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-263	Rm A05	Manual	7/31/2025 10:02:32 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-280	Rm A09	Manual	7/31/2025 10:02:55 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-279	Rm A09	Manual	7/31/2025 10:52:33 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-259	Rm A10	Manual	7/31/2025 10:00:58 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-297	Rm B02	Manual	7/31/2025 10:08:47 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-296	Rm B03	Manual	7/31/2025 10:11:53 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-295	Rm B04	Manual	7/31/2025 10:12:20 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-285	Rm B06	Manual	7/31/2025 10:11:57 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-284	Rm B07	Manual	7/31/2025 10:13:54 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-283	Rm B08	Manual	7/31/2025 10:11:20 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-281	Rm B10	Manual	7/31/2025 10:52:44 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-310	Rm B11	Manual	7/31/2025 10:14:01 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-308	Rm B14	Manual	7/31/2025 10:17:02 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-309	Rm B14	Manual	7/31/2025 10:17:21 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-306	Rm B15	Manual	7/31/2025 10:14:33 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-307	Rm B15	Manual	7/31/2025 10:16:44 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-290	Rm B16	Manual	7/31/2025 10:12:50 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-292	Rm B17	Manual	7/31/2025 10:10:26 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-305	Rm B18	Manual	7/31/2025 10:09:48 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-303	Rm B19	Manual	7/31/2025 10:08:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-304	Rm B19	Manual	7/31/2025 10:09:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-322	Rm C02	Manual	7/31/2025 10:36:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-323	Rm C02	Manual	7/31/2025 10:37:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-317	Rm C07	Manual	7/31/2025 10:28:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-316	Rm C08	Manual	7/31/2025 10:27:36 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-065	Rm E01	Manual	7/31/2025 10:12:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-066	Rm E01	Manual	7/31/2025 10:12:39 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-067	Rm E02	Manual	7/31/2025 10:14:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-068	Rm E02	Manual	7/31/2025 10:17:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-069	Rm E03	Manual	7/31/2025 10:18:16 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-070	Rm E03	Manual	7/31/2025 10:19:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-072	Rm E03	Manual	7/31/2025 10:22:16 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-071	Rm E04	Manual	7/31/2025 10:21:19 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-073	Rm E05	Manual	7/31/2025 10:23:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-074	Rm E05	Manual	7/31/2025 10:24:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-075	Rm E06	Manual	7/31/2025 10:26:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-076	Rm E06	Manual	7/31/2025 10:27:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-060	Rm E11	Manual	7/31/2025 10:08:55 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-059	Rm E12	Manual	7/31/2025 10:10:06 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-058	Rm E13	Manual	7/31/2025 10:10:58 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-008	Rm F01	Manual	7/31/2025 9:42:02 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-009	Rm F01	Manual	7/31/2025 9:42:36 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-011	Rm F02	Manual	7/31/2025 9:43:44 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-010	Rm F02	Manual	7/31/2025 1:44:09 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-013	Rm F03	Manual	7/31/2025 9:46:10 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-012	Rm F03	Manual	7/31/2025 9:46:51 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-015	Rm F04	Manual	7/31/2025 9:48:20 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-014	Rm F04	Manual	7/31/2025 1:44:05 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-017	Rm F05	Manual	7/31/2025 9:52:30 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-016	Rm F05	Manual	7/31/2025 9:53:02 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-019	Rm F06	Manual	7/31/2025 9:54:28 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-018	Rm F06	Manual	7/31/2025 9:54:56 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-038	Rm G01	Manual	7/31/2025 9:41:53 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-039	Rm G01	Manual	7/31/2025 9:42:11 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-050	Rm G01	Manual	7/31/2025 9:42:40 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-055	Rm G01	Manual	7/31/2025 9:44:23 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-021	Rm G02	Manual	7/31/2025 9:50:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-056	Rm G07	Manual	7/31/2025 9:44:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-057	Rm G07	Manual	7/31/2025 9:44:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-052	Rm G08	Manual	7/31/2025 9:43:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-051	Rm G08	Manual	7/31/2025 9:43:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-048	Rm G09	Manual	7/31/2025 9:43:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-047	Rm G09	Manual	7/31/2025 9:43:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-045	Rm G10	Manual	7/31/2025 9:43:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-044	Rm G10	Manual	7/31/2025 9:43:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-043	Rm G11	Manual	7/31/2025 9:42:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-042	Rm G11	Manual	7/31/2025 9:42:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-040	Rm G12	Manual	7/31/2025 9:42:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-033	Rm G13	Manual	7/31/2025 9:41:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-035	Rm G14	Manual	7/31/2025 9:41:33 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-020	Rm G18	Manual	7/31/2025 9:41:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-023	Rm G2	Manual	7/31/2025 9:50:39 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-024	Rm G2	Manual	7/31/2025 9:50:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-022	Rm G2 RR	Manual	7/31/2025 9:50:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-034	Rm G26	Manual	7/31/2025 9:52:35 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-026	Rm G3	Manual	7/31/2025 9:48:05 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-025	Rm G3	Manual	7/31/2025 9:49:40 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-027	Rm G4	Manual	7/31/2025 9:48:09 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-028	Rm G4	Manual	7/31/2025 10:53:10 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-029	Rm G5	Manual	7/31/2025 9:46:39 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-030	Rm G5	Manual	7/31/2025 9:46:44 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-032	Rm G6	Manual	7/31/2025 9:45:17 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-031	Rm G6	Manual	7/31/2025 9:45:19 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-064	Rm T 6	Manual	7/31/2025 5:37:18 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-055	Rm T1	Manual	7/31/2025 1:11:09 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-054	Rm T1	Manual	7/31/2025 1:11:29 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-057	Rm T2	Manual	7/31/2025 1:13:28 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-056	Rm T2	Manual	7/31/2025 1:13:53 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-058	Rm T3	Manual	7/31/2025 1:17:36 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-059	Rm T3	Manual	7/31/2025 1:17:38 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-061	Rm T4	Manual	7/31/2025 10:03:56 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-061(1)	Rm T4	Manual	7/31/2025 1:20:33 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-060	Rm T4	Manual	7/31/2025 1:20:39 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-063	Rm T5	Manual	7/31/2025 1:23:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-062	Rm T5	Manual	7/31/2025 1:23:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-065	Rm T6	Manual	7/31/2025 1:27:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-064	Rm T6	Manual	7/31/2025 1:27:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-126 215	Rooms 26-29 Bldg Attic Classroom 29	Manual	7/31/2025 12:56:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-394 231	Rooms C D Bldg Attic Room C	Manual	7/31/2025 5:37:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-260	RR A04	Manual	7/31/2025 10:03:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-261	RR A05	Manual	7/31/2025 10:02:35 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-287	RR B12	Manual	7/31/2025 10:11:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-288	RR b13	Manual	7/31/2025 10:10:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-291	RR B17	Manual	7/31/2025 10:09:38 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-301	RR b20	Manual	7/31/2025 10:08:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-318	Staff RR C02	Manual	7/31/2025 10:36:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-063	Staff RR E09	Manual	7/31/2025 10:06:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-062	Staff RR Rm E08	Manual	7/31/2025 10:06:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Ventilation and Cooking Equipment

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Cooking Equipment	Appliances		Manual	7/31/2025 1:42:59 PM
Fusible Links	Fusible Link 450 x 4		Manual	7/31/2025 1:43:09 PM
Range Hood	Kitchen Hood		Manual	7/31/2025 1:43:06 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Range Suppression	Suppression System		Manual	7/31/2025 1:43:03 PM
Range Suppression Tank	R102 3 Gallon Cylinder		Manual	7/31/2025 1:42:36 PM

Device/Equipment details

Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Audible					
024	Admin Building North Exterior				
025	Admin Building South Exterior				
067	Rooms 1-6 Bldg North Exterior				
068	Rooms 1-6 Bldg North Exterior				
069	Rooms 1-6 Bldg North Exterior				
070	Rooms 1-6 Bldg South Exterior				
071	Rooms 1-6 Bldg South Exterior				
072	Rooms 1-6 Bldg West Exterior				
116	Rooms 7-12 Bldg North Exterior				
117	Rooms 7-12 Bldg North Exterior				
167	Portables Classroom 15				
168	Portables Classroom 16				
169	Portables Classroom 17				
170	Portables Classroom 18				
171	Portables Classroom 19				
172	Portables Classroom 20				
173	Portables Classroom 21				
174	Portables Classroom 25				
184	Portables Classroom 24				
217	Rooms 26-29 Bldg South Exterior				
245	Rooms C D Bldg Northwest Exterior				
246	Rooms C D Bldg West Exterior				
247	Rooms C D Bldg West Exterior				
272	Multi-Purpose Bldg East Exterior				
273	Multi-Purpose Bldg West Exterior				
Audible And Visible					
026	Admin Building Admin Office				
027	Admin Building Classroom 22				
073	Rooms 1-6 Bldg Classroom 1				
074	Rooms 1-6 Bldg Classroom 2				
075	Rooms 1-6 Bldg Classroom 3				
076	Rooms 1-6 Bldg Classroom 4				
077	Rooms 1-6 Bldg Classroom 5				
078	Rooms 1-6 Bldg Classroom 6				
118	Rooms 7-12 Bldg Classroom 7				
119	Rooms 7-12 Bldg Classroom 8				
120	Rooms 7-12 Bldg Classroom 9				
121	Rooms 7-12 Bldg Classroom 10				
122	Rooms 7-12 Bldg Classroom 11				
123	Rooms 7-12 Bldg Classroom 12				
175	Portables Classroom 14				
176	Portables Classroom 15				
177	Portables Classroom 16				
178	Portables Classroom 17				
179	Portables Classroom 18				
180	Portables Classroom 19				
181	Portables Classroom 20				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
182	Portables Classroom 21				
183	Portables Classroom 25				
185	Portables Classroom 23				
186	Portables Classroom 24				
218	Rooms 26-29 Bldg Classroom 26				
219	Rooms 26-29 Bldg Classroom 27				
220	Rooms 26-29 Bldg Classroom 28				
221	Rooms 26-29 Bldg Classroom 29				
222	Rooms 26-29 Bldg Classroom 29 Office				
248	Rooms C D Bldg Classroom C				
249	Rooms C D Bldg Classroom D				
250	Rooms C D Bldg Staff Room				
251	Rooms C D Bldg Work Room				
274	Multi-Purpose Bldg MP Room				
275	Multi-Purpose Bldg MP Room				
276	Multi-Purpose Bldg Stage				
277	Multi-Purpose Bldg Kitchen				

Visible

028	Admin Building Staff Restroom				
029	Admin Building Principal Office				
030	Admin Building Staff RR by Admin				
031	Admin Building Classroom 22				
032	Admin Building Classroom 22 RR				
079	Rooms 1-6 Bldg Room E				
124	Rooms 7-12 Bldg Boys RR by Rm 7				
125	Rooms 7-12 Bldg Girls RR by Rm 7				
252	Rooms C D Bldg Boys RR by Rm C				
253	Rooms C D Bldg Girls RR by Staff Rm				
254	Rooms C D Bldg Work Room RR				
278	Multi-Purpose Bldg Kitchen				
279	Multi-Purpose Bldg Custodial Office				

Horn / Strobe

all AV's					07/31/2025
----------	--	--	--	--	------------

Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Remote Annunciator					
001	Admin Building Admin Office				

Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Manual Pull Station					
2-131 002	Admin Building Admin Office				
2-134 255	Multi-Purpose Bldg East				
2-139 256	Multi-Purpose Bldg North				
2-138 257	Multi-Purpose Bldg Stage				
2-135 258	Multi-Purpose Bldg South				
2-381	Bldg B Admin				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-394	MP Rm East				
2-403	MP Rm North				
2-405	MP Rm South East				
2-408	MP Rm South				
2-407	MP Rm South West				
Smoke Detector - General					
2-026 003	Admin Building Admin Office				
2-022 004	Admin Building Admin Off Back Rm				
2-023 005	Admin Building Back Room Closet				
2-024 006	Admin Building Back Room Closet				
2-025 007	Admin Building Staff Restroom				
2-027 008	Admin Building Principal Office				
2-037 009	Admin Building Staff RR by Admin				
2-029 010	Admin Building Classroom 22				
2-031 011	Admin Building Classroom 22				
2-033 012	Admin Building Classroom 22				
2-034 013	Admin Building Classroom 22				
2-032 014	Admin Building Classroom 22				
2-028 015	Admin Building Classroom 22 RR				
2-030 016	Admin Building Classrm 22 Storage				
2-016 033	Rooms 1-6 Bldg Classroom 1				
2-005 034	Rooms 1-6 Bldg Classroom 1				
2-004 035	Rooms 1-6 Bldg Classroom 1				
2-017 036	Rooms 1-6 Bldg Classroom 2				
2-007 037	Rooms 1-6 Bldg Classroom 2				
2-006 038	Rooms 1-6 Bldg Classroom 2				
2-018 039	Rooms 1-6 Bldg Classroom 3				
2-008 040	Rooms 1-6 Bldg Classroom 3				
2-009 041	Rooms 1-6 Bldg Classroom 3				
2-019 042	Rooms 1-6 Bldg Classroom 4				
2-010 043	Rooms 1-6 Bldg Classroom 4				
2-011 044	Rooms 1-6 Bldg Classroom 4				
2-020 045	Rooms 1-6 Bldg Classroom 5				
2-012 046	Rooms 1-6 Bldg Classroom 5				
2-013 047	Rooms 1-6 Bldg Classroom 5				
2-014 048	Rooms 1-6 Bldg Classroom 6				
2-015 049	Rooms 1-6 Bldg Classroom 6				
2-021 050	Rooms 1-6 Bldg Classroom 6				
2-003 051	Rooms 1-6 Bldg Room E				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-002 052	Rooms 1-6 Bldg Storage by Boiler Rm				
2-001 053	Rooms 1-6 Bldg Server Rm/Headend				
2-272 082	Rooms 7-12 Bldg Classroom 7				
2-273 083	Rooms 7-12 Bldg Classroom 7				
2-266 084	Rooms 7-12 Bldg Classroom 7				
2-274 085	Rooms 7-12 Bldg Classroom 8				
2-275 086	Rooms 7-12 Bldg Classroom 8				
2-267 087	Rooms 7-12 Bldg Classroom 8				
2-276 088	Rooms 7-12 Bldg Classroom 9				
2-277 089	Rooms 7-12 Bldg Classroom 9				
2-268 090	Rooms 7-12 Bldg Classroom 9				
2-269 091	Rooms 7-12 Bldg Classroom 10				
2-279 092	Rooms 7-12 Bldg Classroom 10				
2-278 093	Rooms 7-12 Bldg Classroom 10				
2-270 094	Rooms 7-12 Bldg Classroom 11				
2-281 095	Rooms 7-12 Bldg Classroom 11				
2-280 096	Rooms 7-12 Bldg Classroom 11				
2-282 097	Rooms 7-12 Bldg Classroom 12				
2-283 098	Rooms 7-12 Bldg Classroom 12				
2-271 099	Rooms 7-12 Bldg Classroom 12				
2-265 100	Rooms 7-12 Bldg Girls RR by Rm 7				
2-263 101	Rooms 7-12 Bldg Storage by Room 7				
2-264 102	Rooms 7-12 Bldg Boys RR by Rm 7				
2-286 127	Portables Classroom 14				
2-285 128	Portables Classroom 14				
2-290 129	Portables Classroom 15				
2-289 130	Portables Classroom 15				
2-035 131	Portables Classroom 16				
2-036 132	Portables Classroom 17				
2-294 133	Portables Classroom 18				
2-293 134	Portables Classroom 18				
2-292 135	Portables Classroom 19				
2-291 136	Portables Classroom 19				
2-287 137	Portables Classroom 20				
2-288 138	Portables Classroom 20				
2-295 139	Portables Classroom 21				
2-296 140	Portables Classroom 21				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-261 141	Portables Classroom 23				
2-262 142	Portables Classroom 23				
2-259 143	Portables Classroom 24				
2-260 144	Portables Classroom 24				
2-297 145	Portables Classroom 25				
2-298 146	Portables Classroom 25				
4-021 188	Rooms 26-29 Bldg Classroom 26				
4-024 189	Rooms 26-29 Bldg Classroom 26				
4-020 190	Rooms 26-29 Bldg Classroom 26				
4-022 191	Rooms 26-29 Bldg Classroom 26				
4-023 192	Rooms 26-29 Bldg Classroom 26				
4-018 193	Rooms 26-29 Bldg Classroom 27				
4-015 194	Rooms 26-29 Bldg Classroom 27				
4-019 195	Rooms 26-29 Bldg Classroom 27				
4-017 196	Rooms 26-29 Bldg Classroom 27				
4-016 197	Rooms 26-29 Bldg Classroom 27				
4-012 198	Rooms 26-29 Bldg Classroom 28				
4-011 199	Rooms 26-29 Bldg Classroom 28				
4-013 200	Rooms 26-29 Bldg Classroom 28				
4-014 201	Rooms 26-29 Bldg Classroom 28				
4-010 202	Rooms 26-29 Bldg Classroom 28				
4-002 203	Rooms 26-29 Bldg Library Room 29				
4-003 204	Rooms 26-29 Bldg Library Room 29				
4-004 205	Rooms 26-29 Bldg Library Room 29				
4-005 206	Rooms 26-29 Bldg Library Room 29				
4-007 207	Rooms 26-29 Bldg Library Room 29				
4-008 208	Rooms 26-29 Bldg Library Room 29				
4-006 209	Rooms 26-29 Bldg Library Room 29				
4-009 210	Rooms 26-29 Bldg Library Room 29A				
4-009 211	Rooms 26-29 Bldg Library Room 29A Clst				
2-257 223	Rooms C D Bldg Classroom C				
2-256 224	Rooms C D Bldg Classroom D				
2-258 225	Rooms C D Bldg Boys RR by Rm C				
2-255 226	Rooms C D Bldg Girls RR by Staff Rm				
2-254 227	Rooms C D Bldg Staff Room				
2-251 228	Rooms C D Bldg Work Room				
2-253 229	Rooms C D Bldg Work Room RR				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-252 230	Rooms C D Bldg Storage by Work Rm				
2-045 259	Multi-Purpose Bldg MP Room				
2-041 260	Multi-Purpose Bldg MP Room				
2-044 261	Multi-Purpose Bldg Stage				
2-043 262	Multi-Purpose Bldg Stage				
2-042 263	Multi-Purpose Bldg Stage				
2-040 264	Multi-Purpose Bldg Custodial Office				
2-039 265	Multi-Purpose Bldg Custodial Office Clst				
2-006	Elec Rm F08				
2-007	Custodial Rm F08				
2-008	Rm F01				
2-009	Rm F01				
2-010	Rm F02				
2-011	Rm F02				
2-012	Rm F03				
2-013	Rm F03				
2-014	Rm F04				
2-015	Rm F04				
2-016	Rm F05				
2-017	Rm F05				
2-018	Rm F06				
2-019	Rm F06				
2-020	Rm G18				
2-021	Rm G02				
2-022	Rm G2 RR				
2-023	Rm G2				
2-024	Rm G2				
2-025	Rm G3				
2-026	Rm G3				
2-027	Rm G4				
2-028	Rm G4				
2-029	Rm G5				
2-030	Rm G5				
2-031	Rm G6				
2-032	Rm G6				
2-033	Rm G13				
2-034	Rm G26				
2-035	Rm G14				
2-036	Girls RR Rm G16				
2-037	Boys RR Rm G17				
2-038	Rm G01				
2-039	Rm G01				
2-040	Rm G12				
2-041	Bldg G Hallway				
2-042	Rm G11				
2-043	Rm G11				
2-044	Rm G10				
2-045	Rm G10				
2-046	Bldg G hallway				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-047	Rm G09				
2-048	Rm G09				
2-049	Bldg G Hallway				
2-050	Rm G01				
2-051	Rm G08				
2-052	Rm G08				
2-053	Bldg G Hallway				
2-054	Bldg G Hallway				
2-055	Rm G01				
2-056	Rm G07				
2-057	Rm G07				
2-058	Rm E13				
2-059	Rm E12				
2-060	Rm E11				
2-061	Boys RR Rm E07				
2-062	Staff RR Rm E08				
2-063	Staff RR E09				
2-064	Girls RR E10				
2-065	Rm E01				
2-066	Rm E01				
2-067	Rm E02				
2-068	Rm E02				
2-069	Rm E03				
2-070	Rm E03				
2-071	Rm E04				
2-072	Rm E03				
2-073	Rm E05				
2-074	Rm E05				
2-075	Rm E06				
2-076	Rm E06				
2-255	Rm A04				
2-256	Rm A04				
2-257	Rm A04				
2-258	Rm A04				
2-259	Rm A10				
2-260	RR A04				
2-261	RR A05				
2-262	Rm A05				
2-263	Rm A05				
2-264	A01 Hallway				
2-265	Rm A05				
2-266	Rm A05				
2-267	A01 Hallway				
2-268	Rm A02				
2-269	Rm A02				
2-270	Rm A02				
2-271	Rm A02				
2-272	Rm A02				
2-273	Rm A03				
2-274	Rm A03				
2-275	Rm A03				
2-276	Rm A03				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-277	Rm A03				
2-278	Rm A03				
2-279	Rm A09				
2-280	Rm A09				
2-281	Rm B10				
2-282	Bldg B Custodial				
2-283	Rm B08				
2-284	Rm B07				
2-285	Rm B06				
2-286	Bldg B East Hall				
2-287	RR B12				
2-288	RR b13				
2-289	Bldg B Hall				
2-290	Rm B16				
2-291	RR B17				
2-292	Rm B17				
2-293	Nurse Rm B17				
2-294	Bldg B West Hall				
2-295	Rm B04				
2-296	Rm B03				
2-297	Rm B02				
2-298	Lobby B01				
2-299	Lobby B01				
2-300	Bldg B Lobby Hall				
2-301	RR b20				
2-302	Closet B19				
2-303	Rm B19				
2-304	Rm B19				
2-305	Rm B18				
2-306	Rm B15				
2-307	Rm B15				
2-308	Rm B14				
2-309	Rm B14				
2-310	Rm B11				
2-311	IDF Rm C08				
2-312	East Hallway MP Rm				
2-313	Girls RR C05				
2-314	Boys RR C06				
2-315	Kitchen Hall				
2-316	Rm C08				
2-317	Rm C07				
2-318	Staff RR C02				
2-322	Rm C02				
2-323	Rm C02				
2-324	MP Rm Stage Ramp				
2-325	MP Rm C10				
2-326	MP Rm Stage C10				
2-327	MP Rm C10				
2-328	MP Rm C10				
2-329	MP Rm C01				
2-330	MP Rm Hallway				
2-331	MP Rm C01				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-332	MP Rm C01				
2-333	MP Rm C01				
2-335	MP Rm C01				
2-336	MP Rm C01				
2-337	MP RM C01				
2-338	MP Rm C01				
2-339	MP Rm C01				
2-340	MP Rm C01				
2-341	MP Rm C01				
2-342	MP Rm C01				
2-343	MP Rm C01				
2-344	MP Rm Stage				
2-345	Elect Rm C09				
4-002	Library Rm 29				
4-003	Library Rm 29				
4-004	Library Rm 29				
4-005	Library Rm 29				
4-006	Library Rm 29				
4-007	Library Rm 29				
4-008	Library Rm 29				
4-009	Library Rm 29 A				
4-010	Classroom 28				
4-011	Classroom 28				
4-012	Classroom 28				
4-013	Classroom 28				
4-014	Classroom 28				
4-015	Rm 27				
4-016	Rm 27				
4-017	Rm 27				
4-018	Rm 27				
4-019	Rm 27				
4-020	Rm 26				
4-021	Rm 26				
4-022	Rm 26				
4-023	Rm 26				
4-024	Rm 26				
4-009	Library Rm 29A				
2-054	Rm T1				
2-055	Rm T1				
2-056	Rm T2				
2-057	Rm T2				
2-058	Rm T3				
2-059	Rm T3				
2-060	Rm T4				
2-061	Rm T4				
2-062	Rm T5				
2-063	Rm T5				
2-064	Rm T 6				
2-061(1)	Rm T4				
2-065	Rm T6				
2-064	Rm T6				
Heat Detector - Restorable Spot					

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-127 017	Admin Building Attic Admin Office				
2-127 018	Admin Building Attic Admin Office				
2-128 019	Admin Building Attic Classroom 22				
2-157 020	Admin Building Attic Classroom 22				
2-157 021	Admin Building Attic Classroom 22				
2-377 022	Admin Building Main Walk Soffit				
2-378 023	Admin Building Main Walk Soffit				
2-151 054	Rooms 1-6 Bldg Attic Classroom 1				
2-151 055	Rooms 1-6 Bldg Attic Classroom 1				
2-152 056	Rooms 1-6 Bldg Attic Classroom 2				
2-152 057	Rooms 1-6 Bldg Attic Classroom 2				
2-153 058	Rooms 1-6 Bldg Attic Classroom 3				
2-153 059	Rooms 1-6 Bldg Attic Classroom 3				
2-154 060	Rooms 1-6 Bldg Attic Classroom 4				
2-154 061	Rooms 1-6 Bldg Attic Classroom 4				
2-155 062	Rooms 1-6 Bldg Attic Classroom 5				
2-155 063	Rooms 1-6 Bldg Attic Classroom 5				
2-156 064	Rooms 1-6 Bldg Attic Classroom 6				
2-156 065	Rooms 1-6 Bldg Attic Classroom 6				
2-126 066	Rooms 1-6 Bldg Attic Room E				
2-396 103	Rooms 7-12 Bldg Attic Classroom 7				
2-396 104	Rooms 7-12 Bldg Attic Classroom 7				
2-397 105	Rooms 7-12 Bldg Attic Classroom 8				
2-397 106	Rooms 7-12 Bldg Attic Classroom 8				
2-398 107	Rooms 7-12 Bldg Attic Classroom 9				
2-398 108	Rooms 7-12 Bldg Attic Classroom 9				
2-399 109	Rooms 7-12 Bldg Attic Classroom 10				
2-399 110	Rooms 7-12 Bldg Attic Classroom 10				
2-400 111	Rooms 7-12 Bldg Attic Classroom 11				
2-400 112	Rooms 7-12 Bldg Attic Classroom 11				
2-401 113	Rooms 7-12 Bldg Attic Classroom 12				
2-401 114	Rooms 7-12 Bldg Attic Classroom 12				
2-382 115	Rooms 7-12 Bldg RR Plumb Chase				
2-383 147	Portables Attic Classroom 14				
2-383 148	Portables Attic Classroom 14				
2-385 149	Portables Attic Classroom 15				
2-385 150	Portables Attic Classroom 15				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-129 151	Portables Attic Classroom 16				
2-130 152	Portables Attic Classroom 17				
2-387 153	Portables Attic Classroom 18				
2-387 154	Portables Attic Classroom 18				
2-386 155	Portables Attic Classroom 19				
2-386 156	Portables Attic Classroom 19				
2-384 157	Portables Attic Classroom 20				
2-384 158	Portables Attic Classroom 20				
2-388 159	Portables Attic Classroom 21				
2-388 160	Portables Attic Classroom 21				
2-381 161	Portables Attic Classroom 23				
2-381 162	Portables Attic Classroom 23				
2-380 163	Portables Attic Classroom 24				
2-380 164	Portables Attic Classroom 24				
2-389 165	Portables Attic Classroom 25				
2-389 166	Portables Attic Classroom 25				
4-134 212	Rooms 26-29 Bldg Attic Classroom 26				
4-132 213	Rooms 26-29 Bldg Attic Classroom 27				
4-130 214	Rooms 26-29 Bldg Attic Classroom 28				
4-126 215	Rooms 26-29 Bldg Attic Classroom 29				
4-127 216	Rooms 26-29 Bldg Attic Classrm 29A				
2-394 231	Rooms C D Bldg Attic Room C				
2-395 232	Rooms C D Bldg Attic Room D				
2-393 233	Rooms C D Bldg Attic Boys RR by C				
2-392 234	Rooms C D Bldg Attic Girls RR by Staff				
2-391 235	Rooms C D Bldg Attic Staff Room				
2-390 236	Rooms C D Bldg Attic Work Room				
2-132 237	Rooms C D Bldg Main Walk Soffit				
2-132 238	Rooms C D Bldg Main Walk Soffit				
2-133 239	Rooms C D Bldg Main Walk Soffit				
2-377 240	Rooms C D Bldg Main Walk Soffit				
2-378 241	Rooms C D Bldg Main Walk Soffit				
2-402 242	Rooms C D Bldg Main Walk Soffit				
2-376 243	Rooms C D Bldg Plumb Chase by Staff				
2-379 244	Rooms C D Bldg Plumb Chs by Rm D				
2-038 266	Multi-Purpose Bldg Kitchen				
2-158 267	Multi-Purpose Bldg Attic South				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-159 268	Multi-Purpose Bldg Attic North				
2-142 269	Multi-Purpose Bldg Attic Stage HVAC				
2-319	Kitchen C02				
2-320	Kitchen C02				
2-321	Kitchen C02.2				
4-1286	Attic Library Rm 29				
4-127	Attic Rm 29A				
4-128	Attic HVAC OS Rm				
4-129	HVAC Attic OS Rm 28				
4-130	Attic Rm 28				
4-131	Attic OS Rm 27				
4-132	Attic Rm 27				
4-133	Attic HVAC OS Rm 26				
4-134	Bldg P Rm 1				
2-166	Attic Rm T1				
2-167	Attic Rm T2				
2-168	Attic Rm T3				
2-169	Attic Rm T4				
2-170	Attic Rm T5				
2-171	Attic Rm T6				
Smoke Detector - Projected Beam					
2-136 270	Multi-Purpose Bldg MP Room Left				
2-140 271	Multi-Purpose Bldg MP Room Right				
Valve Tamper Switch					
2-134	Bldg B OSY				
2-141	Riser E				
2-150	Riser G				
2-157	Riser E				
2-377	Bldg A				
2-380	bldg B				
2-397	Bldg C				
Mechanical, Electrosonic, or Pressure Waterflow Device					
2-140	Riser E				
2-149	Riser G				
2-156	Riser F				
2-376	Bldg A				
2-379	Bldg B				
2-396	Bldg C				
Ventilation and Cooking Equipment					
ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Fusible Links					
	Fusible Link 450 x 4				07/28/2025
Range Hood					
	Kitchen Hood				07/28/2025
Range Suppression					
	Suppression System				07/28/2025
Cooking Equipment					
	Appliances				07/28/2025
Range Suppression Tank					

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
R102 3 Gallon Cylinder					07/28/2025