

Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

LOUIS PASTEUR MIDDLE

8935 ELM AVE
ORANGEVALE, California 95662
United States

This site has been inspected and tested in compliance with applicable standards.

Completed

Wednesday, February 11, 2026

Test Session:09 Feb 2026 15:03 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD
5320 HEMLOCK ST
SACRAMENTO, California
United States

TESTED BY

Riley Goyet
Western States Fire Protection-
Sacramento
188 Cirby Way
Roseville, CA 95678
United States



Inspection Summary

Building Information

PROPERTY	LOUIS PASTEUR MIDDLE	CONTACT
ADDRESS	8935 ELM AVE	PHONE
CITY/STATE	ORANGEVALE, California 95662	MOBILE
COUNTRY	United States	EMAIL

Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us

Testing Summary


EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Alarm Notification Appliance	126	126(100%)	126(100%)	0(0%)
Fire Control Panel	10	10(100%)	10(100%)	0(0%)
Ventilation and Cooking Equipment	4	0(0%)	0(0%)	0(0%)
Initiating Device	389	389(100%)	388(100%)	1(0%)
Chemical Extinguishing Systems	1	0(0%)	0(0%)	0(0%)

Certification

The equipment specified herein was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Wednesday, February 11, 2026

ACCEPTED BY 02/11/2026

Building Representative


TESTED BY 02/11/2026
Riley Goyet
Technician

System Details

Control Units

ADDRESS/ SCAN ADDRESS		DESCRIPTION	Admin Building MDF Room
MANUFACTURER	EST	S/W VERSION	
MODEL	3	LAST UPDATE	
SERIAL NUMBER		S/W LOCATION	
INSTALL DATE			

Open Corrective Action & Solution Summary

The following 5 corrective action(s) remain open following the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
Range Suppression	Suppression System	

Created By: Casey Smith
 Creation Date: 09/05/2025
 Corrective Action: Entire system is not UL300 rated.
 Proposed Solution: Replace Automan, cylinder, cartridge, nozzles, fusible links.
 Manufacturer:
 Model:



Nozzle	Nozzles	
--------	---------	--

Created By: Casey Smith
 Creation Date: 09/05/2025
 Corrective Action: Non UL300 nozzles
 Proposed Solution: Replace all nozzles
 Manufacturer:
 Model:



Range Suppression Tank	3 Gallon Cylinder	
------------------------	-------------------	--

Created By: Casey Smith
 Creation Date: 09/05/2025
 Corrective Action: Non UL300 Cylinder
 Proposed Solution: Replace with new cylinder
 Manufacturer:
 Model:

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
----------------	---------	-------------



Fusible Links	Fusible Links	
---------------	---------------	--

Created By: Casey Smith
 Creation Date: 09/05/2025
 Corrective Action: Did not replace due to system not being UL300
 Proposed Solution: Replace
 Manufacturer:
 Model:

Heat Detector - Restorable Spot	3-382 230	100-Buildings Attic Classroom 105
---------------------------------	--------------	-----------------------------------

Created By: Riley Goyet
 Creation Date: 02/09/2026
 Corrective Action: Heat near cabinets did not report to panel. Stick heat
 Proposed Solution:
 Manufacturer:
 Model:

Testing Details

Alarm Notification Appliance

Passed				
EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible		100-Buildings Boys Locker Entry	Manual	2/9/2026 4:46:35 PM
		Visual inspection	Passed (Manual)	
Visible		100-Buildings Boys Locker Office	Manual	2/9/2026 4:46:31 PM
		Visual inspection	Passed (Manual)	
Audible And Visible		100-Buildings Boys Locker Room	Manual	2/9/2026 4:45:23 PM
		Visual inspection	Passed (Manual)	
Visible		100-Buildings Boys Locker Room	Manual	2/9/2026 4:46:30 PM
		Visual inspection	Passed (Manual)	
Visible		100-Buildings Boys Locker RR	Manual	2/9/2026 4:46:33 PM
		Visual inspection	Passed (Manual)	
Visible		100-Buildings Boys RR by Rm 104	Manual	2/9/2026 4:46:28 PM
		Visual inspection	Passed (Manual)	
Audible And Visible		100-Buildings Classroom 101	Manual	2/9/2026 4:46:02 PM
		Visual inspection	Passed (Manual)	
Audible And Visible		100-Buildings Classroom 102	Manual	2/9/2026 4:45:59 PM
		Visual inspection	Passed (Manual)	
Audible And Visible		100-Buildings Classroom 103	Manual	2/9/2026 4:45:58 PM
		Visual inspection	Passed (Manual)	
Audible And Visible		100-Buildings Classroom 104	Manual	2/9/2026 4:45:56 PM
		Visual inspection	Passed (Manual)	
Audible And Visible		100-Buildings Classroom 105	Manual	2/9/2026 4:45:53 PM
		Visual inspection	Passed (Manual)	
Audible And Visible		100-Buildings Classroom 105	Manual	2/9/2026 4:45:55 PM
		Visual inspection	Passed (Manual)	
Audible And Visible		100-Buildings Classroom 107	Manual	2/9/2026 4:45:51 PM
		Visual inspection	Passed (Manual)	
Audible And Visible		100-Buildings Custodial Office	Manual	2/9/2026 4:45:46 PM
		Visual inspection	Passed (Manual)	
Visible		100-Buildings Custodial Office RR	Manual	2/9/2026 4:47:00 PM
		Visual inspection	Passed (Manual)	
Audible		100-Buildings East Exterior	Manual	2/9/2026 4:46:06 PM
		Visual inspection	Passed (Manual)	
Audible		100-Buildings East Exterior	Manual	2/9/2026 4:46:08 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		100-Buildings East Exterior	Manual	2/9/2026 4:46:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		100-Buildings East Exterior	Manual	2/9/2026 4:46:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		100-Buildings East Exterior	Manual	2/9/2026 4:46:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		100-Buildings Game Room	Manual	2/9/2026 4:45:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		100-Buildings Game Room	Manual	2/9/2026 4:47:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		100-Buildings Girls Locker Entry	Manual	2/9/2026 4:46:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		100-Buildings Girls Locker Office	Manual	2/9/2026 4:46:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		100-Buildings Girls Locker Room	Manual	2/9/2026 4:45:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		100-Buildings Girls Locker Room	Manual	2/9/2026 4:46:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		100-Buildings Girls Locker RR	Manual	2/9/2026 4:46:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		100-Buildings Girls RR by Rm 104	Manual	2/9/2026 4:46:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		100-Buildings Kitchen	Manual	2/9/2026 4:45:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		100-Buildings Kitchen	Manual	2/9/2026 4:46:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		100-Buildings Kitchen Hall	Manual	2/9/2026 4:45:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		100-Buildings Kitchen Office	Manual	2/9/2026 4:46:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		100-Buildings Kitchen Scullery	Manual	2/9/2026 4:46:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		100-Buildings Kitchen Staff RR	Manual	2/9/2026 4:46:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		100-Buildings Kitchen Staff RR	Manual	2/9/2026 4:46:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible		100-Buildings Locker Hall	Manual	2/9/2026 4:45:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		100-Buildings Mens Restroom	Manual	2/9/2026 4:47:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		100-Buildings MP Room	Manual	2/9/2026 4:45:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		100-Buildings MP Room	Manual	2/9/2026 4:45:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		100-Buildings North Exterior	Manual	2/9/2026 4:46:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		100-Buildings Parent Resource Rm	Manual	2/9/2026 4:45:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		100-Buildings Rm 107 Band Office	Manual	2/9/2026 4:46:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		100-Buildings Rm 107 Band Office	Manual	2/9/2026 4:46:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		100-Buildings Room 107 Office Hall	Manual	2/9/2026 4:46:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		100-Buildings Staff RR by Rm 104	Manual	2/9/2026 4:46:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		100-Buildings Stage	Manual	2/9/2026 4:45:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		100-Buildings Stage Stairs	Manual	2/9/2026 4:45:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		100-Buildings West Exterior	Manual	2/9/2026 4:45:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		100-Buildings West Exterior	Manual	2/9/2026 4:46:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		100-Buildings West Exterior	Manual	2/9/2026 4:46:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		100-Buildings Womens Restroom	Manual	2/9/2026 4:47:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		200-Building Boys Restroom	Manual	2/9/2026 4:44:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		200-Building Classroom 201	Manual	2/9/2026 4:45:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		200-Building Classroom 202	Manual	2/9/2026 4:45:11 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	200-Building Classroom 203		Manual	2/9/2026 4:45:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	200-Building Classroom 204		Manual	2/9/2026 4:45:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	200-Building Classroom 205		Manual	2/9/2026 4:45:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	200-Building Classroom 206		Manual	2/9/2026 4:45:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	200-Building Girls Restroom		Manual	2/9/2026 4:45:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	200-Building North Exterior		Manual	2/9/2026 4:45:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	200-Building Project Room		Manual	2/9/2026 4:46:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	200-Building West Exterior		Manual	2/9/2026 4:45:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	300-Building Boys Restroom		Manual	2/9/2026 4:44:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	300-Building Classroom 301		Manual	2/9/2026 4:44:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	300-Building Classroom 302		Manual	2/9/2026 4:44:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	300-Building Classroom 303		Manual	2/9/2026 4:44:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	300-Building Classroom 304		Manual	2/9/2026 4:44:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	300-Building Classroom 305		Manual	2/9/2026 4:44:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	300-Building Classroom 306		Manual	2/9/2026 4:44:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	300-Building Girls Restroom		Manual	2/9/2026 4:44:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	300-Building Project Room		Manual	2/9/2026 4:46:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	300-Building West Exterior		Manual	2/9/2026 4:44:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible		400-Building Classroom 401	Manual	2/9/2026 4:44:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		400-Building Classroom 402	Manual	2/9/2026 4:44:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		400-Building Classroom 403	Manual	2/9/2026 4:44:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		400-Building Classroom 404	Manual	2/9/2026 4:44:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		400-Building North Exterior	Manual	2/9/2026 4:44:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		400-Building South Exterior	Manual	2/9/2026 4:44:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		500-Building Boys Restroom	Manual	2/9/2026 4:44:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		500-Building Classroom 501	Manual	2/9/2026 4:44:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		500-Building Classroom 502	Manual	2/9/2026 4:44:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		500-Building Classroom 503	Manual	2/9/2026 4:44:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		500-Building Classroom 504	Manual	2/9/2026 4:44:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		500-Building Classroom 505	Manual	2/9/2026 4:44:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		500-Building Classroom 506	Manual	2/9/2026 4:44:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		500-Building East Exterior	Manual	2/9/2026 4:44:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		500-Building Girls Restroom	Manual	2/9/2026 4:44:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		500-Building North Exterior	Manual	2/9/2026 4:44:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		500-Building Project Room	Manual	2/9/2026 4:46:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		500-Building West Exterior	Manual	2/9/2026 4:44:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		600-Building Boys Restroom	Manual	2/9/2026 4:43:52 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	600-Building Classroom 601		Manual	2/9/2026 4:44:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	600-Building Classroom 602		Manual	2/9/2026 4:44:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	600-Building Classroom 603		Manual	2/9/2026 4:44:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	600-Building Classroom 604		Manual	2/9/2026 4:43:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	600-Building Classroom 605		Manual	2/9/2026 4:43:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	600-Building Classroom 606		Manual	2/9/2026 4:43:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	600-Building East Exterior		Manual	2/9/2026 4:44:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	600-Building Girls Restroom		Manual	2/9/2026 4:43:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	600-Building Project Room		Manual	2/9/2026 4:46:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	600-Building West Exterior		Manual	2/9/2026 4:44:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	700-Building Classroom 701		Manual	2/9/2026 4:43:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	700-Building Classroom 702		Manual	2/9/2026 4:43:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	700-Building Classroom 703		Manual	2/9/2026 4:43:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	700-Building Classroom 704		Manual	2/9/2026 4:43:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	700-Building East Exterior		Manual	2/9/2026 4:43:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	700-Building West Exterior		Manual	2/9/2026 4:43:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	Admin Building Attendance Nurse Rm		Manual	2/9/2026 4:47:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	Admin Building Attendance Office		Manual	2/9/2026 4:43:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible		Admin Building Copy Room	Manual	2/9/2026 4:43:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Admin Building Counselors Office	Manual	2/9/2026 4:46:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Admin Building East Exterior	Manual	2/9/2026 4:43:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Admin Building Hall by Restrooms	Manual	2/9/2026 4:47:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Admin Building Mens Restroom	Manual	2/9/2026 4:47:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Admin Building Mens Restroom	Manual	2/9/2026 4:47:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Admin Building North Exterior	Manual	2/9/2026 4:43:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Admin Building Off By Staff Breakrm	Manual	2/9/2026 4:43:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Admin Building Office by Reception	Manual	2/9/2026 4:47:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Admin Building Office by VP Office	Manual	2/9/2026 4:47:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Admin Building Principals Office	Manual	2/9/2026 4:43:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Admin Building Recep Staff Breakrm	Manual	2/9/2026 4:47:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Admin Building Reception	Manual	2/9/2026 4:43:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Admin Building South Exterior	Manual	2/9/2026 4:43:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Admin Building VP Office	Manual	2/9/2026 4:47:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Admin Building Womens Restroom	Manual	2/9/2026 4:47:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Admin Building Womens Restroom	Manual	2/9/2026 4:47:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Chemical Extinguishing Systems

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
----------------	---------	-------------	--------	-----------

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Nozzle	Nozzles		Manual	2/9/2026 3:17:28 PM

Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
NAC Power Extender Panel		100-Buildings Kitchen Staff RR - BPS "G"	Manual	2/9/2026 6:35:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		100-Buildings Portable Room 104 - BPS "I"	Manual	2/9/2026 6:35:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		100-Buildings Rm 107 Band Choir - BPS "H"	Manual	2/9/2026 6:35:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		200-Building Custodial Closet - BPS "C"	Manual	2/9/2026 6:35:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		300-Building Custodial Closet - BPS "F"	Manual	2/9/2026 6:35:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		500-Building Custodial Closet - BPS "D"	Manual	2/9/2026 6:35:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		600-Building Custodial Closet - BPS "E"	Manual	2/9/2026 6:35:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Fire Alarm Panel		Admin Building MDF Room	Manual	2/9/2026 6:42:19 PM
		Manufacturer	EST	
		Model	3	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Admin Building MDF Room - BPS "B"	Manual	2/9/2026 6:35:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Remote Annunciator		Admin Building Reception	Manual	2/9/2026 6:42:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	3-380 216	100-Buildings Attic Boys Locker Rm	Manual	2/9/2026 8:10:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-380 217	100-Buildings Attic Boys Locker Rm	Manual	2/9/2026 8:10:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-383 233	100-Buildings Attic Boys Restroom	Manual	2/9/2026 7:49:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-385	100-Buildings Attic Classroom 103	Manual	2/9/2026 7:18:34 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-385 219	100-Buildings Attic Classroom 103	Manual	2/9/2026 7:18:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-385 220	100-Buildings Attic Classroom 103	Manual	2/9/2026 7:18:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-384 221	100-Buildings Attic Classroom 104	Manual	2/9/2026 7:28:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-384 222	100-Buildings Attic Classroom 104	Manual	2/9/2026 7:28:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-382 223	100-Buildings Attic Classroom 105	Manual	2/9/2026 7:44:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-382 224	100-Buildings Attic Classroom 105	Manual	2/9/2026 7:44:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-382 225	100-Buildings Attic Classroom 105	Manual	2/9/2026 7:45:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-382 226	100-Buildings Attic Classroom 105	Manual	2/9/2026 7:45:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-382 227	100-Buildings Attic Classroom 105	Manual	2/9/2026 7:45:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-382 228	100-Buildings Attic Classroom 105	Manual	2/9/2026 7:45:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-382 229	100-Buildings Attic Classroom 105	Manual	2/9/2026 7:45:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-126 206	100-Buildings Attic Faculty Entry	Manual	2/9/2026 7:58:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-378 214	100-Buildings Attic Girls Locker Rm	Manual	2/9/2026 8:10:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-378 213	100-Buildings Attic Girls Locker Rm	Manual	2/9/2026 8:10:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-383 231	100-Buildings Attic Girls Restroom	Manual	2/9/2026 7:58:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-127 207	100-Buildings Attic Kitchen	Manual	2/9/2026 7:18:48 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-206 209	100-Buildings Attic Kitchen Staff	Manual	2/9/2026 7:18:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-206 208	100-Buildings Attic Kitchen Staff	Manual	2/9/2026 7:49:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-207 210	100-Buildings Attic Rm 107 Band	Manual	2/9/2026 7:49:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-131 212	100-Buildings Attic Rm 107 Office	Manual	2/9/2026 7:49:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-130 211	100-Buildings Attic Rm 107 Office	Manual	2/9/2026 7:49:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-383 232	100-Buildings Attic Staff Restroom	Manual	2/9/2026 7:49:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-283 190	100-Buildings Ball Room	Manual	2/9/2026 5:36:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-282 189	100-Buildings Ball Room	Manual	2/9/2026 5:36:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-071 205	100-Buildings Boiler Room	Manual	2/9/2026 8:17:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	3-136 236	100-Buildings Boiler Room	Manual	2/9/2026 6:35:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-287 171	100-Buildings Boys Locker Entry	Manual	2/9/2026 5:02:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-277 185	100-Buildings Boys Locker Office	Manual	2/9/2026 5:03:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-286 186	100-Buildings Boys Locker Office Storage	Manual	2/9/2026 5:03:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-278 174	100-Buildings Boys Locker Room	Manual	2/9/2026 5:03:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-279 175	100-Buildings Boys Locker Room	Manual	2/9/2026 5:03:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-280 176	100-Buildings Boys Locker Room	Manual	2/9/2026 5:03:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-284 177	100-Buildings Boys Locker Room	Manual	2/9/2026 5:03:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-285 178	100-Buildings Boys Locker Room	Manual	2/9/2026 5:03:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-275 179	100-Buildings Boys Locker Room	Manual	2/9/2026 5:03:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-274 180	100-Buildings Boys Locker Room	Manual	2/9/2026 5:03:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-273 181	100-Buildings Boys Locker Room	Manual	2/9/2026 5:03:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-272 182	100-Buildings Boys Locker Room	Manual	2/9/2026 5:03:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-271 183	100-Buildings Boys Locker Room	Manual	2/9/2026 5:03:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-270 184	100-Buildings Boys Locker Room	Manual	2/9/2026 5:03:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-288 172	100-Buildings Boys Locker RR	Manual	2/9/2026 5:02:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-289 173	100-Buildings Boys Locker RR	Manual	2/9/2026 5:03:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-276 187	100-Buildings Boys Locker Storage	Manual	2/9/2026 5:02:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-296 199	100-Buildings Boys RR by Rm 104	Manual	2/9/2026 5:35:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-008 075	100-Buildings Classroom 101 Display	Manual	2/9/2026 5:36:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-009 065	100-Buildings Classroom 101 Shop	Manual	2/9/2026 5:33:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-010 066	100-Buildings Classroom 101 Shop	Manual	2/9/2026 5:34:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-011 067	100-Buildings Classroom 101 Shop	Manual	2/9/2026 5:34:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-012 068	100-Buildings Classroom 101 Shop	Manual	2/9/2026 5:34:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-013 069	100-Buildings Classroom 101 Shop	Manual	2/9/2026 5:34:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-016 070	100-Buildings Classroom 101 Shop	Manual	2/9/2026 5:34:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-018 072	100-Buildings Classroom 101 Shop	Manual	2/9/2026 5:34:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-017 071	100-Buildings Classroom 101 Shop	Manual	2/9/2026 5:34:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-014 074	100-Buildings Classroom 101 Storage	Manual	2/9/2026 5:34:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-015 073	100-Buildings Classroom 101 Storage	Manual	2/9/2026 5:34:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-021 083	100-Buildings Classroom 102 Art	Manual	2/9/2026 5:34:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-022 082	100-Buildings Classroom 102 Art	Manual	2/9/2026 5:34:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-023 081	100-Buildings Classroom 102 Art	Manual	2/9/2026 5:34:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-024 080	100-Buildings Classroom 102 Art	Manual	2/9/2026 5:34:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-004 079	100-Buildings Classroom 102 Art	Manual	2/9/2026 5:34:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-005 078	100-Buildings Classroom 102 Art	Manual	2/9/2026 5:34:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-006 077	100-Buildings Classroom 102 Art	Manual	2/9/2026 5:34:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-007 076	100-Buildings Classroom 102 Art	Manual	2/9/2026 5:34:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-026 084	100-Buildings Classroom 102 Storage	Manual	2/9/2026 5:35:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-025 085	100-Buildings Classroom 102 Storage	Manual	2/9/2026 5:35:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-019 086	100-Buildings Classrooms 101 & 102 Storage	Manual	2/9/2026 5:34:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-020 087	100-Buildings Classrooms 101 & 102 Storage	Manual	2/9/2026 5:34:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-046 104	100-Buildings Custodial Office	Manual	2/9/2026 5:35:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-045 103	100-Buildings Custodial Office	Manual	2/9/2026 5:35:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-044 102	100-Buildings Custodial Office	Manual	2/9/2026 5:35:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-043 105	100-Buildings Custodial Office RR	Manual	2/9/2026 5:35:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-379 235	100-Buildings Duct Boys Locker	Manual	2/9/2026 8:17:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-377 234	100-Buildings Duct Girls Locker	Manual	2/9/2026 8:17:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-035 093	100-Buildings Faculty Lounge	Manual	2/9/2026 5:34:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-036 094	100-Buildings Faculty Lounge	Manual	2/9/2026 5:34:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-037 095	100-Buildings Faculty Lounge	Manual	2/9/2026 5:34:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-032 096	100-Buildings Faculty Lounge	Manual	2/9/2026 5:34:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-033 097	100-Buildings Faculty Lounge	Manual	2/9/2026 5:34:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-034 098	100-Buildings Faculty Lounge	Manual	2/9/2026 5:34:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-029 099	100-Buildings Faculty Lounge	Manual	2/9/2026 5:34:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-030 100	100-Buildings Faculty Lounge	Manual	2/9/2026 5:34:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-031 101	100-Buildings Faculty Lounge	Manual	2/9/2026 5:34:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-028 092	100-Buildings Faculty Lounge Closet	Manual	2/9/2026 5:34:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-027 091	100-Buildings Faculty Lounge Entry	Manual	2/9/2026 5:34:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-255 154	100-Buildings Girls Locker Entry	Manual	2/9/2026 5:04:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-262 168	100-Buildings Girls Locker Office	Manual	2/9/2026 5:03:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-256 169	100-Buildings Girls Locker Office Storage	Manual	2/9/2026 5:03:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-269 167	100-Buildings Girls Locker Room	Manual	2/9/2026 5:03:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-264 166	100-Buildings Girls Locker Room	Manual	2/9/2026 5:03:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-265 165	100-Buildings Girls Locker Room	Manual	2/9/2026 5:03:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-266 164	100-Buildings Girls Locker Room	Manual	2/9/2026 5:03:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-267 163	100-Buildings Girls Locker Room	Manual	2/9/2026 5:03:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-268 162	100-Buildings Girls Locker Room	Manual	2/9/2026 5:03:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-261 161	100-Buildings Girls Locker Room	Manual	2/9/2026 5:03:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-260 160	100-Buildings Girls Locker Room	Manual	2/9/2026 5:03:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-259 159	100-Buildings Girls Locker Room	Manual	2/9/2026 5:04:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-258 158	100-Buildings Girls Locker Room	Manual	2/9/2026 5:04:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-257 157	100-Buildings Girls Locker Room	Manual	2/9/2026 5:04:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-253 156	100-Buildings Girls Locker RR	Manual	2/9/2026 5:04:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-254 155	100-Buildings Girls Locker RR	Manual	2/9/2026 5:04:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-263 170	100-Buildings Girls Locker Storage	Manual	2/9/2026 5:03:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-294 201	100-Buildings Girls RR by Rm 104	Manual	2/9/2026 5:35:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-047 202	100-Buildings Kitchen	Manual	2/9/2026 6:36:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-049 203	100-Buildings Kitchen	Manual	2/9/2026 6:36:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-040 107	100-Buildings Kitchen Hall	Manual	2/9/2026 5:34:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-038 106	100-Buildings Kitchen Office	Manual	2/9/2026 5:35:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-048 204	100-Buildings Kitchen Scullery	Manual	2/9/2026 6:36:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-041 109	100-Buildings Kitchen Staff RR	Manual	2/9/2026 5:34:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-042 110	100-Buildings Kitchen Staff RR	Manual	2/9/2026 5:34:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-051 112	100-Buildings Kitchen Storage	Manual	2/9/2026 5:35:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-050 111	100-Buildings Kitchen Storage	Manual	2/9/2026 5:35:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-039 108	100-Buildings Kitchen Storage	Manual	2/9/2026 5:35:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Manual Pull Station	3-128 064	100-Buildings Kitchen West	Manual	2/9/2026 6:31:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-281 188	100-Buildings Loaner Room	Manual	2/9/2026 5:36:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-251 152	100-Buildings Locker Hall	Manual	2/9/2026 5:04:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-252 153	100-Buildings Locker Hall	Manual	2/9/2026 5:04:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-001 088	100-Buildings Mens Restroom	Manual	2/9/2026 5:34:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-073 129	100-Buildings MP Rm Chair Storage	Manual	2/9/2026 5:13:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-077 128	100-Buildings MP Rm Chair Storage	Manual	2/9/2026 5:13:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-076 127	100-Buildings MP Rm Chair Storage	Manual	2/9/2026 5:13:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-072 132	100-Buildings MP Rm Stage Stairs	Manual	2/9/2026 5:13:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-074 131	100-Buildings MP Rm Stage Stairs	Manual	2/9/2026 5:13:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-075 130	100-Buildings MP Rm Stage Stairs	Manual	2/9/2026 5:13:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-091 114	100-Buildings MP Room	Manual	2/9/2026 5:13:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-087 118	100-Buildings MP Room	Manual	2/9/2026 5:13:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-083 122	100-Buildings MP Room	Manual	2/9/2026 5:13:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-081 123	100-Buildings MP Room	Manual	2/9/2026 5:13:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-079 126	100-Buildings MP Room	Manual	2/9/2026 5:13:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-078 125	100-Buildings MP Room	Manual	2/9/2026 5:13:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-089 115	100-Buildings MP Room	Manual	2/9/2026 5:13:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-085 119	100-Buildings MP Room	Manual	2/9/2026 5:13:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-080 124	100-Buildings MP Room	Manual	2/9/2026 5:13:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-082 121	100-Buildings MP Room	Manual	2/9/2026 5:13:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-084 120	100-Buildings MP Room	Manual	2/9/2026 5:13:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-086 117	100-Buildings MP Room	Manual	2/9/2026 5:13:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-088 116	100-Buildings MP Room	Manual	2/9/2026 5:13:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-090 113	100-Buildings MP Room	Manual	2/9/2026 5:13:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-134 063	100-Buildings MP Room NE	Manual	2/9/2026 6:31:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-135 062	100-Buildings MP Room SE	Manual	2/9/2026 6:31:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-064 138	100-Buildings MP Room Stage	Manual	2/9/2026 5:13:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-063 137	100-Buildings MP Room Stage	Manual	2/9/2026 5:13:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-062 136	100-Buildings MP Room Stage	Manual	2/9/2026 5:13:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-065 135	100-Buildings MP Room Stage	Manual	2/9/2026 5:13:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-066 134	100-Buildings MP Room Stage	Manual	2/9/2026 5:13:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-067 133	100-Buildings MP Room Stage	Manual	2/9/2026 5:13:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-133 061	100-Buildings MP Room SW	Manual	2/9/2026 6:31:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Valve Tamper Switch	3-137 237	100-Buildings OS&Y Boiler Room	Manual	2/9/2026 6:42:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-381 218	100-Buildings Plumbing Chase Boys Locker RR	Manual	2/9/2026 6:42:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-376 215	100-Buildings Plumbing Chase Girls Locker RR	Manual	2/9/2026 6:42:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-300 191	100-Buildings Portable Room 103	Manual	2/9/2026 5:35:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-299 192	100-Buildings Portable Room 103	Manual	2/9/2026 5:35:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-298 193	100-Buildings Portable Room 104	Manual	2/9/2026 5:35:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-297 194	100-Buildings Portable Room 104	Manual	2/9/2026 5:35:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-293 197	100-Buildings Portable Room 105	Manual	2/9/2026 5:35:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-292 198	100-Buildings Portable Room 105	Manual	2/9/2026 5:35:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-290 196	100-Buildings Portable Room 105	Manual	2/9/2026 5:35:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-291 195	100-Buildings Portable Room 105	Manual	2/9/2026 5:35:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-052 142	100-Buildings Rm 107 Band Choir	Manual	2/9/2026 5:35:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-053 143	100-Buildings Rm 107 Band Choir	Manual	2/9/2026 5:35:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-054 144	100-Buildings Rm 107 Band Choir	Manual	2/9/2026 5:35:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-057 145	100-Buildings Rm 107 Band Choir	Manual	2/9/2026 5:35:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-056 146	100-Buildings Rm 107 Band Choir	Manual	2/9/2026 5:35:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-055 147	100-Buildings Rm 107 Band Choir	Manual	2/9/2026 5:35:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-058 149	100-Buildings Rm 107 Band Office	Manual	2/9/2026 5:35:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-061 150	100-Buildings Rm 107 Band Office	Manual	2/9/2026 5:35:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-059 148	100-Buildings Room 107 Office Hall	Manual	2/9/2026 5:35:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-060 151	100-Buildings Room 107 Office Storage	Manual	2/9/2026 5:35:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-295 200	100-Buildings Staff RR by Rm 104	Manual	2/9/2026 5:35:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-069 140	100-Buildings Stage Storage	Manual	2/9/2026 5:35:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-070 139	100-Buildings Stage Storage	Manual	2/9/2026 5:35:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-068 141	100-Buildings Stage Storage	Manual	2/9/2026 5:35:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-002 089	100-Buildings Womens Restroom	Manual	2/9/2026 5:34:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-003 090	100-Buildings Womens Restroom	Manual	2/9/2026 5:34:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-133 322	200-Building Attic Classroom 201	Manual	2/9/2026 7:58:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-132 321	200-Building Attic Classroom 201	Manual	2/9/2026 7:58:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-131 323	200-Building Attic Project Room	Manual	2/9/2026 7:58:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-034 320	200-Building Boys Restroom	Manual	2/9/2026 4:37:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-061 292	200-Building Classroom 201	Manual	2/9/2026 4:38:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-060 293	200-Building Classroom 201	Manual	2/9/2026 4:38:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-059 294	200-Building Classroom 201	Manual	2/9/2026 4:38:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-058 295	200-Building Classroom 201	Manual	2/9/2026 4:38:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-057 300	200-Building Classroom 202	Manual	2/9/2026 4:38:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-056 299	200-Building Classroom 202	Manual	2/9/2026 4:38:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-055 298	200-Building Classroom 202	Manual	2/9/2026 4:38:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-054 297	200-Building Classroom 202	Manual	2/9/2026 4:38:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-051 301	200-Building Classroom 203	Manual	2/9/2026 4:38:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-052 302	200-Building Classroom 203	Manual	2/9/2026 4:38:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-053 303	200-Building Classroom 203	Manual	2/9/2026 4:38:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-050 304	200-Building Classroom 203	Manual	2/9/2026 4:38:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-036 308	200-Building Classroom 204	Manual	2/9/2026 4:37:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-037 307	200-Building Classroom 204	Manual	2/9/2026 4:37:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-038 306	200-Building Classroom 204	Manual	2/9/2026 4:37:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-039 305	200-Building Classroom 204	Manual	2/9/2026 4:37:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-041 309	200-Building Classroom 204 Storage	Manual	2/9/2026 4:37:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-043 310	200-Building Classroom 205	Manual	2/9/2026 4:38:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-044 311	200-Building Classroom 205	Manual	2/9/2026 4:38:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-045 312	200-Building Classroom 205	Manual	2/9/2026 4:38:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-042 313	200-Building Classroom 205	Manual	2/9/2026 4:38:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-049 317	200-Building Classroom 206	Manual	2/9/2026 4:38:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-048 316	200-Building Classroom 206	Manual	2/9/2026 4:38:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-047 315	200-Building Classroom 206	Manual	2/9/2026 4:38:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-046 314	200-Building Classroom 206	Manual	2/9/2026 4:38:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-033 319	200-Building Custodial Closet	Manual	2/9/2026 4:37:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-035 318	200-Building Girls Restroom	Manual	2/9/2026 4:37:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-040 296	200-Building Project Room	Manual	2/9/2026 4:38:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-130 324	200-Building RR Plumbing Chase	Manual	2/9/2026 6:42:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-380 366	300-Building Attic Project Room	Manual	2/9/2026 8:10:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-300 365	300-Building Boys Restroom	Manual	2/9/2026 4:37:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-326 337	300-Building Classroom 301	Manual	2/9/2026 4:37:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-325 338	300-Building Classroom 301	Manual	2/9/2026 4:37:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-324 339	300-Building Classroom 301	Manual	2/9/2026 4:37:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-323 340	300-Building Classroom 301	Manual	2/9/2026 4:37:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-322 345	300-Building Classroom 302	Manual	2/9/2026 4:37:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-321 344	300-Building Classroom 302	Manual	2/9/2026 4:37:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-320 343	300-Building Classroom 302	Manual	2/9/2026 4:37:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-319 342	300-Building Classroom 302	Manual	2/9/2026 4:37:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-316 346	300-Building Classroom 303	Manual	2/9/2026 4:36:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-317 347	300-Building Classroom 303	Manual	2/9/2026 4:36:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-318 348	300-Building Classroom 303	Manual	2/9/2026 4:36:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-315 349	300-Building Classroom 303	Manual	2/9/2026 4:36:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-301 353	300-Building Classroom 304	Manual	2/9/2026 4:37:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-303 351	300-Building Classroom 304	Manual	2/9/2026 4:37:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-302 352	300-Building Classroom 304	Manual	2/9/2026 4:37:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-304 350	300-Building Classroom 304	Manual	2/9/2026 4:37:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-306 354	300-Building Classroom 304 Storage	Manual	2/9/2026 4:37:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-310 357	300-Building Classroom 305	Manual	2/9/2026 4:36:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-308 355	300-Building Classroom 305	Manual	2/9/2026 4:36:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-307 358	300-Building Classroom 305	Manual	2/9/2026 4:37:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-309 356	300-Building Classroom 305	Manual	2/9/2026 4:37:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-314 362	300-Building Classroom 306	Manual	2/9/2026 4:36:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-313 361	300-Building Classroom 306	Manual	2/9/2026 4:36:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-312 360	300-Building Classroom 306	Manual	2/9/2026 4:36:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-311 359	300-Building Classroom 306	Manual	2/9/2026 4:36:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-298 364	300-Building Custodial Closet	Manual	2/9/2026 4:37:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-299 363	300-Building Girls Restroom	Manual	2/9/2026 4:37:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-305 341	300-Building Project Room	Manual	2/9/2026 4:37:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-379 367	300-Building RR Plumbing Chase	Manual	2/9/2026 6:42:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-265 382	400-Building Classroom 401	Manual	2/9/2026 4:39:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-268 381	400-Building Classroom 401	Manual	2/9/2026 4:39:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-267 380	400-Building Classroom 401	Manual	2/9/2026 4:39:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-266 379	400-Building Classroom 401	Manual	2/9/2026 4:39:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-262 386	400-Building Classroom 402	Manual	2/9/2026 4:38:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-261 385	400-Building Classroom 402	Manual	2/9/2026 4:38:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-260 384	400-Building Classroom 402	Manual	2/9/2026 4:38:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-259 383	400-Building Classroom 402	Manual	2/9/2026 4:38:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-263 388	400-Building Classroom 402 Storage	Manual	2/9/2026 4:38:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-264 387	400-Building Classroom 402 Storage	Manual	2/9/2026 4:38:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-254 392	400-Building Classroom 403	Manual	2/9/2026 4:39:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-253 391	400-Building Classroom 403	Manual	2/9/2026 4:39:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-252 390	400-Building Classroom 403	Manual	2/9/2026 4:39:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-251 389	400-Building Classroom 403	Manual	2/9/2026 4:39:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-255 396	400-Building Classroom 404	Manual	2/9/2026 4:39:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-257 395	400-Building Classroom 404	Manual	2/9/2026 4:39:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-256 394	400-Building Classroom 404	Manual	2/9/2026 4:39:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-258 393	400-Building Classroom 404	Manual	2/9/2026 4:39:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-135 432	500-Building Attic Project Room	Manual	2/9/2026 7:58:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-064 431	500-Building Boys Restroom	Manual	2/9/2026 4:40:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-065 406	500-Building Classroom 501	Manual	2/9/2026 4:40:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-068 404	500-Building Classroom 501	Manual	2/9/2026 4:40:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-066 405	500-Building Classroom 501	Manual	2/9/2026 4:40:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-067 403	500-Building Classroom 501	Manual	2/9/2026 4:40:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-073 408	500-Building Classroom 502	Manual	2/9/2026 4:39:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-074 409	500-Building Classroom 502	Manual	2/9/2026 4:39:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-072 410	500-Building Classroom 502	Manual	2/9/2026 4:40:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-071 411	500-Building Classroom 502	Manual	2/9/2026 4:40:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-078 416	500-Building Classroom 503	Manual	2/9/2026 4:39:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-077 415	500-Building Classroom 503	Manual	2/9/2026 4:39:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-076 414	500-Building Classroom 503	Manual	2/9/2026 4:39:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-075 413	500-Building Classroom 503	Manual	2/9/2026 4:39:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-087 420	500-Building Classroom 504	Manual	2/9/2026 4:40:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-088 419	500-Building Classroom 504	Manual	2/9/2026 4:40:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-089 418	500-Building Classroom 504	Manual	2/9/2026 4:40:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-090 417	500-Building Classroom 504	Manual	2/9/2026 4:40:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-083 421	500-Building Classroom 505	Manual	2/9/2026 4:39:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-084 422	500-Building Classroom 505	Manual	2/9/2026 4:39:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-086 423	500-Building Classroom 505	Manual	2/9/2026 4:39:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-085 424	500-Building Classroom 505	Manual	2/9/2026 4:39:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-079 428	500-Building Classroom 506	Manual	2/9/2026 4:39:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-082 427	500-Building Classroom 506	Manual	2/9/2026 4:39:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-081 426	500-Building Classroom 506	Manual	2/9/2026 4:39:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-080 425	500-Building Classroom 506	Manual	2/9/2026 4:39:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-062 430	500-Building Custodial Closet	Manual	2/9/2026 4:40:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-063 429	500-Building Girls Restroom	Manual	2/9/2026 4:40:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-069 412	500-Building Project Room	Manual	2/9/2026 4:40:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-070 407	500-Building Room 501A Storage	Manual	2/9/2026 4:40:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-134 433	500-Building RR Plumbing Chase	Manual	2/9/2026 6:42:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-378 476	600-Building Attic Project Room	Manual	2/9/2026 7:58:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-271 475	600-Building Boys Restroom	Manual	2/9/2026 4:41:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-272 450	600-Building Classroom 601	Manual	2/9/2026 4:41:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-273 449	600-Building Classroom 601	Manual	2/9/2026 4:41:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-275 448	600-Building Classroom 601	Manual	2/9/2026 4:41:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-274 447	600-Building Classroom 601	Manual	2/9/2026 4:41:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-279 452	600-Building Classroom 602	Manual	2/9/2026 4:40:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-280 453	600-Building Classroom 602	Manual	2/9/2026 4:40:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-281 454	600-Building Classroom 602	Manual	2/9/2026 4:40:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-278 455	600-Building Classroom 602	Manual	2/9/2026 4:40:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-282 457	600-Building Classroom 603	Manual	2/9/2026 4:40:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-283 458	600-Building Classroom 603	Manual	2/9/2026 4:41:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-284 459	600-Building Classroom 603	Manual	2/9/2026 4:41:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-285 460	600-Building Classroom 603	Manual	2/9/2026 4:41:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-294 461	600-Building Classroom 604	Manual	2/9/2026 4:40:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-295 462	600-Building Classroom 604	Manual	2/9/2026 4:41:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-296 463	600-Building Classroom 604	Manual	2/9/2026 4:41:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-297 464	600-Building Classroom 604	Manual	2/9/2026 4:41:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-290 465	600-Building Classroom 605	Manual	2/9/2026 4:41:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-291 466	600-Building Classroom 605	Manual	2/9/2026 4:41:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-292 467	600-Building Classroom 605	Manual	2/9/2026 4:41:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-293 468	600-Building Classroom 605	Manual	2/9/2026 4:41:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-289 470	600-Building Classroom 606	Manual	2/9/2026 4:41:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-288 471	600-Building Classroom 606	Manual	2/9/2026 4:41:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-287 472	600-Building Classroom 606	Manual	2/9/2026 4:41:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-286 469	600-Building Classroom 606	Manual	2/9/2026 4:41:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-269 474	600-Building Custodial Closet	Manual	2/9/2026 4:41:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-270 473	600-Building Girls Restroom	Manual	2/9/2026 4:40:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-276 456	600-Building Project Room	Manual	2/9/2026 4:41:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-277 451	600-Building Room 601A Storage	Manual	2/9/2026 4:41:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-377 477	600-Building RR Plumbing Chase	Manual	2/9/2026 6:41:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-091 490	700-Building Classroom 701	Manual	2/9/2026 4:42:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-092 491	700-Building Classroom 701	Manual	2/9/2026 4:42:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-093 492	700-Building Classroom 701	Manual	2/9/2026 4:42:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-094 493	700-Building Classroom 701	Manual	2/9/2026 4:42:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-095 494	700-Building Classroom 701	Manual	2/9/2026 4:42:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-096 495	700-Building Classroom 702	Manual	2/9/2026 4:42:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-097 496	700-Building Classroom 702	Manual	2/9/2026 4:42:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-098 497	700-Building Classroom 702	Manual	2/9/2026 4:42:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-099 498	700-Building Classroom 702	Manual	2/9/2026 4:42:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-100 499	700-Building Classroom 702	Manual	2/9/2026 4:42:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-106 505	700-Building Classroom 703	Manual	2/9/2026 4:42:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-105 504	700-Building Classroom 703	Manual	2/9/2026 4:42:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-104 503	700-Building Classroom 703	Manual	2/9/2026 4:42:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-103 502	700-Building Classroom 703	Manual	2/9/2026 4:42:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-102 501	700-Building Classroom 703	Manual	2/9/2026 4:42:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-101 500	700-Building Classroom 703	Manual	2/9/2026 4:42:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-107 506	700-Building Classroom 703 Storage	Manual	2/9/2026 4:42:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-111 512	700-Building Classroom 704	Manual	2/9/2026 4:42:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-112 511	700-Building Classroom 704	Manual	2/9/2026 4:42:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-113 510	700-Building Classroom 704	Manual	2/9/2026 4:42:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-114 509	700-Building Classroom 704	Manual	2/9/2026 4:42:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-115 508	700-Building Classroom 704	Manual	2/9/2026 4:42:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-116 507	700-Building Classroom 704	Manual	2/9/2026 4:42:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-108 513	700-Building Classroom 704A Storage	Manual	2/9/2026 4:42:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-110 515	700-Building Classroom 704B Storage	Manual	2/9/2026 4:41:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-109 514	700-Building Classroom 704B Storage	Manual	2/9/2026 4:42:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-031 019	Admin Building Attendance Nurse Rm	Manual	2/9/2026 4:34:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-032 017	Admin Building Attendance Office	Manual	2/9/2026 4:34:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-030 018	Admin Building Attendance Office	Manual	2/9/2026 4:34:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-002 014	Admin Building Attendance Storage	Manual	2/9/2026 4:34:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-003 015	Admin Building Attendance Storage	Manual	2/9/2026 4:34:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-127 037	Admin Building Attic Office by VP Off	Manual	2/9/2026 7:58:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-027 022	Admin Building Copy Room	Manual	2/9/2026 4:34:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-028 021	Admin Building Copy Room	Manual	2/9/2026 4:34:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-029 020	Admin Building Copy Room Storage	Manual	2/9/2026 4:35:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-006 033	Admin Building Counselors Office	Manual	2/9/2026 4:34:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-007 034	Admin Building Counselors Office	Manual	2/9/2026 4:34:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-018 026	Admin Building Custodial Closet	Manual	2/9/2026 4:34:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-019 023	Admin Building Hall by Restrooms	Manual	2/9/2026 4:35:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-129 040	Admin Building HVAC Chase	Manual	2/9/2026 8:20:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-129 039	Admin Building HVAC Chase	Manual	2/9/2026 8:20:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-129 038	Admin Building HVAC Chase	Manual	2/9/2026 8:21:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-001 016	Admin Building MDF Room	Manual	2/9/2026 3:06:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-126 035	Admin Building Mechanical Room	Manual	2/9/2026 8:21:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-126 036	Admin Building Mechanical Room	Manual	2/9/2026 8:21:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-025 025	Admin Building Mens Restroom	Manual	2/9/2026 4:34:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-026 024	Admin Building Mens Restroom	Manual	2/9/2026 4:34:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-017 032	Admin Building Office by Reception	Manual	2/9/2026 4:34:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-008 011	Admin Building Office By Staff Breakrm	Manual	2/9/2026 4:34:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-005 012	Admin Building Office By Staff Breakrm	Manual	2/9/2026 4:34:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-004 013	Admin Building Office By Staff Breakrm	Manual	2/9/2026 4:34:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-010 008	Admin Building Office by VP Office	Manual	2/9/2026 4:34:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-020 029	Admin Building Principals Office	Manual	2/9/2026 4:35:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-022 030	Admin Building Principals Office	Manual	2/9/2026 4:35:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-021 031	Admin Building Principals Office	Manual	2/9/2026 4:35:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-014 010	Admin Building Recep Staff Breakrm	Manual	2/9/2026 4:34:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-128 002	Admin Building Reception	Manual	2/9/2026 6:31:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-013 005	Admin Building Reception	Manual	2/9/2026 4:34:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-015 004	Admin Building Reception	Manual	2/9/2026 4:34:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-016 003	Admin Building Reception	Manual	2/9/2026 4:34:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-009 009	Admin Building Reception Storage	Manual	2/9/2026 4:35:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-012 007	Admin Building VP Office	Manual	2/9/2026 4:34:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-011 006	Admin Building VP Office	Manual	2/9/2026 4:34:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-024 028	Admin Building Womens Restroom	Manual	2/9/2026 4:34:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-023 027	Admin Building Womens Restroom	Manual	2/9/2026 4:35:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-376 522	Boiler/Chiller Bldg - Boiler/Chiller Room	Manual	2/9/2026 7:54:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-376 523	Boiler/Chiller Bldg - Boiler/Chiller Room	Manual	2/9/2026 7:54:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Failed				

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	3-382 230	100-Buildings Attic Classroom 105	Manual	2/9/2026 7:48:08 PM
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	

Ventilation and Cooking Equipment

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Fusible Links	Fusible Links		Manual	2/9/2026 3:17:34 PM
Range Hood	Hood		Manual	2/9/2026 3:17:31 PM
Range Suppression	Suppression System		Manual	2/9/2026 3:17:25 PM
Range Suppression Tank	3 Gallon Cylinder		Manual	2/9/2026 3:17:38 PM

Device/Equipment details

Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Audible And Visible					
049	Admin Building Counselors Office				
246	100-Buildings Classroom 101				
247	100-Buildings Classroom 102				
248	100-Buildings Classroom 103				
249	100-Buildings Classroom 104				
250	100-Buildings Classroom 105				
251	100-Buildings Classroom 105				
252	100-Buildings Classroom 107				
253	100-Buildings Game Room				
254	100-Buildings Parent Resource Rm				
255	100-Buildings Custodial Office				
256	100-Buildings Kitchen				
257	100-Buildings Kitchen Hall				
258	100-Buildings MP Room				
259	100-Buildings MP Room				
260	100-Buildings Stage Stairs				
261	100-Buildings Stage				
262	100-Buildings Locker Hall				
263	100-Buildings Girls Locker Room				
264	100-Buildings Boys Locker Room				
327	200-Building Classroom 201				
328	200-Building Classroom 202				
329	200-Building Classroom 203				
330	200-Building Classroom 204				
331	200-Building Classroom 205				
332	200-Building Classroom 206				
334	200-Building Girls Restroom				
335	200-Building Boys Restroom				
369	300-Building Classroom 301				
370	300-Building Classroom 302				
371	300-Building Classroom 303				
372	300-Building Classroom 304				
373	300-Building Classroom 305				
374	300-Building Classroom 306				
376	300-Building Girls Restroom				
377	300-Building Boys Restroom				
399	400-Building Classroom 401				
400	400-Building Classroom 402				
401	400-Building Classroom 403				
402	400-Building Classroom 404				
437	500-Building Classroom 501				
438	500-Building Classroom 502				
439	500-Building Classroom 503				
440	500-Building Classroom 504				
441	500-Building Classroom 505				
442	500-Building Classroom 506				
444	500-Building Girls Restroom				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
445	500-Building Boys Restroom				
480	600-Building Classroom 601				
481	600-Building Classroom 602				
482	600-Building Classroom 603				
483	600-Building Classroom 604				
484	600-Building Classroom 605				
485	600-Building Classroom 606				
487	600-Building Girls Restroom				
488	600-Building Boys Restroom				
518	700-Building Classroom 701				
519	700-Building Classroom 702				
520	700-Building Classroom 703				
521	700-Building Classroom 704				
044	Admin Building Reception				
045	Admin Building Off By Staff Breakrm				
046	Admin Building Attendance Office				
047	Admin Building Copy Room				
048	Admin Building Principals Office				
Visible					
050	Admin Building VP Office				
051	Admin Building Office by VP Office				
052	Admin Building Recep Staff Breakrm				
053	Admin Building Attendance Nurse Rm				
054	Admin Building Hall by Restrooms				
055	Admin Building Mens Restroom				
056	Admin Building Mens Restroom				
057	Admin Building Womens Restroom				
058	Admin Building Womens Restroom				
059	Admin Building Office by Reception				
265	100-Buildings Mens Restroom				
266	100-Buildings Womens Restroom				
267	100-Buildings Game Room				
268	100-Buildings Custodial Office RR				
269	100-Buildings Kitchen Office				
270	100-Buildings Kitchen Scullery				
271	100-Buildings Kitchen				
272	100-Buildings Kitchen Staff RR				
273	100-Buildings Kitchen Staff RR				
274	100-Buildings Room 107 Office Hall				
275	100-Buildings Rm 107 Band Office				
276	100-Buildings Rm 107 Band Office				
277	100-Buildings Girls Locker Entry				
278	100-Buildings Girls Locker RR				
279	100-Buildings Girls Locker Office				
280	100-Buildings Girls Locker Room				
281	100-Buildings Boys Locker Entry				
282	100-Buildings Boys Locker RR				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
283	100-Buildings Boys Locker Office				
284	100-Buildings Boys Locker Room				
285	100-Buildings Boys RR by Rm 104				
286	100-Buildings Staff RR by Rm 104				
287	100-Buildings Girls RR by Rm 104				
333	200-Building Project Room				
375	300-Building Project Room				
443	500-Building Project Room				
486	600-Building Project Room				
Audible					
238	100-Buildings North Exterior				
239	100-Buildings East Exterior				
240	100-Buildings East Exterior				
241	100-Buildings East Exterior				
242	100-Buildings East Exterior				
243	100-Buildings East Exterior				
244	100-Buildings West Exterior				
245	100-Buildings West Exterior				
288	100-Buildings West Exterior				
325	200-Building North Exterior				
326	200-Building West Exterior				
368	300-Building West Exterior				
397	400-Building North Exterior				
398	400-Building South Exterior				
434	500-Building North Exterior				
435	500-Building East Exterior				
436	500-Building West Exterior				
478	600-Building East Exterior				
479	600-Building West Exterior				
516	700-Building East Exterior				
517	700-Building West Exterior				
041	Admin Building North Exterior				
042	Admin Building East Exterior				
043	Admin Building South Exterior				

Chemical Extinguishing Systems

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Nozzle					
	Nozzles				01/01/1985

Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
NAC Power Extender Panel					
060	Admin Building MDF Room - BPS "B"				
289	100-Buildings Kitchen Staff RR - BPS "G"				
290	100-Buildings Rm 107 Band Choir - BPS "H"				
291	100-Buildings Portable Room 104 - BPS "I"				
336	200-Building Custodial Closet - BPS "C"				
378	300-Building Custodial Closet - BPS "F"				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
446	500-Building Custodial Closet - BPS "D"				
489	600-Building Custodial Closet - BPS "E"				
Remote Annunciator					
001	Admin Building Reception				
Fire Alarm Panel					
	Admin Building MDF Room	EST	3		
Initiating Device					
ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Manual Pull Station					
3-133 061	100-Buildings MP Room SW				
3-135 062	100-Buildings MP Room SE				
3-134 063	100-Buildings MP Room NE				
3-128 064	100-Buildings Kitchen West				
2-128 002	Admin Building Reception				
Smoke Detector - General					
3-009 065	100-Buildings Classroom 101 Shop				
3-010 066	100-Buildings Classroom 101 Shop				
3-011 067	100-Buildings Classroom 101 Shop				
3-012 068	100-Buildings Classroom 101 Shop				
3-013 069	100-Buildings Classroom 101 Shop				
3-016 070	100-Buildings Classroom 101 Shop				
3-017 071	100-Buildings Classroom 101 Shop				
3-018 072	100-Buildings Classroom 101 Shop				
3-015 073	100-Buildings Classroom 101 Storage				
3-014 074	100-Buildings Classroom 101 Storage				
3-008 075	100-Buildings Classroom 101 Display				
3-007 076	100-Buildings Classroom 102 Art				
3-006 077	100-Buildings Classroom 102 Art				
3-005 078	100-Buildings Classroom 102 Art				
3-004 079	100-Buildings Classroom 102 Art				
3-024 080	100-Buildings Classroom 102 Art				
3-023 081	100-Buildings Classroom 102 Art				
3-022 082	100-Buildings Classroom 102 Art				
3-021 083	100-Buildings Classroom 102 Art				
3-026 084	100-Buildings Classroom 102 Storage				
3-025 085	100-Buildings Classroom 102 Storage				
3-019 086	100-Buildings Classrooms 101 & 102 Storage				
3-020 087	100-Buildings Classrooms 101 & 102 Storage				
3-001 088	100-Buildings Mens Restroom				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3-002 089	100-Buildings Womens Restroom				
3-003 090	100-Buildings Womens Restroom				
3-027 091	100-Buildings Faculty Lounge Entry				
3-028 092	100-Buildings Faculty Lounge Closet				
3-035 093	100-Buildings Faculty Lounge				
3-036 094	100-Buildings Faculty Lounge				
3-037 095	100-Buildings Faculty Lounge				
3-032 096	100-Buildings Faculty Lounge				
3-033 097	100-Buildings Faculty Lounge				
3-034 098	100-Buildings Faculty Lounge				
3-029 099	100-Buildings Faculty Lounge				
3-030 100	100-Buildings Faculty Lounge				
3-031 101	100-Buildings Faculty Lounge				
3-044 102	100-Buildings Custodial Office				
3-045 103	100-Buildings Custodial Office				
3-046 104	100-Buildings Custodial Office				
3-043 105	100-Buildings Custodial Office RR				
3-038 106	100-Buildings Kitchen Office				
3-040 107	100-Buildings Kitchen Hall				
3-039 108	100-Buildings Kitchen Storage				
3-041 109	100-Buildings Kitchen Staff RR				
3-042 110	100-Buildings Kitchen Staff RR				
3-050 111	100-Buildings Kitchen Storage				
3-051 112	100-Buildings Kitchen Storage				
3-090 113	100-Buildings MP Room				
3-091 114	100-Buildings MP Room				
3-089 115	100-Buildings MP Room				
3-088 116	100-Buildings MP Room				
3-086 117	100-Buildings MP Room				
3-087 118	100-Buildings MP Room				
3-085 119	100-Buildings MP Room				
3-084 120	100-Buildings MP Room				
3-082 121	100-Buildings MP Room				
3-083 122	100-Buildings MP Room				
3-081 123	100-Buildings MP Room				
3-080 124	100-Buildings MP Room				
3-078 125	100-Buildings MP Room				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3-079 126	100-Buildings MP Room				
3-076 127	100-Buildings MP Rm Chair Storage				
3-077 128	100-Buildings MP Rm Chair Storage				
3-073 129	100-Buildings MP Rm Chair Storage				
3-075 130	100-Buildings MP Rm Stage Stairs				
3-074 131	100-Buildings MP Rm Stage Stairs				
3-072 132	100-Buildings MP Rm Stage Stairs				
3-067 133	100-Buildings MP Room Stage				
3-066 134	100-Buildings MP Room Stage				
3-065 135	100-Buildings MP Room Stage				
3-062 136	100-Buildings MP Room Stage				
3-063 137	100-Buildings MP Room Stage				
3-064 138	100-Buildings MP Room Stage				
3-070 139	100-Buildings Stage Storage				
3-069 140	100-Buildings Stage Storage				
3-068 141	100-Buildings Stage Storage				
3-052 142	100-Buildings Rm 107 Band Choir				
3-053 143	100-Buildings Rm 107 Band Choir				
3-054 144	100-Buildings Rm 107 Band Choir				
3-057 145	100-Buildings Rm 107 Band Choir				
3-056 146	100-Buildings Rm 107 Band Choir				
3-055 147	100-Buildings Rm 107 Band Choir				
3-059 148	100-Buildings Room 107 Office Hall				
3-058 149	100-Buildings Rm 107 Band Office				
3-061 150	100-Buildings Rm 107 Band Office				
3-060 151	100-Buildings Room 107 Office Storage				
3-251 152	100-Buildings Locker Hall				
3-252 153	100-Buildings Locker Hall				
3-255 154	100-Buildings Girls Locker Entry				
3-254 155	100-Buildings Girls Locker RR				
3-253 156	100-Buildings Girls Locker RR				
3-257 157	100-Buildings Girls Locker Room				
3-258 158	100-Buildings Girls Locker Room				
3-259 159	100-Buildings Girls Locker Room				
3-260 160	100-Buildings Girls Locker Room				
3-261 161	100-Buildings Girls Locker Room				
3-268 162	100-Buildings Girls Locker Room				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3-267 163	100-Buildings Girls Locker Room				
3-266 164	100-Buildings Girls Locker Room				
3-265 165	100-Buildings Girls Locker Room				
3-264 166	100-Buildings Girls Locker Room				
3-269 167	100-Buildings Girls Locker Room				
3-262 168	100-Buildings Girls Locker Office				
3-256 169	100-Buildings Girls Locker Office Storage				
3-263 170	100-Buildings Girls Locker Storage				
3-287 171	100-Buildings Boys Locker Entry				
3-288 172	100-Buildings Boys Locker RR				
3-289 173	100-Buildings Boys Locker RR				
3-278 174	100-Buildings Boys Locker Room				
3-279 175	100-Buildings Boys Locker Room				
3-280 176	100-Buildings Boys Locker Room				
3-284 177	100-Buildings Boys Locker Room				
3-285 178	100-Buildings Boys Locker Room				
3-275 179	100-Buildings Boys Locker Room				
3-274 180	100-Buildings Boys Locker Room				
3-273 181	100-Buildings Boys Locker Room				
3-272 182	100-Buildings Boys Locker Room				
3-271 183	100-Buildings Boys Locker Room				
3-270 184	100-Buildings Boys Locker Room				
3-277 185	100-Buildings Boys Locker Office				
3-286 186	100-Buildings Boys Locker Office Storage				
3-276 187	100-Buildings Boys Locker Storage				
3-281 188	100-Buildings Loaner Room				
3-282 189	100-Buildings Ball Room				
3-283 190	100-Buildings Ball Room				
3-300 191	100-Buildings Portable Room 103				
3-299 192	100-Buildings Portable Room 103				
3-298 193	100-Buildings Portable Room 104				
3-297 194	100-Buildings Portable Room 104				
3-291 195	100-Buildings Portable Room 105				
3-290 196	100-Buildings Portable Room 105				
3-293 197	100-Buildings Portable Room 105				
3-292 198	100-Buildings Portable Room 105				
3-296 199	100-Buildings Boys RR by Rm 104				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3-295 200	100-Buildings Staff RR by Rm 104				
3-294 201	100-Buildings Girls RR by Rm 104				
2-061 292	200-Building Classroom 201				
2-060 293	200-Building Classroom 201				
2-059 294	200-Building Classroom 201				
2-058 295	200-Building Classroom 201				
2-040 296	200-Building Project Room				
2-054 297	200-Building Classroom 202				
2-055 298	200-Building Classroom 202				
2-056 299	200-Building Classroom 202				
2-057 300	200-Building Classroom 202				
2-051 301	200-Building Classroom 203				
2-052 302	200-Building Classroom 203				
2-053 303	200-Building Classroom 203				
2-050 304	200-Building Classroom 203				
2-039 305	200-Building Classroom 204				
2-038 306	200-Building Classroom 204				
2-037 307	200-Building Classroom 204				
2-036 308	200-Building Classroom 204				
2-041 309	200-Building Classroom 204 Storage				
2-043 310	200-Building Classroom 205				
2-044 311	200-Building Classroom 205				
2-045 312	200-Building Classroom 205				
2-042 313	200-Building Classroom 205				
2-046 314	200-Building Classroom 206				
2-047 315	200-Building Classroom 206				
2-048 316	200-Building Classroom 206				
2-049 317	200-Building Classroom 206				
2-035 318	200-Building Girls Restroom				
2-033 319	200-Building Custodial Closet				
2-034 320	200-Building Boys Restroom				
2-326 337	300-Building Classroom 301				
2-325 338	300-Building Classroom 301				
2-324 339	300-Building Classroom 301				
2-323 340	300-Building Classroom 301				
2-305 341	300-Building Project Room				
2-319 342	300-Building Classroom 302				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-320 343	300-Building Classroom 302				
2-321 344	300-Building Classroom 302				
2-322 345	300-Building Classroom 302				
2-316 346	300-Building Classroom 303				
2-317 347	300-Building Classroom 303				
2-318 348	300-Building Classroom 303				
2-315 349	300-Building Classroom 303				
2-304 350	300-Building Classroom 304				
2-303 351	300-Building Classroom 304				
2-302 352	300-Building Classroom 304				
2-301 353	300-Building Classroom 304				
2-306 354	300-Building Classroom 304 Storage				
2-308 355	300-Building Classroom 305				
2-309 356	300-Building Classroom 305				
2-310 357	300-Building Classroom 305				
2-307 358	300-Building Classroom 305				
2-311 359	300-Building Classroom 306				
2-312 360	300-Building Classroom 306				
2-313 361	300-Building Classroom 306				
2-314 362	300-Building Classroom 306				
2-299 363	300-Building Girls Restroom				
2-298 364	300-Building Custodial Closet				
2-300 365	300-Building Boys Restroom				
2-266 379	400-Building Classroom 401				
2-267 380	400-Building Classroom 401				
2-268 381	400-Building Classroom 401				
2-265 382	400-Building Classroom 401				
2-259 383	400-Building Classroom 402				
2-260 384	400-Building Classroom 402				
2-261 385	400-Building Classroom 402				
2-262 386	400-Building Classroom 402				
2-264 387	400-Building Classroom 402 Storage				
2-263 388	400-Building Classroom 402 Storage				
2-251 389	400-Building Classroom 403				
2-252 390	400-Building Classroom 403				
2-253 391	400-Building Classroom 403				
2-254 392	400-Building Classroom 403				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-258 393	400-Building Classroom 404				
2-256 394	400-Building Classroom 404				
2-257 395	400-Building Classroom 404				
2-255 396	400-Building Classroom 404				
2-067 403	500-Building Classroom 501				
2-068 404	500-Building Classroom 501				
2-066 405	500-Building Classroom 501				
2-065 406	500-Building Classroom 501				
2-070 407	500-Building Room 501A Storage				
2-073 408	500-Building Classroom 502				
2-074 409	500-Building Classroom 502				
2-072 410	500-Building Classroom 502				
2-071 411	500-Building Classroom 502				
2-069 412	500-Building Project Room				
2-075 413	500-Building Classroom 503				
2-076 414	500-Building Classroom 503				
2-077 415	500-Building Classroom 503				
2-078 416	500-Building Classroom 503				
2-090 417	500-Building Classroom 504				
2-089 418	500-Building Classroom 504				
2-088 419	500-Building Classroom 504				
2-087 420	500-Building Classroom 504				
2-083 421	500-Building Classroom 505				
2-084 422	500-Building Classroom 505				
2-086 423	500-Building Classroom 505				
2-085 424	500-Building Classroom 505				
2-080 425	500-Building Classroom 506				
2-081 426	500-Building Classroom 506				
2-082 427	500-Building Classroom 506				
2-079 428	500-Building Classroom 506				
2-063 429	500-Building Girls Restroom				
2-062 430	500-Building Custodial Closet				
2-064 431	500-Building Boys Restroom				
2-274 447	600-Building Classroom 601				
2-275 448	600-Building Classroom 601				
2-273 449	600-Building Classroom 601				
2-272 450	600-Building Classroom 601				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-277 451	600-Building Room 601A Storage				
2-279 452	600-Building Classroom 602				
2-280 453	600-Building Classroom 602				
2-281 454	600-Building Classroom 602				
2-278 455	600-Building Classroom 602				
2-276 456	600-Building Project Room				
2-282 457	600-Building Classroom 603				
2-283 458	600-Building Classroom 603				
2-284 459	600-Building Classroom 603				
2-285 460	600-Building Classroom 603				
2-294 461	600-Building Classroom 604				
2-295 462	600-Building Classroom 604				
2-296 463	600-Building Classroom 604				
2-297 464	600-Building Classroom 604				
2-290 465	600-Building Classroom 605				
2-291 466	600-Building Classroom 605				
2-292 467	600-Building Classroom 605				
2-293 468	600-Building Classroom 605				
2-286 469	600-Building Classroom 606				
2-289 470	600-Building Classroom 606				
2-288 471	600-Building Classroom 606				
2-287 472	600-Building Classroom 606				
2-270 473	600-Building Girls Restroom				
2-269 474	600-Building Custodial Closet				
2-271 475	600-Building Boys Restroom				
2-091 490	700-Building Classroom 701				
2-092 491	700-Building Classroom 701				
2-093 492	700-Building Classroom 701				
2-094 493	700-Building Classroom 701				
2-095 494	700-Building Classroom 701				
2-096 495	700-Building Classroom 702				
2-097 496	700-Building Classroom 702				
2-098 497	700-Building Classroom 702				
2-099 498	700-Building Classroom 702				
2-100 499	700-Building Classroom 702				
2-101 500	700-Building Classroom 703				
2-102 501	700-Building Classroom 703				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-103 502	700-Building Classroom 703				
2-104 503	700-Building Classroom 703				
2-105 504	700-Building Classroom 703				
2-106 505	700-Building Classroom 703				
2-107 506	700-Building Classroom 703 Storage				
2-116 507	700-Building Classroom 704				
2-115 508	700-Building Classroom 704				
2-114 509	700-Building Classroom 704				
2-113 510	700-Building Classroom 704				
2-112 511	700-Building Classroom 704				
2-111 512	700-Building Classroom 704				
2-108 513	700-Building Classroom 704A Storage				
2-109 514	700-Building Classroom 704B Storage				
2-110 515	700-Building Classroom 704B Storage				
2-016 003	Admin Building Reception				
2-015 004	Admin Building Reception				
2-013 005	Admin Building Reception				
2-011 006	Admin Building VP Office				
2-012 007	Admin Building VP Office				
2-010 008	Admin Building Office by VP Office				
2-009 009	Admin Building Reception Storage				
2-014 010	Admin Building Recep Staff Breakrm				
2-008 011	Admin Building Office By Staff Breakrm				
2-005 012	Admin Building Office By Staff Breakrm				
2-004 013	Admin Building Office By Staff Breakrm				
2-002 014	Admin Building Attendance Storage				
2-003 015	Admin Building Attendance Storage				
2-001 016	Admin Building MDF Room				
2-032 017	Admin Building Attendance Office				
2-030 018	Admin Building Attendance Office				
2-031 019	Admin Building Attendance Nurse Rm				
2-029 020	Admin Building Copy Room Storage				
2-028 021	Admin Building Copy Room				
2-027 022	Admin Building Copy Room				
2-019 023	Admin Building Hall by Restrooms				
2-026 024	Admin Building Mens Restroom				
2-025 025	Admin Building Mens Restroom				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-018 026	Admin Building Custodial Closet				
2-023 027	Admin Building Womens Restroom				
2-024 028	Admin Building Womens Restroom				
2-020 029	Admin Building Principals Office				
2-022 030	Admin Building Principals Office				
2-021 031	Admin Building Principals Office				
2-017 032	Admin Building Office by Reception				
2-006 033	Admin Building Counselors Office				
2-007 034	Admin Building Counselors Office				
Heat Detector - Restorable Spot					
3-047 202	100-Buildings Kitchen				
3-049 203	100-Buildings Kitchen				
3-048 204	100-Buildings Kitchen Scullery				
3-071 205	100-Buildings Boiler Room				
3-126 206	100-Buildings Attic Faculty Entry				
3-127 207	100-Buildings Attic Kitchen				
3-206 208	100-Buildings Attic Kitchen Staff				
3-206 209	100-Buildings Attic Kitchen Staff				
3-207 210	100-Buildings Attic Rm 107 Band				
3-130 211	100-Buildings Attic Rm 107 Office				
3-131 212	100-Buildings Attic Rm 107 Office				
3-378 213	100-Buildings Attic Girls Locker Rm				
3-378 214	100-Buildings Attic Girls Locker Rm				
3-376 215	100-Buildings Plumbing Chase Girls Locker RR				
3-380 216	100-Buildings Attic Boys Locker Rm				
3-380 217	100-Buildings Attic Boys Locker Rm				
3-381 218	100-Buildings Plumbing Chase Boys Locker RR				
3-385 219	100-Buildings Attic Classroom 103				
3-385 220	100-Buildings Attic Classroom 103				
3-384 221	100-Buildings Attic Classroom 104				
3-384 222	100-Buildings Attic Classroom 104				
3-382 223	100-Buildings Attic Classroom 105				
3-382 224	100-Buildings Attic Classroom 105				
3-382 225	100-Buildings Attic Classroom 105				
3-382 226	100-Buildings Attic Classroom 105				
3-382 227	100-Buildings Attic Classroom 105				
3-382 228	100-Buildings Attic Classroom 105				
3-382 229	100-Buildings Attic Classroom 105				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3-382 230	100-Buildings Attic Classroom 105				
3-383 231	100-Buildings Attic Girls Restroom				
3-383 232	100-Buildings Attic Staff Restroom				
3-383 233	100-Buildings Attic Boys Restroom				
2-132 321	200-Building Attic Classroom 201				
2-133 322	200-Building Attic Classroom 201				
2-131 323	200-Building Attic Project Room				
2-130 324	200-Building RR Plumbing Chase				
2-380 366	300-Building Attic Project Room				
2-379 367	300-Building RR Plumbing Chase				
2-135 432	500-Building Attic Project Room				
2-134 433	500-Building RR Plumbing Chase				
2-378 476	600-Building Attic Project Room				
2-377 477	600-Building RR Plumbing Chase				
2-376 522	Boiler/Chiller Bldg - Boiler/Chiller Room				
2-376 523	Boiler/Chiller Bldg - Boiler/Chiller Room				
2-126 035	Admin Building Mechanical Room				
2-126 036	Admin Building Mechanical Room				
2-127 037	Admin Building Attic Office by VP Off				
2-129 038	Admin Building HVAC Chase				
2-129 039	Admin Building HVAC Chase				
2-129 040	Admin Building HVAC Chase				
3-385	100-Buildings Attic Classroom 103				
Smoke Detector - Duct					
3-377 234	100-Buildings Duct Girls Locker				
3-379 235	100-Buildings Duct Boys Locker				
Mechanical, Electrosonic, or Pressure Waterflow Device					
3-136 236	100-Buildings Boiler Room				
Valve Tamper Switch					
3-137 237	100-Buildings OS&Y Boiler Room				
Ventilation and Cooking Equipment					
ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Range Suppression					
Suppression System					01/01/1985
Range Suppression Tank					
3 Gallon Cylinder					01/01/1985
Range Hood					
Hood					01/01/1985
Fusible Links					
Fusible Links					01/01/1985