

Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

TWIN LAKES ELEMENTARY

5515 MAIN AVE
ORANGEVALE, California
United States

This site has been inspected and tested in compliance with applicable standards.

Completed
Wednesday, October 08, 2025

Test Session:08 Oct 2025 13:35 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD
5320 HEMLOCK ST
SACRAMENTO, California
United States

TESTED BY

Riley Goyet
Western States Fire Protection-
Sacramento
188 Cirby Way
Roseville, CA 95678
United States



Inspection Summary

Building Information

PROPERTY	TWIN LAKES ELEMENTARY	CONTACT
ADDRESS	5515 MAIN AVE	PHONE
CITY/STATE	ORANGEVALE, California	MOBILE
COUNTRY	United States	EMAIL

Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us

Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Alarm Notification Appliance	89	89(100%)	89(100%)	0(0%)
Fire Control Panel	7	7(100%)	7(100%)	0(0%)
Initiating Device	330	329(100%)	329(100%)	0(0%)

Certification

The equipment specified herein was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Wednesday, October 08, 2025

ACCEPTED BY 10/08/2025

Building Representative


TESTED BY 10/08/2025
Riley Goyet
Technician

Testing Details

Alarm Notification Appliance

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible		Admin / MP Bldg Admin Lobby	Manual	10/8/2025 2:14:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Admin / MP Bldg Admin Mens RR	Manual	10/8/2025 2:14:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Admin / MP Bldg Admin Reception	Manual	10/8/2025 2:15:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Admin / MP Bldg Admin Restrnm Hall	Manual	10/8/2025 2:15:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Admin / MP Bldg Admin Womens RR	Manual	10/8/2025 2:14:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Admin / MP Bldg Classrm 5 Computer Rm	Manual	10/8/2025 2:14:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Admin / MP Bldg Classroom 3	Manual	10/8/2025 2:15:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Admin / MP Bldg Classroom 4	Manual	10/8/2025 2:15:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Admin / MP Bldg Classroom 5	Manual	10/8/2025 2:15:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Admin / MP Bldg Classroom 6	Manual	10/8/2025 2:14:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Admin / MP Bldg East Exterior	Manual	10/8/2025 2:15:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Admin / MP Bldg Kitchen	Manual	10/8/2025 2:15:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Admin / MP Bldg Kitchen Office	Manual	10/8/2025 2:14:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Admin / MP Bldg Media A/V Room	Manual	10/8/2025 2:14:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Admin / MP Bldg Media Room	Manual	10/8/2025 2:15:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Admin / MP Bldg Media Work Room	Manual	10/8/2025 2:15:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible		Admin / MP Bldg MP East Entrance	Manual	10/8/2025 2:14:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Admin / MP Bldg MP Music Rm Hall	Manual	10/8/2025 2:14:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Admin / MP Bldg MP Music Room	Manual	10/8/2025 2:15:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Admin / MP Bldg MP Room	Manual	10/8/2025 2:15:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Admin / MP Bldg MP Room	Manual	10/8/2025 2:15:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Admin / MP Bldg MP Room Mezz	Manual	10/8/2025 2:15:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Admin / MP Bldg MP Stage	Manual	10/8/2025 2:15:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Admin / MP Bldg MP West Entrance	Manual	10/8/2025 2:14:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Admin / MP Bldg North Exterior	Manual	10/8/2025 2:15:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Admin / MP Bldg North Exterior	Manual	10/8/2025 2:15:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Admin / MP Bldg Northeast Exterior - Electric Bell	Manual	10/8/2025 2:14:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Admin / MP Bldg Nurses Office	Manual	10/8/2025 2:14:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Admin / MP Bldg Nurses Office RR	Manual	10/8/2025 2:14:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Admin / MP Bldg Principals Office	Manual	10/8/2025 2:14:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Admin / MP Bldg South Exterior	Manual	10/8/2025 2:15:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Admin / MP Bldg South Exterior	Manual	10/8/2025 2:15:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Admin / MP Bldg Staff Break Room	Manual	10/8/2025 2:15:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Admin / MP Bldg West Exterior	Manual	10/8/2025 2:15:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Rooms 1 & 2 Bldg Classrm 1 Girls RR	Manual	10/8/2025 2:14:35 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Rooms 1 & 2 Bldg Classrm 2 Boys RR	Manual	10/8/2025 2:14:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 1 & 2 Bldg Classroom 1	Manual	10/8/2025 2:14:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 1 & 2 Bldg Classroom 2	Manual	10/8/2025 2:14:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 1 & 2 Bldg South Exterior	Manual	10/8/2025 2:14:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 11-14 Bldg Classroom 11	Manual	10/8/2025 2:14:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 11-14 Bldg Classroom 12	Manual	10/8/2025 2:14:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 11-14 Bldg Classroom 13	Manual	10/8/2025 2:14:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 11-14 Bldg Classroom 14	Manual	10/8/2025 2:14:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 11-14 Bldg West Exterior	Manual	10/8/2025 2:14:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 15-17 Bldg Boys RR by Rm 15	Manual	10/8/2025 2:14:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 15-17 Bldg Classroom 15	Manual	10/8/2025 2:14:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 15-17 Bldg Classroom 16	Manual	10/8/2025 2:14:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 15-17 Bldg Classroom 17	Manual	10/8/2025 2:14:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 15-17 Bldg Girls RR by Rm 15	Manual	10/8/2025 2:14:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 15-17 Bldg North Exterior	Manual	10/8/2025 2:14:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 15-17 Bldg South Exterior	Manual	10/8/2025 2:14:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 18-21 Bldg Classroom 18	Manual	10/8/2025 2:13:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 18-21 Bldg Classroom 19	Manual	10/8/2025 2:14:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible		Rooms 18-21 Bldg Classroom 20	Manual	10/8/2025 2:14:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 18-21 Bldg Classroom 21	Manual	10/8/2025 2:13:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 18-21 Bldg North Exterior	Manual	10/8/2025 2:14:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 18-21 Bldg West Exterior	Manual	10/8/2025 2:13:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 22-25 Bldg Classroom 22	Manual	10/8/2025 2:13:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 22-25 Bldg Classroom 23	Manual	10/8/2025 2:13:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 22-25 Bldg Classroom 24	Manual	10/8/2025 2:13:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 22-25 Bldg Classroom 25	Manual	10/8/2025 2:13:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 22-25 Bldg East Exterior	Manual	10/8/2025 2:13:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 22-25 Bldg North Exterior	Manual	10/8/2025 2:13:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 22-25 Bldg West Exterior	Manual	10/8/2025 2:13:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 26-28 Bldg Boys RR by Rm 28	Manual	10/8/2025 2:13:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 26-28 Bldg Classroom 26	Manual	10/8/2025 2:13:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 26-28 Bldg Classroom 27	Manual	10/8/2025 2:13:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 26-28 Bldg Classroom 28	Manual	10/8/2025 2:13:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 26-28 Bldg Girls RR by Rm 28	Manual	10/8/2025 2:13:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 26-28 Bldg North Exterior	Manual	10/8/2025 2:13:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 26-28 Bldg West Exterior	Manual	10/8/2025 2:13:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 29-32 Bldg Classroom 29	Manual	10/8/2025 2:13:16 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	Rooms 29-32 Bldg Classroom 30		Manual	10/8/2025 2:13:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	Rooms 29-32 Bldg Classroom 31		Manual	10/8/2025 2:13:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	Rooms 29-32 Bldg Classroom 32		Manual	10/8/2025 2:13:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	Rooms 29-32 Bldg East Exterior		Manual	10/8/2025 2:13:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	Rooms 29-32 Bldg North Exterior		Manual	10/8/2025 2:13:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	Rooms 29-32 Bldg West Exterior		Manual	10/8/2025 2:13:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	Rooms 33-36 Bldg Classroom 33		Manual	10/8/2025 2:13:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	Rooms 33-36 Bldg Classroom 34		Manual	10/8/2025 2:13:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	Rooms 33-36 Bldg Classroom 35		Manual	10/8/2025 2:13:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	Rooms 33-36 Bldg Classroom 36		Manual	10/8/2025 2:13:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	Rooms 33-36 Bldg North Exterior		Manual	10/8/2025 2:13:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	Rooms 7-10 Bldg Classroom 10		Manual	10/8/2025 2:14:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	Rooms 7-10 Bldg Classroom 7		Manual	10/8/2025 2:14:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	Rooms 7-10 Bldg Classroom 8		Manual	10/8/2025 2:14:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	Rooms 7-10 Bldg Classroom 9		Manual	10/8/2025 2:14:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	Rooms 7-10 Bldg East Exterior		Manual	10/8/2025 2:14:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	Rooms 7-10 Bldg West Exterior		Manual	10/8/2025 2:14:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Remote Annunciator		Admin / MP Bldg Admin Reception	Manual	10/8/2025 8:48:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Fire Alarm Panel		Admin / MP Bldg MP Chair Storage	Manual	10/8/2025 8:48:29 PM
		Manufacturer	EST	
		Model	3	
		Visual inspection	Passed (Manual)	
NAC Power Extender Panel		Admin / MP Bldg MP Chair Storage - P.E. "B"	Manual	10/8/2025 8:48:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Admin / MP Bldg MP Chair Storage - P.E. "IL2"	Manual	10/8/2025 8:48:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Rooms 1 & 2 Bldg Rms 1 & 2 O/S Storage - P.E. "C"	Manual	10/8/2025 8:48:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Rooms 15-17 Bldg Cust. Closet by Rm 15 - P.E. "D"	Manual	10/8/2025 8:48:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Rooms 26-28 Bldg Cust. Closet by Rm 28 - P.E. "E"	Manual	10/8/2025 8:48:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-010 044	Admin / MP Bldg Admin Lobby	Manual	10/8/2025 8:49:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-011 040	Admin / MP Bldg Admin Mens RR	Manual	10/8/2025 9:27:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-092 041	Admin / MP Bldg Admin Mens RR Closet	Manual	10/8/2025 9:27:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-130 002	Admin / MP Bldg Admin Reception	Manual	10/8/2025 8:48:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-007 045	Admin / MP Bldg Admin Reception	Manual	10/8/2025 8:50:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-013 038	Admin / MP Bldg Admin Restrm Hall	Manual	10/8/2025 9:27:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-012 039	Admin / MP Bldg Admin Womens RR	Manual	10/8/2025 9:27:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-129 076	Admin / MP Bldg Attic Admin	Manual	10/8/2025 10:20:26 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-129 075	Admin / MP Bldg Attic Admin	Manual	10/8/2025 10:20:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-131 073	Admin / MP Bldg Attic Admin Lobby	Manual	10/8/2025 10:20:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-131 074	Admin / MP Bldg Attic Admin Lobby	Manual	10/8/2025 10:20:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-138 067	Admin / MP Bldg Attic Classroom 3	Manual	10/8/2025 10:20:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-139 068	Admin / MP Bldg Attic Classroom 4	Manual	10/8/2025 10:20:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-140 069	Admin / MP Bldg Attic Classroom 5	Manual	10/8/2025 10:20:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-141 070	Admin / MP Bldg Attic Classroom 6	Manual	10/8/2025 10:20:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-143 060	Admin / MP Bldg Attic Kitchen	Manual	10/8/2025 10:19:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-134 062	Admin / MP Bldg Attic Media A/V Rm	Manual	10/8/2025 10:19:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-137 065	Admin / MP Bldg Attic Media Room	Manual	10/8/2025 10:02:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-137 066	Admin / MP Bldg Attic Media Room	Manual	10/8/2025 10:19:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-133 064	Admin / MP Bldg Attic Media Work Rm	Manual	10/8/2025 10:19:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-133 063	Admin / MP Bldg Attic Media Work Rm	Manual	10/8/2025 10:19:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-135 061	Admin / MP Bldg Attic MP W Entrance	Manual	10/8/2025 10:20:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-132 071	Admin / MP Bldg Attic Staff Breakroom	Manual	10/8/2025 10:20:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-132 072	Admin / MP Bldg Attic Staff Breakroom	Manual	10/8/2025 10:20:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-036 057	Admin / MP Bldg Classrm 5 Computer Rm	Manual	10/8/2025 9:28:10 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-033 053	Admin / MP Bldg Classroom 3	Manual	10/8/2025 9:27:52 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-034 054	Admin / MP Bldg Classroom 3 Closet	Manual	10/8/2025 9:27:49 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-035 055	Admin / MP Bldg Classroom 4	Manual	10/8/2025 9:27:50 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-037 056	Admin / MP Bldg Classroom 5	Manual	10/8/2025 9:28:12 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-038 058	Admin / MP Bldg Classroom 6	Manual	10/8/2025 9:27:47 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-057 031	Admin / MP Bldg Field Storage	Manual	10/8/2025 9:27:45 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-056	Admin / MP Bldg Field Storage ACS	Manual	10/8/2025 8:49:52 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	2-042 059	Admin / MP Bldg Kitchen	Manual	10/8/2025 10:20:22 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-028 032	Admin / MP Bldg Media A/V Room	Manual	10/8/2025 9:28:08 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-030 036	Admin / MP Bldg Media Room	Manual	10/8/2025 9:28:16 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-031 035	Admin / MP Bldg Media Room	Manual	10/8/2025 9:28:18 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-032 034	Admin / MP Bldg Media Room	Manual	10/8/2025 9:28:20 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-027 033	Admin / MP Bldg Media Work Room	Manual	10/8/2025 9:28:06 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - Duct	2-170	Admin / MP Bldg MP Chair Storage	Manual	10/8/2025 9:27:22 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-039 014	Admin / MP Bldg MP Chair Storage	Manual	10/8/2025 8:49:59 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-040	Admin / MP Bldg MP Chair Storage	Manual	10/8/2025 9:27:20 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General		Admin / MP Bldg MP Custodial Office	Manual	10/8/2025 8:49:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-142 003	Admin / MP Bldg MP East Entrance	Manual	10/8/2025 9:27:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-041 016	Admin / MP Bldg MP East Entrance	Manual	10/8/2025 9:27:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-001 015	Admin / MP Bldg MP Electrical Room	Manual	10/8/2025 8:50:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-016 043	Admin / MP Bldg MP Mezz Storage	Manual	10/8/2025 9:27:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-017	Admin / MP Bldg MP Mezz Storage	Manual	10/8/2025 9:27:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-093 042	Admin / MP Bldg MP Mezz Storage Stairs	Manual	10/8/2025 9:27:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-054 028	Admin / MP Bldg MP Music Rm Hall	Manual	10/8/2025 9:27:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-052 027	Admin / MP Bldg MP Music Room	Manual	10/8/2025 9:27:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-053 026	Admin / MP Bldg MP Music Room	Manual	10/8/2025 9:27:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-021 008	Admin / MP Bldg MP Room	Manual	10/8/2025 8:50:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-024 005	Admin / MP Bldg MP Room	Manual	10/8/2025 8:50:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-026 006	Admin / MP Bldg MP Room	Manual	10/8/2025 8:50:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-022 012	Admin / MP Bldg MP Room	Manual	10/8/2025 8:50:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-025 013	Admin / MP Bldg MP Room	Manual	10/8/2025 8:50:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-023 007	Admin / MP Bldg MP Room	Manual	10/8/2025 9:27:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-019 011	Admin / MP Bldg MP Room	Manual	10/8/2025 9:27:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-018 009	Admin / MP Bldg MP Room Mezz	Manual	10/8/2025 8:49:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-020 010	Admin / MP Bldg MP Room Mezz	Manual	10/8/2025 8:50:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-047 024	Admin / MP Bldg MP Stage	Manual	10/8/2025 9:27:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-048 023	Admin / MP Bldg MP Stage	Manual	10/8/2025 9:27:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-051 022	Admin / MP Bldg MP Stage	Manual	10/8/2025 9:27:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-046 019	Admin / MP Bldg MP Stage	Manual	10/8/2025 9:27:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-049 020	Admin / MP Bldg MP Stage	Manual	10/8/2025 9:27:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-050 021	Admin / MP Bldg MP Stage	Manual	10/8/2025 9:27:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-044 025	Admin / MP Bldg MP Stage Storage	Manual	10/8/2025 9:27:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-171	Admin / MP Bldg MP Stage storage	Manual	10/8/2025 8:50:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-171	Admin / MP Bldg MP Stage storage	Manual	10/8/2025 8:50:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-136 004	Admin / MP Bldg MP West Entrance	Manual	10/8/2025 10:19:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-029 030	Admin / MP Bldg MP West Entrance	Manual	10/8/2025 8:50:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-055 029	Admin / MP Bldg Music Rm Mezz. Access	Manual	10/8/2025 9:27:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	2-127 077	Admin / MP Bldg Northeast Exterior	Manual	10/8/2025 10:19:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Valve Tamper Switch	2-128 078	Admin / MP Bldg Northeast Exterior	Manual	10/8/2025 10:20:20 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-008 051	Admin / MP Bldg Nurse Office Closet	Manual	10/8/2025 8:50:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-006 049	Admin / MP Bldg Nurses Office	Manual	10/8/2025 8:50:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-005 050	Admin / MP Bldg Nurses Office RR	Manual	10/8/2025 8:50:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-002 048	Admin / MP Bldg Princ Off Conf Rm	Manual	10/8/2025 8:50:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-004 047	Admin / MP Bldg Principals Off Closet	Manual	10/8/2025 8:50:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-003 046	Admin / MP Bldg Principals Office	Manual	10/8/2025 8:50:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-014	Admin / MP Bldg Staff Break Rm Ph Booth	Manual	10/8/2025 9:27:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-015 037	Admin / MP Bldg Staff Break Room	Manual	10/8/2025 9:28:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-009 052	Admin / MP Bldg Vice Principals Office	Manual	10/8/2025 8:50:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-169	MP electric Room	Manual	10/8/2025 8:50:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-172	Room 5 AHU 8	Manual	10/8/2025 8:50:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-173	Room 5 AHU 8	Manual	10/8/2025 9:28:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-147 130	Rooms 1 & 2 Bldg Attic Btwn Rms 1 & 2	Manual	10/8/2025 10:20:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-147 129	Rooms 1 & 2 Bldg Attic Btwn Rms 1 & 2	Manual	10/8/2025 10:20:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-146 128	Rooms 1 & 2 Bldg Attic Classroom 1	Manual	10/8/2025 10:20:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-146 127	Rooms 1 & 2 Bldg Attic Classroom 1	Manual	10/8/2025 10:20:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-145 132	Rooms 1 & 2 Bldg Attic Classroom 2	Manual	10/8/2025 10:20:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-145 131	Rooms 1 & 2 Bldg Attic Classroom 2	Manual	10/8/2025 10:20:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-069 118	Rooms 1 & 2 Bldg Classrm 1 Girls RR	Manual	10/8/2025 10:02:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-071 125	Rooms 1 & 2 Bldg Classrm 2 Boys RR	Manual	10/8/2025 10:02:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-067 116	Rooms 1 & 2 Bldg Classroom 1	Manual	10/8/2025 10:02:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-066 115	Rooms 1 & 2 Bldg Classroom 1	Manual	10/8/2025 10:02:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-065 117	Rooms 1 & 2 Bldg Classroom 1	Manual	10/8/2025 10:02:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-068 114	Rooms 1 & 2 Bldg Classroom 1	Manual	10/8/2025 10:02:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-064 119	Rooms 1 & 2 Bldg Classroom 1 Storage	Manual	10/8/2025 10:02:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-059 124	Rooms 1 & 2 Bldg Classroom 2	Manual	10/8/2025 10:02:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-060 123	Rooms 1 & 2 Bldg Classroom 2	Manual	10/8/2025 10:02:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-061 122	Rooms 1 & 2 Bldg Classroom 2	Manual	10/8/2025 10:02:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-058 121	Rooms 1 & 2 Bldg Classroom 2	Manual	10/8/2025 10:02:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-063 120	Rooms 1 & 2 Bldg Classroom 2	Manual	10/8/2025 10:02:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-062	Rooms 1 & 2 Bldg Classroom 2 Storage	Manual	10/8/2025 10:02:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-070 126	Rooms 1 & 2 Bldg Rms 1 & 2 O/S Storage	Manual	10/8/2025 8:50:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-376 194	Rooms 11-14 Bldg Attic Classroom 11	Manual	10/8/2025 8:49:30 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-376 193	Rooms 11-14 Bldg Attic Classroom 11	Manual	10/8/2025 8:49:32 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-379 195	Rooms 11-14 Bldg Attic Classroom 12	Manual	10/8/2025 8:49:23 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-379 196	Rooms 11-14 Bldg Attic Classroom 12	Manual	10/8/2025 8:49:24 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-377 198	Rooms 11-14 Bldg Attic Classroom 13	Manual	10/8/2025 10:19:58 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-377 197	Rooms 11-14 Bldg Attic Classroom 13	Manual	10/8/2025 10:19:59 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-378 199	Rooms 11-14 Bldg Attic Classroom 14	Manual	10/8/2025 10:19:53 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-378 200	Rooms 11-14 Bldg Attic Classroom 14	Manual	10/8/2025 10:19:54 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-252 176	Rooms 11-14 Bldg Classroom 11	Manual	10/8/2025 10:01:30 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-253 175	Rooms 11-14 Bldg Classroom 11	Manual	10/8/2025 10:01:31 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-255 173	Rooms 11-14 Bldg Classroom 11	Manual	10/8/2025 10:01:33 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-254 174	Rooms 11-14 Bldg Classroom 11	Manual	10/8/2025 10:01:35 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-251 177	Rooms 11-14 Bldg Classroom 11 Storage	Manual	10/8/2025 10:01:27 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-270 180	Rooms 11-14 Bldg Classroom 12	Manual	10/8/2025 10:01:16 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-269 181	Rooms 11-14 Bldg Classroom 12	Manual	10/8/2025 10:01:18 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-267 178	Rooms 11-14 Bldg Classroom 12	Manual	10/8/2025 10:01:21 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-266 179	Rooms 11-14 Bldg Classroom 12	Manual	10/8/2025 10:01:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-268 182	Rooms 11-14 Bldg Classroom 12 Storage	Manual	10/8/2025 10:01:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-260 186	Rooms 11-14 Bldg Classroom 13	Manual	10/8/2025 10:00:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-259 185	Rooms 11-14 Bldg Classroom 13	Manual	10/8/2025 10:01:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-257 183	Rooms 11-14 Bldg Classroom 13	Manual	10/8/2025 10:01:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-256 184	Rooms 11-14 Bldg Classroom 13	Manual	10/8/2025 10:01:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-258 187	Rooms 11-14 Bldg Classroom 13 Storage	Manual	10/8/2025 10:00:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-261 191	Rooms 11-14 Bldg Classroom 14	Manual	10/8/2025 10:01:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-262 190	Rooms 11-14 Bldg Classroom 14	Manual	10/8/2025 10:01:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-264 189	Rooms 11-14 Bldg Classroom 14	Manual	10/8/2025 10:01:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-265 188	Rooms 11-14 Bldg Classroom 14	Manual	10/8/2025 10:01:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-263 192	Rooms 11-14 Bldg Classroom 14 Storage	Manual	10/8/2025 10:01:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-382 228	Rooms 15-17 Bldg Attic Classroom 15	Manual	10/8/2025 10:19:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-382 227	Rooms 15-17 Bldg Attic Classroom 15	Manual	10/8/2025 10:19:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-381 229	Rooms 15-17 Bldg Attic Classroom 16	Manual	10/8/2025 10:19:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-381 230	Rooms 15-17 Bldg Attic Classroom 16	Manual	10/8/2025 10:20:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-380 232	Rooms 15-17 Bldg Attic Classroom 17	Manual	10/8/2025 8:49:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-380 231	Rooms 15-17 Bldg Attic Classroom 17	Manual	10/8/2025 8:49:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-276 225	Rooms 15-17 Bldg Boys RR by Rm 15	Manual	10/8/2025 10:00:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-277 226	Rooms 15-17 Bldg Boys RR by Rm 15	Manual	10/8/2025 10:00:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-290 209	Rooms 15-17 Bldg Classroom 15	Manual	10/8/2025 10:00:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-289 208	Rooms 15-17 Bldg Classroom 15	Manual	10/8/2025 10:00:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-287 206	Rooms 15-17 Bldg Classroom 15	Manual	10/8/2025 10:00:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-286 207	Rooms 15-17 Bldg Classroom 15	Manual	10/8/2025 10:00:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-288 210	Rooms 15-17 Bldg Classroom 15 Storage	Manual	10/8/2025 10:00:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-281 213	Rooms 15-17 Bldg Classroom 16	Manual	10/8/2025 10:00:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-282 214	Rooms 15-17 Bldg Classroom 16	Manual	10/8/2025 10:00:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-284 211	Rooms 15-17 Bldg Classroom 16	Manual	10/8/2025 10:00:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-285 212	Rooms 15-17 Bldg Classroom 16	Manual	10/8/2025 10:00:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-283 215	Rooms 15-17 Bldg Classroom 16 Storage	Manual	10/8/2025 10:00:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-272 219	Rooms 15-17 Bldg Classroom 17	Manual	10/8/2025 10:00:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-273 218	Rooms 15-17 Bldg Classroom 17	Manual	10/8/2025 10:00:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-275 216	Rooms 15-17 Bldg Classroom 17	Manual	10/8/2025 10:00:18 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-274 217	Rooms 15-17 Bldg Classroom 17	Manual	10/8/2025 10:00:19 PM
		Functional Inspection	Passed	
Smoke Detector - General	2-271 220	Rooms 15-17 Bldg Classroom 17 Storage	Manual	10/8/2025 10:00:13 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-291 221	Rooms 15-17 Bldg Cust. Closet by Rm 15	Manual	10/8/2025 10:00:41 PM
		Functional Inspection	Passed	
Smoke Detector - General	2-278 224	Rooms 15-17 Bldg Field Storage by Rm 15	Manual	10/8/2025 10:00:53 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-279 223	Rooms 15-17 Bldg Girls RR by Rm 15	Manual	10/8/2025 10:00:36 PM
		Functional Inspection	Passed	
Smoke Detector - General	2-280 222	Rooms 15-17 Bldg Girls RR by Rm 15	Manual	10/8/2025 10:00:38 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-280 222	Rooms 15-17 Bldg Girls RR by Rm 15	Manual	10/8/2025 10:00:38 PM
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-383 263	Rooms 18-21 Bldg Attic Classroom 18	Manual	10/8/2025 8:49:02 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	2-383 262	Rooms 18-21 Bldg Attic Classroom 18	Manual	10/8/2025 8:49:04 PM
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-386 265	Rooms 18-21 Bldg Attic Classroom 19	Manual	10/8/2025 8:48:59 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	2-386 264	Rooms 18-21 Bldg Attic Classroom 19	Manual	10/8/2025 9:28:34 PM
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-384 267	Rooms 18-21 Bldg Attic Classroom 20	Manual	10/8/2025 8:48:46 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	2-384 266	Rooms 18-21 Bldg Attic Classroom 20	Manual	10/8/2025 8:48:57 PM
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-385 269	Rooms 18-21 Bldg Attic Classroom 21	Manual	10/8/2025 8:48:43 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	2-385 268	Rooms 18-21 Bldg Attic Classroom 21	Manual	10/8/2025 8:48:44 PM
		Functional Inspection	Passed	
Smoke Detector - General	2-306 261	Rooms 18-21 Bldg Classrm 21 Kiln Rm	Manual	10/8/2025 9:59:50 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-306 261	Rooms 18-21 Bldg Classrm 21 Kiln Rm	Manual	10/8/2025 9:59:50 PM
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-296 241	Rooms 18-21 Bldg Classroom 18	Manual	10/8/2025 10:00:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-295 242	Rooms 18-21 Bldg Classroom 18	Manual	10/8/2025 10:00:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-292 244	Rooms 18-21 Bldg Classroom 18	Manual	10/8/2025 10:00:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-294 243	Rooms 18-21 Bldg Classroom 18	Manual	10/8/2025 10:00:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-293 245	Rooms 18-21 Bldg Classroom 18 Storage	Manual	10/8/2025 10:00:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-312 249	Rooms 18-21 Bldg Classroom 19	Manual	10/8/2025 9:59:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-311 248	Rooms 18-21 Bldg Classroom 19	Manual	10/8/2025 9:59:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-309 246	Rooms 18-21 Bldg Classroom 19	Manual	10/8/2025 10:00:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-308 247	Rooms 18-21 Bldg Classroom 19	Manual	10/8/2025 10:00:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-310 250	Rooms 18-21 Bldg Classroom 19 Storage	Manual	10/8/2025 10:00:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-301 253	Rooms 18-21 Bldg Classroom 20	Manual	10/8/2025 9:59:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-300 254	Rooms 18-21 Bldg Classroom 20	Manual	10/8/2025 9:59:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-298 251	Rooms 18-21 Bldg Classroom 20	Manual	10/8/2025 9:59:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-297 252	Rooms 18-21 Bldg Classroom 20	Manual	10/8/2025 9:59:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-299 255	Rooms 18-21 Bldg Classroom 20 Storage	Manual	10/8/2025 9:59:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-302 259	Rooms 18-21 Bldg Classroom 21	Manual	10/8/2025 9:59:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-303 258	Rooms 18-21 Bldg Classroom 21	Manual	10/8/2025 9:59:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-305 256	Rooms 18-21 Bldg Classroom 21	Manual	10/8/2025 9:59:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-307 257	Rooms 18-21 Bldg Classroom 21	Manual	10/8/2025 9:59:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-304 260	Rooms 18-21 Bldg Classroom 21 Storage	Manual	10/8/2025 9:59:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-389 297	Rooms 22-25 Bldg Attic Classroom 22	Manual	10/8/2025 8:48:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-389 296	Rooms 22-25 Bldg Attic Classroom 22	Manual	10/8/2025 8:48:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-388 299	Rooms 22-25 Bldg Attic Classroom 23	Manual	10/8/2025 8:48:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-388 298	Rooms 22-25 Bldg Attic Classroom 23	Manual	10/8/2025 8:48:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-390 301	Rooms 22-25 Bldg Attic Classroom 24	Manual	10/8/2025 8:48:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-390 300	Rooms 22-25 Bldg Attic Classroom 24	Manual	10/8/2025 8:48:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-387 303	Rooms 22-25 Bldg Attic Classroom 25	Manual	10/8/2025 8:48:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-387 302	Rooms 22-25 Bldg Attic Classroom 25	Manual	10/8/2025 8:48:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-322 278	Rooms 22-25 Bldg Classroom 22	Manual	10/8/2025 9:59:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-323 279	Rooms 22-25 Bldg Classroom 22	Manual	10/8/2025 9:59:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-325 276	Rooms 22-25 Bldg Classroom 22	Manual	10/8/2025 9:59:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-326 277	Rooms 22-25 Bldg Classroom 22	Manual	10/8/2025 9:59:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-324 280	Rooms 22-25 Bldg Classroom 22 Storage	Manual	10/8/2025 10:00:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-317 283	Rooms 22-25 Bldg Classroom 23	Manual	10/8/2025 9:59:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-318 284	Rooms 22-25 Bldg Classroom 23	Manual	10/8/2025 9:59:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-320 282	Rooms 22-25 Bldg Classroom 23	Manual	10/8/2025 9:59:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-321 281	Rooms 22-25 Bldg Classroom 23	Manual	10/8/2025 9:59:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-319 285	Rooms 22-25 Bldg Classroom 23 Storage	Manual	10/8/2025 9:58:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-331 289	Rooms 22-25 Bldg Classroom 24	Manual	10/8/2025 9:58:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-330 288	Rooms 22-25 Bldg Classroom 24	Manual	10/8/2025 9:58:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-328 286	Rooms 22-25 Bldg Classroom 24	Manual	10/8/2025 9:58:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-327 287	Rooms 22-25 Bldg Classroom 24	Manual	10/8/2025 9:58:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-329 290	Rooms 22-25 Bldg Classroom 24 Storage	Manual	10/8/2025 9:58:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-314 294	Rooms 22-25 Bldg Classroom 25	Manual	10/8/2025 9:28:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-313 293	Rooms 22-25 Bldg Classroom 25	Manual	10/8/2025 9:28:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-316 291	Rooms 22-25 Bldg Classroom 25	Manual	10/8/2025 9:28:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-315 292	Rooms 22-25 Bldg Classroom 25	Manual	10/8/2025 9:58:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-312 295	Rooms 22-25 Bldg Classroom 25 Storage	Manual	10/8/2025 9:28:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	3-385 332	Rooms 26-28 Bldg Attic Classroom 26	Manual	10/8/2025 8:48:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-385 333	Rooms 26-28 Bldg Attic Classroom 26	Manual	10/8/2025 10:20:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-384 334	Rooms 26-28 Bldg Attic Classroom 27	Manual	10/8/2025 8:48:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-384 335	Rooms 26-28 Bldg Attic Classroom 27	Manual	10/8/2025 8:48:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-386 336	Rooms 26-28 Bldg Attic Classroom 28	Manual	10/8/2025 10:19:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-386 337	Rooms 26-28 Bldg Attic Classroom 28	Manual	10/8/2025 10:19:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-296 329	Rooms 26-28 Bldg Boys RR by Rm 28	Manual	10/8/2025 9:29:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-297 330	Rooms 26-28 Bldg Boys RR by Rm 28	Manual	10/8/2025 9:29:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-302 313	Rooms 26-28 Bldg Classroom 26	Manual	10/8/2025 9:30:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-301 314	Rooms 26-28 Bldg Classroom 26	Manual	10/8/2025 9:30:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-304 311	Rooms 26-28 Bldg Classroom 26	Manual	10/8/2025 9:30:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-305 312	Rooms 26-28 Bldg Classroom 26	Manual	10/8/2025 9:58:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-303 315	Rooms 26-28 Bldg Classroom 26 Storage	Manual	10/8/2025 9:30:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-293 317	Rooms 26-28 Bldg Classroom 27	Manual	10/8/2025 9:58:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-292 316	Rooms 26-28 Bldg Classroom 27	Manual	10/8/2025 9:58:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-295 318	Rooms 26-28 Bldg Classroom 27	Manual	10/8/2025 9:58:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-294 319	Rooms 26-28 Bldg Classroom 27	Manual	10/8/2025 9:58:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-291 320	Rooms 26-28 Bldg Classroom 27 Storage	Manual	10/8/2025 9:58:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-309 323	Rooms 26-28 Bldg Classroom 28	Manual	10/8/2025 9:30:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-307 321	Rooms 26-28 Bldg Classroom 28	Manual	10/8/2025 9:30:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-306 322	Rooms 26-28 Bldg Classroom 28	Manual	10/8/2025 9:30:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-310 324	Rooms 26-28 Bldg Classroom 28	Manual	10/8/2025 9:59:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-308 325	Rooms 26-28 Bldg Classroom 28 Storage	Manual	10/8/2025 9:30:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-311 326	Rooms 26-28 Bldg Cust. Closet by Rm 28	Manual	10/8/2025 9:29:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-298 331	Rooms 26-28 Bldg Field Storage by Rm 28	Manual	10/8/2025 9:29:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-299 327	Rooms 26-28 Bldg Girls RR by Rm 28	Manual	10/8/2025 9:29:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-300 328	Rooms 26-28 Bldg Girls RR by Rm 28	Manual	10/8/2025 9:29:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-383 366	Rooms 29-32 Bldg Attic Classroom 29	Manual	10/8/2025 10:19:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-383 367	Rooms 29-32 Bldg Attic Classroom 29	Manual	10/8/2025 10:19:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-380 368	Rooms 29-32 Bldg Attic Classroom 30	Manual	10/8/2025 8:49:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-380 369	Rooms 29-32 Bldg Attic Classroom 30	Manual	10/8/2025 10:19:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-382 371	Rooms 29-32 Bldg Attic Classroom 31	Manual	10/8/2025 10:19:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	3-382 370	Rooms 29-32 Bldg Attic Classroom 31	Manual	10/8/2025 10:19:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-381 372	Rooms 29-32 Bldg Attic Classroom 32	Manual	10/8/2025 10:19:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-381 373	Rooms 29-32 Bldg Attic Classroom 32	Manual	10/8/2025 10:19:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-290 349	Rooms 29-32 Bldg Classroom 29	Manual	10/8/2025 9:29:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-289 348	Rooms 29-32 Bldg Classroom 29	Manual	10/8/2025 9:29:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-287 346	Rooms 29-32 Bldg Classroom 29	Manual	10/8/2025 9:29:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-286 347	Rooms 29-32 Bldg Classroom 29	Manual	10/8/2025 9:29:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-288 350	Rooms 29-32 Bldg Classroom 29 Storage	Manual	10/8/2025 9:29:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-273 351	Rooms 29-32 Bldg Classroom 30	Manual	10/8/2025 9:29:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-272 352	Rooms 29-32 Bldg Classroom 30	Manual	10/8/2025 9:29:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-275 353	Rooms 29-32 Bldg Classroom 30	Manual	10/8/2025 9:29:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-274 354	Rooms 29-32 Bldg Classroom 30	Manual	10/8/2025 9:29:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-271 355	Rooms 29-32 Bldg Classroom 30 Storage	Manual	10/8/2025 9:29:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-282 358	Rooms 29-32 Bldg Classroom 31	Manual	10/8/2025 9:29:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-281 359	Rooms 29-32 Bldg Classroom 31	Manual	10/8/2025 9:29:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-284 356	Rooms 29-32 Bldg Classroom 31	Manual	10/8/2025 9:29:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-285 357	Rooms 29-32 Bldg Classroom 31	Manual	10/8/2025 9:29:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-283 360	Rooms 29-32 Bldg Classroom 31 Storage	Manual	10/8/2025 9:29:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-280 362	Rooms 29-32 Bldg Classroom 32	Manual	10/8/2025 9:29:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-279 361	Rooms 29-32 Bldg Classroom 32	Manual	10/8/2025 9:29:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-277 363	Rooms 29-32 Bldg Classroom 32	Manual	10/8/2025 9:29:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-276 364	Rooms 29-32 Bldg Classroom 32	Manual	10/8/2025 9:29:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-278 365	Rooms 29-32 Bldg Classroom 32 Storage	Manual	10/8/2025 9:29:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-376 402	Rooms 33-36 Bldg Attic Classroom 33	Manual	10/8/2025 8:49:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-376 401	Rooms 33-36 Bldg Attic Classroom 33	Manual	10/8/2025 8:49:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-379 403	Rooms 33-36 Bldg Attic Classroom 34	Manual	10/8/2025 8:49:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-379 404	Rooms 33-36 Bldg Attic Classroom 34	Manual	10/8/2025 8:49:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-377 405	Rooms 33-36 Bldg Attic Classroom 35	Manual	10/8/2025 10:19:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-377 406	Rooms 33-36 Bldg Attic Classroom 35	Manual	10/8/2025 10:19:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-378 407	Rooms 33-36 Bldg Attic Classroom 36	Manual	10/8/2025 10:19:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-378 408	Rooms 33-36 Bldg Attic Classroom 36	Manual	10/8/2025 10:19:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-255 381	Rooms 33-36 Bldg Classroom 33	Manual	10/8/2025 9:28:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-252 384	Rooms 33-36 Bldg Classroom 33	Manual	10/8/2025 9:28:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-253 383	Rooms 33-36 Bldg Classroom 33	Manual	10/8/2025 9:28:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-254 382	Rooms 33-36 Bldg Classroom 33	Manual	10/8/2025 10:01:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-251 385	Rooms 33-36 Bldg Classroom 33 Storage	Manual	10/8/2025 9:28:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-269 388	Rooms 33-36 Bldg Classroom 34	Manual	10/8/2025 9:28:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-270 389	Rooms 33-36 Bldg Classroom 34	Manual	10/8/2025 9:28:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-267 386	Rooms 33-36 Bldg Classroom 34	Manual	10/8/2025 9:28:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-266 387	Rooms 33-36 Bldg Classroom 34	Manual	10/8/2025 10:01:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-268 390	Rooms 33-36 Bldg Classroom 34 Storage	Manual	10/8/2025 9:28:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-259 394	Rooms 33-36 Bldg Classroom 35	Manual	10/8/2025 8:49:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-260 393	Rooms 33-36 Bldg Classroom 35	Manual	10/8/2025 9:28:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-256 392	Rooms 33-36 Bldg Classroom 35	Manual	10/8/2025 9:28:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-257 391	Rooms 33-36 Bldg Classroom 35	Manual	10/8/2025 9:28:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-258 395	Rooms 33-36 Bldg Classroom 35 Storage	Manual	10/8/2025 9:28:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-261 398	Rooms 33-36 Bldg Classroom 36	Manual	10/8/2025 9:28:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-262 399	Rooms 33-36 Bldg Classroom 36	Manual	10/8/2025 9:28:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-264 396	Rooms 33-36 Bldg Classroom 36	Manual	10/8/2025 9:28:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-265 397	Rooms 33-36 Bldg Classroom 36	Manual	10/8/2025 9:28:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-263 400	Rooms 33-36 Bldg Classroom 36 Storage	Manual	10/8/2025 9:28:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-151 165	Rooms 7-10 Bldg Attic Classroom 10	Manual	10/8/2025 8:49:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-151 166	Rooms 7-10 Bldg Attic Classroom 10	Manual	10/8/2025 8:49:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-149 160	Rooms 7-10 Bldg Attic Classroom 7	Manual	10/8/2025 8:49:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-149 159	Rooms 7-10 Bldg Attic Classroom 7	Manual	10/8/2025 8:49:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-150 161	Rooms 7-10 Bldg Attic Classroom 8	Manual	10/8/2025 8:49:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-150 162	Rooms 7-10 Bldg Attic Classroom 8	Manual	10/8/2025 8:49:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-148 164	Rooms 7-10 Bldg Attic Classroom 9	Manual	10/8/2025 8:49:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-148 163	Rooms 7-10 Bldg Attic Classroom 9	Manual	10/8/2025 8:49:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-090 157	Rooms 7-10 Bldg Classroom 10	Manual	10/8/2025 10:02:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-091 156	Rooms 7-10 Bldg Classroom 10	Manual	10/8/2025 10:02:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-088 154	Rooms 7-10 Bldg Classroom 10	Manual	10/8/2025 10:02:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-087 155	Rooms 7-10 Bldg Classroom 10	Manual	10/8/2025 10:02:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-089 158	Rooms 7-10 Bldg Classroom 10 Storage	Manual	10/8/2025 10:02:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-081 140	Rooms 7-10 Bldg Classroom 7	Manual	10/8/2025 10:02:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-080 139	Rooms 7-10 Bldg Classroom 7	Manual	10/8/2025 10:02:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-078 142	Rooms 7-10 Bldg Classroom 7	Manual	10/8/2025 10:02:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-077 141	Rooms 7-10 Bldg Classroom 7	Manual	10/8/2025 10:02:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-079 143	Rooms 7-10 Bldg Classroom 7 Storage	Manual	10/8/2025 10:02:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-083 145	Rooms 7-10 Bldg Classroom 8	Manual	10/8/2025 10:02:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-082 144	Rooms 7-10 Bldg Classroom 8	Manual	10/8/2025 10:02:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-085 146	Rooms 7-10 Bldg Classroom 8	Manual	10/8/2025 10:02:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-086 147	Rooms 7-10 Bldg Classroom 8	Manual	10/8/2025 10:02:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-084 148	Rooms 7-10 Bldg Classroom 8 Storage	Manual	10/8/2025 10:02:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-073 151	Rooms 7-10 Bldg Classroom 9	Manual	10/8/2025 10:01:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-074 152	Rooms 7-10 Bldg Classroom 9	Manual	10/8/2025 10:01:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-076 149	Rooms 7-10 Bldg Classroom 9	Manual	10/8/2025 10:01:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-075 150	Rooms 7-10 Bldg Classroom 9	Manual	10/8/2025 10:01:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-072 153	Rooms 7-10 Bldg Classroom 9 Storage	Manual	10/8/2025 10:01:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Skipped				
EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General		Admin / MP Bldg Kitchen Office	Manual	10/8/2025 10:02:54 PM

Device/Equipment details

Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Audible					
079	Admin / MP Bldg North Exterior				
080	Admin / MP Bldg North Exterior				
081	Admin / MP Bldg East Exterior				
082	Admin / MP Bldg South Exterior				
083	Admin / MP Bldg South Exterior				
084	Admin / MP Bldg West Exterior				
112	Admin / MP Bldg Northeast Exterior - Electric Bell				
133	Rooms 1 & 2 Bldg South Exterior				
167	Rooms 7-10 Bldg East Exterior				
168	Rooms 7-10 Bldg West Exterior				
201	Rooms 11-14 Bldg West Exterior				
233	Rooms 15-17 Bldg North Exterior				
234	Rooms 15-17 Bldg South Exterior				
270	Rooms 18-21 Bldg North Exterior				
271	Rooms 18-21 Bldg West Exterior				
304	Rooms 22-25 Bldg North Exterior				
305	Rooms 22-25 Bldg East Exterior				
306	Rooms 22-25 Bldg West Exterior				
338	Rooms 26-28 Bldg North Exterior				
339	Rooms 26-28 Bldg West Exterior				
374	Rooms 29-32 Bldg North Exterior				
375	Rooms 29-32 Bldg East Exterior				
376	Rooms 29-32 Bldg West Exterior				
409	Rooms 33-36 Bldg North Exterior				
Audible And Visible					
085	Admin / MP Bldg MP Room				
086	Admin / MP Bldg MP Room				
087	Admin / MP Bldg MP Room Mezz				
088	Admin / MP Bldg Kitchen				
089	Admin / MP Bldg MP Stage				
090	Admin / MP Bldg MP Music Room				
091	Admin / MP Bldg Media Work Room				
092	Admin / MP Bldg Media Room				
093	Admin / MP Bldg Staff Break Room				
094	Admin / MP Bldg Admin Restrnm Hall				
095	Admin / MP Bldg Admin Reception				
096	Admin / MP Bldg Classroom 3				
097	Admin / MP Bldg Classroom 4				
098	Admin / MP Bldg Classroom 5				
099	Admin / MP Bldg Classroom 6				
134	Rooms 1 & 2 Bldg Classroom 1				
135	Rooms 1 & 2 Bldg Classroom 2				
169	Rooms 7-10 Bldg Classroom 7				
170	Rooms 7-10 Bldg Classroom 8				
171	Rooms 7-10 Bldg Classroom 9				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
172	Rooms 7-10 Bldg Classroom 10				
202	Rooms 11-14 Bldg Classroom 11				
203	Rooms 11-14 Bldg Classroom 12				
204	Rooms 11-14 Bldg Classroom 13				
205	Rooms 11-14 Bldg Classroom 14				
235	Rooms 15-17 Bldg Classroom 15				
236	Rooms 15-17 Bldg Classroom 16				
237	Rooms 15-17 Bldg Classroom 17				
238	Rooms 15-17 Bldg Girls RR by Rm 15				
239	Rooms 15-17 Bldg Boys RR by Rm 15				
272	Rooms 18-21 Bldg Classroom 18				
273	Rooms 18-21 Bldg Classroom 19				
274	Rooms 18-21 Bldg Classroom 20				
275	Rooms 18-21 Bldg Classroom 21				
307	Rooms 22-25 Bldg Classroom 22				
308	Rooms 22-25 Bldg Classroom 23				
309	Rooms 22-25 Bldg Classroom 24				
310	Rooms 22-25 Bldg Classroom 25				
340	Rooms 26-28 Bldg Classroom 26				
341	Rooms 26-28 Bldg Classroom 27				
342	Rooms 26-28 Bldg Classroom 28				
343	Rooms 26-28 Bldg Girls RR by Rm 28				
344	Rooms 26-28 Bldg Boys RR by Rm 28				
377	Rooms 29-32 Bldg Classroom 29				
378	Rooms 29-32 Bldg Classroom 30				
379	Rooms 29-32 Bldg Classroom 31				
380	Rooms 29-32 Bldg Classroom 32				
410	Rooms 33-36 Bldg Classroom 33				
411	Rooms 33-36 Bldg Classroom 34				
412	Rooms 33-36 Bldg Classroom 35				
413	Rooms 33-36 Bldg Classroom 36				
Visible					
100	Admin / MP Bldg MP East Entrance				
101	Admin / MP Bldg Kitchen Office				
102	Admin / MP Bldg MP Music Rm Hall				
103	Admin / MP Bldg MP West Entrance				
104	Admin / MP Bldg Media A/V Room				
105	Admin / MP Bldg Admin Womens RR				
106	Admin / MP Bldg Admin Mens RR				
107	Admin / MP Bldg Admin Lobby				
108	Admin / MP Bldg Principals Office				
109	Admin / MP Bldg Nurses Office				
110	Admin / MP Bldg Nurses Office RR				
111	Admin / MP Bldg Classrm 5 Computer Rm				
136	Rooms 1 & 2 Bldg Classrm 1 Girls RR				
137	Rooms 1 & 2 Bldg Classrm 2 Boys RR				

Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Remote Annunciator					
001	Admin / MP Bldg Admin Reception				
NAC Power Extender Panel					
113	Admin / MP Bldg MP Chair Storage - P.E. "B"				
138	Rooms 1 & 2 Bldg Rms 1 & 2 O/S Storage - P.E. "C"				
240	Rooms 15-17 Bldg Cust. Closet by Rm 15 - P.E. "D"				
345	Rooms 26-28 Bldg Cust. Closet by Rm 28 - P.E. "E"				
	Admin / MP Bldg MP Chair Storage - P.E. "IL2"				
Fire Alarm Panel					
	Admin / MP Bldg MP Chair Storage	EST		3	

Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Manual Pull Station					
2-130 002	Admin / MP Bldg Admin Reception				
2-142 003	Admin / MP Bldg MP East Entrance				
2-136 004	Admin / MP Bldg MP West Entrance				
Smoke Detector - General					
2-024 005	Admin / MP Bldg MP Room				
2-026 006	Admin / MP Bldg MP Room				
2-023 007	Admin / MP Bldg MP Room				
2-021 008	Admin / MP Bldg MP Room				
2-018 009	Admin / MP Bldg MP Room Mezz				
2-020 010	Admin / MP Bldg MP Room Mezz				
2-019 011	Admin / MP Bldg MP Room				
2-022 012	Admin / MP Bldg MP Room				
2-025 013	Admin / MP Bldg MP Room				
2-039 014	Admin / MP Bldg MP Chair Storage				
2-001 015	Admin / MP Bldg MP Electrical Room				
2-041 016	Admin / MP Bldg MP East Entrance				
017	Admin / MP Bldg MP Custodial Office				
018	Admin / MP Bldg Kitchen Office				
2-046 019	Admin / MP Bldg MP Stage				
2-049 020	Admin / MP Bldg MP Stage				
2-050 021	Admin / MP Bldg MP Stage				
2-051 022	Admin / MP Bldg MP Stage				
2-048 023	Admin / MP Bldg MP Stage				
2-047 024	Admin / MP Bldg MP Stage				
2-044 025	Admin / MP Bldg MP Stage Storage				
2-053 026	Admin / MP Bldg MP Music Room				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-052 027	Admin / MP Bldg MP Music Room				
2-054 028	Admin / MP Bldg MP Music Rm Hall				
2-055 029	Admin / MP Bldg Music Rm Mezz. Access				
2-029 030	Admin / MP Bldg MP West Entrance				
2-057 031	Admin / MP Bldg Field Storage				
2-028 032	Admin / MP Bldg Media A/V Room				
2-027 033	Admin / MP Bldg Media Work Room				
2-032 034	Admin / MP Bldg Media Room				
2-031 035	Admin / MP Bldg Media Room				
2-030 036	Admin / MP Bldg Media Room				
2-015 037	Admin / MP Bldg Staff Break Room				
2-013 038	Admin / MP Bldg Admin Restrtn Hall				
2-012 039	Admin / MP Bldg Admin Womens RR				
2-011 040	Admin / MP Bldg Admin Mens RR				
2-092 041	Admin / MP Bldg Admin Mens RR Closet				
2-093 042	Admin / MP Bldg MP Mezz Storage Stairs				
2-016 043	Admin / MP Bldg MP Mezz Storage				
2-010 044	Admin / MP Bldg Admin Lobby				
2-007 045	Admin / MP Bldg Admin Reception				
2-003 046	Admin / MP Bldg Principals Office				
2-004 047	Admin / MP Bldg Principals Off Closet				
2-002 048	Admin / MP Bldg Princ Off Conf Rm				
2-006 049	Admin / MP Bldg Nurses Office				
2-005 050	Admin / MP Bldg Nurses Office RR				
2-008 051	Admin / MP Bldg Nurse Office Closet				
2-009 052	Admin / MP Bldg Vice Principals Office				
2-033 053	Admin / MP Bldg Classroom 3				
2-034 054	Admin / MP Bldg Classroom 3 Closet				
2-035 055	Admin / MP Bldg Classroom 4				
2-037 056	Admin / MP Bldg Classroom 5				
2-036 057	Admin / MP Bldg Classrm 5 Computer Rm				
2-038 058	Admin / MP Bldg Classroom 6				
2-068 114	Rooms 1 & 2 Bldg Classroom 1				
2-066 115	Rooms 1 & 2 Bldg Classroom 1				
2-067 116	Rooms 1 & 2 Bldg Classroom 1				
2-065 117	Rooms 1 & 2 Bldg Classroom 1				
2-069 118	Rooms 1 & 2 Bldg Classrm 1 Girls RR				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-064 119	Rooms 1 & 2 Bldg Classroom 1 Storage				
2-063 120	Rooms 1 & 2 Bldg Classroom 2				
2-058 121	Rooms 1 & 2 Bldg Classroom 2				
2-061 122	Rooms 1 & 2 Bldg Classroom 2				
2-060 123	Rooms 1 & 2 Bldg Classroom 2				
2-059 124	Rooms 1 & 2 Bldg Classroom 2				
2-071 125	Rooms 1 & 2 Bldg Classrm 2 Boys RR				
2-070 126	Rooms 1 & 2 Bldg Rms 1 & 2 O/S Storage				
2-080 139	Rooms 7-10 Bldg Classroom 7				
2-081 140	Rooms 7-10 Bldg Classroom 7				
2-077 141	Rooms 7-10 Bldg Classroom 7				
2-078 142	Rooms 7-10 Bldg Classroom 7				
2-079 143	Rooms 7-10 Bldg Classroom 7 Storage				
2-082 144	Rooms 7-10 Bldg Classroom 8				
2-083 145	Rooms 7-10 Bldg Classroom 8				
2-085 146	Rooms 7-10 Bldg Classroom 8				
2-086 147	Rooms 7-10 Bldg Classroom 8				
2-084 148	Rooms 7-10 Bldg Classroom 8 Storage				
2-076 149	Rooms 7-10 Bldg Classroom 9				
2-075 150	Rooms 7-10 Bldg Classroom 9				
2-073 151	Rooms 7-10 Bldg Classroom 9				
2-074 152	Rooms 7-10 Bldg Classroom 9				
2-072 153	Rooms 7-10 Bldg Classroom 9 Storage				
2-088 154	Rooms 7-10 Bldg Classroom 10				
2-087 155	Rooms 7-10 Bldg Classroom 10				
2-091 156	Rooms 7-10 Bldg Classroom 10				
2-090 157	Rooms 7-10 Bldg Classroom 10				
2-089 158	Rooms 7-10 Bldg Classroom 10 Storage				
2-255 173	Rooms 11-14 Bldg Classroom 11				
2-254 174	Rooms 11-14 Bldg Classroom 11				
2-253 175	Rooms 11-14 Bldg Classroom 11				
2-252 176	Rooms 11-14 Bldg Classroom 11				
2-251 177	Rooms 11-14 Bldg Classroom 11 Storage				
2-267 178	Rooms 11-14 Bldg Classroom 12				
2-266 179	Rooms 11-14 Bldg Classroom 12				
2-270 180	Rooms 11-14 Bldg Classroom 12				
2-269 181	Rooms 11-14 Bldg Classroom 12				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-268 182	Rooms 11-14 Bldg Classroom 12 Storage				
2-257 183	Rooms 11-14 Bldg Classroom 13				
2-256 184	Rooms 11-14 Bldg Classroom 13				
2-259 185	Rooms 11-14 Bldg Classroom 13				
2-260 186	Rooms 11-14 Bldg Classroom 13				
2-258 187	Rooms 11-14 Bldg Classroom 13 Storage				
2-265 188	Rooms 11-14 Bldg Classroom 14				
2-264 189	Rooms 11-14 Bldg Classroom 14				
2-262 190	Rooms 11-14 Bldg Classroom 14				
2-261 191	Rooms 11-14 Bldg Classroom 14				
2-263 192	Rooms 11-14 Bldg Classroom 14 Storage				
2-287 206	Rooms 15-17 Bldg Classroom 15				
2-286 207	Rooms 15-17 Bldg Classroom 15				
2-289 208	Rooms 15-17 Bldg Classroom 15				
2-290 209	Rooms 15-17 Bldg Classroom 15				
2-288 210	Rooms 15-17 Bldg Classroom 15 Storage				
2-284 211	Rooms 15-17 Bldg Classroom 16				
2-285 212	Rooms 15-17 Bldg Classroom 16				
2-281 213	Rooms 15-17 Bldg Classroom 16				
2-282 214	Rooms 15-17 Bldg Classroom 16				
2-283 215	Rooms 15-17 Bldg Classroom 16 Storage				
2-275 216	Rooms 15-17 Bldg Classroom 17				
2-274 217	Rooms 15-17 Bldg Classroom 17				
2-273 218	Rooms 15-17 Bldg Classroom 17				
2-272 219	Rooms 15-17 Bldg Classroom 17				
2-271 220	Rooms 15-17 Bldg Classroom 17 Storage				
2-291 221	Rooms 15-17 Bldg Cust. Closet by Rm 15				
2-280 222	Rooms 15-17 Bldg Girls RR by Rm 15				
2-279 223	Rooms 15-17 Bldg Girls RR by Rm 15				
2-278 224	Rooms 15-17 Bldg Field Storage by Rm 15				
2-276 225	Rooms 15-17 Bldg Boys RR by Rm 15				
2-277 226	Rooms 15-17 Bldg Boys RR by Rm 15				
2-296 241	Rooms 18-21 Bldg Classroom 18				
2-295 242	Rooms 18-21 Bldg Classroom 18				
2-294 243	Rooms 18-21 Bldg Classroom 18				
2-292 244	Rooms 18-21 Bldg Classroom 18				
2-293 245	Rooms 18-21 Bldg Classroom 18 Storage				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-309 246	Rooms 18-21 Bldg Classroom 19				
2-308 247	Rooms 18-21 Bldg Classroom 19				
2-311 248	Rooms 18-21 Bldg Classroom 19				
2-312 249	Rooms 18-21 Bldg Classroom 19				
2-310 250	Rooms 18-21 Bldg Classroom 19 Storage				
2-298 251	Rooms 18-21 Bldg Classroom 20				
2-297 252	Rooms 18-21 Bldg Classroom 20				
2-301 253	Rooms 18-21 Bldg Classroom 20				
2-300 254	Rooms 18-21 Bldg Classroom 20				
2-299 255	Rooms 18-21 Bldg Classroom 20 Storage				
2-305 256	Rooms 18-21 Bldg Classroom 21				
2-307 257	Rooms 18-21 Bldg Classroom 21				
2-303 258	Rooms 18-21 Bldg Classroom 21				
2-302 259	Rooms 18-21 Bldg Classroom 21				
2-304 260	Rooms 18-21 Bldg Classroom 21 Storage				
2-306 261	Rooms 18-21 Bldg Classrm 21 Kiln Rm				
3-325 276	Rooms 22-25 Bldg Classroom 22				
3-326 277	Rooms 22-25 Bldg Classroom 22				
3-322 278	Rooms 22-25 Bldg Classroom 22				
3-323 279	Rooms 22-25 Bldg Classroom 22				
3-324 280	Rooms 22-25 Bldg Classroom 22 Storage				
3-321 281	Rooms 22-25 Bldg Classroom 23				
3-320 282	Rooms 22-25 Bldg Classroom 23				
3-317 283	Rooms 22-25 Bldg Classroom 23				
3-318 284	Rooms 22-25 Bldg Classroom 23				
3-319 285	Rooms 22-25 Bldg Classroom 23 Storage				
3-328 286	Rooms 22-25 Bldg Classroom 24				
3-327 287	Rooms 22-25 Bldg Classroom 24				
3-330 288	Rooms 22-25 Bldg Classroom 24				
3-331 289	Rooms 22-25 Bldg Classroom 24				
3-329 290	Rooms 22-25 Bldg Classroom 24 Storage				
3-316 291	Rooms 22-25 Bldg Classroom 25				
3-315 292	Rooms 22-25 Bldg Classroom 25				
3-313 293	Rooms 22-25 Bldg Classroom 25				
3-314 294	Rooms 22-25 Bldg Classroom 25				
3-312 295	Rooms 22-25 Bldg Classroom 25 Storage				
3-304 311	Rooms 26-28 Bldg Classroom 26				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3-305 312	Rooms 26-28 Bldg Classroom 26				
3-302 313	Rooms 26-28 Bldg Classroom 26				
3-301 314	Rooms 26-28 Bldg Classroom 26				
3-303 315	Rooms 26-28 Bldg Classroom 26 Storage				
3-292 316	Rooms 26-28 Bldg Classroom 27				
3-293 317	Rooms 26-28 Bldg Classroom 27				
3-295 318	Rooms 26-28 Bldg Classroom 27				
3-294 319	Rooms 26-28 Bldg Classroom 27				
3-291 320	Rooms 26-28 Bldg Classroom 27 Storage				
3-307 321	Rooms 26-28 Bldg Classroom 28				
3-306 322	Rooms 26-28 Bldg Classroom 28				
3-309 323	Rooms 26-28 Bldg Classroom 28				
3-310 324	Rooms 26-28 Bldg Classroom 28				
3-308 325	Rooms 26-28 Bldg Classroom 28 Storage				
3-311 326	Rooms 26-28 Bldg Cust. Closet by Rm 28				
3-299 327	Rooms 26-28 Bldg Girls RR by Rm 28				
3-300 328	Rooms 26-28 Bldg Girls RR by Rm 28				
3-296 329	Rooms 26-28 Bldg Boys RR by Rm 28				
3-297 330	Rooms 26-28 Bldg Boys RR by Rm 28				
3-298 331	Rooms 26-28 Bldg Field Storage by Rm 28				
3-287 346	Rooms 29-32 Bldg Classroom 29				
3-286 347	Rooms 29-32 Bldg Classroom 29				
3-289 348	Rooms 29-32 Bldg Classroom 29				
3-290 349	Rooms 29-32 Bldg Classroom 29				
3-288 350	Rooms 29-32 Bldg Classroom 29 Storage				
3-273 351	Rooms 29-32 Bldg Classroom 30				
3-272 352	Rooms 29-32 Bldg Classroom 30				
3-275 353	Rooms 29-32 Bldg Classroom 30				
3-274 354	Rooms 29-32 Bldg Classroom 30				
3-271 355	Rooms 29-32 Bldg Classroom 30 Storage				
3-284 356	Rooms 29-32 Bldg Classroom 31				
3-285 357	Rooms 29-32 Bldg Classroom 31				
3-282 358	Rooms 29-32 Bldg Classroom 31				
3-281 359	Rooms 29-32 Bldg Classroom 31				
3-283 360	Rooms 29-32 Bldg Classroom 31 Storage				
3-279 361	Rooms 29-32 Bldg Classroom 32				
3-280 362	Rooms 29-32 Bldg Classroom 32				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3-277 363	Rooms 29-32 Bldg Classroom 32				
3-276 364	Rooms 29-32 Bldg Classroom 32				
3-278 365	Rooms 29-32 Bldg Classroom 32 Storage				
3-255 381	Rooms 33-36 Bldg Classroom 33				
3-254 382	Rooms 33-36 Bldg Classroom 33				
3-253 383	Rooms 33-36 Bldg Classroom 33				
3-252 384	Rooms 33-36 Bldg Classroom 33				
3-251 385	Rooms 33-36 Bldg Classroom 33 Storage				
3-267 386	Rooms 33-36 Bldg Classroom 34				
3-266 387	Rooms 33-36 Bldg Classroom 34				
3-269 388	Rooms 33-36 Bldg Classroom 34				
3-270 389	Rooms 33-36 Bldg Classroom 34				
3-268 390	Rooms 33-36 Bldg Classroom 34 Storage				
3-257 391	Rooms 33-36 Bldg Classroom 35				
3-256 392	Rooms 33-36 Bldg Classroom 35				
3-260 393	Rooms 33-36 Bldg Classroom 35				
3-259 394	Rooms 33-36 Bldg Classroom 35				
3-258 395	Rooms 33-36 Bldg Classroom 35 Storage				
3-264 396	Rooms 33-36 Bldg Classroom 36				
3-265 397	Rooms 33-36 Bldg Classroom 36				
3-261 398	Rooms 33-36 Bldg Classroom 36				
3-262 399	Rooms 33-36 Bldg Classroom 36				
3-263 400	Rooms 33-36 Bldg Classroom 36 Storage				
2-017	Admin / MP Bldg MP Mezz Storage				
2-014	Admin / MP Bldg Staff Break Rm Ph Booth				
2-062	Rooms 1 & 2 Bldg Classroom 2 Storage				
2-040	Admin / MP Bldg MP Chair Storage				
2-056	Admin / MP Bldg Field Storage ACS				
Heat Detector - Restorable Spot					
2-042 059	Admin / MP Bldg Kitchen				
2-143 060	Admin / MP Bldg Attic Kitchen				
2-135 061	Admin / MP Bldg Attic MP W Entrance				
2-134 062	Admin / MP Bldg Attic Media A/V Rm				
2-133 063	Admin / MP Bldg Attic Media Work Rm				
2-133 064	Admin / MP Bldg Attic Media Work Rm				
2-137 065	Admin / MP Bldg Attic Media Room				
2-137 066	Admin / MP Bldg Attic Media Room				
2-138 067	Admin / MP Bldg Attic Classroom 3				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-139 068	Admin / MP Bldg Attic Classroom 4				
2-140 069	Admin / MP Bldg Attic Classroom 5				
2-141 070	Admin / MP Bldg Attic Classroom 6				
2-132 071	Admin / MP Bldg Attic Staff Breakroom				
2-132 072	Admin / MP Bldg Attic Staff Breakroom				
2-131 073	Admin / MP Bldg Attic Admin Lobby				
2-131 074	Admin / MP Bldg Attic Admin Lobby				
2-129 075	Admin / MP Bldg Attic Admin				
2-129 076	Admin / MP Bldg Attic Admin				
2-146 127	Rooms 1 & 2 Bldg Attic Classroom 1				
2-146 128	Rooms 1 & 2 Bldg Attic Classroom 1				
2-147 129	Rooms 1 & 2 Bldg Attic Btwn Rms 1 & 2				
2-147 130	Rooms 1 & 2 Bldg Attic Btwn Rms 1 & 2				
2-145 131	Rooms 1 & 2 Bldg Attic Classroom 2				
2-145 132	Rooms 1 & 2 Bldg Attic Classroom 2				
2-149 159	Rooms 7-10 Bldg Attic Classroom 7				
2-149 160	Rooms 7-10 Bldg Attic Classroom 7				
2-150 161	Rooms 7-10 Bldg Attic Classroom 8				
2-150 162	Rooms 7-10 Bldg Attic Classroom 8				
2-148 163	Rooms 7-10 Bldg Attic Classroom 9				
2-148 164	Rooms 7-10 Bldg Attic Classroom 9				
2-151 165	Rooms 7-10 Bldg Attic Classroom 10				
2-151 166	Rooms 7-10 Bldg Attic Classroom 10				
2-376 193	Rooms 11-14 Bldg Attic Classroom 11				
2-376 194	Rooms 11-14 Bldg Attic Classroom 11				
2-379 195	Rooms 11-14 Bldg Attic Classroom 12				
2-379 196	Rooms 11-14 Bldg Attic Classroom 12				
2-377 197	Rooms 11-14 Bldg Attic Classroom 13				
2-377 198	Rooms 11-14 Bldg Attic Classroom 13				
2-378 199	Rooms 11-14 Bldg Attic Classroom 14				
2-378 200	Rooms 11-14 Bldg Attic Classroom 14				
2-382 227	Rooms 15-17 Bldg Attic Classroom 15				
2-382 228	Rooms 15-17 Bldg Attic Classroom 15				
2-381 229	Rooms 15-17 Bldg Attic Classroom 16				
2-381 230	Rooms 15-17 Bldg Attic Classroom 16				
2-380 231	Rooms 15-17 Bldg Attic Classroom 17				
2-380 232	Rooms 15-17 Bldg Attic Classroom 17				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-383 262	Rooms 18-21 Bldg Attic Classroom 18				
2-383 263	Rooms 18-21 Bldg Attic Classroom 18				
2-386 264	Rooms 18-21 Bldg Attic Classroom 19				
2-386 265	Rooms 18-21 Bldg Attic Classroom 19				
2-384 266	Rooms 18-21 Bldg Attic Classroom 20				
2-384 267	Rooms 18-21 Bldg Attic Classroom 20				
2-385 268	Rooms 18-21 Bldg Attic Classroom 21				
2-385 269	Rooms 18-21 Bldg Attic Classroom 21				
3-389 296	Rooms 22-25 Bldg Attic Classroom 22				
3-389 297	Rooms 22-25 Bldg Attic Classroom 22				
3-388 298	Rooms 22-25 Bldg Attic Classroom 23				
3-388 299	Rooms 22-25 Bldg Attic Classroom 23				
3-390 300	Rooms 22-25 Bldg Attic Classroom 24				
3-390 301	Rooms 22-25 Bldg Attic Classroom 24				
3-387 302	Rooms 22-25 Bldg Attic Classroom 25				
3-387 303	Rooms 22-25 Bldg Attic Classroom 25				
3-385 332	Rooms 26-28 Bldg Attic Classroom 26				
3-385 333	Rooms 26-28 Bldg Attic Classroom 26				
3-384 334	Rooms 26-28 Bldg Attic Classroom 27				
3-384 335	Rooms 26-28 Bldg Attic Classroom 27				
3-386 336	Rooms 26-28 Bldg Attic Classroom 28				
3-386 337	Rooms 26-28 Bldg Attic Classroom 28				
3-383 366	Rooms 29-32 Bldg Attic Classroom 29				
3-383 367	Rooms 29-32 Bldg Attic Classroom 29				
3-380 368	Rooms 29-32 Bldg Attic Classroom 30				
3-380 369	Rooms 29-32 Bldg Attic Classroom 30				
3-382 370	Rooms 29-32 Bldg Attic Classroom 31				
3-382 371	Rooms 29-32 Bldg Attic Classroom 31				
3-381 372	Rooms 29-32 Bldg Attic Classroom 32				
3-381 373	Rooms 29-32 Bldg Attic Classroom 32				
3-376 401	Rooms 33-36 Bldg Attic Classroom 33				
3-376 402	Rooms 33-36 Bldg Attic Classroom 33				
3-379 403	Rooms 33-36 Bldg Attic Classroom 34				
3-379 404	Rooms 33-36 Bldg Attic Classroom 34				
3-377 405	Rooms 33-36 Bldg Attic Classroom 35				
3-377 406	Rooms 33-36 Bldg Attic Classroom 35				
3-378 407	Rooms 33-36 Bldg Attic Classroom 36				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3-378 408	Rooms 33-36 Bldg Attic Classroom 36				
Mechanical, Electrosonic, or Pressure Waterflow Device					
2-127 077	Admin / MP Bldg Northeast Exterior				
Valve Tamper Switch					
2-128 078	Admin / MP Bldg Northeast Exterior				
Smoke Detector - Duct					
2-170	Admin / MP Bldg MP Chair Storage				
2-171	Admin / MP Bldg MP Stage storage				
2-171	Admin / MP Bldg MP Stage storage				
2-172	Room 5 AHU 8				
2-173	Room 5 AHU 8				
2-169	MP electric Room				