

Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

ARDEN MIDDLE SCHOOL

1640 WATT AVE
SACRAMENTO, California 95864
United States

This site has been inspected and tested in compliance with applicable standards.

Completed
Tuesday, March 03, 2026

Test Session:03 Mar 2026 15:40 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD
5320 HEMLOCK ST
SACRAMENTO, California
United States

TESTED BY

Riley Goyet
Western States Fire Protection-
Sacramento
188 Cirby Way
Roseville, CA 95678
United States



Inspection Summary

Building Information

PROPERTY	ARDEN MIDDLE SCHOOL	CONTACT
ADDRESS	1640 WATT AVE	PHONE
CITY/STATE	SACRAMENTO, California 95864	MOBILE
COUNTRY	United States	EMAIL

Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us

Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Ventilation and Cooking Equipment	6	0(0%)	0(0%)	0(0%)
Fire Control Panel	3	3(100%)	2(67%)	1(33%)
Initiating Device	275	263(96%)	261(95%)	2(1%)
Alarm Notification Appliance	1	1(100%)	1(100%)	0(0%)

Certification

The equipment specified herein was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Tuesday, March 03, 2026

ACCEPTED BY 03/03/2026

Building Representative



TESTED BY 03/03/2026

Riley Goyet
Technician

Open Corrective Action & Solution Summary

The following 3 corrective action(s) remain open following the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
Supervisory - Control Valve		OS&Y Left

Created By: Chris Spencer
 Creation Date: 02/26/2025
 Corrective Action: Tamper fail to report to the panel
 Proposed Solution:
 Manufacturer: System Sensor
 Model: OSY2



Supervisory - Control Valve		OS&Y Right
-----------------------------	--	------------

Created By: Chris Spencer
 Creation Date: 02/26/2025
 Corrective Action: Tamper fail to report to the panel
 Proposed Solution:
 Manufacturer:
 Model:



Fire Alarm Control Panel		FACP - F108 MDF 1.0
--------------------------	--	---------------------

Created By: Riley Goyet
 Creation Date: 03/03/2026
 Corrective Action: Replace (2) 12V 55AH Batteries
 Proposed Solution:
 Manufacturer:
 Model:

Resolved Corrective Action & Solution Summary

The following 1 corrective action(s) were resolved during the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	Description
Smoke Detector - General	2.364	MP Bldg Stage Hall W
	Created By:	Riley Goyet
	Creation Date:	03/03/2026
	Corrective Action:	Did not activate
	Resolution:	
	Resolved By:	Riley Goyet
	Resolved On:	03/03/2026
	Manufacturer:	
	Model:	

Testing Details

Alarm Notification Appliance

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Horn/Strobe		Horns/Strobes	Manual	3/3/2026 8:25:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
NAC Power Extender Panel		NAC BPS-C1 C103.1	Manual	3/3/2026 10:07:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		NAC BPS-F1 MDF 1.0	Manual	3/3/2026 10:07:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Failed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Fire Alarm Control Panel		FACP - F108 MDF 1.0	Manual	3/3/2026 10:06:50 PM
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	

Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2.022	1st Floor Elevator Lobby	Manual	3/3/2026 6:23:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Supervisory - Control Valve	2.222	1st Floor Riser Rm B113 Tamper	Manual	3/3/2026 8:21:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	2.221	1st Floor Riser Rm B113 Waterflow	Manual	3/3/2026 5:40:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Supervisory - Control Valve	2.224	2nd Floor Riser Rm B113 Tamper	Manual	3/3/2026 5:34:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	2.223	2nd Floor Riser Rm B113 Waterflow	Manual	3/3/2026 5:40:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.048	Bldg A Admin A111	Manual	3/3/2026 6:35:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.031	Bldg A Admin A111	Manual	3/3/2026 6:43:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.019	Bldg A Book Storage A117.1	Manual	3/3/2026 8:25:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.047	Bldg A Broadcast Lab A202.2	Manual	3/3/2026 8:48:27 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	3.052	Bldg A Class A204	Manual	3/3/2026 8:51:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.050	Bldg A Class A204	Manual	3/3/2026 8:51:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.043	Bldg A Computer Lab A202	Manual	3/3/2026 8:24:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.045	Bldg A Computer Lab A202	Manual	3/3/2026 8:24:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.030	Bldg A Conference Rm A114	Manual	3/3/2026 6:50:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.046	Bldg A Control Rm A202.1	Manual	3/3/2026 8:47:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.030	Bldg A Corridor A201	Manual	3/3/2026 8:58:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.029	Bldg A Corridor A201	Manual	3/3/2026 8:59:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.028	Bldg A Corridor A201	Manual	3/3/2026 8:59:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.026	Bldg A Corridor A201	Manual	3/3/2026 8:59:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.022	Bldg A Corridor A201	Manual	3/3/2026 8:59:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.008	Bldg A Corridor A201	Manual	3/3/2026 8:59:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.043	Bldg A Counseling A110.1	Manual	3/3/2026 6:44:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.038	Bldg A Custodial Rm A119 Heat	Manual	3/3/2026 5:19:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.048	Bldg A Flex Lab Rm A202.4	Manual	3/3/2026 8:44:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.049	Bldg A Flex Lab Rm A202.4	Manual	3/3/2026 8:51:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.031	Bldg A Flex Lab Rm A202.4	Manual	3/3/2026 8:53:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.013	Bldg A IDF 1.3 Rm A118.2	Manual	3/3/2026 6:01:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3.027	Bldg A IDF 2.1 Rm A211	Manual	3/3/2026 8:59:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.011	Bldg A ILS Class A118	Manual	3/3/2026 5:59:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.012	Bldg A ILS Class A118	Manual	3/3/2026 6:00:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.015	Bldg A ILS Class A118	Manual	3/3/2026 6:00:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.017	Bldg A Library A117	Manual	3/3/2026 6:19:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.052	Bldg A Lobby A102	Manual	3/3/2026 6:32:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.024	Bldg A Lobby A116	Manual	3/3/2026 6:23:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.023	Bldg A Lobby A116	Manual	3/3/2026 6:24:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.026	Bldg A Lobby A116	Manual	3/3/2026 6:30:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.027	Bldg A Lobby A116.1	Manual	3/3/2026 6:51:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.010	Bldg A Lobby A116.2	Manual	3/3/2026 5:58:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.009	Bldg A Lobby A116.2	Manual	3/3/2026 6:02:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.021	Bldg A Lobby A116.2	Manual	3/3/2026 6:23:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.018	Bldg A Maker Lab Rm A205	Manual	3/3/2026 6:30:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.017	Bldg A Maker Lab Rm A205	Manual	3/3/2026 8:59:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.015	Bldg A Maker Lab Rm A205	Manual	3/3/2026 8:59:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.053	Bldg A Maker Lab Rm A206	Manual	3/3/2026 7:04:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.021	Bldg A Maker Lab Rm A206	Manual	3/3/2026 8:59:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.020	Bldg A Maker Lab Rm A206	Manual	3/3/2026 8:59:15 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.045	Bldg A Nurse Rm A109	Manual	3/3/2026 6:42:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.050	Bldg A Office A104	Manual	3/3/2026 6:34:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.046	Bldg A Principals Office A106	Manual	3/3/2026 6:36:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.049	Bldg A Reception A115	Manual	3/3/2026 6:41:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.028	Bldg A Records A113	Manual	3/3/2026 6:49:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.041	Bldg A Restroom A107.1	Manual	3/3/2026 6:40:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.044	Bldg A Restroom A108	Manual	3/3/2026 6:43:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.042	Bldg A Restroom A109.1	Manual	3/3/2026 6:41:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.016	Bldg A Restroom A118.1	Manual	3/3/2026 6:01:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.040	Bldg A Restroom A203.1	Manual	3/3/2026 8:56:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.039	Bldg A Restroom A203.2	Manual	3/3/2026 8:56:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.047	Bldg A Secretary A105	Manual	3/3/2026 6:35:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.036	Bldg A Staff Work Rm A203	Manual	3/3/2026 8:53:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.037	Bldg A Staff Work Rm A203	Manual	3/3/2026 8:55:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.029	Bldg A Storage A112	Manual	3/3/2026 6:48:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.041	Bldg A Storage Rm A202.3	Manual	3/3/2026 8:50:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.036	Bldg A Support Center 2 A110.2	Manual	3/3/2026 6:45:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.034	Bldg A Support Center 4 A110.4	Manual	3/3/2026 6:47:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2.032	Bldg A Support Center 5 A110.5	Manual	3/3/2026 6:47:46 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.033	Bldg A Support Center A110	Manual	3/3/2026 6:44:17 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.035	Bldg A Support Center Conference A110.3	Manual	3/3/2026 6:46:17 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.051	Bldg A VP Office A103	Manual	3/3/2026 6:33:11 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.040	Bldg A Workroom A107	Manual	3/3/2026 6:38:33 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.039	Bldg A Workroom A107	Manual	3/3/2026 6:39:01 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.077	Bldg B 1st Fl Stairs B103	Manual	3/3/2026 7:06:30 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	3.078	Bldg B 2nd Fl Stairs	Manual	3/3/2026 9:10:26 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.053	Bldg B Boys Restroom B111	Manual	3/3/2026 6:53:31 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	3.055	Bldg B Boys Restroom B210	Manual	3/3/2026 9:00:28 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.062	Bldg B Class B102	Manual	3/3/2026 6:55:15 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.069	Bldg B Class B102	Manual	3/3/2026 6:57:44 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.058	Bldg B Class B104	Manual	3/3/2026 6:56:02 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.056	Bldg B Class B104	Manual	3/3/2026 6:56:51 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.065	Bldg B Class B105	Manual	3/3/2026 6:58:31 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.063	Bldg B Class B105	Manual	3/3/2026 6:59:03 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.072	Bldg B Class B106	Manual	3/3/2026 7:05:08 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.070	Bldg B Class B106	Manual	3/3/2026 7:05:34 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.075	Bldg B Class B108	Manual	3/3/2026 7:07:08 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.073	Bldg B Class B108	Manual	3/3/2026 7:07:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.068	Bldg B Class B109	Manual	3/3/2026 7:08:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.066	Bldg B Class B109	Manual	3/3/2026 7:09:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.061	Bldg B Class B110	Manual	3/3/2026 7:11:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.059	Bldg B Class B204	Manual	3/3/2026 7:12:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.057	Bldg B Class B204	Manual	3/3/2026 9:02:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.066	Bldg B Class B205	Manual	3/3/2026 9:08:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.064	Bldg B Class B205	Manual	3/3/2026 9:09:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.071	Bldg B Class B206	Manual	3/3/2026 9:10:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.073	Bldg B Class B206	Manual	3/3/2026 9:10:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.074	Bldg B Class B207	Manual	3/3/2026 9:10:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.076	Bldg B Class B207	Manual	3/3/2026 9:12:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.069	Bldg B Class B208	Manual	3/3/2026 9:13:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.067	Bldg B Class B208	Manual	3/3/2026 9:13:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.062	Bldg B Class B209	Manual	3/3/2026 9:13:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.060	Bldg B Class B209	Manual	3/3/2026 9:13:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.055	Bldg B Corridor B102	Manual	3/3/2026 6:54:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.076	Bldg B Corridor B102	Manual	3/3/2026 7:00:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3.056	Bldg B Corridor B202	Manual	3/3/2026 8:59:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.063	Bldg B Corridor B202	Manual	3/3/2026 9:03:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.070	Bldg B Corridor B202	Manual	3/3/2026 9:08:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.077	Bldg B Corridor B202	Manual	3/3/2026 9:10:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.054	Bldg B Girls Restroom B101	Manual	3/3/2026 6:52:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.054	Bldg B Girls Restroom B201	Manual	3/3/2026 8:59:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.025	Bldg B IDF 1.2 Rm B112.1	Manual	3/3/2026 6:28:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.261	Bldg C Class C207	Manual	3/3/2026 9:28:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.259	Bldg C Class C207	Manual	3/3/2026 9:28:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.292	Bldg C Class C208	Manual	3/3/2026 5:18:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.268	Bldg C Class C208	Manual	3/3/2026 9:29:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.266	Bldg C Class C208	Manual	3/3/2026 9:30:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.290	Bldg C Class C208	Manual	3/3/2026 9:45:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.273	Bldg C Class C209	Manual	3/3/2026 9:30:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.275	Bldg C Class C209	Manual	3/3/2026 9:31:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.283	Bldg C Class C209	Manual	3/3/2026 9:45:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.281	Bldg C Class C209	Manual	3/3/2026 9:45:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.272	Bldg C Class C210	Manual	3/3/2026 9:32:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.270	Bldg C Class C210	Manual	3/3/2026 9:33:28 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.265	Bldg C Class C211	Manual	3/3/2026 9:34:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.263	Bldg C Class C211	Manual	3/3/2026 9:34:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.258	Bldg C Class C212	Manual	3/3/2026 9:35:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.256	Bldg C Class C212	Manual	3/3/2026 9:36:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.300	Bldg C Corridor C102	Manual	3/3/2026 5:55:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.297	Bldg C Corridor C102	Manual	3/3/2026 5:56:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.311	Bldg C Corridor C102	Manual	3/3/2026 8:26:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.257	Bldg C Corridor C105	Manual	3/3/2026 6:03:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.267	Bldg C Corridor C105	Manual	3/3/2026 6:06:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.274	Bldg C Corridor C105	Manual	3/3/2026 6:07:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.281	Bldg C Corridor C105	Manual	3/3/2026 6:08:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.253	Bldg C Corridor C205	Manual	3/3/2026 9:26:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.262	Bldg C Corridor C205	Manual	3/3/2026 9:27:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.269	Bldg C Corridor C205	Manual	3/3/2026 9:29:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.276	Bldg C Corridor C205	Manual	3/3/2026 9:31:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.007	Bldg C Custodial Rm C203	Manual	3/3/2026 9:24:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.007	Bldg C IDF Rm C103.1	Manual	3/3/2026 6:22:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.260	Bldg C Kiln Rm C113.1	Manual	3/3/2026 6:16:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2.255	Bldg C Restroom C104	Manual	3/3/2026 6:03:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.259	Bldg C Restroom C114	Manual	3/3/2026 5:59:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.256	Bldg C Restroom C115	Manual	3/3/2026 6:03:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.252	Bldg C Restroom C204	Manual	3/3/2026 9:26:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.281	Bldg C Room C105	Manual	3/3/2026 8:26:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.264	Bldg C Room C107	Manual	3/3/2026 8:26:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.266	Bldg C Room C107	Manual	3/3/2026 8:26:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.273	Bldg C Room C108	Manual	3/3/2026 6:07:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.271	Bldg C Room C108	Manual	3/3/2026 6:08:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.280	Bldg C Room C109	Manual	3/3/2026 6:09:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.278	Bldg C Room C109	Manual	3/3/2026 6:09:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.277	Bldg C Room C111	Manual	3/3/2026 6:12:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.275	Bldg C Room C111	Manual	3/3/2026 6:12:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.270	Bldg C Room C112	Manual	3/3/2026 6:15:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.268	Bldg C Room C112	Manual	3/3/2026 6:15:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.261	Bldg C Room C113	Manual	3/3/2026 6:05:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.263	Bldg C Room C113	Manual	3/3/2026 6:06:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.255	Bldg C Staff Men's Restroom C215	Manual	3/3/2026 9:45:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.254	Bldg C Staff Women's Restroom C214	Manual	3/3/2026 9:45:46 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.282	Bldg C Stairs C106	Manual	3/3/2026 6:10:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.008	Bldg C Storage Rm C103	Manual	3/3/2026 6:21:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.258	Bldg C Storage Rm C113.2	Manual	3/3/2026 6:05:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.284	Bldg D Boys Restroom D111	Manual	3/3/2026 5:57:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.278	Bldg D Boys Restroom D210	Manual	3/3/2026 9:46:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.288	Bldg D Class D204 Heat	Manual	3/3/2026 5:19:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.287	Bldg D Class D204 Heat	Manual	3/3/2026 5:19:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.284	Bldg D Class D204 Heat	Manual	3/3/2026 5:19:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.285	Bldg D Class D204 Heat	Manual	3/3/2026 5:19:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.296	Bldg D Class D206 Heat	Manual	3/3/2026 5:17:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.295	Bldg D Class D206 Heat	Manual	3/3/2026 5:18:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.298	Bldg D Class D206 Heat	Manual	3/3/2026 5:18:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.299	Bldg D Class D206 Heat	Manual	3/3/2026 5:18:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.302	Bldg D Class D207	Manual	3/3/2026 9:59:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.300	Bldg D Class D207	Manual	3/3/2026 9:59:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.286	Bldg D Corridor D102	Manual	3/3/2026 5:56:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.280	Bldg D Corridor D2	Manual	3/3/2026 9:47:45 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	3.289	Bldg D Corridor D2	Manual	3/3/2026 9:49:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.294	Bldg D Corridor D2	Manual	3/3/2026 9:51:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.303	Bldg D Corridor D2	Manual	3/3/2026 9:56:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.285	Bldg D Girls Restroom D101	Manual	3/3/2026 5:57:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.279	Bldg D Girls Restroom D201	Manual	3/3/2026 9:47:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.299	Bldg D Prep Rm D105	Manual	3/3/2026 5:56:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.298	Bldg D Prep Rm D109	Manual	3/3/2026 5:18:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.296	Bldg D Room D104 Heat	Manual	3/3/2026 5:17:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.295	Bldg D Room D104 Heat	Manual	3/3/2026 5:18:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.292	Bldg D Room D104 Heat	Manual	3/3/2026 5:18:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.293	Bldg D Room D104 Heat	Manual	3/3/2026 5:18:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.310	Bldg D Room D106 Heat	Manual	3/3/2026 5:00:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.309	Bldg D Room D106 Heat	Manual	3/3/2026 5:01:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.306	Bldg D Room D106 Heat	Manual	3/3/2026 5:01:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.307	Bldg D Room D106 Heat	Manual	3/3/2026 5:17:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.305	Bldg D Room D108 Heat	Manual	3/3/2026 5:17:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.302	Bldg D Room D108 Heat	Manual	3/3/2026 5:17:28 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.304	Bldg D Room D108 Heat	Manual	3/3/2026 5:17:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.301	Bldg D Room D108 Heat	Manual	3/3/2026 5:17:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.287	Bldg D Room D110 Heat	Manual	3/3/2026 5:18:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.288	Bldg D Room D110 Heat	Manual	3/3/2026 5:18:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.290	Bldg D Room D110 Heat	Manual	3/3/2026 5:18:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.291	Bldg D Room D110 Heat	Manual	3/3/2026 5:18:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.312	Bldg D Stairs D103	Manual	3/3/2026 5:43:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.313	Bldg D Stairs D107	Manual	3/3/2026 5:00:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4.009	Bldg F Band Office F102.1	Manual	3/3/2026 10:27:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4.027	Bldg F Band Rm F102	Manual	3/3/2026 10:27:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4.030	Bldg F Band Rm F102	Manual	3/3/2026 10:27:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4.029	Bldg F Band Rm F102	Manual	3/3/2026 10:27:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4.026	Bldg F Band Rm F102	Manual	3/3/2026 10:27:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4.037	Bldg F Boys Locker Restroom F103	Manual	3/3/2026 10:19:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4.033	Bldg F Boys Locker Rm F103	Manual	3/3/2026 9:23:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4.034	Bldg F Boys Locker Rm F103	Manual	3/3/2026 10:16:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4.031	Bldg F Boys Locker Rm F103	Manual	3/3/2026 10:19:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4.035	Bldg F Boys Locker Rm F103	Manual	3/3/2026 10:19:39 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4.013	Bldg F Choir Office F101.1	Manual	3/3/2026 10:25:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4.018	Bldg F Choir Rm F101	Manual	3/3/2026 6:30:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4.014	Bldg F Choir Rm F101	Manual	3/3/2026 9:45:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4.017	Bldg F Choir Rm F101	Manual	3/3/2026 10:24:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4.015	Bldg F Choir Rm F101	Manual	3/3/2026 10:24:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4.044	Bldg F Girls Locker Office F106	Manual	3/3/2026 10:11:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4.043	Bldg F Girls Locker Office F106.1	Manual	3/3/2026 8:46:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4.038	Bldg F Girls Locker Rm F106	Manual	3/3/2026 8:55:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4.040	Bldg F Girls Locker Rm F106	Manual	3/3/2026 10:09:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4.039	Bldg F Girls Locker Rm F106	Manual	3/3/2026 10:10:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4.041	Bldg F Girls Locker Rm F106 Entrance	Manual	3/3/2026 10:09:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4.005	Bldg F MDF 1.0 F108	Manual	3/3/2026 5:32:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4.049	Bldg F PE Class F107	Manual	3/3/2026 10:05:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4.046	Bldg F PE Class F107	Manual	3/3/2026 10:05:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4.048	Bldg F PE Class F107	Manual	3/3/2026 10:05:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4.045	Bldg F PE Class F107	Manual	3/3/2026 10:05:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4.012	Bldg F Practice F101.2	Manual	3/3/2026 10:25:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4.025	Bldg F Practice Hall	Manual	3/3/2026 10:27:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	4.007	Bldg F Practice Rm F102.3	Manual	3/3/2026 10:27:32 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4.021	Bldg F Practice Rm F102.4	Manual	3/3/2026 10:27:28 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4.024	Bldg F Practice Rm F102.5	Manual	3/3/2026 10:27:27 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Supervisory - Control Valve	4.136	Bldg F Riser Rm F109 Tamper	Manual	3/3/2026 8:21:22 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	4.135	Bldg F Riser Rm F109 Waterflow	Manual	3/4/2026 10:19:24 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4.010	Bldg F Storage F101.3	Manual	3/3/2026 10:25:55 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4.050	Bldg F Storage F125	Manual	3/3/2026 10:03:24 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4.051	Bldg F Storage F125	Manual	3/3/2026 10:04:24 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4.036	Bldg F Storage Rm F104	Manual	3/3/2026 10:13:28 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4.042	Bldg F Unisex Restroom F105	Manual	3/3/2026 10:10:33 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.374	MP Bldg Boys Restroom E	Manual	3/3/2026 8:24:33 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.375	MP Bldg Boys Restroom W	Manual	3/3/2026 8:24:35 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.321	MP Bldg Cust Rm	Manual	3/3/2026 8:21:13 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.371	MP Bldg Girls Restroom E	Manual	3/3/2026 8:24:31 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.370	MP Bldg Girls Restroom W	Manual	3/3/2026 8:24:26 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2.348	MP Bldg Kitchen Heat	Manual	3/3/2026 5:28:38 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.316	MP Bldg Kitchen Office	Manual	3/3/2026 8:23:37 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.346	MP Bldg Kitchen Restroom	Manual	3/3/2026 8:24:10 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Supervisory - Control Valve	2.389	MP Bldg PIV Tamper	Manual	3/3/2026 8:21:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2.397	MP Bldg Room NW Pull	Manual	3/3/2026 8:20:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2.395	MP Bldg Room SE Pull	Manual	3/3/2026 8:20:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2.396	MP Bldg Room SW Pull	Manual	3/3/2026 8:20:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.337	MP Bldg Serving E Heat	Manual	3/3/2026 5:27:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.347	MP Bldg Serving E Heat	Manual	3/3/2026 5:28:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.342	MP Bldg Serving W Heat	Manual	3/3/2026 5:29:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.365	MP Bldg Stage Hall E	Manual	3/3/2026 8:24:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.364	MP Bldg Stage Hall W	Manual	3/3/2026 8:32:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.367	MP Bldg Stage N	Manual	3/3/2026 8:24:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.368	MP Bldg Stage S	Manual	3/3/2026 8:24:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.366	MP Bldg Stage Storage	Manual	3/3/2026 8:24:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Supervisory - Control Valve	2.389	MP Bldg Tamper	Manual	3/3/2026 8:21:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	2.388	MP Bldg Waterflow	Manual	3/3/2026 8:24:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Supervisory - Control Valve	4.140	Tamper Riser Rm F109 (PIV)	Manual	3/3/2026 8:21:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2.236	Vestibule A101	Manual	3/3/2026 6:31:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Skipped				
EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General		MP Bldg Gym Smoke 01	Manual	3/3/2026 8:20:58 PM
Smoke Detector - General		MP Bldg Gym Smoke 02	Manual	3/3/2026 8:20:55 PM
Smoke Detector - General		MP Bldg Gym Smoke 03	Manual	3/3/2026 8:20:52 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General		MP Bldg Gym Smoke 04	Manual	3/3/2026 8:20:50 PM
Smoke Detector - General		MP Bldg Gym Smoke 05	Manual	3/3/2026 8:20:47 PM
Smoke Detector - General		MP Bldg Gym Smoke 06	Manual	3/3/2026 8:20:44 PM
Smoke Detector - General		MP Bldg Gym Smoke 07	Manual	3/3/2026 8:20:41 PM
Smoke Detector - General		MP Bldg Gym Smoke 08	Manual	3/3/2026 8:20:35 PM
Smoke Detector - General		MP Bldg Gym Smoke 09	Manual	3/3/2026 8:20:38 PM
Smoke Detector - General		MP Bldg Gym Smoke 10	Manual	3/3/2026 8:20:28 PM
Smoke Detector - General		MP Bldg Gym Smoke 11	Manual	3/3/2026 8:20:32 PM
Smoke Detector - General		MP Bldg Gym Smoke 12	Manual	3/3/2026 8:20:24 PM

Failed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Supervisory - Control Valve		OS&Y Left	Manual	3/4/2026 10:19:16 AM
		Manufacturer	System Sensor	
		Model	OSY2	
		Functional Inspection	Failed	
Supervisory - Control Valve		OS&Y Right	Manual	3/4/2026 10:19:21 AM
		Visual inspection	Failed (Manual)	

Ventilation and Cooking Equipment

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Cooking Equipment	Appliances (1)		Manual	3/3/2026 8:25:01 PM
Cooking Equipment	Appliances		Manual	3/3/2026 8:25:04 PM
Fusible Links	Fusible Links 450 Degree X 3		Manual	3/3/2026 8:24:58 PM
Range Hood	Hood		Manual	3/3/2026 8:25:09 PM
Range Suppression	Cartridge		Manual	3/3/2026 8:24:55 PM
Range Suppression Tank	Ansul R102 3 Gallon Cylinder		Manual	3/3/2026 8:25:12 PM

Device/Equipment details

Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Horn/Strobe					
	Horns/Strobes				02/26/2025

Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Fire Alarm Control Panel					
	FACP - F108 MDF 1.0				02/26/2025
NAC Power Extender Panel					
	NAC BPS-F1 MDF 1.0				02/26/2025
	NAC BPS-C1 C103.1				02/26/2025

Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Mechanical, Electrosonic, or Pressure Waterflow Device					
2.223	2nd Floor Riser Rm B113 Waterflow				02/20/2025
4.135	Bldg F Riser Rm F109 Waterflow				02/20/2025
2.388	MP Bldg Waterflow				02/20/2025
2.221	1st Floor Riser Rm B113 Waterflow				02/20/2025
Supervisory - Control Valve					
2.224	2nd Floor Riser Rm B113 Tamper				02/20/2025
4.136	Bldg F Riser Rm F109 Tamper				02/20/2025
2.389	MP Bldg Tamper				02/20/2025
2.222	1st Floor Riser Rm B113 Tamper				02/20/2025
2.389	MP Bldg PIV Tamper				02/26/2025
4.140	Tamper Riser Rm F109 (PIV)				02/26/2025
	OS&Y Left	System Sensor	OSY2		02/26/2025
	OS&Y Right				02/26/2025
Heat Detector - Restorable Spot					
2.348	MP Bldg Kitchen Heat				02/20/2025
2.342	MP Bldg Serving W Heat				02/20/2025
2.337	MP Bldg Serving E Heat				02/20/2025
2.347	MP Bldg Serving E Heat				02/20/2025
2.038	Bldg A Custodial Rm A119 Heat				02/20/2025
3.298	Bldg D Class D206 Heat				02/20/2025
3.299	Bldg D Class D206 Heat				02/20/2025
3.295	Bldg D Class D206 Heat				02/20/2025
3.296	Bldg D Class D206 Heat				02/20/2025
3.284	Bldg D Class D204 Heat				02/20/2025
3.285	Bldg D Class D204 Heat				02/20/2025
3.287	Bldg D Class D204 Heat				02/20/2025
3.288	Bldg D Class D204 Heat				02/20/2025
2.305	Bldg D Room D108 Heat				02/20/2025
2.304	Bldg D Room D108 Heat				02/20/2025
2.302	Bldg D Room D108 Heat				02/20/2025
2.301	Bldg D Room D108 Heat				02/20/2025
2.309	Bldg D Room D106 Heat				02/20/2025
2.310	Bldg D Room D106 Heat				02/20/2025
2.307	Bldg D Room D106 Heat				02/20/2025
2.306	Bldg D Room D106 Heat				02/20/2025

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2.287	Bldg D Room D110 Heat				02/20/2025
2.288	Bldg D Room D110 Heat				02/20/2025
2.290	Bldg D Room D110 Heat				02/20/2025
2.291	Bldg D Room D110 Heat				02/20/2025
2.296	Bldg D Room D104 Heat				02/20/2025
2.295	Bldg D Room D104 Heat				02/20/2025
2.293	Bldg D Room D104 Heat				02/20/2025
2.292	Bldg D Room D104 Heat				02/20/2025
Smoke Detector - General					
2.321	MP Bldg Cust Rm				02/20/2025
2.346	MP Bldg Kitchen Restroom				02/20/2025
2.316	MP Bldg Kitchen Office				02/20/2025
2.364	MP Bldg Stage Hall W				02/20/2025
2.366	MP Bldg Stage Storage				02/20/2025
2.365	MP Bldg Stage Hall E				02/20/2025
2.367	MP Bldg Stage N				02/20/2025
2.368	MP Bldg Stage S				02/20/2025
2.375	MP Bldg Boys Restroom W				02/20/2025
2.371	MP Bldg Girls Restroom E				02/20/2025
2.374	MP Bldg Boys Restroom E				02/20/2025
2.370	MP Bldg Girls Restroom W				02/20/2025
4.051	Bldg F Storage F125				02/21/2025
4.050	Bldg F Storage F125				02/21/2025
4.049	Bldg F PE Class F107				02/21/2025
4.048	Bldg F PE Class F107				02/21/2025
4.045	Bldg F PE Class F107				02/21/2025
4.046	Bldg F PE Class F107				02/21/2025
4.043	Bldg F Girls Locker Office F106.1				02/21/2025
4.040	Bldg F Girls Locker Rm F106				02/21/2025
4.039	Bldg F Girls Locker Rm F106				02/21/2025
4.044	Bldg F Girls Locker Office F106				02/21/2025
4.038	Bldg F Girls Locker Rm F106				02/21/2025
4.041	Bldg F Girls Locker Rm F106 Entrance				02/21/2025
4.037	Bldg F Boys Locker Restroom F103				02/21/2025
4.042	Bldg F Unisex Restroom F105				02/21/2025
4.036	Bldg F Storage Rm F104				02/21/2025
4.031	Bldg F Boys Locker Rm F103				02/21/2025
4.033	Bldg F Boys Locker Rm F103				02/21/2025
4.034	Bldg F Boys Locker Rm F103				02/21/2025
4.035	Bldg F Boys Locker Rm F103				02/21/2025
4.024	Bldg F Practice Rm F102.5				02/21/2025
4.021	Bldg F Practice Rm F102.4				02/21/2025
4.007	Bldg F Practice Rm F102.3				02/21/2025
4.025	Bldg F Practice Hall				02/21/2025
4.009	Bldg F Band Office F102.1				02/21/2025
4.026	Bldg F Band Rm F102				02/21/2025
4.030	Bldg F Band Rm F102				02/21/2025
4.029	Bldg F Band Rm F102				02/21/2025
4.027	Bldg F Band Rm F102				02/21/2025
4.010	Bldg F Storage F101.3				02/21/2025
4.012	Bldg F Practice F101.2				02/21/2025

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
4.013	Bldg F Choir Office F101.1				02/21/2025
4.018	Bldg F Choir Rm F101				02/21/2025
4.014	Bldg F Choir Rm F101				02/21/2025
4.015	Bldg F Choir Rm F101				02/21/2025
4.017	Bldg F Choir Rm F101				02/21/2025
3.015	Bldg A Maker Lab Rm A205				02/20/2025
3.017	Bldg A Maker Lab Rm A205				02/20/2025
3.018	Bldg A Maker Lab Rm A205				02/20/2025
3.053	Bldg A Maker Lab Rm A206				02/20/2025
3.020	Bldg A Maker Lab Rm A206				02/20/2025
3.021	Bldg A Maker Lab Rm A206				02/20/2025
3.278	Bldg D Boys Restroom D210				02/25/2025
3.302	Bldg D Class D207				02/25/2025
3.300	Bldg D Class D207				02/25/2025
3.279	Bldg D Girls Restroom D201				02/25/2025
3.303	Bldg D Corridor D2				02/25/2025
3.294	Bldg D Corridor D2				02/25/2025
3.289	Bldg D Corridor D2				02/25/2025
3.280	Bldg D Corridor D2				02/25/2025
3.008	Bldg A Corridor A201				02/20/2025
3.049	Bldg A Flex Lab Rm A202.4				02/20/2025
3.048	Bldg A Flex Lab Rm A202.4				02/20/2025
3.027	Bldg A IDF 2.1 Rm A211				02/20/2025
3.031	Bldg A Flex Lab Rm A202.4				02/20/2025
3.030	Bldg A Corridor A201				02/20/2025
3.029	Bldg A Corridor A201				02/20/2025
3.026	Bldg A Corridor A201				02/20/2025
3.022	Bldg A Corridor A201				02/20/2025
3.028	Bldg A Corridor A201				02/20/2025
3.050	Bldg A Class A204				02/20/2025
3.052	Bldg A Class A204				02/20/2025
3.041	Bldg A Storage Rm A202.3				02/20/2025
3.043	Bldg A Computer Lab A202				02/20/2025
3.045	Bldg A Computer Lab A202				02/20/2025
3.046	Bldg A Control Rm A202.1				02/20/2025
3.047	Bldg A Broadcast Lab A202.2				02/20/2025
3.040	Bldg A Restroom A203.1				02/20/2025
3.039	Bldg A Restroom A203.2				02/20/2025
3.037	Bldg A Staff Work Rm A203				02/20/2025
3.036	Bldg A Staff Work Rm A203				02/20/2025
2.312	Bldg D Stairs D103				02/25/2025
2.298	Bldg D Prep Rm D109				02/25/2025
2.299	Bldg D Prep Rm D105				02/25/2025
2.284	Bldg D Boys Restroom D111				02/25/2025
2.285	Bldg D Girls Restroom D101				02/25/2025
2.286	Bldg D Corridor D102				02/25/2025
2.010	Bldg A Lobby A116.2				02/20/2025
2.013	Bldg A IDF 1.3 Rm A118.2				02/20/2025
2.016	Bldg A Restroom A118.1				02/20/2025
2.015	Bldg A ILS Class A118				02/20/2025
2.012	Bldg A ILS Class A118				02/20/2025
2.011	Bldg A ILS Class A118				02/20/2025

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2.019	Bldg A Book Storage A117.1				02/20/2025
2.017	Bldg A Library A117				02/20/2025
2.021	Bldg A Lobby A116.2				02/20/2025
2.009	Bldg A Lobby A116.2				02/20/2025
2.023	Bldg A Lobby A116				02/20/2025
2.024	Bldg A Lobby A116				02/20/2025
2.026	Bldg A Lobby A116				02/20/2025
2.028	Bldg A Records A113				02/20/2025
2.051	Bldg A VP Office A103				02/20/2025
2.050	Bldg A Office A104				02/20/2025
2.047	Bldg A Secretary A105				02/20/2025
2.030	Bldg A Conference Rm A114				02/20/2025
2.046	Bldg A Principals Office A106				02/20/2025
2.049	Bldg A Reception A115				02/20/2025
2.043	Bldg A Counseling A110.1				02/20/2025
2.052	Bldg A Lobby A102				02/20/2025
2.041	Bldg A Restroom A107.1				02/20/2025
2.040	Bldg A Workroom A107				02/20/2025
2.033	Bldg A Support Center A110				02/20/2025
2.039	Bldg A Workroom A107				02/20/2025
2.036	Bldg A Support Center 2 A110.2				02/20/2025
2.035	Bldg A Support Center Conference A110.3				02/20/2025
2.048	Bldg A Admin A111				02/20/2025
2.034	Bldg A Support Center 4 A110.4				02/20/2025
2.044	Bldg A Restroom A108				02/20/2025
2.042	Bldg A Restroom A109.1				02/20/2025
2.032	Bldg A Support Center 5 A110.5				02/20/2025
2.045	Bldg A Nurse Rm A109				02/20/2025
2.029	Bldg A Storage A112				02/20/2025
2.031	Bldg A Admin A111				02/20/2025
2.027	Bldg A Lobby A116.1				02/20/2025
3.290	Bldg C Class C208				02/25/2025
3.292	Bldg C Class C208				02/25/2025
3.281	Bldg C Class C209				02/25/2025
3.283	Bldg C Class C209				02/25/2025
3.255	Bldg C Staff Men's Restroom C215				02/25/2025
3.254	Bldg C Staff Women's Restroom C214				02/25/2025
3.256	Bldg C Class C212				02/25/2025
3.258	Bldg C Class C212				02/25/2025
3.263	Bldg C Class C211				02/25/2025
3.265	Bldg C Class C211				02/25/2025
3.272	Bldg C Class C210				02/25/2025
3.270	Bldg C Class C210				02/25/2025
3.276	Bldg C Corridor C205				02/25/2025
3.275	Bldg C Class C209				02/25/2025
3.269	Bldg C Corridor C205				02/25/2025
3.273	Bldg C Class C209				02/25/2025
3.262	Bldg C Corridor C205				02/25/2025
3.253	Bldg C Corridor C205				02/25/2025
3.266	Bldg C Class C208				02/25/2025
3.268	Bldg C Class C208				02/25/2025

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3.259	Bldg C Class C207				02/25/2025
3.261	Bldg C Class C207				02/25/2025
3.252	Bldg C Restroom C204				02/25/2025
3.007	Bldg C Custodial Rm C203				02/25/2025
2.311	Bldg C Corridor C102				02/25/2025
2.300	Bldg C Corridor C102				02/25/2025
2.297	Bldg C Corridor C102				02/25/2025
2.259	Bldg C Restroom C114				02/25/2025
2.258	Bldg C Storage Rm C113.2				02/25/2025
2.260	Bldg C Kiln Rm C113.1				02/25/2025
2.263	Bldg C Room C113				02/25/2025
2.261	Bldg C Room C113				02/25/2025
2.268	Bldg C Room C112				02/25/2025
2.270	Bldg C Room C112				02/25/2025
2.275	Bldg C Room C111				02/25/2025
2.277	Bldg C Room C111				02/25/2025
2.278	Bldg C Room C109				02/25/2025
2.280	Bldg C Room C109				02/25/2025
2.273	Bldg C Room C108				02/25/2025
2.271	Bldg C Room C108				02/25/2025
2.266	Bldg C Room C107				02/25/2025
2.264	Bldg C Room C107				02/25/2025
2.256	Bldg C Restroom C115				02/25/2025
2.255	Bldg C Restroom C104				02/25/2025
2.282	Bldg C Stairs C106				02/25/2025
2.281	Bldg C Corridor C105				02/25/2025
2.281	Bldg C Room C105				02/25/2025
2.274	Bldg C Corridor C105				02/25/2025
2.267	Bldg C Corridor C105				02/25/2025
2.007	Bldg C IDF Rm C103.1				02/25/2025
2.257	Bldg C Corridor C105				02/25/2025
2.008	Bldg C Storage Rm C103				02/25/2025
3.078	Bldg B 2nd Fl Stairs				02/25/2025
3.070	Bldg B Corridor B202				02/25/2025
3.077	Bldg B Corridor B202				02/25/2025
3.063	Bldg B Corridor B202				02/25/2025
3.056	Bldg B Corridor B202				02/25/2025
3.055	Bldg B Boys Restroom B210				02/25/2025
3.060	Bldg B Class B209				02/25/2025
3.062	Bldg B Class B209				02/25/2025
3.067	Bldg B Class B208				02/25/2025
3.069	Bldg B Class B208				02/25/2025
3.076	Bldg B Class B207				02/25/2025
3.074	Bldg B Class B207				02/25/2025
3.073	Bldg B Class B206				02/25/2025
3.071	Bldg B Class B206				02/25/2025
3.064	Bldg B Class B205				02/25/2025
3.066	Bldg B Class B205				02/25/2025
3.057	Bldg B Class B204				02/25/2025
3.059	Bldg B Class B204				02/25/2025
3.054	Bldg B Girls Restroom B201				02/25/2025
2.022	1st Floor Elevator Lobby				02/20/2025

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2.025	Bldg B IDF 1.2 Rm B112.1				02/25/2025
2.061	Bldg B Class B110				02/25/2025
2.068	Bldg B Class B109				02/25/2025
2.066	Bldg B Class B109				02/25/2025
2.073	Bldg B Class B108				02/25/2025
2.075	Bldg B Class B108				02/25/2025
2.072	Bldg B Class B106				02/25/2025
2.070	Bldg B Class B106				02/25/2025
2.063	Bldg B Class B105				02/25/2025
2.065	Bldg B Class B105				02/25/2025
2.076	Bldg B Corridor B102				02/25/2025
2.056	Bldg B Class B104				02/25/2025
2.058	Bldg B Class B104				02/25/2025
2.069	Bldg B Class B102				02/25/2025
2.062	Bldg B Class B102				02/25/2025
2.053	Bldg B Boys Restroom B111				02/25/2025
2.055	Bldg B Corridor B102				02/25/2025
2.054	Bldg B Girls Restroom B101				02/25/2025
2.077	Bldg B 1st FI Stairs B103				02/25/2025
	MP Bldg Gym Smoke 01				02/20/2025
	MP Bldg Gym Smoke 02				02/20/2025
	MP Bldg Gym Smoke 03				02/20/2025
	MP Bldg Gym Smoke 04				02/20/2025
	MP Bldg Gym Smoke 05				02/20/2025
	MP Bldg Gym Smoke 06				02/20/2025
	MP Bldg Gym Smoke 07				02/20/2025
	MP Bldg Gym Smoke 08				02/20/2025
	MP Bldg Gym Smoke 09				02/20/2025
	MP Bldg Gym Smoke 10				02/20/2025
	MP Bldg Gym Smoke 11				02/20/2025
	MP Bldg Gym Smoke 12				02/20/2025
2.313	Bldg D Stairs D107				02/25/2025
4.005	Bldg F MDF 1.0 F108				03/03/2026

Manual Pull Station

2.395	MP Bldg Room SE Pull				02/21/2025
2.396	MP Bldg Room SW Pull				02/21/2025
2.397	MP Bldg Room NW Pull				02/21/2025
2.236	Vestibule A101				02/21/2025

Ventilation and Cooking Equipment

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Range Suppression Tank					
	Ansul R102 3 Gallon Cylinder				01/01/2014
Range Hood					
	Hood				01/01/2014
Cooking Equipment					
Appliances					
	Appliances (1)				01/01/2014
Fusible Links					
	Fusible Links 450 Degree X 3				08/29/2025
Range Suppression					

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
	Cartridge				01/01/2014