

# Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

CAMERON RANCH ELEMENTARY

4333 HACKBERRY LN  
CARMICHAEL, California  
United States

This site has been inspected and tested in compliance with applicable standards.

Completed  
Monday, May 04, 2026

Test Session: 11 Mar 2026 15:25 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD  
5320 HEMLOCK ST  
SACRAMENTO, California  
United States

TESTED BY

Riley Goyet  
Western States Fire Protection-  
Sacramento  
188 Cirby Way  
Roseville, CA 95678  
United States



# Inspection Summary

## Building Information

PROPERTY	CAMERON RANCH ELEMENTARY	CONTACT
ADDRESS	4333 HACKBERRY LN	PHONE
CITY/STATE	CARMICHAEL, California	MOBILE
COUNTRY	United States	EMAIL

## Inspector Information

COMPANY	Western States Fire Protection- Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us

## Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Fire Control Panel	3	3(100%)	3(100%)	0(0%)
Initiating Device	187	187(100%)	186(99%)	1(1%)

## Certification

The equipment specified herein was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Monday, May 04, 2026

ACCEPTED BY	05/04/2026	TESTED BY	05/04/2026
	Building Representative		 Riley Goyet Technician

# Open Corrective Action & Solution Summary

The following 1 corrective action(s) remain open following the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
Manual Pull Station	2-156 103	Multi-Purpose Bldg MP Room NE

Created By: Riley Goyet  
Creation Date: 03/12/2026  
Corrective Action: Unable to test due to extinguisher case under pull  
Proposed Solution:  
Manufacturer:  
Model:



# Testing Details

## Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Remote Annunciator		Admin Building Admin Office	Manual	3/11/2026 9:25:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Fire Alarm Panel		Administration Building Break Room	Manual	3/11/2026 9:27:22 PM
		Manufacturer	Notifier	
		Model	NFS-3030	
		Visual inspection	Passed (Manual)	
NAC Power Extender Panel		Administration Building Break Room	Manual	3/11/2026 9:27:23 PM
		Manufacturer	Notifier	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

## Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-050 008	Admin Building Admin Hall	Manual	3/11/2026 9:25:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-135 002	Admin Building Admin Office	Manual	3/11/2026 4:10:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-043 003	Admin Building Admin Office	Manual	3/11/2026 9:25:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-046 005	Admin Building Attendance Office	Manual	3/11/2026 9:25:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-036 016	Admin Building Conference Room	Manual	3/11/2026 9:25:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-037 015	Admin Building Copy Area	Manual	3/11/2026 9:25:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	? 017	Admin Building Electrical Room	Manual	3/11/2026 9:25:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-045 010	Admin Building Mens Restroom	Manual	3/11/2026 9:25:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-049 007	Admin Building Nurse Restroom	Manual	3/11/2026 9:25:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-047 006	Admin Building Nurses Room	Manual	3/11/2026 9:25:30 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	2-040 004	Admin Building Principal Office	Manual	3/11/2026 9:25:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-038 014	Admin Building Staff Room	Manual	3/11/2026 9:25:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-039 013	Admin Building Staff Room	Manual	3/11/2026 9:25:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-041 012	Admin Building Staff Room Hall	Manual	3/11/2026 9:25:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-042 011	Admin Building Staff Workroom	Manual	3/11/2026 9:25:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-044 009	Admin Building Womens Restroom	Manual	3/11/2026 9:25:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-048	Admin Mech Rm	Manual	3/11/2026 3:54:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-127	Attic Rm 18	Manual	3/11/2026 3:53:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-150	Attic Rm 21	Manual	3/11/2026 3:53:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-006	Bldg A Staff Rm	Manual	3/11/2026 9:27:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-386	Media Center Attic Computer Lab	Manual	3/11/2026 3:53:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-387	Media Center Attic Hall	Manual	3/11/2026 3:53:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-394	Media Center Attic N Overhang	Manual	3/11/2026 3:53:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-393	Media Center Attic N/E Hall	Manual	3/11/2026 3:53:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-391	Media Center Attic N/W Hall	Manual	3/11/2026 3:53:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-390	Media Center Attic Office	Manual	3/11/2026 3:53:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-388	Media Center Attic Office	Manual	3/11/2026 3:53:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-389	Media Center Attic RR	Manual	3/11/2026 3:53:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-385	Media Center Attic S/E Hall	Manual	3/11/2026 3:53:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-268	Media Center Custd Clst	Manual	3/11/2026 3:53:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-376	Media Center Head Custodian Off	Manual	3/11/2026 4:00:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-392	Media Center Learn Lab	Manual	3/11/2026 3:53:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-076	Mod Rm Kitchen	Manual	3/11/2026 4:00:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-075	Mod Rm Kitchen storage	Manual	3/11/2026 3:54:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-074	MP Rm Custodial Closet	Manual	3/11/2026 3:54:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-075	MP Rm Kitchen Storage	Manual	3/11/2026 9:27:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-157	MP Rm Roof	Manual	3/11/2026 9:27:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-177	MP Rm Stage	Manual	3/11/2026 9:27:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-136	MP Rm Under Stage	Manual	3/11/2026 3:54:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-136	MP Rm Under Stage	Manual	3/11/2026 3:54:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-136	MP Rm Under Stage	Manual	3/11/2026 3:54:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-136	MP Rm Under Stage	Manual	3/11/2026 3:54:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-136	MP Rm Under Stage	Manual	3/11/2026 3:54:07 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-136	MP Rm Under Stage	Manual	3/11/2026 3:54:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-148	MP Room	Manual	3/11/2026 3:53:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-170	Multi-Purpose Bldg Attic Boys RR	Manual	3/11/2026 3:53:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-169	Multi-Purpose Bldg Attic Girls RR	Manual	3/11/2026 3:53:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-167	Multi-Purpose Bldg Attic Kitchen	Manual	3/11/2026 3:53:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-166	Multi-Purpose Bldg Attic Kitchen Freezer	Manual	3/11/2026 3:53:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-171	Multi-Purpose Bldg Attic Kitchen Strg	Manual	3/11/2026 3:53:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-168	Multi-Purpose Bldg Attic RR Hall	Manual	3/11/2026 3:53:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-165	Multi-Purpose Bldg Attic Stage	Manual	3/11/2026 3:53:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Valve Tamper Switch	2-137 128	Multi-Purpose Bldg Backflow Valve	Manual	3/11/2026 9:25:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Valve Tamper Switch	2-138 129	Multi-Purpose Bldg Backflow Valve	Manual	3/11/2026 9:25:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-073 109	Multi-Purpose Bldg Boys Restroom	Manual	3/11/2026 9:26:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-015 106	Multi-Purpose Bldg Electrical Room	Manual	3/11/2026 9:26:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-071 108	Multi-Purpose Bldg Girls Restroom	Manual	3/11/2026 9:26:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-154 105	Multi-Purpose Bldg Kitchen	Manual	3/11/2026 4:09:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	2-142 127	Multi-Purpose Bldg Mech Rm by Stage	Manual	3/11/2026 9:25:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-077 110	Multi-Purpose Bldg Mech Rm by Stage	Manual	3/11/2026 9:25:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-052 122	Multi-Purpose Bldg MP Rm Center Row	Manual	3/11/2026 9:25:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-057 121	Multi-Purpose Bldg MP Rm Center Row	Manual	3/11/2026 9:25:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-060 120	Multi-Purpose Bldg MP Rm Center Row	Manual	3/11/2026 9:25:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-064 119	Multi-Purpose Bldg MP Rm Center Row	Manual	3/11/2026 9:25:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-155 104	Multi-Purpose Bldg MP Room Hall East	Manual	3/11/2026 4:10:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-065 115	Multi-Purpose Bldg MP Room North Row	Manual	3/11/2026 9:26:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-059 116	Multi-Purpose Bldg MP Room North Row	Manual	3/11/2026 9:26:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-051 118	Multi-Purpose Bldg MP Room North Row	Manual	3/11/2026 9:26:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-058 117	Multi-Purpose Bldg MP Room North Row	Manual	3/11/2026 9:26:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-152 102	Multi-Purpose Bldg MP Room NW	Manual	3/11/2026 4:10:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-053 123	Multi-Purpose Bldg MP Room South Row	Manual	3/11/2026 9:26:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-056 124	Multi-Purpose Bldg MP Room South Row	Manual	3/11/2026 9:26:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-061 125	Multi-Purpose Bldg MP Room South Row	Manual	3/11/2026 9:26:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-062 126	Multi-Purpose Bldg MP Room South Row	Manual	3/11/2026 9:26:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-153 101	Multi-Purpose Bldg MP Room SW	Manual	3/11/2026 4:10:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Valve Tamper Switch	2-143 130	Multi-Purpose Bldg PIV	Manual	3/11/2026 9:25:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-072 107	Multi-Purpose Bldg Restroom Hall	Manual	3/11/2026 9:26:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-055 113	Multi-Purpose Bldg Stage	Manual	3/11/2026 9:25:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-054 112	Multi-Purpose Bldg Stage	Manual	3/11/2026 9:25:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-078 111	Multi-Purpose Bldg Stage Stairs East	Manual	3/11/2026 9:25:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-079 114	Multi-Purpose Bldg Stage Stairs West	Manual	3/11/2026 9:25:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-133	Portable Rm 19	Manual	3/11/2026 3:54:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-383	Portables Rm 14 Attic	Manual	3/11/2026 3:54:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-384	Portables Rm 14 Attic O/S N Overhang	Manual	3/11/2026 4:00:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-382	Portables Rm 14 Attic O/S S Overhang	Manual	3/11/2026 4:00:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-381	Portables Rm 15 Attic	Manual	3/11/2026 3:54:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-379	Portables Rm 16 Attic	Manual	3/11/2026 3:54:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-380	Portables Rm 16 Attic O/S Overhang	Manual	3/11/2026 4:00:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-380	Portables Rm 16 Attic O/S Overhang	Manual	3/11/2026 4:00:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-378	Portables Rm 17 Attic	Manual	3/11/2026 4:00:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-377	Portables Rm 17 Attic O/S Overhang	Manual	3/11/2026 4:00:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-134	Portables Rm 20 Attic	Manual	3/11/2026 3:54:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-134	Portables Rm 20 Attic	Manual	3/11/2026 4:00:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-134	Portables Rm 20 Attic	Manual	3/11/2026 4:00:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-081 092	Portables Room 18	Manual	3/11/2026 9:26:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-067 093	Portables Room 18	Manual	3/11/2026 9:26:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-066 094	Portables Room 18 Closet	Manual	3/11/2026 9:25:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-083 096	Portables Room 19	Manual	3/11/2026 9:26:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-082 095	Portables Room 19	Manual	3/11/2026 9:26:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-063 097	Portables Room 20	Manual	3/11/2026 9:26:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-068 098	Portables Room 20	Manual	3/11/2026 9:26:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-069 099	Portables Room 21	Manual	3/11/2026 9:26:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-070 100	Portables Room 21	Manual	3/11/2026 9:26:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-394	Rm 13 N Overhang	Manual	3/11/2026 3:53:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-130 054	Rms 1-9 / Bldg A Attic Hall Center	Manual	3/11/2026 3:53:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-132 053	Rms 1-9 / Bldg A Attic Hall East	Manual	3/11/2026 3:53:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-128 055	Rms 1-9 / Bldg A Attic Hall West	Manual	3/11/2026 3:53:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-131 050	Rms 1-9 / Bldg A Attic Rm 3 Work Rm	Manual	3/11/2026 3:53:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-126 052	Rms 1-9 / Bldg A Attic Rm 6 Work Rm	Manual	3/11/2026 3:53:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-129 051	Rms 1-9 / Bldg A Attic Rm 6 Work Rm	Manual	3/11/2026 3:53:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-026 046	Rms 1-9 / Bldg A Boys Restroom	Manual	3/11/2026 4:11:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-010 049	Rms 1-9 / Bldg A Custodial Room	Manual	3/11/2026 3:53:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-009 048	Rms 1-9 / Bldg A Electrical Room	Manual	3/11/2026 4:10:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-025 047	Rms 1-9 / Bldg A Girls Restroom	Manual	3/11/2026 4:11:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-024 042	Rms 1-9 / Bldg A Hall O/S Room 2	Manual	3/11/2026 4:10:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-023 043	Rms 1-9 / Bldg A Hall O/S Room 6	Manual	3/11/2026 4:10:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-021 044	Rms 1-9 / Bldg A Hall O/S Room 7	Manual	3/11/2026 4:11:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-022 045	Rms 1-9 / Bldg A Hall O/S Room 8	Manual	3/11/2026 4:11:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-019 020	Rms 1-9 / Bldg A Room 1	Manual	3/11/2026 4:10:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-017 019	Rms 1-9 / Bldg A Room 1	Manual	3/11/2026 4:10:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-020 018	Rms 1-9 / Bldg A Room 1	Manual	3/11/2026 4:10:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-035 021	Rms 1-9 / Bldg A Room 2	Manual	3/11/2026 4:10:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-012 023	Rms 1-9 / Bldg A Room 3	Manual	3/11/2026 4:10:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-014 022	Rms 1-9 / Bldg A Room 3	Manual	3/11/2026 4:10:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-011 025	Rms 1-9 / Bldg A Room 3	Manual	3/11/2026 4:10:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-016 024	Rms 1-9 / Bldg A Room 3 Work Rm	Manual	3/11/2026 4:10:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-034 026	Rms 1-9 / Bldg A Room 4	Manual	3/11/2026 4:10:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-033 027	Rms 1-9 / Bldg A Room 4	Manual	3/11/2026 4:10:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-007 029	Rms 1-9 / Bldg A Room 5	Manual	3/11/2026 4:11:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-008 028	Rms 1-9 / Bldg A Room 5	Manual	3/11/2026 4:11:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-031 030	Rms 1-9 / Bldg A Room 6	Manual	3/11/2026 4:10:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-029 031	Rms 1-9 / Bldg A Room 6	Manual	3/11/2026 4:10:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-032 033	Rms 1-9 / Bldg A Room 6 Work Room	Manual	3/11/2026 4:10:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-030 032	Rms 1-9 / Bldg A Room 6 Work Room	Manual	3/11/2026 4:11:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-004 035	Rms 1-9 / Bldg A Room 7	Manual	3/11/2026 4:10:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-005 034	Rms 1-9 / Bldg A Room 7	Manual	3/11/2026 4:11:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-003 037	Rms 1-9 / Bldg A Room 7 Work Room	Manual	3/11/2026 4:10:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-013 036	Rms 1-9 / Bldg A Room 7 Work Room	Manual	3/11/2026 4:11:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-027 039	Rms 1-9 / Bldg A Room 8	Manual	3/11/2026 4:11:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-028 038	Rms 1-9 / Bldg A Room 8	Manual	3/11/2026 4:11:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-001 041	Rms 1-9 / Bldg A Room 9	Manual	3/11/2026 4:11:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-002 040	Rms 1-9 / Bldg A Room 9	Manual	3/11/2026 4:11:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-395	Room 13	Manual	3/11/2026 3:53:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-401	Rooms 10-17 Bldg Attic Classroom 10	Manual	3/11/2026 9:26:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-400	Rooms 10-17 Bldg Attic Classroom 10 Overhang	Manual	3/11/2026 9:27:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-399	Rooms 10-17 Bldg Attic Classroom 11	Manual	3/11/2026 9:26:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-397	Rooms 10-17 Bldg Attic Classroom 12	Manual	3/11/2026 4:00:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-276	Rooms 10-17 Bldg Attic Rm N Overhang	Manual	3/11/2026 3:53:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-266 089	Rooms 10-17 Bldg Boys Restroom	Manual	3/11/2026 9:25:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-280 057	Rooms 10-17 Bldg Classroom 10	Manual	3/11/2026 9:26:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-281 056	Rooms 10-17 Bldg Classroom 10	Manual	3/11/2026 9:26:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-278 058	Rooms 10-17 Bldg Classroom 11	Manual	3/11/2026 9:26:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-279 059	Rooms 10-17 Bldg Classroom 11	Manual	3/11/2026 9:26:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-277 061	Rooms 10-17 Bldg Classroom 12	Manual	3/11/2026 9:26:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-276 060	Rooms 10-17 Bldg Classroom 12	Manual	3/11/2026 9:26:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-275 062	Rooms 10-17 Bldg Classroom 13	Manual	3/11/2026 9:27:02 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-274 063	Rooms 10-17 Bldg Classroom 13	Manual	3/11/2026 9:27:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-396	Rooms 10-17 Bldg Classroom 13 S Overhang	Manual	3/11/2026 3:53:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-259 065	Rooms 10-17 Bldg Classroom 14	Manual	3/11/2026 9:26:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-260 064	Rooms 10-17 Bldg Classroom 14	Manual	3/11/2026 9:26:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-258 067	Rooms 10-17 Bldg Classroom 15	Manual	3/11/2026 9:26:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-257 066	Rooms 10-17 Bldg Classroom 15	Manual	3/11/2026 9:26:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-255 068	Rooms 10-17 Bldg Classroom 16	Manual	3/11/2026 9:25:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-256 069	Rooms 10-17 Bldg Classroom 16	Manual	3/11/2026 9:25:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-254 071	Rooms 10-17 Bldg Classroom 17	Manual	3/11/2026 9:27:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-253 070	Rooms 10-17 Bldg Classroom 17	Manual	3/11/2026 9:27:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot		Rooms 10-17 Bldg Custodial Closet	Manual	3/11/2026 3:53:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-267 090	Rooms 10-17 Bldg Girls Restroom	Manual	3/11/2026 9:26:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-284 076	Rooms 10-17 Bldg Media Center	Manual	3/11/2026 9:26:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-286	Rooms 10-17 Bldg Media Center	Manual	3/11/2026 9:27:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-285 077	Rooms 10-17 Bldg Media Center	Manual	3/11/2026 9:27:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-273 078	Rooms 10-17 Bldg Media Center NE Hall	Manual	3/11/2026 9:26:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-271 079	Rooms 10-17 Bldg Media Center NW Hall	Manual	3/11/2026 9:27:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-270 085	Rooms 10-17 Bldg Media Center Office	Manual	3/11/2026 9:27:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-264 086	Rooms 10-17 Bldg Media Center Office	Manual	3/11/2026 9:27:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-261 075	Rooms 10-17 Bldg Media Center SE Hall	Manual	3/11/2026 9:27:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-263 082	Rooms 10-17 Bldg Media Center SW Hall	Manual	3/11/2026 9:27:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-282 073	Rooms 10-17 Bldg Media Ctr Book Strg	Manual	3/11/2026 9:26:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-262 084	Rooms 10-17 Bldg Media Ctr Comp Lab	Manual	3/11/2026 9:27:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-251 088	Rooms 10-17 Bldg Media Ctr Cust Office	Manual	3/11/2026 9:26:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-272 083	Rooms 10-17 Bldg Media Ctr Learn Lab	Manual	3/11/2026 9:26:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-283 072	Rooms 10-17 Bldg Media Ctr NE Entry	Manual	3/11/2026 9:26:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-269 080	Rooms 10-17 Bldg Media Ctr NW Entry	Manual	3/11/2026 9:25:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-252 074	Rooms 10-17 Bldg Media Ctr SE Entry	Manual	3/11/2026 9:26:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-265 081	Rooms 10-17 Bldg Media Ctr SW Entry	Manual	3/11/2026 9:27:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-287 087	Rooms 10-17 Bldg Speech Language	Manual	3/11/2026 9:25:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Failed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Manual Pull Station	2-156 103	Multi-Purpose Bldg MP Room NE	Manual	3/11/2026 4:07:51 PM
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	

## Device/Equipment details

### Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Remote Annunciator					
001	Admin Building Admin Office				
Fire Alarm Panel					
	Administration Building Break Room	Notifier	NFS-3030		03/05/2020
NAC Power Extender Panel					
	Administration Building Break Room	Notifier			03/05/2020

### Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Manual Pull Station					
2-135 002	Admin Building Admin Office				
2-153 101	Multi-Purpose Bldg MP Room SW				
2-152 102	Multi-Purpose Bldg MP Room NW				
2-156 103	Multi-Purpose Bldg MP Room NE				
2-155 104	Multi-Purpose Bldg MP Room Hall East				
2-154 105	Multi-Purpose Bldg Kitchen				
Smoke Detector - General					
2-043 003	Admin Building Admin Office				
2-040 004	Admin Building Principal Office				
2-046 005	Admin Building Attendance Office				
2-047 006	Admin Building Nurses Room				
2-049 007	Admin Building Nurse Restroom				
2-050 008	Admin Building Admin Hall				
2-044 009	Admin Building Womens Restroom				
2-045 010	Admin Building Mens Restroom				
2-042 011	Admin Building Staff Workroom				
2-041 012	Admin Building Staff Room Hall				
2-039 013	Admin Building Staff Room				
2-038 014	Admin Building Staff Room				
2-037 015	Admin Building Copy Area				
2-036 016	Admin Building Conference Room				
? 017	Admin Building Electrical Room				
2-020 018	Rms 1-9 / Bldg A Room 1				
2-017 019	Rms 1-9 / Bldg A Room 1				
2-019 020	Rms 1-9 / Bldg A Room 1				
2-035 021	Rms 1-9 / Bldg A Room 2				
2-014 022	Rms 1-9 / Bldg A Room 3				
2-012 023	Rms 1-9 / Bldg A Room 3				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-016 024	Rms 1-9 / Bldg A Room 3 Work Rm				
2-011 025	Rms 1-9 / Bldg A Room 3				
2-034 026	Rms 1-9 / Bldg A Room 4				
2-033 027	Rms 1-9 / Bldg A Room 4				
2-008 028	Rms 1-9 / Bldg A Room 5				
2-007 029	Rms 1-9 / Bldg A Room 5				
2-031 030	Rms 1-9 / Bldg A Room 6				
2-029 031	Rms 1-9 / Bldg A Room 6				
2-030 032	Rms 1-9 / Bldg A Room 6 Work Room				
2-032 033	Rms 1-9 / Bldg A Room 6 Work Room				
2-005 034	Rms 1-9 / Bldg A Room 7				
2-004 035	Rms 1-9 / Bldg A Room 7				
2-013 036	Rms 1-9 / Bldg A Room 7 Work Room				
2-003 037	Rms 1-9 / Bldg A Room 7 Work Room				
2-028 038	Rms 1-9 / Bldg A Room 8				
2-027 039	Rms 1-9 / Bldg A Room 8				
2-002 040	Rms 1-9 / Bldg A Room 9				
2-001 041	Rms 1-9 / Bldg A Room 9				
2-024 042	Rms 1-9 / Bldg A Hall O/S Room 2				
2-023 043	Rms 1-9 / Bldg A Hall O/S Room 6				
2-021 044	Rms 1-9 / Bldg A Hall O/S Room 7				
2-022 045	Rms 1-9 / Bldg A Hall O/S Room 8				
2-026 046	Rms 1-9 / Bldg A Boys Restroom				
2-025 047	Rms 1-9 / Bldg A Girls Restroom				
2-009 048	Rms 1-9 / Bldg A Electrical Room				
2-281 056	Rooms 10-17 Bldg Classroom 10				
2-280 057	Rooms 10-17 Bldg Classroom 10				
2-278 058	Rooms 10-17 Bldg Classroom 11				
2-279 059	Rooms 10-17 Bldg Classroom 11				
2-276 060	Rooms 10-17 Bldg Classroom 12				
2-277 061	Rooms 10-17 Bldg Classroom 12				
2-275 062	Rooms 10-17 Bldg Classroom 13				
2-274 063	Rooms 10-17 Bldg Classroom 13				
2-260 064	Rooms 10-17 Bldg Classroom 14				
2-259 065	Rooms 10-17 Bldg Classroom 14				
2-257 066	Rooms 10-17 Bldg Classroom 15				
2-258 067	Rooms 10-17 Bldg Classroom 15				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-255 068	Rooms 10-17 Bldg Classroom 16				
2-256 069	Rooms 10-17 Bldg Classroom 16				
2-253 070	Rooms 10-17 Bldg Classroom 17				
2-254 071	Rooms 10-17 Bldg Classroom 17				
2-283 072	Rooms 10-17 Bldg Media Ctr NE Entry				
2-282 073	Rooms 10-17 Bldg Media Ctr Book Strg				
2-252 074	Rooms 10-17 Bldg Media Ctr SE Entry				
2-261 075	Rooms 10-17 Bldg Media Center SE Hall				
2-284 076	Rooms 10-17 Bldg Media Center				
2-285 077	Rooms 10-17 Bldg Media Center				
2-273 078	Rooms 10-17 Bldg Media Center NE Hall				
2-271 079	Rooms 10-17 Bldg Media Center NW Hall				
2-269 080	Rooms 10-17 Bldg Media Ctr NW Entry				
2-265 081	Rooms 10-17 Bldg Media Ctr SW Entry				
2-263 082	Rooms 10-17 Bldg Media Center SW Hall				
2-272 083	Rooms 10-17 Bldg Media Ctr Learn Lab				
2-262 084	Rooms 10-17 Bldg Media Ctr Comp Lab				
2-270 085	Rooms 10-17 Bldg Media Center Office				
2-264 086	Rooms 10-17 Bldg Media Center Office				
2-287 087	Rooms 10-17 Bldg Speech Language				
2-251 088	Rooms 10-17 Bldg Media Ctr Cust Office				
2-266 089	Rooms 10-17 Bldg Boys Restroom				
2-267 090	Rooms 10-17 Bldg Girls Restroom				
2-081 092	Portables Room 18				
2-067 093	Portables Room 18				
2-066 094	Portables Room 18 Closet				
2-082 095	Portables Room 19				
2-083 096	Portables Room 19				
2-063 097	Portables Room 20				
2-068 098	Portables Room 20				
2-069 099	Portables Room 21				
2-070 100	Portables Room 21				
2-015 106	Multi-Purpose Bldg Electrical Room				
2-072 107	Multi-Purpose Bldg Restroom Hall				
2-071 108	Multi-Purpose Bldg Girls Restroom				
2-073 109	Multi-Purpose Bldg Boys Restroom				
2-077 110	Multi-Purpose Bldg Mech Rm by Stage				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-078 111	Multi-Purpose Bldg Stage Stairs East				
2-054 112	Multi-Purpose Bldg Stage				
2-055 113	Multi-Purpose Bldg Stage				
2-079 114	Multi-Purpose Bldg Stage Stairs West				
2-065 115	Multi-Purpose Bldg MP Room North Row				
2-059 116	Multi-Purpose Bldg MP Room North Row				
2-058 117	Multi-Purpose Bldg MP Room North Row				
2-051 118	Multi-Purpose Bldg MP Room North Row				
2-064 119	Multi-Purpose Bldg MP Rm Center Row				
2-060 120	Multi-Purpose Bldg MP Rm Center Row				
2-057 121	Multi-Purpose Bldg MP Rm Center Row				
2-052 122	Multi-Purpose Bldg MP Rm Center Row				
2-053 123	Multi-Purpose Bldg MP Room South Row				
2-056 124	Multi-Purpose Bldg MP Room South Row				
2-061 125	Multi-Purpose Bldg MP Room South Row				
2-062 126	Multi-Purpose Bldg MP Room South Row				
2-006	Bldg A Staff Rm				06/06/2019
2-075	MP Rm Kitchen Storage				06/06/2019
2-399	Rooms 10-17 Bldg Attic Classroom 11				
2-400	Rooms 10-17 Bldg Attic Classroom 10 Overhang				
2-401	Rooms 10-17 Bldg Attic Classroom 10				
2-286	Rooms 10-17 Bldg Media Center				
Heat Detector - Restorable Spot					
2-010 049	Rms 1-9 / Bldg A Custodial Room				
2-131 050	Rms 1-9 / Bldg A Attic Rm 3 Work Rm				
2-129 051	Rms 1-9 / Bldg A Attic Rm 6 Work Rm				
2-126 052	Rms 1-9 / Bldg A Attic Rm 6 Work Rm				
2-132 053	Rms 1-9 / Bldg A Attic Hall East				
2-130 054	Rms 1-9 / Bldg A Attic Hall Center				
2-128 055	Rms 1-9 / Bldg A Attic Hall West				
091	Rooms 10-17 Bldg Custodial Closet				
2-048	Admin Mech Rm				06/06/2019
2-074	MP Rm Custodial Closet				06/06/2019
2-076	Mod Rm Kitchen				06/06/2019
2-127	Attic Rm 18				06/06/2019
2-148	MP Room				06/06/2019
2-150	Attic Rm 21				06/06/2019
2-268	Media Center Custd Clst				06/06/2019
2-133	Portable Rm 19				06/06/2019
2-134	Portables Rm 20 Attic				06/06/2019
2-134	Portables Rm 20 Attic				06/06/2019
2-134	Portables Rm 20 Attic				06/06/2019

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-136	MP Rm Under Stage				06/06/2019
2-136	MP Rm Under Stage				06/06/2019
2-136	MP Rm Under Stage				06/06/2019
2-136	MP Rm Under Stage				06/06/2019
2-136	MP Rm Under Stage				06/06/2019
2-136	MP Rm Under Stage				06/06/2019
2-387	Media Center Attic Hall				06/06/2019
2-388	Media Center Attic Office				06/06/2019
2-389	Media Center Attic RR				06/06/2019
2-390	Media Center Attic Office				06/06/2019
2-391	Media Center Attic N/W Hall				06/06/2019
2-392	Media Center Learn Lab				06/06/2019
2-393	Media Center Attic N/E Hall				06/06/2019
2-394	Media Center Attic N Overhang				06/06/2019
2-395	Room 13				06/06/2019
2-394	Rm 13 N Overhang				06/06/2019
2-378	Portables Rm 17 Attic				06/06/2019
2-379	Portables Rm 16 Attic				06/06/2019
2-380	Portables Rm 16 Attic O/S Overhang				06/06/2019
2-380	Portables Rm 16 Attic O/S Overhang				06/06/2019
2-381	Portables Rm 15 Attic				06/06/2019
2-382	Portables Rm 14 Attic O/S S Overhang				06/06/2019
2-384	Portables Rm 14 Attic O/S N Overhang				06/06/2019
2-383	Portables Rm 14 Attic				06/06/2019
2-385	Media Center Attic S/E Hall				06/06/2019
2-386	Media Center Attic Computer Lab				06/06/2019
2-376	Media Center Head Custodian Off				06/06/2019
2-377	Portables Rm 17 Attic O/S Overhang				06/06/2019
2-165	Multi-Purpose Bldg Attic Stage				
2-166	Multi-Purpose Bldg Attic Kitchen Freezer				
2-167	Multi-Purpose Bldg Attic Kitchen				
2-168	Multi-Purpose Bldg Attic RR Hall				
2-169	Multi-Purpose Bldg Attic Girls RR				
2-170	Multi-Purpose Bldg Attic Boys RR				
2-171	Multi-Purpose Bldg Attic Kitchen Strg				
2-396	Rooms 10-17 Bldg Classroom 13 S Overhang				
2-397	Rooms 10-17 Bldg Attic Classroom 12				
2-276	Rooms 10-17 Bldg Attic Rm N Overhang				
2-075	Mod Rm Kitchen storage				
Mechanical, Electrosonic, or Pressure Waterflow Device					
2-142 127	Multi-Purpose Bldg Mech Rm by Stage				
Valve Tamper Switch					
2-137 128	Multi-Purpose Bldg Backflow Valve				
2-138 129	Multi-Purpose Bldg Backflow Valve				
2-143 130	Multi-Purpose Bldg PIV				
Smoke Detector - Duct					

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-157	MP Rm Roof				06/06/2019
2-177	MP Rm Stage				06/06/2019