

Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

JOHN BARRETT MIDDLE SCHOOL

4243 BARRETT RD
CARMICHAEL, California
United States

This site has been inspected and tested in compliance with applicable standards.

Completed

Wednesday, February 11, 2026

Test Session:26 Jan 2026 15:08 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD
5320 HEMLOCK ST
SACRAMENTO, California
United States

TESTED BY

Riley Goyet
Western States Fire Protection-
Sacramento
188 Cirby Way
Roseville, CA 95678
United States



Inspection Summary

Building Information

PROPERTY	JOHN BARRETT MIDDLE SCHOOL	CONTACT
ADDRESS	4243 BARRETT RD	PHONE
CITY/STATE	CARMICHAEL, California	MOBILE
COUNTRY	United States	EMAIL

Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us

Testing Summary


EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Ventilation and Cooking Equipment	6	0(0%)	0(0%)	0(0%)
Fire Control Panel	1	1(100%)	1(100%)	0(0%)
Initiating Device	285	285(100%)	285(100%)	0(0%)

Certification

The equipment specified herein was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Wednesday, February 11, 2026

ACCEPTED BY 02/11/2026

Building Representative


TESTED BY 02/11/2026
Riley Goyet
Technician

System Details

Control Units

ADDRESS/ SCAN ADDRESS		DESCRIPTION	FACP Bldg F Electric Room
MANUFACTURER	EST3	S/W VERSION	
MODEL		LAST UPDATE	
SERIAL NUMBER		S/W LOCATION	
INSTALL DATE	02/19/2025		

Testing Details

Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Fire Alarm Control Panel		FACP Bldg F Electric Room	Manual	1/27/2026 4:11:04 PM
		Manufacturer	EST3	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3.074	Bldg A Admin A01	Manual	1/26/2026 3:52:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.072	Bldg A Admin A01	Manual	1/26/2026 3:53:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.076	Bldg A Attendance A02	Manual	1/26/2026 3:54:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.065	Bldg A Conference Rm A07	Manual	1/26/2026 3:51:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.067	Bldg A Counselor A05	Manual	1/26/2026 3:55:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.066	Bldg A Counselor A06	Manual	1/26/2026 3:52:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.064	Bldg A Hallway	Manual	1/26/2026 3:50:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.069	Bldg A Health A04	Manual	1/26/2026 3:55:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.068	Bldg A Health Restroom	Manual	1/26/2026 3:56:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.184	Bldg A Heat	Manual	1/27/2026 4:09:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.070	Bldg A ICT A03	Manual	1/26/2026 5:58:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.063	Bldg A Principal A08	Manual	1/26/2026 3:50:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3.182	Bldg A Pull	Manual	1/26/2026 6:57:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.062	Bldg A Server Rm	Manual	1/26/2026 5:58:51 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.060	Bldg A Staff Restroom	Manual	1/26/2026 3:48:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.061	Bldg A Staff Restroom	Manual	1/26/2026 3:49:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.079	Bldg A Staff Rm A10	Manual	1/26/2026 3:47:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.078	Bldg A Staff Rm A10	Manual	1/26/2026 3:49:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.077	Bldg A VP Office A09	Manual	1/26/2026 4:21:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.290	Bldg B Center Open Office	Manual	1/26/2026 4:01:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.288	Bldg B Conference Rm	Manual	1/26/2026 4:02:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.293	Bldg B Conference Rm	Manual	1/26/2026 4:02:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.388	Bldg B Open Office Heat 1	Manual	1/27/2026 4:10:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.388	Bldg B Open Office Heat 2	Manual	1/27/2026 4:10:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.388	Bldg B Open Office Heat 3	Manual	1/27/2026 4:10:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.388	Bldg B Open Office Heat 4	Manual	1/27/2026 4:10:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.388	Bldg B Open Office Heat 5	Manual	1/27/2026 4:10:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.388	Bldg B Open Office Heat 6	Manual	1/27/2026 4:10:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.388	Bldg B Open Office Heat 7	Manual	1/27/2026 4:10:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.388	Bldg B Open Office Heat 8	Manual	1/27/2026 4:10:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.294	Bldg B South Office	Manual	1/26/2026 3:57:48 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	2.292	Bldg B South Open Office	Manual	1/26/2026 4:00:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.297	Bldg C Custodial Office C04	Manual	1/26/2026 4:06:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.295	Bldg C Custodial Office C04.1	Manual	1/26/2026 4:06:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.299	Bldg C Kitchen C02	Manual	1/26/2026 5:59:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.307	Bldg C Kitchen Room C02	Manual	1/27/2026 4:10:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.306	Bldg C Kitchen Room C02	Manual	1/27/2026 4:10:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.298	Bldg C Kitchen Room C02	Manual	1/27/2026 4:10:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2.402	Bldg C Multi Purpose NE Pull	Manual	1/26/2026 6:57:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2.401	Bldg C Multi Purpose NW Pull	Manual	1/26/2026 6:57:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2.399	Bldg C Multi Purpose SE Pull	Manual	1/26/2026 6:57:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2.394	Bldg C Multi Purpose SW Pull	Manual	1/26/2026 6:57:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Beam	2.398	Bldg C Multi-Purpose Beam Smoke	Manual	1/26/2026 5:59:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Beam	2.397	Bldg C Multi-Purpose Beam Smoke	Manual	1/26/2026 5:59:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.302	Bldg C Restroom C02.2	Manual	1/26/2026 5:59:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.296	Bldg C Storage C03	Manual	1/26/2026 5:59:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.010	Bldg E Boys Restroom	Manual	1/26/2026 3:38:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.008	Bldg E Custodial	Manual	1/26/2026 3:36:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.009	Bldg E Custodial Heat	Manual	1/26/2026 5:30:19 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	3.007	Bldg E Girls Restroom	Manual	1/26/2026 3:36:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.069	Bldg J Boys Restroom	Manual	1/26/2026 4:26:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.065	Bldg J Girls Restroom	Manual	1/26/2026 5:59:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.068	Bldg J Men's Restroom	Manual	1/26/2026 5:59:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.066	Bldg J Women's Restroom	Manual	1/26/2026 4:28:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.315	Bldg L	Manual	1/26/2026 4:06:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.316	Bldg L	Manual	1/26/2026 4:06:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.314	Bldg L	Manual	1/26/2026 4:07:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.312	Bldg L	Manual	1/26/2026 4:07:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.313	Bldg L	Manual	1/26/2026 5:58:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.409	Bldg L Heat 1	Manual	1/27/2026 4:09:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.409	Bldg L Heat 2	Manual	1/27/2026 4:09:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.409	Bldg L Heat 3	Manual	1/27/2026 4:09:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.322	Bldg M	Manual	1/26/2026 4:08:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.321	Bldg M	Manual	1/26/2026 4:09:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.320	Bldg M	Manual	1/26/2026 4:09:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.319	Bldg M	Manual	1/26/2026 4:10:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.323	Bldg M	Manual	1/26/2026 4:11:18 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	3.090	Bldg P Boys Restroom	Manual	1/26/2026 4:29:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.091	Bldg P Classroom P01	Manual	1/26/2026 4:31:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.092	Bldg P Classroom P01	Manual	1/26/2026 4:32:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.096	Bldg P Classroom P01.2	Manual	1/26/2026 4:30:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.097	Bldg P Classroom P01.3	Manual	1/26/2026 4:29:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.087	Bldg P Classroom P02	Manual	1/26/2026 4:35:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.085	Bldg P Classroom P02	Manual	1/26/2026 5:58:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.083	Bldg P Classroom P02.3	Manual	1/26/2026 4:34:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.080	Bldg P Equipment Storage P07	Manual	1/26/2026 5:58:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.094	Bldg P Equipment Storage P08	Manual	1/26/2026 5:58:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.088	Bldg P Girls Restroom	Manual	1/26/2026 4:33:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.089	Bldg P Mechanical Rm P09	Manual	1/26/2026 5:58:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.082	Bldg P Office P02.2	Manual	1/26/2026 4:34:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.095	Bldg P Storage P01.1	Manual	1/26/2026 4:32:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.081	Bldg P Storage P02.1	Manual	1/26/2026 4:36:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.016	Bldg Q Band Room NE	Manual	1/26/2026 6:29:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.017	Bldg Q Band Room NW	Manual	1/26/2026 6:29:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.019	Bldg Q Band Room SE	Manual	1/26/2026 6:29:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2.015	Bldg Q Band Room Storage Q11.1	Manual	1/26/2026 6:29:54 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.020	Bldg Q Band Room SW	Manual	1/26/2026 6:29:49 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.055	Bldg Q Boys Locker Entry	Manual	1/26/2026 6:25:02 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.058	Bldg Q Boys Locker NE	Manual	1/26/2026 6:28:22 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.057	Bldg Q Boys Locker NW	Manual	1/26/2026 6:28:23 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.052	Bldg Q Boys Locker Restroom	Manual	1/26/2026 6:25:06 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.062	Bldg Q Boys Locker SE	Manual	1/26/2026 6:28:12 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.061	Bldg Q Boys Locker SW	Manual	1/26/2026 6:28:15 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.041	Bldg Q Boys Restroom	Manual	1/26/2026 5:28:15 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.053	Bldg Q Changing Room	Manual	1/26/2026 6:28:31 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	2.040	Bldg Q Custodial Q08.1 Heat	Manual	1/27/2026 4:11:01 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.010	Bldg Q Drama Room North	Manual	1/26/2026 5:31:28 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.012	Bldg Q Drama Room South	Manual	1/26/2026 5:32:40 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.049	Bldg Q Girls Locker Back Entry	Manual	1/26/2026 5:42:19 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.043	Bldg Q Girls Locker NE	Manual	1/26/2026 5:40:59 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.044	Bldg Q Girls Locker NW	Manual	1/26/2026 5:40:22 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.047	Bldg Q Girls Locker SE	Manual	1/26/2026 5:39:19 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.048	Bldg Q Girls Locker SW	Manual	1/26/2026 5:39:47 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.009	Bldg Q Girls Restroom	Manual	1/26/2026 5:37:58 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.051	Bldg Q Girls Restroom	Manual	1/26/2026 5:41:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.008	Bldg Q Girls Restroom Heat	Manual	1/27/2026 4:11:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.025	Bldg Q Gym NE	Manual	1/26/2026 6:29:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.030	Bldg Q Gym NE Center	Manual	1/26/2026 6:29:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2.130	Bldg Q Gym NE Pull	Manual	1/26/2026 6:57:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.028	Bldg Q Gym NW	Manual	1/26/2026 6:29:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.032	Bldg Q Gym NW Center	Manual	1/26/2026 6:29:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2.131	Bldg Q Gym NW Pull	Manual	1/26/2026 6:57:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.036	Bldg Q Gym SE	Manual	1/26/2026 6:29:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.033	Bldg Q Gym SE Center	Manual	1/26/2026 6:29:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2.129	Bldg Q Gym SE Pull	Manual	1/26/2026 6:57:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.039	Bldg Q Gym SW	Manual	1/26/2026 6:29:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.035	Bldg Q Gym SW Center	Manual	1/26/2026 6:29:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2.142	Bldg Q Gym SW Pull	Manual	1/26/2026 6:57:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.054	Bldg Q Locker Vestibule	Manual	1/26/2026 6:19:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.056	Bldg Q Men's Office Restroom	Manual	1/26/2026 6:28:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.059	Bldg Q Men's P.E. Office	Manual	1/26/2026 6:28:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.063	Bldg Q Men's Restroom	Manual	1/26/2026 6:28:10 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	2.014	Bldg Q Riser Room	Manual	1/26/2026 6:29:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.021	Bldg Q Stage Corridor	Manual	1/26/2026 6:29:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.024	Bldg Q Stage North	Manual	1/26/2026 5:36:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.023	Bldg Q Stage South	Manual	1/26/2026 5:36:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.029	Bldg Q Stage Stair	Manual	1/26/2026 5:36:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.007	Bldg Q Storage Q02.1	Manual	1/26/2026 5:37:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	2.126	Bldg Q Waterflow	Manual	1/27/2026 4:11:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.045	Bldg Q Women's P.E. Office	Manual	1/26/2026 6:24:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.042	Bldg Q Women's Restroom	Manual	1/26/2026 6:24:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.272	Bldg R Classroom 1 E	Manual	1/26/2026 5:07:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.274	Bldg R Classroom 1 W	Manual	1/26/2026 5:28:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.268	Bldg R Classroom 2 E	Manual	1/26/2026 5:09:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.270	Bldg R Classroom 2 W	Manual	1/26/2026 5:10:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.262	Bldg R Classroom 3 N	Manual	1/26/2026 5:12:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.264	Bldg R Classroom 3 S	Manual	1/26/2026 5:11:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.260	Bldg R Classroom 4 N	Manual	1/26/2026 5:14:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.258	Bldg R Classroom 4 S	Manual	1/26/2026 5:59:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.284	Bldg R Classroom 5 E	Manual	1/26/2026 5:20:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2.282	Bldg R Classroom 5 W	Manual	1/26/2026 5:20:09 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.281	Bldg R Classroom 6 E	Manual	1/26/2026 5:22:57 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.279	Bldg R Classroom 6 W	Manual	1/26/2026 5:22:12 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.276	Bldg R Flex Space Center	Manual	1/26/2026 5:25:57 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.277	Bldg R Flex Space North	Manual	1/26/2026 5:26:26 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.275	Bldg R Flex Space South	Manual	1/26/2026 5:26:03 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.255	Bldg R IDF	Manual	1/26/2026 5:59:16 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.267	Bldg R Outside Classroom 2	Manual	1/26/2026 5:23:54 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.265	Bldg R Outside Classroom 3	Manual	1/26/2026 5:24:43 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.266	Bldg R Outside Staff Room	Manual	1/26/2026 5:24:17 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.286	Bldg R Riser Rm	Manual	1/26/2026 5:21:48 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.257	Bldg R Staff Restroom	Manual	1/26/2026 5:17:01 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.256	Bldg R Staff Room	Manual	1/26/2026 5:16:57 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.271	Bldg R Storage Prep Rm 01.1	Manual	1/26/2026 5:08:34 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.261	Bldg R Storage Prep Rm 03.1	Manual	1/26/2026 5:59:12 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.278	Bldg R Storage Prep Rm 05.1	Manual	1/26/2026 5:20:21 PM
		Visual inspection	Passed (Manual)	
Mechanical, Electrosonic, or Pressure Waterflow Device	2.387	Bldg R Waterflow	Manual	1/27/2026 4:10:37 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	3.047	Classroom D01	Manual	1/26/2026 3:39:47 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	3.046	Classroom D01	Manual	1/26/2026 3:40:42 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.045	Classroom D01	Manual	1/26/2026 5:58:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.156	Classroom D01 Heat 1	Manual	1/27/2026 4:10:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.156	Classroom D01 Heat 2	Manual	1/27/2026 4:10:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.049	Classroom D02	Manual	1/26/2026 3:42:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.051	Classroom D02	Manual	1/26/2026 3:44:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.050	Classroom D02	Manual	1/26/2026 5:58:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.152	Classroom D02 Heat 1	Manual	1/27/2026 4:10:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.152	Classroom D02 Heat 2	Manual	1/27/2026 4:10:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.055	Classroom D03	Manual	1/26/2026 3:45:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.054	Classroom D03	Manual	1/26/2026 3:45:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.053	Classroom D03	Manual	1/26/2026 5:58:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.153	Classroom D03 Heat 1	Manual	1/27/2026 4:10:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.153	Classroom D03 Heat 2	Manual	1/27/2026 4:10:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.059	Classroom D04	Manual	1/26/2026 3:46:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.058	Classroom D04	Manual	1/26/2026 3:46:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.057	Classroom D04	Manual	1/26/2026 5:58:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.154	Classroom D04 Heat 1	Manual	1/27/2026 4:10:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	3.154	Classroom D04 Heat 2	Manual	1/27/2026 4:10:05 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	3.035	Classroom F01	Manual	1/26/2026 5:04:02 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	3.034	Classroom F01	Manual	1/26/2026 5:04:33 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	3.033	Classroom F01	Manual	1/26/2026 5:05:12 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	3.128	Classroom F01 Heat 1	Manual	1/27/2026 4:10:22 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	3.128	Classroom F01 Heat 2	Manual	1/27/2026 4:10:21 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	3.038	Classroom F02	Manual	1/26/2026 4:59:47 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	3.037	Classroom F02	Manual	1/26/2026 5:00:21 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	3.036	Classroom F02	Manual	1/26/2026 5:02:00 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	3.168	Classroom F02 Heat 1	Manual	1/27/2026 4:10:00 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	3.168	Classroom F02 Heat 2	Manual	1/27/2026 4:09:59 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	3.041	Classroom F03	Manual	1/26/2026 4:58:40 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	3.040	Classroom F03	Manual	1/26/2026 4:58:57 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	3.039	Classroom F03	Manual	1/26/2026 5:02:04 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	3.042	Classroom F03	Manual	1/26/2026 5:03:04 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	3.169	Classroom F03 Heat 1	Manual	1/27/2026 4:09:57 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	3.169	Classroom F03 Heat 2	Manual	1/27/2026 4:09:56 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	3.044	Classroom F04	Manual	1/26/2026 4:56:56 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.043	Classroom F04	Manual	1/26/2026 4:57:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.170	Classroom F04 Heat 1	Manual	1/27/2026 4:09:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.170	Classroom F04 Heat 2	Manual	1/27/2026 4:09:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.301	Classroom G01	Manual	1/26/2026 4:50:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.302	Classroom G01	Manual	1/26/2026 4:51:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.310	Classroom G01	Manual	1/26/2026 4:52:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.311	Classroom G01	Manual	1/26/2026 4:53:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.305	Classroom G01	Manual	1/26/2026 4:54:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.306	Classroom G01	Manual	1/26/2026 4:54:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.304	Classroom G01	Manual	1/26/2026 5:58:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.303	Classroom G01	Manual	1/26/2026 5:58:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.390	Classroom G01 Heat 1	Manual	1/27/2026 4:09:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.390	Classroom G01 Heat 2	Manual	1/27/2026 4:09:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.318	Classroom G01 Storage	Manual	1/26/2026 4:49:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.300	Classroom G02	Manual	1/26/2026 4:48:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.299	Classroom G02	Manual	1/26/2026 4:48:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.298	Classroom G02	Manual	1/26/2026 5:58:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.391	Classroom G02 Heat 1	Manual	1/27/2026 4:09:34 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.391	Classroom G02 Heat 2	Manual	1/27/2026 4:09:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.291	Classroom G03	Manual	1/26/2026 4:46:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.275	Classroom G03	Manual	1/26/2026 4:47:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.274	Classroom G03	Manual	1/26/2026 5:07:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.393	Classroom G03 Heat 1	Manual	1/27/2026 4:09:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.393	Classroom G03 Heat 2	Manual	1/27/2026 4:09:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.085	Classroom H01	Manual	1/26/2026 4:25:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.083	Classroom H01	Manual	1/26/2026 4:25:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.082	Classroom H01	Manual	1/26/2026 5:59:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.146	Classroom H01 Heat 1	Manual	1/27/2026 4:10:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.146	Classroom H01 Heat 2	Manual	1/27/2026 4:10:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.081	Classroom H02	Manual	1/26/2026 4:23:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.079	Classroom H02	Manual	1/26/2026 4:23:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.078	Classroom H02	Manual	1/26/2026 5:59:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.145	Classroom H02 Heat 1	Manual	1/27/2026 4:10:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.145	Classroom H02 Heat 2	Manual	1/27/2026 4:10:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.077	Classroom H03	Manual	1/26/2026 4:21:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2.075	Classroom H03	Manual	1/26/2026 4:21:31 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.074	Classroom H03	Manual	1/26/2026 5:59:21 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2.144	Classroom H03 Heat 1	Manual	1/27/2026 4:10:55 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2.144	Classroom H03 Heat 2	Manual	1/27/2026 4:10:54 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.073	Classroom H04	Manual	1/26/2026 4:19:47 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.071	Classroom H04	Manual	1/26/2026 4:20:26 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.070	Classroom H04	Manual	1/26/2026 5:59:23 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2.143	Classroom H04 Heat 1	Manual	1/27/2026 4:10:58 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2.143	Classroom H04 Heat 2	Manual	1/27/2026 4:10:57 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.253	Classroom K01	Manual	1/26/2026 4:38:18 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.254	Classroom K01	Manual	1/26/2026 4:38:40 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.252	Classroom K01	Manual	1/26/2026 5:58:40 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3.389	Classroom K01 Heat 1	Manual	1/27/2026 4:09:40 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3.389	Classroom K01 Heat 2	Manual	1/27/2026 4:09:39 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.257	Classroom K02	Manual	1/26/2026 4:39:27 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.256	Classroom K02	Manual	1/26/2026 4:39:54 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.255	Classroom K02	Manual	1/26/2026 5:17:09 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3.387	Classroom K02 Heat 1	Manual	1/27/2026 4:09:47 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.387	Classroom K02 Heat 2	Manual	1/27/2026 4:09:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.260	Classroom K03	Manual	1/26/2026 4:40:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.259	Classroom K03	Manual	1/26/2026 4:41:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.258	Classroom K03	Manual	1/26/2026 5:14:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.388	Classroom K03 Heat 1	Manual	1/27/2026 4:09:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.388	Classroom K03 Heat 2	Manual	1/27/2026 4:09:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.263	Classroom K04	Manual	1/26/2026 4:44:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.262	Classroom K04	Manual	1/26/2026 4:45:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.261	Classroom K04	Manual	1/26/2026 5:12:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.385	Classroom K04 Heat 1	Manual	1/27/2026 4:09:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.385	Classroom K04 Heat 2	Manual	1/27/2026 4:09:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.326	Classroom N01	Manual	1/26/2026 4:18:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.325	Classroom N01	Manual	1/26/2026 4:18:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.433	Classroom N01 Heat 1	Manual	1/27/2026 4:09:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.433	Classroom N01 Heat 2	Manual	1/27/2026 4:09:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.328	Classroom N02	Manual	1/26/2026 4:16:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.327	Classroom N02	Manual	1/26/2026 4:17:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	3.432	Classroom N02 Heat 1	Manual	1/27/2026 4:09:20 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3.432	Classroom N02 Heat 2	Manual	1/27/2026 4:09:18 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.330	Classroom N03	Manual	1/26/2026 4:15:03 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.329	Classroom N03	Manual	1/26/2026 4:15:44 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3.435	Classroom N03 Heat 1	Manual	1/27/2026 4:09:10 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3.435	Classroom N03 Heat 2	Manual	1/27/2026 4:09:09 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.332	Classroom N04	Manual	1/26/2026 4:13:51 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.331	Classroom N04	Manual	1/26/2026 4:14:19 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3.413	Classroom N04 Heat 1	Manual	1/27/2026 4:09:23 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3.413	Classroom N04 Heat 2	Manual	1/27/2026 4:09:21 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.334	Classroom N05	Manual	1/26/2026 4:13:05 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3.333	Classroom N05	Manual	1/26/2026 4:13:19 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3.434	Classroom N05 Heat 1	Manual	1/27/2026 4:09:13 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3.434	Classroom N05 Heat 2	Manual	1/27/2026 4:09:12 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3.132	Classroom P01 Heat 1	Manual	1/27/2026 4:10:19 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3.132	Classroom P01 Heat 2	Manual	1/27/2026 4:10:18 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3.133	Classroom P02 Heat 1	Manual	1/27/2026 4:10:16 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	3.133	Classroom P02 Heat 2	Manual	1/27/2026 4:10:14 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - Projected Beam	3-136 369	Multi-Purpose Bldg MP Room Center	Manual	1/26/2026 6:29:58 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - Projected Beam	3-134 368	Multi-Purpose Bldg MP Room East	Manual	1/26/2026 6:29:59 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - Projected Beam	3-138 370	Multi-Purpose Bldg MP Room West	Manual	1/26/2026 6:29:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Ventilation and Cooking Equipment

Skipped				
EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Cooking Equipment	Appliances		Manual	1/26/2026 3:11:39 PM
Fusible Links	Fusible Links 450 x 3		Manual	1/26/2026 3:11:21 PM
Range Hood	Hood		Manual	1/26/2026 3:11:36 PM
Range Suppression	Suppression System		Manual	1/26/2026 3:11:43 PM
Range Suppression	101-20 Cartridge		Manual	1/26/2026 3:11:50 PM
Range Suppression Tank	Ansul R102 1.5 Gallon Cylinder		Manual	1/26/2026 3:11:46 PM

Device/Equipment details

Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Fire Alarm Control Panel					
	FACP Bldg F Electric Room	EST3			02/20/2025

Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Smoke Detector - Projected Beam					
3-134 368	Multi-Purpose Bldg MP Room East				
3-136 369	Multi-Purpose Bldg MP Room Center				
3-138 370	Multi-Purpose Bldg MP Room West				
Smoke Detector - General					
3.059	Classroom D04				02/19/2025
3.058	Classroom D04				02/19/2025
3.057	Classroom D04				02/19/2025
3.078	Bldg A Staff Rm A10				02/19/2025
3.055	Classroom D03				02/19/2025
3.079	Bldg A Staff Rm A10				02/19/2025
3.054	Classroom D03				02/19/2025
3.053	Classroom D03				02/19/2025
3.060	Bldg A Staff Restroom				02/19/2025
3.061	Bldg A Staff Restroom				02/19/2025
3.062	Bldg A Server Rm				02/19/2025
3.049	Classroom D02				02/19/2025
3.064	Bldg A Hallway				02/19/2025
3.051	Classroom D02				02/19/2025
3.077	Bldg A VP Office A09				02/19/2025
3.063	Bldg A Principal A08				02/19/2025
3.050	Classroom D02				02/19/2025
3.047	Classroom D01				02/19/2025
3.065	Bldg A Conference Rm A07				02/19/2025
3.046	Classroom D01				02/19/2025
3.045	Classroom D01				02/19/2025
3.066	Bldg A Counselor A06				02/19/2025
3.076	Bldg A Attendance A02				02/19/2025
3.074	Bldg A Admin A01				02/19/2025
3.067	Bldg A Counselor A05				02/19/2025
3.069	Bldg A Health A04				02/19/2025
3.068	Bldg A Health Restroom				02/19/2025
3.070	Bldg A ICT A03				02/19/2025
3.072	Bldg A Admin A01				02/19/2025
3.010	Bldg E Boys Restroom				02/19/2025
3.008	Bldg E Custodial				02/19/2025
3.007	Bldg E Girls Restroom				02/19/2025
3.035	Classroom F01				02/19/2025
3.034	Classroom F01				02/19/2025
3.033	Classroom F01				02/19/2025
3.038	Classroom F02				02/19/2025
3.037	Classroom F02				02/19/2025
3.036	Classroom F02				02/19/2025

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2.294	Bldg B South Office				02/19/2025
3.041	Classroom F03				02/19/2025
3.040	Classroom F03				02/19/2025
3.039	Classroom F03				02/19/2025
3.044	Classroom F04				02/19/2025
3.043	Classroom F04				02/19/2025
3.042	Classroom F03				02/19/2025
3.291	Classroom G03				02/19/2025
3.275	Classroom G03				02/19/2025
3.274	Classroom G03				02/19/2025
3.300	Classroom G02				02/19/2025
3.299	Classroom G02				02/19/2025
3.298	Classroom G02				02/19/2025
3.318	Classroom G01 Storage				02/19/2025
3.301	Classroom G01				02/19/2025
3.306	Classroom G01				02/19/2025
3.305	Classroom G01				02/19/2025
3.304	Classroom G01				02/19/2025
3.303	Classroom G01				02/19/2025
3.302	Classroom G01				02/19/2025
3.311	Classroom G01				02/19/2025
2.085	Classroom H01				02/19/2025
2.082	Classroom H01				02/19/2025
2.083	Classroom H01				02/19/2025
2.081	Classroom H02				02/19/2025
2.079	Classroom H02				02/19/2025
2.078	Classroom H02				02/19/2025
2.077	Classroom H03				02/19/2025
2.075	Classroom H03				02/19/2025
2.074	Classroom H03				02/19/2025
2.073	Classroom H04				02/19/2025
2.071	Classroom H04				02/19/2025
2.070	Classroom H04				02/19/2025
3.263	Classroom K04				02/19/2025
3.262	Classroom K04				02/19/2025
3.261	Classroom K04				02/19/2025
3.260	Classroom K03				02/19/2025
3.259	Classroom K03				02/19/2025
3.258	Classroom K03				02/19/2025
3.257	Classroom K02				02/19/2025
3.256	Classroom K02				02/19/2025
3.255	Classroom K02				02/19/2025
3.254	Classroom K01				02/19/2025
3.253	Classroom K01				02/19/2025
3.252	Classroom K01				02/19/2025
3.328	Classroom N02				02/19/2025
3.327	Classroom N02				02/19/2025
3.330	Classroom N03				02/19/2025
3.329	Classroom N03				02/19/2025
3.332	Classroom N04				02/19/2025
3.331	Classroom N04				02/19/2025
3.333	Classroom N05				02/19/2025

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3.334	Classroom N05				02/19/2025
3.326	Classroom N01				02/19/2025
3.325	Classroom N01				02/19/2025
2.292	Bldg B South Open Office				02/19/2025
2.290	Bldg B Center Open Office				02/19/2025
2.288	Bldg B Conference Rm				02/19/2025
2.293	Bldg B Conference Rm				02/19/2025
2.296	Bldg C Storage C03				02/19/2025
2.302	Bldg C Restroom C02.2				02/19/2025
2.299	Bldg C Kitchen C02				02/19/2025
2.069	Bldg J Boys Restroom				02/19/2025
2.068	Bldg J Men's Restroom				02/19/2025
2.066	Bldg J Women's Restroom				02/19/2025
2.065	Bldg J Girls Restroom				02/19/2025
3.315	Bldg L				02/19/2025
3.316	Bldg L				02/19/2025
3.314	Bldg L				02/19/2025
3.312	Bldg L				02/19/2025
3.313	Bldg L				02/19/2025
3.320	Bldg M				02/19/2025
3.321	Bldg M				02/19/2025
3.322	Bldg M				02/19/2025
3.323	Bldg M				02/19/2025
3.319	Bldg M				02/19/2025
3.088	Bldg P Girls Restroom				02/19/2025
3.083	Bldg P Classroom P02.3				02/19/2025
3.082	Bldg P Office P02.2				02/19/2025
3.085	Bldg P Classroom P02				02/19/2025
3.087	Bldg P Classroom P02				02/19/2025
3.081	Bldg P Storage P02.1				02/19/2025
3.090	Bldg P Boys Restroom				02/19/2025
3.097	Bldg P Classroom P01.3				02/19/2025
3.096	Bldg P Classroom P01.2				02/19/2025
3.091	Bldg P Classroom P01				02/19/2025
3.092	Bldg P Classroom P01				02/19/2025
3.095	Bldg P Storage P01.1				02/19/2025
3.089	Bldg P Mechanical Rm P09				02/19/2025
3.080	Bldg P Equipment Storage P07				02/19/2025
3.094	Bldg P Equipment Storage P08				02/19/2025
2.276	Bldg R Flex Space Center				02/19/2025
2.277	Bldg R Flex Space North				02/19/2025
2.275	Bldg R Flex Space South				02/19/2025
2.281	Bldg R Classroom 6 E				02/19/2025
2.279	Bldg R Classroom 6 W				02/19/2025
2.278	Bldg R Storage Prep Rm 05.1				02/19/2025
2.282	Bldg R Classroom 5 W				02/19/2025
2.284	Bldg R Classroom 5 E				02/19/2025
2.267	Bldg R Outside Classroom 2				02/19/2025
2.266	Bldg R Outside Staff Room				02/19/2025
2.256	Bldg R Staff Room				02/19/2025
2.255	Bldg R IDF				02/19/2025
2.257	Bldg R Staff Restroom				02/19/2025

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2.258	Bldg R Classroom 4 S				02/19/2025
2.260	Bldg R Classroom 4 N				02/19/2025
2.261	Bldg R Storage Prep Rm 03.1				02/19/2025
2.262	Bldg R Classroom 3 N				02/19/2025
2.264	Bldg R Classroom 3 S				02/19/2025
2.265	Bldg R Outside Classroom 3				02/19/2025
2.270	Bldg R Classroom 2 W				02/19/2025
2.268	Bldg R Classroom 2 E				02/19/2025
2.271	Bldg R Storage Prep Rm 01.1				02/19/2025
2.274	Bldg R Classroom 1 W				02/19/2025
2.272	Bldg R Classroom 1 E				02/19/2025
2.014	Bldg Q Riser Room				02/19/2025
2.016	Bldg Q Band Room NE				02/19/2025
2.019	Bldg Q Band Room SE				02/19/2025
2.020	Bldg Q Band Room SW				02/19/2025
2.017	Bldg Q Band Room NW				02/19/2025
2.015	Bldg Q Band Room Storage Q11.1				02/19/2025
2.036	Bldg Q Gym SE				02/19/2025
2.033	Bldg Q Gym SE Center				02/19/2025
2.010	Bldg Q Drama Room North				02/19/2025
2.030	Bldg Q Gym NE Center				02/19/2025
2.012	Bldg Q Drama Room South				02/19/2025
2.025	Bldg Q Gym NE				02/19/2025
2.029	Bldg Q Stage Stair				02/19/2025
2.007	Bldg Q Storage Q02.1				02/19/2025
2.009	Bldg Q Girls Restroom				02/19/2025
2.024	Bldg Q Stage North				02/19/2025
2.023	Bldg Q Stage South				02/19/2025
2.021	Bldg Q Stage Corridor				02/19/2025
2.028	Bldg Q Gym NW				02/19/2025
2.055	Bldg Q Boys Locker Entry				02/19/2025
2.058	Bldg Q Boys Locker NE				02/19/2025
2.057	Bldg Q Boys Locker NW				02/19/2025
2.061	Bldg Q Boys Locker SW				02/19/2025
2.062	Bldg Q Boys Locker SE				02/19/2025
2.052	Bldg Q Boys Locker Restroom				02/19/2025
2.056	Bldg Q Men's Office Restroom				02/19/2025
2.059	Bldg Q Men's P.E. Office				02/19/2025
2.063	Bldg Q Men's Restroom				02/19/2025
2.054	Bldg Q Locker Vestibule				02/19/2025
2.053	Bldg Q Changing Room				02/19/2025
2.051	Bldg Q Girls Restroom				02/19/2025
2.047	Bldg Q Girls Locker SE				02/19/2025
2.043	Bldg Q Girls Locker NE				02/19/2025
2.048	Bldg Q Girls Locker SW				02/19/2025
2.044	Bldg Q Girls Locker NW				02/19/2025
2.049	Bldg Q Girls Locker Back Entry				02/19/2025
2.045	Bldg Q Women's P.E. Office				02/19/2025
2.042	Bldg Q Women's Restroom				02/19/2025
2.041	Bldg Q Boys Restroom				02/19/2025
2.032	Bldg Q Gym NW Center				02/19/2025
2.035	Bldg Q Gym SW Center				02/19/2025

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2.039	Bldg Q Gym SW				02/19/2025
2.297	Bldg C Custodial Office C04				02/19/2025
2.295	Bldg C Custodial Office C04.1				02/19/2025
3.310	Classroom G01				02/19/2025
2.286	Bldg R Riser Rm				02/19/2025
Manual Pull Station					
3.182	Bldg A Pull				02/19/2025
2.131	Bldg Q Gym NW Pull				02/19/2025
2.130	Bldg Q Gym NE Pull				02/19/2025
2.129	Bldg Q Gym SE Pull				02/19/2025
2.142	Bldg Q Gym SW Pull				02/19/2025
2.394	Bldg C Multi Purpose SW Pull				02/19/2025
2.399	Bldg C Multi Purpose SE Pull				02/19/2025
2.401	Bldg C Multi Purpose NW Pull				02/19/2025
2.402	Bldg C Multi Purpose NE Pull				02/19/2025
Smoke Detector - Beam					
2.398	Bldg C Multi-Purpose Beam Smoke				02/19/2025
2.397	Bldg C Multi-Purpose Beam Smoke				02/19/2025
Mechanical, Electrosonic, or Pressure Waterflow Device					
2.387	Bldg R Waterflow				02/19/2025
2.126	Bldg Q Waterflow				02/19/2025
Heat Detector - Restorable Spot					
2.306	Bldg C Kitchen Room C02				02/19/2025
2.298	Bldg C Kitchen Room C02				02/19/2025
2.307	Bldg C Kitchen Room C02				02/19/2025
3.132	Classroom P01 Heat 1				02/19/2025
3.132	Classroom P01 Heat 2				02/19/2025
3.133	Classroom P02 Heat 1				02/19/2025
3.133	Classroom P02 Heat 2				02/19/2025
2.008	Bldg Q Girls Restroom Heat				02/19/2025
2.040	Bldg Q Custodial Q08.1 Heat				02/19/2025
3.184	Bldg A Heat				02/19/2025
3.128	Classroom F01 Heat 1				02/19/2025
3.128	Classroom F01 Heat 2				02/19/2025
3.168	Classroom F02 Heat 1				02/19/2025
3.168	Classroom F02 Heat 2				02/19/2025
3.169	Classroom F03 Heat 1				02/19/2025
3.169	Classroom F03 Heat 2				02/19/2025
3.170	Classroom F04 Heat 1				02/19/2025
3.170	Classroom F04 Heat 2				02/19/2025
3.156	Classroom D01 Heat 1				02/19/2025
3.156	Classroom D01 Heat 2				02/19/2025
3.152	Classroom D02 Heat 1				02/19/2025
3.152	Classroom D02 Heat 2				02/19/2025
3.153	Classroom D03 Heat 1				02/19/2025
3.153	Classroom D03 Heat 2				02/19/2025
3.154	Classroom D04 Heat 1				02/19/2025
3.154	Classroom D04 Heat 2				02/19/2025
2.388	Bldg B Open Office Heat 1				02/20/2025
2.388	Bldg B Open Office Heat 2				02/20/2025
2.388	Bldg B Open Office Heat 3				02/20/2025

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2.388	Bldg B Open Office Heat 4				02/20/2025
2.388	Bldg B Open Office Heat 5				02/20/2025
2.388	Bldg B Open Office Heat 6				02/20/2025
2.388	Bldg B Open Office Heat 7				02/20/2025
2.388	Bldg B Open Office Heat 8				02/20/2025
3.390	Classroom G01 Heat 1				02/20/2025
3.390	Classroom G01 Heat 2				02/20/2025
3.391	Classroom G02 Heat 1				02/20/2025
3.391	Classroom G02 Heat 2				02/20/2025
3.393	Classroom G03 Heat 1				02/20/2025
3.393	Classroom G03 Heat 2				02/20/2025
2.146	Classroom H01 Heat 1				02/19/2025
2.146	Classroom H01 Heat 2				02/19/2025
2.145	Classroom H02 Heat 1				02/19/2025
2.145	Classroom H02 Heat 2				02/19/2025
2.144	Classroom H03 Heat 1				02/19/2025
2.144	Classroom H03 Heat 2				02/19/2025
2.143	Classroom H04 Heat 1				02/19/2025
2.143	Classroom H04 Heat 2				02/19/2025
3.389	Classroom K01 Heat 1				02/19/2025
3.389	Classroom K01 Heat 2				02/19/2025
3.387	Classroom K02 Heat 1				02/19/2025
3.387	Classroom K02 Heat 2				02/19/2025
3.388	Classroom K03 Heat 1				02/19/2025
3.388	Classroom K03 Heat 2				02/19/2025
3.385	Classroom K04 Heat 1				02/19/2025
3.385	Classroom K04 Heat 2				02/19/2025
3.009	Bldg E Custodial Heat				02/19/2025
3.409	Bldg L Heat 1				02/19/2025
3.409	Bldg L Heat 2				02/19/2025
3.409	Bldg L Heat 3				02/19/2025
3.433	Classroom N01 Heat 1				02/19/2025
3.433	Classroom N01 Heat 2				02/19/2025
3.432	Classroom N02 Heat 1				02/19/2025
3.432	Classroom N02 Heat 2				02/19/2025
3.435	Classroom N03 Heat 1				02/19/2025
3.435	Classroom N03 Heat 2				02/19/2025
3.413	Classroom N04 Heat 1				02/19/2025
3.413	Classroom N04 Heat 2				02/19/2025
3.434	Classroom N05 Heat 1				02/19/2025
3.434	Classroom N05 Heat 2				02/19/2025

Ventilation and Cooking Equipment

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Range Suppression					
101-20	Cartridge				01/04/2020
	Suppression System				01/04/2023
Range Suppression Tank					
	Ansul R102 1.5 Gallon Cylinder				01/04/2023
Cooking Equipment					
	Appliances				01/04/2023
Range Hood					

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Hood					01/04/2023
Fusible Links					
Fusible Links 450 x 3					09/04/2025