

Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

WINTERSTEIN (GATEWAY INT)

900 MORSE AVENUE
SACRAMENTO, California 95864
United States

This site has been inspected and tested in compliance with applicable standards.

Completed

Wednesday, March 04, 2026

Test Session:04 Mar 2026 11:27 RJ AFA

ACCEPTED BY

SAN JUAN USD
5320 HEMLOCK ST
SACRAMENTO, California
United States

TESTED BY

Riley Goyet
Western States Fire Protection-
Sacramento
188 Cirby Way
Roseville, CA 95678
United States



Inspection Summary

Building Information

PROPERTY	WINTERSTEIN (GATEWAY INT)	CONTACT
ADDRESS	900 MORSE AVENUE	PHONE
CITY/STATE	SACRAMENTO, California 95864	MOBILE
COUNTRY	United States	EMAIL

Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us

Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Power Supplies	2	2(100%)	2(100%)	0(0%)
Fire Control Panel	1	1(100%)	1(100%)	0(0%)
Alarm Notification Appliance	1	1(100%)	1(100%)	0(0%)
Initiating Device	134	134(100%)	134(100%)	0(0%)

Certification

The equipment specified herein was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Wednesday, March 04, 2026

ACCEPTED BY 03/04/2026

Building Representative


TESTED BY 03/04/2026
Riley Goyet
Technician

Testing Details

Alarm Notification Appliance

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Horn/Strobe		Horns/Strobes	Manual	3/4/2026 8:31:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Fire Alarm Control Panel		FACP	Manual	3/4/2026 8:31:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2.028	Admin Front Office	Manual	3/4/2026 8:28:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.023	Admin Office	Manual	3/4/2026 8:28:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.025	Admin Office	Manual	3/4/2026 8:28:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.024	Admin Storage	Manual	3/4/2026 8:28:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.026	Admin VP Office	Manual	3/4/2026 8:28:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.029	Boys Restroom by B01	Manual	3/4/2026 8:28:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.282	Boys Restroom by C06	Manual	3/4/2026 8:30:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.318	Boys Restroom by D03	Manual	3/4/2026 8:31:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.323	Boys Restroom by H01	Manual	3/4/2026 8:31:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.036	Classroom B02	Manual	3/4/2026 8:28:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.037	Classroom B02	Manual	3/4/2026 8:28:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.038	Classroom B02	Manual	3/4/2026 8:28:51 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	2.039	Classroom B02	Manual	3/4/2026 8:28:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.040	Classroom B03	Manual	3/4/2026 8:28:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.041	Classroom B03	Manual	3/4/2026 8:28:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.042	Classroom B03	Manual	3/4/2026 8:28:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.043	Classroom B03	Manual	3/4/2026 8:28:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.044	Classroom B04	Manual	3/4/2026 8:29:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.045	Classroom B04	Manual	3/4/2026 8:29:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.046	Classroom B04	Manual	3/4/2026 8:29:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.047	Classroom B04	Manual	3/4/2026 8:29:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.048	Classroom B05	Manual	3/4/2026 8:29:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.049	Classroom B05	Manual	3/4/2026 8:29:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.050	Classroom B05	Manual	3/4/2026 8:29:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.051	Classroom B05	Manual	3/4/2026 8:29:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.052	Classroom B06	Manual	3/4/2026 8:29:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.053	Classroom B06	Manual	3/4/2026 8:29:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.054	Classroom B06	Manual	3/4/2026 8:29:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.055	Classroom B06	Manual	3/4/2026 8:29:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.256	Classroom C01	Manual	3/4/2026 8:29:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2.257	Classroom C01	Manual	3/4/2026 8:29:41 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.258	Classroom C01	Manual	3/4/2026 8:29:43 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.259	Classroom C01	Manual	3/4/2026 8:29:45 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.260	Classroom C02	Manual	3/4/2026 8:29:46 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.261	Classroom C02	Manual	3/4/2026 8:29:48 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.262	Classroom C02	Manual	3/4/2026 8:29:49 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.263	Classroom C02	Manual	3/4/2026 8:29:51 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.264	Classroom C03	Manual	3/4/2026 8:29:52 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.265	Classroom C03	Manual	3/4/2026 8:29:54 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.266	Classroom C03	Manual	3/4/2026 8:29:55 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.267	Classroom C03	Manual	3/4/2026 8:29:57 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.268	Classroom C04	Manual	3/4/2026 8:29:58 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.269	Classroom C04	Manual	3/4/2026 8:29:59 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.270	Classroom C04	Manual	3/4/2026 8:30:01 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.271	Classroom C04	Manual	3/4/2026 8:30:03 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.272	Classroom C05	Manual	3/4/2026 8:30:04 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.273	Classroom C05	Manual	3/4/2026 8:30:05 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.274	Classroom C05	Manual	3/4/2026 8:30:09 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.275	Classroom C05	Manual	3/4/2026 8:30:10 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.276	Classroom C06	Manual	3/4/2026 8:30:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.277	Classroom C06	Manual	3/4/2026 8:30:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.278	Classroom C06	Manual	3/4/2026 8:30:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.279	Classroom C06	Manual	3/4/2026 8:30:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.303	Classroom D01	Manual	3/4/2026 8:30:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.304	Classroom D01	Manual	3/4/2026 8:30:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.305	Classroom D01	Manual	3/4/2026 8:30:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.306	Classroom D01	Manual	3/4/2026 8:30:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.307	Classroom D02	Manual	3/4/2026 8:30:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.308	Classroom D02	Manual	3/4/2026 8:30:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.309	Classroom D02	Manual	3/4/2026 8:31:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.310	Classroom D02	Manual	3/4/2026 8:31:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.311	Classroom D03	Manual	3/4/2026 8:31:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.312	Classroom D03	Manual	3/4/2026 8:31:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.313	Classroom D03	Manual	3/4/2026 8:31:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.314	Classroom D03	Manual	3/4/2026 8:31:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.315	Classroom D03	Manual	3/4/2026 8:31:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.381	Classroom D03	Manual	3/4/2026 8:31:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2.283	Classroom E01	Manual	3/4/2026 8:30:21 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.284	Classroom E01	Manual	3/4/2026 8:30:22 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.285	Classroom E01	Manual	3/4/2026 8:30:24 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.286	Classroom E01	Manual	3/4/2026 8:30:25 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.289	Classroom E02	Manual	3/4/2026 8:30:28 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.290	Classroom E02	Manual	3/4/2026 8:30:30 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.291	Classroom E02	Manual	3/4/2026 8:30:31 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.292	Classroom E02	Manual	3/4/2026 8:30:32 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.294	Classroom E02	Manual	3/4/2026 8:30:35 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.293	Classroom E02 Restroom	Manual	3/4/2026 8:30:34 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.297	Classroom E03	Manual	3/4/2026 8:30:40 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.299	Classroom E03	Manual	3/4/2026 8:30:43 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.300	Classroom E03	Manual	3/4/2026 8:30:45 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.301	Classroom E03	Manual	3/4/2026 8:30:46 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.302	Classroom E03	Manual	3/4/2026 8:30:47 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.296	Classroom E03 Restroom	Manual	3/4/2026 8:30:39 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.319	Classroom G01	Manual	3/4/2026 8:31:14 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.320	Classroom G01	Manual	3/4/2026 8:31:15 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2.321	Classroom G02	Manual	3/4/2026 8:31:17 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.322	Classroom G02	Manual	3/4/2026 8:31:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.326	Classroom H01	Manual	3/4/2026 8:31:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.327	Classroom H01	Manual	3/4/2026 8:31:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.328	Classroom H02	Manual	3/4/2026 8:31:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.329	Classroom H02	Manual	3/4/2026 8:31:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.330	Classroom I01	Manual	3/4/2026 8:31:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.331	Classroom I01	Manual	3/4/2026 8:31:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.332	Classroom I02	Manual	3/4/2026 8:31:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.333	Classroom I02	Manual	3/4/2026 8:31:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.346	Classroom J01	Manual	3/4/2026 8:31:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.347	Classroom J01	Manual	3/4/2026 8:31:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.348	Classroom J02	Manual	3/4/2026 8:31:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.349	Classroom J02	Manual	3/4/2026 8:31:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.350	Classroom J03	Manual	3/4/2026 8:31:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.351	Classroom J03	Manual	3/4/2026 8:31:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.352	Classroom J04	Manual	3/4/2026 8:31:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.353	Classroom J04	Manual	3/4/2026 8:31:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.030	Custodian Closet by Rm 1	Manual	3/4/2026 8:28:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2.254	Custodian Office C11	Manual	3/4/2026 8:29:39 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.316	Custodian Rm by D03	Manual	3/4/2026 8:31:11 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.031	Girls Restroom by B01	Manual	3/4/2026 8:28:40 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.004	MP Room	Manual	3/4/2026 8:28:09 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.005	MP Room	Manual	3/4/2026 8:28:11 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.006	MP Room	Manual	3/4/2026 8:28:12 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.007	MP Room	Manual	3/4/2026 8:28:14 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.008	MP Room	Manual	3/4/2026 8:28:16 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.009	MP Room	Manual	3/4/2026 8:28:17 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.010	MP Room	Manual	3/4/2026 8:28:19 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.011	MP Room	Manual	3/4/2026 8:28:20 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.012	MP Room Hall	Manual	3/4/2026 8:28:21 PM
		Visual inspection	Passed (Manual)	
Manual Pull Station	2.142	MP Room NE Pull station	Manual	3/4/2026 8:29:28 PM
		Visual inspection	Passed (Manual)	
Manual Pull Station	2.137	MP Room SE Pull station	Manual	3/4/2026 8:29:24 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.015	MP Room Stage	Manual	3/4/2026 8:28:26 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.017	MP Room Stage	Manual	3/4/2026 8:28:28 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.013	MP Room Stage Storage	Manual	3/4/2026 8:28:23 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2.014	MP Room Stage Storage	Manual	3/4/2026 8:28:25 PM
		Visual inspection	Passed (Manual)	
Manual Pull Station	2.138	MP Room SW Pull station	Manual	3/4/2026 8:29:26 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.032	Staff Rm B01	Manual	3/4/2026 8:28:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.033	Staff Rm B01	Manual	3/4/2026 8:28:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.034	Staff Rm B01	Manual	3/4/2026 8:28:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.068	Staff Rm B01	Manual	3/4/2026 8:29:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.069	Staff Rm B01	Manual	3/4/2026 8:29:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.035	Staff Rm by B01	Manual	3/4/2026 8:28:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.280	Storage by Classroom C06	Manual	3/4/2026 8:30:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.287	Storage Classroom E01	Manual	3/4/2026 8:30:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.295	Storage Classroom E02	Manual	3/4/2026 8:30:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.298	Storage Classroom E03	Manual	3/4/2026 8:30:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.324	Unisex Restroom by H01	Manual	3/4/2026 8:31:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Power Supplies

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
BPS - Booster Power Supply		BPS-A at FACP	Manual	3/4/2026 8:31:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
BPS - Booster Power Supply		BPS-B at FACP	Manual	3/4/2026 8:31:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Device/Equipment details

Alarm Notification Appliance					
ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Horn/Strobe					
	Horns/Strobes				02/27/2025
Fire Control Panel					
ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Fire Alarm Control Panel					
	FACP				02/27/2025
Initiating Device					
ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Smoke Detector - General					
2.284	Classroom E01				02/27/2025
2.283	Classroom E01				02/27/2025
2.286	Classroom E01				02/27/2025
2.285	Classroom E01				02/27/2025
2.287	Storage Classroom E01				02/27/2025
2.290	Classroom E02				02/27/2025
2.289	Classroom E02				02/27/2025
2.295	Storage Classroom E02				02/27/2025
2.292	Classroom E02				02/27/2025
2.291	Classroom E02				02/27/2025
2.294	Classroom E02				02/27/2025
2.293	Classroom E02 Restroom				02/27/2025
2.297	Classroom E03				02/27/2025
2.300	Classroom E03				02/27/2025
2.296	Classroom E03 Restroom				02/27/2025
2.302	Classroom E03				02/27/2025
2.301	Classroom E03				02/27/2025
2.299	Classroom E03				02/27/2025
2.298	Storage Classroom E03				02/27/2025
2.305	Classroom D01				02/27/2025
2.304	Classroom D01				02/27/2025
2.303	Classroom D01				02/27/2025
2.306	Classroom D01				02/27/2025
2.307	Classroom D02				02/27/2025
2.308	Classroom D02				02/27/2025
2.309	Classroom D02				02/27/2025
2.310	Classroom D02				02/27/2025
2.311	Classroom D03				02/27/2025
2.381	Classroom D03				02/27/2025
2.313	Classroom D03				02/27/2025
2.312	Classroom D03				02/27/2025
2.314	Classroom D03				02/27/2025
2.315	Classroom D03				02/27/2025
2.318	Boys Restroom by D03				02/27/2025
2.316	Custodian Rm by D03				02/27/2025
2.322	Classroom G02				02/27/2025
2.320	Classroom G01				02/27/2025
2.321	Classroom G02				02/27/2025
2.319	Classroom G01				02/27/2025

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2.323	Boys Restroom by H01				02/27/2025
2.327	Classroom H01				02/27/2025
2.324	Unisex Restroom by H01				02/27/2025
2.326	Classroom H01				02/27/2025
2.329	Classroom H02				02/27/2025
2.328	Classroom H02				02/27/2025
2.331	Classroom I01				02/27/2025
2.330	Classroom I01				02/27/2025
2.333	Classroom I02				02/27/2025
2.332	Classroom I02				02/27/2025
2.347	Classroom J01				02/27/2025
2.346	Classroom J01				02/27/2025
2.349	Classroom J02				02/27/2025
2.348	Classroom J02				02/27/2025
2.351	Classroom J03				02/27/2025
2.350	Classroom J03				02/27/2025
2.352	Classroom J04				02/27/2025
2.353	Classroom J04				02/27/2025
2.280	Storage by Classroom C06				02/27/2025
2.282	Boys Restroom by C06				02/27/2025
2.277	Classroom C06				02/27/2025
2.278	Classroom C06				02/27/2025
2.276	Classroom C06				02/27/2025
2.279	Classroom C06				02/27/2025
2.275	Classroom C05				02/27/2025
2.272	Classroom C05				02/27/2025
2.274	Classroom C05				02/27/2025
2.273	Classroom C05				02/27/2025
2.269	Classroom C04				02/27/2025
2.268	Classroom C04				02/27/2025
2.270	Classroom C04				02/27/2025
2.271	Classroom C04				02/27/2025
2.264	Classroom C03				02/27/2025
2.265	Classroom C03				02/27/2025
2.266	Classroom C03				02/27/2025
2.267	Classroom C03				02/27/2025
2.262	Classroom C02				02/27/2025
2.261	Classroom C02				02/27/2025
2.263	Classroom C02				02/27/2025
2.260	Classroom C02				02/27/2025
2.258	Classroom C01				02/27/2025
2.256	Classroom C01				02/27/2025
2.257	Classroom C01				02/27/2025
2.259	Classroom C01				02/27/2025
2.030	Custodian Closet by Rm 1				02/27/2025
2.028	Admin Front Office				02/27/2025
2.035	Staff Rm by B01				02/27/2025
2.031	Girls Restroom by B01				02/27/2025
2.068	Staff Rm B01				02/27/2025
2.033	Staff Rm B01				02/27/2025
2.034	Staff Rm B01				02/27/2025
2.032	Staff Rm B01				02/27/2025

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2.069	Staff Rm B01				02/27/2025
2.036	Classroom B02				02/27/2025
2.038	Classroom B02				02/27/2025
2.037	Classroom B02				02/27/2025
2.039	Classroom B02				02/27/2025
2.040	Classroom B03				02/27/2025
2.043	Classroom B03				02/27/2025
2.042	Classroom B03				02/27/2025
2.041	Classroom B03				02/27/2025
2.044	Classroom B04				02/27/2025
2.046	Classroom B04				02/27/2025
2.045	Classroom B04				02/27/2025
2.047	Classroom B04				02/27/2025
2.051	Classroom B05				02/27/2025
2.049	Classroom B05				02/27/2025
2.050	Classroom B05				02/27/2025
2.048	Classroom B05				02/27/2025
2.054	Classroom B06				02/27/2025
2.052	Classroom B06				02/27/2025
2.053	Classroom B06				02/27/2025
2.055	Classroom B06				02/27/2025
2.029	Boys Restroom by B01				02/27/2025
2.024	Admin Storage				02/27/2025
2.023	Admin Office				02/27/2025
2.025	Admin Office				02/27/2025
2.026	Admin VP Office				02/27/2025
2.254	Custodian Office C11				02/27/2025
2.005	MP Room				02/27/2025
2.008	MP Room				02/27/2025
2.006	MP Room				02/27/2025
2.009	MP Room				02/27/2025
2.007	MP Room				02/27/2025
2.010	MP Room				02/27/2025
2.004	MP Room				02/27/2025
2.011	MP Room				02/27/2025
2.012	MP Room Hall				02/27/2025
2.017	MP Room Stage				02/27/2025
2.015	MP Room Stage				02/27/2025
2.014	MP Room Stage Storage				02/27/2025
2.013	MP Room Stage Storage				02/27/2025
Manual Pull Station					
2.137	MP Room SE Pull station				02/27/2025
2.138	MP Room SW Pull station				02/27/2025
2.142	MP Room NE Pull station				02/27/2025
Power Supplies					
ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
BPS - Booster Power Supply					
	BPS-A at FACP				02/27/2025
	BPS-B at FACP				02/27/2025