

Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

PALISADES LA VISTA SPECIA

9601 LAKE NATOMA DR
ORANGEVALE, California
United States

This site has been inspected and tested in compliance with applicable standards.

Completed
Monday, May 04, 2026

Test Session:04 Mar 2026 17:09 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD
5320 HEMLOCK ST
SACRAMENTO, California
United States

TESTED BY

Riley Goyet
Western States Fire Protection-
Sacramento
188 Cirby Way
Roseville, CA 95678
United States



Inspection Summary

Building Information

PROPERTY	PALISADES LA VISTA SPECIA	CONTACT
ADDRESS	9601 LAKE NATOMA DR	PHONE
CITY/STATE	ORANGEVALE, California	MOBILE
COUNTRY	United States	EMAIL

Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us

Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Alarm Notification Appliance	62	62(100%)	62(100%)	0(0%)
Fire Control Panel	4	4(100%)	2(50%)	2(50%)
Initiating Device	89	83(93%)	83(93%)	0(0%)

Certification

The equipment specified herein was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Monday, May 04, 2026

ACCEPTED BY 05/04/2026

Building Representative



TESTED BY 05/04/2026
Riley Goyet
Technician

Open Corrective Action & Solution Summary

The following 7 corrective action(s) remain open following the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
NAC Power Extender Panel	082	Rooms 5-9 Bldg Cust Strge by Rm C
	Created By:	
	Creation Date:	03/19/2020
	Corrective Action:	Batteries failed test
	Proposed Solution:	Costumer to replace
	Manufacturer:	
	Model:	
	Created By:	Riley Goyet
	Creation Date:	03/01/2023
	Corrective Action:	Replace batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
	Created By:	Riley Goyet
	Creation Date:	02/07/2024
	Corrective Action:	BPS A replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
	Created By:	Riley Goyet
	Creation Date:	04/21/2025
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
Fire Alarm Panel		Rooms 5-9 Bldg Cust Strge by Rm C
	Created By:	Riley Goyet
	Creation Date:	04/21/2025
	Corrective Action:	Replace (2) 12V 55AH Batteries.
	Proposed Solution:	
	Manufacturer:	Notifier
	Model:	NFS-3030
	Created By:	Riley Goyet
	Creation Date:	03/04/2026
	Corrective Action:	Replace (2) 12V 55AH Batteries
	Proposed Solution:	
	Manufacturer:	Notifier
	Model:	NFS-3030
	Created By:	Riley Goyet
	Creation Date:	03/04/2026
	Corrective Action:	Ground fault detected
	Proposed Solution:	
	Manufacturer:	Notifier
	Model:	NFS-3030

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
----------------	---------	-------------



Resolved Corrective Action & Solution Summary

The following 1 corrective action(s) were resolved during the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	Description
NAC Power Extender Panel	081	Rooms 5-9 Bldg Cust Strge by Rm C BPS A
	Created By:	Riley Goyet
	Creation Date:	04/21/2025
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Resolution:	
	Resolved By:	Riley Goyet
	Resolved On:	03/04/2026
	Manufacturer:	
	Model:	

Testing Details

Alarm Notification Appliance

Passed				
EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible		Admin Building Library	Manual	3/4/2026 6:13:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Admin Building North Exterior	Manual	3/4/2026 6:13:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Admin Building Nurse Restroom	Manual	3/4/2026 6:13:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Admin Building Nurse Room	Manual	3/4/2026 6:13:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Admin Building Principals Office	Manual	3/4/2026 6:13:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Admin Building Reception	Manual	3/4/2026 6:13:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Admin Building Room A	Manual	3/4/2026 6:13:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Admin Building Room B	Manual	3/4/2026 6:13:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Admin Building Staff Room	Manual	3/4/2026 6:13:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Admin Building Staff RR by Library	Manual	3/4/2026 6:13:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Admin Building Staff RR by Room B	Manual	3/4/2026 6:13:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Admin Building West Exterior	Manual	3/4/2026 6:13:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Multi-Purpose Bldg Kitchen	Manual	3/4/2026 6:11:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Multi-Purpose Bldg Kitchen	Manual	3/4/2026 6:11:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Multi-Purpose Bldg Kitchen	Manual	3/4/2026 6:11:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Multi-Purpose Bldg Kitchen	Manual	3/4/2026 6:11:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Multi-Purpose Bldg MP Room	Manual	3/4/2026 6:11:47 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Multi-Purpose Bldg MP Room	Manual	3/4/2026 6:11:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Multi-Purpose Bldg Staff Break Room	Manual	3/4/2026 6:11:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Multi-Purpose Bldg Stage	Manual	3/4/2026 6:11:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Multi-Purpose Bldg Stage HC Lift Right	Manual	3/4/2026 6:11:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Multi-Purpose Bldg West Exterior	Manual	3/4/2026 6:11:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Room 15 Building East Exterior	Manual	3/4/2026 6:11:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Room 15 Building Room 15	Manual	3/4/2026 6:11:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Room 15 Building Room 15 Restroom	Manual	3/4/2026 6:11:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Room 15 Building West Exterior	Manual	3/4/2026 6:11:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 10-14 Bldg Boys RR by Rm 14	Manual	3/4/2026 6:12:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 10-14 Bldg Girls RR by Rm 14	Manual	3/4/2026 6:12:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 10-14 Bldg Room 10	Manual	3/4/2026 6:12:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 10-14 Bldg Room 11	Manual	3/4/2026 6:12:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 10-14 Bldg Room 12	Manual	3/4/2026 6:12:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 10-14 Bldg Room 13	Manual	3/4/2026 6:12:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 10-14 Bldg Room 13A	Manual	3/4/2026 6:12:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 10-14 Bldg Room 13B	Manual	3/4/2026 6:12:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 10-14 Bldg Room 14	Manual	3/4/2026 6:12:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible		Rooms 10-14 Bldg Room D by Room 10	Manual	3/4/2026 6:11:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 10-14 Bldg South Exterior	Manual	3/4/2026 6:12:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 10-14 Bldg South Exterior	Manual	3/4/2026 6:12:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 10-14 Bldg South Exterior	Manual	3/4/2026 6:12:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 10-14 Bldg West Exterior	Manual	3/4/2026 6:12:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 1-4 Bldg Boys RR by Rm 4	Manual	3/4/2026 6:12:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 1-4 Bldg Girls RR by Rm 4	Manual	3/4/2026 6:12:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 1-4 Bldg Room 1	Manual	3/4/2026 6:12:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 1-4 Bldg Room 2	Manual	3/4/2026 6:12:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 1-4 Bldg Room 3	Manual	3/4/2026 6:12:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 1-4 Bldg Room 4	Manual	3/4/2026 6:12:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 1-4 Bldg Room E by Room 4	Manual	3/4/2026 6:12:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 1-4 Bldg South Exterior	Manual	3/4/2026 6:13:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 1-4 Bldg South Exterior	Manual	3/4/2026 6:13:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 1-4 Bldg West Exterior	Manual	3/4/2026 6:12:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Rooms 5-9 Bldg Boys RR by Rm 5	Manual	3/4/2026 6:12:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Rooms 5-9 Bldg Girls RR by Rm 5	Manual	3/4/2026 6:12:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 5-9 Bldg Room 5	Manual	3/4/2026 6:12:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 5-9 Bldg Room 6	Manual	3/4/2026 6:12:37 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 5-9 Bldg Room 7	Manual	3/4/2026 6:12:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 5-9 Bldg Room 8	Manual	3/4/2026 6:12:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 5-9 Bldg Room 9	Manual	3/4/2026 6:12:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 5-9 Bldg Room C	Manual	3/4/2026 6:11:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 5-9 Bldg South Exterior	Manual	3/4/2026 6:12:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 5-9 Bldg South Exterior	Manual	3/4/2026 6:12:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 5-9 Bldg South Exterior	Manual	3/4/2026 6:12:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 5-9 Bldg West Exterior	Manual	3/4/2026 6:12:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Remote Annunciator		Admin Building Reception	Manual	3/4/2026 7:03:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Rooms 5-9 Bldg Cust Strge by Rm C BPS A	Manual	3/4/2026 6:16:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Failed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Fire Alarm Panel		Rooms 5-9 Bldg Cust Strge by Rm C	Manual	3/4/2026 6:16:24 PM
		Manufacturer	Notifier	
		Model	NFS-3030	
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	
NAC Power Extender Panel		Rooms 5-9 Bldg Cust Strge by Rm C	Manual	3/4/2026 6:16:19 PM
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	

Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-030 014	Admin Building Library	Manual	3/4/2026 6:42:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-029 015	Admin Building Library	Manual	3/4/2026 6:42:42 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-022 008	Admin Building Nurse Closet	Manual	3/4/2026 6:47:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-023 007	Admin Building Nurse Restroom	Manual	3/4/2026 6:46:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-020 006	Admin Building Nurse Room	Manual	3/4/2026 6:45:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-027 004	Admin Building Principals Office	Manual	3/4/2026 6:46:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-026 005	Admin Building Principals Office Clst	Manual	3/4/2026 6:46:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-126 002	Admin Building Reception	Manual	3/4/2026 7:08:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-021 003	Admin Building Reception	Manual	3/4/2026 6:44:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-031 012	Admin Building Room A	Manual	3/4/2026 6:44:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-032 013	Admin Building Room B	Manual	3/4/2026 6:43:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-025 010	Admin Building Staff Office	Manual	3/4/2026 6:46:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-028 009	Admin Building Staff Office	Manual	3/4/2026 6:47:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-024 011	Admin Building Staff Office Closet	Manual	3/4/2026 6:46:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-033 016	Admin Building Staff RR by Library	Manual	3/4/2026 6:41:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-034 017	Admin Building Staff RR by Room B	Manual	3/4/2026 6:41:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-040 138	Multi-Purpose Bldg Kitchen	Manual	3/4/2026 6:25:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-041 135	Multi-Purpose Bldg Kitchen	Manual	3/4/2026 6:52:55 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	2-042 136	Multi-Purpose Bldg Kitchen	Manual	3/4/2026 6:54:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-043 137	Multi-Purpose Bldg Kitchen	Manual	3/4/2026 6:54:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-130 144	Multi-Purpose Bldg Kitchen W/H Closet	Manual	3/4/2026 6:30:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-038 125	Multi-Purpose Bldg MP Room	Manual	3/4/2026 6:48:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-035 126	Multi-Purpose Bldg MP Room	Manual	3/4/2026 6:49:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-037 128	Multi-Purpose Bldg MP Room	Manual	3/4/2026 6:49:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-036 127	Multi-Purpose Bldg MP Room	Manual	3/4/2026 6:49:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-129 123	Multi-Purpose Bldg SE Entry	Manual	3/4/2026 6:31:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-039 129	Multi-Purpose Bldg Staff Break Room	Manual	3/4/2026 6:55:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-047 132	Multi-Purpose Bldg Stage	Manual	3/4/2026 6:51:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-045 131	Multi-Purpose Bldg Stage HC Lift Right	Manual	3/4/2026 6:52:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-050 134	Multi-Purpose Bldg Stage Stair Left	Manual	3/4/2026 6:50:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-044 130	Multi-Purpose Bldg Stage Stair Right	Manual	3/4/2026 6:51:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-049 133	Multi-Purpose Bldg Stage Storage Left	Manual	3/4/2026 6:50:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-128 124	Multi-Purpose Bldg SW Entry	Manual	3/4/2026 6:33:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-267 114	Room 15 Building Room 15	Manual	3/4/2026 7:10:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-266 115	Room 15 Building Room 15	Manual	3/4/2026 7:10:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-265 113	Room 15 Building Room 15	Manual	3/4/2026 7:10:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-270 116	Room 15 Building Room 15	Manual	3/4/2026 7:10:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-269 117	Room 15 Building Room 15 Restroom	Manual	3/4/2026 7:10:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-268 118	Room 15 Building Room 15 Storage	Manual	3/4/2026 7:10:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-065 095	Rooms 10-14 Bldg Boys RR by Rm 14	Manual	3/4/2026 7:02:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-064 097	Rooms 10-14 Bldg Cust Clst by Rm 14	Manual	3/4/2026 6:22:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-066 096	Rooms 10-14 Bldg Girls RR by Rm 14	Manual	3/4/2026 7:02:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-053 084	Rooms 10-14 Bldg Room 10	Manual	3/4/2026 6:57:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-054 083	Rooms 10-14 Bldg Room 10	Manual	3/4/2026 6:57:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-056 085	Rooms 10-14 Bldg Room 11	Manual	3/4/2026 6:58:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-055 086	Rooms 10-14 Bldg Room 11	Manual	3/4/2026 6:58:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-057 087	Rooms 10-14 Bldg Room 12	Manual	3/4/2026 6:59:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-058 088	Rooms 10-14 Bldg Room 12	Manual	3/4/2026 6:59:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-060 089	Rooms 10-14 Bldg Room 13	Manual	3/4/2026 6:59:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-061 090	Rooms 10-14 Bldg Room 13A	Manual	3/4/2026 6:59:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-059 091	Rooms 10-14 Bldg Room 13B	Manual	3/4/2026 6:59:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-062 092	Rooms 10-14 Bldg Room 14	Manual	3/4/2026 7:00:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-063 093	Rooms 10-14 Bldg Room 14	Manual	3/4/2026 7:00:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-051 094	Rooms 10-14 Bldg Room D by Room 10	Manual	3/4/2026 6:56:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-052 098	Rooms 10-14 Bldg Storage behind Rm 10	Manual	3/4/2026 6:36:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-263 040	Rooms 1-4 Bldg Boys RR by Rm 4	Manual	3/4/2026 7:16:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-262 042	Rooms 1-4 Bldg Cust Closet by Rm 4	Manual	3/4/2026 6:19:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-264 041	Rooms 1-4 Bldg Girls RR by Rm 4	Manual	3/4/2026 7:16:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-253 031	Rooms 1-4 Bldg Room 1	Manual	3/4/2026 7:13:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-254 032	Rooms 1-4 Bldg Room 1	Manual	3/4/2026 7:13:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-256 033	Rooms 1-4 Bldg Room 2	Manual	3/4/2026 7:14:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-255 034	Rooms 1-4 Bldg Room 2	Manual	3/4/2026 7:14:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-257 035	Rooms 1-4 Bldg Room 3	Manual	3/4/2026 7:15:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-258 036	Rooms 1-4 Bldg Room 3	Manual	3/4/2026 7:15:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-259 037	Rooms 1-4 Bldg Room 4	Manual	3/4/2026 7:16:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-260 038	Rooms 1-4 Bldg Room 4	Manual	3/4/2026 7:16:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-261 039	Rooms 1-4 Bldg Room E by Room 4	Manual	3/4/2026 7:16:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-006 063	Rooms 5-9 Bldg Boys RR by Rm 5	Manual	3/4/2026 7:03:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-007 067	Rooms 5-9 Bldg Cust Closet by Rm 5	Manual	3/4/2026 6:18:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-005 066	Rooms 5-9 Bldg Cust Strge by Rm C	Manual	3/4/2026 6:40:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-008 064	Rooms 5-9 Bldg Girls RR by Rm 5	Manual	3/4/2026 7:03:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-132 068	Rooms 5-9 Bldg Plumb Chse by Rm 5	Manual	3/4/2026 6:36:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-010 053	Rooms 5-9 Bldg Room 5	Manual	3/4/2026 7:04:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-011 054	Rooms 5-9 Bldg Room 5	Manual	3/4/2026 7:04:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-013 055	Rooms 5-9 Bldg Room 6	Manual	3/4/2026 7:05:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-012 056	Rooms 5-9 Bldg Room 6	Manual	3/4/2026 7:05:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-014 057	Rooms 5-9 Bldg Room 7	Manual	3/4/2026 7:06:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-015 058	Rooms 5-9 Bldg Room 7	Manual	3/4/2026 7:06:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-016 060	Rooms 5-9 Bldg Room 8	Manual	3/4/2026 7:07:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-017 059	Rooms 5-9 Bldg Room 8	Manual	3/4/2026 7:07:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-018 061	Rooms 5-9 Bldg Room 9	Manual	3/4/2026 7:07:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-019 062	Rooms 5-9 Bldg Room 9	Manual	3/4/2026 7:07:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-009 065	Rooms 5-9 Bldg Room C	Manual	3/4/2026 7:02:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-127 018	Admin Building Attic Staff Office	Manual	3/4/2026 6:36:25 PM
Heat Detector - Restorable Spot	2-048 140	Multi-Purpose Bldg Stage HVAC Loft Left	Manual	3/4/2026 6:14:05 PM
Heat Detector - Restorable Spot	2-046 139	Multi-Purpose Bldg Stage HVAC Loft Rt	Manual	3/4/2026 6:14:02 PM
Heat Detector - Restorable Spot	2-131 142	Multi-Purpose Bldg Under Stage	Manual	3/4/2026 6:14:16 PM
Heat Detector - Restorable Spot	2-131 143	Multi-Purpose Bldg Under Stage	Manual	3/4/2026 6:14:22 PM
Heat Detector - Restorable Spot	2-131 141	Multi-Purpose Bldg Under Stage	Manual	3/4/2026 6:14:25 PM

Device/Equipment details

Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Audible					
019	Admin Building North Exterior				
020	Admin Building West Exterior				
043	Rooms 1-4 Bldg South Exterior				
044	Rooms 1-4 Bldg South Exterior				
045	Rooms 1-4 Bldg West Exterior				
069	Rooms 5-9 Bldg South Exterior				
070	Rooms 5-9 Bldg South Exterior				
071	Rooms 5-9 Bldg South Exterior				
072	Rooms 5-9 Bldg West Exterior				
099	Rooms 10-14 Bldg South Exterior				
100	Rooms 10-14 Bldg South Exterior				
101	Rooms 10-14 Bldg South Exterior				
102	Rooms 10-14 Bldg West Exterior				
119	Room 15 Building East Exterior				
120	Room 15 Building West Exterior				
145	Multi-Purpose Bldg West Exterior				
Audible And Visible					
021	Admin Building Reception				
022	Admin Building Nurse Room				
023	Admin Building Staff Room				
024	Admin Building Library				
046	Rooms 1-4 Bldg Room 1				
047	Rooms 1-4 Bldg Room 2				
048	Rooms 1-4 Bldg Room 3				
049	Rooms 1-4 Bldg Room 4				
050	Rooms 1-4 Bldg Room E by Room 4				
051	Rooms 1-4 Bldg Boys RR by Rm 4				
052	Rooms 1-4 Bldg Girls RR by Rm 4				
073	Rooms 5-9 Bldg Room 5				
074	Rooms 5-9 Bldg Room 6				
075	Rooms 5-9 Bldg Room 7				
076	Rooms 5-9 Bldg Room 8				
077	Rooms 5-9 Bldg Room 9				
078	Rooms 5-9 Bldg Room C				
103	Rooms 10-14 Bldg Room 10				
104	Rooms 10-14 Bldg Room 11				
105	Rooms 10-14 Bldg Room 12				
106	Rooms 10-14 Bldg Room 13				
107	Rooms 10-14 Bldg Room 13A				
108	Rooms 10-14 Bldg Room 13B				
109	Rooms 10-14 Bldg Room 14				
110	Rooms 10-14 Bldg Boys RR by Rm 14				
111	Rooms 10-14 Bldg Girls RR by Rm 14				
112	Rooms 10-14 Bldg Room D by Room 10				
121	Room 15 Building Room 15				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
146	Multi-Purpose Bldg MP Room				
147	Multi-Purpose Bldg MP Room				
148	Multi-Purpose Bldg Staff Break Room				
149	Multi-Purpose Bldg Stage				
150	Multi-Purpose Bldg Kitchen				
Visible					
025	Admin Building Principals Office				
026	Admin Building Nurse Restroom				
027	Admin Building Room A				
028	Admin Building Room B				
029	Admin Building Staff RR by Library				
030	Admin Building Staff RR by Room B				
079	Rooms 5-9 Bldg Boys RR by Rm 5				
080	Rooms 5-9 Bldg Girls RR by Rm 5				
122	Room 15 Building Room 15 Restroom				
151	Multi-Purpose Bldg Stage HC Lift Right				
152	Multi-Purpose Bldg Kitchen				
153	Multi-Purpose Bldg Kitchen				
154	Multi-Purpose Bldg Kitchen				

Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Remote Annunciator					
001	Admin Building Reception				
NAC Power Extender Panel					
081	Rooms 5-9 Bldg Cust Strge by Rm C BPS A				
082	Rooms 5-9 Bldg Cust Strge by Rm C				
Fire Alarm Panel					
	Rooms 5-9 Bldg Cust Strge by Rm C	Notifier	NFS-3030		03/19/2020

Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Manual Pull Station					
2-126 002	Admin Building Reception				
2-129 123	Multi-Purpose Bldg SE Entry				
2-128 124	Multi-Purpose Bldg SW Entry				
Smoke Detector - General					
2-021 003	Admin Building Reception				
2-027 004	Admin Building Principals Office				
2-026 005	Admin Building Principals Office Clst				
2-020 006	Admin Building Nurse Room				
2-023 007	Admin Building Nurse Restroom				
2-022 008	Admin Building Nurse Closet				
2-028 009	Admin Building Staff Office				
2-025 010	Admin Building Staff Office				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-024 011	Admin Building Staff Office Closet				
2-031 012	Admin Building Room A				
2-032 013	Admin Building Room B				
2-030 014	Admin Building Library				
2-029 015	Admin Building Library				
2-033 016	Admin Building Staff RR by Library				
2-034 017	Admin Building Staff RR by Room B				
2-253 031	Rooms 1-4 Bldg Room 1				
2-254 032	Rooms 1-4 Bldg Room 1				
2-256 033	Rooms 1-4 Bldg Room 2				
2-255 034	Rooms 1-4 Bldg Room 2				
2-257 035	Rooms 1-4 Bldg Room 3				
2-258 036	Rooms 1-4 Bldg Room 3				
2-259 037	Rooms 1-4 Bldg Room 4				
2-260 038	Rooms 1-4 Bldg Room 4				
2-261 039	Rooms 1-4 Bldg Room E by Room 4				
2-263 040	Rooms 1-4 Bldg Boys RR by Rm 4				
2-264 041	Rooms 1-4 Bldg Girls RR by Rm 4				
2-010 053	Rooms 5-9 Bldg Room 5				
2-011 054	Rooms 5-9 Bldg Room 5				
2-013 055	Rooms 5-9 Bldg Room 6				
2-012 056	Rooms 5-9 Bldg Room 6				
2-014 057	Rooms 5-9 Bldg Room 7				
2-015 058	Rooms 5-9 Bldg Room 7				
2-017 059	Rooms 5-9 Bldg Room 8				
2-016 060	Rooms 5-9 Bldg Room 8				
2-018 061	Rooms 5-9 Bldg Room 9				
2-019 062	Rooms 5-9 Bldg Room 9				
2-006 063	Rooms 5-9 Bldg Boys RR by Rm 5				
2-008 064	Rooms 5-9 Bldg Girls RR by Rm 5				
2-009 065	Rooms 5-9 Bldg Room C				
2-005 066	Rooms 5-9 Bldg Cust Strge by Rm C				
2-054 083	Rooms 10-14 Bldg Room 10				
2-053 084	Rooms 10-14 Bldg Room 10				
2-056 085	Rooms 10-14 Bldg Room 11				
2-055 086	Rooms 10-14 Bldg Room 11				
2-057 087	Rooms 10-14 Bldg Room 12				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-058 088	Rooms 10-14 Bldg Room 12				
2-060 089	Rooms 10-14 Bldg Room 13				
2-061 090	Rooms 10-14 Bldg Room 13A				
2-059 091	Rooms 10-14 Bldg Room 13B				
2-062 092	Rooms 10-14 Bldg Room 14				
2-063 093	Rooms 10-14 Bldg Room 14				
2-051 094	Rooms 10-14 Bldg Room D by Room 10				
2-065 095	Rooms 10-14 Bldg Boys RR by Rm 14				
2-066 096	Rooms 10-14 Bldg Girls RR by Rm 14				
2-265 113	Room 15 Building Room 15				
2-267 114	Room 15 Building Room 15				
2-266 115	Room 15 Building Room 15				
2-270 116	Room 15 Building Room 15				
2-269 117	Room 15 Building Room 15 Restroom				
2-268 118	Room 15 Building Room 15 Storage				
2-038 125	Multi-Purpose Bldg MP Room				
2-035 126	Multi-Purpose Bldg MP Room				
2-036 127	Multi-Purpose Bldg MP Room				
2-037 128	Multi-Purpose Bldg MP Room				
2-039 129	Multi-Purpose Bldg Staff Break Room				
2-044 130	Multi-Purpose Bldg Stage Stair Right				
2-045 131	Multi-Purpose Bldg Stage HC Lift Right				
2-047 132	Multi-Purpose Bldg Stage				
2-049 133	Multi-Purpose Bldg Stage Storage Left				
2-050 134	Multi-Purpose Bldg Stage Stair Left				
2-041 135	Multi-Purpose Bldg Kitchen				
2-042 136	Multi-Purpose Bldg Kitchen				
2-043 137	Multi-Purpose Bldg Kitchen				
Heat Detector - Restorable Spot					
2-127 018	Admin Building Attic Staff Office				
2-262 042	Rooms 1-4 Bldg Cust Closet by Rm 4				
2-007 067	Rooms 5-9 Bldg Cust Closet by Rm 5				
2-132 068	Rooms 5-9 Bldg Plumb Chse by Rm 5				
2-064 097	Rooms 10-14 Bldg Cust Clst by Rm 14				
2-052 098	Rooms 10-14 Bldg Storage behind Rm 10				
2-040 138	Multi-Purpose Bldg Kitchen				
2-046 139	Multi-Purpose Bldg Stage HVAC Loft Rt				
2-048 140	Multi-Purpose Bldg Stage HVAC Loft Left				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-131 141	Multi-Purpose Bldg Under Stage				
2-131 142	Multi-Purpose Bldg Under Stage				
2-131 143	Multi-Purpose Bldg Under Stage				
2-130 144	Multi-Purpose Bldg Kitchen W/H Closet				