

# Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

DETERTING ELEMENTARY

6000 Stanley Avenue  
CARMICHAEL, California  
United States

This site has been inspected and tested in compliance with applicable standards.

Completed  
Wednesday, March 04, 2026

Test Session:11 Feb 2026 14:46 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD  
5320 HEMLOCK ST  
SACRAMENTO, California  
United States

TESTED BY

Riley Goyet  
Western States Fire Protection-  
Sacramento  
188 Cirby Way  
Roseville, CA 95678  
United States



# Inspection Summary

## Building Information

PROPERTY	DETERTING ELEMENTARY	CONTACT
ADDRESS	6000 Stanley Avenue	PHONE
CITY/STATE	CARMICHAEL, California	MOBILE
COUNTRY	United States	EMAIL

## Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us


## Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Alarm Notification Appliance	75	75(100%)	75(100%)	0(0%)
Fire Control Panel	9	9(100%)	9(100%)	0(0%)
Initiating Device	142	140(99%)	140(99%)	0(0%)

## Certification

The equipment specified herein was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Wednesday, March 04, 2026

ACCEPTED BY      03/04/2026  
  
Building Representative

  
TESTED BY      03/04/2026  
Riley Goyet  
Technician

# System Details

## Control Units

ADDRESS/ SCAN ADDRESS	/ 059	DESCRIPTION	Rooms 3-6 Bldg Work Rm by Rm 3
MANUFACTURER	Notifier	S/W VERSION	
MODEL	NFS-3030	LAST UPDATE	
SERIAL NUMBER		S/W LOCATION	
INSTALL DATE			

# Open Corrective Action & Solution Summary

The following 1 corrective action(s) remain open following the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
Fire Alarm Panel	059	Rooms 3-6 Bldg Work Rm by Rm 3
	Created By:	Riley Goyet
	Creation Date:	02/15/2026
	Corrective Action:	Replace (2) 12V 55AH Batteries
	Proposed Solution:	
	Manufacturer:	Notifier
	Model:	NFS-3030

# Resolved Corrective Action & Solution Summary

The following 8 corrective action(s) were resolved during the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	Description
NAC Power Extender Panel	060	Rooms 3-6 Bldg Work Rm by Rm 3 P.E. C
	Created By:	Riley Goyet
	Creation Date:	11/30/2022
	Corrective Action:	Replace (2) 12V 8AH batteries.
	Resolution:	
	Resolved By:	Riley Goyet
	Resolved On:	02/15/2026
	Manufacturer:	
	Model:	
	Created By:	Riley Goyet
	Creation Date:	02/06/2025
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Resolution:	
	Resolved By:	Riley Goyet
	Resolved On:	02/15/2026
	Manufacturer:	
	Model:	
Fire Alarm Panel	059	Rooms 3-6 Bldg Work Rm by Rm 3
	Created By:	Riley Goyet
	Creation Date:	02/06/2025
	Corrective Action:	Replace (2) 12V 55AH Batteries
	Resolution:	
	Resolved By:	Riley Goyet
	Resolved On:	02/15/2026
	Manufacturer:	Notifier
	Model:	NFS-3030
NAC Power Extender Panel	156	Rms 1920 Library Cust Strge by Rm 20
	Created By:	Riley Goyet
	Creation Date:	02/06/2025
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Resolution:	
	Resolved By:	Riley Goyet
	Resolved On:	02/15/2026
	Manufacturer:	
	Model:	
NAC Power Extender Panel	189	Portables Classroom 21
	Created By:	Riley Goyet
	Creation Date:	02/06/2025
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Resolution:	
	Resolved By:	Riley Goyet
	Resolved On:	02/15/2026
	Manufacturer:	
	Model:	
NAC Power Extender Panel	219	Multi-Purpose Bldg Stage Storage
	Created By:	Riley Goyet
	Creation Date:	02/06/2025
	Corrective Action:	Replace (2) 12V 8AH Batteries

EQUIPMENT TYPE	ADDRESS	Description
----------------	---------	-------------

Resolution:  
 Resolved By: Riley Goyet  
 Resolved On: 02/15/2026  
 Manufacturer:  
 Model:

NAC Power Extender Panel		Rooms 3-6 Bldg Work Rm by Rm 3
--------------------------	--	--------------------------------

Created By: Riley Goyet  
 Creation Date: 02/06/2025  
 Corrective Action: Replace (2) 12V 8AH Batteries  
 Resolution:  
 Resolved By: Riley Goyet  
 Resolved On: 02/15/2026  
 Manufacturer:  
 Model:

NAC Power Extender Panel		Portables classroom 25
--------------------------	--	------------------------

Created By: Riley Goyet  
 Creation Date: 02/06/2025  
 Corrective Action: Replace (2) 12V 7AH Batteries  
 Resolution:  
 Resolved By: Riley Goyet  
 Resolved On: 02/15/2026  
 Manufacturer:  
 Model:

# Testing Details

## Alarm Notification Appliance

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible		Admin Building File Room	Manual	2/11/2026 2:49:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Admin Building File Room Restroom	Manual	2/11/2026 2:49:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Admin Building North Exterior	Manual	2/11/2026 2:49:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Admin Building Office Reception	Manual	2/11/2026 2:49:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Admin Building Principal Restroom	Manual	2/11/2026 2:49:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Admin Building Principals Office	Manual	2/11/2026 2:49:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Admin Building Secretary Office	Manual	2/11/2026 2:49:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Admin Building South Exterior	Manual	2/11/2026 2:49:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Admin Building Work Room	Manual	2/11/2026 2:49:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Multi-Purpose Bldg Kitchen	Manual	2/11/2026 2:48:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Multi-Purpose Bldg Kitchen	Manual	2/11/2026 2:48:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Multi-Purpose Bldg Kitchen Restroom	Manual	2/11/2026 2:48:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Multi-Purpose Bldg Kitchen Restroom	Manual	2/11/2026 2:48:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Multi-Purpose Bldg MP Room	Manual	2/11/2026 2:48:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Multi-Purpose Bldg MP Room	Manual	2/11/2026 2:48:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Multi-Purpose Bldg North Exterior	Manual	2/11/2026 2:48:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Multi-Purpose Bldg South Exterior	Manual	2/11/2026 2:48:12 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Multi-Purpose Bldg Stage	Manual	2/11/2026 2:48:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Portables Classroom 21	Manual	2/11/2026 2:48:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Portables Classroom 22	Manual	2/11/2026 2:48:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Portables Classroom 23	Manual	2/11/2026 2:48:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Portables Classroom 24	Manual	2/11/2026 2:48:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Portables Classroom 25	Manual	2/11/2026 2:48:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Portables Classroom 26	Manual	2/11/2026 2:48:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Portables East Exterior	Manual	2/11/2026 2:48:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Portables West Exterior	Manual	2/11/2026 2:48:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Rms 1920 Library Boys RR by Rm 20	Manual	2/11/2026 2:48:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rms 1920 Library Classroom 19	Manual	2/11/2026 2:48:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rms 1920 Library Classroom 20	Manual	2/11/2026 2:48:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rms 1920 Library East Exterior	Manual	2/11/2026 2:48:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Rms 1920 Library Girls RR by Rm 20	Manual	2/11/2026 2:48:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rms 1920 Library Library	Manual	2/11/2026 2:48:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rms 1920 Library South Exterior	Manual	2/11/2026 2:48:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rms 1920 Library West Exterior	Manual	2/11/2026 2:48:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Room 1 2 Bldg Classroom 1	Manual	2/11/2026 2:49:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible		Room 1 2 Bldg Classroom 1 RR	Manual	2/11/2026 2:49:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Room 1 2 Bldg Classroom 1 RR	Manual	2/11/2026 2:49:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Room 1 2 Bldg Classroom 2	Manual	2/11/2026 2:49:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Room 1 2 Bldg Classroom 2 RR	Manual	2/11/2026 2:49:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Room 1 2 Bldg West Exterior	Manual	2/11/2026 2:49:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 11-14 Bldg Classroom 11	Manual	2/11/2026 2:49:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 11-14 Bldg Classroom 12	Manual	2/11/2026 2:49:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 11-14 Bldg Classroom 13	Manual	2/11/2026 2:49:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 11-14 Bldg Classroom 14	Manual	2/11/2026 2:48:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Rooms 11-14 Bldg Girls RR by Resource	Manual	2/11/2026 2:48:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 11-14 Bldg North Exterior	Manual	2/11/2026 2:49:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 11-14 Bldg North Exterior	Manual	2/11/2026 2:49:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Rooms 11-14 Bldg Resource Room	Manual	2/11/2026 2:48:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 11-14 Bldg South Exterior	Manual	2/11/2026 2:49:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 11-14 Bldg South Exterior	Manual	2/11/2026 2:49:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 11-14 Bldg Staff Room	Manual	2/11/2026 2:48:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Rooms 11-14 Bldg Staff Room Restroom	Manual	2/11/2026 2:48:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Rooms 11-14 Bldg Staff Room Restroom	Manual	2/11/2026 2:48:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible		Rooms 15-18 Bldg Classroom 15	Manual	2/11/2026 2:48:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 15-18 Bldg Classroom 16	Manual	2/11/2026 2:48:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 15-18 Bldg Classroom 17	Manual	2/11/2026 2:48:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 15-18 Bldg Classroom 18	Manual	2/11/2026 2:48:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 15-18 Bldg South Exterior	Manual	2/11/2026 2:48:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 15-18 Bldg South Exterior	Manual	2/11/2026 2:48:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 15-18 Bldg West Exterior	Manual	2/11/2026 2:48:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 3-6 Bldg Classroom 3	Manual	2/11/2026 2:49:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 3-6 Bldg Classroom 4	Manual	2/11/2026 2:49:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 3-6 Bldg Classroom 5	Manual	2/11/2026 2:49:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 3-6 Bldg Classroom 6	Manual	2/11/2026 2:49:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Rooms 3-6 Bldg Custodial Office	Manual	2/11/2026 2:49:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 3-6 Bldg South Exterior	Manual	2/11/2026 2:49:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Rooms 7-10 Bldg Boys RR by Rm 7	Manual	2/11/2026 2:49:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Rooms 7-10 Bldg Boys RR by Rm 7	Manual	2/11/2026 2:49:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 7-10 Bldg Classroom 10	Manual	2/11/2026 2:49:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 7-10 Bldg Classroom 7	Manual	2/11/2026 2:49:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 7-10 Bldg Classroom 8	Manual	2/11/2026 2:49:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 7-10 Bldg Classroom 9	Manual	2/11/2026 2:49:18 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Rooms 7-10 Bldg Girls RR by Rm 7	Manual	2/11/2026 2:49:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 7-10 Bldg South Exterior	Manual	2/11/2026 2:49:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 7-10 Bldg South Exterior	Manual	2/11/2026 2:49:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

### Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Remote Annunciator		Admin Building Office Reception	Manual	2/11/2026 4:27:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Multi-Purpose Bldg Stage Storage	Manual	2/11/2026 4:26:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Portables classroom 21	Manual	2/11/2026 4:26:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Portables Classroom 21	Manual	2/11/2026 4:23:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Portables classroom 25	Manual	2/11/2026 4:23:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Rms 1920 Library Cust Strge by Rm 20	Manual	2/11/2026 4:24:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Fire Alarm Panel		Rooms 3-6 Bldg Work Rm by Rm 3	Manual	2/11/2026 4:26:27 PM
		Manufacturer	Notifier	
		Model	NFS-3030	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Rooms 3-6 Bldg Work Rm by Rm 3	Manual	2/11/2026 4:26:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Rooms 3-6 Bldg Work Rm by Rm 3 P.E. C	Manual	2/11/2026 4:26:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

### Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-027 009	Admin Building File Room	Manual	2/11/2026 4:35:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-028 010	Admin Building File Room Restroom	Manual	2/11/2026 4:35:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Manual Pull Station	2-131 002	Admin Building Office Reception	Manual	2/11/2026 4:39:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-033 003	Admin Building Office Reception	Manual	2/11/2026 4:35:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-039 013	Admin Building Principal Closet	Manual	2/11/2026 4:38:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-029 008	Admin Building Principal Restroom	Manual	2/11/2026 4:37:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-030 007	Admin Building Principal Storage	Manual	2/11/2026 4:36:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-031 006	Admin Building Principals Office	Manual	2/11/2026 4:36:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-040 011	Admin Building Reception Closet	Manual	2/11/2026 4:39:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-039 012	Admin Building Secretary Closet	Manual	2/11/2026 4:39:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-034 004	Admin Building Secretary Office	Manual	2/11/2026 4:39:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-032 005	Admin Building Work Room	Manual	2/11/2026 4:35:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.387	Attic Portable Rm 27	Manual	2/11/2026 2:51:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.387	Attic Portable Rm 27	Manual	2/11/2026 2:51:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-157 207	Multi-Purpose Bldg Attic Kitchen	Manual	2/11/2026 3:29:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-048 204	Multi-Purpose Bldg Kitchen	Manual	2/11/2026 3:28:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-047 205	Multi-Purpose Bldg Kitchen	Manual	2/11/2026 3:28:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-046 206	Multi-Purpose Bldg Kitchen	Manual	2/11/2026 3:29:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-045 200	Multi-Purpose Bldg Kitchen Restroom	Manual	2/11/2026 3:34:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-044 201	Multi-Purpose Bldg Kitchen Restroom	Manual	2/11/2026 3:34:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Projected Beam	2-133 208	Multi-Purpose Bldg MP Room Left	Manual	2/11/2026 4:28:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-156 191	Multi-Purpose Bldg MP Room North	Manual	2/11/2026 3:36:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Projected Beam	2-150 209	Multi-Purpose Bldg MP Room Right	Manual	2/11/2026 4:28:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-155 193	Multi-Purpose Bldg MP Room SE	Manual	2/11/2026 3:37:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-154 192	Multi-Purpose Bldg MP Room SW	Manual	2/11/2026 3:38:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-037 196	Multi-Purpose Bldg Stage	Manual	2/11/2026 3:39:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-038 197	Multi-Purpose Bldg Stage	Manual	2/11/2026 3:39:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-152 195	Multi-Purpose Bldg Stage North	Manual	2/11/2026 3:42:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-036 198	Multi-Purpose Bldg Stage O/S Storage	Manual	2/11/2026 4:28:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-153 194	Multi-Purpose Bldg Stage South	Manual	2/11/2026 3:40:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-043 199	Multi-Purpose Bldg Storage	Manual	2/11/2026 3:43:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.315	Portable Rm 27	Manual	2/11/2026 2:52:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.314	Portable Rm 27	Manual	2/11/2026 2:53:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-377 169	Portables Attic Classroom 21	Manual	2/11/2026 3:24:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-377 170	Portables Attic Classroom 21	Manual	2/11/2026 3:25:01 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-378 171	Portables Attic Classroom 22	Manual	2/11/2026 3:20:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-378 172	Portables Attic Classroom 22	Manual	2/11/2026 3:20:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-379 173	Portables Attic Classroom 23	Manual	2/11/2026 3:30:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-379 174	Portables Attic Classroom 23	Manual	2/11/2026 3:30:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-380 176	Portables Attic Classroom 24	Manual	2/11/2026 3:10:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-380 175	Portables Attic Classroom 24	Manual	2/11/2026 3:10:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-386 180	Portables Attic Classroom 25	Manual	2/11/2026 3:01:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-386 179	Portables Attic Classroom 25	Manual	2/11/2026 3:01:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-385 178	Portables Attic Classroom 26	Manual	2/11/2026 2:56:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-385 177	Portables Attic Classroom 26	Manual	2/11/2026 2:56:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-291 157	Portables Classroom 21	Manual	2/11/2026 3:17:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-292 158	Portables Classroom 21	Manual	2/11/2026 3:17:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-293 159	Portables Classroom 22	Manual	2/11/2026 3:17:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-294 160	Portables Classroom 22	Manual	2/11/2026 3:17:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-295 161	Portables Classroom 23	Manual	2/11/2026 3:14:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-296 162	Portables Classroom 23	Manual	2/11/2026 3:14:23 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	2-304 164	Portables Classroom 24	Manual	2/11/2026 3:06:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-305 163	Portables Classroom 24	Manual	2/11/2026 3:11:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-312 168	Portables Classroom 25	Manual	2/11/2026 3:02:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-313 167	Portables Classroom 25	Manual	2/11/2026 3:02:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-310 166	Portables Classroom 26	Manual	2/11/2026 2:58:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-311 165	Portables Classroom 26	Manual	2/11/2026 2:58:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-314	Portables Classroom 27	Manual	2/11/2026 2:53:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-302 142	Rms 1920 Library Boys RR by Rm 20	Manual	2/11/2026 3:51:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-262 131	Rms 1920 Library Classroom 19	Manual	2/11/2026 3:55:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-269 132	Rms 1920 Library Classroom 19	Manual	2/11/2026 3:55:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-268 133	Rms 1920 Library Classroom 19	Manual	2/11/2026 3:55:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-261 134	Rms 1920 Library Classroom 20	Manual	2/11/2026 3:53:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-271 135	Rms 1920 Library Classroom 20	Manual	2/11/2026 3:54:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-270 136	Rms 1920 Library Classroom 20	Manual	2/11/2026 3:54:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-303 144	Rms 1920 Library Cust Strge by Rm 20	Manual	2/11/2026 3:52:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-301 143	Rms 1920 Library Girls RR by Rm 20	Manual	2/11/2026 3:52:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-264 137	Rms 1920 Library Library	Manual	2/11/2026 3:56:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-263 138	Rms 1920 Library Library	Manual	2/11/2026 3:57:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-267 139	Rms 1920 Library Library	Manual	2/11/2026 3:57:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-266 140	Rms 1920 Library Library	Manual	2/11/2026 3:57:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-265 141	Rms 1920 Library Library	Manual	2/11/2026 3:57:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-376 147	Rms 1920 Library Restroom Chase	Manual	2/11/2026 2:51:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-273 145	Rms 1920 Library Strg Behind Boys RR	Manual	2/11/2026 4:27:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-272 146	Rms 1920 Library Strg Behind Girls RR	Manual	2/11/2026 4:27:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-021 023	Room 1 2 Bldg Classroom 1	Manual	2/11/2026 4:27:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-023 025	Room 1 2 Bldg Classroom 1	Manual	2/11/2026 4:27:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-022 024	Room 1 2 Bldg Classroom 1	Manual	2/11/2026 4:27:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-020 026	Room 1 2 Bldg Classroom 1	Manual	2/11/2026 4:27:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-018 028	Room 1 2 Bldg Classroom 1 RR	Manual	2/11/2026 4:27:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-019 027	Room 1 2 Bldg Classroom 1 RR	Manual	2/11/2026 4:27:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-015 030	Room 1 2 Bldg Classroom 2	Manual	2/11/2026 4:30:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-025 031	Room 1 2 Bldg Classroom 2	Manual	2/11/2026 4:30:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-024 032	Room 1 2 Bldg Classroom 2	Manual	2/11/2026 4:30:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-016 029	Room 1 2 Bldg Classroom 2	Manual	2/11/2026 4:30:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-017 033	Room 1 2 Bldg Classroom 2 RR	Manual	2/11/2026 4:30:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-158 034	Room 1 2 Bldg Closet O/S Room 1	Manual	2/11/2026 2:51:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-277 084	Rooms 11-14 Bldg Classroom 11	Manual	2/11/2026 4:03:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-284 085	Rooms 11-14 Bldg Classroom 11	Manual	2/11/2026 4:04:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-278 086	Rooms 11-14 Bldg Classroom 12	Manual	2/11/2026 4:05:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-283 087	Rooms 11-14 Bldg Classroom 12	Manual	2/11/2026 4:05:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-279 088	Rooms 11-14 Bldg Classroom 13	Manual	2/11/2026 4:06:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-282 089	Rooms 11-14 Bldg Classroom 13	Manual	2/11/2026 4:06:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-280 090	Rooms 11-14 Bldg Classroom 14	Manual	2/11/2026 4:07:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-281 091	Rooms 11-14 Bldg Classroom 14	Manual	2/11/2026 4:07:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-287 098	Rooms 11-14 Bldg Girls RR by Resource	Manual	2/11/2026 3:59:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-275 096	Rooms 11-14 Bldg Resource Room	Manual	2/11/2026 4:00:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-289 097	Rooms 11-14 Bldg Resource Room	Manual	2/11/2026 4:00:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-276 092	Rooms 11-14 Bldg Staff Room	Manual	2/11/2026 4:02:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-288 093	Rooms 11-14 Bldg Staff Room	Manual	2/11/2026 4:02:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-286 094	Rooms 11-14 Bldg Staff Room Restroom	Manual	2/11/2026 4:02:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-285 095	Rooms 11-14 Bldg Staff Room Restroom	Manual	2/11/2026 4:03:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-300 113	Rooms 15-18 Bldg Classroom 15	Manual	2/11/2026 3:45:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-299 114	Rooms 15-18 Bldg Classroom 15	Manual	2/11/2026 3:46:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-258 112	Rooms 15-18 Bldg Classroom 15	Manual	2/11/2026 3:46:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-252 116	Rooms 15-18 Bldg Classroom 16	Manual	2/11/2026 3:46:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-253 115	Rooms 15-18 Bldg Classroom 16	Manual	2/11/2026 3:47:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-257 117	Rooms 15-18 Bldg Classroom 16	Manual	2/11/2026 3:47:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-259 118	Rooms 15-18 Bldg Classroom 17	Manual	2/11/2026 3:48:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-254 119	Rooms 15-18 Bldg Classroom 17	Manual	2/11/2026 3:48:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-256 120	Rooms 15-18 Bldg Classroom 17	Manual	2/11/2026 3:48:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-255 123	Rooms 15-18 Bldg Classroom 18	Manual	2/11/2026 3:48:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-298 122	Rooms 15-18 Bldg Classroom 18	Manual	2/11/2026 3:49:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-297 121	Rooms 15-18 Bldg Classroom 18	Manual	2/11/2026 3:49:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-004 041	Rooms 3-6 Bldg Classroom 3	Manual	2/11/2026 4:22:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-011 042	Rooms 3-6 Bldg Classroom 3	Manual	2/11/2026 4:23:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-005 043	Rooms 3-6 Bldg Classroom 4	Manual	2/11/2026 4:22:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-010 044	Rooms 3-6 Bldg Classroom 4	Manual	2/11/2026 4:22:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-006 045	Rooms 3-6 Bldg Classroom 5	Manual	2/11/2026 4:20:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-009 046	Rooms 3-6 Bldg Classroom 5	Manual	2/11/2026 4:21:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-007 047	Rooms 3-6 Bldg Classroom 6	Manual	2/11/2026 4:20:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-008 048	Rooms 3-6 Bldg Classroom 6	Manual	2/11/2026 4:20:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-012 050	Rooms 3-6 Bldg Custodial Office	Manual	2/11/2026 4:27:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-013 049	Rooms 3-6 Bldg Storage MPOE	Manual	2/11/2026 4:27:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-003 052	Rooms 3-6 Bldg Work Rm by Rm 3	Manual	2/11/2026 2:51:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-002 051	Rooms 3-6 Bldg Work Rm by Rm 3	Manual	2/11/2026 4:27:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-132 074	Rooms 7-10 Bldg Boys RestrM Chase	Manual	2/11/2026 2:51:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-061 070	Rooms 7-10 Bldg Boys RR by Rm 7	Manual	2/11/2026 4:17:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-060 069	Rooms 7-10 Bldg Boys RR by Rm 7	Manual	2/11/2026 4:18:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-055 068	Rooms 7-10 Bldg Classroom 10	Manual	2/11/2026 4:08:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-054 067	Rooms 7-10 Bldg Classroom 10	Manual	2/11/2026 4:08:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-058 062	Rooms 7-10 Bldg Classroom 7	Manual	2/11/2026 4:15:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-051 061	Rooms 7-10 Bldg Classroom 7	Manual	2/11/2026 4:16:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-057 064	Rooms 7-10 Bldg Classroom 8	Manual	2/11/2026 4:14:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-052 063	Rooms 7-10 Bldg Classroom 8	Manual	2/11/2026 4:14:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-056 066	Rooms 7-10 Bldg Classroom 9	Manual	2/11/2026 4:09:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-053 065	Rooms 7-10 Bldg Classroom 9	Manual	2/11/2026 4:10:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-062 072	Rooms 7-10 Bldg Cust Strge by Rm 7	Manual	2/11/2026 4:18:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-050 071	Rooms 7-10 Bldg Girls RR by Rm 7	Manual	2/11/2026 4:27:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-059 073	Rooms 7-10 Bldg Storage by Room 7	Manual	2/11/2026 4:17:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-064 202	Multi-Purpose Bldg Kitchen Closet	Manual	2/11/2026 4:27:03 PM
Smoke Detector - General	2-065 203	Multi-Purpose Bldg Kitchen Closet	Manual	2/11/2026 4:27:06 PM

## Device/Equipment details

### Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Audible					
014	Admin Building North Exterior				
015	Admin Building South Exterior				
035	Room 1 2 Bldg West Exterior				
053	Rooms 3-6 Bldg South Exterior				
075	Rooms 7-10 Bldg South Exterior				
076	Rooms 7-10 Bldg South Exterior				
099	Rooms 11-14 Bldg North Exterior				
100	Rooms 11-14 Bldg North Exterior				
101	Rooms 11-14 Bldg South Exterior				
102	Rooms 11-14 Bldg South Exterior				
124	Rooms 15-18 Bldg South Exterior				
125	Rooms 15-18 Bldg South Exterior				
126	Rooms 15-18 Bldg West Exterior				
148	Rms 1920 Library South Exterior				
149	Rms 1920 Library East Exterior				
150	Rms 1920 Library West Exterior				
181	Portables East Exterior				
182	Portables West Exterior				
210	Multi-Purpose Bldg North Exterior				
211	Multi-Purpose Bldg South Exterior				
Audible And Visible					
016	Admin Building Office Reception				
017	Admin Building Work Room				
036	Room 1 2 Bldg Classroom 1				
037	Room 1 2 Bldg Classroom 2				
054	Rooms 3-6 Bldg Classroom 3				
055	Rooms 3-6 Bldg Classroom 4				
056	Rooms 3-6 Bldg Classroom 5				
057	Rooms 3-6 Bldg Classroom 6				
077	Rooms 7-10 Bldg Classroom 7				
078	Rooms 7-10 Bldg Classroom 8				
079	Rooms 7-10 Bldg Classroom 9				
080	Rooms 7-10 Bldg Classroom 10				
103	Rooms 11-14 Bldg Classroom 11				
104	Rooms 11-14 Bldg Classroom 12				
105	Rooms 11-14 Bldg Classroom 13				
106	Rooms 11-14 Bldg Classroom 14				
107	Rooms 11-14 Bldg Staff Room				
127	Rooms 15-18 Bldg Classroom 15				
128	Rooms 15-18 Bldg Classroom 16				
129	Rooms 15-18 Bldg Classroom 17				
130	Rooms 15-18 Bldg Classroom 18				
151	Rms 1920 Library Classroom 19				
152	Rms 1920 Library Classroom 20				
153	Rms 1920 Library Library				
183	Portables Classroom 21				
184	Portables Classroom 22				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
185	Portables Classroom 23				
186	Portables Classroom 24				
187	Portables Classroom 25				
188	Portables Classroom 26				
212	Multi-Purpose Bldg MP Room				
213	Multi-Purpose Bldg Kitchen				
Visible					
018	Admin Building Secretary Office				
019	Admin Building Principals Office				
020	Admin Building Principal Restroom				
021	Admin Building File Room				
022	Admin Building File Room Restroom				
038	Room 1 2 Bldg Classroom 1 RR				
039	Room 1 2 Bldg Classroom 1 RR				
040	Room 1 2 Bldg Classroom 2 RR				
058	Rooms 3-6 Bldg Custodial Office				
081	Rooms 7-10 Bldg Boys RR by Rm 7				
082	Rooms 7-10 Bldg Boys RR by Rm 7				
083	Rooms 7-10 Bldg Girls RR by Rm 7				
108	Rooms 11-14 Bldg Staff Room Restroom				
109	Rooms 11-14 Bldg Staff Room Restroom				
110	Rooms 11-14 Bldg Resource Room				
111	Rooms 11-14 Bldg Girls RR by Resource				
154	Rms 1920 Library Boys RR by Rm 20				
155	Rms 1920 Library Girls RR by Rm 20				
214	Multi-Purpose Bldg MP Room				
215	Multi-Purpose Bldg Stage				
216	Multi-Purpose Bldg Kitchen				
217	Multi-Purpose Bldg Kitchen Restroom				
218	Multi-Purpose Bldg Kitchen Restroom				
<b>Fire Control Panel</b>					
ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Remote Annunciator					
001	Admin Building Office Reception				
Fire Alarm Panel					
059	Rooms 3-6 Bldg Work Rm by Rm 3	Notifier	NFS-3030		
NAC Power Extender Panel					
060	Rooms 3-6 Bldg Work Rm by Rm 3 P.E. C				
156	Rms 1920 Library Cust Strge by Rm 20				
189	Portables Classroom 21				
219	Multi-Purpose Bldg Stage Storage				
	Rooms 3-6 Bldg Work Rm by Rm 3				03/01/2019
	Portables classroom 25				03/01/2019
	Portables classroom 21				03/01/2019

## Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Manual Pull Station					
2-131 002	Admin Building Office Reception				
2-156 191	Multi-Purpose Bldg MP Room North				
2-154 192	Multi-Purpose Bldg MP Room SW				
2-155 193	Multi-Purpose Bldg MP Room SE				
2-153 194	Multi-Purpose Bldg Stage South				
2-152 195	Multi-Purpose Bldg Stage North				
Smoke Detector - General					
2-033 003	Admin Building Office Reception				
2-034 004	Admin Building Secretary Office				
2-032 005	Admin Building Work Room				
2-031 006	Admin Building Principals Office				
2-030 007	Admin Building Principal Storage				
2-029 008	Admin Building Principal Restroom				
2-027 009	Admin Building File Room				
2-028 010	Admin Building File Room Restroom				
2-040 011	Admin Building Reception Closet				
2-039 012	Admin Building Secretary Closet				
2-039 013	Admin Building Principal Closet				
2-021 023	Room 1 2 Bldg Classroom 1				
2-022 024	Room 1 2 Bldg Classroom 1				
2-023 025	Room 1 2 Bldg Classroom 1				
2-020 026	Room 1 2 Bldg Classroom 1				
2-019 027	Room 1 2 Bldg Classroom 1 RR				
2-018 028	Room 1 2 Bldg Classroom 1 RR				
2-016 029	Room 1 2 Bldg Classroom 2				
2-015 030	Room 1 2 Bldg Classroom 2				
2-025 031	Room 1 2 Bldg Classroom 2				
2-024 032	Room 1 2 Bldg Classroom 2				
2-017 033	Room 1 2 Bldg Classroom 2 RR				
2-004 041	Rooms 3-6 Bldg Classroom 3				
2-011 042	Rooms 3-6 Bldg Classroom 3				
2-005 043	Rooms 3-6 Bldg Classroom 4				
2-010 044	Rooms 3-6 Bldg Classroom 4				
2-006 045	Rooms 3-6 Bldg Classroom 5				
2-009 046	Rooms 3-6 Bldg Classroom 5				
2-007 047	Rooms 3-6 Bldg Classroom 6				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-008 048	Rooms 3-6 Bldg Classroom 6				
2-013 049	Rooms 3-6 Bldg Storage MPOE				
2-012 050	Rooms 3-6 Bldg Custodial Office				
2-002 051	Rooms 3-6 Bldg Work Rm by Rm 3				
2-051 061	Rooms 7-10 Bldg Classroom 7				
2-058 062	Rooms 7-10 Bldg Classroom 7				
2-052 063	Rooms 7-10 Bldg Classroom 8				
2-057 064	Rooms 7-10 Bldg Classroom 8				
2-053 065	Rooms 7-10 Bldg Classroom 9				
2-056 066	Rooms 7-10 Bldg Classroom 9				
2-054 067	Rooms 7-10 Bldg Classroom 10				
2-055 068	Rooms 7-10 Bldg Classroom 10				
2-060 069	Rooms 7-10 Bldg Boys RR by Rm 7				
2-061 070	Rooms 7-10 Bldg Boys RR by Rm 7				
2-050 071	Rooms 7-10 Bldg Girls RR by Rm 7				
2-062 072	Rooms 7-10 Bldg Cust Strge by Rm 7				
2-059 073	Rooms 7-10 Bldg Storage by Room 7				
2-277 084	Rooms 11-14 Bldg Classroom 11				
2-284 085	Rooms 11-14 Bldg Classroom 11				
2-278 086	Rooms 11-14 Bldg Classroom 12				
2-283 087	Rooms 11-14 Bldg Classroom 12				
2-279 088	Rooms 11-14 Bldg Classroom 13				
2-282 089	Rooms 11-14 Bldg Classroom 13				
2-280 090	Rooms 11-14 Bldg Classroom 14				
2-281 091	Rooms 11-14 Bldg Classroom 14				
2-276 092	Rooms 11-14 Bldg Staff Room				
2-288 093	Rooms 11-14 Bldg Staff Room				
2-286 094	Rooms 11-14 Bldg Staff Room Restroom				
2-285 095	Rooms 11-14 Bldg Staff Room Restroom				
2-275 096	Rooms 11-14 Bldg Resource Room				
2-289 097	Rooms 11-14 Bldg Resource Room				
2-287 098	Rooms 11-14 Bldg Girls RR by Resource				
2-258 112	Rooms 15-18 Bldg Classroom 15				
2-300 113	Rooms 15-18 Bldg Classroom 15				
2-299 114	Rooms 15-18 Bldg Classroom 15				
2-253 115	Rooms 15-18 Bldg Classroom 16				
2-252 116	Rooms 15-18 Bldg Classroom 16				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-257 117	Rooms 15-18 Bldg Classroom 16				
2-259 118	Rooms 15-18 Bldg Classroom 17				
2-254 119	Rooms 15-18 Bldg Classroom 17				
2-256 120	Rooms 15-18 Bldg Classroom 17				
2-297 121	Rooms 15-18 Bldg Classroom 18				
2-298 122	Rooms 15-18 Bldg Classroom 18				
2-255 123	Rooms 15-18 Bldg Classroom 18				
2-262 131	Rms 1920 Library Classroom 19				
2-269 132	Rms 1920 Library Classroom 19				
2-268 133	Rms 1920 Library Classroom 19				
2-261 134	Rms 1920 Library Classroom 20				
2-271 135	Rms 1920 Library Classroom 20				
2-270 136	Rms 1920 Library Classroom 20				
2-264 137	Rms 1920 Library Library				
2-263 138	Rms 1920 Library Library				
2-267 139	Rms 1920 Library Library				
2-266 140	Rms 1920 Library Library				
2-265 141	Rms 1920 Library Library				
2-302 142	Rms 1920 Library Boys RR by Rm 20				
2-301 143	Rms 1920 Library Girls RR by Rm 20				
2-303 144	Rms 1920 Library Cust Strge by Rm 20				
2-273 145	Rms 1920 Library Strg Behind Boys RR				
2-272 146	Rms 1920 Library Strg Behind Girls RR				
2-291 157	Portables Classroom 21				
2-292 158	Portables Classroom 21				
2-293 159	Portables Classroom 22				
2-294 160	Portables Classroom 22				
2-295 161	Portables Classroom 23				
2-296 162	Portables Classroom 23				
2-305 163	Portables Classroom 24				
2-304 164	Portables Classroom 24				
2-311 165	Portables Classroom 26				
2-310 166	Portables Classroom 26				
2-313 167	Portables Classroom 25				
2-312 168	Portables Classroom 25				
2-037 196	Multi-Purpose Bldg Stage				
2-038 197	Multi-Purpose Bldg Stage				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-036 198	Multi-Purpose Bldg Stage O/S Storage				
2-043 199	Multi-Purpose Bldg Storage				
2-045 200	Multi-Purpose Bldg Kitchen Restroom				
2-044 201	Multi-Purpose Bldg Kitchen Restroom				
2-064 202	Multi-Purpose Bldg Kitchen Closet				
2-065 203	Multi-Purpose Bldg Kitchen Closet				
2.314	Portable Rm 27				
2.315	Portable Rm 27				
2-314	Portables Classroom 27				11/16/2023
Heat Detector - Restorable Spot					
2-158 034	Room 1 2 Bldg Closet O/S Room 1				
2-003 052	Rooms 3-6 Bldg Work Rm by Rm 3				
2-132 074	Rooms 7-10 Bldg Boys Restrm Chase				
2-376 147	Rms 1920 Library Restroom Chase				
2-377 169	Portables Attic Classroom 21				
2-377 170	Portables Attic Classroom 21				
2-378 171	Portables Attic Classroom 22				
2-378 172	Portables Attic Classroom 22				
2-379 173	Portables Attic Classroom 23				
2-379 174	Portables Attic Classroom 23				
2-380 175	Portables Attic Classroom 24				
2-380 176	Portables Attic Classroom 24				
2-385 177	Portables Attic Classroom 26				
2-385 178	Portables Attic Classroom 26				
2-386 179	Portables Attic Classroom 25				
2-386 180	Portables Attic Classroom 25				
2-048 204	Multi-Purpose Bldg Kitchen				
2-047 205	Multi-Purpose Bldg Kitchen				
2-046 206	Multi-Purpose Bldg Kitchen				
2-157 207	Multi-Purpose Bldg Attic Kitchen				
2.387	Attic Portable Rm 27				
2.387	Attic Portable Rm 27				
Smoke Detector - Projected Beam					
2-133 208	Multi-Purpose Bldg MP Room Left				
2-150 209	Multi-Purpose Bldg MP Room Right				