

Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

SAN JUAN HIGH

7551 GREENBACK LANE
CITRUS HEIGHT, California
United States

This site has been inspected and tested in compliance with applicable standards.

Completed
Wednesday, February 11, 2026

Test Session:112425 RJ6615 AFA

Test Plans :Fire Alarm - Annual

ACCEPTED BY

SAN JUAN USD
5320 HEMLOCK ST
SACRAMENTO, California
United States

TESTED BY

Riley Goyet
Western States Fire Protection-
Sacramento
188 Cirby Way
Roseville, CA 95678
United States



Inspection Summary

Building Information

PROPERTY	SAN JUAN HIGH	CONTACT
ADDRESS	7551 GREENBACK LANE	PHONE
CITY/STATE	CITRUS HEIGHT, California	MOBILE
COUNTRY	United States	EMAIL

Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us

Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Alarm Notification Appliance	307	307(100%)	307(100%)	0(0%)
Fire Control Panel	9	9(100%)	4(44%)	5(56%)
Initiating Device	766	761(99%)	761(99%)	0(0%)

Certification

The equipment specified herein was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Wednesday, February 11, 2026

ACCEPTED BY 02/11/2026

Building Representative


TESTED BY 02/11/2026
Riley Goyet
Technician

System Details

Control Units

ADDRESS/ SCAN ADDRESS		DESCRIPTION	Main Fire Panel MDF Room
MANUFACTURER	Notifier	S/W VERSION	
MODEL	NFS-3030	LAST UPDATE	
SERIAL NUMBER		S/W LOCATION	
INSTALL DATE	03/12/2020		

ADDRESS/ SCAN ADDRESS		DESCRIPTION	C Wing Fire Panel Room
MANUFACTURER	Notifier	S/W VERSION	
MODEL	NFS-3030	LAST UPDATE	
SERIAL NUMBER		S/W LOCATION	
INSTALL DATE	03/12/2020		

Open Corrective Action & Solution Summary

The following 9 corrective action(s) remain open following the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
Heat Detector - Restorable Spot	4-384 254	B Wing Attic Portable B13
	Created By:	
	Creation Date:	02/26/2019
	Corrective Action:	Say E-13 on Panel should say B-13
	Proposed Solution:	
	Manufacturer:	
	Model:	
Heat Detector - Restorable Spot	4-384 255	B Wing Attic Portable B13
	Created By:	
	Creation Date:	02/26/2019
	Corrective Action:	E-13 on Panel should say B-13
	Proposed Solution:	
	Manufacturer:	
	Model:	
Heat Detector - Restorable Spot	4-384 256	B Wing Attic Portable B13
	Created By:	
	Creation Date:	02/26/2019
	Corrective Action:	Say E-13 on Panel should say B-13
	Proposed Solution:	
	Manufacturer:	
	Model:	
Heat Detector - Restorable Spot	4-384 257	B Wing Attic Portable B13
	Created By:	
	Creation Date:	02/26/2019
	Corrective Action:	Say E-13 on Panel should say B-13
	Proposed Solution:	
	Manufacturer:	
	Model:	
NAC Power Extender Panel	BPS H	
	Created By:	Riley Goyet
	Creation Date:	01/19/2023
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
NAC Power Extender Panel	BPS N	
	Created By:	Riley Goyet
	Creation Date:	01/19/2023
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
NAC Power Extender Panel	BPS T	
	Created By:	Riley Goyet
	Creation Date:	01/19/2023
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
----------------	---------	-------------

NAC Power Extender Panel	BPS R	
	Created By:	Riley Goyet
	Creation Date:	01/19/2023
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	

NAC Power Extender Panel	BPS P	
	Created By:	Riley Goyet
	Creation Date:	01/19/2023
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	

Testing Details

Alarm Notification Appliance

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible		A Wing Admin Hallway	Manual	12/3/2025 4:03:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		A Wing Admin Hallway	Manual	12/3/2025 4:03:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		A Wing Admin Hallway	Manual	12/3/2025 3:58:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		A Wing Admin Offices	Manual	12/3/2025 4:02:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		A Wing Admin Offices	Manual	12/3/2025 4:02:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		A Wing Admin Offices	Manual	12/3/2025 4:02:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		A Wing Admin Offices	Manual	12/3/2025 4:02:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		A Wing Admin Offices	Manual	12/3/2025 4:02:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		A Wing Admin Offices	Manual	12/3/2025 3:58:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		A Wing Admin Offices	Manual	12/3/2025 3:58:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		A Wing Admin Offices	Manual	12/3/2025 3:58:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		A Wing Admin Offices	Manual	12/3/2025 3:58:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		A Wing Admin Offices	Manual	12/3/2025 3:58:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		A Wing Admin Offices	Manual	12/3/2025 3:58:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		A Wing Admin Offices	Manual	12/3/2025 3:58:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		A Wing Admin Offices	Manual	12/3/2025 3:58:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		A Wing Admin Offices	Manual	12/3/2025 3:58:24 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		A Wing Computer Lab	Manual	12/3/2025 4:02:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		A Wing East Exterior	Manual	12/3/2025 4:04:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		A Wing East Exterior	Manual	12/3/2025 4:04:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		A Wing East Exterior	Manual	12/3/2025 4:04:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		A Wing East Exterior	Manual	12/3/2025 4:04:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		A Wing Library	Manual	12/3/2025 4:02:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		A Wing Library	Manual	12/3/2025 4:02:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		A Wing Library Storage	Manual	12/3/2025 3:58:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		A Wing Lower A Wing Hall	Manual	12/3/2025 4:02:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		A Wing Lower A Wing Hall	Manual	12/3/2025 4:02:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		A Wing Lower A Wing Hall	Manual	12/3/2025 3:58:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		A Wing Media Classroom A5	Manual	12/3/2025 4:02:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		A Wing Media Classroom A6	Manual	12/3/2025 4:02:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		A Wing Media Classroom A7	Manual	12/3/2025 4:02:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		A Wing Media Classroom A8	Manual	12/3/2025 4:02:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		A Wing Media Control A9A	Manual	12/3/2025 4:02:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		A Wing Media Dress Rm A12	Manual	12/3/2025 4:02:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		A Wing Media Dress Rm A13	Manual	12/3/2025 4:02:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible		A Wing Media Dress RR A12	Manual	12/3/2025 3:57:59 PM
		Visual inspection	Passed (Manual)	
Visible		Functional Inspection	Passed	
		A Wing Media Dress RR A13	Manual	12/3/2025 3:57:58 PM
Visible		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		A Wing Media Staff RR A14	Manual	12/3/2025 3:58:02 PM
		Visual inspection	Passed (Manual)	
Audible And Visible		Functional Inspection	Passed	
		A Wing Media Studio Rm A9	Manual	12/3/2025 4:02:12 PM
Visible		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		A Wing Media Vestible Rm A9	Manual	12/3/2025 3:58:05 PM
		Visual inspection	Passed (Manual)	
Visible		Functional Inspection	Passed	
		A Wing Men RR Admin N Hall	Manual	12/3/2025 3:58:15 PM
Audible		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		A Wing North Exterior	Manual	12/3/2025 3:55:31 PM
		Visual inspection	Passed (Manual)	
Audible		Functional Inspection	Passed	
		A Wing North Exterior	Manual	12/3/2025 4:04:24 PM
Audible And Visible		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		A Wing PA Backstage	Manual	12/3/2025 4:02:35 PM
		Visual inspection	Passed (Manual)	
Audible And Visible		Functional Inspection	Passed	
		A Wing PA Lobby	Manual	12/3/2025 4:02:44 PM
Audible And Visible		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		A Wing PA Seating Area	Manual	12/3/2025 4:02:29 PM
		Visual inspection	Passed (Manual)	
Audible And Visible		Functional Inspection	Passed	
		A Wing PA Seating Area	Manual	12/3/2025 4:02:30 PM
Audible And Visible		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		A Wing PA Seating Area	Manual	12/3/2025 4:02:36 PM
		Visual inspection	Passed (Manual)	
Audible And Visible		Functional Inspection	Passed	
		A Wing PA Seating Area	Manual	12/3/2025 4:02:38 PM
Audible And Visible		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		A Wing PA Seating Area	Manual	12/3/2025 4:02:39 PM
		Visual inspection	Passed (Manual)	
Audible And Visible		Functional Inspection	Passed	
		A Wing PA Seating Area	Manual	12/3/2025 4:02:41 PM
Audible And Visible		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		A Wing PA Seating NE Entr	Manual	12/3/2025 4:02:45 PM
		Visual inspection	Passed (Manual)	
Audible And Visible		Functional Inspection	Passed	
		A Wing PA Seating SE Entr	Manual	12/3/2025 4:02:47 PM
Audible And Visible		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		A Wing PA Stage	Manual	12/3/2025 4:02:32 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		A Wing PA Stage	Manual	12/3/2025 4:02:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		A Wing PA Stage	Manual	12/3/2025 3:57:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		A Wing PA Steps North	Manual	12/3/2025 3:58:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		A Wing Room A3	Manual	12/3/2025 4:02:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		A Wing South Exterior	Manual	12/3/2025 4:04:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		A Wing South Exterior	Manual	12/3/2025 4:04:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		A Wing South Exterior	Manual	12/3/2025 4:04:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		A Wing Upper A Wing Hall	Manual	12/3/2025 4:03:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		A Wing Upper A Wing Hall	Manual	12/3/2025 4:03:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		A Wing Upper A Wing Hall	Manual	12/3/2025 4:03:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		A Wing Upper A Wing Hall	Manual	12/3/2025 4:03:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		A Wing West Exterior	Manual	12/3/2025 4:04:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		A Wing West Exterior	Manual	12/3/2025 4:04:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		A Wing Womens RR Admin N	Manual	12/3/2025 3:58:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		B Wing B Wing Hallway	Manual	12/3/2025 4:02:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		B Wing B Wing Hallway	Manual	12/3/2025 4:02:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		B Wing B Wing Hallway	Manual	12/3/2025 4:02:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		B Wing B Wing Hallway	Manual	12/3/2025 4:02:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible		B Wing B Wing Hallway	Manual	12/3/2025 4:02:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		B Wing East Exterior	Manual	12/3/2025 4:04:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		B Wing East Exterior	Manual	12/3/2025 4:04:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		B Wing Room B10	Manual	12/3/2025 4:01:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		B Wing Room B11	Manual	12/3/2025 4:01:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		B Wing Room B12	Manual	12/3/2025 4:02:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		B Wing Room B3	Manual	12/3/2025 4:02:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		B Wing Room B4	Manual	12/3/2025 4:01:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		B Wing Room B5	Manual	12/3/2025 4:01:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		B Wing Room B5	Manual	12/3/2025 3:57:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		B Wing Room B6	Manual	12/3/2025 4:01:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		B Wing Room B7	Manual	12/3/2025 4:01:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		B Wing Room B8	Manual	12/3/2025 4:01:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		B Wing Room B9	Manual	12/3/2025 4:01:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		B Wing Science Portble B13	Manual	12/3/2025 4:01:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		B Wing Womens Facilit RR	Manual	12/3/2025 3:58:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		B Wing Womens Facilities	Manual	12/3/2025 4:02:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		B Wing Womens Facilities	Manual	12/3/2025 3:58:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		C Wing Admin Breakroom	Manual	12/3/2025 4:01:35 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		C Wing Admin Breakroom	Manual	12/3/2025 4:01:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		C Wing Admin Breakroom	Manual	12/3/2025 3:57:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		C Wing Admin Breakroom	Manual	12/3/2025 3:57:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		C Wing Admin Hallway	Manual	12/3/2025 3:57:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		C Wing Admin Mens RR	Manual	12/3/2025 3:57:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		C Wing Admin Womens RR	Manual	12/3/2025 3:57:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		C Wing C Wing Hallway	Manual	12/3/2025 4:01:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		C Wing C Wing Hallway	Manual	12/3/2025 4:01:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		C Wing C Wing Hallway	Manual	12/3/2025 4:01:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		C Wing North Exterior	Manual	12/3/2025 4:04:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		C Wing Room C1	Manual	12/3/2025 4:01:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		C Wing Room C3	Manual	12/3/2025 4:01:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		C Wing Room C4	Manual	12/3/2025 4:01:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		C Wing Room C4	Manual	12/3/2025 3:57:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		C Wing Room C5	Manual	12/3/2025 4:01:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Cafeteria Alumni Room	Manual	12/3/2025 3:58:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Cafeteria Alumni Room	Manual	12/3/2025 3:55:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Cafeteria Kitchen	Manual	12/3/2025 3:58:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible		Cafeteria Kitchen	Manual	12/3/2025 3:58:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Cafeteria Kitchen	Manual	12/3/2025 3:58:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Cafeteria Kitchen	Manual	12/3/2025 3:58:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Cafeteria Kitchen	Manual	12/3/2025 3:58:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Cafeteria Kitchen	Manual	12/3/2025 3:55:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Cafeteria Kitchen Restroom	Manual	12/3/2025 3:56:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Cafeteria North Exterior	Manual	12/3/2025 4:03:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Cafeteria Room	Manual	12/3/2025 3:58:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Cafeteria Room	Manual	12/3/2025 3:58:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Cafeteria Room	Manual	12/3/2025 3:58:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Cafeteria Room	Manual	12/3/2025 3:58:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Cafeteria Snack Bar	Manual	12/3/2025 3:55:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Cafeteria South Exterior	Manual	12/3/2025 4:03:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		D Wing East Exterior	Manual	12/3/2025 4:04:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		D Wing Lower D Wing Hall	Manual	12/3/2025 4:01:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		D Wing Lower D Wing Hall	Manual	12/3/2025 4:01:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		D Wing Lower D Wing Hall	Manual	12/3/2025 4:01:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		D Wing Mens Restroom	Manual	12/3/2025 3:57:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		D Wing Room D1	Manual	12/3/2025 4:01:26 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		D Wing Room D10	Manual	12/3/2025 4:01:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		D Wing Room D11	Manual	12/3/2025 4:01:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		D Wing Room D12	Manual	12/3/2025 4:01:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		D Wing Room D13	Manual	12/3/2025 4:01:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		D Wing Room D14	Manual	12/3/2025 4:00:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		D Wing Room D15	Manual	12/3/2025 4:00:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		D Wing Room D16	Manual	12/3/2025 4:00:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		D Wing Room D17	Manual	12/3/2025 4:00:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		D Wing Room D18	Manual	12/3/2025 4:00:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		D Wing Room D19	Manual	12/3/2025 4:00:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		D Wing Room D2	Manual	12/3/2025 4:01:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		D Wing Room D2	Manual	12/3/2025 3:57:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		D Wing Room D2	Manual	12/3/2025 3:57:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		D Wing Room D20	Manual	12/3/2025 4:00:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		D Wing Room D3	Manual	12/3/2025 4:01:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		D Wing Room D4	Manual	12/3/2025 4:01:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		D Wing Room D5	Manual	12/3/2025 4:01:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		D Wing Room D6	Manual	12/3/2025 4:01:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible		D Wing Room D7	Manual	12/3/2025 4:01:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		D Wing Room D8	Manual	12/3/2025 4:01:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		D Wing Room D9	Manual	12/3/2025 4:01:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		D Wing Upper D Wing Hall	Manual	12/3/2025 4:01:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		D Wing Upper D Wing Hall	Manual	12/3/2025 4:01:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		D Wing Upper D Wing Hall	Manual	12/3/2025 4:01:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		D Wing West Exterior	Manual	12/3/2025 4:04:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		D Wing Womens Restroom	Manual	12/3/2025 3:57:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		E Wing Custodial Office	Manual	12/3/2025 3:57:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		E Wing E Wing Hallway	Manual	12/3/2025 4:00:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		E Wing E Wing Hallway	Manual	12/3/2025 4:00:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		E Wing E1 Dark Room	Manual	12/3/2025 3:57:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		E Wing E1 Photo Classroom	Manual	12/3/2025 4:00:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		E Wing E1A MDF Room	Manual	12/3/2025 4:00:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		E Wing East Exterior	Manual	12/3/2025 4:04:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		E Wing Room E2	Manual	12/3/2025 4:00:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		E Wing Room E3	Manual	12/3/2025 4:00:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		E Wing Room E4	Manual	12/3/2025 4:00:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		E Wing Room E5	Manual	12/3/2025 4:00:38 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		E Wing Room E6	Manual	12/3/2025 4:00:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		E Wing West Exterior	Manual	12/3/2025 4:04:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		F Wing Room F1	Manual	12/3/2025 4:00:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		F Wing Room F2	Manual	12/3/2025 4:00:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		F Wing Room F3	Manual	12/3/2025 4:00:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		F Wing Room F4	Manual	12/3/2025 4:00:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		F Wing Room F5	Manual	12/3/2025 4:00:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		F Wing South Exterior	Manual	12/3/2025 4:03:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		G Wing Restroom	Manual	12/3/2025 3:57:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		G Wing Room G1	Manual	12/3/2025 4:00:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		G Wing Room G2	Manual	12/3/2025 4:00:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		G Wing Room G2	Manual	12/3/2025 3:57:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		G Wing Room G3	Manual	12/3/2025 4:00:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		G Wing Room G4	Manual	12/3/2025 4:00:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		G Wing Room G5	Manual	12/3/2025 4:00:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		G Wing Room G6	Manual	12/3/2025 4:00:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		G Wing South Exterior	Manual	12/3/2025 4:03:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		H Wing Auto Room H1	Manual	12/3/2025 4:00:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible		H Wing Auto Room H1	Manual	12/3/2025 4:00:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		H Wing Auto Room H1	Manual	12/3/2025 4:00:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		H Wing Auto Room H1	Manual	12/3/2025 3:57:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		H Wing Auto Room H1	Manual	12/3/2025 3:57:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		H Wing East Exterior	Manual	12/3/2025 4:03:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		H Wing East Exterior	Manual	12/3/2025 4:03:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		H Wing East Exterior	Manual	12/3/2025 4:03:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		H Wing H1 Bldg/SW Exterior	Manual	12/3/2025 4:03:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		H Wing H2-H10 Bldg/SW Ext	Manual	12/3/2025 4:03:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		H Wing H4 Mens Restroom	Manual	12/3/2025 3:57:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		H Wing H6 Womens Restrm	Manual	12/3/2025 3:57:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		H Wing North Exterior	Manual	12/3/2025 4:03:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		H Wing North Exterior	Manual	12/3/2025 4:03:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		H Wing Room H1C	Manual	12/3/2025 4:00:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		H Wing Room H2	Manual	12/3/2025 4:00:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		H Wing Room H2A	Manual	12/3/2025 3:57:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		H Wing Room H3	Manual	12/3/2025 4:00:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		H Wing Room H5	Manual	12/3/2025 4:00:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		H Wing Room H5	Manual	12/3/2025 4:00:11 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		H Wing Room H5A	Manual	12/3/2025 3:57:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		H Wing Room H5C	Manual	12/3/2025 4:00:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		H Wing Room H7	Manual	12/3/2025 4:00:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		H Wing Room H8	Manual	12/3/2025 3:59:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		H Wing Room H8	Manual	12/3/2025 3:59:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		H Wing Room H8A	Manual	12/3/2025 3:57:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		H Wing Room H9	Manual	12/3/2025 3:59:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		H Wing South Exterior	Manual	12/3/2025 4:03:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		H Wing West Exterior	Manual	12/3/2025 4:03:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		H Wing West Exterior	Manual	12/3/2025 4:03:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		H Wing West Exterior	Manual	12/3/2025 4:03:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		I Wing Boys Restroom	Manual	12/3/2025 3:57:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		I Wing East Exterior	Manual	12/3/2025 4:03:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		I Wing Girls Restroom	Manual	12/3/2025 3:57:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		I Wing I-1 Conference Room	Manual	12/3/2025 3:59:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		I Wing Room I-1	Manual	12/3/2025 3:59:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		I Wing Room I-1 Office	Manual	12/3/2025 3:57:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		I Wing Room I-2	Manual	12/3/2025 3:57:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible		I Wing Room I-3	Manual	12/3/2025 3:59:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		I Wing Room I-4	Manual	12/3/2025 3:57:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		I Wing West Exterior	Manual	12/3/2025 4:03:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		J Wing East Exterior	Manual	12/3/2025 4:03:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		J Wing North Exterior	Manual	12/3/2025 4:03:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	3-171 817	J Wing O/S Riser Rm J12	Manual	12/3/2025 4:03:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		J Wing Room J1	Manual	12/3/2025 3:59:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		J Wing Room J1	Manual	12/3/2025 3:57:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		J Wing Room J11	Manual	12/3/2025 3:56:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		J Wing Room J11A	Manual	12/3/2025 3:56:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		J Wing Room J1A	Manual	12/3/2025 3:57:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		J Wing Room J1B	Manual	12/3/2025 3:57:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		J Wing Room J1C	Manual	12/3/2025 3:57:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		J Wing Room J1D	Manual	12/3/2025 3:57:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		J Wing Room J4	Manual	12/3/2025 3:59:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		J Wing Room J4	Manual	12/3/2025 3:57:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		J Wing Room J4	Manual	12/3/2025 3:57:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		J Wing Room J4	Manual	12/3/2025 3:57:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		J Wing Room J4A	Manual	12/3/2025 3:57:00 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		J Wing Room J5	Manual	12/3/2025 4:00:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		J Wing Room J5	Manual	12/3/2025 3:57:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		J Wing Room J5A	Manual	12/3/2025 3:59:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		J Wing Room J6	Manual	12/3/2025 3:59:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		J Wing Room J6A	Manual	12/3/2025 3:56:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		J Wing Room J7	Manual	12/3/2025 3:59:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		J Wing Room J7A	Manual	12/3/2025 3:59:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		J Wing Room J8	Manual	12/3/2025 3:59:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		J Wing Room J8	Manual	12/3/2025 3:56:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		J Wing Room J9	Manual	12/3/2025 3:59:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		J Wing Room J9A	Manual	12/3/2025 3:56:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		J Wing South Exterior	Manual	12/3/2025 4:03:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		J Wing West Exterior	Manual	12/3/2025 4:03:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Large Gym Basketball Court	Manual	12/3/2025 3:58:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Large Gym Basketball Court	Manual	12/3/2025 3:58:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Large Gym Basketball Court	Manual	12/3/2025 3:58:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Large Gym Basketball Court	Manual	12/3/2025 3:58:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Large Gym Boys Locker Room	Manual	12/3/2025 3:58:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible		Large Gym Boys Locker Room	Manual	12/3/2025 3:58:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Large Gym Boys Locker Room	Manual	12/3/2025 3:59:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Large Gym Boys Locker Room	Manual	12/3/2025 3:59:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Large Gym Boys Locker Room	Manual	12/3/2025 3:56:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Large Gym Boys Locker Room	Manual	12/3/2025 3:56:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Large Gym Boys Locker Room	Manual	12/3/2025 3:56:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Large Gym Boys Restroom	Manual	12/3/2025 3:56:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Large Gym East Exterior	Manual	12/3/2025 4:03:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Large Gym Front Entrance	Manual	12/3/2025 3:59:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Large Gym Front Entrance	Manual	12/3/2025 3:59:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Large Gym Girls Restroom	Manual	12/3/2025 3:56:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Large Gym North Exterior	Manual	12/3/2025 4:03:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Large Gym Southeast Exit	Manual	12/3/2025 3:58:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Large Gym Southwest Exit	Manual	12/3/2025 3:58:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Large Gym West Exterior	Manual	12/3/2025 4:03:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Nursery Buildings North Exterior	Manual	12/3/2025 4:03:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Nursery Buildings Nursery N1	Manual	12/3/2025 3:59:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Nursery Buildings Nursery N1 Adult RR	Manual	12/3/2025 3:56:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Nursery Buildings Nursery N1 Kids RR	Manual	12/3/2025 3:56:58 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Nursery Buildings Nursery N1 Kitchen	Manual	12/3/2025 3:56:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Nursery Buildings Nursery N1 Office	Manual	12/3/2025 3:56:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Nursery Buildings Nursery N2	Manual	12/3/2025 3:59:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Nursery Buildings Upper Nursery	Manual	12/3/2025 3:59:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Nursery Buildings Upper Nursery Closet	Manual	12/3/2025 3:56:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Nursery Buildings Upper Nursery RR	Manual	12/3/2025 3:56:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Nursery Buildings West Exterior	Manual	12/3/2025 4:03:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Small Gym Basketball Court	Manual	12/3/2025 3:59:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Small Gym Basketball Court	Manual	12/3/2025 3:59:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Small Gym Basketball Court	Manual	12/3/2025 3:59:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Small Gym Basketball Court	Manual	12/3/2025 3:59:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Small Gym East Girls Locker	Manual	12/3/2025 3:59:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Small Gym East Girls Locker	Manual	12/3/2025 3:59:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Small Gym East Girls Locker	Manual	12/3/2025 3:59:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Small Gym East Girls Locker	Manual	12/3/2025 3:56:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Small Gym East Girls Locker	Manual	12/3/2025 3:56:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Small Gym East Girls Locker	Manual	12/3/2025 3:56:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Small Gym Hallway	Manual	12/3/2025 3:59:15 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Audible And Visible		Small Gym Hallway	Manual	12/3/2025 3:59:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Small Gym Hallway NE Exit	Manual	12/3/2025 3:59:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Small Gym Hallway NW Exit	Manual	12/3/2025 3:59:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Small Gym North Exterior	Manual	12/3/2025 4:03:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Small Gym North Exterior	Manual	12/3/2025 4:03:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Small Gym West Girls Locker	Manual	12/3/2025 3:59:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Small Gym West Girls Locker	Manual	12/3/2025 3:59:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Small Gym West Girls Locker	Manual	12/3/2025 3:59:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Small Gym West Girls Locker	Manual	12/3/2025 3:59:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Small Gym West Girls Locker	Manual	12/3/2025 3:56:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Small Gym West Girls Locker	Manual	12/3/2025 3:56:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Weight Room East Interior Wall	Manual	12/3/2025 3:58:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Weight Room East Interior Wall	Manual	12/3/2025 3:58:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
NAC Power Extender Panel	BPS C		Manual	11/26/2025 10:25:54 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Remote Annunciator		A Wing Reception	Manual	11/26/2025 1:49:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Fire Alarm Panel		C Wing Fire Panel Room	Manual	11/26/2025 10:25:17 AM
		Manufacturer	Notifier	
		Model	NFS-3030	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Alarm Verification Timer (s)	30_seconds	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Fire Alarm Panel		Main Fire Panel MDF Room	Manual	11/26/2025 10:25:16 AM
		Manufacturer	Notifier	
		Model	NFS-3030	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Failed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
NAC Power Extender Panel	BPS T		Manual	11/25/2025 11:34:17 AM
		Visual inspection	Failed (Manual)	
NAC Power Extender Panel	BPS R		Manual	11/25/2025 11:34:24 AM
		Visual inspection	Failed (Manual)	
NAC Power Extender Panel	BPS P		Manual	11/25/2025 11:34:29 AM
		Visual inspection	Failed (Manual)	
NAC Power Extender Panel	BPS N		Manual	11/25/2025 11:34:33 AM
		Visual inspection	Failed (Manual)	
NAC Power Extender Panel	BPS H		Manual	11/25/2025 11:34:38 AM
		Visual inspection	Failed (Manual)	

Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - Duct	2-141 118	A Wing Admin Hallway	Manual	11/26/2025 1:49:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-040 035	A Wing Admin North Hallway	Manual	11/25/2025 6:42:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-029 010	A Wing Attendance A1A	Manual	11/25/2025 6:35:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-027 020	A Wing Attendance Hall A1i	Manual	11/25/2025 6:34:39 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-030 009	A Wing Attendance Hall A1i	Manual	11/25/2025 6:35:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-376 117	A Wing Attic Library	Manual	11/26/2025 1:49:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-378 109	A Wing Attic Room A5	Manual	11/25/2025 11:31:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-378 108	A Wing Attic Room A5	Manual	11/26/2025 1:49:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-381 110	A Wing Attic Room A6	Manual	11/26/2025 1:49:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-381 111	A Wing Attic Room A6	Manual	11/26/2025 1:49:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-383 112	A Wing Attic Room A7	Manual	11/26/2025 6:05:22 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-383 113	A Wing Attic Room A7	Manual	11/26/2025 6:05:25 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-376 115	A Wing Attic Room A8	Manual	11/26/2025 1:49:19 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-376 114	A Wing Attic Room A8	Manual	11/26/2025 1:49:21 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-389 116	A Wing Attic Studio Room A9	Manual	11/26/2025 1:49:22 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-047 105	A Wing Auditorium Hallway	Manual	11/25/2025 11:32:19 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-049	A Wing Auditorium Hallway	Manual	11/25/2025 11:32:21 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Manual Pull Station	4-002	A Wing Computer Lab	Manual	11/26/2025 6:10:18 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Manual Pull Station	4-134 008	A Wing Computer Lab	Manual	11/26/2025 6:10:33 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-002 073	A Wing Computer Lab	Manual	11/25/2025 11:30:02 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-001 072	A Wing Computer Lab	Manual	11/26/2025 6:10:24 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-043 033	A Wing Conference Rm A2F	Manual	11/25/2025 6:37:28 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-018 023	A Wing Display Case A1H	Manual	11/25/2025 11:29:05 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-032 015	A Wing Electrical Room A1C	Manual	11/25/2025 6:36:28 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-026 011	A Wing Finance Office A1G	Manual	11/25/2025 6:36:08 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-033 014	A Wing Fire Riser Admin E	Manual	11/26/2025 10:27:14 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-039 104	A Wing Front Entrance Hall	Manual	11/25/2025 6:43:06 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-050	A Wing Front Entrance Hall	Manual	11/25/2025 11:32:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-041 027	A Wing Hallway by A2A	Manual	11/25/2025 6:34:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-171 003	A Wing Hallway by Room A2	Manual	11/26/2025 1:47:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-042 026	A Wing Hallway to B Wing	Manual	11/25/2025 11:29:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-388 124	A Wing HVAC Corridor A14	Manual	11/26/2025 1:49:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-421 126	A Wing HVAC PA Roof	Manual	11/26/2025 1:49:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-420 125	A Wing HVAC PA SW	Manual	11/26/2025 1:49:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-379 119	A Wing HVAC Room A5	Manual	11/26/2025 1:49:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-380 120	A Wing HVAC Room A6	Manual	11/26/2025 1:49:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-383 121	A Wing HVAC Room A7	Manual	11/26/2025 6:05:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-377 122	A Wing HVAC Room A8	Manual	11/26/2025 1:49:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-390 123	A Wing HVAC Room A9	Manual	11/26/2025 1:49:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-286 103	A Wing IDF Closet Rm A18	Manual	11/25/2025 11:30:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-006 065	A Wing Library	Manual	11/25/2025 11:29:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-007 064	A Wing Library	Manual	11/25/2025 11:29:54 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-004 067	A Wing Library	Manual	11/25/2025 11:29:57 AM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	4-003 068	A Wing Library	Manual	11/25/2025 11:29:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-055 066	A Wing Library	Manual	11/25/2025 11:30:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-010 069	A Wing Library Classroom	Manual	11/25/2025 11:30:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	4-132 006	A Wing Library Northeast	Manual	11/26/2025 1:47:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	4-133 007	A Wing Library Northwest	Manual	11/26/2025 1:47:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-008 071	A Wing Library Storage	Manual	11/25/2025 6:44:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-009 070	A Wing Library Storage	Manual	11/25/2025 11:29:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-025 024	A Wing Lobby Display A1H	Manual	11/25/2025 11:29:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-019 022	A Wing Lobby Skylight A1H	Manual	11/25/2025 6:35:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-255 075	A Wing Media Classroom A5	Manual	11/26/2025 6:12:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-257 074	A Wing Media Classroom A5	Manual	11/26/2025 6:13:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-256 076	A Wing Media Classroom A5	Manual	11/26/2025 6:13:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-260 078	A Wing Media Classroom A6	Manual	11/26/2025 6:12:39 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-259 079	A Wing Media Classroom A6	Manual	11/26/2025 6:12:44 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-258 077	A Wing Media Classroom A6	Manual	11/26/2025 6:12:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-264 081	A Wing Media Classroom A7	Manual	11/26/2025 6:12:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-262 080	A Wing Media Classroom A7	Manual	11/26/2025 6:12:33 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-263 082	A Wing Media Classroom A7 Storage	Manual	11/26/2025 6:12:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-254 083	A Wing Media Classroom A8	Manual	11/26/2025 6:13:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-253 084	A Wing Media Classroom A8	Manual	11/26/2025 6:13:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-270 090	A Wing Media Control A9A	Manual	11/26/2025 6:11:38 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-261 100	A Wing Media Corridor A15	Manual	11/25/2025 11:30:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-265 099	A Wing Media Corridor A15	Manual	11/25/2025 11:30:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-272 094	A Wing Media Dress Rm A12	Manual	11/26/2025 6:13:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-268 096	A Wing Media Dress Rm A13	Manual	11/26/2025 6:14:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-267 097	A Wing Media Dress Rm A13	Manual	11/26/2025 6:14:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-273 095	A Wing Media Dress RR A12	Manual	11/26/2025 6:13:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-277 092	A Wing Media Elect Rm A10	Manual	11/26/2025 6:11:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-266 102	A Wing Media IDF Room A17	Manual	11/26/2025 6:14:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-275 101	A Wing Media Janitor Rm A16	Manual	11/26/2025 6:13:16 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-271	A Wing Media Staff RM Corridor	Manual	11/26/2025 6:13:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-274 098	A Wing Media Staff RR A14	Manual	11/26/2025 6:13:20 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-276 093	A Wing Media Stroage A11	Manual	11/26/2025 6:13:41 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-280 085	A Wing Media Studio Rm A9	Manual	11/26/2025 6:11:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-281 086	A Wing Media Studio Rm A9	Manual	11/26/2025 6:11:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-282 088	A Wing Media Studio Rm A9	Manual	11/26/2025 6:12:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-279 087	A Wing Media Studio Rm A9	Manual	11/26/2025 6:12:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-269 089	A Wing Media Vestible Rm A9	Manual	11/26/2025 6:11:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-278 091	A Wing Media Wardrobe A9B	Manual	11/26/2025 6:11:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-038 037	A Wing Men RR Admin N Hall	Manual	11/25/2025 6:43:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-037 036	A Wing Men RR Admin N Hall	Manual	11/25/2025 6:43:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-022 018	A Wing Office A1E	Manual	11/25/2025 11:29:44 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Valve Tamper Switch	2-143 131	A Wing OSY - NE of Admin	Manual	11/26/2025 1:49:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Valve Tamper Switch	2-143 130	A Wing OSY - NE of Admin	Manual	11/26/2025 1:49:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-287 060	A Wing PA Backstage	Manual	11/25/2025 11:29:19 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-424 004	A Wing PA Lobby	Manual	11/26/2025 1:47:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-310 042	A Wing PA Lobby	Manual	11/25/2025 6:43:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-306 041	A Wing PA Lobby	Manual	11/25/2025 6:44:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-307 040	A Wing PA Lobby	Manual	11/25/2025 6:44:09 AM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	2-296 052	A Wing PA Lower Seating	Manual	11/25/2025 11:29:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-303 046	A Wing PA Lower Seating	Manual	11/25/2025 11:29:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-302 047	A Wing PA Lower Seating	Manual	11/25/2025 11:29:16 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-299 050	A Wing PA Lower Seating	Manual	11/25/2025 11:29:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-295 053	A Wing PA Lower Seating	Manual	11/25/2025 11:29:39 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-298 051	A Wing PA Lower Seating	Manual	11/25/2025 11:30:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-422 005	A Wing PA S Entrance	Manual	11/26/2025 1:47:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-309 043	A Wing PA Seating NE Entr	Manual	11/25/2025 11:29:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-308 054	A Wing PA Seating SE Entr	Manual	11/25/2025 11:29:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-293 057	A Wing PA Stage	Manual	11/25/2025 11:29:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-292 058	A Wing PA Stage	Manual	11/25/2025 11:29:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-291 059	A Wing PA Stage	Manual	11/25/2025 11:29:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-294 055	A Wing PA Steps North	Manual	11/25/2025 11:29:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-297 056	A Wing PA Steps South	Manual	11/25/2025 11:29:20 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-044 034	A Wing PE-f IDF Clst Hall A2A	Manual	11/25/2025 6:42:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Valve Tamper Switch	2-143 129	A Wing PIV - NE of Admin	Manual	11/26/2025 1:49:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-024 016	A Wing Principals Office A1D	Manual	11/25/2025 6:36:19 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-127 002	A Wing Reception	Manual	11/26/2025 1:47:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-021 019	A Wing Reception A1F	Manual	11/25/2025 6:35:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-023 017	A Wing Reception Hall A1F	Manual	11/25/2025 6:35:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-290 062	A Wing Room A3	Manual	11/26/2025 6:10:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-289 063	A Wing Room A3	Manual	11/26/2025 6:10:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-288 061	A Wing Room A3A Storage	Manual	11/26/2025 6:11:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	2-145 127	A Wing Sprinkler Riser Admin	Manual	11/26/2025 1:47:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Valve Tamper Switch	2-144 128	A Wing Sprinkler Riser Admin	Manual	11/26/2025 1:49:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-283 294	A Wing Vestibule Rm A9	Manual	11/26/2025 6:12:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-015 030	A Wing VP Office A2C	Manual	11/25/2025 6:37:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-013 031	A Wing VP Office A2D	Manual	11/25/2025 6:42:36 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-012 032	A Wing VP Office A2E	Manual	11/25/2025 6:42:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-014 028	A Wing VP Office Hall A2A	Manual	11/25/2025 6:37:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-016 029	A Wing VP Work Room A2B	Manual	11/25/2025 6:36:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-048 107	A Wing West Hallway	Manual	11/25/2025 11:32:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-037 106	A Wing West Hallway	Manual	11/26/2025 1:49:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-035 039	A Wing Womens RR Admin N	Manual	11/25/2025 6:43:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-036 038	A Wing Womens RR Admin N	Manual	11/25/2025 6:43:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-028 012	A Wing Work Room A1B	Manual	11/25/2025 6:36:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-031 013	A Wing Work Room A1B RR	Manual	11/25/2025 6:36:38 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-129 251	B Wing Attic B Hall by E Exit	Manual	11/26/2025 10:26:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-134 252	B Wing Attic B Wing Hall	Manual	11/26/2025 10:27:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-133 253	B Wing Attic Hall Closet	Manual	11/26/2025 10:26:42 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-384 254	B Wing Attic Portable B13	Manual	11/26/2025 10:26:35 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-384 256	B Wing Attic Portable B13	Manual	11/26/2025 10:26:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-384 257	B Wing Attic Portable B13	Manual	11/26/2025 10:26:39 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-384 255	B Wing Attic Portable B13	Manual	11/26/2025 10:26:40 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-131 244	B Wing Attic Room B4A	Manual	11/26/2025 10:26:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-131 245	B Wing Attic Room B4A	Manual	11/26/2025 10:26:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-131 246	B Wing Attic Room B4A	Manual	11/26/2025 10:26:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-130 247	B Wing Attic Room B5	Manual	11/26/2025 10:26:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-132 248	B Wing Attic Room B8A	Manual	11/26/2025 10:26:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-132 249	B Wing Attic Room B8A	Manual	11/26/2025 10:26:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-132 250	B Wing Attic Room B8A	Manual	11/26/2025 10:26:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-128 243	B Wing Attic Womens Facilt	Manual	11/26/2025 10:26:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-065 242	B Wing B Wing Hall by B12	Manual	11/26/2025 6:05:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-058 219	B Wing B Wing Hall by B5	Manual	11/26/2025 10:26:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-065 222	B Wing B Wing Hall by B6	Manual	11/26/2025 10:26:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-070 225	B Wing B Wing Hall by B6/B7	Manual	11/26/2025 10:26:19 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-076 234	B Wing B Wing Hall by B8	Manual	11/26/2025 10:26:20 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-081 235	B Wing B Wing Hall by B9	Manual	11/26/2025 6:05:36 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-476 200	B Wing B Wing Hall North	Manual	11/26/2025 10:26:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-059 204	B Wing Hall by Room B3	Manual	11/25/2025 6:34:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-082 238	B Wing Room B10	Manual	11/26/2025 6:05:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-083 239	B Wing Room B11	Manual	11/26/2025 6:05:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-063 240	B Wing Room B12	Manual	11/26/2025 6:05:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-064 241	B Wing Room B12	Manual	11/25/2025 11:30:19 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Manual Pull Station	4-390 202	B Wing Room B13 East	Manual	11/26/2025 10:26:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	4-389 201	B Wing Room B13 South	Manual	11/26/2025 10:26:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-055 211	B Wing Room B3 North	Manual	11/26/2025 6:09:35 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-054 212	B Wing Room B3 South	Manual	11/26/2025 6:09:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-056 213	B Wing Room B4	Manual	11/26/2025 6:08:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-057 214	B Wing Room B4	Manual	11/26/2025 6:08:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-063 220	B Wing Room B4A	Manual	11/26/2025 6:08:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-062 221	B Wing Room B4B	Manual	11/26/2025 6:07:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-066 217	B Wing Room B5	Manual	11/26/2025 6:09:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-060 215	B Wing Room B5	Manual	11/26/2025 6:09:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-067 218	B Wing Room B5	Manual	11/26/2025 6:09:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-061 216	B Wing Room B5	Manual	11/26/2025 6:09:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-071 223	B Wing Room B6	Manual	11/26/2025 6:06:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-064 224	B Wing Room B6	Manual	11/26/2025 6:07:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-069 227	B Wing Room B7	Manual	11/26/2025 6:08:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-068 226	B Wing Room B7	Manual	11/26/2025 6:09:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-077 228	B Wing Room B7A	Manual	11/26/2025 10:26:44 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-078 229	B Wing Room B7A1	Manual	11/26/2025 6:08:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-074 230	B Wing Room B8	Manual	11/26/2025 6:06:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-075 231	B Wing Room B8	Manual	11/26/2025 6:06:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-101 233	B Wing Room B8A	Manual	11/26/2025 10:26:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-102 232	B Wing Room B8A	Manual	11/26/2025 10:26:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-080 236	B Wing Room B9	Manual	11/26/2025 6:08:20 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-079 237	B Wing Room B9	Manual	11/26/2025 6:08:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-256 205	B Wing Science Portble B13	Manual	11/25/2025 11:30:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-255 207	B Wing Science Portble B13	Manual	11/25/2025 11:30:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-254 208	B Wing Science Portble B13	Manual	11/25/2025 11:30:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-257 206	B Wing Science Portble B13	Manual	11/25/2025 11:30:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-052 210	B Wing Womens Facilit RR	Manual	11/26/2025 6:10:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-053 203	B Wing Womens Facilities	Manual	11/26/2025 6:10:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-051 209	B Wing Work Room	Manual	11/26/2025 6:10:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-072	B6 Storage	Manual	11/26/2025 1:47:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-072	B6 Storage	Manual	11/26/2025 1:47:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-072	B6 Storage	Manual	11/26/2025 1:47:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-073	B6 Storage	Manual	11/26/2025 6:06:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-073	B6 Storage	Manual	11/26/2025 6:06:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-073	B6 Storage	Manual	11/26/2025 6:06:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-032	C Wing Admin Breakroom	Manual	11/26/2025 1:47:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-028 291	C Wing Admin Breakroom	Manual	11/25/2025 6:45:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-030 292	C Wing Admin Breakroom	Manual	11/25/2025 6:46:20 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-029 306	C Wing Admin Mens RR	Manual	11/25/2025 6:46:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-060 300	C Wing Admin Room by C4	Manual	11/25/2025 6:46:40 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-038 309	C Wing Admin RR by C4	Manual	11/25/2025 6:47:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-027 305	C Wing Admin Womens RR	Manual	11/25/2025 6:45:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-377 314	C Wing Attic Admin Classrm	Manual	11/26/2025 10:25:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-031 304	C Wing C Wing Hall by C3	Manual	11/25/2025 6:47:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-020 303	C Wing C Wing Hall Closet	Manual	11/26/2025 1:47:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-013	C Wing C Wing Hallway	Manual	11/25/2025 11:32:32 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-012	C Wing C Wing Hallway	Manual	11/25/2025 11:32:37 AM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-014	C Wing C Wing Hallway	Manual	11/25/2025 11:32:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-015	C Wing C Wing Hallway	Manual	11/25/2025 11:32:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-016	C Wing C Wing Hallway	Manual	11/25/2025 11:32:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-084 281	C Wing Fire Panel Room	Manual	11/25/2025 11:35:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-033 285	C Wing Rm C3 Nurse Rm.	Manual	11/25/2025 6:45:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-021	C Wing Rm C3 VP hall	Manual	11/25/2025 6:45:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-023 284	C Wing Rm C3 VP Office	Manual	11/25/2025 6:44:38 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-024 289	C Wing Rm C3 VP Office	Manual	11/25/2025 6:44:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-022	C Wing Rm C3 VP Office	Manual	11/25/2025 6:45:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-019	C Wing Rm C3 VP Office	Manual	11/25/2025 6:45:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-025	C Wing Rm C3 VP Offices	Manual	11/25/2025 6:44:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-026	C Wing Rm C3 VP Offices	Manual	11/25/2025 6:44:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-017 283	C Wing Room C1	Manual	11/25/2025 6:44:19 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-040 295	C Wing Room C4	Manual	11/25/2025 6:46:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-036	C Wing Room C4 Office	Manual	11/25/2025 6:46:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-034	C Wing Room C4 Office	Manual	11/25/2025 6:47:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-037	C Wing Room C4 Office	Manual	11/25/2025 6:47:20 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	4-039 310	C Wing Room C5	Manual	11/25/2025 11:32:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-011 282	C Wing West Hall Fire Door	Manual	11/25/2025 11:35:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-287 1059	Cafeteria Alumni Room	Manual	11/26/2025 9:04:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-381 1063	Cafeteria Attic	Manual	11/26/2025 10:25:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-383 1066	Cafeteria Attic Kitchen	Manual	11/26/2025 10:25:38 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-383 1065	Cafeteria Attic Kitchen	Manual	11/26/2025 10:25:40 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-382 1064	Cafeteria Attic Kitchen	Manual	11/26/2025 10:25:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-285 1054	Cafeteria Kitchen	Manual	11/26/2025 9:02:54 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-286 1052	Cafeteria Kitchen	Manual	11/26/2025 9:03:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-288 1055	Cafeteria Kitchen	Manual	11/26/2025 9:03:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-283 1053	Cafeteria Kitchen Dish Wash	Manual	11/26/2025 9:02:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	4-405 1040	Cafeteria Kitchen East Exit	Manual	11/26/2025 1:47:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-334 1060	Cafeteria Kitchen O/S Storage	Manual	11/26/2025 9:04:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	4-469 1041	Cafeteria Kitchen Office	Manual	11/26/2025 1:50:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-289 1056	Cafeteria Kitchen Restroom	Manual	11/26/2025 9:04:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	4-397 1038	Cafeteria Northeast Exit	Manual	11/26/2025 1:47:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Manual Pull Station	4-396 1039	Cafeteria Northwest Exit	Manual	11/26/2025 1:47:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-276 1048	Cafeteria Room	Manual	11/26/2025 9:01:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-273 1047	Cafeteria Room	Manual	11/26/2025 9:02:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-279 1046	Cafeteria Room	Manual	11/26/2025 9:02:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-274 1050	Cafeteria Room	Manual	11/26/2025 9:02:19 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-275 1045	Cafeteria Room	Manual	11/26/2025 9:02:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-281 1044	Cafeteria Room	Manual	11/26/2025 9:02:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-280 1051	Cafeteria Room	Manual	11/26/2025 9:02:36 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-277 1049	Cafeteria Room	Manual	11/26/2025 9:02:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-278 1043	Cafeteria Room	Manual	11/26/2025 9:02:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-291	Cafeteria Snack Bar	Manual	11/26/2025 9:03:44 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-323 1057	Cafeteria Snack Bar	Manual	11/26/2025 10:25:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-290	Cafeteria Snack Bar Storage	Manual	11/26/2025 9:04:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-322 1058	Cafeteria Snack Bar Storage	Manual	11/26/2025 10:25:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	4-404 1037	Cafeteria Southeast Exit	Manual	11/26/2025 1:47:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	4-398 1036	Cafeteria Southwest Exit	Manual	11/26/2025 1:47:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	4-335 1062	Cafeteria Utility Closet	Manual	11/26/2025 9:04:36 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3-378 375	D Wing Attic Room D2	Manual	11/25/2025 11:31:42 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3-321 358	D Wing Custodial Closet	Manual	11/26/2025 6:14:35 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	4-046 340	D Wing D Wing Hall by D1	Manual	11/25/2025 11:32:57 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3-327 359	D Wing D Wing Hall by D10	Manual	11/26/2025 6:14:59 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3-329 366	D Wing D Wing Hall by D14	Manual	11/26/2025 6:15:13 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3-331 369	D Wing D Wing Hall by D16	Manual	11/26/2025 6:15:23 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3-333 371	D Wing D Wing Hall by D17	Manual	11/26/2025 6:17:10 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	4-048 348	D Wing D Wing Hall by D4	Manual	11/25/2025 11:32:51 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	4-047	D Wing D Wing Hall by D4	Manual	11/25/2025 11:32:53 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	4-049 353	D Wing D Wing Hall by D8	Manual	11/25/2025 11:32:49 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3-324 338	D Wing D Wing Hall East	Manual	11/26/2025 6:14:41 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3-339 355	D Wing D Wing Mens RR	Manual	11/26/2025 6:14:47 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3-322 356	D Wing D Wing Womens RR	Manual	11/26/2025 6:14:19 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3-337 357	D Wing Low D Wing IDF Clst	Manual	11/26/2025 6:14:28 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-290 335	D Wing Low D Wing IDF Clst	Manual	11/25/2025 11:33:03 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Manual Pull Station	3-465 332	D Wing Lower D Hall East	Manual	11/26/2025 6:16:54 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-466 333	D Wing Lower D Hall West	Manual	11/26/2025 6:15:33 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot		D Wing Plum Chs Mens RR	Manual	11/25/2025 11:31:39 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot		D Wing Plum Chs Wom RR	Manual	11/25/2025 11:31:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-041 339	D Wing Room D1	Manual	11/25/2025 11:32:44 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-335 360	D Wing Room D10	Manual	11/26/2025 6:17:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-325 361	D Wing Room D11	Manual	11/26/2025 6:14:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-326 362	D Wing Room D11 Storage	Manual	11/26/2025 6:15:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-315 336	D Wing Room D12	Manual	11/25/2025 11:33:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-316 337	D Wing Room D12	Manual	11/25/2025 11:33:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-328 363	D Wing Room D13	Manual	11/25/2025 11:32:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-327 364	D Wing Room D13 Storage	Manual	11/26/2025 6:15:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-317 365	D Wing Room D14	Manual	11/26/2025 6:17:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-330 367	D Wing Room D15	Manual	11/26/2025 6:15:39 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-318 368	D Wing Room D16	Manual	11/26/2025 6:17:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-332 370	D Wing Room D17	Manual	11/26/2025 6:17:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	3-319 372	D Wing Room D18	Manual	11/26/2025 6:17:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-334 373	D Wing Room D19	Manual	11/26/2025 6:17:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-053 345	D Wing Room D2	Manual	11/25/2025 11:32:35 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-054 344	D Wing Room D2	Manual	11/25/2025 11:32:39 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-052 343	D Wing Room D2	Manual	11/25/2025 11:32:40 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-051 342	D Wing Room D2	Manual	11/25/2025 11:32:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-050 341	D Wing Room D2	Manual	11/25/2025 11:32:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	4-141 334	D Wing Room D2	Manual	11/25/2025 11:31:38 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-320 374	D Wing Room D20	Manual	11/26/2025 6:17:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-042 346	D Wing Room D3	Manual	11/25/2025 11:32:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-055 347	D Wing Room D4	Manual	11/25/2025 11:32:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-043 349	D Wing Room D5	Manual	11/25/2025 11:32:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-056 350	D Wing Room D6	Manual	11/25/2025 11:32:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-044 351	D Wing Room D7	Manual	11/25/2025 11:32:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-057 352	D Wing Room D8	Manual	11/25/2025 11:32:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-045 354	D Wing Room D9	Manual	11/25/2025 11:32:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Manual Pull Station	4-1420 331	D Wing Upper D Hall West	Manual	11/25/2025 11:31:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-437 449	E Wing Attic Cust Office	Manual	11/25/2025 11:31:35 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-384 450	E Wing Attic Room E3	Manual	11/25/2025 11:31:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-384 451	E Wing Attic Room E3	Manual	11/25/2025 11:31:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-384 453	E Wing Attic Room E3	Manual	11/25/2025 11:31:32 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-384 452	E Wing Attic Room E3	Manual	11/25/2025 11:31:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-346 456	E Wing Attic Room E4	Manual	11/25/2025 11:31:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-346 457	E Wing Attic Room E4	Manual	11/25/2025 11:31:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-346 454	E Wing Attic Room E4	Manual	11/25/2025 11:31:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-346 455	E Wing Attic Room E4	Manual	11/25/2025 11:31:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-385 458	E Wing Attic Room E5	Manual	11/25/2025 11:31:19 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-299 426	E Wing Custodial Office	Manual	11/25/2025 11:35:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-469 411	E Wing E Hall NW by Rm E3	Manual	11/25/2025 11:31:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-468 410	E Wing E Hall SW by Rm E2	Manual	11/25/2025 11:31:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-102 433	E Wing E1 Dark Room	Manual	11/25/2025 11:31:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-103 432	E Wing E1 Photo Classroom	Manual	11/26/2025 6:01:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	4-018 434	E Wing E1 Photo Rm Storage	Manual	11/26/2025 6:01:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-009 422	E Wing E1A MDF Basement	Manual	11/25/2025 11:30:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-008 425	E Wing E1A MDF Basement	Manual	11/25/2025 11:30:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-006 423	E Wing E1A MDF Basement	Manual	11/25/2025 11:30:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-007 424	E Wing E1A MDF Basement	Manual	11/25/2025 11:30:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-002 421	E Wing E1A MDF Basement	Manual	11/25/2025 11:30:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-346 431	E Wing E1A MDF Room	Manual	11/25/2025 11:31:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-005 418	E Wing E1A MDF Room	Manual	11/25/2025 11:30:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-003 420	E Wing E1A MDF Room	Manual	11/25/2025 11:30:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-004 419	E Wing E1A MDF Room	Manual	11/25/2025 11:30:33 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-298 436	E Wing Room E2	Manual	11/26/2025 7:38:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-381 412	E Wing Room E3	Manual	11/25/2025 11:31:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-300 429	E Wing Room E3	Manual	11/25/2025 11:30:35 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-301 428	E Wing Room E3	Manual	11/25/2025 11:30:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-302 427	E Wing Room E3	Manual	11/25/2025 11:30:38 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-305 440	E Wing Room E4	Manual	11/25/2025 11:31:20 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	3-303 439	E Wing Room E4	Manual	12/3/2025 4:13:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-304 438	E Wing Room E4	Manual	12/3/2025 4:13:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-407 413	E Wing Room E4	Manual	11/25/2025 11:31:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-432 414	E Wing Room E4 Elec Rm	Manual	11/25/2025 11:31:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-306 443	E Wing Room E5	Manual	12/3/2025 4:05:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-307 441	E Wing Room E5	Manual	12/3/2025 4:06:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-308 442	E Wing Room E5	Manual	12/3/2025 4:06:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-429 415	E Wing Room E5	Manual	12/3/2025 4:07:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-336 444	E Wing Room E5 Closet	Manual	11/25/2025 11:31:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-430 416	E Wing Room E5 Kiln Rm	Manual	11/25/2025 11:31:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-313 445	E Wing Room E6	Manual	12/3/2025 4:07:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-312 446	E Wing Room E6	Manual	12/3/2025 4:08:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-310 447	E Wing Room E6	Manual	12/3/2025 4:10:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-309 448	E Wing Room E6	Manual	12/3/2025 4:13:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-431 417	E Wing Room E6	Manual	11/25/2025 11:31:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-311 430	E Wing Room E6	Manual	11/25/2025 11:35:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	3-057 477	F Wing Room F1	Manual	12/3/2025 4:28:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-245 472	F Wing Room F1	Manual	11/25/2025 11:31:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-058 478	F Wing Room F2	Manual	12/3/2025 4:25:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-246 473	F Wing Room F2	Manual	11/25/2025 11:31:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-059 479	F Wing Room F3	Manual	12/3/2025 4:23:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-247 474	F Wing Room F3	Manual	11/25/2025 11:31:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-060 480	F Wing Room F4	Manual	12/3/2025 4:21:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-248 475	F Wing Room F4	Manual	11/25/2025 11:30:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-062 482	F Wing Room F5	Manual	12/3/2025 4:16:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-061 483	F Wing Room F5	Manual	12/3/2025 4:16:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-063 481	F Wing Room F5	Manual	12/3/2025 4:17:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-064 484	F Wing Room F5	Manual	12/3/2025 4:20:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-249 476	F Wing Room F5	Manual	11/25/2025 11:30:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-065 485	F Wing Room F5 Storage	Manual	12/3/2025 4:18:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-045 517	G Wing Restroom	Manual	12/3/2025 5:05:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-238 493	G Wing Room G1	Manual	11/26/2025 10:27:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-072 501	G Wing Room G1	Manual	11/25/2025 11:35:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-056 500	G Wing Room G1	Manual	11/25/2025 11:35:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-022 505	G Wing Room G2	Manual	11/26/2025 7:49:54 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-054 506	G Wing Room G2	Manual	12/3/2025 4:33:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-239 494	G Wing Room G2	Manual	11/26/2025 10:27:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-055 507	G Wing Room G3	Manual	12/3/2025 4:32:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-052 510	G Wing Room G3	Manual	12/3/2025 4:35:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-051 508	G Wing Room G3	Manual	12/3/2025 4:36:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-050 509	G Wing Room G3	Manual	12/3/2025 4:38:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-240 495	G Wing Room G3	Manual	11/25/2025 11:30:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-049 511	G Wing Room G4	Manual	12/3/2025 4:40:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-241 496	G Wing Room G4	Manual	11/25/2025 11:30:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-048	G Wing Room G4	Manual	11/25/2025 6:34:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-047 512	G Wing Room G4 Storage	Manual	12/3/2025 4:41:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-046 513	G Wing Room G4 Storage	Manual	12/3/2025 4:52:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-043 503	G Wing Room G5	Manual	11/25/2025 6:33:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-044 502	G Wing Room G5	Manual	11/25/2025 6:33:55 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-242 497	G Wing Room G5 South	Manual	11/25/2025 11:30:54 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-243 498	G Wing Room G5 West	Manual	11/25/2025 11:30:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-042 514	G Wing Room G6	Manual	12/3/2025 4:58:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-244 499	G Wing Room G6	Manual	11/25/2025 11:30:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-040 515	G Wing Room G6 Storage	Manual	12/3/2025 5:05:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-008 516	G Wing Room G6 Storage	Manual	12/3/2025 5:05:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-145 585	H Wing Art Room H5	Manual	11/26/2025 7:39:33 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-145 586	H Wing Art Room H5	Manual	11/26/2025 7:39:36 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-145 587	H Wing Art Room H5	Manual	11/26/2025 7:39:38 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-145 588	H Wing Art Room H5	Manual	11/26/2025 7:39:40 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-146 592	H Wing Art Room H5	Manual	11/26/2025 7:39:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-146 590	H Wing Art Room H5	Manual	11/26/2025 7:39:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-146 591	H Wing Art Room H5	Manual	11/26/2025 7:39:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-146 589	H Wing Art Room H5	Manual	11/26/2025 7:39:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-141 603	H Wing Attic H4 Mens RR	Manual	11/26/2025 1:50:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-150 608	H Wing Attic H6 Womens RR	Manual	11/26/2025 1:50:21 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-139 601	H Wing Attic Room H2A	Manual	11/26/2025 10:24:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-140 602	H Wing Attic Room H2A	Manual	11/26/2025 1:47:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-138 604	H Wing Attic Room H5A	Manual	11/26/2025 10:24:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-151 605	H Wing Attic Room H5C	Manual	11/26/2025 10:24:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-152 607	H Wing Attic Room H5C	Manual	11/26/2025 10:24:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-152 606	H Wing Attic Room H5C	Manual	11/26/2025 10:24:16 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-154 609	H Wing Attic Room H8A	Manual	11/26/2025 10:24:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-134 566	H Wing Auto Room H1	Manual	11/26/2025 7:38:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-134 565	H Wing Auto Room H1	Manual	11/26/2025 7:38:54 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-134 564	H Wing Auto Room H1	Manual	11/26/2025 7:38:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-134 563	H Wing Auto Room H1	Manual	11/26/2025 7:38:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-132 574	H Wing Auto Room H1	Manual	11/26/2025 7:39:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-132 573	H Wing Auto Room H1	Manual	11/26/2025 7:39:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-132 572	H Wing Auto Room H1	Manual	11/26/2025 7:39:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-132 571	H Wing Auto Room H1	Manual	11/26/2025 7:39:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-129 581	H Wing Auto Room H1	Manual	11/26/2025 1:50:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	3-129 580	H Wing Auto Room H1	Manual	11/26/2025 1:50:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-129 579	H Wing Auto Room H1	Manual	11/26/2025 1:50:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-129 582	H Wing Auto Room H1	Manual	11/26/2025 1:50:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-131 578	H Wing Auto Room H1	Manual	11/26/2025 1:50:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-131 577	H Wing Auto Room H1	Manual	11/26/2025 1:50:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-131 576	H Wing Auto Room H1	Manual	11/26/2025 1:50:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-131 575	H Wing Auto Room H1	Manual	11/26/2025 1:50:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-133 567	H Wing Auto Room H1	Manual	11/26/2025 1:50:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-133 568	H Wing Auto Room H1	Manual	11/26/2025 1:50:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-133 569	H Wing Auto Room H1	Manual	11/26/2025 1:50:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-133 570	H Wing Auto Room H1	Manual	11/26/2025 1:50:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Valve Tamper Switch	3-127 625	H Wing Auto Room H1	Manual	11/26/2025 1:50:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-135 583	H Wing Auto Room H1A	Manual	11/26/2025 7:39:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-128 610	H Wing Auto Room H1C	Manual	11/26/2025 10:24:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	3-126 623	H Wing H1 Bldg/SW Exterior	Manual	11/26/2025 7:38:42 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	3-136 624	H Wing H2-H10 Bldg/SW Ext	Manual	11/26/2025 1:50:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-013 550	H Wing H4 Mens Restroom	Manual	11/26/2025 7:50:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-022 555	H Wing H6 Womens Restrm	Manual	11/26/2025 7:49:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Valve Tamper Switch	3-137 628	H Wing OSY/SE of Rm H1	Manual	11/26/2025 1:50:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Valve Tamper Switch	3-137 629	H Wing OSY/SE of Rm H1	Manual	11/26/2025 1:50:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Valve Tamper Switch	3-137 627	H Wing PIV - SE of Room H1	Manual	11/26/2025 1:50:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-225 528	H Wing Room H1 North Exit	Manual	11/26/2025 1:48:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-224 527	H Wing Room H1 South Exit	Manual	11/26/2025 1:48:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-009 562	H Wing Room H10	Manual	11/25/2025 11:33:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-006 537	H Wing Room H1B	Manual	11/26/2025 8:59:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-003 538	H Wing Room H1B	Manual	11/26/2025 9:00:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-005 539	H Wing Room H1C	Manual	11/26/2025 8:59:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-004 540	H Wing Room H1C	Manual	11/26/2025 8:59:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-014 542	H Wing Room H2	Manual	11/26/2025 9:00:36 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-018 541	H Wing Room H2	Manual	11/26/2025 9:00:42 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-019 544	H Wing Room H2	Manual	11/26/2025 9:00:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-015 543	H Wing Room H2	Manual	11/26/2025 9:00:54 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Manual Pull Station	3-226 529	H Wing Room H2 South Exit	Manual	11/26/2025 1:48:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-227 530	H Wing Room H2 West Exit	Manual	11/26/2025 1:48:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-012 545	H Wing Room H2A	Manual	11/26/2025 9:01:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-160 611	H Wing Room H2A Attic	Manual	11/26/2025 10:24:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-161 612	H Wing Room H2A Attic	Manual	11/26/2025 10:24:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-021 548	H Wing Room H3	Manual	11/26/2025 9:00:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-017 549	H Wing Room H3	Manual	11/26/2025 9:00:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-016 546	H Wing Room H3	Manual	11/26/2025 9:00:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-020 547	H Wing Room H3	Manual	11/26/2025 9:00:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-229 532	H Wing Room H3 East Exit	Manual	11/26/2025 1:48:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-228 531	H Wing Room H3 South Exit	Manual	11/26/2025 1:48:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-231 534	H Wing Room H5 East Exit	Manual	11/26/2025 1:48:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-230 533	H Wing Room H5 West Exit	Manual	11/26/2025 1:48:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-011 551	H Wing Room H5A	Manual	11/26/2025 9:01:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-010 552	H Wing Room H5B	Manual	11/26/2025 9:01:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-024 554	H Wing Room H5C	Manual	11/26/2025 9:01:19 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-025 553	H Wing Room H5C	Manual	11/26/2025 9:01:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-163 617	H Wing Room H5C Attic	Manual	11/26/2025 10:24:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-143 614	H Wing Room H5C Attic	Manual	11/26/2025 10:24:19 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-144 615	H Wing Room H5C Attic	Manual	11/26/2025 10:24:20 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-165 618	H Wing Room H5C Attic	Manual	11/26/2025 10:24:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-162 616	H Wing Room H5C Attic	Manual	11/26/2025 10:24:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-166 619	H Wing Room H5C Attic	Manual	11/26/2025 10:24:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-028 556	H Wing Room H7	Manual	11/26/2025 9:01:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-026 557	H Wing Room H7	Manual	11/26/2025 9:01:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-157 593	H Wing Room H8	Manual	11/26/2025 7:39:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-157 594	H Wing Room H8	Manual	11/26/2025 7:39:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-157 595	H Wing Room H8	Manual	11/26/2025 7:40:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-157 596	H Wing Room H8	Manual	11/26/2025 7:40:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-158 600	H Wing Room H8	Manual	11/26/2025 7:40:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-158 599	H Wing Room H8	Manual	11/26/2025 7:40:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-158 598	H Wing Room H8	Manual	11/26/2025 7:40:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	3-158 597	H Wing Room H8	Manual	11/26/2025 7:40:15 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - Duct	3-142 613	H Wing Room H8	Manual	11/26/2025 10:24:28 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Manual Pull Station	3-233 536	H Wing Room H8 East Exit	Manual	11/26/2025 1:48:58 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Manual Pull Station	3-232 535	H Wing Room H8 West Exit	Manual	11/26/2025 1:48:56 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-029 558	H Wing Room H8A	Manual	11/26/2025 9:01:30 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-030 559	H Wing Room H8B	Manual	11/26/2025 9:01:36 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-023 560	H Wing Room H9	Manual	11/25/2025 11:35:46 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-027 561	H Wing Room H9	Manual	11/25/2025 11:35:48 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Valve Tamper Switch	3-137 626	H Wing Rooms H2-H10 Bldg	Manual	11/26/2025 10:24:10 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3-132 684	I Wing Attic Boys Restroom	Manual	11/26/2025 7:39:15 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3-131 685	I Wing Attic Girls Restroom	Manual	11/26/2025 10:25:15 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3-167 677	I Wing Attic Room I-1	Manual	11/26/2025 10:25:02 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3-167 676	I Wing Attic Room I-1	Manual	11/26/2025 10:25:04 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3-168 678	I Wing Attic Room I-2	Manual	11/26/2025 10:25:05 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3-168 679	I Wing Attic Room I-2	Manual	11/26/2025 10:25:07 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3-156 681	I Wing Attic Room I-3	Manual	11/26/2025 10:25:08 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	3-156 680	I Wing Attic Room I-3	Manual	11/26/2025 10:25:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-155 682	I Wing Attic Room I-4	Manual	11/26/2025 10:25:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-155 683	I Wing Attic Room I-4	Manual	11/26/2025 10:25:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-039 667	I Wing Boys Restroom	Manual	11/25/2025 11:30:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-035 674	I Wing Custodial Closet	Manual	12/3/2025 5:15:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-036 675	I Wing Electrical Room	Manual	12/3/2025 5:16:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-038 668	I Wing Electrical Room	Manual	11/25/2025 11:35:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-037 669	I Wing Girls Restroom	Manual	11/25/2025 11:35:44 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-034 666	I Wing I-1 Conference Room	Manual	11/25/2025 6:33:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-068 670	I Wing Room I-1	Manual	12/3/2025 5:10:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-184 662	I Wing Room I-1 North	Manual	11/26/2025 1:47:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-069 665	I Wing Room I-1 Office	Manual	11/25/2025 6:33:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-187 661	I Wing Room I-1 South	Manual	11/26/2025 1:47:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-067 671	I Wing Room I-2	Manual	12/3/2025 5:09:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-185 664	I Wing Room I-2 North	Manual	11/26/2025 1:47:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-186 663	I Wing Room I-2 South	Manual	11/26/2025 1:47:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	3-066 672	I Wing Room I-3	Manual	12/3/2025 5:08:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-038 673	I Wing Room I-4	Manual	12/3/2025 5:08:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-398 758	J Wing ACU-1 J6	Manual	11/26/2025 10:25:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-387 754	J Wing ACU-2 J6	Manual	11/26/2025 1:47:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-393 757	J Wing ACU-3 J6	Manual	11/26/2025 1:48:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-399 759	J Wing ACU-4 J6	Manual	11/26/2025 1:48:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-416 762	J Wing ACU-5 J11	Manual	11/26/2025 1:47:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-391 756	J Wing ACU-5 J11	Manual	11/26/2025 1:47:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-400 760	J Wing ACU-6 J6	Manual	11/26/2025 1:48:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-409 753	J Wing Attic Room J11	Manual	11/26/2025 10:24:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-413 744	J Wing Attic Room J1A	Manual	11/26/2025 10:24:35 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-428 745	J Wing Attic Room J2	Manual	11/26/2025 10:24:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-426 746	J Wing Attic Room J3	Manual	11/26/2025 10:24:38 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-427 747	J Wing Attic Room J4	Manual	11/26/2025 10:24:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-397 748	J Wing Attic Room J6	Manual	11/26/2025 10:24:40 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-388 749	J Wing Attic Room J7	Manual	11/26/2025 10:24:42 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	3-383 750	J Wing Attic Room J9	Manual	11/26/2025 10:24:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-382 751	J Wing Attic Room J9A	Manual	11/26/2025 10:24:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-377 752	J Wing Attic Room J9B	Manual	11/26/2025 10:24:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-236 696	J Wing Culinary Caf? East	Manual	11/26/2025 1:47:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-235 697	J Wing Culinary Caf? South	Manual	11/26/2025 1:47:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-404 761	J Wing MAU-1 J6	Manual	11/26/2025 1:48:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-389 755	J Wing MAU-2 J6	Manual	11/26/2025 1:48:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Valve Tamper Switch	3-376 788	J Wing OSY/NE of Bldg	Manual	11/26/2025 10:24:32 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Valve Tamper Switch	3-376 787	J Wing OSY/NE of Bldg	Manual	11/26/2025 10:24:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Valve Tamper Switch	3-376 786	J Wing PIV - NE Side of Bldg	Manual	11/26/2025 10:24:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-234 698	J Wing Rm J4 Kitchen West	Manual	11/26/2025 1:47:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-265 742	J Wing Rm J9 Foods 1 2	Manual	11/26/2025 10:24:44 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-266 743	J Wing Rm J9 Foods 1 2	Manual	11/26/2025 10:24:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-262 740	J Wing Rm J9 Foods 1 2	Manual	11/26/2025 10:24:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-263 741	J Wing Rm J9 Foods 1 2	Manual	11/26/2025 10:24:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-261 739	J Wing Rm J9 Foods 1 2	Manual	11/26/2025 10:24:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	3-260 738	J Wing Rm J9 Foods 1 2	Manual	11/26/2025 10:24:51 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - Projected Beam	3-424 783	J Wing Room J1	Manual	11/26/2025 1:48:08 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - Projected Beam	3-422 782	J Wing Room J1	Manual	11/26/2025 1:48:10 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - Projected Beam	3-420 781	J Wing Room J1	Manual	11/26/2025 1:48:12 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-256 722	J Wing Room J10	Manual	11/25/2025 11:35:37 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-283 723	J Wing Room J11	Manual	11/24/2025 11:38:01 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-285 724	J Wing Room J11	Manual	11/24/2025 11:38:05 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-288 725	J Wing Room J11	Manual	11/24/2025 11:38:10 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-286 726	J Wing Room J11A	Manual	11/24/2025 11:38:29 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-287 727	J Wing Room J11B	Manual	11/24/2025 11:38:34 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-281 728	J Wing Room J11C	Manual	11/25/2025 11:35:36 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-282 729	J Wing Room J11D	Manual	11/24/2025 11:37:56 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-292 730	J Wing Room J11D1	Manual	11/25/2025 11:35:34 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	3-410 784	J Wing Room J12	Manual	11/26/2025 1:47:47 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-290 731	J Wing Room J12	Manual	11/25/2025 11:35:40 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Valve Tamper Switch	3-411 785	J Wing Room J12 - OSY	Manual	11/26/2025 10:24:31 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-291 700	J Wing Room J1A	Manual	11/25/2025 11:35:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-289 701	J Wing Room J1B	Manual	11/25/2025 11:35:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-297 702	J Wing Room J1C	Manual	11/25/2025 11:35:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-296 703	J Wing Room J1D	Manual	11/25/2025 11:35:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-295 734	J Wing Room J4	Manual	11/26/2025 1:48:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-280 733	J Wing Room J4	Manual	11/26/2025 1:48:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-294 732	J Wing Room J4	Manual	11/26/2025 1:49:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-293 704	J Wing Room J4	Manual	11/24/2025 11:37:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-294 705	J Wing Room J4	Manual	11/25/2025 11:35:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-277 706	J Wing Room J4A	Manual	11/25/2025 11:35:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-279 735	J Wing Room J4B	Manual	11/25/2025 11:32:16 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-270 708	J Wing Room J5	Manual	11/25/2025 11:35:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-269 707	J Wing Room J5	Manual	11/25/2025 11:35:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-275 709	J Wing Room J5	Manual	11/25/2025 11:35:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-276 710	J Wing Room J5A	Manual	11/25/2025 11:35:38 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-267 711	J Wing Room J6	Manual	11/25/2025 11:35:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-271 713	J Wing Room J6	Manual	11/25/2025 11:35:16 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-278 712	J Wing Room J6	Manual	11/25/2025 11:35:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-274 714	J Wing Room J6A	Manual	11/25/2025 11:35:20 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-273 736	J Wing Room J7	Manual	11/25/2025 11:32:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-268 737	J Wing Room J7	Manual	11/26/2025 1:48:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-257 715	J Wing Room J7A	Manual	11/24/2025 11:38:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-255 716	J Wing Room J7B	Manual	11/25/2025 11:35:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-272 717	J Wing Room J7C	Manual	11/25/2025 11:35:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-284 718	J Wing Room J7D	Manual	11/25/2025 11:35:33 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-258 719	J Wing Room J8	Manual	11/25/2025 11:35:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-237 699	J Wing Room J9 North	Manual	11/26/2025 1:47:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-264 720	J Wing Room J9A	Manual	11/25/2025 11:35:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-259 721	J Wing Room J9B	Manual	11/25/2025 11:35:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-258 970	Large Gym Announcers Booth	Manual	11/25/2025 11:31:44 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-336 969	Large Gym Announcers Booth	Manual	11/25/2025 11:31:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-316 968	Large Gym Announcers Booth	Manual	11/25/2025 11:31:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	4-376 989	Large Gym Attic Storage NE	Manual	11/26/2025 1:49:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-376 990	Large Gym Attic Storage NE	Manual	11/26/2025 1:49:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-377 988	Large Gym Attic Storage NW	Manual	11/26/2025 1:49:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-377 987	Large Gym Attic Storage NW	Manual	11/26/2025 1:49:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-320 953	Large Gym Basketball Court	Manual	11/25/2025 11:34:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-333 940	Large Gym Basketball Court	Manual	11/25/2025 11:34:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-342 945	Large Gym Basketball Court	Manual	11/25/2025 11:34:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-337 944	Large Gym Basketball Court	Manual	11/25/2025 11:34:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-350 943	Large Gym Basketball Court	Manual	11/25/2025 11:34:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-343 942	Large Gym Basketball Court	Manual	11/25/2025 11:34:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-338 941	Large Gym Basketball Court	Manual	11/25/2025 11:34:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-314 947	Large Gym Basketball Court	Manual	11/25/2025 11:34:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-318 946	Large Gym Basketball Court	Manual	11/25/2025 11:34:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-304 949	Large Gym Basketball Court	Manual	11/25/2025 11:34:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-302 950	Large Gym Basketball Court	Manual	11/25/2025 11:34:44 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-307 948	Large Gym Basketball Court	Manual	11/25/2025 11:34:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	4-312 952	Large Gym Basketball Court	Manual	11/25/2025 11:34:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-315 955	Large Gym Basketball Court	Manual	11/25/2025 11:34:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-317 954	Large Gym Basketball Court	Manual	11/25/2025 11:34:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-305 957	Large Gym Basketball Court	Manual	11/25/2025 11:34:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-301 958	Large Gym Basketball Court	Manual	11/25/2025 11:34:54 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-306 956	Large Gym Basketball Court	Manual	11/25/2025 11:34:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-310 959	Large Gym Basketball Court	Manual	11/25/2025 11:34:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-309 951	Large Gym Basketball Court	Manual	11/25/2025 11:34:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	4-462 991	Large Gym Boys Locker North	Manual	11/26/2025 1:50:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	4-465 994	Large Gym Boys Locker Roof E	Manual	11/26/2025 1:49:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	4-463 992	Large Gym Boys Locker Roof S	Manual	11/26/2025 1:49:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	4-464 993	Large Gym Boys Locker Roof W	Manual	11/26/2025 1:49:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-378 979	Large Gym Boys Locker Room	Manual	11/25/2025 11:31:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-378 980	Large Gym Boys Locker Room	Manual	11/25/2025 11:31:54 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-378 981	Large Gym Boys Locker RR E	Manual	11/25/2025 11:31:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-378 973	Large Gym Boys Locker RR W	Manual	11/25/2025 11:31:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	4-293 967	Large Gym Boys Restroom	Manual	11/26/2025 1:48:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-332 976	Large Gym Coaches Off Storage	Manual	11/26/2025 1:48:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-311 960	Large Gym Coaches Off Storage	Manual	11/25/2025 11:34:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-325 974	Large Gym Coaches Office	Manual	11/25/2025 11:32:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-326 975	Large Gym Coaches Office	Manual	11/25/2025 11:32:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-365 986	Large Gym East Storage Closet	Manual	11/26/2025 1:49:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-359 971	Large Gym Electrical Room	Manual	11/26/2025 1:49:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-296 965	Large Gym Food Counter	Manual	11/26/2025 1:49:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-298 937	Large Gym Front Entrance	Manual	11/25/2025 11:35:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-294 938	Large Gym Front Entrance	Manual	11/25/2025 11:35:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	4-394 934	Large Gym Front Entrance NE	Manual	11/26/2025 1:48:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	4-393 933	Large Gym Front Entrance NW	Manual	11/26/2025 1:48:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-297 963	Large Gym Front Storage Room	Manual	11/26/2025 1:48:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-299 961	Large Gym Girls Restroom	Manual	11/26/2025 1:48:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-333 985	Large Gym Hall Southeast	Manual	11/26/2025 1:48:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-360 972	Large Gym Hall Southwest	Manual	11/26/2025 1:49:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - Duct	4-466 995	Large Gym North Foyer	Manual	11/26/2025 1:49:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	4-391 936	Large Gym Southeast Exit	Manual	11/26/2025 1:48:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	4-392 935	Large Gym Southwest Exit	Manual	11/26/2025 1:48:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-292 978	Large Gym Storage	Manual	11/26/2025 1:48:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-329 984	Large Gym Storage Closet	Manual	11/25/2025 11:32:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-331 977	Large Gym Storage Closet	Manual	11/26/2025 1:48:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-324 966	Large Gym Storage Room	Manual	11/25/2025 11:31:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-300 962	Large Gym Storage Room	Manual	11/26/2025 1:48:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-322 939	Large Gym Strg by Snack Bar	Manual	11/25/2025 11:34:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-253 982	Large Gym Team Room	Manual	11/25/2025 11:31:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-378 983	Large Gym Team Room Storage	Manual	11/25/2025 11:31:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-082	Nursery arm N-3 Off	Manual	11/26/2025 10:25:33 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-181 840	Nursery Buildings Attic Nursery N1	Manual	11/26/2025 10:25:19 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-181 841	Nursery Buildings Attic Nursery N1	Manual	11/26/2025 10:25:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-182 842	Nursery Buildings Attic Nursery N2	Manual	11/26/2025 10:25:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-182 843	Nursery Buildings Attic Nursery N2	Manual	11/26/2025 10:25:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	3-183 844	Nursery Buildings Attic Upper Nursery	Manual	11/26/2025 10:25:25 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3-183 845	Nursery Buildings Attic Upper Nursery	Manual	11/26/2025 10:25:26 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3-076 834	Nursery Buildings N1/N2 Adult RR	Manual	11/26/2025 10:25:30 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3-077 836	Nursery Buildings N1/N2 Kids RR	Manual	11/26/2025 10:25:28 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3-078 835	Nursery Buildings N1/N2 Kitchen	Manual	11/26/2025 10:25:31 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-075 826	Nursery Buildings N1/N2 Office	Manual	11/25/2025 11:33:13 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-081 830	Nursery Buildings N2 Washer/Dryer Clst	Manual	11/25/2025 11:33:16 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-073 824	Nursery Buildings Nursery N1	Manual	11/25/2025 11:33:09 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-074 825	Nursery Buildings Nursery N1	Manual	11/25/2025 11:33:11 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-070 827	Nursery Buildings Nursery N1 Closet	Manual	11/25/2025 11:33:08 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Manual Pull Station	3-172 819	Nursery Buildings Nursery N1 North	Manual	11/26/2025 1:49:01 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Manual Pull Station	3-171 818	Nursery Buildings Nursery N1 South	Manual	11/26/2025 1:48:59 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-079 828	Nursery Buildings Nursery N2	Manual	11/25/2025 11:33:14 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-080 829	Nursery Buildings Nursery N2	Manual	11/25/2025 11:33:17 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Manual Pull Station	3-174 820	Nursery Buildings Nursery N2 North	Manual	11/26/2025 1:49:03 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Manual Pull Station	3-173 821	Nursery Buildings Nursery N2 South	Manual	11/26/2025 1:49:04 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	3-083 838	Nursery Buildings Upp Nurs Adult RR	Manual	11/26/2025 10:25:36 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-085 833	Nursery Buildings Upper Nursery	Manual	11/25/2025 11:33:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-087 832	Nursery Buildings Upper Nursery	Manual	11/25/2025 11:33:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-086 831	Nursery Buildings Upper Nursery	Manual	11/25/2025 11:33:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-175 822	Nursery Buildings Upper Nursery East	Manual	11/26/2025 1:49:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-084 839	Nursery Buildings Upper Nursery Office	Manual	11/26/2025 10:25:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-176 823	Nursery Buildings Upper Nursery West	Manual	11/26/2025 1:49:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-058	Old Boiler Room	Manual	11/25/2025 11:33:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-041	Rm G-6	Manual	11/26/2025 1:47:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-053	Room G-2	Manual	11/26/2025 1:47:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-093 864	Small Gym Basketball Court	Manual	11/25/2025 11:33:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-342 866	Small Gym Basketball Court	Manual	11/25/2025 11:33:32 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-077 880	Small Gym Basketball Court	Manual	11/25/2025 11:33:33 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-104 863	Small Gym Basketball Court	Manual	11/25/2025 11:33:35 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-079 878	Small Gym Basketball Court	Manual	11/25/2025 11:33:36 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-078 879	Small Gym Basketball Court	Manual	11/25/2025 11:33:39 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	4-081 876	Small Gym Basketball Court	Manual	11/25/2025 11:33:40 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-088 874	Small Gym Basketball Court	Manual	11/25/2025 11:33:42 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-080 877	Small Gym Basketball Court	Manual	11/25/2025 11:33:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-082 875	Small Gym Basketball Court	Manual	11/25/2025 11:33:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-087 873	Small Gym Basketball Court	Manual	11/25/2025 11:33:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-086 872	Small Gym Basketball Court	Manual	11/25/2025 11:33:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-084 870	Small Gym Basketball Court	Manual	11/25/2025 11:33:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-089 868	Small Gym Basketball Court	Manual	11/25/2025 11:33:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-085 871	Small Gym Basketball Court	Manual	11/25/2025 11:33:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-083 869	Small Gym Basketball Court	Manual	11/25/2025 11:33:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-091 865	Small Gym Basketball Court	Manual	11/25/2025 11:33:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-090 867	Small Gym Basketball Court	Manual	11/25/2025 11:33:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-473 861	Small Gym Basketball Court NW	Manual	11/26/2025 10:26:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-472	Small Gym Basketball NW	Manual	11/25/2025 11:33:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-472	Small Gym Basketball NW	Manual	11/26/2025 10:26:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-099	Small Gym Closet	Manual	11/26/2025 6:04:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-351 893	Small Gym E Lock Closet North	Manual	11/26/2025 10:26:14 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-096 887	Small Gym E Lock Hall by RR	Manual	11/26/2025 6:03:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-098 892	Small Gym E Lock Strg by Off	Manual	11/26/2025 6:04:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-094 889	Small Gym E Locker Clst by RR	Manual	11/26/2025 7:36:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-129 891	Small Gym E Locker Office RR	Manual	11/26/2025 6:04:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-074 895	Small Gym East Girls Locker Rm	Manual	11/26/2025 7:37:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-073 896	Small Gym East Girls Locker Rm	Manual	11/26/2025 7:37:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-076 894	Small Gym East Girls Locker Rm	Manual	11/26/2025 7:38:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-097 890	Small Gym East Locker Office	Manual	11/26/2025 6:04:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-095 888	Small Gym East Locker RR	Manual	11/26/2025 6:03:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-106	Small Gym Hall	Manual	11/26/2025 6:01:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-106	Small Gym Hall	Manual	11/26/2025 6:01:19 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-105	Small Gym Hall	Manual	11/26/2025 6:01:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-105	Small Gym Hall	Manual	11/26/2025 6:01:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-100	Small Gym Hall	Manual	11/26/2025 6:01:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-101	Small Gym Hall	Manual	11/26/2025 10:26:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-101	Small Gym Hall	Manual	11/26/2025 10:26:10 AM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-068 885	Small Gym Hallway	Manual	11/26/2025 6:03:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-130	Small Gym Locker Rm Attic	Manual	11/26/2025 6:02:16 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-474 857	Small Gym Sm Gym Hall by B12	Manual	11/26/2025 10:26:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-470 859	Small Gym Sm Gym Hall by E1	Manual	11/26/2025 10:26:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3-475 858	Small Gym Sm Gym Hall S Exit	Manual	11/26/2025 10:26:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-062 882	Small Gym Small Gym Hallway	Manual	11/26/2025 6:02:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-067 883	Small Gym Small Gym Hallway	Manual	11/26/2025 6:03:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-066 884	Small Gym Small Gym Hallway	Manual	11/26/2025 6:03:16 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-061	Small Gym Small Gym Hallway	Manual	11/26/2025 6:03:44 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-069 899	Small Gym W Lock Cust Clst	Manual	11/26/2025 6:02:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-062 897	Small Gym W Lock Hall by RR	Manual	11/26/2025 6:02:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-062 901	Small Gym W Lock Office RR	Manual	11/26/2025 6:07:54 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-322 909	Small Gym W Lock Plum Chase	Manual	11/26/2025 10:26:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-073 906	Small Gym W Lock Sm Storage	Manual	11/26/2025 7:37:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-074 905	Small Gym W Lock Storage NE	Manual	11/26/2025 7:37:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-076 908	Small Gym W Lock Strg by N Ext	Manual	11/26/2025 7:38:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	4-075 900	Small Gym W Locker Office	Manual	11/26/2025 6:02:24 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	4-070 898	Small Gym W Locker Restroom	Manual	11/26/2025 6:02:10 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Manual Pull Station	3-471 860	Small Gym West Girls Locker	Manual	11/26/2025 10:26:11 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	4-072 903	Small Gym West Girls Locker Rm	Manual	11/26/2025 6:02:39 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	4-072 904	Small Gym West Girls Locker Rm	Manual	11/26/2025 6:02:41 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	4-072 902	Small Gym West Girls Locker Rm	Manual	11/26/2025 6:02:43 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	4-267 1030	Weight Room	Manual	11/25/2025 11:32:09 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	4-379 1032	Weight Room Attic North	Manual	11/26/2025 10:26:01 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	4-380 1033	Weight Room Attic South	Manual	11/26/2025 10:25:50 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	4-270 1027	Weight Room North Storage	Manual	11/25/2025 11:32:12 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	4-269 1026	Weight Room North Storage	Manual	11/26/2025 1:48:17 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	4-272 1028	Weight Room North Storage	Manual	11/26/2025 1:48:19 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Manual Pull Station	4-388 1016	Weight Room Northeast Exit	Manual	11/25/2025 11:32:06 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Manual Pull Station	4-387	Weight Room South Exit	Manual	11/26/2025 1:48:21 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	4-271 1031	Weight Room South Storage	Manual	11/25/2025 11:32:07 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	4-260 1029	Weight Room South Storage	Manual	11/26/2025 1:48:42 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Manual Pull Station	4-450 1017	Weight Room Southeast Exit	Manual	11/26/2025 10:25:53 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-261 1025	Weight Room Weight Room	Manual	11/25/2025 11:32:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-262 1020	Weight Room Weight Room	Manual	11/26/2025 10:25:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-263 1024	Weight Room Weight Room	Manual	11/26/2025 10:25:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-268 1023	Weight Room Weight Room	Manual	11/26/2025 10:25:44 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-265 1018	Weight Room Weight Room	Manual	11/26/2025 10:25:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-264 1019	Weight Room Weight Room	Manual	11/26/2025 10:25:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-259 1022	Weight Room Weight Room	Manual	11/26/2025 10:25:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-266 1021	Weight Room Weight Room	Manual	11/26/2025 1:48:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-300 049	A Wing PA Upper Seating	Manual	11/25/2025 11:29:24 AM
Smoke Detector - General	2-305 048	A Wing PA Upper Seating	Manual	11/25/2025 11:29:27 AM
Smoke Detector - General	2-301 044	A Wing PA Upper Seating	Manual	11/25/2025 11:29:30 AM
Smoke Detector - General	2-304 045	A Wing PA Upper Seating	Manual	11/25/2025 11:29:41 AM
Smoke Detector - General	4-321 1042	Cafeteria Kitchen Office	Manual	11/25/2025 11:33:20 AM

Device/Equipment details

Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Audible					
132	A Wing North Exterior				
133	A Wing North Exterior				
134	A Wing East Exterior				
135	A Wing East Exterior				
136	A Wing East Exterior				
137	A Wing South Exterior				
138	A Wing South Exterior				
139	A Wing South Exterior				
140	A Wing West Exterior				
141	A Wing West Exterior				
199	A Wing East Exterior				
258	B Wing East Exterior				
259	B Wing East Exterior				
315	C Wing North Exterior				
378	D Wing East Exterior				
379	D Wing West Exterior				
459	E Wing East Exterior				
460	E Wing West Exterior				
486	F Wing South Exterior				
518	G Wing South Exterior				
630	H Wing North Exterior				
631	H Wing North Exterior				
632	H Wing East Exterior				
633	H Wing East Exterior				
634	H Wing East Exterior				
635	H Wing South Exterior				
636	H Wing West Exterior				
637	H Wing West Exterior				
638	H Wing West Exterior				
659	H Wing H1 Bldg/SW Exterior				
660	H Wing H2-H10 Bldg/SW Ext				
686	I Wing East Exterior				
687	I Wing West Exterior				
789	J Wing North Exterior				
790	J Wing East Exterior				
791	J Wing South Exterior				
792	J Wing West Exterior				
3-171 817	J Wing O/S Riser Rm J12				
846	Nursery Buildings North Exterior				
847	Nursery Buildings West Exterior				
911	Small Gym North Exterior				
912	Small Gym North Exterior				
996	Large Gym North Exterior				
997	Large Gym East Exterior				
998	Large Gym West Exterior				
1067	Cafeteria North Exterior				
1068	Cafeteria South Exterior				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Audible And Visible					
142	A Wing Admin Hallway				
143	A Wing Admin Hallway				
144	A Wing Upper A Wing Hall				
145	A Wing Upper A Wing Hall				
146	A Wing Upper A Wing Hall				
147	A Wing Upper A Wing Hall				
148	A Wing Lower A Wing Hall				
149	A Wing Lower A Wing Hall				
150	A Wing Admin Offices				
151	A Wing Admin Offices				
152	A Wing Admin Offices				
153	A Wing Admin Offices				
154	A Wing Admin Offices				
155	A Wing PA Lobby				
156	A Wing PA Seating NE Entr				
157	A Wing PA Seating SE Entr				
158	A Wing PA Seating Area				
159	A Wing PA Seating Area				
160	A Wing PA Seating Area				
161	A Wing PA Seating Area				
162	A Wing PA Seating Area				
163	A Wing PA Seating Area				
164	A Wing PA Stage				
165	A Wing PA Stage				
166	A Wing PA Backstage				
167	A Wing Room A3				
168	A Wing Library				
169	A Wing Library				
170	A Wing Computer Lab				
171	A Wing Media Classroom A5				
172	A Wing Media Classroom A6				
173	A Wing Media Classroom A7				
174	A Wing Media Classroom A8				
175	A Wing Media Studio Rm A9				
176	A Wing Media Control A9A				
177	A Wing Media Dress Rm A12				
178	A Wing Media Dress Rm A13				
260	B Wing Womens Facilities				
261	B Wing B Wing Hallway				
262	B Wing B Wing Hallway				
263	B Wing B Wing Hallway				
264	B Wing B Wing Hallway				
265	B Wing B Wing Hallway				
266	B Wing Room B3				
267	B Wing Room B4				
268	B Wing Room B5				
269	B Wing Room B6				
270	B Wing Room B7				
271	B Wing Room B8				
272	B Wing Room B9				
273	B Wing Room B10				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
274	B Wing Room B11				
275	B Wing Room B12				
276	B Wing Science Portble B13				
316	C Wing C Wing Hallway				
317	C Wing C Wing Hallway				
318	C Wing C Wing Hallway				
319	C Wing Room C1				
320	C Wing Room C3				
321	C Wing Admin Breakroom				
322	C Wing Admin Breakroom				
323	C Wing Room C4				
324	C Wing Room C5				
380	D Wing Upper D Wing Hall				
381	D Wing Upper D Wing Hall				
382	D Wing Upper D Wing Hall				
383	D Wing Lower D Wing Hall				
384	D Wing Lower D Wing Hall				
385	D Wing Lower D Wing Hall				
386	D Wing Room D1				
387	D Wing Room D2				
388	D Wing Room D3				
389	D Wing Room D4				
390	D Wing Room D5				
391	D Wing Room D6				
392	D Wing Room D7				
393	D Wing Room D8				
394	D Wing Room D9				
395	D Wing Room D10				
396	D Wing Room D11				
397	D Wing Room D12				
398	D Wing Room D13				
399	D Wing Room D14				
400	D Wing Room D15				
401	D Wing Room D16				
402	D Wing Room D17				
403	D Wing Room D18				
404	D Wing Room D19				
405	D Wing Room D20				
461	E Wing E Wing Hallway				
462	E Wing E Wing Hallway				
463	E Wing E1A MDF Room				
464	E Wing E1 Photo Classroom				
465	E Wing Room E2				
466	E Wing Room E3				
467	E Wing Room E4				
468	E Wing Room E5				
469	E Wing Room E6				
487	F Wing Room F1				
488	F Wing Room F2				
489	F Wing Room F3				
490	F Wing Room F4				
491	F Wing Room F5				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
519	G Wing Room G1				
520	G Wing Room G2				
521	G Wing Room G3				
522	G Wing Room G4				
523	G Wing Room G5				
524	G Wing Room G6				
639	H Wing Auto Room H1				
640	H Wing Auto Room H1				
641	H Wing Auto Room H1				
642	H Wing Room H1C				
643	H Wing Room H2				
644	H Wing Room H3				
645	H Wing Room H5				
646	H Wing Room H5				
647	H Wing Room H5C				
648	H Wing Room H7				
649	H Wing Room H8				
650	H Wing Room H8				
651	H Wing Room H9				
688	I Wing Room I-1				
689	I Wing Room I-3				
690	I Wing I-1 Conference Room				
793	J Wing Room J1				
794	J Wing Room J4				
795	J Wing Room J5				
796	J Wing Room J5A				
797	J Wing Room J6				
798	J Wing Room J7				
799	J Wing Room J7A				
800	J Wing Room J8				
801	J Wing Room J9				
848	Nursery Buildings Nursery N1				
849	Nursery Buildings Nursery N2				
850	Nursery Buildings Upper Nursery				
913	Small Gym Hallway NW Exit				
914	Small Gym Hallway NE Exit				
915	Small Gym Hallway				
916	Small Gym Hallway				
917	Small Gym Basketball Court				
918	Small Gym Basketball Court				
919	Small Gym Basketball Court				
920	Small Gym Basketball Court				
921	Small Gym West Girls Locker				
922	Small Gym West Girls Locker				
923	Small Gym West Girls Locker				
924	Small Gym West Girls Locker				
925	Small Gym East Girls Locker				
926	Small Gym East Girls Locker				
927	Small Gym East Girls Locker				
999	Large Gym Front Entrance				
1000	Large Gym Front Entrance				
1001	Large Gym Basketball Court				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
1002	Large Gym Basketball Court				
1003	Large Gym Basketball Court				
1004	Large Gym Basketball Court				
1005	Large Gym Southeast Exit				
1006	Large Gym Southwest Exit				
1007	Large Gym Boys Locker Room				
1008	Large Gym Boys Locker Room				
1009	Large Gym Boys Locker Room				
1010	Large Gym Boys Locker Room				
1034	Weight Room East Interior Wall				
1035	Weight Room East Interior Wall				
1069	Cafeteria Room				
1070	Cafeteria Room				
1071	Cafeteria Room				
1072	Cafeteria Room				
1073	Cafeteria Kitchen				
1074	Cafeteria Kitchen				
1075	Cafeteria Kitchen				
1076	Cafeteria Kitchen				
1077	Cafeteria Kitchen				
1078	Cafeteria Alumni Room				
Visible					
179	A Wing Admin Hallway				
180	A Wing Lower A Wing Hall				
181	A Wing Admin Offices				
182	A Wing Admin Offices				
183	A Wing Admin Offices				
184	A Wing Admin Offices				
185	A Wing Admin Offices				
186	A Wing Admin Offices				
187	A Wing Admin Offices				
188	A Wing Admin Offices				
189	A Wing Admin Offices				
190	A Wing Men RR Admin N Hall				
191	A Wing Womens RR Admin N				
192	A Wing PA Steps North				
193	A Wing PA Stage				
194	A Wing Library Storage				
195	A Wing Media Staff RR A14				
196	A Wing Media Dress RR A12				
197	A Wing Media Dress RR A13				
198	A Wing Media Vestible Rm A9				
277	B Wing Womens Facilities				
278	B Wing Womens Facilit RR				
279	B Wing Room B5				
325	C Wing Admin Breakroom				
326	C Wing Admin Womens RR				
327	C Wing Admin Mens RR				
328	C Wing Admin Breakroom				
329	C Wing Admin Hallway				
330	C Wing Room C4				
406	D Wing Room D2				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
407	D Wing Room D2				
408	D Wing Mens Restroom				
409	D Wing Womens Restroom				
470	E Wing E1 Dark Room				
471	E Wing Custodial Office				
525	G Wing Room G2				
526	G Wing Restroom				
652	H Wing Auto Room H1				
653	H Wing Auto Room H1				
654	H Wing Room H2A				
655	H Wing H4 Mens Restroom				
656	H Wing Room H5A				
657	H Wing H6 Womens Restrm				
658	H Wing Room H8A				
691	I Wing Room I-2				
692	I Wing Room I-4				
693	I Wing Room I-1 Office				
694	I Wing Boys Restroom				
695	I Wing Girls Restroom				
802	J Wing Room J1				
803	J Wing Room J1A				
804	J Wing Room J1B				
805	J Wing Room J1C				
806	J Wing Room J1D				
807	J Wing Room J4				
808	J Wing Room J4				
809	J Wing Room J4				
810	J Wing Room J4A				
811	J Wing Room J5				
812	J Wing Room J6A				
813	J Wing Room J8				
814	J Wing Room J9A				
815	J Wing Room J11				
816	J Wing Room J11A				
851	Nursery Buildings Nursery N1 Office				
852	Nursery Buildings Nursery N1 Kitchen				
853	Nursery Buildings Nursery N1 Adult RR				
854	Nursery Buildings Nursery N1 Kids RR				
855	Nursery Buildings Upper Nursery RR				
856	Nursery Buildings Upper Nursery Closet				
928	Small Gym West Girls Locker				
929	Small Gym West Girls Locker				
930	Small Gym East Girls Locker				
931	Small Gym East Girls Locker				
932	Small Gym East Girls Locker				
1011	Large Gym Girls Restroom				
1012	Large Gym Boys Restroom				
1013	Large Gym Boys Locker Room				
1014	Large Gym Boys Locker Room				
1015	Large Gym Boys Locker Room				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
1079	Cafeteria Kitchen				
1080	Cafeteria Kitchen Restroom				
1081	Cafeteria Snack Bar				
1082	Cafeteria Alumni Room				

Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Remote Annunciator					
001	A Wing Reception				
Fire Alarm Panel					
	Main Fire Panel MDF Room	Notifier	NFS-3030		03/13/2020
	C Wing Fire Panel Room	Notifier	NFS-3030		03/13/2020

NAC Power Extender Panel

BPS H					01/19/2023
BPS N					01/19/2023
BPS T					01/19/2023
BPS R					01/19/2023
BPS P					01/19/2023
BPS C					01/19/2023

Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Manual Pull Station					
2-127 002	A Wing Reception				
2-171 003	A Wing Hallway by Room A2				
2-424 004	A Wing PA Lobby				
2-422 005	A Wing PA S Entrance				
4-132 006	A Wing Library Northeast				
4-133 007	A Wing Library Northwest				
4-134 008	A Wing Computer Lab				
3-476 200	B Wing B Wing Hall North				
4-389 201	B Wing Room B13 South				
4-390 202	B Wing Room B13 East				
4-1420 331	D Wing Upper D Hall West				
3-465 332	D Wing Lower D Hall East				
3-466 333	D Wing Lower D Hall West				
4-141 334	D Wing Room D2				
3-468 410	E Wing E Hall SW by Rm E2				
3-469 411	E Wing E Hall NW by Rm E3				
3-381 412	E Wing Room E3				
3-407 413	E Wing Room E4				
3-432 414	E Wing Room E4 Elec Rm				
3-429 415	E Wing Room E5				
3-430 416	E Wing Room E5 Kiln Rm				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3-431 417	E Wing Room E6				
3-245 472	F Wing Room F1				
3-246 473	F Wing Room F2				
3-247 474	F Wing Room F3				
3-248 475	F Wing Room F4				
3-249 476	F Wing Room F5				
3-238 493	G Wing Room G1				
3-239 494	G Wing Room G2				
3-240 495	G Wing Room G3				
3-241 496	G Wing Room G4				
2-242 497	G Wing Room G5 South				
3-243 498	G Wing Room G5 West				
3-244 499	G Wing Room G6				
3-224 527	H Wing Room H1 South Exit				
3-225 528	H Wing Room H1 North Exit				
3-226 529	H Wing Room H2 South Exit				
3-227 530	H Wing Room H2 West Exit				
3-228 531	H Wing Room H3 South Exit				
3-229 532	H Wing Room H3 East Exit				
3-230 533	H Wing Room H5 West Exit				
3-231 534	H Wing Room H5 East Exit				
3-232 535	H Wing Room H8 West Exit				
3-233 536	H Wing Room H8 East Exit				
3-187 661	I Wing Room I-1 South				
3-184 662	I Wing Room I-1 North				
3-186 663	I Wing Room I-2 South				
3-185 664	I Wing Room I-2 North				
3-236 696	J Wing Culinary Caf? East				
3-235 697	J Wing Culinary Caf? South				
3-234 698	J Wing Rm J4 Kitchen West				
3-237 699	J Wing Room J9 North				
3-171 818	Nursery Buildings Nursery N1 South				
3-172 819	Nursery Buildings Nursery N1 North				
3-174 820	Nursery Buildings Nursery N2 North				
3-173 821	Nursery Buildings Nursery N2 South				
3-175 822	Nursery Buildings Upper Nursery East				
3-176 823	Nursery Buildings Upper Nursery West				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3-474 857	Small Gym Sm Gym Hall by B12				
3-475 858	Small Gym Sm Gym Hall S Exit				
3-470 859	Small Gym Sm Gym Hall by E1				
3-471 860	Small Gym West Girls Locker				
3-473 861	Small Gym Basketball Court NW				
4-393 933	Large Gym Front Entrance NW				
4-394 934	Large Gym Front Entrance NE				
4-392 935	Large Gym Southwest Exit				
4-391 936	Large Gym Southeast Exit				
4-388 1016	Weight Room Northeast Exit				
4-450 1017	Weight Room Southeast Exit				
4-398 1036	Cafeteria Southwest Exit				
4-404 1037	Cafeteria Southeast Exit				
4-397 1038	Cafeteria Northeast Exit				
4-396 1039	Cafeteria Northwest Exit				
4-405 1040	Cafeteria Kitchen East Exit				
4-469 1041	Cafeteria Kitchen Office				
3-472	Small Gym Basketball NW				
3-472	Small Gym Basketball NW				
4-002	A Wing Computer Lab				
4-387	Weight Room South Exit				
Smoke Detector - General					
2-030 009	A Wing Attendance Hall A1i				
2-029 010	A Wing Attendance A1A				
2-026 011	A Wing Finance Office A1G				
2-028 012	A Wing Work Room A1B				
2-031 013	A Wing Work Room A1B RR				
2-033 014	A Wing Fire Riser Admin E				
2-032 015	A Wing Electrical Room A1C				
2-024 016	A Wing Principals Office A1D				
2-023 017	A Wing Reception Hall A1F				
2-022 018	A Wing Office A1E				
2-021 019	A Wing Reception A1F				
2-027 020	A Wing Attendance Hall A1i				
2-019 022	A Wing Lobby Skylight A1H				
2-018 023	A Wing Display Case A1H				
2-025 024	A Wing Lobby Display A1H				
2-042 026	A Wing Hallway to B Wing				
2-041 027	A Wing Hallway by A2A				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-014 028	A Wing VP Office Hall A2A				
2-016 029	A Wing VP Work Room A2B				
2-015 030	A Wing VP Office A2C				
2-013 031	A Wing VP Office A2D				
2-012 032	A Wing VP Office A2E				
2-043 033	A Wing Conference Rm A2F				
2-044 034	A Wing PE-f IDF Clst Hall A2A				
2-040 035	A Wing Admin North Hallway				
2-037 036	A Wing Men RR Admin N Hall				
2-038 037	A Wing Men RR Admin N Hall				
2-036 038	A Wing Womens RR Admin N				
2-035 039	A Wing Womens RR Admin N				
2-307 040	A Wing PA Lobby				
2-306 041	A Wing PA Lobby				
2-310 042	A Wing PA Lobby				
2-309 043	A Wing PA Seating NE Entr				
2-301 044	A Wing PA Upper Seating				
2-304 045	A Wing PA Upper Seating				
2-303 046	A Wing PA Lower Seating				
2-302 047	A Wing PA Lower Seating				
2-305 048	A Wing PA Upper Seating				
2-300 049	A Wing PA Upper Seating				
2-299 050	A Wing PA Lower Seating				
2-298 051	A Wing PA Lower Seating				
2-296 052	A Wing PA Lower Seating				
2-295 053	A Wing PA Lower Seating				
2-308 054	A Wing PA Seating SE Entr				
2-294 055	A Wing PA Steps North				
2-297 056	A Wing PA Steps South				
2-293 057	A Wing PA Stage				
2-292 058	A Wing PA Stage				
2-291 059	A Wing PA Stage				
2-287 060	A Wing PA Backstage				
2-288 061	A Wing Room A3A Storage				
2-290 062	A Wing Room A3				
2-289 063	A Wing Room A3				
4-007 064	A Wing Library				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
4-006 065	A Wing Library				
4-055 066	A Wing Library				
4-004 067	A Wing Library				
4-003 068	A Wing Library				
4-010 069	A Wing Library Classroom				
4-009 070	A Wing Library Storage				
4-008 071	A Wing Library Storage				
4-001 072	A Wing Computer Lab				
4-002 073	A Wing Computer Lab				
2-257 074	A Wing Media Classroom A5				
2-255 075	A Wing Media Classroom A5				
2-256 076	A Wing Media Classroom A5				
2-258 077	A Wing Media Classroom A6				
2-260 078	A Wing Media Classroom A6				
2-259 079	A Wing Media Classroom A6				
2-262 080	A Wing Media Classroom A7				
2-264 081	A Wing Media Classroom A7				
2-263 082	A Wing Media Classroom A7 Storage				
2-254 083	A Wing Media Classroom A8				
2-253 084	A Wing Media Classroom A8				
2-280 085	A Wing Media Studio Rm A9				
2-281 086	A Wing Media Studio Rm A9				
2-279 087	A Wing Media Studio Rm A9				
2-282 088	A Wing Media Studio Rm A9				
2-269 089	A Wing Media Vestible Rm A9				
2-270 090	A Wing Media Control A9A				
2-278 091	A Wing Media Wardrobe A9B				
2-277 092	A Wing Media Elect Rm A10				
2-276 093	A Wing Media Stroage A11				
2-272 094	A Wing Media Dress Rm A12				
2-273 095	A Wing Media Dress RR A12				
2-268 096	A Wing Media Dress Rm A13				
2-267 097	A Wing Media Dress Rm A13				
2-274 098	A Wing Media Staff RR A14				
2-265 099	A Wing Media Corridor A15				
2-261 100	A Wing Media Corridor A15				
2-275 101	A Wing Media Janitor Rm A16				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-266 102	A Wing Media IDF Room A17				
2-286 103	A Wing IDF Closet Rm A18				
2-053 203	B Wing Womens Facilities				
2-059 204	B Wing Hall by Room B3				
4-256 205	B Wing Science Portble B13				
4-257 206	B Wing Science Portble B13				
4-255 207	B Wing Science Portble B13				
4-254 208	B Wing Science Portble B13				
4-064 241	B Wing Room B12				
2-084 281	C Wing Fire Panel Room				
4-011 282	C Wing West Hall Fire Door				
4-017 283	C Wing Room C1				
4-023 284	C Wing Rm C3 VP Office				
4-033 285	C Wing Rm C3 Nurse Rm.				
4-024 289	C Wing Rm C3 VP Office				
4-028 291	C Wing Admin Breakroom				
4-030 292	C Wing Admin Breakroom				
2-283 294	A Wing Vestibule Rm A9				
4-040 295	C Wing Room C4				
4-060 300	C Wing Admin Room by C4				
3-290 335	D Wing Low D Wing IDF Clst				
3-315 336	D Wing Room D12				
3-316 337	D Wing Room D12				
2-005 418	E Wing E1A MDF Room				
2-004 419	E Wing E1A MDF Room				
2-003 420	E Wing E1A MDF Room				
2-002 421	E Wing E1A MDF Basement				
2-009 422	E Wing E1A MDF Basement				
2-006 423	E Wing E1A MDF Basement				
2-007 424	E Wing E1A MDF Basement				
2-008 425	E Wing E1A MDF Basement				
3-299 426	E Wing Custodial Office				
3-302 427	E Wing Room E3				
3-301 428	E Wing Room E3				
3-300 429	E Wing Room E3				
3-311 430	E Wing Room E6				
3-056 500	G Wing Room G1				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3-072 501	G Wing Room G1				
3-044 502	G Wing Room G5				
3-043 503	G Wing Room G5				
3-006 537	H Wing Room H1B				
3-003 538	H Wing Room H1B				
3-005 539	H Wing Room H1C				
3-004 540	H Wing Room H1C				
3-018 541	H Wing Room H2				
3-014 542	H Wing Room H2				
3-015 543	H Wing Room H2				
3-019 544	H Wing Room H2				
3-012 545	H Wing Room H2A				
3-016 546	H Wing Room H3				
3-020 547	H Wing Room H3				
3-021 548	H Wing Room H3				
3-017 549	H Wing Room H3				
3-013 550	H Wing H4 Mens Restroom				
3-011 551	H Wing Room H5A				
3-010 552	H Wing Room H5B				
3-025 553	H Wing Room H5C				
3-024 554	H Wing Room H5C				
3-022 555	H Wing H6 Womens Restrm				
3-028 556	H Wing Room H7				
3-026 557	H Wing Room H7				
3-029 558	H Wing Room H8A				
3-030 559	H Wing Room H8B				
3-023 560	H Wing Room H9				
3-027 561	H Wing Room H9				
3-009 562	H Wing Room H10				
3-069 665	I Wing Room I-1 Office				
3-034 666	I Wing I-1 Conference Room				
3-039 667	I Wing Boys Restroom				
3-038 668	I Wing Electrical Room				
3-037 669	I Wing Girls Restroom				
3-291 700	J Wing Room J1A				
3-289 701	J Wing Room J1B				
3-297 702	J Wing Room J1C				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3-296 703	J Wing Room J1D				
3-293 704	J Wing Room J4				
3-294 705	J Wing Room J4				
3-277 706	J Wing Room J4A				
3-269 707	J Wing Room J5				
3-270 708	J Wing Room J5				
3-275 709	J Wing Room J5				
3-276 710	J Wing Room J5A				
3-267 711	J Wing Room J6				
3-278 712	J Wing Room J6				
3-271 713	J Wing Room J6				
3-274 714	J Wing Room J6A				
3-257 715	J Wing Room J7A				
3-255 716	J Wing Room J7B				
3-272 717	J Wing Room J7C				
3-284 718	J Wing Room J7D				
3-258 719	J Wing Room J8				
3-264 720	J Wing Room J9A				
3-259 721	J Wing Room J9B				
3-256 722	J Wing Room J10				
3-283 723	J Wing Room J11				
3-285 724	J Wing Room J11				
3-288 725	J Wing Room J11				
3-286 726	J Wing Room J11A				
3-287 727	J Wing Room J11B				
3-281 728	J Wing Room J11C				
3-282 729	J Wing Room J11D				
3-292 730	J Wing Room J11D1				
3-290 731	J Wing Room J12				
3-073 824	Nursery Buildings Nursery N1				
3-074 825	Nursery Buildings Nursery N1				
3-075 826	Nursery Buildings N1/N2 Office				
3-070 827	Nursery Buildings Nursery N1 Closet				
3-079 828	Nursery Buildings Nursery N2				
3-080 829	Nursery Buildings Nursery N2				
3-081 830	Nursery Buildings N2 Washer/Dryer Clst				
3-086 831	Nursery Buildings Upper Nursery				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3-087 832	Nursery Buildings Upper Nursery				
3-085 833	Nursery Buildings Upper Nursery				
4-104 863	Small Gym Basketball Court				
4-093 864	Small Gym Basketball Court				
4-091 865	Small Gym Basketball Court				
2-342 866	Small Gym Basketball Court				
4-090 867	Small Gym Basketball Court				
4-089 868	Small Gym Basketball Court				
4-083 869	Small Gym Basketball Court				
4-084 870	Small Gym Basketball Court				
4-085 871	Small Gym Basketball Court				
4-086 872	Small Gym Basketball Court				
4-087 873	Small Gym Basketball Court				
4-088 874	Small Gym Basketball Court				
4-082 875	Small Gym Basketball Court				
4-081 876	Small Gym Basketball Court				
4-080 877	Small Gym Basketball Court				
4-079 878	Small Gym Basketball Court				
4-078 879	Small Gym Basketball Court				
4-077 880	Small Gym Basketball Court				
4-298 937	Large Gym Front Entrance				
4-294 938	Large Gym Front Entrance				
4-322 939	Large Gym Strg by Snack Bar				
4-333 940	Large Gym Basketball Court				
4-338 941	Large Gym Basketball Court				
4-343 942	Large Gym Basketball Court				
4-350 943	Large Gym Basketball Court				
4-337 944	Large Gym Basketball Court				
4-342 945	Large Gym Basketball Court				
4-318 946	Large Gym Basketball Court				
4-314 947	Large Gym Basketball Court				
4-307 948	Large Gym Basketball Court				
4-304 949	Large Gym Basketball Court				
4-302 950	Large Gym Basketball Court				
4-309 951	Large Gym Basketball Court				
4-312 952	Large Gym Basketball Court				
4-320 953	Large Gym Basketball Court				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
4-317 954	Large Gym Basketball Court				
4-315 955	Large Gym Basketball Court				
4-306 956	Large Gym Basketball Court				
4-305 957	Large Gym Basketball Court				
4-301 958	Large Gym Basketball Court				
4-310 959	Large Gym Basketball Court				
4-311 960	Large Gym Coaches Off Storage				
4-321 1042	Cafeteria Kitchen Office				
3-048	G Wing Room G4				
2-073	B6 Storage				
2-073	B6 Storage				
2-073	B6 Storage				
4-022	C Wing Rm C3 VP Office				
4-021	C Wing Rm C3 VP hall				
4-019	C Wing Rm C3 VP Office				
4-026	C Wing Rm C3 VP Offices				02/21/2019
4-025	C Wing Rm C3 VP Offices				
4-036	C Wing Room C4 Office				02/21/2019
4-034	C Wing Room C4 Office				
4-037	C Wing Room C4 Office				
2-271	A Wing Media Staff RM Corridor				
Heat Detector - Restorable Spot					
2-039 104	A Wing Front Entrance Hall				
2-047 105	A Wing Auditorium Hallway				
2-037 106	A Wing West Hallway				
2-048 107	A Wing West Hallway				
2-378 108	A Wing Attic Room A5				
2-378 109	A Wing Attic Room A5				
2-381 110	A Wing Attic Room A6				
2-381 111	A Wing Attic Room A6				
2-383 112	A Wing Attic Room A7				
2-383 113	A Wing Attic Room A7				
2-376 114	A Wing Attic Room A8				
2-376 115	A Wing Attic Room A8				
2-389 116	A Wing Attic Studio Room A9				
2-376 117	A Wing Attic Library				
2-051 209	B Wing Work Room				
2-052 210	B Wing Womens Facilit RR				
2-055 211	B Wing Room B3 North				
2-054 212	B Wing Room B3 South				
2-056 213	B Wing Room B4				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-057 214	B Wing Room B4				
2-060 215	B Wing Room B5				
2-061 216	B Wing Room B5				
2-066 217	B Wing Room B5				
2-067 218	B Wing Room B5				
2-058 219	B Wing B Wing Hall by B5				
2-063 220	B Wing Room B4A				
2-062 221	B Wing Room B4B				
2-065 222	B Wing B Wing Hall by B6				
2-071 223	B Wing Room B6				
2-064 224	B Wing Room B6				
2-070 225	B Wing B Wing Hall by B6/B7				
2-068 226	B Wing Room B7				
2-069 227	B Wing Room B7				
2-077 228	B Wing Room B7A				
2-078 229	B Wing Room B7A1				
2-074 230	B Wing Room B8				
2-075 231	B Wing Room B8				
2-102 232	B Wing Room B8A				
2-101 233	B Wing Room B8A				
2-076 234	B Wing B Wing Hall by B8				
2-081 235	B Wing B Wing Hall by B9				
2-080 236	B Wing Room B9				
2-079 237	B Wing Room B9				
2-082 238	B Wing Room B10				
2-083 239	B Wing Room B11				
4-063 240	B Wing Room B12				
4-065 242	B Wing B Wing Hall by B12				
2-128 243	B Wing Attic Womens Facilt				
2-131 244	B Wing Attic Room B4A				
2-131 245	B Wing Attic Room B4A				
2-131 246	B Wing Attic Room B4A				
2-130 247	B Wing Attic Room B5				
2-132 248	B Wing Attic Room B8A				
2-132 249	B Wing Attic Room B8A				
2-132 250	B Wing Attic Room B8A				
2-129 251	B Wing Attic B Hall by E Exit				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-134 252	B Wing Attic B Wing Hall				
2-133 253	B Wing Attic Hall Closet				
4-384 254	B Wing Attic Portable B13				
4-384 255	B Wing Attic Portable B13				
4-384 256	B Wing Attic Portable B13				
4-384 257	B Wing Attic Portable B13				
4-020 303	C Wing C Wing Hall Closet				
4-031 304	C Wing C Wing Hall by C3				
4-027 305	C Wing Admin Womens RR				
4-029 306	C Wing Admin Mens RR				
4-038 309	C Wing Admin RR by C4				
4-039 310	C Wing Room C5				
2-377 314	C Wing Attic Admin Classrm				
3-324 338	D Wing D Wing Hall East				
4-041 339	D Wing Room D1				
4-046 340	D Wing D Wing Hall by D1				
4-050 341	D Wing Room D2				
4-051 342	D Wing Room D2				
4-052 343	D Wing Room D2				
4-054 344	D Wing Room D2				
4-053 345	D Wing Room D2				
4-042 346	D Wing Room D3				
4-055 347	D Wing Room D4				
4-048 348	D Wing D Wing Hall by D4				
4-043 349	D Wing Room D5				
4-056 350	D Wing Room D6				
4-044 351	D Wing Room D7				
4-057 352	D Wing Room D8				
4-049 353	D Wing D Wing Hall by D8				
4-045 354	D Wing Room D9				
3-339 355	D Wing D Wing Mens RR				
3-322 356	D Wing D Wing Womens RR				
3-337 357	D Wing Low D Wing IDF Clst				
3-321 358	D Wing Custodial Closet				
3-327 359	D Wing D Wing Hall by D10				
3-335 360	D Wing Room D10				
3-325 361	D Wing Room D11				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3-326 362	D Wing Room D11 Storage				
3-328 363	D Wing Room D13				
3-327 364	D Wing Room D13 Storage				
3-317 365	D Wing Room D14				
3-329 366	D Wing D Wing Hall by D14				
3-330 367	D Wing Room D15				
3-318 368	D Wing Room D16				
3-331 369	D Wing D Wing Hall by D16				
3-332 370	D Wing Room D17				
3-333 371	D Wing D Wing Hall by D17				
3-319 372	D Wing Room D18				
3-334 373	D Wing Room D19				
3-320 374	D Wing Room D20				
3-378 375	D Wing Attic Room D2				
376	D Wing Plum Chs Wom RR				
377	D Wing Plum Chs Mens RR				
2-346 431	E Wing E1A MDF Room				
4-103 432	E Wing E1 Photo Classroom				
4-102 433	E Wing E1 Dark Room				
4-018 434	E Wing E1 Photo Rm Storage				
3-298 436	E Wing Room E2				
3-304 438	E Wing Room E4				
3-303 439	E Wing Room E4				
3-305 440	E Wing Room E4				
3-307 441	E Wing Room E5				
3-308 442	E Wing Room E5				
3-306 443	E Wing Room E5				
3-336 444	E Wing Room E5 Closet				
3-313 445	E Wing Room E6				
3-312 446	E Wing Room E6				
3-310 447	E Wing Room E6				
3-309 448	E Wing Room E6				
3-437 449	E Wing Attic Cust Office				
3-384 450	E Wing Attic Room E3				
3-384 451	E Wing Attic Room E3				
3-384 452	E Wing Attic Room E3				
3-384 453	E Wing Attic Room E3				
3-346 454	E Wing Attic Room E4				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3-346 455	E Wing Attic Room E4				
3-346 456	E Wing Attic Room E4				
3-346 457	E Wing Attic Room E4				
3-385 458	E Wing Attic Room E5				
3-057 477	F Wing Room F1				
3-058 478	F Wing Room F2				
3-059 479	F Wing Room F3				
3-060 480	F Wing Room F4				
3-063 481	F Wing Room F5				
3-062 482	F Wing Room F5				
3-061 483	F Wing Room F5				
3-064 484	F Wing Room F5				
3-065 485	F Wing Room F5 Storage				
3-022 505	G Wing Room G2				
3-054 506	G Wing Room G2				
3-055 507	G Wing Room G3				
3-051 508	G Wing Room G3				
3-050 509	G Wing Room G3				
3-052 510	G Wing Room G3				
3-049 511	G Wing Room G4				
3-047 512	G Wing Room G4 Storage				
3-046 513	G Wing Room G4 Storage				
3-042 514	G Wing Room G6				
3-040 515	G Wing Room G6 Storage				
3-008 516	G Wing Room G6 Storage				
3-045 517	G Wing Restroom				
3-134 563	H Wing Auto Room H1				
3-134 564	H Wing Auto Room H1				
3-134 565	H Wing Auto Room H1				
3-134 566	H Wing Auto Room H1				
3-133 567	H Wing Auto Room H1				
3-133 568	H Wing Auto Room H1				
3-133 569	H Wing Auto Room H1				
3-133 570	H Wing Auto Room H1				
3-132 571	H Wing Auto Room H1				
3-132 572	H Wing Auto Room H1				
3-132 573	H Wing Auto Room H1				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3-132 574	H Wing Auto Room H1				
3-131 575	H Wing Auto Room H1				
3-131 576	H Wing Auto Room H1				
3-131 577	H Wing Auto Room H1				
3-131 578	H Wing Auto Room H1				
3-129 579	H Wing Auto Room H1				
3-129 580	H Wing Auto Room H1				
3-129 581	H Wing Auto Room H1				
3-129 582	H Wing Auto Room H1				
3-135 583	H Wing Auto Room H1A				
3-145 585	H Wing Art Room H5				
3-145 586	H Wing Art Room H5				
3-145 587	H Wing Art Room H5				
3-145 588	H Wing Art Room H5				
3-146 589	H Wing Art Room H5				
3-146 590	H Wing Art Room H5				
3-146 591	H Wing Art Room H5				
3-146 592	H Wing Art Room H5				
3-157 593	H Wing Room H8				
3-157 594	H Wing Room H8				
3-157 595	H Wing Room H8				
3-157 596	H Wing Room H8				
3-158 597	H Wing Room H8				
3-158 598	H Wing Room H8				
3-158 599	H Wing Room H8				
3-158 600	H Wing Room H8				
3-139 601	H Wing Attic Room H2A				
3-140 602	H Wing Attic Room H2A				
3-141 603	H Wing Attic H4 Mens RR				
3-138 604	H Wing Attic Room H5A				
3-151 605	H Wing Attic Room H5C				
3-152 606	H Wing Attic Room H5C				
3-152 607	H Wing Attic Room H5C				
3-150 608	H Wing Attic H6 Womens RR				
3-154 609	H Wing Attic Room H8A				
3-068 670	I Wing Room I-1				
3-067 671	I Wing Room I-2				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3-066 672	I Wing Room I-3				
3-038 673	I Wing Room I-4				
3-035 674	I Wing Custodial Closet				
3-036 675	I Wing Electrical Room				
3-167 676	I Wing Attic Room I-1				
3-167 677	I Wing Attic Room I-1				
3-168 678	I Wing Attic Room I-2				
3-168 679	I Wing Attic Room I-2				
3-156 680	I Wing Attic Room I-3				
3-156 681	I Wing Attic Room I-3				
3-155 682	I Wing Attic Room I-4				
3-155 683	I Wing Attic Room I-4				
3-132 684	I Wing Attic Boys Restroom				
3-131 685	I Wing Attic Girls Restroom				
3-294 732	J Wing Room J4				
3-280 733	J Wing Room J4				
3-295 734	J Wing Room J4				
3-279 735	J Wing Room J4B				
3-273 736	J Wing Room J7				
3-268 737	J Wing Room J7				
3-260 738	J Wing Rm J9 Foods 1 2				
3-261 739	J Wing Rm J9 Foods 1 2				
3-262 740	J Wing Rm J9 Foods 1 2				
3-263 741	J Wing Rm J9 Foods 1 2				
3-265 742	J Wing Rm J9 Foods 1 2				
3-266 743	J Wing Rm J9 Foods 1 2				
3-413 744	J Wing Attic Room J1A				
3-428 745	J Wing Attic Room J2				
3-426 746	J Wing Attic Room J3				
3-427 747	J Wing Attic Room J4				
3-397 748	J Wing Attic Room J6				
3-388 749	J Wing Attic Room J7				
3-383 750	J Wing Attic Room J9				
3-382 751	J Wing Attic Room J9A				
3-377 752	J Wing Attic Room J9B				
3-409 753	J Wing Attic Room J11				
3-076 834	Nursery Buildings N1/N2 Adult RR				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3-078 835	Nursery Buildings N1/N2 Kitchen				
3-077 836	Nursery Buildings N1/N2 Kids RR				
3-083 838	Nursery Buildings Upp Nurs Adult RR				
3-084 839	Nursery Buildings Upper Nursery Office				
3-181 840	Nursery Buildings Attic Nursery N1				
3-181 841	Nursery Buildings Attic Nursery N1				
3-182 842	Nursery Buildings Attic Nursery N2				
3-182 843	Nursery Buildings Attic Nursery N2				
3-183 844	Nursery Buildings Attic Upper Nursery				
3-183 845	Nursery Buildings Attic Upper Nursery				
4-062 882	Small Gym Small Gym Hallway				
4-067 883	Small Gym Small Gym Hallway				
4-066 884	Small Gym Small Gym Hallway				
4-068 885	Small Gym Hallway				
4-096 887	Small Gym E Lock Hall by RR				
4-095 888	Small Gym East Locker RR				
4-094 889	Small Gym E Locker Clst by RR				
4-097 890	Small Gym East Locker Office				
4-129 891	Small Gym E Locker Office RR				
4-098 892	Small Gym E Lock Strg by Off				
2-351 893	Small Gym E Lock Closet North				
4-076 894	Small Gym East Girls Locker Rm				
4-074 895	Small Gym East Girls Locker Rm				
4-073 896	Small Gym East Girls Locker Rm				
4-062 897	Small Gym W Lock Hall by RR				
4-070 898	Small Gym W Locker Restroom				
4-069 899	Small Gym W Lock Cust Clst				
4-075 900	Small Gym W Locker Office				
2-062 901	Small Gym W Lock Office RR				
4-072 902	Small Gym West Girls Locker Rm				
4-072 903	Small Gym West Girls Locker Rm				
4-072 904	Small Gym West Girls Locker Rm				
4-074 905	Small Gym W Lock Storage NE				
4-073 906	Small Gym W Lock Sm Storage				
4-076 908	Small Gym W Lock Strg by N Ext				
2-322 909	Small Gym W Lock Plum Chase				
4-299 961	Large Gym Girls Restroom				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
4-300 962	Large Gym Storage Room				
4-297 963	Large Gym Front Storage Room				
4-296 965	Large Gym Food Counter				
4-324 966	Large Gym Storage Room				
4-293 967	Large Gym Boys Restroom				
4-316 968	Large Gym Announcers Booth				
4-336 969	Large Gym Announcers Booth				
4-258 970	Large Gym Announcers Booth				
4-359 971	Large Gym Electrical Room				
4-360 972	Large Gym Hall Southwest				
4-378 973	Large Gym Boys Locker RR W				
4-325 974	Large Gym Coaches Office				
4-326 975	Large Gym Coaches Office				
4-332 976	Large Gym Coaches Off Storage				
4-331 977	Large Gym Storage Closet				
4-292 978	Large Gym Storage				
4-378 979	Large Gym Boys Locker Room				
4-378 980	Large Gym Boys Locker Room				
4-378 981	Large Gym Boys Locker RR E				
4-253 982	Large Gym Team Room				
4-378 983	Large Gym Team Room Storage				
4-329 984	Large Gym Storage Closet				
4-333 985	Large Gym Hall Southeast				
4-365 986	Large Gym East Storage Closet				
4-377 987	Large Gym Attic Storage NW				
4-377 988	Large Gym Attic Storage NW				
4-376 989	Large Gym Attic Storage NE				
4-376 990	Large Gym Attic Storage NE				
4-265 1018	Weight Room Weight Room				
4-264 1019	Weight Room Weight Room				
4-262 1020	Weight Room Weight Room				
4-266 1021	Weight Room Weight Room				
4-259 1022	Weight Room Weight Room				
4-268 1023	Weight Room Weight Room				
4-263 1024	Weight Room Weight Room				
4-261 1025	Weight Room Weight Room				
4-269 1026	Weight Room North Storage				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
4-270 1027	Weight Room North Storage				
4-272 1028	Weight Room North Storage				
4-260 1029	Weight Room South Storage				
4-267 1030	Weight Room				
4-271 1031	Weight Room South Storage				
4-379 1032	Weight Room Attic North				
4-380 1033	Weight Room Attic South				
4-278 1043	Cafeteria Room				
4-281 1044	Cafeteria Room				
4-275 1045	Cafeteria Room				
4-279 1046	Cafeteria Room				
4-273 1047	Cafeteria Room				
4-276 1048	Cafeteria Room				
4-277 1049	Cafeteria Room				
4-274 1050	Cafeteria Room				
4-280 1051	Cafeteria Room				
4-286 1052	Cafeteria Kitchen				
4-283 1053	Cafeteria Kitchen Dish Wash				
4-285 1054	Cafeteria Kitchen				
4-288 1055	Cafeteria Kitchen				
4-289 1056	Cafeteria Kitchen Restroom				
4-323 1057	Cafeteria Snack Bar				
4-322 1058	Cafeteria Snack Bar Storage				
4-287 1059	Cafeteria Alumni Room				
4-334 1060	Cafeteria Kitchen O/S Storage				
4-335 1062	Cafeteria Utility Closet				
4-381 1063	Cafeteria Attic				
4-382 1064	Cafeteria Attic Kitchen				
4-383 1065	Cafeteria Attic Kitchen				
4-383 1066	Cafeteria Attic Kitchen				
4-100	Small Gym Hall				
4-101	Small Gym Hall				
4-105	Small Gym Hall				
4-106	Small Gym Hall				
4-101	Small Gym Hall				
4-105	Small Gym Hall				
4-106	Small Gym Hall				
2-072	B6 Storage				
2-072	B6 Storage				
2-072	B6 Storage				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-049	A Wing Auditorium Hallway				
4-032	C Wing Admin Breakroom				
4-058	Old Boiler Room				
4-013	C Wing C Wing Hallway				
4-014	C Wing C Wing Hallway				
4-015	C Wing C Wing Hallway				
4-016	C Wing C Wing Hallway				
4-012	C Wing C Wing Hallway				
4-047	D Wing D Wing Hall by D4				
2-050	A Wing Front Entrance Hall				
3-082	Nursery arm N-3 Off				
3-041	Rm G-6				
3-053	Room G-2				
4-130	Small Gym Locker Rm Attic				
4-061	Small Gym Small Gym Hallway				
4-099	Small Gym Closet				
4-291	Cafeteria Snack Bar				
4-290	Cafeteria Snack Bar Storage				
Smoke Detector - Duct					
2-141 118	A Wing Admin Hallway				
2-379 119	A Wing HVAC Room A5				
2-380 120	A Wing HVAC Room A6				
2-383 121	A Wing HVAC Room A7				
2-377 122	A Wing HVAC Room A8				
2-390 123	A Wing HVAC Room A9				
2-388 124	A Wing HVAC Corridor A14				
2-420 125	A Wing HVAC PA SW				
2-421 126	A Wing HVAC PA Roof				
3-128 610	H Wing Auto Room H1C				
3-160 611	H Wing Room H2A Attic				
3-161 612	H Wing Room H2A Attic				
3-142 613	H Wing Room H8				
3-143 614	H Wing Room H5C Attic				
3-144 615	H Wing Room H5C Attic				
3-162 616	H Wing Room H5C Attic				
3-163 617	H Wing Room H5C Attic				
3-165 618	H Wing Room H5C Attic				
3-166 619	H Wing Room H5C Attic				
3-387 754	J Wing ACU-2 J6				
3-389 755	J Wing MAU-2 J6				
3-391 756	J Wing ACU-5 J11				
3-393 757	J Wing ACU-3 J6				
3-398 758	J Wing ACU-1 J6				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3-399 759	J Wing ACU-4 J6				
3-400 760	J Wing ACU-6 J6				
3-404 761	J Wing MAU-1 J6				
3-416 762	J Wing ACU-5 J11				
4-462 991	Large Gym Boys Locker North				
4-463 992	Large Gym Boys Locker Roof S				
4-464 993	Large Gym Boys Locker Roof W				
4-465 994	Large Gym Boys Locker Roof E				
4-466 995	Large Gym North Foyer				
Mechanical, Electrosonic, or Pressure Waterflow Device					
2-145 127	A Wing Sprinkler Riser Admin				
3-126 623	H Wing H1 Bldg/SW Exterior				
3-136 624	H Wing H2-H10 Bldg/SW Ext				
3-410 784	J Wing Room J12				
Valve Tamper Switch					
2-144 128	A Wing Sprinkler Riser Admin				
2-143 129	A Wing PIV - NE of Admin				
2-143 130	A Wing OSY - NE of Admin				
2-143 131	A Wing OSY - NE of Admin				
3-127 625	H Wing Auto Room H1				
3-137 626	H Wing Rooms H2-H10 Bldg				
3-137 627	H Wing PIV - SE of Room H1				
3-137 628	H Wing OSY/SE of Rm H1				
3-137 629	H Wing OSY/SE of Rm H1				
3-411 785	J Wing Room J12 - OSY				
3-376 786	J Wing PIV - NE Side of Bldg				
3-376 787	J Wing OSY/NE of Bldg				
3-376 788	J Wing OSY/NE of Bldg				
Smoke Detector - Projected Beam					
3-420 781	J Wing Room J1				
3-422 782	J Wing Room J1				
3-424 783	J Wing Room J1				