

# Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

OTTOMON ELEMENTARY

9460 OTTOMON WAY  
ORANGEVALE, California  
United States

This site has been inspected and tested in compliance with applicable standards.

Completed  
Thursday, July 24, 2025

Test Session :23 Jul 2025 06:31 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD  
5320 HEMLOCK ST  
SACRAMENTO, California  
United States

TESTED BY

Riley Goyet  
Western States Fire Protection-  
Sacramento  
188 Cirby Way  
Roseville, CA 95678  
United States



# Inspection Summary

## Building Information

PROPERTY	OTTOMON ELEMENTARY	CONTACT
ADDRESS	9460 OTTOMON WAY	PHONE
CITY/STATE/ZIP	ORANGEVALE, California	MOBILE
COUNTRY	United States	EMAIL

## Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us

## Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Power Supplies	5	5(100%)	5(100%)	0(0%)
Initiating Device	207	206(100%)	206(100%)	0(0%)
Alarm Notification Appliance	1	1(100%)	1(100%)	0(0%)
Water-Based Fire Protection Systems	1	1(100%)	1(100%)	0(0%)

## Certification

The equipment specified herein was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Thursday, July 24, 2025

ACCEPTED BY      07/24/2025  
  
Building Representative

TESTED BY      07/24/2025  
Riley Goyet  
Technician

*Riley*

## System Details

### Primary Power

ADDRESS / SCAN ADDRESS	/ 045	DESCRIPTION	Admin / MP Bldg MP Rm Elect Rm
TYPE	Primary Power	PROTECTION	
NOMINAL VOLTAGE		AMPS	
NOMINAL AMPS		DISCONNECT	
LOCATION			

ADDRESS / SCAN ADDRESS	/ 046	DESCRIPTION	Admin / MP Bldg MP Rm Elect Rm
TYPE	Primary Power	PROTECTION	
NOMINAL VOLTAGE		AMPS	
NOMINAL AMPS		DISCONNECT	
LOCATION			

### Secondary Power

# Open Corrective Action & Solution Summary

The following 1 corrective action(s) remain open following the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
BPS - Booster Power Supply	1	BPS-B

Created By: Kurtis Boller  
Creation Date: 01/12/2024  
Corrective Action: Both 12v 8amp batteries failed  
Proposed Solution:  
Manufacturer:  
Model:




# Resolved Corrective Action & Solution Summary

The following 1 corrective action(s) were resolved during the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
BPS - Booster Power Supply	1	ACP

Created By: Kurtis Boller  
Creation Date: 01/12/2024  
Corrective Action: Both 12v 8amp failed  
Resolution:  
Resolved By: Riley Goyet  
Resolved On: 07/24/2025  
Manufacturer:  
Model:



# Testing Details

## Alarm Notification Appliance

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Horn/Strobe		Horns/Strobes	Manual	7/23/2025 9:05:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

## Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-026 020	A/V Room	Manual	7/23/2025 7:41:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-131 002	Admin / MP Bldg Admin Reception	Manual	7/24/2025 6:49:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-143	Admin / MP Bldg Attic	Manual	7/24/2025 6:47:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-145	Admin / MP Bldg Attic Admin Office	Manual	7/24/2025 6:47:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-142	Admin / MP Bldg Attic Office	Manual	7/24/2025 6:47:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-141	Admin / MP Bldg Attic Principals Off	Manual	7/24/2025 6:47:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-151	Admin / MP Bldg Attic RSP Rm	Manual	7/24/2025 6:47:54 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-152	Admin / MP Bldg Attic Speech	Manual	7/24/2025 6:49:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-152	Admin / MP Bldg Attic Speech	Manual	7/24/2025 6:49:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-152	Admin / MP Bldg Attic Speech	Manual	7/24/2025 6:49:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-152	Admin / MP Bldg Attic Speech	Manual	7/24/2025 6:49:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-054	Admin / MP Bldg Custodian Office	Manual	7/24/2025 6:49:39 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-005	Admin / MP Bldg Electric Rm	Manual	7/24/2025 6:49:54 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-074	Admin / MP Bldg Field Storage	Manual	7/24/2025 6:49:42 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-027 018	Admin / MP Bldg Media Center	Manual	7/24/2025 6:49:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-021 009	Admin / MP Bldg Mens Restroom	Manual	7/24/2025 6:49:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-034	Admin / MP Bldg Mens Restroom Clst	Manual	7/24/2025 6:49:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-044	Admin / MP Bldg MP Room	Manual	7/24/2025 6:49:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-042	Admin / MP Bldg MP Room	Manual	7/24/2025 6:49:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-041	Admin / MP Bldg MP Room	Manual	7/24/2025 6:49:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-043	Admin / MP Bldg MP Room	Manual	7/24/2025 6:49:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-050	Admin / MP Bldg MP Room	Manual	7/24/2025 6:49:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-049	Admin / MP Bldg MP Room	Manual	7/24/2025 6:49:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-046	Admin / MP Bldg MP Room	Manual	7/24/2025 6:49:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-045	Admin / MP Bldg MP Room	Manual	7/24/2025 6:49:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-047	Admin / MP Bldg MP Room	Manual	7/24/2025 6:49:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-051	Admin / MP Bldg MP Room	Manual	7/24/2025 6:49:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-048	Admin / MP Bldg MP Room	Manual	7/24/2025 6:49:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-052	Admin / MP Bldg MP Room	Manual	7/24/2025 6:49:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-003 032	Admin / MP Bldg MP Room Storage	Manual	7/24/2025 6:47:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-002 026	Admin / MP Bldg MP Room Storage	Manual	7/24/2025 6:49:49 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-053	Admin / MP Bldg MP Room Storage MDF	Manual	7/24/2025 6:49:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-032	Admin / MP Bldg RSP Rm	Manual	7/24/2025 6:50:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-033	Admin / MP Bldg RSP Rm Closet	Manual	7/24/2025 6:50:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-035	Admin / MP Bldg Speech therapy	Manual	7/24/2025 6:50:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-167	Admin / MP Bldg Stage Attic Storage	Manual	7/24/2025 6:47:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-166	Admin / MP Bldg Stage Duct	Manual	7/23/2025 9:06:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-168	Admin / MP Bldg Stage Soffit Front	Manual	7/24/2025 6:47:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-018	Admin Hall Storage	Manual	7/23/2025 7:57:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-019 008	Admin Hallway	Manual	7/23/2025 7:57:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-017	Admin Lobby	Manual	7/23/2025 7:52:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-020	Admin Lobby	Manual	7/23/2025 7:52:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-146	Admin Office	Manual	7/23/2025 7:56:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-009	Admin Office	Manual	7/23/2025 7:53:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-012	Admin Office	Manual	7/23/2025 7:53:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-011	Admin Office	Manual	7/23/2025 7:53:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-157	Admin Room North Exit	Manual	7/23/2025 7:59:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-022 010	Admin Womens Restroom	Manual	7/23/2025 7:57:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-171	Bldg A W Music Rm Soffit	Manual	7/24/2025 6:47:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-380	Bldg B Rm 1 Soffit	Manual	7/24/2025 6:48:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-030 070	Boys Restroom	Manual	7/23/2025 7:17:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-256 053	Building B Electrical Rm	Manual	7/24/2025 6:48:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-130	Building C2 Classroom 3 Attic	Manual	7/24/2025 6:48:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-132	Building D Classroom 7 Soffit	Manual	7/24/2025 6:48:39 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-132	Building D Classroom 7 Soffit	Manual	7/24/2025 6:48:40 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-132	Building D Classroom 7 Soffit	Manual	7/24/2025 6:48:42 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-132	Building D Classroom 7 Soffit	Manual	7/24/2025 6:48:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-132	Building D Classroom 7 Soffit	Manual	7/24/2025 6:48:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-132	Building D Classroom 7 Soffit	Manual	7/24/2025 6:48:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-135	Building D Classroom 9 Attic	Manual	7/24/2025 6:48:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-135	Building D Classroom 9 Soffit	Manual	7/24/2025 6:48:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-135	Building D Classroom 9 Soffit	Manual	7/24/2025 6:48:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-135	Building D Classroom 9 Soffit	Manual	7/24/2025 6:49:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-260 050	Classroom 1	Manual	7/23/2025 6:49:42 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-261	Classroom 1	Manual	7/23/2025 6:49:46 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-262	Classroom 1	Manual	7/23/2025 6:55:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-258	Classroom 1 & 2	Manual	7/23/2025 6:56:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-379	Classroom 1 & 2 Attic	Manual	7/23/2025 8:04:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-381	Classroom 1 Attic	Manual	7/23/2025 8:03:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-263	Classroom 1 Restroom	Manual	7/23/2025 6:56:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-259	Classroom 1 Storage	Manual	7/23/2025 6:56:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-279	Classroom 10	Manual	7/23/2025 7:21:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-276	Classroom 10	Manual	7/23/2025 7:22:20 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-278	Classroom 10	Manual	7/23/2025 7:22:35 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-386	Classroom 10 Soffit	Manual	7/24/2025 6:48:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-277	Classroom 10 Storage	Manual	7/23/2025 7:22:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-280	Classroom 11	Manual	7/23/2025 7:20:40 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-281	Classroom 11	Manual	7/23/2025 7:20:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-282	Classroom 11	Manual	7/23/2025 7:21:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-387	Classroom 11 Attic	Manual	7/23/2025 8:09:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-284	Classroom 11 Kiln Rm	Manual	7/23/2025 7:21:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-283	Classroom 11 Storage	Manual	7/23/2025 7:21:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-272	Classroom 12	Manual	7/23/2025 7:24:58 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-273 080	Classroom 12	Manual	7/23/2025 7:25:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-274	Classroom 12	Manual	7/23/2025 7:25:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-384	Classroom 12 Attic	Manual	7/23/2025 8:12:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-275	Classroom 12 Storage	Manual	7/23/2025 7:25:54 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-271	Classroom 13	Manual	7/23/2025 7:26:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-270	Classroom 13	Manual	7/23/2025 7:26:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-269 082	Classroom 13	Manual	7/23/2025 7:26:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-385	Classroom 13 Attic	Manual	7/23/2025 8:11:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-383	Classroom 13 Attic	Manual	7/23/2025 8:11:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-268 083	Classroom 13 Storage	Manual	7/23/2025 7:27:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-267	Classroom 14	Manual	7/23/2025 7:30:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-264	Classroom 14	Manual	7/23/2025 7:31:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-266 085	Classroom 14	Manual	7/23/2025 7:31:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-380	Classroom 14 Attic	Manual	7/23/2025 8:13:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-265	Classroom 14 Storage	Manual	7/23/2025 7:31:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-255	Classroom 15	Manual	7/23/2025 7:28:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-253	Classroom 15	Manual	7/23/2025 7:28:57 AM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	3-254	Classroom 15	Manual	7/23/2025 7:29:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-376	Classroom 15 Attic	Manual	7/23/2025 8:13:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-252	Classroom 15 Storage	Manual	7/23/2025 7:29:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-260	Classroom 16	Manual	7/23/2025 7:32:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-261	Classroom 16	Manual	7/23/2025 7:32:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-262	Classroom 16	Manual	7/23/2025 7:32:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-379	Classroom 16 Attic	Manual	7/23/2025 8:14:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-263	Classroom 16 Storage	Manual	7/23/2025 7:32:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-259	Classroom 17	Manual	7/23/2025 7:33:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-258	Classroom 17	Manual	7/23/2025 7:35:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-256	Classroom 17	Manual	7/23/2025 7:33:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-377	Classroom 17 Attic	Manual	7/23/2025 8:13:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-257	Classroom 17 Storage	Manual	7/23/2025 7:35:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-285	Classroom 19	Manual	7/23/2025 7:27:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-286	Classroom 19	Manual	7/23/2025 8:00:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-388	Classroom 19 Attic	Manual	7/23/2025 8:12:32 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-252	Classroom 2	Manual	7/23/2025 6:58:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-254	Classroom 2	Manual	7/23/2025 6:58:24 AM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	2-253 052	Classroom 2	Manual	7/23/2025 6:58:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-376	Classroom 2 Attic	Manual	7/23/2025 8:06:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-255	Classroom 2 Restroom	Manual	7/23/2025 6:57:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-257	Classroom 2 Storage	Manual	7/23/2025 6:57:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-013 055	Classroom 3	Manual	7/23/2025 7:02:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-010	Classroom 3	Manual	7/23/2025 7:02:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-012	Classroom 3	Manual	7/23/2025 7:05:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-011 056	Classroom 3 Storage	Manual	7/23/2025 7:02:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-014 057	Classroom 4	Manual	7/23/2025 6:59:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-015	Classroom 4	Manual	7/23/2025 6:59:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-016	Classroom 4	Manual	7/23/2025 7:00:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-131	Classroom 4 Attic	Manual	7/23/2025 8:06:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-017 058	Classroom 4 Storage	Manual	7/23/2025 7:00:19 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-008	Classroom 5	Manual	7/23/2025 7:05:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-006 059	Classroom 5	Manual	7/23/2025 7:06:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-007	Classroom 5	Manual	7/23/2025 7:07:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-128	Classroom 5 Attic	Manual	7/23/2025 8:06:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-009 060	Classroom 5 Storage	Manual	7/23/2025 7:07:26 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-005	Classroom 6	Manual	7/23/2025 7:07:54 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-004	Classroom 6	Manual	7/23/2025 7:08:49 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-003 061	Classroom 6	Manual	7/23/2025 7:09:24 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3-127	Classroom 6 Attic	Manual	7/23/2025 8:07:09 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-002 062	Classroom 6 Storage	Manual	7/23/2025 7:09:41 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-021	Classroom 7	Manual	7/23/2025 7:12:55 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-019 064	Classroom 7	Manual	7/23/2025 7:13:36 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-020	Classroom 7	Manual	7/23/2025 7:14:11 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3-133	Classroom 7 Attic	Manual	7/23/2025 8:07:26 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-018 065	Classroom 7 Storage	Manual	7/23/2025 7:14:33 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-026 066	Classroom 8	Manual	7/23/2025 7:17:48 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-027	Classroom 8	Manual	7/23/2025 7:18:04 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-028	Classroom 8	Manual	7/23/2025 7:18:34 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3-136	Classroom 8 Attic	Manual	7/23/2025 8:08:34 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-029 067	Classroom 8 Storage	Manual	7/23/2025 7:18:20 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-025	Classroom 9	Manual	7/23/2025 7:19:02 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-022	Classroom 9	Manual	7/23/2025 7:19:25 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-024 068	Classroom 9	Manual	7/23/2025 7:20:11 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3-134	Classroom 9 Attic	Manual	7/23/2025 8:09:00 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-023 069	Classroom 9 Storage	Manual	7/23/2025 7:19:49 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-006	Conference Room Admin	Manual	7/23/2025 7:54:33 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3-031 072	Custodial Closet	Manual	7/23/2025 8:07:49 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-073	Field Storage	Manual	7/23/2025 7:44:14 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-032 071	Girls Restroom	Manual	7/23/2025 7:16:52 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	2-163	Kitchen Hall Waterflow	Manual	7/23/2025 8:18:42 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-056	Kitchen Heat	Manual	7/23/2025 8:17:06 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-057 035	Kitchen Heat	Manual	7/23/2025 8:17:26 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-058 031	Kitchen Office	Manual	7/23/2025 7:51:47 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - Duct	2-156	MDF Rm Above FACP	Manual	7/23/2025 9:07:19 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-030	Media Center	Manual	7/23/2025 7:37:58 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-031	Media Center	Manual	7/23/2025 7:38:17 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-028 019	Media Center	Manual	7/23/2025 7:40:08 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-029	Media Center	Manual	7/23/2025 7:40:56 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-405	Media Overhand Attic	Manual	7/24/2025 6:49:32 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-055	MP Room Entry North	Manual	7/23/2025 7:51:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-072 029	MP Room Entry South	Manual	7/23/2025 7:43:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-147	MP Room Lobby	Manual	7/23/2025 7:56:38 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-173	MP Room South Exit	Manual	7/23/2025 7:59:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-064	MP Room Stage	Manual	7/23/2025 7:48:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-062	MP Room Stage	Manual	7/23/2025 7:48:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-061	MP Room Stage	Manual	7/23/2025 7:49:54 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-063	MP Room Stage	Manual	7/23/2025 7:50:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-060	MP Room Stage	Manual	7/23/2025 7:50:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-059	MP Room Stage Stairs	Manual	7/23/2025 7:50:54 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-069	Music Room	Manual	7/23/2025 7:46:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-067	Music Room	Manual	7/23/2025 7:46:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-065 028	Music Room	Manual	7/23/2025 7:47:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-066	Music Room	Manual	7/23/2025 7:47:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-071	Music Room Ramp	Manual	7/23/2025 7:45:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-070	Music Room Ramp	Manual	7/23/2025 7:45:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-068	Music Room Storage	Manual	7/23/2025 7:44:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-013	Nurse Office	Manual	7/23/2025 7:55:12 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-010	Nurse Restroom	Manual	7/23/2025 7:55:35 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-039	Parents Resource Room	Manual	7/23/2025 7:36:21 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-038 017	Parents Resource Room	Manual	7/23/2025 7:36:56 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-040	Parents Resource Room	Manual	7/23/2025 7:37:27 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Manual Pull Station	2-131 094	Portable Classroom 19	Manual	7/24/2025 6:48:50 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-007	Principals Office	Manual	7/23/2025 7:54:07 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-008	Principals Office Closet	Manual	7/23/2025 7:54:55 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-016	Program Office	Manual	7/23/2025 7:56:13 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - Duct	2.153	Reading Rm	Manual	7/24/2025 6:48:15 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - Duct	2.162	Reading Rm	Manual	7/24/2025 6:48:17 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-037	Reading Room	Manual	7/23/2025 7:38:47 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-036	Reading Room Storage	Manual	7/23/2025 7:39:22 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-150	RSP Room Attic	Manual	7/23/2025 8:15:04 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-024 012	Staff Room	Manual	7/23/2025 7:58:13 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-023	Staff Room	Manual	7/23/2025 7:58:32 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-159	Water Heater O/S Kitchen	Manual	7/24/2025 6:48:20 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-025	Work Rm	Manual	7/23/2025 7:42:15 AM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-149	Work Room Attic	Manual	7/23/2025 8:16:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	3-129	Classroom 3 Attic	Manual	7/23/2025 7:03:17 AM
	Comment:	No access		

**Power Supplies**

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
BPS - Booster Power Supply 1		ACP	Manual	7/24/2025 6:48:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Primary Power	046	Admin / MP Bldg MP Rm Elect Rm	Manual	7/24/2025 6:47:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Primary Power	045	Admin / MP Bldg MP Rm Elect Rm	Manual	7/24/2025 6:47:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
BPS - Booster Power Supply 1		BPS-A	Manual	7/24/2025 6:48:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
BPS - Booster Power Supply 1		BPS-B	Manual	7/24/2025 6:48:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

**Water-Based Fire Protection Systems**

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Supervisory Tamper Switch	2-164	Kitchen Hall Back Flow	Manual	7/23/2025 9:06:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

# Device/Equipment Details

## Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Horn/Strobe					
	Horns/Strobes				07/23/2025

## Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Manual Pull Station					
2-131 002	Admin / MP Bldg Admin Reception				
2-131 094	Portable Classroom 19				
2-146	Admin Office				
2-157	Admin Room North Exit				
2-173	MP Room South Exit				
2-147	MP Room Lobby				

## Smoke Detector - General

2-019 008	Admin Hallway				
2-021 009	Admin / MP Bldg Mens Restroom				
2-022 010	Admin Womens Restroom				
2-024 012	Staff Room				
2-038 017	Parents Resource Room				
2-027 018	Admin / MP Bldg Media Center				
2-028 019	Media Center				
2-026 020	A/V Room				
2-002 026	Admin / MP Bldg MP Room Storage				
2-065 028	Music Room				
2-072 029	MP Room Entry South				
2-058 031	Kitchen Office				
2-260 050	Classroom 1				
2-253 052	Classroom 2				
2-256 053	Building B Electrical Rm				
3-013 055	Classroom 3				
3-011 056	Classroom 3 Storage				
3-014 057	Classroom 4				
3-017 058	Classroom 4 Storage				
3-006 059	Classroom 5				
3-009 060	Classroom 5 Storage				
3-003 061	Classroom 6				
3-002 062	Classroom 6 Storage				
3-019 064	Classroom 7				
3-018 065	Classroom 7 Storage				
3-026 066	Classroom 8				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3-029 067	Classroom 8 Storage				
3-024 068	Classroom 9				
3-023 069	Classroom 9 Storage				
3-030 070	Boys Restroom				
3-032 071	Girls Restroom				
3-273 080	Classroom 12				
3-269 082	Classroom 13				
3-268 083	Classroom 13 Storage				
3-266 085	Classroom 14				
3-267	Classroom 14				
3-271	Classroom 13				
3-270	Classroom 13				
3-272	Classroom 12				
3-274	Classroom 12				
2-020	Admin Lobby				
2-023	Staff Room				
2-025	Work Rm				
2-029	Media Center				
2-030	Media Center				
2-031	Media Center				
2-032	Admin / MP Bldg RSP Rm				
2-033	Admin / MP Bldg RSP Rm Closet				
2-034	Admin / MP Bldg Mens Restroom Clst				
2-035	Admin / MP Bldg Speech therapy				
2-036	Reading Room Storage				
2-037	Reading Room				
2-039	Parents Resource Room				
2-040	Parents Resource Room				
2-041	Admin / MP Bldg MP Room				
2-042	Admin / MP Bldg MP Room				
2-043	Admin / MP Bldg MP Room				
2-044	Admin / MP Bldg MP Room				
2-045	Admin / MP Bldg MP Room				
2-046	Admin / MP Bldg MP Room				
2-047	Admin / MP Bldg MP Room				
2-048	Admin / MP Bldg MP Room				
2-049	Admin / MP Bldg MP Room				
2-050	Admin / MP Bldg MP Room				
2-051	Admin / MP Bldg MP Room				
2-052	Admin / MP Bldg MP Room				
2-053	Admin / MP Bldg MP Room Storage MDF				
2-054	Admin / MP Bldg Custodian Office				
2-055	MP Room Entry North				
2-059	MP Room Stage Stairs				
2-060	MP Room Stage				
2-061	MP Room Stage				
2-062	MP Room Stage				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-063	MP Room Stage				
2-064	MP Room Stage				
2-066	Music Room				
2-067	Music Room				
2-068	Music Room Storage				
2-069	Music Room				
2-070	Music Room Ramp				
2-071	Music Room Ramp				
2-073	Field Storage				
2-074	Admin / MP Bldg Field Storage				
2-252	Classroom 2				
2-254	Classroom 2				
2-255	Classroom 2 Restroom				
2-257	Classroom 2 Storage				
2-261	Classroom 1				
3-004	Classroom 6				
3-005	Classroom 6				
3-007	Classroom 5				
3-008	Classroom 5				
3-010	Classroom 3				
3-012	Classroom 3				
3-015	Classroom 4				
3-016	Classroom 4				
3-020	Classroom 7				
3-021	Classroom 7				
3-022	Classroom 9				
3-025	Classroom 9				
3-027	Classroom 8				
3-028	Classroom 8				
3-275	Classroom 12 Storage				
3-276	Classroom 10				
3-277	Classroom 10 Storage				
3-278	Classroom 10				
3-279	Classroom 10				
3-280	Classroom 11				
3-281	Classroom 11				
3-282	Classroom 11				
3-283	Classroom 11 Storage				
3-257	Classroom 17 Storage				
3-258	Classroom 17				
3-259	Classroom 17				
3-260	Classroom 16				
3-261	Classroom 16				
3-262	Classroom 16				
3-263	Classroom 16 Storage				
3-264	Classroom 14				
3-265	Classroom 14 Storage				
2-005	Admin / MP Bldg Electric Rm				
2-006	Conference Room Admin				
2-007	Principals Office				
2-008	Principals Office Closet				
2-009	Admin Office				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-018	Admin Hall Storage				
2-016	Program Office				
2-012	Admin Office				
2-011	Admin Office				
2-013	Nurse Office				
2-010	Nurse Restroom				
2-258	Classroom 1 & 2				
3-284	Classroom 11 Kiln Rm				
3-286	Classroom 19				
3-285	Classroom 19				
3-255	Classroom 15				
3-254	Classroom 15				
3-252	Classroom 15 Storage				
3-253	Classroom 15				
3-256	Classroom 17				
2-262	Classroom 1				
2-263	Classroom 1 Restroom				
2-259	Classroom 1 Storage				
2-017	Admin Lobby				
Heat Detector - Restorable Spot					
2-003 032	Admin / MP Bldg MP Room Storage				
2-057 035	Kitchen Heat				
3-031 072	Custodial Closet				
2-056	Kitchen Heat				
2-141	Admin / MP Bldg Attic Principals Off				
2-142	Admin / MP Bldg Attic Office				
2-143	Admin / MP Bldg Attic				
2-145	Admin / MP Bldg Attic Admin Office				
2-149	Work Room Attic				
2-150	RSP Room Attic				
2-151	Admin / MP Bldg Attic RSP Rm				
2-152	Admin / MP Bldg Attic Speech				
2-152	Admin / MP Bldg Attic Speech				
2-152	Admin / MP Bldg Attic Speech				
2-152	Admin / MP Bldg Attic Speech				
3-127	Classroom 6 Attic				
3-128	Classroom 5 Attic				
3-129	Classroom 3 Attic				
3-130	Building C2 Classroom 3 Attic				
3-131	Classroom 4 Attic				
3-132	Building D Classroom 7 Soffit				
3-132	Building D Classroom 7 Soffit				
3-132	Building D Classroom 7 Soffit				
3-132	Building D Classroom 7 Soffit				
3-132	Building D Classroom 7 Soffit				
3-132	Building D Classroom 7 Soffit				
3-133	Classroom 7 Attic				
3-135	Building D Classroom 9 Soffit				
3-135	Building D Classroom 9 Soffit				
3-135	Building D Classroom 9 Soffit				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3-135	Building D Classroom 9 Attic				
2-405	Media Overhand Attic				06/28/2020
2-167	Admin / MP Bldg Stage Attic Storage				
2-168	Admin / MP Bldg Stage Soffit Front				
2-380	Bldg B Rm 1 Soffit				
3-386	Classroom 10 Soffit				
3-388	Classroom 19 Attic				
2-381	Classroom 1 Attic				
2-171	Bldg A W Music Rm Soffit				
2-159	Water Heater O/S Kitchen				
2-379	Classroom 1 & 2 Attic				
2-376	Classroom 2 Attic				07/23/2025
3-136	Classroom 8 Attic				07/23/2025
3-134	Classroom 9 Attic				07/23/2025
3-387	Classroom 11 Attic				07/23/2025
3-385	Classroom 13 Attic				07/23/2025
3-383	Classroom 13 Attic				07/23/2025
3-384	Classroom 12 Attic				07/23/2025
3-376	Classroom 15 Attic				
3-380	Classroom 14 Attic				
3-377	Classroom 17 Attic				
3-379	Classroom 16 Attic				

**Smoke Detector - Duct**

2-166	Admin / MP Bldg Stage Duct				
2.162	Reading Rm				
2.153	Reading Rm				
2-156	MDF Rm Above FACP				

**Mechanical, Electrosonic, or Pressure Waterflow Device**

2-163	Kitchen Hall Waterflow				07/23/2025
-------	------------------------	--	--	--	------------

**Power Supplies**

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
---------	-------------	--------------	-------	--------	--------------

**Primary Power**

045	Admin / MP Bldg MP Rm Elect Rm				
046	Admin / MP Bldg MP Rm Elect Rm				

**BPS - Booster Power Supply**

1	BPS-B				01/12/2024
1	BPS-A				01/12/2024
1	ACP				01/12/2024

**Water-Based Fire Protection Systems**

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
---------	-------------	--------------	-------	--------	--------------

**Supervisory Tamper Switch**

2-164	Kitchen Hall Back Flow				06/28/2020
-------	------------------------	--	--	--	------------