

Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

RALPH RICHARDSON & STARR KING

4848 COTTAGE WAY
CARMICHAEL, California 95608
United States

This site has been inspected and tested in compliance with applicable standards.

Completed

Thursday, September 11, 2025

Test Session:03 Sep 2025 15:33 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD
5320 HEMLOCK ST
SACRAMENTO, California
United States

TESTED BY

Riley Goyet
Western States Fire Protection-
Sacramento
188 Cirby Way
Roseville, CA 95678
United States



Inspection Summary

Building Information

PROPERTY	RALPH RICHARDSON & STARR KING	CONTACT
ADDRESS	4848 COTTAGE WAY	PHONE
CITY/STATE	CARMICHAEL, California 95608	MOBILE
COUNTRY	United States	EMAIL

Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us


Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Ventilation and Cooking Equipment	5	0(0%)	0(0%)	0(0%)
Alarm Notification Appliance	101	101(100%)	101(100%)	0(0%)
Power Supplies	7	7(100%)	6(86%)	1(14%)
Fire Control Panel	8	8(100%)	8(100%)	0(0%)
Initiating Device	162	162(100%)	162(100%)	0(0%)

Certification

The equipment specified here in was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Thursday, September 11, 2025

ACCEPTED BY 09/11/2025
Building Representative


TESTED BY 09/11/2025
Riley Goyet
Technician

System Details

Control Units

ADDRESS/ SCAN ADDRESS		DESCRIPTION	Rooms 21 & 22 Bldg Elect Rm by Rm 22
MANUFACTURER	EST	S/W VERSION	
MODEL	3	LAST UPDATE	
SERIAL NUMBER		S/W LOCATION	
INSTALL DATE			

Secondary Power

TYPE	Battery - Sealed Lead-acid	DESCRIPTION	Rooms 6-8 Area Cust Office by Rm 7 - P.E. "E"
ADDRESS/ SCAN ADDRESS		NOMINAL VOLTAGE	12
Load Voltage		Amp Hours	12
Standby Hours		Alarm Minutes	
Battery Location		Charger Voltage	
TYPE	Battery - Sealed Lead-acid	DESCRIPTION	Rooms 21 & 22 Bldg Elect Rm by Rm 22 - FACP
ADDRESS/ SCAN ADDRESS		NOMINAL VOLTAGE	12
Load Voltage		Amp Hours	55
Standby Hours		Alarm Minutes	
Battery Location		Charger Voltage	
TYPE	Battery - Sealed Lead-acid	DESCRIPTION	Admin Area Conference Room - P.E. "C"
ADDRESS/ SCAN ADDRESS		NOMINAL VOLTAGE	12
Load Voltage		Amp Hours	8
Standby Hours		Alarm Minutes	
Battery Location		Charger Voltage	
TYPE	Battery - Sealed Lead-acid	DESCRIPTION	Admin Area Conference Room - P.E. "D"
ADDRESS/ SCAN ADDRESS		NOMINAL VOLTAGE	12
Load Voltage		Amp Hours	8
Standby Hours		Alarm Minutes	
Battery Location		Charger Voltage	
TYPE	Battery - Sealed Lead-acid	DESCRIPTION	Rooms 21 & 22 Bldg Elect Rm by Rm 22 - P.E. "A"
ADDRESS/ SCAN ADDRESS		NOMINAL VOLTAGE	12
Load Voltage		Amp Hours	8
Standby Hours		Alarm Minutes	
Battery Location		Charger Voltage	
TYPE	Battery - Sealed Lead-acid	DESCRIPTION	Rooms 21 & 22 Bldg Elect Rm by Rm 22 - P.E. "B"
ADDRESS/ SCAN ADDRESS		NOMINAL VOLTAGE	12
Load Voltage		Amp Hours	8
Standby Hours		Alarm Minutes	
Battery Location		Charger Voltage	
TYPE	Battery - Sealed Lead-acid	DESCRIPTION	Rooms 6-8 Area Cust Office by Rm 7 - P.E. "F"
ADDRESS/ SCAN ADDRESS		NOMINAL VOLTAGE	12

Load Voltage

Amp Hours

8

Standby Hours

Alarm Minutes

Battery Location

Charger Voltage

Open Corrective Action & Solution Summary

The following 2 corrective action(s) remain open following the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
Battery - Sealed Lead-acid	Created By: Creation Date: Corrective Action: Proposed Solution: Manufacturer: Model:	Admin Area Conference Room - P.E. "C" Riley Goyet 09/04/2025 Replace 12V 8AH Battery
[Other]	Fire Alarm Connection Created By: Creation Date: Corrective Action: Proposed Solution: Manufacturer: Model:	Casey Smith 07/30/2025 Fire Alarm Panel did not receive signal when activated even though it's connected Have fire alarm technician diagnose issue and fix

Testing Details

Alarm Notification Appliance

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	019	Admin Area Conference Room	Manual	9/3/2025 5:38:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	022	Admin Area Conference Room RR	Manual	9/3/2025 5:39:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	025	Admin Area Mens Restroom	Manual	9/3/2025 5:39:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	018	Admin Area Office Reception	Manual	9/3/2025 5:38:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	023	Admin Area Principals Office	Manual	9/3/2025 5:39:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	021	Admin Area Restroom Hall	Manual	9/3/2025 5:38:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	016	Admin Area Southeast Exterior	Manual	9/3/2025 5:38:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	017	Admin Area Southwest Exterior	Manual	9/3/2025 5:38:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	020	Admin Area Staff Room	Manual	9/3/2025 5:38:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	024	Admin Area Womens Restroom	Manual	9/3/2025 5:39:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	269	Multi-Purpose Bldg Boys Restroom	Manual	9/3/2025 5:40:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	270	Multi-Purpose Bldg Girls Restroom	Manual	9/3/2025 5:40:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	264	Multi-Purpose Bldg Hallway	Manual	9/3/2025 5:39:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	268	Multi-Purpose Bldg Hallway	Manual	9/3/2025 5:40:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	266	Multi-Purpose Bldg Kitchen	Manual	9/3/2025 5:39:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	265	Multi-Purpose Bldg MP Room	Manual	9/3/2025 5:39:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	267	Multi-Purpose Bldg Restroom Hall	Manual	9/3/2025 5:39:31 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	248	Pool Area Dressing Area	Manual	9/3/2025 5:39:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	246	Pool Area Pool Area	Manual	9/3/2025 5:39:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	247	Pool Area Pool Area	Manual	9/3/2025 5:39:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	249	Pool Area Restroom	Manual	9/3/2025 5:40:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	250	Pool Area Shower	Manual	9/3/2025 5:40:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	039	Rooms 1-3 Area Classroom 1	Manual	9/3/2025 5:38:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	042	Rooms 1-3 Area Classroom 1	Manual	9/3/2025 5:39:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	044	Rooms 1-3 Area Classroom 1 RR	Manual	9/3/2025 5:39:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	040	Rooms 1-3 Area Classroom 2	Manual	9/3/2025 5:38:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	045	Rooms 1-3 Area Classroom 2 RR	Manual	9/3/2025 5:39:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	041	Rooms 1-3 Area Classroom 3	Manual	9/3/2025 5:38:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	043	Rooms 1-3 Area Classroom 3	Manual	9/3/2025 5:39:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	046	Rooms 1-3 Area Classroom 3 RR	Manual	9/3/2025 5:39:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	038	Rooms 1-3 Area Southwest Exterior	Manual	9/3/2025 5:38:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	128	Rooms 15-17 Bldg Classrm 15 16 RR	Manual	9/3/2025 5:40:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	129	Rooms 15-17 Bldg Classrm 15 16 RR	Manual	9/3/2025 5:40:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	130	Rooms 15-17 Bldg Classrm 16 17 RR	Manual	9/3/2025 5:40:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	131	Rooms 15-17 Bldg Classrm 16 17 RR	Manual	9/3/2025 5:40:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible	125	Rooms 15-17 Bldg Classroom 15	Manual	9/3/2025 5:38:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	126	Rooms 15-17 Bldg Classroom 16	Manual	9/3/2025 5:38:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	127	Rooms 15-17 Bldg Classroom 17	Manual	9/3/2025 5:38:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	146	Rooms 18 & 20 Bldg Breakroom	Manual	9/3/2025 5:40:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	144	Rooms 18 & 20 Bldg Classroom 18	Manual	9/3/2025 5:38:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	145	Rooms 18 & 20 Bldg Classroom 20	Manual	9/3/2025 5:38:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	148	Rooms 18 & 20 Bldg Closet	Manual	9/3/2025 5:40:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	147	Rooms 18 & 20 Bldg Restroom	Manual	9/3/2025 5:40:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	143	Rooms 18 & 20 Bldg West Exterior	Manual	9/3/2025 5:38:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	164	Rooms 21 22 Bldg	Manual	9/3/2025 5:39:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	165	Rooms 21 22 Bldg Classroom 22	Manual	9/3/2025 5:39:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	163	Rooms 21 & 22 Bldg Classroom 21	Manual	9/3/2025 5:39:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	162	Rooms 21 & 22 Bldg Northwest Exterior	Manual	9/3/2025 5:38:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	166	Rooms 21 & 22 Bldg Restroom	Manual	9/3/2025 5:40:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	177	Rooms 25 & 26 Bldg Classrm 25 Breakroom	Manual	9/3/2025 5:39:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	176	Rooms 25 & 26 Bldg Classroom 25	Manual	9/3/2025 5:39:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	179	Rooms 25 & 26 Bldg Classroom 25	Manual	9/3/2025 5:40:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	178	Rooms 25 & 26 Bldg Classroom 26	Manual	9/3/2025 5:39:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	195	Rooms 27-29 Bldg Classroom 27	Manual	9/3/2025 5:39:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	196	Rooms 27-29 Bldg Classroom 28	Manual	9/3/2025 5:39:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	198	Rooms 27-29 Bldg Classroom 28 RR	Manual	9/3/2025 5:40:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	197	Rooms 27-29 Bldg Classroom 29	Manual	9/3/2025 5:39:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	199	Rooms 27-29 Bldg Classroom 29 RR	Manual	9/3/2025 5:40:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	193	Rooms 27-29 Bldg East Exterior	Manual	9/3/2025 5:38:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	192	Rooms 27-29 Bldg North Exterior	Manual	9/3/2025 5:38:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	194	Rooms 27-29 Bldg South Exterior	Manual	9/3/2025 5:38:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	216	Rooms 30-32 Bldg Classroom 30	Manual	9/3/2025 5:39:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	217	Rooms 30-32 Bldg Classroom 31	Manual	9/3/2025 5:39:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	219	Rooms 30-32 Bldg Classroom 31 RR	Manual	9/3/2025 5:40:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	218	Rooms 30-32 Bldg Classroom 32	Manual	9/3/2025 5:39:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	220	Rooms 30-32 Bldg Classroom 32 RR	Manual	9/3/2025 5:40:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	221	Rooms 30-32 Bldg Mens RR by Rm 30	Manual	9/3/2025 5:40:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	215	Rooms 30-32 Bldg South Exterior	Manual	9/3/2025 5:38:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	222	Rooms 30-32 Bldg Woms RR by Rm 30	Manual	9/3/2025 5:40:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	235	Rooms 33 & 34 Classroom 33	Manual	9/3/2025 5:39:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	237	Rooms 33 & 34 Classroom 33 RR	Manual	9/3/2025 5:40:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	236	Rooms 33 & 34 Classroom 34	Manual	9/3/2025 5:39:20 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	233	Rooms 33 & 34 South Exterior	Manual	9/3/2025 5:38:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	234	Rooms 33 & 34 West Exterior	Manual	9/3/2025 5:38:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	112	Rooms 6-8 Area Casting Room	Manual	9/3/2025 5:40:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	087	Rooms 6-8 Area Classroom 6	Manual	9/3/2025 5:38:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	088	Rooms 6-8 Area Classroom 7	Manual	9/3/2025 5:38:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	089	Rooms 6-8 Area Classroom 8	Manual	9/3/2025 5:38:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	103	Rooms 6-8 Area Classroom 8 RR	Manual	9/3/2025 5:39:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	104	Rooms 6-8 Area Classroom 8 RR	Manual	9/3/2025 5:39:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	090	Rooms 6-8 Area Classroom 8 RR Hall	Manual	9/3/2025 5:38:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	106	Rooms 6-8 Area Cust Office by Rm 7	Manual	9/3/2025 5:39:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	091	Rooms 6-8 Area Hallway	Manual	9/3/2025 5:38:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	092	Rooms 6-8 Area Hallway	Manual	9/3/2025 5:38:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	093	Rooms 6-8 Area Hallway	Manual	9/3/2025 5:38:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	086	Rooms 6-8 Area North Exterior	Manual	9/3/2025 5:38:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	101	Rooms 6-8 Area Physical Therapy	Manual	9/3/2025 5:38:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	102	Rooms 6-8 Area Physical Therapy	Manual	9/3/2025 5:38:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	109	Rooms 6-8 Area Physical Therapy	Manual	9/3/2025 5:39:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	110	Rooms 6-8 Area Physical Therapy	Manual	9/3/2025 5:39:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible	108	Rooms 6-8 Area Restroom	Manual	9/3/2025 5:39:52 PM
		Visual inspection	Passed (Manual)	
Visible	107	Rooms 6-8 Area Restroom	Manual	9/3/2025 5:39:53 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	100	Rooms 6-8 Area Restroom Hall	Manual	9/3/2025 5:38:53 PM
		Visual inspection	Passed (Manual)	
Visible	111	Rooms 6-8 Area Setting Station	Manual	9/3/2025 5:39:58 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	094	Rooms 6-8 Area Speech Room	Manual	9/3/2025 5:38:45 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	095	Rooms 6-8 Area Speech Storage	Manual	9/3/2025 5:38:46 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	096	Rooms 6-8 Area Speech Storage	Manual	9/3/2025 5:38:48 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	097	Rooms 6-8 Area Speech Storage	Manual	9/3/2025 5:38:49 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	098	Rooms 6-8 Area Speech Storage RR	Manual	9/3/2025 5:38:50 PM
		Visual inspection	Passed (Manual)	
Visible	105	Rooms 6-8 Area Speech Storage RR	Manual	9/3/2025 5:39:49 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	099	Rooms 6-8 Area Staff Room	Manual	9/3/2025 5:38:52 PM
		Visual inspection	Passed (Manual)	

Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
NAC Power Extender Panel	026	Admin Area Conference Room - P.E. "C"	Manual	9/3/2025 6:58:38 PM
		Visual inspection	Passed (Manual)	
NAC Power Extender Panel	027	Admin Area Conference Room - P.E. "D"	Manual	9/3/2025 6:58:39 PM
		Visual inspection	Passed (Manual)	
Remote Annunciator	001	Admin Area Office Reception	Manual	9/3/2025 6:24:32 PM
		Visual inspection	Passed (Manual)	
Fire Alarm Panel		Rooms 21 & 22 Bldg Elect Rm by Rm 22	Manual	9/3/2025 6:54:18 PM
		Manufacturer	EST	
		Model	3	
		Visual inspection	Passed (Manual)	
NAC Power Extender Panel	167	Rooms 21 & 22 Bldg Elect Rm by Rm 22 - P.E. "A"	Manual	9/3/2025 6:54:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
NAC Power Extender Panel	168	Rooms 21 & 22 Bldg Elect Rm by Rm 22 - P.E. "B"	Manual	9/3/2025 6:54:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	113	Rooms 6-8 Area Cust Office by Rm 7 - P.E. "E"	Manual	9/3/2025 6:58:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	114	Rooms 6-8 Area Cust Office by Rm 7 - P.E. "E"	Manual	9/3/2025 6:58:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	4-298 007	Admin Area Conference Room	Manual	9/3/2025 6:39:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-299 008	Admin Area Conference Room RR	Manual	9/3/2025 6:40:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-273 013	Admin Area Mens Restroom	Manual	9/3/2025 6:36:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-300 005	Admin Area Office Closet	Manual	9/3/2025 6:42:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	4-384 002	Admin Area Office Reception	Manual	9/3/2025 6:42:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-303 004	Admin Area Office Reception	Manual	9/3/2025 6:39:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-302 003	Admin Area Office Reception	Manual	9/3/2025 6:39:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-301 006	Admin Area Principals Office	Manual	9/3/2025 6:42:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-274 012	Admin Area Restroom Hall	Manual	9/3/2025 6:36:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-271 010	Admin Area Staff Room	Manual	9/3/2025 6:38:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-272 009	Admin Area Staff Room	Manual	9/3/2025 6:38:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	4-382 015	Admin Area Storage/Laundry Rm	Manual	9/3/2025 6:43:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	4-276 011	Admin Area Storage/Laundry Rm	Manual	9/3/2025 6:35:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-275 014	Admin Area Womens Restroom	Manual	9/3/2025 6:37:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-287 262	Multi-Purpose Bldg Boys Restroom	Manual	9/3/2025 6:27:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-286 263	Multi-Purpose Bldg Girls Restroom	Manual	9/3/2025 6:27:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-277 254	Multi-Purpose Bldg Hallway	Manual	9/3/2025 6:34:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-278 253	Multi-Purpose Bldg Hallway	Manual	9/3/2025 6:42:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-284 260	Multi-Purpose Bldg Kitchen	Manual	9/3/2025 6:31:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-282 257	Multi-Purpose Bldg MP Room	Manual	9/3/2025 6:32:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-281 256	Multi-Purpose Bldg MP Room	Manual	9/3/2025 6:33:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-280 255	Multi-Purpose Bldg MP Room	Manual	9/3/2025 6:33:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-279 258	Multi-Purpose Bldg MP Room	Manual	9/3/2025 6:33:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	4-389 252	Multi-Purpose Bldg MP Room Southeast	Manual	9/3/2025 6:28:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	4-388 251	Multi-Purpose Bldg MP Room Southwest	Manual	9/3/2025 6:43:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-283 259	Multi-Purpose Bldg MP Room Storage	Manual	9/3/2025 6:31:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-285 261	Multi-Purpose Bldg Restroom Hall	Manual	9/3/2025 6:27:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-130 243	Pool Area Dressing Area	Manual	9/11/2025 9:43:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	4-132 245	Pool Area Mechanical Room	Manual	9/11/2025 9:43:52 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	4-131 238	Pool Area Pool Area	Manual	9/11/2025 9:43:46 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	4-131 239	Pool Area Pool Area	Manual	9/11/2025 9:43:47 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	4-131 240	Pool Area Pool Area	Manual	9/11/2025 9:43:49 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	4-131 241	Pool Area Pool Area	Manual	9/11/2025 9:43:50 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	4-130 242	Pool Area Restroom	Manual	9/11/2025 9:43:42 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	4-130 244	Pool Area Shower	Manual	9/11/2025 9:43:44 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-295 029	Rooms 1-3 Area Classroom 1	Manual	9/3/2025 6:21:29 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-296 028	Rooms 1-3 Area Classroom 1	Manual	9/3/2025 6:22:19 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-297 030	Rooms 1-3 Area Classroom 1 RR	Manual	9/3/2025 6:21:56 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-293 032	Rooms 1-3 Area Classroom 2	Manual	9/3/2025 6:23:02 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-292 033	Rooms 1-3 Area Classroom 2	Manual	9/3/2025 6:23:18 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-291 034	Rooms 1-3 Area Classroom 2 RR	Manual	9/3/2025 6:23:44 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-289 036	Rooms 1-3 Area Classroom 3	Manual	9/3/2025 6:25:33 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-288 035	Rooms 1-3 Area Classroom 3	Manual	9/3/2025 6:26:23 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-290 037	Rooms 1-3 Area Classroom 3 RR	Manual	9/3/2025 6:25:14 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	4-294 031	Rooms 1-3 Area Storage by Classroom 1	Manual	9/3/2025 6:42:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-029 117	Rooms 15-17 Bldg Classrm 15 & 16 RR	Manual	9/3/2025 5:57:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-030 118	Rooms 15-17 Bldg Classrm 15 & 16 RR	Manual	9/3/2025 5:57:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-025 121	Rooms 15-17 Bldg Classrm 16 & 17 RR	Manual	9/3/2025 5:58:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-026 122	Rooms 15-17 Bldg Classrm 16 & 17 RR	Manual	9/3/2025 5:59:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-031 116	Rooms 15-17 Bldg Classroom 15	Manual	9/3/2025 5:56:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-032 115	Rooms 15-17 Bldg Classroom 15	Manual	9/3/2025 5:56:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-028 119	Rooms 15-17 Bldg Classroom 16	Manual	9/3/2025 5:58:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-027 120	Rooms 15-17 Bldg Classroom 16	Manual	9/3/2025 5:58:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-024 123	Rooms 15-17 Bldg Classroom 17	Manual	9/3/2025 6:00:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-023 124	Rooms 15-17 Bldg Classroom 17	Manual	9/3/2025 6:01:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-129 142	Rooms 18 & 20 Bldg Arric Classroom 20	Manual	9/11/2025 9:44:20 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-129 140	Rooms 18 & 20 Bldg Attic Classroom 18	Manual	9/11/2025 9:44:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-129 141	Rooms 18 & 20 Bldg Attic Restrooms	Manual	9/11/2025 9:44:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-019 136	Rooms 18 & 20 Bldg Breakroom	Manual	9/3/2025 5:55:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-017 132	Rooms 18 & 20 Bldg Classroom 18	Manual	9/3/2025 5:54:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	4-018 133	Rooms 18 & 20 Bldg Classroom 18	Manual	9/3/2025 5:55:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-021 135	Rooms 18 & 20 Bldg Classroom 20	Manual	9/3/2025 5:53:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-022 134	Rooms 18 & 20 Bldg Classroom 20	Manual	9/3/2025 5:53:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-016 138	Rooms 18 & 20 Bldg Closet	Manual	9/3/2025 5:54:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-015 139	Rooms 18 & 20 Bldg Equipment Closet	Manual	9/3/2025 6:42:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-020 137	Rooms 18 & 20 Bldg Restroom	Manual	9/3/2025 6:42:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-143 161	Rooms 21 & 22 Bldg Attic Kitchen by Rm 22	Manual	9/11/2025 9:44:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-014 151	Rooms 21 & 22 Bldg Classrm 21 N Storage	Manual	9/3/2025 6:42:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-008 157	Rooms 21 & 22 Bldg Classrm 22 Kitchen	Manual	9/3/2025 5:51:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-010 150	Rooms 21 & 22 Bldg Classroom 21	Manual	9/3/2025 5:51:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-011 149	Rooms 21 & 22 Bldg Classroom 21	Manual	9/3/2025 5:52:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-012 152	Rooms 21 & 22 Bldg Classroom 21 Storage	Manual	9/3/2025 5:52:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-006 154	Rooms 21 & 22 Bldg Classroom 22	Manual	9/3/2025 5:48:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-007 153	Rooms 21 & 22 Bldg Classroom 22	Manual	9/3/2025 5:48:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-009 156	Rooms 21 & 22 Bldg Classroom 22 RR	Manual	9/3/2025 5:49:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-004 155	Rooms 21 & 22 Bldg Classroom 22 Storage	Manual	9/3/2025 5:50:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	4-003 158	Rooms 21 & 22 Bldg Elect Rm by Rm 22	Manual	9/3/2025 5:48:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-013 159	Rooms 21 & 22 Bldg Storage O/S Rm 21	Manual	9/3/2025 6:43:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-005 160	Rooms 21 & 22 Bldg Storage O/S Rm 22	Manual	9/3/2025 6:43:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-385 174	Rooms 25 & 26 Bldg Attic Classroom 25	Manual	9/11/2025 9:44:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-385 173	Rooms 25 & 26 Bldg Attic Classroom 25	Manual	9/11/2025 9:44:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-385 175	Rooms 25 & 26 Bldg Attic Classroom 26	Manual	9/11/2025 9:44:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-307 171	Rooms 25 & 26 Bldg Classrm 25 Breakroom	Manual	9/3/2025 6:42:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-304 169	Rooms 25 & 26 Bldg Classroom 25	Manual	9/3/2025 6:42:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-305 170	Rooms 25 & 26 Bldg Classroom 25	Manual	9/3/2025 6:42:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-306 172	Rooms 25 & 26 Bldg Classroom 26	Manual	9/3/2025 6:42:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-380 190	Rooms 27-29 Bldg Attic Classroom 27	Manual	9/11/2025 9:43:54 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-381 191	Rooms 27-29 Bldg Attic Classroom 28	Manual	9/11/2025 9:43:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-262 180	Rooms 27-29 Bldg Classroom 27	Manual	9/3/2025 5:45:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-261 181	Rooms 27-29 Bldg Classroom 27	Manual	9/3/2025 5:45:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-266 182	Rooms 27-29 Bldg Classroom 28	Manual	9/3/2025 5:44:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-265 183	Rooms 27-29 Bldg Classroom 28	Manual	9/3/2025 5:44:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	4-267 184	Rooms 27-29 Bldg Classroom 28 RR	Manual	9/3/2025 6:43:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-269 185	Rooms 27-29 Bldg Classroom 29	Manual	9/3/2025 5:43:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-270 186	Rooms 27-29 Bldg Classroom 29	Manual	9/3/2025 5:43:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-268 187	Rooms 27-29 Bldg Classroom 29 RR	Manual	9/3/2025 6:43:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-264 188	Rooms 27-29 Bldg Elect/Telco by Rm 27	Manual	9/3/2025 6:02:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-263 189	Rooms 27-29 Bldg Storage by Rm 27	Manual	9/3/2025 6:02:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-376 211	Rooms 30-32 Bldg Attic Classroom 30	Manual	9/11/2025 9:44:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-378 212	Rooms 30-32 Bldg Attic Classroom 31	Manual	9/11/2025 9:43:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-379 213	Rooms 30-32 Bldg Attic Classroom 32	Manual	9/11/2025 9:43:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-252 201	Rooms 30-32 Bldg Classroom 30	Manual	9/3/2025 5:08:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-251 200	Rooms 30-32 Bldg Classroom 30	Manual	9/3/2025 5:08:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-257 203	Rooms 30-32 Bldg Classroom 31	Manual	9/3/2025 6:43:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-256 202	Rooms 30-32 Bldg Classroom 31	Manual	9/3/2025 6:43:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-258 204	Rooms 30-32 Bldg Classroom 31 RR	Manual	9/3/2025 6:43:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-260 206	Rooms 30-32 Bldg Classroom 32	Manual	9/3/2025 6:43:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-259 205	Rooms 30-32 Bldg Classroom 32	Manual	9/3/2025 6:43:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	4-315 207	Rooms 30-32 Bldg Classroom 32 RR	Manual	9/3/2025 6:43:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-254 209	Rooms 30-32 Bldg Janitor Rm by Rm 30	Manual	9/3/2025 5:46:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-255 208	Rooms 30-32 Bldg Mens RR by Rm 30	Manual	9/3/2025 5:46:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-314 214	Rooms 30-32 Bldg Plumbing Chase by Rm 30	Manual	9/11/2025 9:44:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-253 210	Rooms 30-32 Bldg Woms RR by Rm 30	Manual	9/3/2025 5:47:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-386 229	Rooms 33 & 34 Attic Classroom 33	Manual	9/11/2025 9:43:39 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-386 230	Rooms 33 & 34 Attic Classroom 33	Manual	9/11/2025 9:43:40 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-387 232	Rooms 33 & 34 Attic Classroom 34	Manual	9/11/2025 9:43:36 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-387 231	Rooms 33 & 34 Attic Classroom 34	Manual	9/11/2025 9:43:38 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-308 223	Rooms 33 & 34 Classroom 33	Manual	9/3/2025 6:43:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-309 224	Rooms 33 & 34 Classroom 33	Manual	9/3/2025 6:43:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-310 226	Rooms 33 & 34 Classroom 33 Closet	Manual	9/3/2025 6:43:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-311 225	Rooms 33 & 34 Classroom 33 RR	Manual	9/3/2025 6:43:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-312 227	Rooms 33 & 34 Classroom 34	Manual	9/3/2025 6:43:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-313 228	Rooms 33 & 34 Classroom 34	Manual	9/3/2025 6:43:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-140 077	Rooms 6-8 Area Attic Classroom 6	Manual	9/11/2025 9:44:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	4-141 078	Rooms 6-8 Area Attic Classroom 7	Manual	9/11/2025 9:44:03 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	4-142 079	Rooms 6-8 Area Attic Classroom 8	Manual	9/11/2025 9:44:01 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	4-139 082	Rooms 6-8 Area Attic Hallway	Manual	9/11/2025 9:44:09 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	4-139 081	Rooms 6-8 Area Attic Hallway	Manual	9/11/2025 9:44:11 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	4-139 080	Rooms 6-8 Area Attic Hallway	Manual	9/11/2025 9:44:12 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	4-138 084	Rooms 6-8 Area Attic Physical Therapy	Manual	9/11/2025 9:44:05 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	4-138 085	Rooms 6-8 Area Attic Physical Therapy	Manual	9/11/2025 9:44:07 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	4-138 083	Rooms 6-8 Area Attic Physical Therapy	Manual	9/11/2025 9:44:08 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-043 076	Rooms 6-8 Area Casting Room	Manual	9/3/2025 6:20:17 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-056 047	Rooms 6-8 Area Classroom 6	Manual	9/3/2025 6:16:22 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-055 048	Rooms 6-8 Area Classroom 6	Manual	9/3/2025 6:17:09 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-058 050	Rooms 6-8 Area Classroom 7	Manual	9/3/2025 6:05:18 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-057 049	Rooms 6-8 Area Classroom 7	Manual	9/3/2025 6:05:28 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-063 051	Rooms 6-8 Area Classroom 8	Manual	9/3/2025 6:03:35 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-062 052	Rooms 6-8 Area Classroom 8	Manual	9/3/2025 6:03:51 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-059 055	Rooms 6-8 Area Classroom 8 RR	Manual	9/3/2025 6:04:28 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	4-060 054	Rooms 6-8 Area Classroom 8 RR	Manual	9/3/2025 6:04:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-061 053	Rooms 6-8 Area Classroom 8 RR Hall	Manual	9/3/2025 6:04:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-038 065	Rooms 6-8 Area Cust Office by Rm 7	Manual	9/3/2025 6:09:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-048 056	Rooms 6-8 Area Hallway	Manual	9/3/2025 6:06:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-047 057	Rooms 6-8 Area Hallway	Manual	9/3/2025 6:08:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-046 058	Rooms 6-8 Area Hallway	Manual	9/3/2025 6:42:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-045 059	Rooms 6-8 Area Hallway	Manual	9/3/2025 6:43:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-053 072	Rooms 6-8 Area Physical Therapy NE	Manual	9/3/2025 6:18:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-054 071	Rooms 6-8 Area Physical Therapy NW	Manual	9/3/2025 6:19:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-052 074	Rooms 6-8 Area Physical Therapy Office	Manual	9/3/2025 6:43:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-050 073	Rooms 6-8 Area Physical Therapy SE	Manual	9/3/2025 6:18:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-049 070	Rooms 6-8 Area Physical Therapy SW	Manual	9/3/2025 6:17:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-040 068	Rooms 6-8 Area Restroom	Manual	9/3/2025 6:11:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-042 069	Rooms 6-8 Area Restroom	Manual	9/3/2025 6:11:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-041 067	Rooms 6-8 Area Restroom Hall	Manual	9/3/2025 6:10:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-044 075	Rooms 6-8 Area Setting Station	Manual	9/3/2025 6:19:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	4-035 060	Rooms 6-8 Area Speech Room	Manual	9/3/2025 6:07:21 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	4-034 062	Rooms 6-8 Area Speech Storage	Manual	9/3/2025 6:03:50 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	4-033 061	Rooms 6-8 Area Speech Storage	Manual	9/3/2025 6:06:39 PM
		Functional Inspection	Passed	
Smoke Detector - General	4-036 063	Rooms 6-8 Area Speech Storage	Manual	9/3/2025 6:07:43 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	4-037 064	Rooms 6-8 Area Speech Storage RR	Manual	9/3/2025 6:43:25 PM
		Functional Inspection	Passed	
Smoke Detector - General	4-039 066	Rooms 6-8 Area Staff Room	Manual	9/3/2025 6:10:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Power Supplies

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Battery - Sealed Lead-acid		Admin Area Conference Room - P.E. "D"	Manual	9/3/2025 6:58:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	8	
Battery - Sealed Lead-acid		Rooms 21 & 22 Bldg Elect Rm by Rm 22 - FACP	Manual	9/3/2025 6:59:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	55	
Battery - Sealed Lead-acid		Rooms 21 & 22 Bldg Elect Rm by Rm 22 - P.E. "A"	Manual	9/3/2025 6:59:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	8	
Battery - Sealed Lead-acid		Rooms 21 & 22 Bldg Elect Rm by Rm 22 - P.E. "B"	Manual	9/3/2025 6:59:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	8	
Battery - Sealed Lead-acid		Rooms 6-8 Area Cust Office by Rm 7 - P.E. "E"	Manual	9/3/2025 6:59:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	12	
Battery - Sealed Lead-acid		Rooms 6-8 Area Cust Office by Rm 7 - P.E. "F"	Manual	9/3/2025 6:59:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	8	
		Nominal Voltage	12	

Failed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Battery - Sealed Lead-acid		Admin Area Conference Room - P.E. "C"	Manual	9/3/2025 6:58:51 PM
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	
		Amp Hours	8	
		Nominal Voltage	12	

Ventilation and Cooking Equipment

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
[Other]	Fire Alarm Connection		Manual	9/3/2025 6:24:00 PM
Fusible Links	Fusible Links 450 x 2		Manual	9/3/2025 6:24:08 PM
Range Hood	Hood		Manual	9/3/2025 6:24:03 PM
Range Suppression	Suppression		Manual	9/3/2025 6:24:05 PM
Range Suppression Tank	WHDR260 Cylinder		Manual	9/3/2025 6:24:11 PM

Device/Equipment details

Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Audible					
016	Admin Area Southeast Exterior				
017	Admin Area Southwest Exterior				
038	Rooms 1-3 Area Southwest Exterior				
086	Rooms 6-8 Area North Exterior				
125	Rooms 15-17 Bldg Classroom 15				
126	Rooms 15-17 Bldg Classroom 16				
127	Rooms 15-17 Bldg Classroom 17				
143	Rooms 18 & 20 Bldg West Exterior				
162	Rooms 21 & 22 Bldg Northwest Exterior				
192	Rooms 27-29 Bldg North Exterior				
193	Rooms 27-29 Bldg East Exterior				
194	Rooms 27-29 Bldg South Exterior				
215	Rooms 30-32 Bldg South Exterior				
233	Rooms 33 & 34 South Exterior				
234	Rooms 33 & 34 West Exterior				
Audible And Visible					
018	Admin Area Office Reception				
019	Admin Area Conference Room				
020	Admin Area Staff Room				
021	Admin Area Restroom Hall				
039	Rooms 1-3 Area Classroom 1				
040	Rooms 1-3 Area Classroom 2				
041	Rooms 1-3 Area Classroom 3				
087	Rooms 6-8 Area Classroom 6				
088	Rooms 6-8 Area Classroom 7				
089	Rooms 6-8 Area Classroom 8				
090	Rooms 6-8 Area Classroom 8 RR Hall				
091	Rooms 6-8 Area Hallway				
092	Rooms 6-8 Area Hallway				
093	Rooms 6-8 Area Hallway				
094	Rooms 6-8 Area Speech Room				
095	Rooms 6-8 Area Speech Storage				
096	Rooms 6-8 Area Speech Storage				
097	Rooms 6-8 Area Speech Storage				
098	Rooms 6-8 Area Speech Storage RR				
099	Rooms 6-8 Area Staff Room				
100	Rooms 6-8 Area Restroom Hall				
101	Rooms 6-8 Area Physical Therapy				
102	Rooms 6-8 Area Physical Therapy				
144	Rooms 18 & 20 Bldg Classroom 18				
145	Rooms 18 & 20 Bldg Classroom 20				
163	Rooms 21 & 22 Bldg Classroom 21				
164	Rooms 21 22 Bldg				
165	Rooms 21 22 Bldg Classroom 22				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
176	Rooms 25 & 26 Bldg Classroom 25				
177	Rooms 25 & 26 Bldg Classrm 25 Breakroom				
178	Rooms 25 & 26 Bldg Classroom 26				
195	Rooms 27-29 Bldg Classroom 27				
196	Rooms 27-29 Bldg Classroom 28				
197	Rooms 27-29 Bldg Classroom 29				
216	Rooms 30-32 Bldg Classroom 30				
217	Rooms 30-32 Bldg Classroom 31				
218	Rooms 30-32 Bldg Classroom 32				
235	Rooms 33 & 34 Classroom 33				
236	Rooms 33 & 34 Classroom 34				
246	Pool Area Pool Area				
247	Pool Area Pool Area				
248	Pool Area Dressing Area				
264	Multi-Purpose Bldg Hallway				
265	Multi-Purpose Bldg MP Room				
266	Multi-Purpose Bldg Kitchen				
267	Multi-Purpose Bldg Restroom Hall				
Visible					
022	Admin Area Conference Room RR				
023	Admin Area Principals Office				
024	Admin Area Womens Restroom				
025	Admin Area Mens Restroom				
042	Rooms 1-3 Area Classroom 1				
043	Rooms 1-3 Area Classroom 3				
044	Rooms 1-3 Area Classroom 1 RR				
045	Rooms 1-3 Area Classroom 2 RR				
046	Rooms 1-3 Area Classroom 3 RR				
103	Rooms 6-8 Area Classroom 8 RR				
104	Rooms 6-8 Area Classroom 8 RR				
105	Rooms 6-8 Area Speech Storage RR				
106	Rooms 6-8 Area Cust Office by Rm 7				
107	Rooms 6-8 Area Restroom				
108	Rooms 6-8 Area Restroom				
109	Rooms 6-8 Area Physical Therapy				
110	Rooms 6-8 Area Physical Therapy				
111	Rooms 6-8 Area Setting Station				
112	Rooms 6-8 Area Casting Room				
128	Rooms 15-17 Bldg Classrm 15 16 RR				
129	Rooms 15-17 Bldg Classrm 15 16 RR				
130	Rooms 15-17 Bldg Classrm 16 17 RR				
131	Rooms 15-17 Bldg Classrm 16 17 RR				
146	Rooms 18 & 20 Bldg Breakroom				
147	Rooms 18 & 20 Bldg Restroom				
148	Rooms 18 & 20 Bldg Closet				
166	Rooms 21 & 22 Bldg Restroom				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
179	Rooms 25 & 26 Bldg Classroom 25				
198	Rooms 27-29 Bldg Classroom 28 RR				
199	Rooms 27-29 Bldg Classroom 29 RR				
219	Rooms 30-32 Bldg Classroom 31 RR				
220	Rooms 30-32 Bldg Classroom 32 RR				
221	Rooms 30-32 Bldg Mens RR by Rm 30				
222	Rooms 30-32 Bldg Woms RR by Rm 30				
237	Rooms 33 & 34 Classroom 33 RR				
249	Pool Area Restroom				
250	Pool Area Shower				
268	Multi-Purpose Bldg Hallway				
269	Multi-Purpose Bldg Boys Restroom				
270	Multi-Purpose Bldg Girls Restroom				

Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Remote Annunciator					
001	Admin Area Office Reception				
NAC Power Extender Panel					
026	Admin Area Conference Room - P.E. "C"				
027	Admin Area Conference Room - P.E. "D"				
113	Rooms 6-8 Area Cust Office by Rm 7 - P.E. "E"				
114	Rooms 6-8 Area Cust Office by Rm 7 - P.E. "F"				
167	Rooms 21 & 22 Bldg Elect Rm by Rm 22 - P.E. "A"				
168	Rooms 21 & 22 Bldg Elect Rm by Rm 22 - P.E. "B"				

Fire Alarm Panel

	Rooms 21 & 22 Bldg Elect Rm by Rm 22	EST	3		
--	--------------------------------------	-----	---	--	--

Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Manual Pull Station					
4-384 002	Admin Area Office Reception				
4-388 251	Multi-Purpose Bldg MP Room Southwest				
4-389 252	Multi-Purpose Bldg MP Room Southeast				
Smoke Detector - General					
4-302 003	Admin Area Office Reception				
4-303 004	Admin Area Office Reception				
4-300 005	Admin Area Office Closet				
4-301 006	Admin Area Principals Office				
4-298 007	Admin Area Conference Room				
4-299 008	Admin Area Conference Room RR				
4-272 009	Admin Area Staff Room				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
4-271 010	Admin Area Staff Room				
4-276 011	Admin Area Storage/Laundry Rm				
4-274 012	Admin Area Restroom Hall				
4-273 013	Admin Area Mens Restroom				
4-275 014	Admin Area Womens Restroom				
4-296 028	Rooms 1-3 Area Classroom 1				
4-295 029	Rooms 1-3 Area Classroom 1				
4-297 030	Rooms 1-3 Area Classroom 1 RR				
4-294 031	Rooms 1-3 Area Storage by Classroom 1				
4-293 032	Rooms 1-3 Area Classroom 2				
4-292 033	Rooms 1-3 Area Classroom 2				
4-291 034	Rooms 1-3 Area Classroom 2 RR				
4-288 035	Rooms 1-3 Area Classroom 3				
4-289 036	Rooms 1-3 Area Classroom 3				
4-290 037	Rooms 1-3 Area Classroom 3 RR				
4-056 047	Rooms 6-8 Area Classroom 6				
4-055 048	Rooms 6-8 Area Classroom 6				
4-057 049	Rooms 6-8 Area Classroom 7				
4-058 050	Rooms 6-8 Area Classroom 7				
4-063 051	Rooms 6-8 Area Classroom 8				
4-062 052	Rooms 6-8 Area Classroom 8				
4-061 053	Rooms 6-8 Area Classroom 8 RR Hall				
4-060 054	Rooms 6-8 Area Classroom 8 RR				
4-059 055	Rooms 6-8 Area Classroom 8 RR				
4-048 056	Rooms 6-8 Area Hallway				
4-047 057	Rooms 6-8 Area Hallway				
4-046 058	Rooms 6-8 Area Hallway				
4-045 059	Rooms 6-8 Area Hallway				
4-035 060	Rooms 6-8 Area Speech Room				
4-033 061	Rooms 6-8 Area Speech Storage				
4-034 062	Rooms 6-8 Area Speech Storage				
4-036 063	Rooms 6-8 Area Speech Storage				
4-037 064	Rooms 6-8 Area Speech Storage RR				
4-038 065	Rooms 6-8 Area Cust Office by Rm 7				
4-039 066	Rooms 6-8 Area Staff Room				
4-041 067	Rooms 6-8 Area Restroom Hall				
4-040 068	Rooms 6-8 Area Restroom				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
4-042 069	Rooms 6-8 Area Restroom				
4-049 070	Rooms 6-8 Area Physical Therapy SW				
4-054 071	Rooms 6-8 Area Physical Therapy NW				
4-053 072	Rooms 6-8 Area Physical Therapy NE				
4-050 073	Rooms 6-8 Area Physical Therapy SE				
4-052 074	Rooms 6-8 Area Physical Therapy Office				
4-044 075	Rooms 6-8 Area Setting Station				
4-043 076	Rooms 6-8 Area Casting Room				
4-032 115	Rooms 15-17 Bldg Classroom 15				
4-031 116	Rooms 15-17 Bldg Classroom 15				
4-029 117	Rooms 15-17 Bldg Classrm 15 & 16 RR				
4-030 118	Rooms 15-17 Bldg Classrm 15 & 16 RR				
4-028 119	Rooms 15-17 Bldg Classroom 16				
4-027 120	Rooms 15-17 Bldg Classroom 16				
4-025 121	Rooms 15-17 Bldg Classrm 16 & 17 RR				
4-026 122	Rooms 15-17 Bldg Classrm 16 & 17 RR				
4-024 123	Rooms 15-17 Bldg Classroom 17				
4-023 124	Rooms 15-17 Bldg Classroom 17				
4-017 132	Rooms 18 & 20 Bldg Classroom 18				
4-018 133	Rooms 18 & 20 Bldg Classroom 18				
4-022 134	Rooms 18 & 20 Bldg Classroom 20				
4-021 135	Rooms 18 & 20 Bldg Classroom 20				
4-019 136	Rooms 18 & 20 Bldg Breakroom				
4-020 137	Rooms 18 & 20 Bldg Restroom				
4-016 138	Rooms 18 & 20 Bldg Closet				
4-015 139	Rooms 18 & 20 Bldg Equipment Closet				
4-011 149	Rooms 21 & 22 Bldg Classroom 21				
4-010 150	Rooms 21 & 22 Bldg Classroom 21				
4-014 151	Rooms 21 & 22 Bldg Classrm 21 N Storage				
4-012 152	Rooms 21 & 22 Bldg Classroom 21 Storage				
4-007 153	Rooms 21 & 22 Bldg Classroom 22				
4-006 154	Rooms 21 & 22 Bldg Classroom 22				
4-004 155	Rooms 21 & 22 Bldg Classroom 22 Storage				
4-009 156	Rooms 21 & 22 Bldg Classroom 22 RR				
4-008 157	Rooms 21 & 22 Bldg Classrm 22 Kitchen				
4-003 158	Rooms 21 & 22 Bldg Elect Rm by Rm 22				
4-013 159	Rooms 21 & 22 Bldg Storage O/S Rm 21				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
4-005 160	Rooms 21 & 22 Bldg Storage O/S Rm 22				
4-304 169	Rooms 25 & 26 Bldg Classroom 25				
4-305 170	Rooms 25 & 26 Bldg Classroom 25				
4-307 171	Rooms 25 & 26 Bldg Classrm Breakroom				
4-306 172	Rooms 25 & 26 Bldg Classroom 26				
4-262 180	Rooms 27-29 Bldg Classroom 27				
4-261 181	Rooms 27-29 Bldg Classroom 27				
4-266 182	Rooms 27-29 Bldg Classroom 28				
4-265 183	Rooms 27-29 Bldg Classroom 28				
4-267 184	Rooms 27-29 Bldg Classroom RR				
4-269 185	Rooms 27-29 Bldg Classroom 29				
4-270 186	Rooms 27-29 Bldg Classroom 29				
4-268 187	Rooms 27-29 Bldg Classroom RR				
4-264 188	Rooms 27-29 Bldg Elect/Telco by Rm 27				
4-263 189	Rooms 27-29 Bldg Storage by Rm 27				
4-251 200	Rooms 30-32 Bldg Classroom 30				
4-252 201	Rooms 30-32 Bldg Classroom 30				
4-256 202	Rooms 30-32 Bldg Classroom 31				
4-257 203	Rooms 30-32 Bldg Classroom 31				
4-258 204	Rooms 30-32 Bldg Classroom RR				
4-259 205	Rooms 30-32 Bldg Classroom 32				
4-260 206	Rooms 30-32 Bldg Classroom 32				
4-315 207	Rooms 30-32 Bldg Classroom RR				
4-255 208	Rooms 30-32 Bldg Mens RR by Rm 30				
4-254 209	Rooms 30-32 Bldg Janitor Rm by Rm 30				
4-253 210	Rooms 30-32 Bldg Woms RR by Rm 30				
4-308 223	Rooms 33 & 34 Classroom 33				
4-309 224	Rooms 33 & 34 Classroom 33				
4-311 225	Rooms 33 & 34 Classroom RR				
4-310 226	Rooms 33 & 34 Classroom Closet				
4-312 227	Rooms 33 & 34 Classroom 34				
4-313 228	Rooms 33 & 34 Classroom 34				
4-278 253	Multi-Purpose Bldg Hallway				
4-277 254	Multi-Purpose Bldg Hallway				
4-280 255	Multi-Purpose Bldg MP Room				
4-281 256	Multi-Purpose Bldg MP Room				
4-282 257	Multi-Purpose Bldg MP Room				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
4-279 258	Multi-Purpose Bldg MP Room				
4-283 259	Multi-Purpose Bldg MP Room Storage				
4-284 260	Multi-Purpose Bldg Kitchen				
4-285 261	Multi-Purpose Bldg Restroom Hall				
4-287 262	Multi-Purpose Bldg Boys Restroom				
4-286 263	Multi-Purpose Bldg Girls Restroom				
Smoke Detector - Duct					
4-382 015	Admin Area Storage/Laundry Rm				
Heat Detector - Restorable Spot					
4-140 077	Rooms 6-8 Area Attic Classroom 6				
4-141 078	Rooms 6-8 Area Attic Classroom 7				
4-142 079	Rooms 6-8 Area Attic Classroom 8				
4-139 080	Rooms 6-8 Area Attic Hallway				
4-139 081	Rooms 6-8 Area Attic Hallway				
4-139 082	Rooms 6-8 Area Attic Hallway				
4-138 083	Rooms 6-8 Area Attic Physical Therapy				
4-138 084	Rooms 6-8 Area Attic Physical Therapy				
4-138 085	Rooms 6-8 Area Attic Physical Therapy				
4-129 140	Rooms 18 & 20 Bldg Attic Classroom 18				
4-129 141	Rooms 18 & 20 Bldg Attic Restrooms				
4-129 142	Rooms 18 & 20 Bldg Arric Classroom 20				
4-143 161	Rooms 21 & 22 Bldg Attic Kitchen by Rm 22				
4-385 173	Rooms 25 & 26 Bldg Attic Classroom 25				
4-385 174	Rooms 25 & 26 Bldg Attic Classroom 25				
4-385 175	Rooms 25 & 26 Bldg Attic Classroom 26				
4-380 190	Rooms 27-29 Bldg Attic Classroom 27				
4-381 191	Rooms 27-29 Bldg Attic Classroom 28				
4-376 211	Rooms 30-32 Bldg Attic Classroom 30				
4-378 212	Rooms 30-32 Bldg Attic Classroom 31				
4-379 213	Rooms 30-32 Bldg Attic Classroom 32				
4-314 214	Rooms 30-32 Bldg Plumbing Chase by Rm 30				
4-386 229	Rooms 33 & 34 Attic Classroom 33				
4-386 230	Rooms 33 & 34 Attic Classroom 33				
4-387 231	Rooms 33 & 34 Attic Classroom 34				
4-387 232	Rooms 33 & 34 Attic Classroom 34				
4-131 238	Pool Area Pool Area				
4-131 239	Pool Area Pool Area				
4-131 240	Pool Area Pool Area				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
4-131 241	Pool Area Pool Area				
4-130 242	Pool Area Restroom				
4-130 243	Pool Area Dressing Area				
4-130 244	Pool Area Shower				
4-132 245	Pool Area Mechanical Room				

Power Supplies

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Battery - Sealed Lead-acid					
	Rooms 21 & 22 Bldg Elect Rm by Rm 22 - FACP				
	Rooms 21 & 22 Bldg Elect Rm by Rm 22 - P.E. "A"				
	Rooms 21 & 22 Bldg Elect Rm by Rm 22 - P.E. "B"				
	Rooms 6-8 Area Cust Office by Rm 7 - P.E. "E"				
	Rooms 6-8 Area Cust Office by Rm 7 - P.E. "F"				
	Admin Area Conference Room - P.E. "C"				
	Admin Area Conference Room - P.E. "D"				

Ventilation and Cooking Equipment

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Range Suppression Tank					
	WHDR260 Cylinder				07/29/2025
Fusible Links					
	Fusible Links 450 x 2				07/29/2025
Range Suppression					
	Suppression				07/29/2025
Range Hood					
	Hood				07/29/2025
[Other]					
	Fire Alarm Connection				07/29/2025