

Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

ANDREW CARNEGIE MIDDLE SC

5820 ILLINOIS AVE
ORANGEVALE, California
United States

This site has been inspected and tested in compliance with applicable standards.

Completed

Thursday, March 19, 2026

Test Session: 19 Mar 2026 13:10 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD
5320 HEMLOCK ST
SACRAMENTO, California
United States

TESTED BY

Riley Goyet
Western States Fire Protection-
Sacramento
188 Cirby Way
Roseville, CA 95678
United States



Inspection Summary

Building Information

PROPERTY	ANDREW CARNEGIE MIDDLE SC	CONTACT
ADDRESS	5820 ILLINOIS AVE	PHONE
CITY/STATE	ORANGEVALE, California	MOBILE
COUNTRY	United States	EMAIL

Inspector Information

COMPANY	Western States Fire Protection- Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us

Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Alarm Notification Appliance	134	134(100%)	134(100%)	0(0%)
Fire Control Panel	9	1(11%)	1(11%)	0(0%)
Initiating Device	408	408(100%)	378(93%)	30(7%)
Chemical Extinguishing Systems	1	0(0%)	0(0%)	0(0%)
Ventilation and Cooking Equipment	3	0(0%)	0(0%)	0(0%)

Certification

The equipment specified herein was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Thursday, March 19, 2026

ACCEPTED BY 03/19/2026

Building Representative

TESTED BY



03/19/2026

Riley Goyet

Technician

Open Corrective Action & Solution Summary

The following 46 corrective action(s) remain open following the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
Heat Detector - Restorable Spot	2-376 540	Music Building Attic Music A29 Off N
	Created By: Creation Date: Corrective Action: Proposed Solution: Manufacturer: Model:	Riley Goyet 02/22/2022 Did not activate
Heat Detector - Restorable Spot		
	Created By: Creation Date: Corrective Action: Proposed Solution: Manufacturer: Model:	Riley Goyet 04/22/2025 Stick heat did not activate.
NAC Power Extender Panel	324	Building H Custodial Closet
	Created By: Creation Date: Corrective Action: Proposed Solution: Manufacturer: Model:	Riley Goyet 01/31/2024 Replace (2) 12V 8AH Batteries
NAC Power Extender Panel		
	Created By: Creation Date: Corrective Action: Proposed Solution: Manufacturer: Model:	Riley Goyet 04/22/2025 Replace (2) 12V 8AH Batteries
NAC Power Extender Panel	427	Rooms P1-P6 Bldg Classroom P2
	Created By: Creation Date: Corrective Action: Proposed Solution: Manufacturer: Model:	Riley Goyet 01/31/2024 Replace (2) 12V 8AH Batteries
NAC Power Extender Panel		
	Created By: Creation Date: Corrective Action: Proposed Solution: Manufacturer: Model:	Riley Goyet 04/22/2025 Replace (2) 12V 8AH Batteries
NAC Power Extender Panel	428	Rooms P1-P6 Bldg Weight Room Closet
	Created By: Creation Date: Corrective Action: Proposed Solution: Manufacturer: Model:	Riley Goyet 01/31/2024 Replace (2) 12V 8AH Batteries
NAC Power Extender Panel		
	Created By: Creation Date: Corrective Action: Proposed Solution:	Riley Goyet 04/22/2025 Replace (2) 12V 8AH Batteries

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
----------------	---------	-------------

Manufacturer:
Model:

NAC Power Extender Panel	547	Music Building Music Room A29
--------------------------	-----	-------------------------------

Created By: Riley Goyet
 Creation Date: 01/31/2024
 Corrective Action: Replace (2) 12V 8AH Batteries
 Proposed Solution:
 Manufacturer:
 Model:

NAC Power Extender Panel	526	Multi-Purpose Bldg Kitchen Restroom
--------------------------	-----	-------------------------------------

Created By: Riley Goyet
 Creation Date: 01/31/2024
 Corrective Action: Replace (2) 12V 8AH batteries
 Proposed Solution:
 Manufacturer:
 Model:

Created By: Riley Goyet
 Creation Date: 01/31/2024
 Corrective Action: Replace (2) 12V 8AH batteries
 Proposed Solution:
 Manufacturer:
 Model:

Created By: Riley Goyet
 Creation Date: 04/22/2025
 Corrective Action: Replace (2) 12V 8AH Batteries
 Proposed Solution:
 Manufacturer:
 Model:

Fire Alarm Panel		Admin Bldg FACP / Server Rm
------------------	--	-----------------------------

Created By: Riley Goyet
 Creation Date: 01/31/2024
 Corrective Action: Panel would randomly show CPU Fault and power completely down. Screen would go black or only half would work randomly.
 Proposed Solution:
 Manufacturer:
 Model:

Created By: Riley Goyet
 Creation Date: 01/31/2024
 Corrective Action: Panel would randomly show CPU Fault and power completely down. Screen would go black or only half would work randomly.
 Proposed Solution:
 Manufacturer:
 Model:

Smoke Detector - General	3-122 388	Rooms P1-P6 Bldg Weight Room
--------------------------	--------------	------------------------------

Created By: Riley Goyet
 Creation Date: 04/22/2025
 Corrective Action: Came in with no description
 Proposed Solution:
 Manufacturer:
 Model:

Created By: Riley Goyet
 Creation Date: 03/19/2026

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
----------------	---------	-------------

Corrective Action: Came in with no description
 Proposed Solution:
 Manufacturer:
 Model:

Range Suppression Tank	Ansul 3 Gallon Cylinder	
------------------------	-------------------------	--

Created By: Casey Smith
 Creation Date: 08/28/2025
 Corrective Action: Cylinder original date is 1984 before UL300
 Proposed Solution: Replace with UL300 3 Gallon cylinder.
 Manufacturer:
 Model:



Range Suppression	Suppression System	
-------------------	--------------------	--

Created By: Casey Smith
 Creation Date: 08/28/2025
 Corrective Action: Replace Automan, cylinder, and cartridge to UL300 rated system
 Proposed Solution: Replace Automan, cylinder, and cartridge to UL300 rated system
 Manufacturer:
 Model:



Smoke Detector - General	3-092 237	Building G Classroom G1
--------------------------	--------------	-------------------------

Created By: Riley Goyet
 Creation Date: 03/19/2026
 Corrective Action: Came in as a trouble.
 Proposed Solution:
 Manufacturer:
 Model:

Smoke Detector - General	3-091 238	Building G Classroom G1
--------------------------	--------------	-------------------------

Created By: Riley Goyet
 Creation Date: 03/19/2026
 Corrective Action: Came in as a trouble.
 Proposed Solution:
 Manufacturer:
 Model:

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
----------------	---------	-------------

Smoke Detector - General	3-090 239	Building G Classroom G1
--------------------------	--------------	-------------------------

Created By: Riley Goyet
 Creation Date: 03/19/2026
 Corrective Action: Came in as a trouble.
 Proposed Solution:
 Manufacturer:
 Model:

Smoke Detector - General	3-119 240	Building G Classroom G1
--------------------------	--------------	-------------------------

Created By: Riley Goyet
 Creation Date: 03/19/2026
 Corrective Action: Came in as a trouble.
 Proposed Solution:
 Manufacturer:
 Model:

Smoke Detector - General	3-089 241	Building G Classroom G1
--------------------------	--------------	-------------------------

Created By: Riley Goyet
 Creation Date: 03/19/2026
 Corrective Action: Came in as a trouble.
 Proposed Solution:
 Manufacturer:
 Model:

Smoke Detector - General	3-088 242	Building G Classroom G1
--------------------------	--------------	-------------------------

Created By: Riley Goyet
 Creation Date: 03/19/2026
 Corrective Action: Came in as a trouble.
 Proposed Solution:
 Manufacturer:
 Model:

Smoke Detector - General	3-087 243	Building G Classroom G1
--------------------------	--------------	-------------------------

Created By: Riley Goyet
 Creation Date: 03/19/2026
 Corrective Action: Came in as a trouble.
 Proposed Solution:
 Manufacturer:
 Model:

Smoke Detector - General	3-085 244	Building G Classroom G1
--------------------------	--------------	-------------------------

Created By: Riley Goyet
 Creation Date: 03/19/2026
 Corrective Action: Came in as a trouble.
 Proposed Solution:
 Manufacturer:
 Model:

Smoke Detector - General	3-086 245	Building G Classroom G1 Office
--------------------------	--------------	--------------------------------

Created By: Riley Goyet
 Creation Date: 03/19/2026
 Corrective Action: Came in as a trouble.
 Proposed Solution:
 Manufacturer:
 Model:

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
Smoke Detector - General	3-084 246	Building G Classroom G1 Office
	Created By:	Riley Goyet
	Creation Date:	03/19/2026
	Corrective Action:	Came in as a trouble.
	Proposed Solution:	
	Manufacturer:	
	Model:	
Smoke Detector - General	3-065 247	Building G Classroom G2
	Created By:	Riley Goyet
	Creation Date:	03/19/2026
	Corrective Action:	Came in as a trouble.
	Proposed Solution:	
	Manufacturer:	
	Model:	
Smoke Detector - General	3-066 248	Building G Classroom G2
	Created By:	Riley Goyet
	Creation Date:	03/19/2026
	Corrective Action:	Came in as a trouble.
	Proposed Solution:	
	Manufacturer:	
	Model:	
Smoke Detector - General	3-067 249	Building G Classroom G3
	Created By:	Riley Goyet
	Creation Date:	03/19/2026
	Corrective Action:	Came in as a trouble.
	Proposed Solution:	
	Manufacturer:	
	Model:	
Smoke Detector - General	3-068 250	Building G Classroom G3
	Created By:	Riley Goyet
	Creation Date:	03/19/2026
	Corrective Action:	Came in as a trouble.
	Proposed Solution:	
	Manufacturer:	
	Model:	
Smoke Detector - General	3-069 251	Building G Classroom G3
	Created By:	Riley Goyet
	Creation Date:	03/19/2026
	Corrective Action:	Came in as a trouble.
	Proposed Solution:	
	Manufacturer:	
	Model:	
Smoke Detector - General	3-070 252	Building G Classroom G4
	Created By:	Riley Goyet
	Creation Date:	03/19/2026
	Corrective Action:	Came in as a trouble.
	Proposed Solution:	
	Manufacturer:	
	Model:	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
Smoke Detector - General	3-071 253	Building G Classroom G4
	Created By:	Riley Goyet
	Creation Date:	03/19/2026
	Corrective Action:	Came in as a trouble.
	Proposed Solution:	
	Manufacturer:	
	Model:	
Smoke Detector - General	3-072 254	Building G Classroom G4
	Created By:	Riley Goyet
	Creation Date:	03/19/2026
	Corrective Action:	Came in as a trouble.
	Proposed Solution:	
	Manufacturer:	
	Model:	
Smoke Detector - General	3-073 255	Building G Classroom G5
	Created By:	Riley Goyet
	Creation Date:	03/19/2026
	Corrective Action:	Came in as a trouble.
	Proposed Solution:	
	Manufacturer:	
	Model:	
Smoke Detector - General	3-074 256	Building G Classroom G5
	Created By:	Riley Goyet
	Creation Date:	03/19/2026
	Corrective Action:	Came in as a trouble.
	Proposed Solution:	
	Manufacturer:	
	Model:	
Smoke Detector - General	3-075 257	Building G Classroom G6
	Created By:	Riley Goyet
	Creation Date:	03/19/2026
	Corrective Action:	Came in as a trouble.
	Proposed Solution:	
	Manufacturer:	
	Model:	
Smoke Detector - General	3-076 258	Building G Classroom G6
	Created By:	Riley Goyet
	Creation Date:	03/19/2026
	Corrective Action:	Came in as a trouble.
	Proposed Solution:	
	Manufacturer:	
	Model:	
Smoke Detector - General	3-077 259	Building G Classroom G6
	Created By:	Riley Goyet
	Creation Date:	03/19/2026
	Corrective Action:	Came in as a trouble.
	Proposed Solution:	
	Manufacturer:	
	Model:	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
Smoke Detector - General	3-121 260	Building G Classroom G6
	Created By:	Riley Goyet
	Creation Date:	03/19/2026
	Corrective Action:	Came in as a trouble.
	Proposed Solution:	
	Manufacturer:	
	Model:	
Smoke Detector - General	3-078 261	Building G Classroom G6
	Created By:	Riley Goyet
	Creation Date:	03/19/2026
	Corrective Action:	Came in as a trouble.
	Proposed Solution:	
	Manufacturer:	
	Model:	
Smoke Detector - General	3-081 263	Building G Classroom G6
	Created By:	Riley Goyet
	Creation Date:	03/19/2026
	Corrective Action:	Came in as a trouble.
	Proposed Solution:	
	Manufacturer:	
	Model:	
Smoke Detector - General	3-083 264	Building G Classroom G6
	Created By:	Riley Goyet
	Creation Date:	03/19/2026
	Corrective Action:	Came in as a trouble.
	Proposed Solution:	
	Manufacturer:	
	Model:	
Smoke Detector - General	3-082 266	Building G Classroom G6 Office
	Created By:	Riley Goyet
	Creation Date:	03/19/2026
	Corrective Action:	Came in as a trouble.
	Proposed Solution:	
	Manufacturer:	
	Model:	

Testing Details

Alarm Notification Appliance

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible		Admin Bldg Admin Office	Manual	3/19/2026 1:13:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Admin Bldg Attendance	Manual	3/19/2026 1:13:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Admin Bldg Counselors Office	Manual	3/19/2026 1:13:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Admin Bldg Mens Staff RR	Manual	3/19/2026 1:11:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Admin Bldg Mens Staff RR	Manual	3/19/2026 1:12:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Admin Bldg North Exterior	Manual	3/19/2026 1:11:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Admin Bldg Nurse	Manual	3/19/2026 1:12:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Admin Bldg Principal Secretary	Manual	3/19/2026 1:13:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Admin Bldg Principals Office	Manual	3/19/2026 1:13:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Admin Bldg Reception	Manual	3/19/2026 1:13:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Admin Bldg Reception Office Hall	Manual	3/19/2026 1:12:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Admin Bldg Southwest Exterior	Manual	3/19/2026 1:11:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Admin Bldg Staff Room	Manual	3/19/2026 1:14:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Admin Bldg Staff RR Hall	Manual	3/19/2026 1:13:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Admin Bldg VP Office North	Manual	3/19/2026 1:13:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Admin Bldg VP Office South	Manual	3/19/2026 1:13:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Admin Bldg West Exterior	Manual	3/19/2026 1:11:46 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	Admin Bldg Womens Staff RR		Manual	3/19/2026 1:11:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	Admin Bldg Womens Staff RR		Manual	3/19/2026 1:12:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	Building A Classroom A1		Manual	3/19/2026 1:13:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	Building A Classroom A1		Manual	3/19/2026 1:14:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	Building A Classroom A4		Manual	3/19/2026 1:13:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	Building A Classroom A4		Manual	3/19/2026 1:14:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	Building A Custodian Office		Manual	3/19/2026 1:12:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	Building A Custodian Office RR		Manual	3/19/2026 1:13:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	Building A Mens Staff RR		Manual	3/19/2026 1:13:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	Building A Southeast Exterior		Manual	3/19/2026 1:13:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	Building A Staff Loung		Manual	3/19/2026 1:13:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	Building A Staff Lounge		Manual	3/19/2026 1:13:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	Building A Staff Lounge		Manual	3/19/2026 1:13:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	Building A Womens Staff RR		Manual	3/19/2026 1:11:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	Building C Boys Restroom		Manual	3/19/2026 1:11:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	Building C Classroom C1		Manual	3/19/2026 1:14:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	Building C Classroom C2		Manual	3/19/2026 1:14:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	Building C Classroom C5		Manual	3/19/2026 1:14:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible		Building C Classroom C8	Manual	3/19/2026 1:14:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building C East Exterior	Manual	3/19/2026 1:11:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Building C Girls Restroom	Manual	3/19/2026 1:11:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building C Media Center	Manual	3/19/2026 1:14:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building C Media Center	Manual	3/19/2026 1:14:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Building C Media Center	Manual	3/19/2026 1:14:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Building C Media Center Storage	Manual	3/19/2026 1:14:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building C North Exterior	Manual	3/19/2026 1:11:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building E Classroom E1	Manual	3/19/2026 1:14:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building E Classroom E2	Manual	3/19/2026 1:14:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building E Classroom E3	Manual	3/19/2026 1:14:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building E Classroom E4	Manual	3/19/2026 1:14:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Building E Classroom E4 Strg	Manual	3/19/2026 1:14:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building E Classroom E5	Manual	3/19/2026 1:14:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building E Classroom E6	Manual	3/19/2026 1:14:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building E East Exterior	Manual	3/19/2026 1:11:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building E North Exterior	Manual	3/19/2026 1:11:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building E South Exterior	Manual	3/19/2026 1:11:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Building E Staff Restroom North	Manual	3/19/2026 1:11:18 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Building E Staff Restroom South	Manual	3/19/2026 1:11:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building E West Exterior	Manual	3/19/2026 1:11:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building F Classroom F1	Manual	3/19/2026 1:13:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building F Classroom F2	Manual	3/19/2026 1:13:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building F Classroom F3	Manual	3/19/2026 1:13:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building F Classroom F4	Manual	3/19/2026 1:13:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building F East Exterior	Manual	3/19/2026 1:11:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building F West Exterior	Manual	3/19/2026 1:11:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building G Classroom G1	Manual	3/19/2026 1:13:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Building G Classroom G1	Manual	3/19/2026 1:14:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Building G Classroom G1 Office	Manual	3/19/2026 1:14:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building G Classroom G2	Manual	3/19/2026 1:13:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building G Classroom G3	Manual	3/19/2026 1:13:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building G Classroom G4	Manual	3/19/2026 1:13:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building G Classroom G5	Manual	3/19/2026 1:13:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building G Classroom G6	Manual	3/19/2026 1:13:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Building G Classroom G6	Manual	3/19/2026 1:14:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Building G Classroom G6 Office	Manual	3/19/2026 1:14:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible		Building G South Exterior	Manual	3/19/2026 1:12:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Building H Boys Restroom	Manual	3/19/2026 1:11:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building H Classroom H1	Manual	3/19/2026 1:13:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building H Classroom H2	Manual	3/19/2026 1:13:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building H Classroom H3	Manual	3/19/2026 1:13:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building H Classroom H4	Manual	3/19/2026 1:13:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Building H Classroom H4 Strg	Manual	3/19/2026 1:14:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building H Classroom H5	Manual	3/19/2026 1:13:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building H Classroom H8	Manual	3/19/2026 1:13:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Building H Girls Restroom	Manual	3/19/2026 1:11:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building H North Exterior	Manual	3/19/2026 1:12:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building H South Exterior	Manual	3/19/2026 1:12:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Building I Boys Restroom	Manual	3/19/2026 1:11:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building I Classroom I-1	Manual	3/19/2026 1:13:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building I Classroom I-2	Manual	3/19/2026 1:13:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building I Classroom I-3	Manual	3/19/2026 1:13:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building I Classroom I-4	Manual	3/19/2026 1:13:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Building I Classroom I-4 Strg	Manual	3/19/2026 1:13:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building I Classroom I-5	Manual	3/19/2026 1:13:24 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Building I Classroom I-8	Manual	3/19/2026 1:12:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building I East Exterior	Manual	3/19/2026 1:12:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Building I Girls Restroom	Manual	3/19/2026 1:11:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building I South Exterior	Manual	3/19/2026 1:12:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Locker Room Bldg Boys Locker Entry	Manual	3/19/2026 1:11:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Locker Room Bldg Boys Locker Office	Manual	3/19/2026 1:11:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Locker Room Bldg Boys Locker Room	Manual	3/19/2026 1:12:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Locker Room Bldg Boys Locker Room	Manual	3/19/2026 1:11:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Locker Room Bldg Boys Locker RR	Manual	3/19/2026 1:12:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Locker Room Bldg East Exterior	Manual	3/19/2026 1:12:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Locker Room Bldg Girls Locker Entry	Manual	3/19/2026 1:11:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Locker Room Bldg Girls Locker Office	Manual	3/19/2026 1:11:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Locker Room Bldg Girls Locker Room	Manual	3/19/2026 1:12:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Locker Room Bldg Girls Locker Room	Manual	3/19/2026 1:11:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Locker Room Bldg Girls Locker RR	Manual	3/19/2026 1:12:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Locker Room Bldg NW Exterior	Manual	3/19/2026 1:12:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Locker Room Bldg NW Exterior	Manual	3/19/2026 1:12:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Multi-Purpose Bldg Kitchen	Manual	3/19/2026 1:12:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible		Multi-Purpose Bldg Kitchen	Manual	3/19/2026 1:11:37 PM
		Visual inspection	Passed (Manual)	
Audible And Visible		Multi-Purpose Bldg Kitchen Dishwash	Manual	3/19/2026 1:12:45 PM
		Visual inspection	Passed (Manual)	
Audible And Visible		Multi-Purpose Bldg Kitchen Restroom	Manual	3/19/2026 1:12:47 PM
		Visual inspection	Passed (Manual)	
Visible		Multi-Purpose Bldg Kitchen Restroom	Manual	3/19/2026 1:11:38 PM
		Visual inspection	Passed (Manual)	
Visible		Multi-Purpose Bldg Kitchen Restroom	Manual	3/19/2026 1:11:40 PM
		Visual inspection	Passed (Manual)	
Audible And Visible		Multi-Purpose Bldg MP Room	Manual	3/19/2026 1:12:41 PM
		Visual inspection	Passed (Manual)	
Audible And Visible		Multi-Purpose Bldg MP Room	Manual	3/19/2026 1:12:42 PM
		Visual inspection	Passed (Manual)	
Audible		Multi-Purpose Bldg North Exterior	Manual	3/19/2026 1:12:15 PM
		Visual inspection	Passed (Manual)	
Audible		Multi-Purpose Bldg North Exterior	Manual	3/19/2026 1:12:16 PM
		Visual inspection	Passed (Manual)	
Audible And Visible		Multi-Purpose Bldg Stage	Manual	3/19/2026 1:12:50 PM
		Visual inspection	Passed (Manual)	
Audible And Visible		Multi-Purpose Bldg Stage Stairs	Manual	3/19/2026 1:12:48 PM
		Visual inspection	Passed (Manual)	
Visible		Music Building Music A29 Office N	Manual	3/19/2026 1:11:43 PM
		Visual inspection	Passed (Manual)	
Visible		Music Building Music A29 Office S	Manual	3/19/2026 1:11:41 PM
		Visual inspection	Passed (Manual)	
Audible And Visible		Music Building Music Room A29	Manual	3/19/2026 1:12:52 PM
		Visual inspection	Passed (Manual)	
Audible And Visible		Music Building Music Room A29	Manual	3/19/2026 1:12:53 PM
		Visual inspection	Passed (Manual)	
Audible And Visible		Music Building South Exterior	Manual	3/19/2026 1:12:55 PM
		Visual inspection	Passed (Manual)	
Audible And Visible		Rooms P1-P6 Bldg Classroom P1	Manual	3/19/2026 1:12:22 PM
		Visual inspection	Passed (Manual)	
Audible And Visible		Rooms P1-P6 Bldg Classroom P2	Manual	3/19/2026 1:12:23 PM
		Visual inspection	Passed (Manual)	
Audible And Visible		Rooms P1-P6 Bldg Classroom P3	Manual	3/19/2026 1:12:26 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms P1-P6 Bldg Classroom P4	Manual	3/19/2026 1:12:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms P1-P6 Bldg Classroom P5	Manual	3/19/2026 1:12:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms P1-P6 Bldg East Exterior	Manual	3/19/2026 1:12:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms P1-P6 Bldg North Exterior	Manual	3/19/2026 1:12:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms P1-P6 Bldg Weight Room	Manual	3/19/2026 1:12:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms P1-P6 Bldg Weight Room	Manual	3/19/2026 1:12:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Chemical Extinguishing Systems

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Nozzle	Nozzles		Manual	3/19/2026 1:14:40 PM

Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Remote Annunciator		Admin Bldg Reception	Manual	3/19/2026 3:32:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-112 032	Admin Bldg Admin Office	Manual	3/19/2026 3:38:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-004 014	Admin Bldg Attendance	Manual	3/19/2026 3:38:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-005 015	Admin Bldg Attendance	Manual	3/19/2026 3:38:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-127 037	Admin Bldg Attic FACP/Server Rm	Manual	3/19/2026 2:42:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-128 040	Admin Bldg Attic Mech Rm W	Manual	3/19/2026 2:41:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-128 041	Admin Bldg Attic Mech Rm W	Manual	3/19/2026 2:41:58 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-127 038	Admin Bldg Attic Rec Strg W	Manual	3/19/2026 2:42:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-127 036	Admin Bldg Attic Staff RR Hall	Manual	3/19/2026 2:42:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-129 039	Admin Bldg Attic VP Office S	Manual	3/19/2026 2:41:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-024 034	Admin Bldg Counselors Office	Manual	3/19/2026 2:52:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-026 033	Admin Bldg Counselors Office	Manual	3/19/2026 3:38:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-028 035	Admin Bldg Counselors Office	Manual	3/19/2026 3:38:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-001 003	Admin Bldg FACP / Server Rm	Manual	3/19/2026 3:37:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-009 021	Admin Bldg Mens Staff RR	Manual	3/19/2026 2:59:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-011 020	Admin Bldg Mens Staff RR	Manual	3/19/2026 3:38:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-007 016	Admin Bldg Nurse	Manual	3/19/2026 3:38:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-019 028	Admin Bldg Principal Secretary	Manual	3/19/2026 3:38:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-018 027	Admin Bldg Principal Secretary	Manual	3/19/2026 3:38:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-021 026	Admin Bldg Principal Secretary	Manual	3/19/2026 3:38:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-111 031	Admin Bldg Principals Office	Manual	3/19/2026 3:38:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-020 030	Admin Bldg Principals Office	Manual	3/19/2026 3:38:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-022 029	Admin Bldg Principals Office	Manual	3/19/2026 3:38:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Manual Pull Station	2-126 002	Admin Bldg Reception	Manual	3/19/2026 3:38:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-034 008	Admin Bldg Reception	Manual	3/19/2026 3:38:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-035 007	Admin Bldg Reception	Manual	3/19/2026 3:38:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-002 005	Admin Bldg Reception	Manual	3/19/2026 3:38:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-036 006	Admin Bldg Reception	Manual	3/19/2026 3:38:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-003 004	Admin Bldg Reception	Manual	3/19/2026 3:38:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-029 025	Admin Bldg Reception Office Hall	Manual	3/19/2026 3:38:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-030 012	Admin Bldg Reception Strg W	Manual	3/19/2026 3:38:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-010 024	Admin Bldg Staff Room	Manual	3/19/2026 3:38:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-013 023	Admin Bldg Staff Room	Manual	3/19/2026 3:38:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-014 022	Admin Bldg Staff Room	Manual	3/19/2026 3:38:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-015 013	Admin Bldg Staff RR Hall	Manual	3/19/2026 3:38:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-012 019	Admin Bldg Staff RR Storage	Manual	3/19/2026 3:38:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-032 011	Admin Bldg VP Office North	Manual	3/19/2026 3:37:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-033 010	Admin Bldg VP Office North	Manual	3/19/2026 3:38:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-031 009	Admin Bldg VP Office South	Manual	3/19/2026 3:38:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-008 018	Admin Bldg Womens Staff RR	Manual	3/19/2026 3:38:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-006 017	Admin Bldg Womens Staff RR	Manual	3/19/2026 3:38:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-128 548	Boiler/Chiller Bldg Boiler Room D1	Manual	3/19/2026 2:42:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-128 549	Boiler/Chiller Bldg Chiller Room	Manual	3/19/2026 2:42:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-387 104	Building A Attic Staff Lounge Hall	Manual	3/19/2026 2:42:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-331 074	Building A Classrm A1 Display	Manual	3/19/2026 3:30:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-341 068	Building A Classroom A1	Manual	3/19/2026 3:31:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-340 069	Building A Classroom A1	Manual	3/19/2026 3:31:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-338 067	Building A Classroom A1	Manual	3/19/2026 3:31:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-336 066	Building A Classroom A1	Manual	3/19/2026 3:31:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-335 065	Building A Classroom A1	Manual	3/19/2026 3:31:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-334 064	Building A Classroom A1	Manual	3/19/2026 3:31:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-333 063	Building A Classroom A1	Manual	3/19/2026 3:31:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-332 062	Building A Classroom A1	Manual	3/19/2026 3:31:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-339 071	Building A Classroom A1 Office	Manual	3/19/2026 3:30:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-337 070	Building A Classroom A1 Office	Manual	3/19/2026 3:30:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-342 072	Building A Classroom A1 Strg	Manual	3/19/2026 3:30:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-344 073	Building A Classroom A1 Strg	Manual	3/19/2026 3:30:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-268 076	Building A Classroom A4	Manual	3/19/2026 3:25:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-345 081	Building A Classroom A4	Manual	3/19/2026 3:31:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-343 082	Building A Classroom A4	Manual	3/19/2026 3:31:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-346 080	Building A Classroom A4	Manual	3/19/2026 3:31:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-348 079	Building A Classroom A4	Manual	3/19/2026 3:31:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-350 078	Building A Classroom A4	Manual	3/19/2026 3:31:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-351 077	Building A Classroom A4	Manual	3/19/2026 3:31:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-267 075	Building A Classroom A4	Manual	3/19/2026 3:31:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-347 084	Building A Classroom A4 Strg	Manual	3/19/2026 3:30:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-344 083	Building A Classroom A4 Strg	Manual	3/19/2026 3:30:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-349 085	Building A Classroom A4 Strg	Manual	3/19/2026 3:31:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-329 098	Building A Custodian Office	Manual	3/19/2026 3:25:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-271 099	Building A Custodian Office	Manual	3/19/2026 3:25:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-270 097	Building A Custodian Office	Manual	3/19/2026 3:26:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-355 100	Building A Custodian Office RR	Manual	3/19/2026 3:31:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-352 103	Building A Mens Staff RR	Manual	3/19/2026 2:47:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-390 105	Building A Plum Chase Staff RR	Manual	3/19/2026 1:15:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-269 088	Building A Staff Lounge	Manual	3/19/2026 3:25:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-265 090	Building A Staff Lounge	Manual	3/19/2026 3:25:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-363 094	Building A Staff Lounge	Manual	3/19/2026 3:31:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-361 095	Building A Staff Lounge	Manual	3/19/2026 3:31:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-360 096	Building A Staff Lounge	Manual	3/19/2026 3:31:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-358 092	Building A Staff Lounge	Manual	3/19/2026 3:31:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-359 093	Building A Staff Lounge	Manual	3/19/2026 3:31:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-357 091	Building A Staff Lounge	Manual	3/19/2026 3:31:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-266 089	Building A Staff Lounge	Manual	3/19/2026 3:31:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-321 086	Building A Staff Lounge Hall	Manual	3/19/2026 3:31:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-322 087	Building A Staff Lounge Hall Clst	Manual	3/19/2026 3:31:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-353 102	Building A Womens Staff RR	Manual	3/19/2026 3:31:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-354 101	Building A Womens Staff RR	Manual	3/19/2026 3:31:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	3-127 148	Building C Attic Media Ctr Strg	Manual	3/19/2026 2:42:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-127 149	Building C Attic Media Ctr Strg	Manual	3/19/2026 2:42:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-002 145	Building C Boys Restroom	Manual	3/19/2026 2:59:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-010 144	Building C Classrm C8 Storage	Manual	3/19/2026 2:59:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-022 118	Building C Classroom C1	Manual	3/19/2026 2:49:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-021 119	Building C Classroom C1	Manual	3/19/2026 2:49:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-020 120	Building C Classroom C1	Manual	3/19/2026 2:50:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-019 121	Building C Classroom C1	Manual	3/19/2026 2:50:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-015 122	Building C Classroom C2	Manual	3/19/2026 2:50:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-016 123	Building C Classroom C2	Manual	3/19/2026 2:50:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-017 124	Building C Classroom C2	Manual	3/19/2026 2:50:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-018 125	Building C Classroom C2	Manual	3/19/2026 2:50:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-030 135	Building C Classroom C5	Manual	3/19/2026 2:48:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-029 136	Building C Classroom C5	Manual	3/19/2026 2:48:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-028 137	Building C Classroom C5	Manual	3/19/2026 2:48:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-007 139	Building C Classroom C8	Manual	3/19/2026 2:51:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-008 138	Building C Classroom C8	Manual	3/19/2026 2:51:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-006 140	Building C Classroom C8	Manual	3/19/2026 2:51:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-113 141	Building C Classroom C8	Manual	3/19/2026 2:51:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-005 142	Building C Classroom C8	Manual	3/19/2026 2:51:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-004 143	Building C Classroom C8	Manual	3/19/2026 2:51:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-003 147	Building C Custodial Closet	Manual	3/19/2026 2:59:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-001 146	Building C Girls Restroom	Manual	3/19/2026 2:59:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-026 129	Building C Media Center	Manual	3/19/2026 2:48:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-025 128	Building C Media Center	Manual	3/19/2026 2:48:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-024 127	Building C Media Center	Manual	3/19/2026 2:49:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-023 126	Building C Media Center	Manual	3/19/2026 2:49:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-014 133	Building C Media Center	Manual	3/19/2026 2:49:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-013 132	Building C Media Center	Manual	3/19/2026 2:49:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-012 131	Building C Media Center	Manual	3/19/2026 2:49:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-011 130	Building C Media Center	Manual	3/19/2026 2:49:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-009 134	Building C Media Center Storage	Manual	3/19/2026 2:59:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	3-126 152	Building C Plum Chas Cust Clst	Manual	3/19/2026 1:15:25 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3-215 150	Building C Soffit Heat Rm C5 E	Manual	3/19/2026 2:41:04 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3-214 151	Building C Soffit Heat Rm C5 W	Manual	3/19/2026 2:42:38 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3-130 199	Building E Attic Room E4 Strg	Manual	3/19/2026 2:41:00 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	3-130 198	Building E Attic Room E4 Strg	Manual	3/19/2026 2:41:02 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-055 165	Building E Classroom E1	Manual	3/19/2026 2:48:14 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-054 166	Building E Classroom E1	Manual	3/19/2026 2:48:29 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-053 167	Building E Classroom E1	Manual	3/19/2026 2:48:41 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-052 168	Building E Classroom E1	Manual	3/19/2026 2:48:52 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-048 169	Building E Classroom E2	Manual	3/19/2026 2:52:17 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-049 170	Building E Classroom E2	Manual	3/19/2026 2:52:21 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-050 171	Building E Classroom E2	Manual	3/19/2026 2:52:25 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-051 172	Building E Classroom E2	Manual	3/19/2026 2:52:29 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-056 176	Building E Classroom E3	Manual	3/19/2026 2:49:22 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-057 175	Building E Classroom E3	Manual	3/19/2026 2:49:36 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	3-058 174	Building E Classroom E3	Manual	3/19/2026 2:49:46 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-059 173	Building E Classroom E3	Manual	3/19/2026 2:49:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-047 177	Building E Classroom E4	Manual	3/19/2026 2:52:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-046 178	Building E Classroom E4	Manual	3/19/2026 2:52:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-045 179	Building E Classroom E4	Manual	3/19/2026 2:52:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-044 180	Building E Classroom E4	Manual	3/19/2026 2:52:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-042 181	Building E Classroom E4 Strg	Manual	3/19/2026 3:00:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-060 186	Building E Classroom E5	Manual	3/19/2026 2:50:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-061 185	Building E Classroom E5	Manual	3/19/2026 2:50:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-062 184	Building E Classroom E5	Manual	3/19/2026 2:50:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-063 183	Building E Classroom E5	Manual	3/19/2026 2:50:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-064 182	Building E Classroom E5	Manual	3/19/2026 3:00:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-041 187	Building E Classroom E8	Manual	3/19/2026 2:50:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-040 188	Building E Classroom E8	Manual	3/19/2026 2:51:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-039 189	Building E Classroom E8	Manual	3/19/2026 2:51:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-038 190	Building E Classroom E8	Manual	3/19/2026 2:51:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-037 191	Building E Classroom E8	Manual	3/19/2026 2:51:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-036 192	Building E Classroom E8	Manual	3/19/2026 2:51:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-043 193	Building E Classroom E8 Strg	Manual	3/19/2026 3:00:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-032 197	Building E Custodial Closet	Manual	3/19/2026 2:52:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-129 200	Building E Plum Chas Cust Clst	Manual	3/19/2026 1:15:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-034 194	Building E Staff Restroom North	Manual	3/19/2026 2:52:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-035 196	Building E Staff Restroom South	Manual	3/19/2026 3:00:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-033 195	Building E Storage in North RR	Manual	3/19/2026 2:52:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-073 216	Building F Classroom F1	Manual	3/19/2026 3:31:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-118 217	Building F Classroom F1	Manual	3/19/2026 3:31:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-072 218	Building F Classroom F1	Manual	3/19/2026 3:31:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-074 215	Building F Classroom F1	Manual	3/19/2026 3:31:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-075 219	Building F Classroom F2	Manual	3/19/2026 2:53:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-076 220	Building F Classroom F2	Manual	3/19/2026 2:53:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-077 222	Building F Classroom F2	Manual	3/19/2026 2:53:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-116 221	Building F Classroom F2	Manual	3/19/2026 2:53:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-070 224	Building F Classroom F3	Manual	3/19/2026 3:31:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-119 225	Building F Classroom F3	Manual	3/19/2026 3:31:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-071 226	Building F Classroom F3	Manual	3/19/2026 3:31:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-069 223	Building F Classroom F3	Manual	3/19/2026 3:31:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-079 228	Building F Classroom F4	Manual	3/19/2026 2:52:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-117 229	Building F Classroom F4	Manual	3/19/2026 2:53:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-078 230	Building F Classroom F4	Manual	3/19/2026 2:53:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-080 227	Building F Classroom F4	Manual	3/19/2026 3:32:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-079 262	Building G Classroom G6	Manual	3/19/2026 2:52:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-080 265	Building G Classroom G6 Office	Manual	3/19/2026 2:52:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-131 311	Building H Attic Room H4 Strg	Manual	3/19/2026 2:42:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-131 310	Building H Attic Room H4 Strg	Manual	3/19/2026 2:42:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-039 307	Building H Boys Restroom	Manual	3/19/2026 3:24:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-058 279	Building H Classroom H1	Manual	3/19/2026 3:24:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-057 280	Building H Classroom H1	Manual	3/19/2026 3:24:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-056 281	Building H Classroom H1	Manual	3/19/2026 3:24:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-059 278	Building H Classroom H1	Manual	3/19/2026 3:24:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-054 284	Building H Classroom H2	Manual	3/19/2026 3:25:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-053 283	Building H Classroom H2	Manual	3/19/2026 3:25:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-055 285	Building H Classroom H2	Manual	3/19/2026 3:25:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-052 282	Building H Classroom H2	Manual	3/19/2026 3:25:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-063 286	Building H Classroom H3	Manual	3/19/2026 2:59:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-062 287	Building H Classroom H3	Manual	3/19/2026 2:59:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-061 288	Building H Classroom H3	Manual	3/19/2026 2:59:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-060 289	Building H Classroom H3	Manual	3/19/2026 2:59:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-048 293	Building H Classroom H4	Manual	3/19/2026 3:25:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-050 291	Building H Classroom H4	Manual	3/19/2026 3:25:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-049 292	Building H Classroom H4	Manual	3/19/2026 3:25:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-051 290	Building H Classroom H4	Manual	3/19/2026 3:25:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-046 294	Building H Classroom H4 Strg	Manual	3/19/2026 3:25:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-068 299	Building H Classroom H5	Manual	3/19/2026 2:59:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-067 298	Building H Classroom H5	Manual	3/19/2026 2:59:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-066 297	Building H Classroom H5	Manual	3/19/2026 2:59:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-065 296	Building H Classroom H5	Manual	3/19/2026 2:59:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-064 295	Building H Classroom H5	Manual	3/19/2026 2:59:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-040 305	Building H Classroom H8	Manual	3/19/2026 3:24:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-041 304	Building H Classroom H8	Manual	3/19/2026 3:24:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-042 303	Building H Classroom H8	Manual	3/19/2026 3:24:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-043 302	Building H Classroom H8	Manual	3/19/2026 3:24:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-044 301	Building H Classroom H8	Manual	3/19/2026 3:24:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-045 300	Building H Classroom H8	Manual	3/19/2026 3:25:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-047 306	Building H Classroom H8 Strg	Manual	3/19/2026 3:24:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-037 309	Building H Custodial Closet	Manual	3/19/2026 3:24:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-038 308	Building H Girls Restroom	Manual	3/19/2026 3:24:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-130 312	Building H Plum Chas Cust Clst	Manual	3/19/2026 1:15:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-133 357	Building I Attic Room I-4 Strg	Manual	3/19/2026 2:42:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-133 358	Building I Attic Room I-4 Strg	Manual	3/19/2026 2:42:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-083 354	Building I Boys Restroom	Manual	3/19/2026 3:00:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-102 325	Building I Classroom I-1	Manual	3/19/2026 2:47:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-101 326	Building I Classroom I-1	Manual	3/19/2026 2:47:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-100 327	Building I Classroom I-1	Manual	3/19/2026 2:47:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-099 328	Building I Classroom I-1	Manual	3/19/2026 2:48:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-095 329	Building I Classroom I-2	Manual	3/19/2026 2:47:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-096 330	Building I Classroom I-2	Manual	3/19/2026 2:47:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-097 331	Building I Classroom I-2	Manual	3/19/2026 2:47:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-098 332	Building I Classroom I-2	Manual	3/19/2026 2:47:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-103 336	Building I Classroom I-3	Manual	3/19/2026 2:47:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-104 335	Building I Classroom I-3	Manual	3/19/2026 2:47:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-105 334	Building I Classroom I-3	Manual	3/19/2026 2:47:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-106 333	Building I Classroom I-3	Manual	3/19/2026 2:47:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-092 338	Building I Classroom I-4	Manual	3/19/2026 2:46:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-091 337	Building I Classroom I-4	Manual	3/19/2026 2:46:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-093 339	Building I Classroom I-4	Manual	3/19/2026 2:46:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-094 340	Building I Classroom I-4	Manual	3/19/2026 2:46:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-089 341	Building I Classroom I-4 Strg	Manual	3/19/2026 2:45:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-115 342	Building I Classroom I-5	Manual	3/19/2026 2:45:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-110 343	Building I Classroom I-5	Manual	3/19/2026 2:45:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-109 344	Building I Classroom I-5	Manual	3/19/2026 2:45:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-108 345	Building I Classroom I-5	Manual	3/19/2026 2:45:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-107 346	Building I Classroom I-5	Manual	3/19/2026 2:45:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-088 347	Building I Classroom I-8	Manual	3/19/2026 2:46:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-087 348	Building I Classroom I-8	Manual	3/19/2026 2:46:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-114 349	Building I Classroom I-8	Manual	3/19/2026 2:46:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-086 350	Building I Classroom I-8	Manual	3/19/2026 2:46:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-085 351	Building I Classroom I-8	Manual	3/19/2026 2:46:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-084 352	Building I Classroom I-8	Manual	3/19/2026 2:46:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-090 353	Building I Classroom I-8 Strg	Manual	3/19/2026 3:00:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-081 356	Building I Custodial Closet	Manual	3/19/2026 3:00:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-082 355	Building I Girls Restroom	Manual	3/19/2026 3:00:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-132 359	Building I Plum Chas Cust Clst	Manual	3/19/2026 1:15:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-378 454	Locker Room Bldg Attic Boys Locker Off	Manual	3/19/2026 2:40:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-381 455	Locker Room Bldg Attic Girls Locker Off	Manual	3/19/2026 2:40:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-261 429	Locker Room Bldg Boys Locker Entry	Manual	3/19/2026 3:29:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-263 432	Locker Room Bldg Boys Locker Office	Manual	3/19/2026 3:29:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-264 431	Locker Room Bldg Boys Locker Office	Manual	3/19/2026 3:29:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-413 442	Locker Room Bldg Boys Locker Room	Manual	3/19/2026 2:41:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-413 443	Locker Room Bldg Boys Locker Room	Manual	3/19/2026 2:41:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-413 444	Locker Room Bldg Boys Locker Room	Manual	3/19/2026 2:41:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-413 445	Locker Room Bldg Boys Locker Room	Manual	3/19/2026 2:41:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-413 446	Locker Room Bldg Boys Locker Room	Manual	3/19/2026 2:41:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-413 447	Locker Room Bldg Boys Locker Room	Manual	3/19/2026 2:41:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-380 457	Locker Room Bldg Boys Locker Room	Manual	3/19/2026 3:29:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-262 430	Locker Room Bldg Boys Locker RR	Manual	3/19/2026 3:29:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-277 433	Locker Room Bldg Boys Locker Storage	Manual	3/19/2026 3:28:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-274 434	Locker Room Bldg Boys Locker Strg S	Manual	3/19/2026 3:29:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-377 456	Locker Room Bldg Girls Lock Plum Chs	Manual	3/19/2026 1:15:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-260 435	Locker Room Bldg Girls Locker Entry	Manual	3/19/2026 3:29:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-280 437	Locker Room Bldg Girls Locker Office	Manual	3/19/2026 3:28:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-279 438	Locker Room Bldg Girls Locker Office	Manual	3/19/2026 3:29:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-414 448	Locker Room Bldg Girls Locker Room	Manual	3/19/2026 2:41:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-414 449	Locker Room Bldg Girls Locker Room	Manual	3/19/2026 2:41:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-414 450	Locker Room Bldg Girls Locker Room	Manual	3/19/2026 2:41:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-414 451	Locker Room Bldg Girls Locker Room	Manual	3/19/2026 2:41:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-414 452	Locker Room Bldg Girls Locker Room	Manual	3/19/2026 2:41:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-414 453	Locker Room Bldg Girls Locker Room	Manual	3/19/2026 2:41:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-382 458	Locker Room Bldg Girls Locker Room	Manual	3/19/2026 3:29:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-259 436	Locker Room Bldg Girls Locker RR	Manual	3/19/2026 3:28:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-291 439	Locker Room Bldg Girls Locker Storage	Manual	3/19/2026 3:29:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-273 440	Locker Room Bldg PE Storage	Manual	3/19/2026 3:29:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-272 441	Locker Room Bldg Wash Mach Room	Manual	3/19/2026 3:29:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-389 512	Multi-Purpose Bldg Attic Kitchen	Manual	3/19/2026 2:41:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-362	Multi-Purpose Bldg Kitchen	Manual	3/19/2026 2:41:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-330 509	Multi-Purpose Bldg Kitchen	Manual	3/19/2026 2:41:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-323 508	Multi-Purpose Bldg Kitchen	Manual	3/19/2026 2:41:40 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-325 493	Multi-Purpose Bldg Kitchen	Manual	3/19/2026 3:28:01 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-326 510	Multi-Purpose Bldg Kitchen Dishwash	Manual	3/19/2026 2:41:35 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Manual Pull Station	2-388 475	Multi-Purpose Bldg Kitchen North Exit	Manual	3/19/2026 3:28:15 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-324 494	Multi-Purpose Bldg Kitchen Office	Manual	3/19/2026 3:27:57 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-328 497	Multi-Purpose Bldg Kitchen Restroom	Manual	3/19/2026 3:27:59 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-327 496	Multi-Purpose Bldg Kitchen Restroom	Manual	3/19/2026 3:28:04 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-326 495	Multi-Purpose Bldg Kitchen RR Entry	Manual	3/19/2026 3:27:24 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-356 498	Multi-Purpose Bldg Kitchen Storage	Manual	3/19/2026 3:27:27 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-325 499	Multi-Purpose Bldg Kitchen Storage Clst	Manual	3/19/2026 3:27:25 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-299 511	Multi-Purpose Bldg Mech Rm O/S Stage	Manual	3/19/2026 2:41:07 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	2-394 513	Multi-Purpose Bldg Mech Rm O/S Stage	Manual	3/19/2026 3:27:28 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-320 490	Multi-Purpose Bldg MP Room	Manual	3/19/2026 3:28:00 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-318 489	Multi-Purpose Bldg MP Room	Manual	3/19/2026 3:28:03 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-317 488	Multi-Purpose Bldg MP Room	Manual	3/19/2026 3:28:06 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-314 487	Multi-Purpose Bldg MP Room	Manual	3/19/2026 3:28:08 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-313 486	Multi-Purpose Bldg MP Room	Manual	3/19/2026 3:28:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-310 485	Multi-Purpose Bldg MP Room	Manual	3/19/2026 3:28:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-309 484	Multi-Purpose Bldg MP Room	Manual	3/19/2026 3:28:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-307 483	Multi-Purpose Bldg MP Room	Manual	3/19/2026 3:28:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-308 482	Multi-Purpose Bldg MP Room	Manual	3/19/2026 3:28:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-311 481	Multi-Purpose Bldg MP Room	Manual	3/19/2026 3:28:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-312 480	Multi-Purpose Bldg MP Room	Manual	3/19/2026 3:28:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-315 479	Multi-Purpose Bldg MP Room	Manual	3/19/2026 3:28:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-316 478	Multi-Purpose Bldg MP Room	Manual	3/19/2026 3:28:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-319 477	Multi-Purpose Bldg MP Room	Manual	3/19/2026 3:28:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-385 474	Multi-Purpose Bldg MP Room NW	Manual	3/19/2026 3:28:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-384 472	Multi-Purpose Bldg MP Room SE	Manual	3/19/2026 3:28:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-306 492	Multi-Purpose Bldg MP Room Storage	Manual	3/19/2026 3:27:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-375 491	Multi-Purpose Bldg MP Room Storage	Manual	3/19/2026 3:27:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-386 473	Multi-Purpose Bldg MP Room SW	Manual	3/19/2026 3:28:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-295 506	Multi-Purpose Bldg Stage	Manual	3/19/2026 3:27:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-294 505	Multi-Purpose Bldg Stage	Manual	3/19/2026 3:27:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-293 504	Multi-Purpose Bldg Stage	Manual	3/19/2026 3:27:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-296 503	Multi-Purpose Bldg Stage	Manual	3/19/2026 3:27:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-297 502	Multi-Purpose Bldg Stage	Manual	3/19/2026 3:27:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-298 501	Multi-Purpose Bldg Stage	Manual	3/19/2026 3:27:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-391 476	Multi-Purpose Bldg Stage South Exit	Manual	3/19/2026 3:28:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-305 500	Multi-Purpose Bldg Stage Stairs	Manual	3/19/2026 3:27:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-300 507	Multi-Purpose Bldg Stage Storage N	Manual	3/19/2026 3:27:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-276 536	Music Building Music A29 Above PE	Manual	3/19/2026 3:26:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-304 537	Music Building Music A29 Hall Closet	Manual	3/19/2026 3:27:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-252 527	Music Building Music A29 O/S Hall	Manual	3/19/2026 3:27:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-251 528	Music Building Music A29 O/S Hall	Manual	3/19/2026 3:27:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-303 539	Music Building Music A29 Office N	Manual	3/19/2026 3:27:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-302 538	Music Building Music A29 Office S	Manual	3/19/2026 3:27:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-383 541	Music Building Music Room A29	Manual	3/19/2026 3:27:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-253 529	Music Building Music Room A29	Manual	3/19/2026 3:26:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-301 535	Music Building Music Room A29	Manual	3/19/2026 3:27:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-256 534	Music Building Music Room A29	Manual	3/19/2026 3:27:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-255 533	Music Building Music Room A29	Manual	3/19/2026 3:27:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-257 531	Music Building Music Room A29	Manual	3/19/2026 3:27:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-258 530	Music Building Music Room A29	Manual	3/19/2026 3:27:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-254 532	Music Building Music Room A29	Manual	3/19/2026 3:27:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-132 392	Rooms P1-P6 Bldg Attic Classroom P1	Manual	3/19/2026 2:42:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-132 393	Rooms P1-P6 Bldg Attic Classroom P1	Manual	3/19/2026 2:42:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-132 394	Rooms P1-P6 Bldg Attic Classroom P1	Manual	3/19/2026 2:42:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-132 395	Rooms P1-P6 Bldg Attic Classroom P1	Manual	3/19/2026 2:42:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-132 396	Rooms P1-P6 Bldg Attic Classroom P1	Manual	3/19/2026 2:42:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-132 397	Rooms P1-P6 Bldg Attic Classroom P1	Manual	3/19/2026 2:42:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-132 398	Rooms P1-P6 Bldg Attic Classroom P1	Manual	3/19/2026 2:42:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-131 400	Rooms P1-P6 Bldg Attic Classroom P2	Manual	3/19/2026 2:42:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-131 399	Rooms P1-P6 Bldg Attic Classroom P2	Manual	3/19/2026 2:42:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-131 401	Rooms P1-P6 Bldg Attic Classroom P2	Manual	3/19/2026 2:42:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	3-131 402	Rooms P1-P6 Bldg Attic Classroom P2	Manual	3/19/2026 2:42:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-131 404	Rooms P1-P6 Bldg Attic Classroom P2	Manual	3/19/2026 2:42:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-131 403	Rooms P1-P6 Bldg Attic Classroom P2	Manual	3/19/2026 2:42:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-138 405	Rooms P1-P6 Bldg Attic Classroom P3	Manual	3/19/2026 2:41:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-138 407	Rooms P1-P6 Bldg Attic Classroom P3	Manual	3/19/2026 2:41:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-138 406	Rooms P1-P6 Bldg Attic Classroom P3	Manual	3/19/2026 2:41:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-137 409	Rooms P1-P6 Bldg Attic Classroom P4	Manual	3/19/2026 2:41:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-137 410	Rooms P1-P6 Bldg Attic Classroom P4	Manual	3/19/2026 2:41:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-137 411	Rooms P1-P6 Bldg Attic Classroom P4	Manual	3/19/2026 2:41:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-135 414	Rooms P1-P6 Bldg Attic Classroom P5	Manual	3/19/2026 2:41:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-135 415	Rooms P1-P6 Bldg Attic Classroom P5	Manual	3/19/2026 2:41:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-135 413	Rooms P1-P6 Bldg Attic Classroom P5	Manual	3/19/2026 2:41:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-099 371	Rooms P1-P6 Bldg Classroom P1	Manual	3/19/2026 2:45:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-098 372	Rooms P1-P6 Bldg Classroom P1	Manual	3/19/2026 2:45:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-101 373	Rooms P1-P6 Bldg Classroom P1	Manual	3/19/2026 2:45:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-100 374	Rooms P1-P6 Bldg Classroom P1	Manual	3/19/2026 2:45:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-096 375	Rooms P1-P6 Bldg Classroom P2	Manual	3/19/2026 2:44:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-095 378	Rooms P1-P6 Bldg Classroom P2	Manual	3/19/2026 2:44:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-094 377	Rooms P1-P6 Bldg Classroom P2	Manual	3/19/2026 2:44:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-097 376	Rooms P1-P6 Bldg Classroom P2	Manual	3/19/2026 2:44:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-093 379	Rooms P1-P6 Bldg Classroom P2 Closet	Manual	3/19/2026 2:44:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-111 380	Rooms P1-P6 Bldg Classroom P3	Manual	3/19/2026 2:44:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-112 381	Rooms P1-P6 Bldg Classroom P3	Manual	3/19/2026 2:44:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-109 383	Rooms P1-P6 Bldg Classroom P4	Manual	3/19/2026 2:44:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-110 382	Rooms P1-P6 Bldg Classroom P4	Manual	3/19/2026 2:44:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-107 384	Rooms P1-P6 Bldg Classroom P5	Manual	3/19/2026 2:43:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-108 385	Rooms P1-P6 Bldg Classroom P5	Manual	3/19/2026 2:43:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-139 408	Rooms P1-P6 Bldg Rm P3 HVAC Closet	Manual	3/19/2026 2:42:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-136 412	Rooms P1-P6 Bldg Rm P4 HVAC Closet	Manual	3/19/2026 2:42:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-134 416	Rooms P1-P6 Bldg Rm P5 HVAC Closet	Manual	3/19/2026 2:42:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-133 417	Rooms P1-P6 Bldg Weight rm HVAC Clst	Manual	3/19/2026 2:41:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-104 389	Rooms P1-P6 Bldg Weight Room	Manual	3/19/2026 2:43:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-105 387	Rooms P1-P6 Bldg Weight Room	Manual	3/19/2026 2:43:38 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	3-106 386	Rooms P1-P6 Bldg Weight Room	Manual	3/19/2026 2:43:42 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	3-103 390	Rooms P1-P6 Bldg Weight Room	Manual	3/19/2026 3:32:10 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	3-102 391	Rooms P1-P6 Bldg Weight Room Closet	Manual	3/19/2026 2:43:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Functional Inspection	Passed	

Failed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-119 240	Building G Classroom G1	Manual	3/19/2026 2:57:37 PM
		Functional Inspection	Failed	
Smoke Detector - General	3-089 241	Building G Classroom G1	Manual	3/19/2026 2:57:46 PM
		Functional Inspection	Failed	
Smoke Detector - General	3-088 242	Building G Classroom G1	Manual	3/19/2026 2:57:54 PM
		Functional Inspection	Failed	
Smoke Detector - General	3-090 239	Building G Classroom G1	Manual	3/19/2026 2:58:02 PM
		Functional Inspection	Failed	
Smoke Detector - General	3-091 238	Building G Classroom G1	Manual	3/19/2026 2:58:13 PM
		Functional Inspection	Failed	
Smoke Detector - General	3-087 243	Building G Classroom G1	Manual	3/19/2026 2:58:22 PM
		Functional Inspection	Failed	
Smoke Detector - General	3-085 244	Building G Classroom G1	Manual	3/19/2026 2:58:31 PM
		Functional Inspection	Failed	
Smoke Detector - General	3-092 237	Building G Classroom G1	Manual	3/19/2026 2:58:41 PM
		Functional Inspection	Failed	
Smoke Detector - General	3-084 246	Building G Classroom G1 Office	Manual	3/19/2026 2:57:18 PM
		Functional Inspection	Failed	
Smoke Detector - General	3-086 245	Building G Classroom G1 Office	Manual	3/19/2026 2:57:27 PM
		Functional Inspection	Failed	
Smoke Detector - General	3-065 247	Building G Classroom G2	Manual	3/19/2026 2:54:00 PM
		Functional Inspection	Failed	
Smoke Detector - General	3-066 248	Building G Classroom G2	Manual	3/19/2026 2:54:34 PM
		Functional Inspection	Failed	
Smoke Detector - General	3-067 249	Building G Classroom G3	Manual	3/19/2026 2:54:45 PM
		Functional Inspection	Failed	
Smoke Detector - General	3-069 251	Building G Classroom G3	Manual	3/19/2026 2:54:56 PM
		Functional Inspection	Failed	
Smoke Detector - General	3-068 250	Building G Classroom G3	Manual	3/19/2026 2:55:05 PM
		Functional Inspection	Failed	
Smoke Detector - General	3-071 253	Building G Classroom G4	Manual	3/19/2026 2:55:16 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Failed	
Smoke Detector - General	3-072 254	Building G Classroom G4	Manual	3/19/2026 2:55:26 PM
		Functional Inspection	Failed	
Smoke Detector - General	3-070 252	Building G Classroom G4	Manual	3/19/2026 2:55:35 PM
		Functional Inspection	Failed	
Smoke Detector - General	3-073 255	Building G Classroom G5	Manual	3/19/2026 2:55:45 PM
		Functional Inspection	Failed	
Smoke Detector - General	3-074 256	Building G Classroom G5	Manual	3/19/2026 2:55:55 PM
		Functional Inspection	Failed	
Smoke Detector - General	3-075 257	Building G Classroom G6	Manual	3/19/2026 2:56:03 PM
		Functional Inspection	Failed	
Smoke Detector - General	3-076 258	Building G Classroom G6	Manual	3/19/2026 2:56:16 PM
		Functional Inspection	Failed	
Smoke Detector - General	3-077 259	Building G Classroom G6	Manual	3/19/2026 2:56:26 PM
		Functional Inspection	Failed	
Smoke Detector - General	3-121 260	Building G Classroom G6	Manual	3/19/2026 2:56:35 PM
		Functional Inspection	Failed	
Smoke Detector - General	3-078 261	Building G Classroom G6	Manual	3/19/2026 2:56:44 PM
		Functional Inspection	Failed	
Smoke Detector - General	3-081 263	Building G Classroom G6	Manual	3/19/2026 2:56:52 PM
		Functional Inspection	Failed	
Smoke Detector - General	3-083 264	Building G Classroom G6	Manual	3/19/2026 2:57:00 PM
		Functional Inspection	Failed	
Smoke Detector - General	3-082 266	Building G Classroom G6 Office	Manual	3/19/2026 2:57:09 PM
		Functional Inspection	Failed	
Heat Detector - Restorable Spot	2-376 540	Music Building Attic Music A29 Off N	Manual	3/19/2026 2:41:32 PM
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	
Smoke Detector - General	3-122 388	Rooms P1-P6 Bldg Weight Room	Manual	3/19/2026 2:43:25 PM
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	

Ventilation and Cooking Equipment

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Range Hood	Hood		Manual	3/19/2026 1:14:37 PM
Range Suppression	Suppression System		Manual	3/19/2026 1:14:43 PM
Range Suppression Tank	Ansul 3 Gallon Cylinder		Manual	3/19/2026 1:14:45 PM

Device/Equipment details

Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Audible					
042	Admin Bldg North Exterior				
043	Admin Bldg West Exterior				
044	Admin Bldg Southwest Exterior				
106	Building A Southeast Exterior				
153	Building C North Exterior				
154	Building C East Exterior				
201	Building E North Exterior				
202	Building E East Exterior				
203	Building E South Exterior				
204	Building E West Exterior				
231	Building F East Exterior				
232	Building F West Exterior				
267	Building G South Exterior				
313	Building H North Exterior				
314	Building H South Exterior				
360	Building I East Exterior				
361	Building I South Exterior				
418	Rooms P1-P6 Bldg North Exterior				
419	Rooms P1-P6 Bldg East Exterior				
459	Locker Room Bldg East Exterior				
460	Locker Room Bldg NW Exterior				
514	Multi-Purpose Bldg North Exterior				
525	Multi-Purpose Bldg North Exterior				
Audible And Visible					
045	Admin Bldg Reception				
046	Admin Bldg Attendance				
047	Admin Bldg Nurse				
048	Admin Bldg Staff Room				
049	Admin Bldg Principal Secretary				
050	Admin Bldg Principals Office				
051	Admin Bldg Admin Office				
052	Admin Bldg Counselors Office				
053	Admin Bldg VP Office South				
054	Admin Bldg VP Office North				
107	Building A Classroom A1				
108	Building A Classroom A4				
109	Building A Staff Lounge				
110	Building A Staff Loung				
111	Building A Custodian Office				
155	Building C Classroom C1				
156	Building C Classroom C2				
157	Building C Media Center				
158	Building C Media Center				
159	Building C Classroom C5				
160	Building C Classroom C8				
205	Building E Classroom E1				
206	Building E Classroom E2				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
207	Building E Classroom E3				
208	Building E Classroom E4				
209	Building E Classroom E5				
210	Building E Classroom E6				
233	Building F Classroom F1				
234	Building F Classroom F2				
235	Building F Classroom F3				
236	Building F Classroom F4				
268	Building G Classroom G1				
269	Building G Classroom G2				
270	Building G Classroom G3				
271	Building G Classroom G4				
272	Building G Classroom G5				
273	Building G Classroom G6				
315	Building H Classroom H1				
316	Building H Classroom H2				
317	Building H Classroom H3				
318	Building H Classroom H4				
319	Building H Classroom H5				
320	Building H Classroom H8				
362	Building I Classroom I-1				
363	Building I Classroom I-2				
364	Building I Classroom I-3				
365	Building I Classroom I-4				
366	Building I Classroom I-5				
367	Building I Classroom I-8				
420	Rooms P1-P6 Bldg Classroom P1				
421	Rooms P1-P6 Bldg Classroom P2				
422	Rooms P1-P6 Bldg Classroom P3				
423	Rooms P1-P6 Bldg Classroom P4				
424	Rooms P1-P6 Bldg Classroom P5				
425	Rooms P1-P6 Bldg Weight Room				
426	Rooms P1-P6 Bldg Weight Room				
461	Locker Room Bldg Boys Locker RR				
462	Locker Room Bldg Boys Locker Room				
463	Locker Room Bldg Girls Locker RR				
464	Locker Room Bldg Girls Locker Room				
465	Locker Room Bldg NW Exterior				
515	Multi-Purpose Bldg MP Room				
516	Multi-Purpose Bldg MP Room				
517	Multi-Purpose Bldg Kitchen				
518	Multi-Purpose Bldg Kitchen Dishwash				
519	Multi-Purpose Bldg Kitchen Restroom				
520	Multi-Purpose Bldg Stage Stairs				
521	Multi-Purpose Bldg Stage				
542	Music Building South Exterior				
543	Music Building Music Room A29				
544	Music Building Music Room A29				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Visible					
055	Admin Bldg Staff RR Hall				
056	Admin Bldg Womens Staff RR				
057	Admin Bldg Womens Staff RR				
058	Admin Bldg Mens Staff RR				
059	Admin Bldg Mens Staff RR				
060	Admin Bldg Reception Office Hall				
112	Building A Classroom A1				
113	Building A Classroom A4				
114	Building A Mens Staff RR				
115	Building A Womens Staff RR				
116	Building A Staff Lounge				
117	Building A Custodian Office RR				
161	Building C Media Center				
162	Building C Media Center Storage				
163	Building C Boys Restroom				
164	Building C Girls Restroom				
211	Building E Classroom E4 Strg				
212	Building E Staff Restroom North				
213	Building E Staff Restroom South				
274	Building G Classroom G1				
275	Building G Classroom G1 Office				
276	Building G Classroom G6				
277	Building G Classroom G6 Office				
321	Building H Classroom H4 Strg				
322	Building H Boys Restroom				
323	Building H Girls Restroom				
368	Building I Classroom I-4 Strg				
369	Building I Boys Restroom				
370	Building I Girls Restroom				
466	Locker Room Bldg Boys Locker Entry				
467	Locker Room Bldg Girls Locker Entry				
468	Locker Room Bldg Boys Locker Office				
469	Locker Room Bldg Girls Locker Office				
470	Locker Room Bldg Boys Locker Room				
471	Locker Room Bldg Girls Locker Room				
522	Multi-Purpose Bldg Kitchen				
523	Multi-Purpose Bldg Kitchen Restroom				
524	Multi-Purpose Bldg Kitchen Restroom				
545	Music Building Music A29 Office N				
546	Music Building Music A29 Office S				

Chemical Extinguishing Systems

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Nozzle					
Nozzles					01/27/2025

Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
---------	-------------	--------------	-------	--------	--------------

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Remote Annunciator					
001	Admin Bldg Reception				
NAC Power Extender Panel					
061	Admin Bldg FACP / Server Rm				
214	Building E Custodial Closet				
324	Building H Custodial Closet				
427	Rooms P1-P6 Bldg Classroom P2				
428	Rooms P1-P6 Bldg Weight Room Closet				
526	Multi-Purpose Bldg Kitchen Restroom				
547	Music Building Music Room A29				
Fire Alarm Panel					
	Admin Bldg FACP / Server Rm				
Initiating Device					
ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Manual Pull Station					
2-126 002	Admin Bldg Reception				
2-384 472	Multi-Purpose Bldg MP Room SE				
2-386 473	Multi-Purpose Bldg MP Room SW				
2-385 474	Multi-Purpose Bldg MP Room NW				
2-388 475	Multi-Purpose Bldg Kitchen North Exit				
2-391 476	Multi-Purpose Bldg Stage South Exit				
Smoke Detector - General					
2-001 003	Admin Bldg FACP / Server Rm				
2-003 004	Admin Bldg Reception				
2-002 005	Admin Bldg Reception				
2-036 006	Admin Bldg Reception				
2-035 007	Admin Bldg Reception				
2-034 008	Admin Bldg Reception				
2-031 009	Admin Bldg VP Office South				
2-033 010	Admin Bldg VP Office North				
2-032 011	Admin Bldg VP Office North				
2-030 012	Admin Bldg Reception Strg W				
2-015 013	Admin Bldg Staff RR Hall				
2-004 014	Admin Bldg Attendance				
2-005 015	Admin Bldg Attendance				
2-007 016	Admin Bldg Nurse				
2-006 017	Admin Bldg Womens Staff RR				
2-008 018	Admin Bldg Womens Staff RR				
2-012 019	Admin Bldg Staff RR Storage				
2-011 020	Admin Bldg Mens Staff RR				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-009 021	Admin Bldg Mens Staff RR				
2-014 022	Admin Bldg Staff Room				
2-013 023	Admin Bldg Staff Room				
2-010 024	Admin Bldg Staff Room				
2-029 025	Admin Bldg Reception Office Hall				
2-021 026	Admin Bldg Principal Secretary				
2-018 027	Admin Bldg Principal Secretary				
2-019 028	Admin Bldg Principal Secretary				
2-022 029	Admin Bldg Principals Office				
2-020 030	Admin Bldg Principals Office				
2-111 031	Admin Bldg Principals Office				
2-112 032	Admin Bldg Admin Office				
2-026 033	Admin Bldg Counselors Office				
2-024 034	Admin Bldg Counselors Office				
2-028 035	Admin Bldg Counselors Office				
2-332 062	Building A Classroom A1				
2-333 063	Building A Classroom A1				
2-334 064	Building A Classroom A1				
2-335 065	Building A Classroom A1				
2-336 066	Building A Classroom A1				
2-338 067	Building A Classroom A1				
2-341 068	Building A Classroom A1				
2-340 069	Building A Classroom A1				
2-337 070	Building A Classroom A1 Office				
2-339 071	Building A Classroom A1 Office				
2-342 072	Building A Classroom A1 Strg				
2-344 073	Building A Classroom A1 Strg				
2-331 074	Building A Classrm A1 Display				
2-267 075	Building A Classroom A4				
2-268 076	Building A Classroom A4				
2-351 077	Building A Classroom A4				
2-350 078	Building A Classroom A4				
2-348 079	Building A Classroom A4				
2-346 080	Building A Classroom A4				
2-345 081	Building A Classroom A4				
2-343 082	Building A Classroom A4				
2-344 083	Building A Classroom A4 Strg				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-347 084	Building A Classroom A4 Strg				
2-349 085	Building A Classroom A4 Strg				
2-321 086	Building A Staff Lounge Hall				
2-322 087	Building A Staff Lounge Hall Clst				
2-269 088	Building A Staff Lounge				
2-266 089	Building A Staff Lounge				
2-265 090	Building A Staff Lounge				
2-357 091	Building A Staff Lounge				
2-358 092	Building A Staff Lounge				
2-359 093	Building A Staff Lounge				
2-363 094	Building A Staff Lounge				
2-361 095	Building A Staff Lounge				
2-360 096	Building A Staff Lounge				
2-270 097	Building A Custodian Office				
2-329 098	Building A Custodian Office				
2-271 099	Building A Custodian Office				
2-355 100	Building A Custodian Office RR				
2-354 101	Building A Womens Staff RR				
2-353 102	Building A Womens Staff RR				
2-352 103	Building A Mens Staff RR				
3-022 118	Building C Classroom C1				
3-021 119	Building C Classroom C1				
3-020 120	Building C Classroom C1				
3-019 121	Building C Classroom C1				
3-015 122	Building C Classroom C2				
3-016 123	Building C Classroom C2				
3-017 124	Building C Classroom C2				
3-018 125	Building C Classroom C2				
3-023 126	Building C Media Center				
3-024 127	Building C Media Center				
3-025 128	Building C Media Center				
3-026 129	Building C Media Center				
3-011 130	Building C Media Center				
3-012 131	Building C Media Center				
3-013 132	Building C Media Center				
3-014 133	Building C Media Center				
3-009 134	Building C Media Center Storage				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3-030 135	Building C Classroom C5				
3-029 136	Building C Classroom C5				
3-028 137	Building C Classroom C5				
3-008 138	Building C Classroom C8				
3-007 139	Building C Classroom C8				
3-006 140	Building C Classroom C8				
3-113 141	Building C Classroom C8				
3-005 142	Building C Classroom C8				
3-004 143	Building C Classroom C8				
3-010 144	Building C Classrm C8 Storage				
3-002 145	Building C Boys Restroom				
3-001 146	Building C Girls Restroom				
3-003 147	Building C Custodial Closet				
3-055 165	Building E Classroom E1				
3-054 166	Building E Classroom E1				
3-053 167	Building E Classroom E1				
3-052 168	Building E Classroom E1				
3-048 169	Building E Classroom E2				
3-049 170	Building E Classroom E2				
3-050 171	Building E Classroom E2				
3-051 172	Building E Classroom E2				
3-059 173	Building E Classroom E3				
3-058 174	Building E Classroom E3				
3-057 175	Building E Classroom E3				
3-056 176	Building E Classroom E3				
3-047 177	Building E Classroom E4				
3-046 178	Building E Classroom E4				
3-045 179	Building E Classroom E4				
3-044 180	Building E Classroom E4				
3-042 181	Building E Classroom E4 Strg				
3-064 182	Building E Classroom E5				
3-063 183	Building E Classroom E5				
3-062 184	Building E Classroom E5				
3-061 185	Building E Classroom E5				
3-060 186	Building E Classroom E5				
3-041 187	Building E Classroom E8				
3-040 188	Building E Classroom E8				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3-039 189	Building E Classroom E8				
3-038 190	Building E Classroom E8				
3-037 191	Building E Classroom E8				
3-036 192	Building E Classroom E8				
3-043 193	Building E Classroom E8 Strg				
3-034 194	Building E Staff Restroom North				
3-033 195	Building E Storage in North RR				
3-035 196	Building E Staff Restroom South				
3-032 197	Building E Custodial Closet				
2-074 215	Building F Classroom F1				
2-073 216	Building F Classroom F1				
2-118 217	Building F Classroom F1				
2-072 218	Building F Classroom F1				
2-075 219	Building F Classroom F2				
2-076 220	Building F Classroom F2				
2-116 221	Building F Classroom F2				
2-077 222	Building F Classroom F2				
2-069 223	Building F Classroom F3				
2-070 224	Building F Classroom F3				
2-119 225	Building F Classroom F3				
2-071 226	Building F Classroom F3				
2-080 227	Building F Classroom F4				
2-079 228	Building F Classroom F4				
2-117 229	Building F Classroom F4				
2-078 230	Building F Classroom F4				
3-092 237	Building G Classroom G1				
3-091 238	Building G Classroom G1				
3-090 239	Building G Classroom G1				
3-119 240	Building G Classroom G1				
3-089 241	Building G Classroom G1				
3-088 242	Building G Classroom G1				
3-087 243	Building G Classroom G1				
3-085 244	Building G Classroom G1				
3-086 245	Building G Classroom G1 Office				
3-084 246	Building G Classroom G1 Office				
3-065 247	Building G Classroom G2				
3-066 248	Building G Classroom G2				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3-067 249	Building G Classroom G3				
3-068 250	Building G Classroom G3				
3-069 251	Building G Classroom G3				
3-070 252	Building G Classroom G4				
3-071 253	Building G Classroom G4				
3-072 254	Building G Classroom G4				
3-073 255	Building G Classroom G5				
3-074 256	Building G Classroom G5				
3-075 257	Building G Classroom G6				
3-076 258	Building G Classroom G6				
3-077 259	Building G Classroom G6				
3-121 260	Building G Classroom G6				
3-078 261	Building G Classroom G6				
3-079 262	Building G Classroom G6				
3-081 263	Building G Classroom G6				
3-083 264	Building G Classroom G6				
3-080 265	Building G Classroom G6 Office				
3-082 266	Building G Classroom G6 Office				
2-059 278	Building H Classroom H1				
2-058 279	Building H Classroom H1				
2-057 280	Building H Classroom H1				
2-056 281	Building H Classroom H1				
2-052 282	Building H Classroom H2				
2-053 283	Building H Classroom H2				
2-054 284	Building H Classroom H2				
2-055 285	Building H Classroom H2				
2-063 286	Building H Classroom H3				
2-062 287	Building H Classroom H3				
2-061 288	Building H Classroom H3				
2-060 289	Building H Classroom H3				
2-051 290	Building H Classroom H4				
2-050 291	Building H Classroom H4				
2-049 292	Building H Classroom H4				
2-048 293	Building H Classroom H4				
2-046 294	Building H Classroom H4 Strg				
2-064 295	Building H Classroom H5				
2-065 296	Building H Classroom H5				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-066 297	Building H Classroom H5				
2-067 298	Building H Classroom H5				
2-068 299	Building H Classroom H5				
2-045 300	Building H Classroom H8				
2-044 301	Building H Classroom H8				
2-043 302	Building H Classroom H8				
2-042 303	Building H Classroom H8				
2-041 304	Building H Classroom H8				
2-040 305	Building H Classroom H8				
2-047 306	Building H Classroom H8 Strg				
2-039 307	Building H Boys Restroom				
2-038 308	Building H Girls Restroom				
2-037 309	Building H Custodial Closet				
2-102 325	Building I Classroom I-1				
2-101 326	Building I Classroom I-1				
2-100 327	Building I Classroom I-1				
2-099 328	Building I Classroom I-1				
2-095 329	Building I Classroom I-2				
2-096 330	Building I Classroom I-2				
2-097 331	Building I Classroom I-2				
2-098 332	Building I Classroom I-2				
2-106 333	Building I Classroom I-3				
2-105 334	Building I Classroom I-3				
2-104 335	Building I Classroom I-3				
2-103 336	Building I Classroom I-3				
2-091 337	Building I Classroom I-4				
2-092 338	Building I Classroom I-4				
2-093 339	Building I Classroom I-4				
2-094 340	Building I Classroom I-4				
2-089 341	Building I Classroom I-4 Strg				
2-115 342	Building I Classroom I-5				
2-110 343	Building I Classroom I-5				
2-109 344	Building I Classroom I-5				
2-108 345	Building I Classroom I-5				
2-107 346	Building I Classroom I-5				
2-088 347	Building I Classroom I-8				
2-087 348	Building I Classroom I-8				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-114 349	Building I Classroom I-8				
2-086 350	Building I Classroom I-8				
2-085 351	Building I Classroom I-8				
2-084 352	Building I Classroom I-8				
2-090 353	Building I Classroom I-8 Strg				
2-083 354	Building I Boys Restroom				
2-082 355	Building I Girls Restroom				
2-081 356	Building I Custodial Closet				
3-099 371	Rooms P1-P6 Bldg Classroom P1				
3-098 372	Rooms P1-P6 Bldg Classroom P1				
3-101 373	Rooms P1-P6 Bldg Classroom P1				
3-100 374	Rooms P1-P6 Bldg Classroom P1				
3-096 375	Rooms P1-P6 Bldg Classroom P2				
3-097 376	Rooms P1-P6 Bldg Classroom P2				
3-094 377	Rooms P1-P6 Bldg Classroom P2				
3-095 378	Rooms P1-P6 Bldg Classroom P2				
3-093 379	Rooms P1-P6 Bldg Classroom P2 Closet				
3-111 380	Rooms P1-P6 Bldg Classroom P3				
3-112 381	Rooms P1-P6 Bldg Classroom P3				
3-110 382	Rooms P1-P6 Bldg Classroom P4				
3-109 383	Rooms P1-P6 Bldg Classroom P4				
3-107 384	Rooms P1-P6 Bldg Classroom P5				
3-108 385	Rooms P1-P6 Bldg Classroom P5				
3-106 386	Rooms P1-P6 Bldg Weight Room				
3-105 387	Rooms P1-P6 Bldg Weight Room				
3-122 388	Rooms P1-P6 Bldg Weight Room				
3-104 389	Rooms P1-P6 Bldg Weight Room				
3-103 390	Rooms P1-P6 Bldg Weight Room				
3-102 391	Rooms P1-P6 Bldg Weight Room Closet				
2-261 429	Locker Room Bldg Boys Locker Entry				
2-262 430	Locker Room Bldg Boys Locker RR				
2-264 431	Locker Room Bldg Boys Locker Office				
2-263 432	Locker Room Bldg Boys Locker Office				
2-277 433	Locker Room Bldg Boys Locker Storage				
2-274 434	Locker Room Bldg Boys Locker Strg S				
2-260 435	Locker Room Bldg Girls Locker Entry				
2-259 436	Locker Room Bldg Girls Locker RR				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-280 437	Locker Room Bldg Girls Locker Office				
2-279 438	Locker Room Bldg Girls Locker Office				
2-291 439	Locker Room Bldg Girls Locker Storage				
2-273 440	Locker Room Bldg PE Storage				
2-272 441	Locker Room Bldg Wash Mach Room				
2-319 477	Multi-Purpose Bldg MP Room				
2-316 478	Multi-Purpose Bldg MP Room				
2-315 479	Multi-Purpose Bldg MP Room				
2-312 480	Multi-Purpose Bldg MP Room				
2-311 481	Multi-Purpose Bldg MP Room				
2-308 482	Multi-Purpose Bldg MP Room				
2-307 483	Multi-Purpose Bldg MP Room				
2-309 484	Multi-Purpose Bldg MP Room				
2-310 485	Multi-Purpose Bldg MP Room				
2-313 486	Multi-Purpose Bldg MP Room				
2-314 487	Multi-Purpose Bldg MP Room				
2-317 488	Multi-Purpose Bldg MP Room				
2-318 489	Multi-Purpose Bldg MP Room				
2-320 490	Multi-Purpose Bldg MP Room				
2-375 491	Multi-Purpose Bldg MP Room Storage				
2-306 492	Multi-Purpose Bldg MP Room Storage				
2-325 493	Multi-Purpose Bldg Kitchen				
2-324 494	Multi-Purpose Bldg Kitchen Office				
2-326 495	Multi-Purpose Bldg Kitchen RR Entry				
2-327 496	Multi-Purpose Bldg Kitchen Restroom				
2-328 497	Multi-Purpose Bldg Kitchen Restroom				
2-356 498	Multi-Purpose Bldg Kitchen Storage				
2-325 499	Multi-Purpose Bldg Kitchen Storage Clst				
2-305 500	Multi-Purpose Bldg Stage Stairs				
2-298 501	Multi-Purpose Bldg Stage				
2-297 502	Multi-Purpose Bldg Stage				
2-296 503	Multi-Purpose Bldg Stage				
2-293 504	Multi-Purpose Bldg Stage				
2-294 505	Multi-Purpose Bldg Stage				
2-295 506	Multi-Purpose Bldg Stage				
2-300 507	Multi-Purpose Bldg Stage Storage N				
2-252 527	Music Building Music A29 O/S Hall				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-251 528	Music Building Music A29 O/S Hall				
2-253 529	Music Building Music Room A29				
2-258 530	Music Building Music Room A29				
2-257 531	Music Building Music Room A29				
2-254 532	Music Building Music Room A29				
2-255 533	Music Building Music Room A29				
2-256 534	Music Building Music Room A29				
2-301 535	Music Building Music Room A29				
2-276 536	Music Building Music A29 Above PE				
2-304 537	Music Building Music A29 Hall Closet				
2-302 538	Music Building Music A29 Office S				
2-303 539	Music Building Music A29 Office N				
Heat Detector - Restorable Spot					
2-127 036	Admin Bldg Attic Staff RR Hall				
2-127 037	Admin Bldg Attic FACP/Server Rm				
2-127 038	Admin Bldg Attic Rec Strg W				
2-129 039	Admin Bldg Attic VP Office S				
2-128 040	Admin Bldg Attic Mech Rm W				
2-128 041	Admin Bldg Attic Mech Rm W				
2-387 104	Building A Attic Staff Lounge Hall				
2-390 105	Building A Plum Chase Staff RR				
3-127 148	Building C Attic Media Ctr Strg				
3-127 149	Building C Attic Media Ctr Strg				
3-215 150	Building C Soffit Heat Rm C5 E				
3-214 151	Building C Soffit Heat Rm C5 W				
3-126 152	Building C Plum Chas Cust Clst				
3-130 198	Building E Attic Room E4 Strg				
3-130 199	Building E Attic Room E4 Strg				
3-129 200	Building E Plum Chas Cust Clst				
2-131 310	Building H Attic Room H4 Strg				
2-131 311	Building H Attic Room H4 Strg				
2-130 312	Building H Plum Chas Cust Clst				
2-133 357	Building I Attic Room I-4 Strg				
2-133 358	Building I Attic Room I-4 Strg				
2-132 359	Building I Plum Chas Cust Clst				
3-132 392	Rooms P1-P6 Bldg Attic Classroom P1				
3-132 393	Rooms P1-P6 Bldg Attic Classroom P1				
3-132 394	Rooms P1-P6 Bldg Attic Classroom P1				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3-132 395	Rooms P1-P6 Bldg Attic Classroom P1				
3-132 396	Rooms P1-P6 Bldg Attic Classroom P1				
3-132 397	Rooms P1-P6 Bldg Attic Classroom P1				
3-132 398	Rooms P1-P6 Bldg Attic Classroom P1				
3-131 399	Rooms P1-P6 Bldg Attic Classroom P2				
3-131 400	Rooms P1-P6 Bldg Attic Classroom P2				
3-131 401	Rooms P1-P6 Bldg Attic Classroom P2				
3-131 402	Rooms P1-P6 Bldg Attic Classroom P2				
3-131 403	Rooms P1-P6 Bldg Attic Classroom P2				
3-131 404	Rooms P1-P6 Bldg Attic Classroom P2				
3-138 405	Rooms P1-P6 Bldg Attic Classroom P3				
3-138 406	Rooms P1-P6 Bldg Attic Classroom P3				
3-138 407	Rooms P1-P6 Bldg Attic Classroom P3				
3-139 408	Rooms P1-P6 Bldg Rm P3 HVAC Closet				
3-137 409	Rooms P1-P6 Bldg Attic Classroom P4				
3-137 410	Rooms P1-P6 Bldg Attic Classroom P4				
3-137 411	Rooms P1-P6 Bldg Attic Classroom P4				
3-136 412	Rooms P1-P6 Bldg Rm P4 HVAC Closet				
3-135 413	Rooms P1-P6 Bldg Attic Classroom P5				
3-135 414	Rooms P1-P6 Bldg Attic Classroom P5				
3-135 415	Rooms P1-P6 Bldg Attic Classroom P5				
3-134 416	Rooms P1-P6 Bldg Rm P5 HVAC Closet				
3-133 417	Rooms P1-P6 Bldg Weight rm HVAC Clst				
2-413 442	Locker Room Bldg Boys Locker Room				
2-413 443	Locker Room Bldg Boys Locker Room				
2-413 444	Locker Room Bldg Boys Locker Room				
2-413 445	Locker Room Bldg Boys Locker Room				
2-413 446	Locker Room Bldg Boys Locker Room				
2-413 447	Locker Room Bldg Boys Locker Room				
2-414 448	Locker Room Bldg Girls Locker Room				
2-414 449	Locker Room Bldg Girls Locker Room				
2-414 450	Locker Room Bldg Girls Locker Room				
2-414 451	Locker Room Bldg Girls Locker Room				
2-414 452	Locker Room Bldg Girls Locker Room				
2-414 453	Locker Room Bldg Girls Locker Room				
2-378 454	Locker Room Bldg Attic Boys Locker Off				
2-381 455	Locker Room Bldg Attic Girls Locker Off				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-377 456	Locker Room Bldg Girls Lock Plum Chs				
2-323 508	Multi-Purpose Bldg Kitchen				
2-330 509	Multi-Purpose Bldg Kitchen				
2-326 510	Multi-Purpose Bldg Kitchen Dishwash				
2-299 511	Multi-Purpose Bldg Mech Rm O/S Stage				
2-389 512	Multi-Purpose Bldg Attic Kitchen				
2-376 540	Music Building Attic Music A29 Off N				
3-128 548	Boiler/Chiller Bldg Boiler Room D1				
3-128 549	Boiler/Chiller Bldg Chiller Room				
2-362	Multi-Purpose Bldg Kitchen				

Smoke Detector - Duct

2-380 457	Locker Room Bldg Boys Locker Room				
2-382 458	Locker Room Bldg Girls Locker Room				
2-383 541	Music Building Music Room A29				

Mechanical, Electrosonic, or Pressure Waterflow Device

2-394 513	Multi-Purpose Bldg Mech Rm O/S Stage				
--------------	---	--	--	--	--

Ventilation and Cooking Equipment

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Range Suppression Tank					
Ansul 3 Gallon Cylinder					01/01/1984
Range Suppression					
Suppression System					01/01/1984
Range Hood					
Hood					01/01/1984