

Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

DEL DAYO ELEMENTARY

1301 MCCLAREN DR
CARMICHAEL, California
United States

This site has been inspected and tested in compliance with applicable standards.

Completed
Tuesday, September 30, 2025

Test Session:04 Sep 2025 13:19 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD
5320 HEMLOCK ST
SACRAMENTO, California
United States

TESTED BY

Riley Goyet
Western States Fire Protection-
Sacramento
188 Cirby Way
Roseville, CA 95678
United States



Inspection Summary

Building Information

| | | |
|------------|------------------------|---------|
| PROPERTY | DEL DAYO ELEMENTARY | CONTACT |
| ADDRESS | 1301 MCCLAREN DR | PHONE |
| CITY/STATE | CARMICHAEL, California | MOBILE |
| COUNTRY | United States | EMAIL |

Inspector Information

| | | | |
|---------|---|----------------|---------------------|
| COMPANY | Western States Fire Protection-Sacramento | CONTACT | Riley Goyet |
| ADDRESS | 188 Cirby Way Roseville, CA 95678 | LICENSE NUMBER | |
| COUNTRY | United States | PHONE | +1 916-200-9514 |
| | | EMAIL | riley.goyet@wsfp.us |

Testing Summary

| EQUIPMENT TYPE | TOTAL | TESTED | PASSED | FAILED |
|------------------------------|-------|-----------|-----------|--------|
| Alarm Notification Appliance | 87 | 87(100%) | 87(100%) | 0(0%) |
| Fire Control Panel | 7 | 7(100%) | 7(100%) | 0(0%) |
| Initiating Device | 196 | 196(100%) | 196(100%) | 0(0%) |

Certification

The equipment specified here in was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Tuesday, September 30, 2025

ACCEPTED BY 09/30/2025

Building Representative



TESTED BY 09/30/2025

Riley Goyet
Technician

System Details

Control Units

| | | | |
|-----------------------|------------|--------------|--------------------------|
| ADDRESS/ SCAN ADDRESS | | DESCRIPTION | Admin Building Copy Room |
| MANUFACTURER | Notifier | S/W VERSION | |
| MODEL | NFS-3030 | LAST UPDATE | |
| SERIAL NUMBER | | S/W LOCATION | |
| INSTALL DATE | 03/17/2019 | | |

Open Corrective Action & Solution Summary

The following 1 corrective action(s) remain open following the system inspection, testing or maintenance activities

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION |
|------------------|--------------------|--------------------------------|
| Fire Alarm Panel | | Admin Building Copy Room |
| | Created By: | Riley Goyet |
| | Creation Date: | 02/20/2023 |
| | Corrective Action: | Replace (2) 12V 55AH Batteries |
| | Proposed Solution: | |
| | Manufacturer: | Notifier |
| | Model: | NFS-3030 |

Testing Details

Alarm Notification Appliance

Passed

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|---------------------|---------|-------------------|-----------------|---------------------|
| Audible | 080 | A Wing | Manual | 9/4/2025 1:21:23 PM |
| | | Visual inspection | Passed (Manual) | |
| Audible | 081 | A Wing | Manual | 9/4/2025 1:21:24 PM |
| | | Visual inspection | Passed (Manual) | |
| Audible | 082 | A Wing | Manual | 9/4/2025 1:21:26 PM |
| | | Visual inspection | Passed (Manual) | |
| Audible And Visible | 083 | A Wing | Manual | 9/4/2025 1:21:27 PM |
| | | Visual inspection | Passed (Manual) | |
| Audible And Visible | 084 | A Wing | Manual | 9/4/2025 1:21:29 PM |
| | | Visual inspection | Passed (Manual) | |
| Audible And Visible | 085 | A Wing | Manual | 9/4/2025 1:21:30 PM |
| | | Visual inspection | Passed (Manual) | |
| Audible And Visible | 086 | A Wing | Manual | 9/4/2025 1:21:31 PM |
| | | Visual inspection | Passed (Manual) | |
| Audible And Visible | 087 | A Wing | Manual | 9/4/2025 1:21:33 PM |
| | | Visual inspection | Passed (Manual) | |
| Audible And Visible | 088 | A Wing | Manual | 9/4/2025 1:21:34 PM |
| | | Visual inspection | Passed (Manual) | |
| Audible And Visible | 089 | A Wing | Manual | 9/4/2025 1:21:36 PM |
| | | Visual inspection | Passed (Manual) | |
| Audible And Visible | 091 | A Wing | Manual | 9/4/2025 1:21:37 PM |
| | | Visual inspection | Passed (Manual) | |
| Audible And Visible | 090 | A Wing | Manual | 9/4/2025 1:21:39 PM |
| | | Visual inspection | Passed (Manual) | |
| Audible And Visible | 092 | A Wing | Manual | 9/4/2025 1:21:40 PM |
| | | Visual inspection | Passed (Manual) | |
| Audible And Visible | 093 | A Wing | Manual | 9/4/2025 1:21:41 PM |
| | | Visual inspection | Passed (Manual) | |
| Audible And Visible | 094 | A Wing | Manual | 9/4/2025 1:21:43 PM |
| | | Visual inspection | Passed (Manual) | |
| Visible | 095 | A Wing | Manual | 9/4/2025 1:21:45 PM |
| | | Visual inspection | Passed (Manual) | |
| Visible | 096 | A Wing | Manual | 9/4/2025 1:21:47 PM |
| | | Visual inspection | Passed (Manual) | |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|---------------------|---------|-----------------------|-----------------|---------------------|
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 098 | A Wing | Manual | 9/4/2025 1:21:48 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 097 | A Wing | Manual | 9/4/2025 1:21:49 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 099 | A Wing | Manual | 9/4/2025 1:21:51 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 100 | A Wing | Manual | 9/4/2025 1:21:52 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 101 | A Wing | Manual | 9/4/2025 1:21:54 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 102 | A Wing | Manual | 9/4/2025 1:21:55 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible | 022 | Admin Building | Manual | 9/4/2025 1:21:02 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 023 | Admin Building | Manual | 9/4/2025 1:21:04 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 024 | Admin Building | Manual | 9/4/2025 1:21:05 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 025 | Admin Building | Manual | 9/4/2025 1:21:09 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 026 | Admin Building | Manual | 9/4/2025 1:21:07 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 028 | Admin Building | Manual | 9/4/2025 1:21:10 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 029 | Admin Building | Manual | 9/4/2025 1:21:12 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 027 | Admin Building | Manual | 9/4/2025 1:21:13 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 031 | Admin Building | Manual | 9/4/2025 1:21:15 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 030 | Admin Building | Manual | 9/4/2025 1:21:16 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 033 | Admin Building | Manual | 9/4/2025 1:21:18 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 032 | Admin Building | Manual | 9/4/2025 1:21:19 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|---------------------|---------|--|---------------------------|---------------------|
| Visible | 034 | Admin Building | Manual | 9/4/2025 1:21:21 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Audible | 275 | Multi-Purpose Bldg | Manual | 9/4/2025 1:22:53 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Audible | 276 | Multi-Purpose Bldg | Manual | 9/4/2025 1:22:54 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Audible | 277 | Multi-Purpose Bldg | Manual | 9/4/2025 1:22:56 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Audible And Visible | 278 | Multi-Purpose Bldg | Manual | 9/4/2025 1:22:57 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Audible And Visible | 279 | Multi-Purpose Bldg | Manual | 9/4/2025 1:22:59 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Audible And Visible | 280 | Multi-Purpose Bldg | Manual | 9/4/2025 1:23:00 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Audible And Visible | 281 | Multi-Purpose Bldg | Manual | 9/4/2025 1:23:02 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Audible And Visible | 282 | Multi-Purpose Bldg | Manual | 9/4/2025 1:23:03 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Audible And Visible | 283 | Multi-Purpose Bldg | Manual | 9/4/2025 1:23:05 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Visible | 284 | Multi-Purpose Bldg | Manual | 9/4/2025 1:23:07 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Visible | 285 | Multi-Purpose Bldg | Manual | 9/4/2025 1:23:08 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Visible | 287 | Multi-Purpose Bldg | Manual | 9/4/2025 1:23:10 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Visible | 288 | Multi-Purpose Bldg | Manual | 9/4/2025 1:23:11 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Visible | 286 | Multi-Purpose Bldg | Manual | 9/4/2025 1:23:13 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Audible | 226 | Portables | Manual | 9/4/2025 1:22:33 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Audible | 225 | Portables | Manual | 9/4/2025 1:22:35 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Audible | 227 | Portables | Manual | 9/4/2025 1:22:38 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Audible And Visible | 228 | Portables | Manual | 9/4/2025 1:22:37 PM |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|---------------------|---------|-----------------------|-----------------|---------------------|
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 229 | Portables | Manual | 9/4/2025 1:22:40 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 230 | Portables | Manual | 9/4/2025 1:22:41 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 231 | Portables | Manual | 9/4/2025 1:22:43 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 232 | Portables | Manual | 9/4/2025 1:22:44 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 233 | Portables | Manual | 9/4/2025 1:22:45 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 234 | Portables | Manual | 9/4/2025 1:22:48 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 235 | Portables | Manual | 9/4/2025 1:22:47 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 236 | Portables | Manual | 9/4/2025 1:22:50 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 237 | Portables | Manual | 9/4/2025 1:22:51 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible | 152 | Rms 7-14 / Library | Manual | 9/4/2025 1:21:57 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible | 153 | Rms 7-14 / Library | Manual | 9/4/2025 1:21:58 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible | 154 | Rms 7-14 / Library | Manual | 9/4/2025 1:21:59 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 155 | Rms 7-14 / Library | Manual | 9/4/2025 1:22:01 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 156 | Rms 7-14 / Library | Manual | 9/4/2025 1:22:02 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 158 | Rms 7-14 / Library | Manual | 9/4/2025 1:22:04 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 157 | Rms 7-14 / Library | Manual | 9/4/2025 1:22:05 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 159 | Rms 7-14 / Library | Manual | 9/4/2025 1:22:07 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 160 | Rms 7-14 / Library | Manual | 9/4/2025 1:22:09 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|---------------------|---------|---------------------------------|-----------------|---------------------|
| Audible And Visible | 161 | Rms 7-14 / Library | Manual | 9/4/2025 1:22:10 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 162 | Rms 7-14 / Library | Manual | 9/4/2025 1:22:12 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 163 | Rms 7-14 / Library | Manual | 9/4/2025 1:22:14 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 164 | Rms 7-14 / Library | Manual | 9/4/2025 1:22:15 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 165 | Rms 7-14 / Library | Manual | 9/4/2025 1:22:16 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 166 | Rms 7-14 / Library | Manual | 9/4/2025 1:22:19 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 167 | Rms 7-14 / Library | Manual | 9/4/2025 1:22:20 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 168 | Rms 7-14 / Library | Manual | 9/4/2025 1:22:21 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 169 | Rms 7-14 / Library | Manual | 9/4/2025 1:22:23 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 170 | Rms 7-14 / Library | Manual | 9/4/2025 1:22:24 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 171 | Rms 7-14 / Library | Manual | 9/4/2025 1:22:26 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 183 | Rooms 15-17 Bldg Room 15 | Manual | 9/4/2025 1:22:29 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 184 | Rooms 15-17 Bldg Room 16 | Manual | 9/4/2025 1:22:30 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 185 | Rooms 15-17 Bldg Room 17 | Manual | 9/4/2025 1:22:32 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible | 182 | Rooms 15-17 Bldg South Exterior | Manual | 9/4/2025 1:22:28 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |

Fire Control Panel

Passed

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|--------------------------|---------|--------------------------|-----------------|---------------------|
| NAC Power Extender Panel | 103 | A Wing Custodial Storage | Manual | 9/4/2025 9:50:32 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Fire Alarm Panel | | Admin Building Copy Room | Manual | 9/4/2025 9:51:21 PM |
| | | Manufacturer | Notifier | |
| | | Model | NFS-3030 | |
| | | Visual inspection | Passed (Manual) | |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|--------------------------|---------|-------------------------------------|-----------------|----------------------|
| | | Functional Inspection | Passed | |
| NAC Power Extender Panel | 035 | Admin Building Copy Room | Manual | 9/4/2025 9:51:23 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| NAC Power Extender Panel | 036 | Admin Building Copy Room | Manual | 9/4/2025 9:51:24 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Remote Annunciator | 001 | Admin Building Office | Manual | 9/4/2025 9:51:16 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| NAC Power Extender Panel | 289 | Multi-Purpose Bldg Electrical Room | Manual | 9/11/2025 9:33:00 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| NAC Power Extender Panel | 172 | Rms 7-14 / Library Custodial Office | Manual | 9/11/2025 4:36:41 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |

Initiating Device

Passed

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|---------------------------------|--------------|-----------------------|-----------------|---------------------|
| Heat Detector - Restorable Spot | 3-128 076 | A Wing Attic Hallway | Manual | 9/4/2025 9:50:19 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-129 077 | A Wing Attic Hallway | Manual | 9/4/2025 9:50:20 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-130 078 | A Wing Attic Hallway | Manual | 9/4/2025 9:50:22 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-131 079 | A Wing Attic Hallway | Manual | 9/4/2025 9:50:23 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-009 075 | A Wing Boiler Room | Manual | 9/4/2025 2:26:56 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Manual Pull Station | 3-146 040 | A Wing Boiler Room | Manual | 9/4/2025 9:52:13 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-026 074 | A Wing Boys Restroom | Manual | 9/4/2025 9:50:25 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-008 053 | A Wing Classroom 1 | Manual | 9/4/2025 2:30:57 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-007 054 | A Wing Classroom 1 | Manual | 9/4/2025 2:31:16 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-003 055 | A Wing Classroom 2 | Manual | 9/4/2025 9:50:29 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-004 056 | A Wing Classroom 2 | Manual | 9/4/2025 9:50:31 PM |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|---------------------------------|--------------|---------------------------|-----------------|----------------------|
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-006 058 | A Wing Classroom 2 Office | Manual | 9/4/2025 9:50:16 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-005 057 | A Wing Classroom 2 Office | Manual | 9/4/2025 9:50:28 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-002 059 | A Wing Classroom 3 | Manual | 9/4/2025 9:50:18 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-001 060 | A Wing Classroom 3 | Manual | 9/4/2025 9:50:44 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-034 061 | A Wing Classroom 4 | Manual | 9/4/2025 2:25:37 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-033 062 | A Wing Classroom 4 | Manual | 9/4/2025 2:25:58 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-030 064 | A Wing Classroom 5 | Manual | 9/4/2025 2:28:03 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-029 063 | A Wing Classroom 5 | Manual | 9/4/2025 2:28:27 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-032 065 | A Wing Classroom 5 Office | Manual | 9/4/2025 2:28:57 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-031 066 | A Wing Classroom 5 Office | Manual | 9/4/2025 9:50:12 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-028 067 | A Wing Classroom 6 | Manual | 9/4/2025 9:50:13 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-027 068 | A Wing Classroom 6 | Manual | 9/4/2025 9:50:14 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-035 046 | A Wing Computer Lab | Manual | 9/4/2025 9:52:05 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-010 047 | A Wing Custodial Storage | Manual | 9/11/2025 4:36:17 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-025 073 | A Wing Girls Restroom | Manual | 9/4/2025 9:50:26 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Manual Pull Station | 3-143 037 | A Wing Hall East Exit | Manual | 9/4/2025 9:52:03 PM |
| | | Visual inspection | Passed (Manual) | |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|---------------------------------|--------------|--------------------------|-----------------|----------------------|
| | | Functional Inspection | Passed | |
| Manual Pull Station | 3-147 041 | A Wing Hall West Exit | Manual | 9/11/2025 4:36:48 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-021 069 | A Wing Hallway | Manual | 9/4/2025 2:20:29 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-022 070 | A Wing Hallway | Manual | 9/4/2025 2:24:38 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-023 071 | A Wing Hallway | Manual | 9/4/2025 2:29:45 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-024 072 | A Wing Hallway | Manual | 9/4/2025 9:50:56 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-016 050 | A Wing KA/KB Storage Rm | Manual | 9/4/2025 2:23:12 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-017 048 | A Wing Room KA | Manual | 9/4/2025 2:23:48 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-020 043 | A Wing Room KA | Manual | 9/4/2025 9:52:08 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-019 042 | A Wing Room KA | Manual | 9/4/2025 9:52:09 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Manual Pull Station | 3-144 038 | A Wing Room KA Rear Exit | Manual | 9/4/2025 9:52:07 PM |
| | | Manufacturer | FCI | |
| | | Model | MS-2 | |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-018 049 | A Wing Room KA Restroom | Manual | 9/4/2025 9:50:55 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-014 051 | A Wing Room KB | Manual | 9/4/2025 2:22:05 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-012 045 | A Wing Room KB | Manual | 9/4/2025 9:52:12 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-011 044 | A Wing Room KB | Manual | 9/11/2025 4:36:20 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Manual Pull Station | 3-145 039 | A Wing Room KB Rear Exit | Manual | 9/4/2025 9:52:11 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-013 052 | A Wing Room KB Restroom | Manual | 9/4/2025 2:22:38 PM |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|---------------------------------|--------------|--|---------------------------|----------------------|
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector - Restorable Spot | 3-051 021 | Admin Building Admin Attendance | Manual | 9/4/2025 9:51:27 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector - Restorable Spot | 3-050 016 | Admin Building Admin Back Hall | Manual | 9/11/2025 4:36:07 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector - Restorable Spot | 3-048 014 | Admin Building Admin Hall | Manual | 9/4/2025 9:51:35 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Smoke Detector - General | 3-015 006 | Admin Building Copy Rm Above PE | Manual | 9/4/2025 9:51:49 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Smoke Detector - General | 2-001 007 | Admin Building Copy Rm Headend | Manual | 9/4/2025 9:51:48 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector - Restorable Spot | 3-042 011 | Admin Building Copy Room | Manual | 9/4/2025 9:51:40 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Smoke Detector - General | 3-053 009 | Admin Building Equipment Room | Manual | 9/4/2025 9:51:42 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Manual Pull Station | 3-127 003 | Admin Building Front Office | Manual | 9/4/2025 9:51:44 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Smoke Detector - General | 3-049 008 | Admin Building Front Office | Manual | 9/4/2025 9:51:43 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector - Restorable Spot | 3-052 019 | Admin Building Nurses Office | Manual | 9/4/2025 9:51:30 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector - Restorable Spot | 3-054 020 | Admin Building Nurses Restroom | Manual | 9/4/2025 9:51:28 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Manual Pull Station | 2-126 002 | Admin Building Office | Manual | 9/4/2025 9:51:17 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Manual Pull Station | 3-132 004 | Admin Building Office Rear | Manual | 9/4/2025 9:51:46 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector - Restorable Spot | 3-043 012 | Admin Building Prep Room | Manual | 9/4/2025 9:51:38 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector - Restorable Spot | 3-046 015 | Admin Building Principals Office | Manual | 9/4/2025 9:51:34 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Manual Pull Station | 3-126 005 | Admin Building Staff Copy Room | Manual | 9/4/2025 9:51:25 PM |
| | | Visual inspection | Passed (Manual) | |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|---------------------------------|--------------|------------------------------------|-----------------|----------------------|
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-045 010 | Admin Building Staff Lunch Room | Manual | 9/4/2025 9:52:15 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-056 017 | Admin Building Staff Restroom | Manual | 9/4/2025 9:51:31 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-055 018 | Admin Building Staff Restroom | Manual | 9/4/2025 9:51:32 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-047 013 | Admin Building Supply Room | Manual | 9/4/2025 9:51:37 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-180 270 | Multi-Purpose Bldg Attic Heat | Manual | 9/4/2025 9:50:59 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-180 269 | Multi-Purpose Bldg Attic Heat | Manual | 9/4/2025 9:51:00 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-180 268 | Multi-Purpose Bldg Attic Heat | Manual | 9/4/2025 9:51:02 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-180 267 | Multi-Purpose Bldg Attic Heat | Manual | 9/4/2025 9:51:04 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-180 265 | Multi-Purpose Bldg Attic Heat | Manual | 9/4/2025 9:51:05 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-180 266 | Multi-Purpose Bldg Attic Heat | Manual | 9/4/2025 9:51:07 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-179 261 | Multi-Purpose Bldg Boys Restroom | Manual | 9/4/2025 9:50:51 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-152 258 | Multi-Purpose Bldg Electrical Room | Manual | 9/11/2025 4:35:12 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-179 262 | Multi-Purpose Bldg Girls Restroom | Manual | 9/4/2025 9:50:54 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-179 263 | Multi-Purpose Bldg Kitchen | Manual | 9/11/2025 9:32:50 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Manual Pull Station | 3-153 242 | Multi-Purpose Bldg Kitchen | Manual | 9/4/2025 9:51:09 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-179 264 | Multi-Purpose Bldg Kitchen Office | Manual | 9/4/2025 9:50:48 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|--------------------------|--------------|-------------------------------------|-----------------|----------------------|
| Smoke Detector - General | 2-152 248 | Multi-Purpose Bldg MP Room | Manual | 9/4/2025 9:52:17 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-152 249 | Multi-Purpose Bldg MP Room | Manual | 9/4/2025 9:52:19 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-152 250 | Multi-Purpose Bldg MP Room | Manual | 9/4/2025 9:52:20 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-152 251 | Multi-Purpose Bldg MP Room | Manual | 9/4/2025 9:52:22 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-152 255 | Multi-Purpose Bldg MP Room | Manual | 9/11/2025 9:48:22 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-152 254 | Multi-Purpose Bldg MP Room | Manual | 9/11/2025 9:48:24 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-152 253 | Multi-Purpose Bldg MP Room | Manual | 9/11/2025 9:48:26 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-152 252 | Multi-Purpose Bldg MP Room | Manual | 9/11/2025 9:48:28 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-152 246 | Multi-Purpose Bldg MP Room | Manual | 9/11/2025 4:35:03 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-152 244 | Multi-Purpose Bldg MP Room | Manual | 9/11/2025 4:35:05 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-152 245 | Multi-Purpose Bldg MP Room | Manual | 9/11/2025 4:35:06 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-152 247 | Multi-Purpose Bldg MP Room | Manual | 9/11/2025 5:48:05 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Manual Pull Station | 3-154 240 | Multi-Purpose Bldg MP Room NE | Manual | 9/4/2025 9:51:12 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Manual Pull Station | 3-149 239 | Multi-Purpose Bldg MP Room NW | Manual | 9/11/2025 4:35:17 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Manual Pull Station | 3-155 241 | Multi-Purpose Bldg MP Room SE | Manual | 9/4/2025 9:51:10 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Valve Tamper Switch | 3-178 274 | Multi-Purpose Bldg PIV MP Bldg West | Manual | 9/4/2025 9:50:33 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|--|--------------|--|---------------------------|----------------------|
| Smoke Detector - Duct | 2-140 271 | Multi-Purpose Bldg Roof Westside | Manual | 9/11/2025 4:36:32 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Smoke Detector - Duct | 2-140 272 | Multi-Purpose Bldg Stage East | Manual | 9/11/2025 4:36:33 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector - Restorable Spot | 3-179 259 | Multi-Purpose Bldg Stage Entrance East | Manual | 9/4/2025 9:50:52 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Smoke Detector - General | 2-152 257 | Multi-Purpose Bldg Stage Stairs East | Manual | 9/11/2025 4:35:11 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Smoke Detector - General | 2-152 256 | Multi-Purpose Bldg Stage Stairs West | Manual | 9/11/2025 4:35:09 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector - Restorable Spot | 3-179 260 | Multi-Purpose Bldg Stage Storage | Manual | 9/4/2025 9:50:49 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Mechanical, Electrosonic, or Pressure Waterflow Device | 3-176 273 | Multi-Purpose Bldg Stage Storage | Manual | 9/4/2025 9:50:58 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Manual Pull Station | 3-152 238 | Multi-Purpose Bldg West Hall | Manual | 9/11/2025 4:35:14 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Smoke Detector - General | 2-152 243 | Multi-Purpose Bldg West Hall | Manual | 9/11/2025 4:35:08 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector - Restorable Spot | 3-040 200 | Portables Art Room | Manual | 9/4/2025 9:51:13 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Manual Pull Station | 3-133 187 | Portables Art Room North | Manual | 9/4/2025 9:51:53 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Manual Pull Station | 3-134 188 | Portables Art Room South | Manual | 9/4/2025 9:51:52 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector - Restorable Spot | 3-140 213 | Portables Attic Art Room | Manual | 9/4/2025 9:50:35 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector - Restorable Spot | 3-140 214 | Portables Attic Art Room | Manual | 9/4/2025 9:50:36 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector - Restorable Spot | 3-140 215 | Portables Attic Art Room | Manual | 9/4/2025 9:50:38 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector - Restorable Spot | 3-160 212 | Portables Attic Classroom 18 | Manual | 9/11/2025 9:33:05 AM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|---------------------------------|--------------|--------------------------------|-----------------|----------------------|
| Heat Detector - Restorable Spot | 3-160 211 | Portables Attic Classroom 18 | Manual | 9/11/2025 9:33:06 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-150 223 | Portables Attic Discovery Club | Manual | 9/11/2025 9:32:32 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-150 222 | Portables Attic Discovery Club | Manual | 9/11/2025 9:32:33 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-150 224 | Portables Attic Discovery Club | Manual | 9/11/2025 9:32:35 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-151 220 | Portables Attic Discovery Club | Manual | 9/11/2025 9:32:41 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-151 219 | Portables Attic Discovery Club | Manual | 9/11/2025 9:32:42 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-151 221 | Portables Attic Discovery Club | Manual | 9/11/2025 9:32:44 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-141 218 | Portables Attic Music Room | Manual | 9/4/2025 9:50:39 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-141 217 | Portables Attic Music Room | Manual | 9/4/2025 9:50:41 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-141 216 | Portables Attic Music Room | Manual | 9/4/2025 9:50:42 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-080 199 | Portables Classroom 18 | Manual | 9/4/2025 9:50:10 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-081 198 | Portables Classroom 18 | Manual | 9/11/2025 9:33:07 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Manual Pull Station | 3-136 186 | Portables Classroom 18 | Manual | 9/11/2025 9:32:57 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-062 209 | Portables Discovery Club | Manual | 9/11/2025 9:32:47 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-072 208 | Portables Discovery Club | Manual | 9/11/2025 9:32:48 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-063 207 | Portables Discovery Club | Manual | 9/11/2025 9:32:51 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|---------------------------------|--------------|-----------------------------|-----------------|----------------------|
| Heat Detector - Restorable Spot | 3-069 206 | Portables Discovery Club | Manual | 9/11/2025 9:32:52 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-071 210 | Portables Discovery Club | Manual | 9/11/2025 9:32:54 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-065 205 | Portables Discovery Club | Manual | 9/11/2025 9:32:56 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-064 204 | Portables Discovery Club | Manual | 9/11/2025 9:32:58 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-068 203 | Portables Discovery Club | Manual | 9/11/2025 9:33:02 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-070 202 | Portables Discovery Club | Manual | 9/11/2025 9:33:03 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-067 195 | Portables Discovery Club | Manual | 9/11/2025 4:35:18 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-066 194 | Portables Discovery Club | Manual | 9/11/2025 4:35:20 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-060 196 | Portables Discovery Club | Manual | 9/11/2025 4:35:23 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-061 197 | Portables Discovery Club | Manual | 9/11/2025 4:35:25 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Manual Pull Station | 3-137 190 | Portables Discovery Club NE | Manual | 9/11/2025 9:32:45 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Manual Pull Station | 3-142 193 | Portables Discovery Club NE | Manual | 9/11/2025 4:35:24 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Manual Pull Station | 3-138 191 | Portables Discovery Club NW | Manual | 9/11/2025 4:35:21 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Manual Pull Station | 3-139 192 | Portables Discovery Club SE | Manual | 9/4/2025 9:50:46 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-041 201 | Portables Music Room | Manual | 9/4/2025 9:51:14 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Manual Pull Station | 3-135 189 | Portables Music Room | Manual | 9/4/2025 9:51:50 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|---------------------------------|--------------|---------------------------------------|-----------------|----------------------|
| Heat Detector - Restorable Spot | 2-156 150 | Rms 7-14 / Library Boys Restroom | Manual | 9/11/2025 4:35:46 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-154 128 | Rms 7-14 / Library Classroom 10 | Manual | 9/11/2025 4:35:28 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-154 127 | Rms 7-14 / Library Classroom 10 | Manual | 9/11/2025 4:35:29 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Manual Pull Station | 3-162 114 | Rms 7-14 / Library Classroom 10 North | Manual | 9/11/2025 4:36:45 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Manual Pull Station | 3-161 113 | Rms 7-14 / Library Classroom 10 South | Manual | 9/11/2025 4:36:47 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-009 131 | Rms 7-14 / Library Classroom 11 | Manual | 9/11/2025 4:36:26 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-008 130 | Rms 7-14 / Library Classroom 11 | Manual | 9/11/2025 4:36:27 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Manual Pull Station | 3-164 116 | Rms 7-14 / Library Classroom 11 North | Manual | 9/11/2025 4:36:30 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Manual Pull Station | 3-163 115 | Rms 7-14 / Library Classroom 11 South | Manual | 9/11/2025 4:36:29 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Manual Pull Station | 3-165 117 | Rms 7-14 / Library Classroom 12 | Manual | 9/11/2025 4:36:23 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-010 132 | Rms 7-14 / Library Classroom 12 | Manual | 9/11/2025 4:36:19 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-011 133 | Rms 7-14 / Library Classroom 12 | Manual | 9/11/2025 4:36:22 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Manual Pull Station | 3-166 118 | Rms 7-14 / Library Classroom 13 | Manual | 9/11/2025 4:36:34 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-012 134 | Rms 7-14 / Library Classroom 13 | Manual | 9/11/2025 4:36:14 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-013 135 | Rms 7-14 / Library Classroom 13 | Manual | 9/11/2025 4:36:16 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-015 136 | Rms 7-14 / Library Classroom 14 | Manual | 9/11/2025 4:36:10 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|---------------------------------|--------------|---------------------------------------|-----------------|----------------------|
| Manual Pull Station | 3-168 120 | Rms 7-14 / Library Classroom 14 North | Manual | 9/11/2025 4:36:11 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Manual Pull Station | 3-167 119 | Rms 7-14 / Library Classroom 14 South | Manual | 9/11/2025 4:36:13 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-154 121 | Rms 7-14 / Library Classroom 7 | Manual | 9/11/2025 4:35:31 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-154 122 | Rms 7-14 / Library Classroom 7 | Manual | 9/11/2025 4:35:34 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Manual Pull Station | 3-157 110 | Rms 7-14 / Library Classroom 7 North | Manual | 9/11/2025 4:35:41 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Manual Pull Station | 3-156 109 | Rms 7-14 / Library Classroom 7 South | Manual | 9/11/2025 4:35:50 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Manual Pull Station | 3-158 111 | Rms 7-14 / Library Classroom 8 | Manual | 9/11/2025 4:36:37 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-154 123 | Rms 7-14 / Library Classroom 8 | Manual | 9/11/2025 4:35:33 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-154 124 | Rms 7-14 / Library Classroom 8 | Manual | 9/11/2025 4:35:35 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Manual Pull Station | 3-159 112 | Rms 7-14 / Library Classroom 9 | Manual | 9/11/2025 4:35:40 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-154 125 | Rms 7-14 / Library Classroom 9 | Manual | 9/11/2025 4:35:37 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-154 126 | Rms 7-14 / Library Classroom 9 | Manual | 9/11/2025 4:35:38 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-156 148 | Rms 7-14 / Library Custodial Office | Manual | 9/11/2025 4:35:51 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 2-156 149 | Rms 7-14 / Library Custodian Closet | Manual | 9/11/2025 4:35:43 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 2-156 151 | Rms 7-14 / Library Girls Restroom | Manual | 9/11/2025 4:35:45 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-156 139 | Rms 7-14 / Library Library | Manual | 9/11/2025 4:35:53 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|--------------------------|--------------|---------------------------------|-----------------|----------------------|
| Smoke Detector - General | 2-156 140 | Rms 7-14 / Library Library | Manual | 9/11/2025 4:35:54 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-156 141 | Rms 7-14 / Library Library | Manual | 9/11/2025 4:35:56 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-156 142 | Rms 7-14 / Library Library | Manual | 9/11/2025 4:35:57 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-156 143 | Rms 7-14 / Library Library | Manual | 9/11/2025 4:36:00 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-156 144 | Rms 7-14 / Library Library | Manual | 9/11/2025 4:36:01 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Manual Pull Station | 3-169 104 | Rms 7-14 / Library Library NE | Manual | 9/11/2025 4:36:06 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Manual Pull Station | 3-170 105 | Rms 7-14 / Library Library NW | Manual | 9/11/2025 4:36:25 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Manual Pull Station | 3-172 107 | Rms 7-14 / Library Library SE | Manual | 9/11/2025 4:36:40 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Manual Pull Station | 3-171 106 | Rms 7-14 / Library Library SW | Manual | 9/11/2025 4:36:04 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-156 146 | Rms 7-14 / Library Media Center | Manual | 9/11/2025 4:35:49 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-156 145 | Rms 7-14 / Library Media Center | Manual | 9/11/2025 4:36:02 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-154 129 | Rms 7-14 / Library Mini Lab | Manual | 9/11/2025 4:35:27 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-158 138 | Rms 7-14 / Library Mini Lab | Manual | 9/11/2025 4:36:38 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Manual Pull Station | 3-173 108 | Rms 7-14 / Library Resource | Manual | 9/11/2025 4:36:44 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-016 137 | Rms 7-14 / Library Resource Rm | Manual | 9/11/2025 4:36:09 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-156 147 | Rms 7-14 / Library Speech Room | Manual | 9/11/2025 4:35:47 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|---------------------------------|--------------|-------------------------------|-----------------|----------------------|
| Smoke Detector - General | 2-007 174 | Rooms 15-17 Bldg Room 15 | Manual | 9/4/2025 9:52:00 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-006 173 | Rooms 15-17 Bldg Room 15 | Manual | 9/4/2025 9:52:02 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 2-130 179 | Rooms 15-17 Bldg Room 15 HVAC | Manual | 9/11/2025 9:32:39 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-004 175 | Rooms 15-17 Bldg Room 16 | Manual | 9/4/2025 9:51:58 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-005 176 | Rooms 15-17 Bldg Room 16 | Manual | 9/4/2025 9:51:59 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 2-129 180 | Rooms 15-17 Bldg Room 16 HVAC | Manual | 9/11/2025 9:32:38 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-003 178 | Rooms 15-17 Bldg Room 17 | Manual | 9/4/2025 9:51:54 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-002 177 | Rooms 15-17 Bldg Room 17 | Manual | 9/4/2025 9:51:56 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 2-128 181 | Rooms 15-17 Bldg Room 17 HVAC | Manual | 9/11/2025 9:32:36 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |

Device/Equipment details

Alarm Notification Appliance

| ADDRESS | DESCRIPTION | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
|---------------------|---------------------------------|--------------|-------|--------|--------------|
| Audible | | | | | |
| 022 | Admin Building | | | | |
| 080 | A Wing | | | | |
| 081 | A Wing | | | | |
| 082 | A Wing | | | | |
| 152 | Rms 7-14 / Library | | | | |
| 153 | Rms 7-14 / Library | | | | |
| 154 | Rms 7-14 / Library | | | | |
| 182 | Rooms 15-17 Bldg South Exterior | | | | |
| 225 | Portables | | | | |
| 226 | Portables | | | | |
| 227 | Portables | | | | |
| 275 | Multi-Purpose Bldg | | | | |
| 276 | Multi-Purpose Bldg | | | | |
| 277 | Multi-Purpose Bldg | | | | |
| Audible And Visible | | | | | |
| 023 | Admin Building | | | | |
| 024 | Admin Building | | | | |
| 025 | Admin Building | | | | |
| 083 | A Wing | | | | |
| 084 | A Wing | | | | |
| 085 | A Wing | | | | |
| 086 | A Wing | | | | |
| 087 | A Wing | | | | |
| 088 | A Wing | | | | |
| 089 | A Wing | | | | |
| 090 | A Wing | | | | |
| 091 | A Wing | | | | |
| 092 | A Wing | | | | |
| 093 | A Wing | | | | |
| 094 | A Wing | | | | |
| 155 | Rms 7-14 / Library | | | | |
| 156 | Rms 7-14 / Library | | | | |
| 157 | Rms 7-14 / Library | | | | |
| 158 | Rms 7-14 / Library | | | | |
| 159 | Rms 7-14 / Library | | | | |
| 160 | Rms 7-14 / Library | | | | |
| 161 | Rms 7-14 / Library | | | | |
| 162 | Rms 7-14 / Library | | | | |
| 163 | Rms 7-14 / Library | | | | |
| 164 | Rms 7-14 / Library | | | | |
| 165 | Rms 7-14 / Library | | | | |
| 166 | Rms 7-14 / Library | | | | |
| 167 | Rms 7-14 / Library | | | | |
| 168 | Rms 7-14 / Library | | | | |
| 169 | Rms 7-14 / Library | | | | |
| 183 | Rooms 15-17 Bldg Room 15 | | | | |
| 184 | Rooms 15-17 Bldg Room 16 | | | | |
| 185 | Rooms 15-17 Bldg Room 17 | | | | |

| ADDRESS | DESCRIPTION | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
|---------|--------------------|--------------|-------|--------|--------------|
| 228 | Portables | | | | |
| 229 | Portables | | | | |
| 230 | Portables | | | | |
| 231 | Portables | | | | |
| 232 | Portables | | | | |
| 233 | Portables | | | | |
| 234 | Portables | | | | |
| 278 | Multi-Purpose Bldg | | | | |
| 279 | Multi-Purpose Bldg | | | | |
| 280 | Multi-Purpose Bldg | | | | |
| 281 | Multi-Purpose Bldg | | | | |
| 282 | Multi-Purpose Bldg | | | | |
| 283 | Multi-Purpose Bldg | | | | |

| Visible | | | | | |
|---------|--------------------|--|--|--|--|
| 026 | Admin Building | | | | |
| 027 | Admin Building | | | | |
| 028 | Admin Building | | | | |
| 029 | Admin Building | | | | |
| 030 | Admin Building | | | | |
| 031 | Admin Building | | | | |
| 032 | Admin Building | | | | |
| 033 | Admin Building | | | | |
| 034 | Admin Building | | | | |
| 095 | A Wing | | | | |
| 096 | A Wing | | | | |
| 097 | A Wing | | | | |
| 098 | A Wing | | | | |
| 099 | A Wing | | | | |
| 100 | A Wing | | | | |
| 101 | A Wing | | | | |
| 102 | A Wing | | | | |
| 170 | Rms 7-14 / Library | | | | |
| 171 | Rms 7-14 / Library | | | | |
| 235 | Portables | | | | |
| 236 | Portables | | | | |
| 237 | Portables | | | | |
| 284 | Multi-Purpose Bldg | | | | |
| 285 | Multi-Purpose Bldg | | | | |
| 286 | Multi-Purpose Bldg | | | | |
| 287 | Multi-Purpose Bldg | | | | |
| 288 | Multi-Purpose Bldg | | | | |

Fire Control Panel

| ADDRESS | DESCRIPTION | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
|--------------------------|-------------------------------------|--------------|-------|--------|--------------|
| Remote Annunciator | | | | | |
| 001 | Admin Building Office | | | | |
| NAC Power Extender Panel | | | | | |
| 035 | Admin Building Copy Room | | | | |
| 036 | Admin Building Copy Room | | | | |
| 103 | A Wing Custodial Storage | | | | |
| 172 | Rms 7-14 / Library Custodial Office | | | | |
| 289 | Multi-Purpose Bldg Electrical Room | | | | |

| ADDRESS | DESCRIPTION | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
|--------------------------|---------------------------------------|--------------|----------|--------|--------------|
| Fire Alarm Panel | | | | | |
| | Admin Building Copy Room | Notifier | NFS-3030 | | 03/18/2019 |
| Initiating Device | | | | | |
| ADDRESS | DESCRIPTION | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
| Manual Pull Station | | | | | |
| 2-126 002 | Admin Building Office | | | | |
| 3-127 003 | Admin Building Front Office | | | | |
| 3-132 004 | Admin Building Office Rear | | | | |
| 3-126 005 | Admin Building Staff Copy Room | | | | |
| 3-143 037 | A Wing Hall East Exit | | | | |
| 3-144 038 | A Wing Room KA Rear Exit | FCI | MS-2 | | |
| 3-145 039 | A Wing Room KB Rear Exit | | | | |
| 3-146 040 | A Wing Boiler Room | | | | |
| 3-147 041 | A Wing Hall West Exit | | | | |
| 3-169 104 | Rms 7-14 / Library Library NE | | | | |
| 3-170 105 | Rms 7-14 / Library Library NW | | | | |
| 3-171 106 | Rms 7-14 / Library Library SW | | | | |
| 3-172 107 | Rms 7-14 / Library Library SE | | | | |
| 3-173 108 | Rms 7-14 / Library Resource | | | | |
| 3-156 109 | Rms 7-14 / Library Classroom 7 South | | | | |
| 3-157 110 | Rms 7-14 / Library Classroom 7 North | | | | |
| 3-158 111 | Rms 7-14 / Library Classroom 8 | | | | |
| 3-159 112 | Rms 7-14 / Library Classroom 9 | | | | |
| 3-161 113 | Rms 7-14 / Library Classroom 10 South | | | | |
| 3-162 114 | Rms 7-14 / Library Classroom 10 North | | | | |
| 3-163 115 | Rms 7-14 / Library Classroom 11 South | | | | |
| 3-164 116 | Rms 7-14 / Library Classroom 11 North | | | | |
| 3-165 117 | Rms 7-14 / Library Classroom 12 | | | | |
| 3-166 118 | Rms 7-14 / Library Classroom 13 | | | | |
| 3-167 119 | Rms 7-14 / Library Classroom 14 South | | | | |
| 3-168 120 | Rms 7-14 / Library Classroom 14 North | | | | |
| 3-136 186 | Portables Classroom 18 | | | | |
| 3-133 187 | Portables Art Room North | | | | |
| 3-134 188 | Portables Art Room South | | | | |
| 3-135 189 | Portables Music Room | | | | |
| 3-137 190 | Portables Discovery Club NE | | | | |
| 3-138 191 | Portables Discovery Club NW | | | | |
| 3-139 192 | Portables Discovery Club SE | | | | |

| ADDRESS | DESCRIPTION | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
|--------------------------|------------------------------------|--------------|-------|--------|--------------|
| 3-142 193 | Portables Discovery Club NE | | | | |
| 3-152 238 | Multi-Purpose Bldg West Hall | | | | |
| 3-149 239 | Multi-Purpose Bldg MP Room NW | | | | |
| 3-154 240 | Multi-Purpose Bldg MP Room NE | | | | |
| 3-155 241 | Multi-Purpose Bldg MP Room SE | | | | |
| 3-153 242 | Multi-Purpose Bldg Kitchen | | | | |
| Smoke Detector - General | | | | | |
| 3-015 006 | Admin Building Copy Rm Above PE | | | | |
| 2-001 007 | Admin Building Copy Rm Headend | | | | |
| 3-049 008 | Admin Building Front Office | | | | |
| 3-053 009 | Admin Building Equipment Room | | | | |
| 3-019 042 | A Wing Room KA | | | | |
| 3-020 043 | A Wing Room KA | | | | |
| 3-011 044 | A Wing Room KB | | | | |
| 3-012 045 | A Wing Room KB | | | | |
| 3-035 046 | A Wing Computer Lab | | | | |
| 3-010 047 | A Wing Custodial Storage | | | | |
| 2-154 121 | Rms 7-14 / Library Classroom 7 | | | | |
| 2-154 122 | Rms 7-14 / Library Classroom 7 | | | | |
| 2-154 123 | Rms 7-14 / Library Classroom 8 | | | | |
| 2-154 124 | Rms 7-14 / Library Classroom 8 | | | | |
| 2-154 125 | Rms 7-14 / Library Classroom 9 | | | | |
| 2-154 126 | Rms 7-14 / Library Classroom 9 | | | | |
| 2-154 127 | Rms 7-14 / Library Classroom 10 | | | | |
| 2-154 128 | Rms 7-14 / Library Classroom 10 | | | | |
| 2-154 129 | Rms 7-14 / Library Mini Lab | | | | |
| 2-008 130 | Rms 7-14 / Library Classroom 11 | | | | |
| 2-009 131 | Rms 7-14 / Library Classroom 11 | | | | |
| 2-010 132 | Rms 7-14 / Library Classroom 12 | | | | |
| 2-011 133 | Rms 7-14 / Library Classroom 12 | | | | |
| 2-012 134 | Rms 7-14 / Library Classroom 13 | | | | |
| 2-013 135 | Rms 7-14 / Library Classroom 13 | | | | |
| 2-015 136 | Rms 7-14 / Library Classroom 14 | | | | |
| 2-016 137 | Rms 7-14 / Library Resource Rm | | | | |
| 2-158 138 | Rms 7-14 / Library Mini Lab | | | | |
| 2-156 139 | Rms 7-14 / Library Library | | | | |
| 2-156 140 | Rms 7-14 / Library Library | | | | |
| 2-156 141 | Rms 7-14 / Library Library | | | | |

| ADDRESS | DESCRIPTION | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
|---------------------------------|--------------------------------------|--------------|-------|--------|--------------|
| 2-156 142 | Rms 7-14 / Library Library | | | | |
| 2-156 143 | Rms 7-14 / Library Library | | | | |
| 2-156 144 | Rms 7-14 / Library Library | | | | |
| 2-156 145 | Rms 7-14 / Library Media Center | | | | |
| 2-156 146 | Rms 7-14 / Library Media Center | | | | |
| 2-156 147 | Rms 7-14 / Library Speech Room | | | | |
| 2-156 148 | Rms 7-14 / Library Custodial Office | | | | |
| 2-006 173 | Rooms 15-17 Bldg Room 15 | | | | |
| 2-007 174 | Rooms 15-17 Bldg Room 15 | | | | |
| 2-004 175 | Rooms 15-17 Bldg Room 16 | | | | |
| 2-005 176 | Rooms 15-17 Bldg Room 16 | | | | |
| 2-002 177 | Rooms 15-17 Bldg Room 17 | | | | |
| 2-003 178 | Rooms 15-17 Bldg Room 17 | | | | |
| 3-066 194 | Portables Discovery Club | | | | |
| 3-067 195 | Portables Discovery Club | | | | |
| 3-060 196 | Portables Discovery Club | | | | |
| 3-061 197 | Portables Discovery Club | | | | |
| 2-152 243 | Multi-Purpose Bldg West Hall | | | | |
| 2-152 244 | Multi-Purpose Bldg MP Room | | | | |
| 2-152 245 | Multi-Purpose Bldg MP Room | | | | |
| 2-152 246 | Multi-Purpose Bldg MP Room | | | | |
| 2-152 247 | Multi-Purpose Bldg MP Room | | | | |
| 2-152 248 | Multi-Purpose Bldg MP Room | | | | |
| 2-152 249 | Multi-Purpose Bldg MP Room | | | | |
| 2-152 250 | Multi-Purpose Bldg MP Room | | | | |
| 2-152 251 | Multi-Purpose Bldg MP Room | | | | |
| 2-152 252 | Multi-Purpose Bldg MP Room | | | | |
| 2-152 253 | Multi-Purpose Bldg MP Room | | | | |
| 2-152 254 | Multi-Purpose Bldg MP Room | | | | |
| 2-152 255 | Multi-Purpose Bldg MP Room | | | | |
| 2-152 256 | Multi-Purpose Bldg Stage Stairs West | | | | |
| 2-152 257 | Multi-Purpose Bldg Stage Stairs East | | | | |
| 2-152 258 | Multi-Purpose Bldg Electrical Room | | | | |
| Heat Detector - Restorable Spot | | | | | |
| 3-045 010 | Admin Building Staff Lunch Room | | | | |
| 3-042 011 | Admin Building Copy Room | | | | |
| 3-043 012 | Admin Building Prep Room | | | | |
| 3-047 013 | Admin Building Supply Room | | | | |

| ADDRESS | DESCRIPTION | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
|--------------|------------------------------------|--------------|-------|--------|--------------|
| 3-048 014 | Admin Building Admin Hall | | | | |
| 3-046 015 | Admin Building Principals Office | | | | |
| 3-050 016 | Admin Building Admin Back Hall | | | | |
| 3-056 017 | Admin Building Staff Restroom | | | | |
| 3-055 018 | Admin Building Staff Restroom | | | | |
| 3-052 019 | Admin Building Nurses Office | | | | |
| 3-054 020 | Admin Building Nurses Restroom | | | | |
| 3-051 021 | Admin Building Admin Attendance | | | | |
| 3-017 048 | A Wing Room KA | | | | |
| 3-018 049 | A Wing Room KA Restroom | | | | |
| 3-016 050 | A Wing KA/KB Storage Rm | | | | |
| 3-014 051 | A Wing Room KB | | | | |
| 3-013 052 | A Wing Room KB Restroom | | | | |
| 3-008 053 | A Wing Classroom 1 | | | | |
| 3-007 054 | A Wing Classroom 1 | | | | |
| 3-003 055 | A Wing Classroom 2 | | | | |
| 3-004 056 | A Wing Classroom 2 | | | | |
| 3-005 057 | A Wing Classroom 2 Office | | | | |
| 3-006 058 | A Wing Classroom 2 Office | | | | |
| 3-002 059 | A Wing Classroom 3 | | | | |
| 3-001 060 | A Wing Classroom 3 | | | | |
| 3-034 061 | A Wing Classroom 4 | | | | |
| 3-033 062 | A Wing Classroom 4 | | | | |
| 3-029 063 | A Wing Classroom 5 | | | | |
| 3-030 064 | A Wing Classroom 5 | | | | |
| 3-032 065 | A Wing Classroom 5 Office | | | | |
| 3-031 066 | A Wing Classroom 5 Office | | | | |
| 3-028 067 | A Wing Classroom 6 | | | | |
| 3-027 068 | A Wing Classroom 6 | | | | |
| 3-021 069 | A Wing Hallway | | | | |
| 3-022 070 | A Wing Hallway | | | | |
| 3-023 071 | A Wing Hallway | | | | |
| 3-024 072 | A Wing Hallway | | | | |
| 3-025 073 | A Wing Girls Restroom | | | | |
| 3-026 074 | A Wing Boys Restroom | | | | |
| 3-009 075 | A Wing Boiler Room | | | | |
| 3-128 076 | A Wing Attic Hallway | | | | |

| ADDRESS | DESCRIPTION | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
|--------------|--|--------------|-------|--------|--------------|
| 3-129 077 | A Wing Attic Hallway | | | | |
| 3-130 078 | A Wing Attic Hallway | | | | |
| 3-131 079 | A Wing Attic Hallway | | | | |
| 2-156 149 | Rms 7-14 / Library Custodian Closet | | | | |
| 2-156 150 | Rms 7-14 / Library Boys Restroom | | | | |
| 2-156 151 | Rms 7-14 / Library Girls Restroom | | | | |
| 2-130 179 | Rooms 15-17 Bldg Room 15 HVAC | | | | |
| 2-129 180 | Rooms 15-17 Bldg Room 16 HVAC | | | | |
| 2-128 181 | Rooms 15-17 Bldg Room 17 HVAC | | | | |
| 3-081 198 | Portables Classroom 18 | | | | |
| 3-080 199 | Portables Classroom 18 | | | | |
| 3-040 200 | Portables Art Room | | | | |
| 3-041 201 | Portables Music Room | | | | |
| 3-070 202 | Portables Discovery Club | | | | |
| 3-068 203 | Portables Discovery Club | | | | |
| 3-064 204 | Portables Discovery Club | | | | |
| 3-065 205 | Portables Discovery Club | | | | |
| 3-069 206 | Portables Discovery Club | | | | |
| 3-063 207 | Portables Discovery Club | | | | |
| 3-072 208 | Portables Discovery Club | | | | |
| 3-062 209 | Portables Discovery Club | | | | |
| 3-071 210 | Portables Discovery Club | | | | |
| 3-160 211 | Portables Attic Classroom 18 | | | | |
| 3-160 212 | Portables Attic Classroom 18 | | | | |
| 3-140 213 | Portables Attic Art Room | | | | |
| 3-140 214 | Portables Attic Art Room | | | | |
| 3-140 215 | Portables Attic Art Room | | | | |
| 3-141 216 | Portables Attic Music Room | | | | |
| 3-141 217 | Portables Attic Music Room | | | | |
| 3-141 218 | Portables Attic Music Room | | | | |
| 3-151 219 | Portables Attic Discovery Club | | | | |
| 3-151 220 | Portables Attic Discovery Club | | | | |
| 3-151 221 | Portables Attic Discovery Club | | | | |
| 3-150 222 | Portables Attic Discovery Club | | | | |
| 3-150 223 | Portables Attic Discovery Club | | | | |
| 3-150 224 | Portables Attic Discovery Club | | | | |
| 3-179 259 | Multi-Purpose Bldg Stage Entrance East | | | | |

| ADDRESS | DESCRIPTION | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
|--|--|--------------|-------|--------|--------------|
| 3-179 260 | Multi-Purpose Bldg Stage Storage | | | | |
| 3-179 261 | Multi-Purpose Bldg Boys Restroom | | | | |
| 3-179 262 | Multi-Purpose Bldg Girls Restroom | | | | |
| 3-179 263 | Multi-Purpose Bldg Kitchen | | | | |
| 3-179 264 | Multi-Purpose Bldg Kitchen Office | | | | |
| 3-180 265 | Multi-Purpose Bldg Attic Heat | | | | |
| 3-180 266 | Multi-Purpose Bldg Attic Heat | | | | |
| 3-180 267 | Multi-Purpose Bldg Attic Heat | | | | |
| 3-180 268 | Multi-Purpose Bldg Attic Heat | | | | |
| 3-180 269 | Multi-Purpose Bldg Attic Heat | | | | |
| 3-180 270 | Multi-Purpose Bldg Attic Heat | | | | |
| Smoke Detector - Duct | | | | | |
| 2-140 271 | Multi-Purpose Bldg Roof Westside | | | | |
| 2-140 272 | Multi-Purpose Bldg Stage East | | | | |
| Mechanical, Electrosonic, or Pressure Waterflow Device | | | | | |
| 3-176 273 | Multi-Purpose Bldg Stage Storage | | | | |
| Valve Tamper Switch | | | | | |
| 3-178 274 | Multi-Purpose Bldg PIV MP Bldg West | | | | |