

# Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

SIERRA OAKS ELEMENTARY

171 MILLS ROAD  
SACRAMENTO, California  
United States

This site has been inspected and tested in compliance with applicable standards.

Completed

Thursday, August 07, 2025

Test Session :06 Aug 2025 05:53 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD  
5320 HEMLOCK ST  
SACRAMENTO, California  
United States

TESTED BY

Riley Goyet  
Western States Fire Protection-  
Sacramento  
188 Cirby Way  
Roseville, CA 95678  
United States



# Inspection Summary

## Building Information

PROPERTY	SIERRA OAKS ELEMENTARY	CONTACT
ADDRESS	171 MILLS ROAD	PHONE
CITY/STATE/ZIP	SACRAMENTO, California	MOBILE
COUNTRY	United States	EMAIL

## Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us

## Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Alarm Notification Appliance	74	74(100%)	74(100%)	0(0%)
Power Supplies	9	9(100%)	6(67%)	3(33%)
Initiating Device	205	204(100%)	204(100%)	0(0%)
Fire Control Panel	9	9(100%)	9(100%)	0(0%)

## Certification

The equipment specified herein was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Thursday, August 07, 2025

ACCEPTED BY      08/07/2025  
  
Building Representative

  
TESTED BY      08/07/2025  
Riley Goyet  
Technician

# System Details

## Secondary Power

TYPE	Battery - Sealed Lead-acid	DESCRIPTION	Portables Classroom 21 - P.E. "B" Batteries
ADDRESS / SCAN ADDRESS		NOMINAL VOLTAGE	12
LOAD VOLTAGE		AMP HOURS	8
STANDBY HOURS		ALARM MINUTES	
BATTERY LOCATION		CHARGER VOLTAGE	
TYPE	Battery - Sealed Lead-acid	DESCRIPTION	Kindergarten Bldg IDF/Electrical Closet - P.E. "A"
ADDRESS / SCAN ADDRESS		NOMINAL VOLTAGE	12
LOAD VOLTAGE		AMP HOURS	8
STANDBY HOURS		ALARM MINUTES	
BATTERY LOCATION		CHARGER VOLTAGE	
TYPE	Battery - Sealed Lead-acid	DESCRIPTION	Multi-Purpose Bldg Stage - P.E. "C"
ADDRESS / SCAN ADDRESS		NOMINAL VOLTAGE	12
LOAD VOLTAGE		AMP HOURS	8
STANDBY HOURS		ALARM MINUTES	
BATTERY LOCATION		CHARGER VOLTAGE	
TYPE	Battery - Sealed Lead-acid	DESCRIPTION	Multi-Purpose Bldg Stage - P.E. "D"
ADDRESS / SCAN ADDRESS		NOMINAL VOLTAGE	12
LOAD VOLTAGE		AMP HOURS	8
STANDBY HOURS		ALARM MINUTES	
BATTERY LOCATION		CHARGER VOLTAGE	
TYPE	Battery - Sealed Lead-acid	DESCRIPTION	Portables Classroom 21 - P.E. "B" Batteries
ADDRESS / SCAN ADDRESS		NOMINAL VOLTAGE	12
LOAD VOLTAGE		AMP HOURS	8
STANDBY HOURS		ALARM MINUTES	
BATTERY LOCATION		CHARGER VOLTAGE	
TYPE	Battery - Sealed Lead-acid	DESCRIPTION	Rooms 14-17 Bldg IDF/Elect Room 13 - P.E. "G"
ADDRESS / SCAN ADDRESS		NOMINAL VOLTAGE	12
LOAD VOLTAGE		AMP HOURS	8
STANDBY HOURS		ALARM MINUTES	
BATTERY LOCATION		CHARGER VOLTAGE	
TYPE	Battery - Sealed Lead-acid	DESCRIPTION	Rooms 7-12 Bldg Custodial Office - P.E. "E"
ADDRESS / SCAN ADDRESS		NOMINAL VOLTAGE	12
LOAD VOLTAGE		AMP HOURS	8
STANDBY HOURS		ALARM MINUTES	
BATTERY LOCATION		CHARGER VOLTAGE	
TYPE	Battery - Sealed Lead-acid	DESCRIPTION	Rooms 7-12 Bldg Custodial Office - P.E. "F"
ADDRESS / SCAN ADDRESS		NOMINAL VOLTAGE	12
LOAD VOLTAGE		AMP HOURS	8
STANDBY HOURS		ALARM MINUTES	

BATTERY LOCATION		CHARGER VOLTAGE	
TYPE	Battery - Sealed Lead-acid	DESCRIPTION	Rooms 7-12 Bldg Custodial Office - P.E. "Master"
ADDRESS / SCAN ADDRESS		NOMINAL VOLTAGE	12
LOAD VOLTAGE		AMP HOURS	8
STANDBY HOURS		ALARM MINUTES	
BATTERY LOCATION		CHARGER VOLTAGE	

# Open Corrective Action & Solution Summary

The following 3 corrective action(s) remain open following the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
Battery - Sealed Lead-acid	Created By: Creation Date: Corrective Action: Proposed Solution: Manufacturer: Model:	Rooms 7-12 Bldg Custodial Office - P.E. "Master"  Riley Goyet 08/06/2025 Replace 12V 8AH Battery
Battery - Sealed Lead-acid	Created By: Creation Date: Corrective Action: Proposed Solution: Manufacturer: Model:	Rooms 7-12 Bldg Custodial Office - P.E. "E"  Riley Goyet 08/06/2025 Replace 12V 8AH Battery
Battery - Sealed Lead-acid	Created By: Creation Date: Corrective Action: Proposed Solution: Manufacturer: Model:	Rooms 7-12 Bldg Custodial Office - P.E. "F"  Riley Goyet 08/06/2025 Replace 12V 8AH Battery

# Testing Details

## Alarm Notification Appliance

Passed				
EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	019	Admin/Library Bldg Library	Manual	8/6/2025 5:54:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	024	Admin/Library Bldg Library	Manual	8/6/2025 5:55:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	022	Admin/Library Bldg Office Restroom	Manual	8/6/2025 5:55:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	023	Admin/Library Bldg Office Restroom	Manual	8/6/2025 5:55:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	018	Admin/Library Bldg Reception	Manual	8/6/2025 5:54:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	017	Admin/Library Bldg South Exterior	Manual	8/6/2025 5:54:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	020	Admin/Library Bldg Support Office	Manual	8/6/2025 5:55:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	021	Admin/Library Bldg Work Room	Manual	8/6/2025 5:55:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	033	Kindergarten Bldg Classroom	Manual	8/6/2025 5:54:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	034	Kindergarten Bldg Classroom	Manual	8/6/2025 5:55:54 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	032	Kindergarten Bldg North Exterior	Manual	8/6/2025 5:54:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	035	Kindergarten Bldg Restroom	Manual	8/6/2025 5:55:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Multi-Purpose Bldg East Exterior	Manual	8/6/2025 5:54:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	260	Multi-Purpose Bldg Kitchen	Manual	8/6/2025 5:55:40 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	262	Multi-Purpose Bldg Mens Restroom	Manual	8/6/2025 5:56:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	255	Multi-Purpose Bldg MP Room	Manual	8/6/2025 5:55:33 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	256	Multi-Purpose Bldg MP Room	Manual	8/6/2025 5:55:34 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	257	Multi-Purpose Bldg Stage	Manual	8/6/2025 5:55:35 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	258	Multi-Purpose Bldg Stage	Manual	8/6/2025 5:55:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	261	Multi-Purpose Bldg Stage	Manual	8/6/2025 5:56:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	259	Multi-Purpose Bldg Teachers Lounge	Manual	8/6/2025 5:55:38 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	263	Multi-Purpose Bldg Womens Restroom	Manual	8/6/2025 5:56:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	210	Portables Classroom 18	Manual	8/6/2025 5:55:20 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	211	Portables Classroom 19	Manual	8/6/2025 5:55:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	212	Portables Classroom 20	Manual	8/6/2025 5:55:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	213	Portables Classroom 21	Manual	8/6/2025 5:55:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	219	Portables Classroom 21	Manual	8/6/2025 5:55:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	220	Portables Classroom 21 RR	Manual	8/6/2025 5:56:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	221	Portables Classroom 21 RR	Manual	8/6/2025 5:56:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	214	Portables Classroom 25	Manual	8/6/2025 5:55:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	215	Portables Classroom 26	Manual	8/6/2025 5:55:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	216	Portables Classroom 27	Manual	8/6/2025 5:55:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	222	Portables Classroom 27 RR	Manual	8/6/2025 5:56:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	223	Portables Classroom 27 RR	Manual	8/6/2025 5:56:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	217	Portables Classroom 28	Manual	8/6/2025 5:55:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	218	Portables Classroom 29	Manual	8/6/2025 5:55:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Portables Classroom 30	Manual	8/6/2025 5:55:42 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Portables Classroom 31	Manual	8/6/2025 5:55:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Portables Classroom 32	Manual	8/6/2025 5:55:44 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Portables North Exterior / By Rm 31	Manual	8/6/2025 5:54:44 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	203	Portables South Exterior / By Rm 19	Manual	8/6/2025 5:54:35 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	204	Portables South Exterior / By Rm 26	Manual	8/6/2025 5:54:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	205	Portables South Exterior / By Rm 27	Manual	8/6/2025 5:54:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	206	Portables West Exterior / By Rm 20	Manual	8/6/2025 5:54:38 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	207	Portables West Exterior / By Rm 21	Manual	8/6/2025 5:54:39 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	208	Portables West Exterior / By Rm 25	Manual	8/6/2025 5:54:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	209	Portables West Exterior / By Rm 28	Manual	8/6/2025 5:54:42 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	154	Rooms 14-17 Bldg Boys Restroom	Manual	8/6/2025 5:55:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	150	Rooms 14-17 Bldg Classroom 14	Manual	8/6/2025 5:55:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	151	Rooms 14-17 Bldg Classroom 15	Manual	8/6/2025 5:55:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	152	Rooms 14-17 Bldg Classroom 16	Manual	8/6/2025 5:55:16 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	153	Rooms 14-17 Bldg Classroom 17	Manual	8/6/2025 5:55:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	155	Rooms 14-17 Bldg Girls Restroom	Manual	8/6/2025 5:55:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	148	Rooms 14-17 Bldg Southeast Exterior	Manual	8/6/2025 5:54:32 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	149	Rooms 14-17 Bldg Southwest Exterior	Manual	8/6/2025 5:54:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	068	Rooms 1-6 Bldg Classroom 1	Manual	8/6/2025 5:54:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	069	Rooms 1-6 Bldg Classroom 2	Manual	8/6/2025 5:54:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	070	Rooms 1-6 Bldg Classroom 3	Manual	8/6/2025 5:54:54 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	071	Rooms 1-6 Bldg Classroom 4	Manual	8/6/2025 5:54:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	072	Rooms 1-6 Bldg Classroom 5	Manual	8/6/2025 5:54:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	073	Rooms 1-6 Bldg Classroom 6	Manual	8/6/2025 5:54:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	066	Rooms 1-6 Bldg South Exterior	Manual	8/6/2025 5:54:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	067	Rooms 1-6 Bldg West Exterior	Manual	8/6/2025 5:54:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	120	Rooms 7-12 Bldg Boys Restroom	Manual	8/6/2025 5:55:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	115	Rooms 7-12 Bldg Classroom 10	Manual	8/6/2025 5:55:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	116	Rooms 7-12 Bldg Classroom 11	Manual	8/6/2025 5:55:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	117	Rooms 7-12 Bldg Classroom 12	Manual	8/6/2025 5:55:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	112	Rooms 7-12 Bldg Classroom 7	Manual	8/6/2025 5:54:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	113	Rooms 7-12 Bldg Classroom 8	Manual	8/6/2025 5:55:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	114	Rooms 7-12 Bldg Classroom 9	Manual	8/6/2025 5:55:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	119	Rooms 7-12 Bldg Custodial Office	Manual	8/6/2025 5:55:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	118	Rooms 7-12 Bldg Girls Restroom	Manual	8/6/2025 5:55:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible	110	Rooms 7-12 Bldg South Exterior	Manual	8/6/2025 5:54:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	111	Rooms 7-12 Bldg West Exterior	Manual	8/6/2025 5:54:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

**Fire Control Panel**

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Remote Annunciator	001	Admin/Library Bldg Reception	Manual	8/6/2025 7:02:40 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Kindergarten Bldg IDF/Electrical Closet - P.E. "A"	Manual	8/6/2025 10:54:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Multi-Purpose Bldg Stage - P.E. "C"	Manual	8/6/2025 10:54:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Multi-Purpose Bldg Stage - P.E. "D"	Manual	8/6/2025 10:54:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Portables Classroom 21 - P.E. "B"	Manual	8/6/2025 10:54:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Rooms 14-17 Bldg IDF/Elect Room 13 - P.E. "G"	Manual	8/6/2025 10:54:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Rooms 7-12 Bldg Custodial Office - P.E. "E"	Manual	8/6/2025 10:54:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Rooms 7-12 Bldg Custodial Office - P.E. "F"	Manual	8/6/2025 10:54:32 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Rooms 7-12 Bldg Custodial Office - P.E. "Master"	Manual	8/6/2025 10:54:35 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

**Initiating Device**

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-132 016	Admin/Library Bldg Attic Off. Restrooms	Manual	8/6/2025 12:36:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-017 013	Admin/Library Bldg Library	Manual	8/6/2025 12:25:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-015 014	Admin/Library Bldg Library	Manual	8/6/2025 12:25:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-014 011	Admin/Library Bldg Library	Manual	8/6/2025 12:25:59 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	2-016 012	Admin/Library Bldg Library	Manual	8/6/2025 12:26:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-060 015	Admin/Library Bldg Library HVAC Closet	Manual	8/6/2025 12:29:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-011 009	Admin/Library Bldg Office Corridor	Manual	8/6/2025 12:31:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-012 010	Admin/Library Bldg Office Restroom	Manual	8/6/2025 12:31:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-009 008	Admin/Library Bldg Office Restroom	Manual	8/6/2025 12:31:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-007 004	Admin/Library Bldg Principals Office	Manual	8/6/2025 12:32:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-130 002	Admin/Library Bldg Reception	Manual	8/6/2025 12:36:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-006 003	Admin/Library Bldg Reception	Manual	8/6/2025 12:33:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-008 005	Admin/Library Bldg Speech Therapist Off	Manual	8/6/2025 12:36:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-005 006	Admin/Library Bldg VP Office	Manual	8/6/2025 12:32:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-010 007	Admin/Library Bldg Work Room	Manual	8/6/2025 12:36:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-024 027	Kindergarten Bldg Classroom	Manual	8/6/2025 7:17:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-020 026	Kindergarten Bldg Classroom	Manual	8/6/2025 7:17:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-023 028	Kindergarten Bldg Classroom	Manual	8/6/2025 7:18:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-021 025	Kindergarten Bldg Classroom	Manual	8/6/2025 7:18:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-018 030	Kindergarten Bldg PE Rm	Manual	8/6/2025 7:22:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-019 029	Kindergarten Bldg Restroom	Manual	8/6/2025 7:19:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-022 031	Kindergarten Bldg Water Heater Closet	Manual	8/6/2025 7:26:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-377 254	Multi-Purpose Bldg AHU Room	Manual	8/6/2025 12:37:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-336 247	Multi-Purpose Bldg AHU Room	Manual	8/6/2025 12:38:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-334 249	Multi-Purpose Bldg Floor Cleaner Storage	Manual	8/6/2025 12:38:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-337 252	Multi-Purpose Bldg Kitchen	Manual	8/6/2025 12:01:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-332 253	Multi-Purpose Bldg Kitchen	Manual	8/6/2025 12:02:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-146 228	Multi-Purpose Bldg Kitchen	Manual	8/6/2025 12:03:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-339 245	Multi-Purpose Bldg Mens Restroom	Manual	8/6/2025 11:56:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-330 231	Multi-Purpose Bldg MP Room	Manual	8/6/2025 11:44:35 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-327 232	Multi-Purpose Bldg MP Room	Manual	8/6/2025 11:44:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-324 237	Multi-Purpose Bldg MP Room	Manual	8/6/2025 11:44:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-321 238	Multi-Purpose Bldg MP Room	Manual	8/6/2025 11:45:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-320 239	Multi-Purpose Bldg MP Room	Manual	8/6/2025 11:45:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-322 240	Multi-Purpose Bldg MP Room	Manual	8/6/2025 11:52:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-325 235	Multi-Purpose Bldg MP Room	Manual	8/6/2025 11:52:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-323 236	Multi-Purpose Bldg MP Room	Manual	8/6/2025 11:52:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-328 234	Multi-Purpose Bldg MP Room	Manual	8/6/2025 11:52:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-326 233	Multi-Purpose Bldg MP Room	Manual	8/6/2025 11:53:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-329 230	Multi-Purpose Bldg MP Room	Manual	8/6/2025 11:55:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-331 229	Multi-Purpose Bldg MP Room	Manual	8/6/2025 11:55:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-144 225	Multi-Purpose Bldg MP Room North	Manual	8/6/2025 12:12:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-143 226	Multi-Purpose Bldg MP Room South	Manual	8/6/2025 12:18:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-145 224	Multi-Purpose Bldg MP Room West	Manual	8/6/2025 12:22:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-341 251	Multi-Purpose Bldg MP Storage	Manual	8/6/2025 12:07:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-319 243	Multi-Purpose Bldg Stage	Manual	8/6/2025 12:13:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-317 241	Multi-Purpose Bldg Stage	Manual	8/6/2025 12:14:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-318 242	Multi-Purpose Bldg Stage	Manual	8/6/2025 12:14:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-142 227	Multi-Purpose Bldg Stage East	Manual	8/6/2025 12:38:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-340 244	Multi-Purpose Bldg Teachers Lounge	Manual	8/6/2025 11:55:33 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-335 248	Multi-Purpose Bldg Water Heater Closet	Manual	8/6/2025 12:38:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-338 246	Multi-Purpose Bldg Womens Restroom	Manual	8/6/2025 11:56:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-131 184	Portables Attic Classroom 18	Manual	8/6/2025 8:53:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-131 183	Portables Attic Classroom 18	Manual	8/6/2025 8:53:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-133 185	Portables Attic Classroom 19	Manual	8/6/2025 8:44:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-133 186	Portables Attic Classroom 19	Manual	8/6/2025 8:44:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-134 187	Portables Attic Classroom 20	Manual	8/6/2025 8:40:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-134 188	Portables Attic Classroom 20	Manual	8/6/2025 8:40:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-135 189	Portables Attic Classroom 21	Manual	8/6/2025 8:32:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-135 190	Portables Attic Classroom 21	Manual	8/6/2025 8:32:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-135 191	Portables Attic Classroom 21	Manual	8/6/2025 8:32:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-382 192	Portables Attic Classroom 25	Manual	8/6/2025 7:08:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-382 193	Portables Attic Classroom 25	Manual	8/6/2025 7:08:32 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-378 194	Portables Attic Classroom 26	Manual	8/6/2025 7:00:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-378 195	Portables Attic Classroom 26	Manual	8/6/2025 7:00:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-379 198	Portables Attic Classroom 27	Manual	8/6/2025 6:49:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-379 197	Portables Attic Classroom 27	Manual	8/6/2025 6:49:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-379 196	Portables Attic Classroom 27	Manual	8/6/2025 6:49:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-380 200	Portables Attic Classroom 28	Manual	8/6/2025 10:01:43 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-380 199	Portables Attic Classroom 28	Manual	8/6/2025 10:01:44 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-381 201	Portables Attic Classroom 29	Manual	8/6/2025 10:15:11 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-381 202	Portables Attic Classroom 29	Manual	8/6/2025 10:15:13 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-152	Portables Attic Classroom 30	Manual	8/6/2025 10:37:12 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-152	Portables Attic Classroom 30	Manual	8/6/2025 10:37:13 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-153	Portables Attic Classroom 31	Manual	8/6/2025 10:47:33 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-153	Portables Attic Classroom 31	Manual	8/6/2025 10:47:35 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-154	Portables Attic Classroom 32	Manual	8/6/2025 10:55:11 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-154	Portables Attic Classroom 32	Manual	8/6/2025 10:55:12 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-054 157	Portables Classroom 18	Manual	8/6/2025 8:48:13 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-055 156	Portables Classroom 18	Manual	8/6/2025 8:48:22 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-057 158	Portables Classroom 19	Manual	8/6/2025 8:43:40 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-056 159	Portables Classroom 19	Manual	8/6/2025 8:43:44 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-059 160	Portables Classroom 20	Manual	8/6/2025 8:35:27 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-058 161	Portables Classroom 20	Manual	8/6/2025 8:35:45 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-064 180	Portables Classroom 21	Manual	8/6/2025 8:21:36 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-066 163	Portables Classroom 21	Manual	8/6/2025 8:19:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-061 162	Portables Classroom 21	Manual	8/6/2025 8:19:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-063 166	Portables Classroom 21 RR	Manual	8/6/2025 8:20:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-062 165	Portables Classroom 21 RR	Manual	8/6/2025 12:53:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-065 164	Portables Classroom 21 Storage	Manual	8/6/2025 8:20:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-349 167	Portables Classroom 25	Manual	8/6/2025 7:04:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-348 168	Portables Classroom 25	Manual	8/6/2025 7:05:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-344 170	Portables Classroom 26	Manual	8/6/2025 6:55:39 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-346 169	Portables Classroom 26	Manual	8/6/2025 6:56:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-354 181	Portables Classroom 27	Manual	8/6/2025 6:42:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-350 172	Portables Classroom 27	Manual	8/6/2025 10:59:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-353 171	Portables Classroom 27	Manual	8/6/2025 6:38:36 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-352 173	Portables Classroom 27	Manual	8/6/2025 6:38:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-357 175	Portables Classroom 27 RR	Manual	8/6/2025 6:39:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-356 174	Portables Classroom 27 RR	Manual	8/6/2025 6:39:42 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-355 182	Portables Classroom 27 Storage	Manual	8/6/2025 6:42:00 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-361 176	Portables Classroom 28	Manual	8/6/2025 9:31:22 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-360 177	Portables Classroom 28	Manual	8/6/2025 9:31:39 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-362 178	Portables Classroom 29	Manual	8/6/2025 10:03:37 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-363 179	Portables Classroom 29	Manual	8/6/2025 10:03:41 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-068	Portables Classroom 30	Manual	8/6/2025 10:19:18 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-069	Portables Classroom 30	Manual	8/6/2025 10:19:24 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-071	Portables Classroom 31	Manual	8/6/2025 10:43:56 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-070	Portables Classroom 31	Manual	8/6/2025 10:43:58 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-073	Portables Classroom 32	Manual	8/6/2025 10:51:51 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-072	Portables Classroom 32	Manual	8/6/2025 10:51:55 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-147 145	Rooms 14-17 Bldg Attic Boys Restroom	Manual	8/6/2025 8:03:08 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-151 133	Rooms 14-17 Bldg Attic Classroom 14	Manual	8/6/2025 7:33:41 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-151 134	Rooms 14-17 Bldg Attic Classroom 14	Manual	8/6/2025 7:33:42 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-151 135	Rooms 14-17 Bldg Attic Classroom 14	Manual	8/6/2025 7:33:44 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-150 136	Rooms 14-17 Bldg Attic Classroom 15	Manual	8/6/2025 7:39:21 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-150 137	Rooms 14-17 Bldg Attic Classroom 15	Manual	8/6/2025 7:39:23 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-150 138	Rooms 14-17 Bldg Attic Classroom 15	Manual	8/6/2025 7:39:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-149 139	Rooms 14-17 Bldg Attic Classroom 16	Manual	8/6/2025 7:52:42 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-149 140	Rooms 14-17 Bldg Attic Classroom 16	Manual	8/6/2025 7:52:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-149 141	Rooms 14-17 Bldg Attic Classroom 16	Manual	8/6/2025 7:52:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-148 142	Rooms 14-17 Bldg Attic Classroom 17	Manual	8/6/2025 7:56:33 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-148 144	Rooms 14-17 Bldg Attic Classroom 17	Manual	8/6/2025 7:56:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-148 143	Rooms 14-17 Bldg Attic Classroom 17	Manual	8/6/2025 7:56:44 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-147 147	Rooms 14-17 Bldg Attic Girls Restroom	Manual	8/6/2025 8:03:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-031 130	Rooms 14-17 Bldg Boys Restroom	Manual	8/6/2025 8:00:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-038 122	Rooms 14-17 Bldg Classroom 14	Manual	8/6/2025 7:29:19 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-039 123	Rooms 14-17 Bldg Classroom 14	Manual	8/6/2025 7:29:33 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-037 124	Rooms 14-17 Bldg Classroom 15	Manual	8/6/2025 7:36:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-036 125	Rooms 14-17 Bldg Classroom 15	Manual	8/6/2025 7:36:42 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-034 127	Rooms 14-17 Bldg Classroom 16	Manual	8/6/2025 7:46:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-035 126	Rooms 14-17 Bldg Classroom 16	Manual	8/6/2025 7:46:33 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-033 129	Rooms 14-17 Bldg Classroom 17	Manual	8/6/2025 7:54:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-032 128	Rooms 14-17 Bldg Classroom 17	Manual	8/6/2025 7:54:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-029 132	Rooms 14-17 Bldg Custodial Closet	Manual	8/6/2025 8:23:33 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-030 131	Rooms 14-17 Bldg Girls Restroom	Manual	8/6/2025 8:07:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-028 121	Rooms 14-17 Bldg IDF/Elect Room 13	Manual	8/6/2025 8:25:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-147 146	Rooms 14-17 Bldg RR Plumb Chase	Manual	8/6/2025 8:03:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-301 060	Rooms 1-6 Bldg Classrm 1 HVAC Clst	Manual	8/7/2025 7:28:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-298 061	Rooms 1-6 Bldg Classrm 2 HVAC Clst	Manual	8/7/2025 7:29:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-295 062	Rooms 1-6 Bldg Classrm 3 HVAC Clst	Manual	8/7/2025 7:29:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-315 063	Rooms 1-6 Bldg Classrm 4 HVAC Clst	Manual	8/7/2025 7:29:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-312 064	Rooms 1-6 Bldg Classrm 5 HVAC Clst	Manual	8/7/2025 7:29:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-309 065	Rooms 1-6 Bldg Classrm 6 HVAC Clst	Manual	8/7/2025 7:29:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-287 036	Rooms 1-6 Bldg Classroom 1	Manual	8/6/2025 12:36:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-288 039	Rooms 1-6 Bldg Classroom 1	Manual	8/6/2025 12:37:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-299 038	Rooms 1-6 Bldg Classroom 1	Manual	8/6/2025 12:37:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-300 037	Rooms 1-6 Bldg Classroom 1	Manual	8/6/2025 12:37:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-289 040	Rooms 1-6 Bldg Classroom 2	Manual	8/6/2025 12:41:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-290 043	Rooms 1-6 Bldg Classroom 2	Manual	8/6/2025 12:41:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-296 042	Rooms 1-6 Bldg Classroom 2	Manual	8/6/2025 12:42:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-297 041	Rooms 1-6 Bldg Classroom 2	Manual	8/6/2025 12:43:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-291 044	Rooms 1-6 Bldg Classroom 3	Manual	8/6/2025 12:44:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-292 047	Rooms 1-6 Bldg Classroom 3	Manual	8/6/2025 12:45:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-293 046	Rooms 1-6 Bldg Classroom 3	Manual	8/6/2025 12:45:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-294 045	Rooms 1-6 Bldg Classroom 3	Manual	8/6/2025 12:45:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-303 048	Rooms 1-6 Bldg Classroom 4	Manual	8/6/2025 9:06:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-314 049	Rooms 1-6 Bldg Classroom 4	Manual	8/6/2025 9:06:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-316 050	Rooms 1-6 Bldg Classroom 4	Manual	8/6/2025 9:06:44 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-302 051	Rooms 1-6 Bldg Classroom 4	Manual	8/6/2025 9:06:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-305 052	Rooms 1-6 Bldg Classroom 5	Manual	8/6/2025 9:21:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-311 053	Rooms 1-6 Bldg Classroom 5	Manual	8/6/2025 9:21:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-313 054	Rooms 1-6 Bldg Classroom 5	Manual	8/6/2025 9:21:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-304 055	Rooms 1-6 Bldg Classroom 5	Manual	8/6/2025 9:22:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-307 056	Rooms 1-6 Bldg Classroom 6	Manual	8/6/2025 9:25:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-308 057	Rooms 1-6 Bldg Classroom 6	Manual	8/6/2025 9:25:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-310 058	Rooms 1-6 Bldg Classroom 6	Manual	8/6/2025 9:25:35 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-306 059	Rooms 1-6 Bldg Classroom 6	Manual	8/6/2025 9:25:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-270 102	Rooms 7-12 Bldg Boys Restroom	Manual	8/6/2025 12:38:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-268 107	Rooms 7-12 Bldg Classrm 10 HVAC Clst	Manual	8/7/2025 7:29:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-265 108	Rooms 7-12 Bldg Classrm 11 HVAC Clst	Manual	8/7/2025 7:28:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-262 109	Rooms 7-12 Bldg Classrm 12 HVAC Clst	Manual	8/7/2025 7:29:16 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-285 104	Rooms 7-12 Bldg Classrm 7 HVAC Clst	Manual	8/7/2025 7:29:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-283 105	Rooms 7-12 Bldg Classrm 8 HVAC Clst	Manual	8/7/2025 7:29:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-280 106	Rooms 7-12 Bldg Classrm 9 HVAC Clst	Manual	8/7/2025 7:29:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-256 086	Rooms 7-12 Bldg Classroom 10	Manual	8/6/2025 1:01:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-255 089	Rooms 7-12 Bldg Classroom 10	Manual	8/6/2025 1:01:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-254 088	Rooms 7-12 Bldg Classroom 10	Manual	8/6/2025 1:01:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-267 087	Rooms 7-12 Bldg Classroom 10	Manual	8/6/2025 1:01:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-258 090	Rooms 7-12 Bldg Classroom 11	Manual	8/6/2025 1:03:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-257 093	Rooms 7-12 Bldg Classroom 11	Manual	8/6/2025 1:03:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-266 092	Rooms 7-12 Bldg Classroom 11	Manual	8/6/2025 1:03:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-264 091	Rooms 7-12 Bldg Classroom 11	Manual	8/6/2025 1:03:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-260 094	Rooms 7-12 Bldg Classroom 12	Manual	8/6/2025 1:04:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-261 095	Rooms 7-12 Bldg Classroom 12	Manual	8/6/2025 1:04:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-259 097	Rooms 7-12 Bldg Classroom 12	Manual	8/6/2025 1:04:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-263 096	Rooms 7-12 Bldg Classroom 12	Manual	8/6/2025 1:04:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-272 074	Rooms 7-12 Bldg Classroom 7	Manual	8/6/2025 12:48:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-273 077	Rooms 7-12 Bldg Classroom 7	Manual	8/6/2025 12:48:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-284 076	Rooms 7-12 Bldg Classroom 7	Manual	8/6/2025 12:48:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-271 075	Rooms 7-12 Bldg Classroom 7	Manual	8/6/2025 12:49:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-274 078	Rooms 7-12 Bldg Classroom 8	Manual	8/6/2025 12:51:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-275 081	Rooms 7-12 Bldg Classroom 8	Manual	8/6/2025 12:51:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-281 080	Rooms 7-12 Bldg Classroom 8	Manual	8/6/2025 12:52:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-282 079	Rooms 7-12 Bldg Classroom 8	Manual	8/6/2025 12:52:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-276 082	Rooms 7-12 Bldg Classroom 9	Manual	8/6/2025 12:53:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-277 085	Rooms 7-12 Bldg Classroom 9	Manual	8/6/2025 12:54:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-278 084	Rooms 7-12 Bldg Classroom 9	Manual	8/6/2025 12:54:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-279 083	Rooms 7-12 Bldg Classroom 9	Manual	8/6/2025 12:54:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-003 103	Rooms 7-12 Bldg Custodial Office	Manual	8/6/2025 12:58:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-002 100	Rooms 7-12 Bldg Custodial Office	Manual	8/6/2025 12:38:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-252 099	Rooms 7-12 Bldg Custodial Office	Manual	8/6/2025 12:38:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-253 098	Rooms 7-12 Bldg Girls Restroom	Manual	8/6/2025 12:38:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-269 101	Rooms 7-12 Bldg Storage by Boys RR	Manual	8/6/2025 12:38:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-333 250	Multi-Purpose Bldg Kitchen Office	Manual	8/6/2025 11:55:59 AM

Power Supplies

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Battery - Sealed Lead-acid		Kindergarten Bldg IDF/Electrical Closet - P.E. "A"	Manual	8/6/2025 12:37:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	8	
		Nominal Voltage	12	
Battery - Sealed Lead-acid		Multi-Purpose Bldg Stage - P.E. "C"	Manual	8/6/2025 12:37:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	8	
		Nominal Voltage	12	
Battery - Sealed Lead-acid		Multi-Purpose Bldg Stage - P.E. "D"	Manual	8/6/2025 12:37:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	8	
		Nominal Voltage	12	
Battery - Sealed Lead-acid		Portables Classroom 21 - P.E. "B" Batteries	Manual	8/6/2025 12:37:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	8	
		Nominal Voltage	12	
Battery - Sealed Lead-acid		Portables Classroom 21 - P.E. "B" Batteries	Manual	8/6/2025 12:37:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	8	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Nominal Voltage	12	
Battery - Sealed Lead-acid		Rooms 14-17 Bldg IDF/Elect Room 13 - P.E. "G"	Manual	8/6/2025 12:37:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	8	
		Nominal Voltage	12	

Failed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Battery - Sealed Lead-acid		Rooms 7-12 Bldg Custodial Office - P.E. "E"	Manual	8/6/2025 10:52:12 AM
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	
		Amp Hours	8	
		Nominal Voltage	12	

Battery - Sealed Lead-acid		Rooms 7-12 Bldg Custodial Office - P.E. "F"	Manual	8/6/2025 10:52:36 AM
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	
		Amp Hours	8	
		Nominal Voltage	12	

Battery - Sealed Lead-acid		Rooms 7-12 Bldg Custodial Office - P.E. "Master"	Manual	8/6/2025 10:52:54 AM
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	
		Amp Hours	8	
		Nominal Voltage	12	

# Device/Equipment Details

## Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Audible					
017	Admin/Library Bldg South Exterior				
032	Kindergarten Bldg North Exterior				
066	Rooms 1-6 Bldg South Exterior				
067	Rooms 1-6 Bldg West Exterior				
110	Rooms 7-12 Bldg South Exterior				
111	Rooms 7-12 Bldg West Exterior				
148	Rooms 14-17 Bldg Southeast Exterior				
149	Rooms 14-17 Bldg Southwest Exterior				
203	Portables South Exterior / By Rm 19				
204	Portables South Exterior / By Rm 26				
205	Portables South Exterior / By Rm 27				
206	Portables West Exterior / By Rm 20				
207	Portables West Exterior / By Rm 21				
208	Portables West Exterior / By Rm 25				
209	Portables West Exterior / By Rm 28				
	Portables North Exterior / By Rm 31				
	Multi-Purpose Bldg East Exterior				
Audible And Visible					
018	Admin/Library Bldg Reception				
019	Admin/Library Bldg Library				
033	Kindergarten Bldg Classroom				
068	Rooms 1-6 Bldg Classroom 1				
069	Rooms 1-6 Bldg Classroom 2				
070	Rooms 1-6 Bldg Classroom 3				
071	Rooms 1-6 Bldg Classroom 4				
072	Rooms 1-6 Bldg Classroom 5				
073	Rooms 1-6 Bldg Classroom 6				
112	Rooms 7-12 Bldg Classroom 7				
113	Rooms 7-12 Bldg Classroom 8				
114	Rooms 7-12 Bldg Classroom 9				
115	Rooms 7-12 Bldg Classroom 10				
116	Rooms 7-12 Bldg Classroom 11				
117	Rooms 7-12 Bldg Classroom 12				
118	Rooms 7-12 Bldg Girls Restroom				
119	Rooms 7-12 Bldg Custodial Office				
120	Rooms 7-12 Bldg Boys Restroom				
150	Rooms 14-17 Bldg Classroom 14				
151	Rooms 14-17 Bldg Classroom 15				
152	Rooms 14-17 Bldg Classroom 16				
153	Rooms 14-17 Bldg Classroom 17				
210	Portables Classroom 18				
211	Portables Classroom 19				
212	Portables Classroom 20				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
213	Portables Classroom 21				
214	Portables Classroom 25				
215	Portables Classroom 26				
216	Portables Classroom 27				
217	Portables Classroom 28				
218	Portables Classroom 29				
255	Multi-Purpose Bldg MP Room				
256	Multi-Purpose Bldg MP Room				
257	Multi-Purpose Bldg Stage				
258	Multi-Purpose Bldg Stage				
259	Multi-Purpose Bldg Teachers Lounge				
260	Multi-Purpose Bldg Kitchen				
	Portables Classroom 30				
	Portables Classroom 31				
	Portables Classroom 32				

Visible

020	Admin/Library Bldg Support Office				
021	Admin/Library Bldg Work Room				
022	Admin/Library Bldg Office Restroom				
023	Admin/Library Bldg Office Restroom				
024	Admin/Library Bldg Library				
034	Kindergarten Bldg Classroom				
035	Kindergarten Bldg Restroom				
154	Rooms 14-17 Bldg Boys Restroom				
155	Rooms 14-17 Bldg Girls Restroom				
219	Portables Classroom 21				
220	Portables Classroom 21 RR				
221	Portables Classroom 21 RR				
222	Portables Classroom 27 RR				
223	Portables Classroom 27 RR				
261	Multi-Purpose Bldg Stage				
262	Multi-Purpose Bldg Mens Restroom				
263	Multi-Purpose Bldg Womens Restroom				

**Fire Control Panel**

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Remote Annunciator					
001	Admin/Library Bldg Reception				
NAC Power Extender Panel					
	Rooms 7-12 Bldg Custodial Office - P.E. "Master"				
	Rooms 7-12 Bldg Custodial Office - P.E. "E"				
	Rooms 7-12 Bldg Custodial Office - P.E. "F"				
	Rooms 14-17 Bldg IDF/Elect Room 13 - P.E. "G"				
	Multi-Purpose Bldg Stage - P.E. "C"				
	Multi-Purpose Bldg Stage - P.E. "D"				
	Kindergarten Bldg IDF/Electrical Closet - P.E. "A"				
	Portables Classroom 21 - P.E. "B"				

01/03/2019

## Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Manual Pull Station					
2-130 002	Admin/Library Bldg Reception				
2-145 224	Multi-Purpose Bldg MP Room West				
2-144 225	Multi-Purpose Bldg MP Room North				
2-143 226	Multi-Purpose Bldg MP Room South				
2-142 227	Multi-Purpose Bldg Stage East				
2-146 228	Multi-Purpose Bldg Kitchen				
Smoke Detector - General					
2-006 003	Admin/Library Bldg Reception				
2-007 004	Admin/Library Bldg Principals Office				
2-008 005	Admin/Library Bldg Speech Therapist Off				
2-005 006	Admin/Library Bldg VP Office				
2-010 007	Admin/Library Bldg Work Room				
2-009 008	Admin/Library Bldg Office Restroom				
2-011 009	Admin/Library Bldg Office Corridor				
2-012 010	Admin/Library Bldg Office Restroom				
2-014 011	Admin/Library Bldg Library				
2-016 012	Admin/Library Bldg Library				
2-017 013	Admin/Library Bldg Library				
2-015 014	Admin/Library Bldg Library				
2-021 025	Kindergarten Bldg Classroom				
2-020 026	Kindergarten Bldg Classroom				
2-024 027	Kindergarten Bldg Classroom				
2-023 028	Kindergarten Bldg Classroom				
2-019 029	Kindergarten Bldg Restroom				
2-018 030	Kindergarten Bldg PE Rm				
2-287 036	Rooms 1-6 Bldg Classroom 1				
2-300 037	Rooms 1-6 Bldg Classroom 1				
2-299 038	Rooms 1-6 Bldg Classroom 1				
2-288 039	Rooms 1-6 Bldg Classroom 1				
2-289 040	Rooms 1-6 Bldg Classroom 2				
2-297 041	Rooms 1-6 Bldg Classroom 2				
2-296 042	Rooms 1-6 Bldg Classroom 2				
2-290 043	Rooms 1-6 Bldg Classroom 2				
2-291 044	Rooms 1-6 Bldg Classroom 3				
2-294 045	Rooms 1-6 Bldg Classroom 3				
2-293 046	Rooms 1-6 Bldg Classroom 3				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-292 047	Rooms 1-6 Bldg Classroom 3				
2-303 048	Rooms 1-6 Bldg Classroom 4				
2-314 049	Rooms 1-6 Bldg Classroom 4				
2-316 050	Rooms 1-6 Bldg Classroom 4				
2-302 051	Rooms 1-6 Bldg Classroom 4				
2-305 052	Rooms 1-6 Bldg Classroom 5				
2-311 053	Rooms 1-6 Bldg Classroom 5				
2-313 054	Rooms 1-6 Bldg Classroom 5				
2-304 055	Rooms 1-6 Bldg Classroom 5				
2-307 056	Rooms 1-6 Bldg Classroom 6				
2-308 057	Rooms 1-6 Bldg Classroom 6				
2-310 058	Rooms 1-6 Bldg Classroom 6				
2-306 059	Rooms 1-6 Bldg Classroom 6				
2-272 074	Rooms 7-12 Bldg Classroom 7				
2-271 075	Rooms 7-12 Bldg Classroom 7				
2-284 076	Rooms 7-12 Bldg Classroom 7				
2-273 077	Rooms 7-12 Bldg Classroom 7				
2-274 078	Rooms 7-12 Bldg Classroom 8				
2-282 079	Rooms 7-12 Bldg Classroom 8				
2-281 080	Rooms 7-12 Bldg Classroom 8				
2-275 081	Rooms 7-12 Bldg Classroom 8				
2-276 082	Rooms 7-12 Bldg Classroom 9				
2-279 083	Rooms 7-12 Bldg Classroom 9				
2-278 084	Rooms 7-12 Bldg Classroom 9				
2-277 085	Rooms 7-12 Bldg Classroom 9				
2-256 086	Rooms 7-12 Bldg Classroom 10				
2-267 087	Rooms 7-12 Bldg Classroom 10				
2-254 088	Rooms 7-12 Bldg Classroom 10				
2-255 089	Rooms 7-12 Bldg Classroom 10				
2-258 090	Rooms 7-12 Bldg Classroom 11				
2-264 091	Rooms 7-12 Bldg Classroom 11				
2-266 092	Rooms 7-12 Bldg Classroom 11				
2-257 093	Rooms 7-12 Bldg Classroom 11				
2-260 094	Rooms 7-12 Bldg Classroom 12				
2-261 095	Rooms 7-12 Bldg Classroom 12				
2-263 096	Rooms 7-12 Bldg Classroom 12				
2-259 097	Rooms 7-12 Bldg Classroom 12				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-253 098	Rooms 7-12 Bldg Girls Restroom				
2-252 099	Rooms 7-12 Bldg Custodial Office				
2-002 100	Rooms 7-12 Bldg Custodial Office				
2-269 101	Rooms 7-12 Bldg Storage by Boys RR				
2-270 102	Rooms 7-12 Bldg Boys Restroom				
2-028 121	Rooms 14-17 Bldg IDF/Elect Room 13				
2-038 122	Rooms 14-17 Bldg Classroom 14				
2-039 123	Rooms 14-17 Bldg Classroom 14				
2-037 124	Rooms 14-17 Bldg Classroom 15				
2-036 125	Rooms 14-17 Bldg Classroom 15				
2-035 126	Rooms 14-17 Bldg Classroom 16				
2-034 127	Rooms 14-17 Bldg Classroom 16				
2-032 128	Rooms 14-17 Bldg Classroom 17				
2-033 129	Rooms 14-17 Bldg Classroom 17				
2-031 130	Rooms 14-17 Bldg Boys Restroom				
2-030 131	Rooms 14-17 Bldg Girls Restroom				
2-029 132	Rooms 14-17 Bldg Custodial Closet				
2-055 156	Portables Classroom 18				
2-054 157	Portables Classroom 18				
2-057 158	Portables Classroom 19				
2-056 159	Portables Classroom 19				
2-059 160	Portables Classroom 20				
2-058 161	Portables Classroom 20				
2-061 162	Portables Classroom 21				
2-066 163	Portables Classroom 21				
2-065 164	Portables Classroom 21 Storage				
2-062 165	Portables Classroom 21 RR				
2-063 166	Portables Classroom 21 RR				
2-349 167	Portables Classroom 25				
2-348 168	Portables Classroom 25				
2-346 169	Portables Classroom 26				
2-344 170	Portables Classroom 26				
2-353 171	Portables Classroom 27				
2-352 173	Portables Classroom 27				
2-356 174	Portables Classroom 27 RR				
2-357 175	Portables Classroom 27 RR				
2-361 176	Portables Classroom 28				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-360 177	Portables Classroom 28				
2-362 178	Portables Classroom 29				
2-363 179	Portables Classroom 29				
2-331 229	Multi-Purpose Bldg MP Room				
2-329 230	Multi-Purpose Bldg MP Room				
2-330 231	Multi-Purpose Bldg MP Room				
2-327 232	Multi-Purpose Bldg MP Room				
2-326 233	Multi-Purpose Bldg MP Room				
2-328 234	Multi-Purpose Bldg MP Room				
2-325 235	Multi-Purpose Bldg MP Room				
2-323 236	Multi-Purpose Bldg MP Room				
2-324 237	Multi-Purpose Bldg MP Room				
2-321 238	Multi-Purpose Bldg MP Room				
2-320 239	Multi-Purpose Bldg MP Room				
2-322 240	Multi-Purpose Bldg MP Room				
2-317 241	Multi-Purpose Bldg Stage				
2-318 242	Multi-Purpose Bldg Stage				
2-319 243	Multi-Purpose Bldg Stage				
2-340 244	Multi-Purpose Bldg Teachers Lounge				
2-339 245	Multi-Purpose Bldg Mens Restroom				
2-338 246	Multi-Purpose Bldg Womens Restroom				
2-336 247	Multi-Purpose Bldg AHU Room				
2-335 248	Multi-Purpose Bldg Water Heater Closet				
2-334 249	Multi-Purpose Bldg Floor Cleaner Storage				
2-333 250	Multi-Purpose Bldg Kitchen Office				
2-069	Portables Classroom 30				
2-068	Portables Classroom 30				
2-071	Portables Classroom 31				
2-070	Portables Classroom 31				
2-072	Portables Classroom 32				
2-073	Portables Classroom 32				
Heat Detector - Restorable Spot					
2-060 015	Admin/Library Bldg Library HVAC Closet				
2-132 016	Admin/Library Bldg Attic Off. Restrooms				
2-022 031	Kindergarten Bldg Water Heater Closet				
2-301 060	Rooms 1-6 Bldg Classrm 1 HVAC Clst				
2-298 061	Rooms 1-6 Bldg Classrm 2 HVAC Clst				
2-295 062	Rooms 1-6 Bldg Classrm 3 HVAC Clst				
2-315 063	Rooms 1-6 Bldg Classrm 4 HVAC Clst				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-312 064	Rooms 1-6 Bldg Classrm 5 HVAC Clst				
2-309 065	Rooms 1-6 Bldg Classrm 6 HVAC Clst				
2-003 103	Rooms 7-12 Bldg Custodial Office				
2-285 104	Rooms 7-12 Bldg Classrm 7 HVAC Clst				
2-283 105	Rooms 7-12 Bldg Classrm 8 HVAC Clst				
2-280 106	Rooms 7-12 Bldg Classrm 9 HVAC Clst				
2-268 107	Rooms 7-12 Bldg Classrm 10 HVAC Clst				
2-265 108	Rooms 7-12 Bldg Classrm 11 HVAC Clst				
2-262 109	Rooms 7-12 Bldg Classrm 12 HVAC Clst				
2-151 133	Rooms 14-17 Bldg Attic Classroom 14				
2-151 134	Rooms 14-17 Bldg Attic Classroom 14				
2-151 135	Rooms 14-17 Bldg Attic Classroom 14				
2-150 136	Rooms 14-17 Bldg Attic Classroom 15				
2-150 137	Rooms 14-17 Bldg Attic Classroom 15				
2-150 138	Rooms 14-17 Bldg Attic Classroom 15				
2-149 139	Rooms 14-17 Bldg Attic Classroom 16				
2-149 140	Rooms 14-17 Bldg Attic Classroom 16				
2-149 141	Rooms 14-17 Bldg Attic Classroom 16				
2-148 142	Rooms 14-17 Bldg Attic Classroom 17				
2-148 143	Rooms 14-17 Bldg Attic Classroom 17				
2-148 144	Rooms 14-17 Bldg Attic Classroom 17				
2-147 145	Rooms 14-17 Bldg Attic Boys Restroom				
2-147 146	Rooms 14-17 Bldg RR Plumb Chase				
2-147 147	Rooms 14-17 Bldg Attic Girls Restroom				
2-350 172	Portables Classroom 27				
2-064 180	Portables Classroom 21				
2-354 181	Portables Classroom 27				
2-355 182	Portables Classroom 27 Storage				
2-131 183	Portables Attic Classroom 18				
2-131 184	Portables Attic Classroom 18				
2-133 185	Portables Attic Classroom 19				
2-133 186	Portables Attic Classroom 19				
2-134 187	Portables Attic Classroom 20				
2-134 188	Portables Attic Classroom 20				
2-135 189	Portables Attic Classroom 21				
2-135 190	Portables Attic Classroom 21				
2-135 191	Portables Attic Classroom 21				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-382 192	Portables Attic Classroom 25				
2-382 193	Portables Attic Classroom 25				
2-378 194	Portables Attic Classroom 26				
2-378 195	Portables Attic Classroom 26				
2-379 196	Portables Attic Classroom 27				
2-379 197	Portables Attic Classroom 27				
2-379 198	Portables Attic Classroom 27				
2-380 199	Portables Attic Classroom 28				
2-380 200	Portables Attic Classroom 28				
2-381 201	Portables Attic Classroom 29				
2-381 202	Portables Attic Classroom 29				
2-341 251	Multi-Purpose Bldg MP Storage				
2-337 252	Multi-Purpose Bldg Kitchen				
2-332 253	Multi-Purpose Bldg Kitchen				
2-152	Portables Attic Classroom 30				
2-152	Portables Attic Classroom 30				
2-153	Portables Attic Classroom 31				
2-153	Portables Attic Classroom 31				
2-154	Portables Attic Classroom 32				
2-154	Portables Attic Classroom 32				

Smoke Detector - Duct

2-377 254	Multi-Purpose Bldg AHU Room				
--------------	-----------------------------	--	--	--	--

**Power Supplies**

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Battery - Sealed Lead-acid					
	Kindergarten Bldg IDF/Electrical Closet - P.E. "A"				08/12/2012
	Rooms 7-12 Bldg Custodial Office - P.E. "Master"				08/03/2017
	Rooms 7-12 Bldg Custodial Office - P.E. "E"				08/18/2019
	Rooms 7-12 Bldg Custodial Office - P.E. "F"				05/03/2019
	Rooms 14-17 Bldg IDF/Elect Room 13 - P.E. "G"				02/20/2020
	Multi-Purpose Bldg Stage - P.E. "C"				05/06/2019
	Multi-Purpose Bldg Stage - P.E. "D"				10/03/2017
	Portables Classroom 21 - P.E. "B" Batteries				07/03/2016
	Portables Classroom 21 - P.E. "B" Batteries				09/03/2018