

Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

SUNRISE TECH ADULT ED

5641 MARIPOSA AVE
CITRUS HEIGHTS, California 95610
United States

This site has been inspected and tested in compliance with applicable standards.

Completed

Thursday, September 12, 2024

Test Session :05 Sep 2024 11:06 RJ5311 AFA

ACCEPTED BY

SAN JUAN USD
5320 HEMLOCK ST
SACRAMENTO, California
United States

TESTED BY

Riley Goyet
Western States Fire Protection-
Sacramento
188 Cirby Way
Roseville, CA 95678
United States



Inspection Summary

Building Information

PROPERTY	SUNRISE TECH ADULT ED	CONTACT
ADDRESS	5641 MARIPOSA AVE	PHONE
CITY/STATE/ZIP	CITRUS HEIGHTS, California 95610	MOBILE
COUNTRY	United States	EMAIL

Inspector Information

COMPANY	Western States Fire Protection- Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us

Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Alarm Notification Appliance	65	65(100%)	65(100%)	0(0%)
Fire Control Panel	5	5(100%)	2(40%)	3(60%)
Initiating Device	186	182(98%)	180(97%)	2(1%)

Certification

The equipment specified herein was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Thursday, September 12, 2024

ACCEPTED BY 09/12/2024

Building Representative

TESTED BY 09/12/2024


Riley Goyet
Technician

System Details

Control Units

ADDRESS / SCAN ADDRESS		DESCRIPTION	Admin Area Copy Room
MANUFACTURER	EST	S/W VERSION	
MODEL	3	LAST UPDATE	
SERIAL NUMBER		S/W LOCATION	
INSTALL DATE			

Open Corrective Action & Solution Summary

The following 11 corrective action(s) remain open following the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
NAC Power Extender Panel	029	Admin Area Copy Room - P.E. "A"
	Created By:	Riley Goyet
	Creation Date:	06/09/2021
	Corrective Action:	Failed 12V 8AH ELK batteries dated 5/17/2016
	Proposed Solution:	
	Manufacturer:	
	Model:	
	Created By:	Riley Goyet
	Creation Date:	09/19/2023
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
NAC Power Extender Panel	205	Restroom Bldgs Janitor Rm by Rm 13 - P.E. "B"
	Created By:	Riley Goyet
	Creation Date:	05/04/2022
	Corrective Action:	Need to replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
	Created By:	Riley Goyet
	Creation Date:	09/19/2023
	Corrective Action:	Need to replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
NAC Power Extender Panel	206	Restroom Bldgs Storage by Rm 21 - P.E. "C"
	Created By:	Riley Goyet
	Creation Date:	09/19/2023
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
Smoke Detector - Duct	2-143 242	Multi-Purpose Bldg Boiler Room
	Created By:	Riley Goyet
	Creation Date:	06/09/2021
	Corrective Action:	Would not trip
	Proposed Solution:	
	Manufacturer:	
	Model:	
	Created By:	Riley Goyet
	Creation Date:	09/19/2023
	Corrective Action:	Did not report to panel
	Proposed Solution:	
	Manufacturer:	
	Model:	
	Created By:	Kurtis Boller
	Creation Date:	09/05/2024
	Corrective Action:	Appear to not have power
	Proposed Solution:	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
----------------	---------	-------------

Manufacturer:
Model:

Smoke Detector - Duct	2-144 243	Multi-Purpose Bldg Boiler Room
-----------------------	--------------	--------------------------------

Created By: Riley Goyet
 Creation Date: 06/09/2021
 Corrective Action: Would not trip.
 Proposed Solution:
 Manufacturer:
 Model:

Created By: Riley Goyet
 Creation Date: 09/19/2023
 Corrective Action: Did not report to panel
 Proposed Solution:
 Manufacturer:
 Model:

Created By: Kurtis Boller
 Creation Date: 09/05/2024
 Corrective Action: Appear to not have power
 Proposed Solution:
 Manufacturer:
 Model:

Testing Details

Alarm Notification Appliance

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	024	Admin Area Admin Office Hall	Manual	9/5/2024 12:32:01 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	025	Admin Area Admin Office Hall	Manual	9/5/2024 12:32:05 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	026	Admin Area Break Rm Kitchenette	Manual	9/5/2024 12:32:00 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	019	Admin Area Copy Room	Manual	9/5/2024 12:31:57 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	018	Admin Area Front Office	Manual	9/5/2024 12:31:54 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	023	Admin Area Mail Room	Manual	9/5/2024 12:32:03 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	027	Admin Area Mens Staff Restroom	Manual	9/5/2024 12:32:15 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	022	Admin Area Principals Office	Manual	9/5/2024 12:31:50 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	020	Admin Area Secretary Office	Manual	9/5/2024 12:31:58 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	021	Admin Area Secretary Office RR	Manual	9/5/2024 12:31:55 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	028	Admin Area Womens Staff RR	Manual	9/5/2024 12:32:14 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	249	Multi-Purpose Bldg File Room	Manual	9/5/2024 12:33:08 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	252	Multi-Purpose Bldg Kitchen	Manual	9/5/2024 12:33:11 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	253	Multi-Purpose Bldg Kitchen	Manual	9/5/2024 12:33:12 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	255	Multi-Purpose Bldg Kitchen	Manual	9/5/2024 12:33:27 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	245	Multi-Purpose Bldg MP Room	Manual	9/5/2024 12:32:56 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	246	Multi-Purpose Bldg MP Room	Manual	9/5/2024 12:33:04 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	250	Multi-Purpose Bldg MP Room Office	Manual	9/5/2024 12:33:07 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	251	Multi-Purpose Bldg Office East	Manual	9/5/2024 12:33:09 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	248	Multi-Purpose Bldg South Hall	Manual	9/5/2024 12:33:02 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	247	Multi-Purpose Bldg Stage	Manual	9/5/2024 12:33:05 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	254	Multi-Purpose Bldg Stage	Manual	9/5/2024 12:31:49 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	244	Multi-Purpose Bldg West Exterior	Manual	9/5/2024 12:33:26 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	200	Restroom Bldgs Boys Restroom	Manual	9/5/2024 12:32:52 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	204	Restroom Bldgs Boys Restroom	Manual	9/5/2024 12:32:59 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	199	Restroom Bldgs Custodial Office	Manual	9/5/2024 12:32:53 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	195	Restroom Bldgs East Exterior	Manual	9/5/2024 12:33:25 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	201	Restroom Bldgs Girls Restroom	Manual	9/5/2024 12:32:50 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	203	Restroom Bldgs Mens Staff RR	Manual	9/5/2024 12:32:58 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	198	Restroom Bldgs Staff Room	Manual	9/5/2024 12:32:55 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	196	Restroom Bldgs West Exterior	Manual	9/5/2024 12:33:23 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	197	Restroom Bldgs Womens Restroom	Manual	9/5/2024 12:32:44 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	202	Restroom Bldgs Womens Staff RR	Manual	9/5/2024 12:33:01 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	047	Rooms 1 2 Bldg Classroom 1	Manual	9/5/2024 12:32:12 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	048	Rooms 1 2 Bldg Classroom 1 RR	Manual	9/5/2024 12:32:17 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	049	Rooms 1 2 Bldg Classroom 2	Manual	9/5/2024 12:32:09 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	050	Rooms 1 2 Bldg Classroom 2 RR	Manual	9/5/2024 12:32:11 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	046	Rooms 1 2 Bldg South Exterior	Manual	9/5/2024 12:33:19 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	131	Rooms 10-13 Bldg Classroom 10	Manual	9/5/2024 12:32:26 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	132	Rooms 10-13 Bldg Classroom 11	Manual	9/5/2024 12:32:27 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	133	Rooms 10-13 Bldg Classroom 12	Manual	9/5/2024 12:32:24 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	134	Rooms 10-13 Bldg Classroom 13	Manual	9/5/2024 12:32:37 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	130	Rooms 10-13 Bldg South Exterior	Manual	9/5/2024 12:33:15 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	144	Rooms 14-17 Bldg Classroom 14	Manual	9/5/2024 12:32:35 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	145	Rooms 14-17 Bldg Classroom 15	Manual	9/5/2024 12:32:34 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	146	Rooms 14-17 Bldg Classroom 16	Manual	9/5/2024 12:32:32 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	147	Rooms 14-17 Bldg Classroom 17	Manual	9/5/2024 12:32:43 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	143	Rooms 14-17 Bldg South Exterior	Manual	9/5/2024 12:33:22 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	157	Rooms 18-21 Bldg Classroom 18	Manual	9/5/2024 12:32:41 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	158	Rooms 18-21 Bldg Classroom 19	Manual	9/5/2024 12:32:40 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	159	Rooms 18-21 Bldg Classroom 20	Manual	9/5/2024 12:32:38 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	160	Rooms 18-21 Bldg Classroom 21	Manual	9/5/2024 12:32:48 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	156	Rooms 18-21 Bldg South Exterior	Manual	9/5/2024 12:33:13 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	175	Rooms 22 23 Bldg Classroom 22	Manual	9/5/2024 12:32:46 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	176	Rooms 22 23 Bldg Classroom 23	Manual	9/5/2024 12:32:47 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	067	Rooms 3 4 Bldgs Classroom 3	Manual	9/5/2024 12:32:08 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	068	Rooms 3 4 Bldgs Classroom 4	Manual	9/5/2024 12:32:06 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	066	Rooms 3 4 Bldgs South Exterior	Manual	9/5/2024 12:33:17 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	101	Rooms 5-9 Bldg Classroom 5	Manual	9/5/2024 12:32:23 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	102	Rooms 5-9 Bldg Classroom 6	Manual	9/5/2024 12:32:21 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	103	Rooms 5-9 Bldg Classroom 7	Manual	9/5/2024 12:32:20 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	104	Rooms 5-9 Bldg Classroom 8	Manual	9/5/2024 12:32:19 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	105	Rooms 5-9 Bldg Classroom 9	Manual	9/5/2024 12:32:29 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	099	Rooms 5-9 Bldg East Exterior	Manual	9/5/2024 12:33:20 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	100	Rooms 5-9 Bldg South Exterior	Manual	9/5/2024 12:33:16 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Fire Alarm Panel		Admin Area Copy Room	Manual	9/5/2024 8:23:03 PM
		Manufacturer	EST	
		Model	3	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Remote Annunciator	001	Admin Area Front Office	Manual	9/5/2024 8:23:05 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

Failed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
NAC Power Extender Panel	029	Admin Area Copy Room - P.E. "A"	Manual	9/5/2024 8:23:49 PM
		Visual Inspection	Failed (Manual)	
		Functional Inspection	Failed	
NAC Power Extender Panel	205	Restroom Bldgs Janitor Rm by Rm 13 - P.E. "B"	Manual	9/5/2024 8:23:54 PM
		Visual Inspection	Failed (Manual)	
NAC Power Extender Panel	206	Restroom Bldgs Storage by Rm 21 - P.E. "C"	Manual	9/5/2024 8:23:44 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual Inspection	Failed (Manual)	
		Functional Inspection	Failed	

Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-005 004	Admin Area Above FACP copy Rm	Manual	9/5/2024 12:36:36 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-013 011	Admin Area Admin Office Hall	Manual	9/5/2024 12:38:31 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-036 010	Admin Area Admin Office Hall	Manual	9/5/2024 12:39:39 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-035 009	Admin Area Admin Office Hall	Manual	9/5/2024 12:40:28 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-132 015	Admin Area Attic Admin Front Off	Manual	9/5/2024 8:23:30 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-150 017	Admin Area Attic North Hall East	Manual	9/5/2024 8:23:27 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-134 016	Admin Area Attic North Hall West	Manual	9/5/2024 8:23:28 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-011 014	Admin Area Break Rm Kitchenette	Manual	9/5/2024 12:38:10 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-133 002	Admin Area Front Office	Manual	9/5/2024 8:22:14 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-009 003	Admin Area Front Office	Manual	9/5/2024 12:36:39 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-006 008	Admin Area Mail Room	Manual	9/5/2024 12:40:41 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-014 013	Admin Area Mens Staff Restroom	Manual	9/5/2024 12:38:48 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-010 007	Admin Area Principals Office	Manual	9/5/2024 12:37:16 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-008 005	Admin Area Secretary Office	Manual	9/5/2024 12:36:33 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-007 006	Admin Area Secretary Office RR	Manual	9/5/2024 12:36:50 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-012 012	Admin Area Womens Staff RR	Manual	9/5/2024 1:29:41 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-147 238	Multi-Purpose Bldg Attic File Room	Manual	9/5/2024 8:23:00 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-136 241	Multi-Purpose Bldg Attic Kitchen	Manual	9/5/2024 8:23:09 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-141 240	Multi-Purpose Bldg Attic MP E Office	Manual	9/5/2024 8:22:48 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-148 239	Multi-Purpose Bldg Attic MP S Office	Manual	9/5/2024 8:22:50 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-145 237	Multi-Purpose Bldg Attic South Hall	Manual	9/5/2024 8:23:31 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-139 235	Multi-Purpose Bldg Attic Stage	Manual	9/5/2024 8:23:33 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-139 234	Multi-Purpose Bldg Attic Stage	Manual	9/5/2024 8:23:34 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-029 225	Multi-Purpose Bldg Boiler Room	Manual	9/5/2024 1:37:33 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-033 222	Multi-Purpose Bldg File Room	Manual	9/5/2024 1:37:34 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-032 221	Multi-Purpose Bldg File Room	Manual	9/5/2024 1:37:39 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-016 227	Multi-Purpose Bldg Kitchen	Manual	9/5/2024 1:36:39 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-015 226	Multi-Purpose Bldg Kitchen	Manual	9/5/2024 8:23:25 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-017 228	Multi-Purpose Bldg Kitchen Storage	Manual	9/5/2024 1:37:56 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-018 229	Multi-Purpose Bldg Kitchen Store Room	Manual	9/5/2024 1:37:26 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-022 211	Multi-Purpose Bldg MP Room	Manual	9/5/2024 1:33:31 PM
		Visual Inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	2-020 212	Multi-Purpose Bldg MP Room	Manual	9/5/2024 1:33:50 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-021 215	Multi-Purpose Bldg MP Room	Manual	9/5/2024 1:34:01 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-025 214	Multi-Purpose Bldg MP Room	Manual	9/5/2024 1:34:13 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-024 213	Multi-Purpose Bldg MP Room	Manual	9/5/2024 1:34:33 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-023 210	Multi-Purpose Bldg MP Room	Manual	9/5/2024 1:37:46 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-135 207	Multi-Purpose Bldg MP Room North	Manual	9/5/2024 8:23:36 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-149 208	Multi-Purpose Bldg MP Room Northeast	Manual	9/5/2024 8:23:38 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-034 223	Multi-Purpose Bldg MP Room Office	Manual	9/5/2024 12:41:05 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-146 209	Multi-Purpose Bldg MP Room South	Manual	9/5/2024 8:23:40 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-019 216	Multi-Purpose Bldg MP Room Storage	Manual	9/5/2024 1:35:42 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-028 224	Multi-Purpose Bldg Office East	Manual	9/5/2024 1:37:43 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-031 220	Multi-Purpose Bldg South Hall	Manual	9/5/2024 1:32:11 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-030 219	Multi-Purpose Bldg South Hall	Manual	9/5/2024 1:37:45 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-027 217	Multi-Purpose Bldg Stage	Manual	9/5/2024 1:32:17 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-026 218	Multi-Purpose Bldg Stage	Manual	9/5/2024 1:32:32 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-140 236	Multi-Purpose Bldg Under Stage	Manual	9/5/2024 8:23:06 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-175 193	Restroom Bldgs Attic RR Hall by Staff	Manual	9/5/2024 8:22:45 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-089 185	Restroom Bldgs Boys RR by Rm 13	Manual	9/5/2024 1:05:43 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-090 186	Restroom Bldgs Boys RR by Rm 13	Manual	9/5/2024 1:05:50 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-262 190	Restroom Bldgs Boys RR by Rm 21	Manual	9/5/2024 1:18:06 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-165 194	Restroom Bldgs Boys RR Plumb Chse	Manual	9/5/2024 8:24:00 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-088 184	Restroom Bldgs Custodial Office	Manual	9/5/2024 1:03:32 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-260 187	Restroom Bldgs Girls RR by Rm 21	Manual	9/5/2024 1:19:26 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-173 192	Restroom Bldgs Girls RR Plumb Chse	Manual	9/5/2024 8:24:03 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-081 180	Restroom Bldgs Janitor Rm by Rm 13	Manual	9/5/2024 1:01:36 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-263 189	Restroom Bldgs Mens Staff RR by 21	Manual	9/5/2024 1:17:36 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-085 179	Restroom Bldgs Staff Office Storage	Manual	9/5/2024 1:01:04 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-082 178	Restroom Bldgs Staff Room by Rm 9	Manual	9/5/2024 1:00:43 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-086 181	Restroom Bldgs Storage by Rm 13	Manual	9/5/2024 1:02:03 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-087 182	Restroom Bldgs Storage by Rm 13	Manual	9/5/2024 1:02:37 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-261 191	Restroom Bldgs Storage by Rm 21	Manual	9/5/2024 1:18:57 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-084 183	Restroom Bldgs Storage Closet	Manual	9/5/2024 1:03:00 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-083 177	Restroom Bldgs Womens RR by Rm 9	Manual	9/5/2024 1:00:16 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-259 188	Restroom Bldgs Womens Staff RR	Manual	9/5/2024 1:16:46 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-151 044	Rooms 1 2 Bldg Attic Classroom 1	Manual	9/5/2024 8:23:10 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-151 043	Rooms 1 2 Bldg Attic Classroom 1	Manual	9/5/2024 8:23:12 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-152 045	Rooms 1 2 Bldg Attic Classroom 2	Manual	9/5/2024 8:23:13 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-040 035	Rooms 1 2 Bldg Classrm 1 Coat Rm	Manual	9/5/2024 12:58:09 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-043 042	Rooms 1 2 Bldg Classrm 1 O/S Strge	Manual	9/5/2024 12:56:06 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-037 030	Rooms 1 2 Bldg Classroom 1	Manual	9/5/2024 12:56:41 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-038 031	Rooms 1 2 Bldg Classroom 1	Manual	9/5/2024 12:57:08 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-042 032	Rooms 1 2 Bldg Classroom 1	Manual	9/5/2024 12:57:26 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-041 033	Rooms 1 2 Bldg Classroom 1	Manual	9/5/2024 12:57:44 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-039 034	Rooms 1 2 Bldg Classroom 1 RR	Manual	9/5/2024 12:58:44 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-044 036	Rooms 1 2 Bldg Classroom 1 Storage	Manual	9/5/2024 12:58:29 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-048 037	Rooms 1 2 Bldg Classroom 2	Manual	9/5/2024 12:53:58 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-049 038	Rooms 1 2 Bldg Classroom 2	Manual	9/5/2024 12:54:14 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-047 039	Rooms 1 2 Bldg Classroom 2	Manual	9/5/2024 12:54:45 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-046 040	Rooms 1 2 Bldg Classroom 2	Manual	9/5/2024 12:55:00 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-045 041	Rooms 1 2 Bldg Classroom 2 RR	Manual	9/5/2024 12:55:14 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-172 122	Rooms 10-13 Bldg Attic Classroom 10	Manual	9/5/2024 8:22:25 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-173 123	Rooms 10-13 Bldg Attic Classroom 10	Manual	9/5/2024 8:22:27 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-170 124	Rooms 10-13 Bldg Attic Classroom 11	Manual	9/5/2024 8:22:28 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-171 125	Rooms 10-13 Bldg Attic Classroom 11	Manual	9/5/2024 8:22:30 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-168 126	Rooms 10-13 Bldg Attic Classroom 12	Manual	9/5/2024 8:22:31 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-169 127	Rooms 10-13 Bldg Attic Classroom 12	Manual	9/5/2024 8:22:52 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-166 128	Rooms 10-13 Bldg Attic Classroom 13	Manual	9/5/2024 8:22:32 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-167 129	Rooms 10-13 Bldg Attic Classroom 13	Manual	9/5/2024 8:22:33 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-105 109	Rooms 10-13 Bldg Classroom 10	Manual	9/5/2024 1:11:41 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-106 106	Rooms 10-13 Bldg Classroom 10	Manual	9/5/2024 1:11:49 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-103 107	Rooms 10-13 Bldg Classroom 10	Manual	9/5/2024 1:12:10 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-104 108	Rooms 10-13 Bldg Classroom 10	Manual	9/5/2024 1:12:18 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-101 113	Rooms 10-13 Bldg Classroom 11	Manual	9/5/2024 1:10:12 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-100 112	Rooms 10-13 Bldg Classroom 11	Manual	9/5/2024 1:10:25 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-099 111	Rooms 10-13 Bldg Classroom 11	Manual	9/5/2024 1:10:47 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-102 110	Rooms 10-13 Bldg Classroom 11	Manual	9/5/2024 1:11:03 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-097 117	Rooms 10-13 Bldg Classroom 12	Manual	9/5/2024 1:08:11 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-096 116	Rooms 10-13 Bldg Classroom 12	Manual	9/5/2024 1:08:23 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-095 115	Rooms 10-13 Bldg Classroom 12	Manual	9/5/2024 1:08:39 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-098 114	Rooms 10-13 Bldg Classroom 12	Manual	9/5/2024 1:09:01 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-091 121	Rooms 10-13 Bldg Classroom 13	Manual	9/5/2024 1:06:25 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-093 120	Rooms 10-13 Bldg Classroom 13	Manual	9/5/2024 1:06:43 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-092 118	Rooms 10-13 Bldg Classroom 13	Manual	9/5/2024 1:07:12 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-094 119	Rooms 10-13 Bldg Classroom 13	Manual	9/5/2024 1:29:44 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-251 135	Rooms 14-17 Bldg Classroom 14	Manual	9/5/2024 1:13:05 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-252 136	Rooms 14-17 Bldg Classroom 14	Manual	9/5/2024 1:13:24 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-253 137	Rooms 14-17 Bldg Classroom 15	Manual	9/5/2024 1:14:05 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-254 138	Rooms 14-17 Bldg Classroom 15	Manual	9/5/2024 1:14:16 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-255 139	Rooms 14-17 Bldg Classroom 16	Manual	9/5/2024 1:14:55 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-256 140	Rooms 14-17 Bldg Classroom 16	Manual	9/5/2024 1:15:09 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-257 141	Rooms 14-17 Bldg Classroom 17	Manual	9/5/2024 1:15:49 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-258 142	Rooms 14-17 Bldg Classroom 17	Manual	9/5/2024 1:16:00 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-271 148	Rooms 18-21 Bldg Classroom 18	Manual	9/5/2024 1:29:47 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-270 149	Rooms 18-21 Bldg Classroom 18	Manual	9/5/2024 1:29:48 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-269 150	Rooms 18-21 Bldg Classroom 19	Manual	9/5/2024 1:22:33 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-268 151	Rooms 18-21 Bldg Classroom 19	Manual	9/5/2024 1:22:41 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-267 152	Rooms 18-21 Bldg Classroom 20	Manual	9/5/2024 1:21:25 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-266 153	Rooms 18-21 Bldg Classroom 20	Manual	9/5/2024 1:21:49 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-265 154	Rooms 18-21 Bldg Classroom 21	Manual	9/5/2024 1:20:15 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-264 155	Rooms 18-21 Bldg Classroom 21	Manual	9/5/2024 1:20:33 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-377 171	Rooms 22 23 Bldg Attic Classroom 22	Manual	9/5/2024 8:22:20 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-377 170	Rooms 22 23 Bldg Attic Classroom 22	Manual	9/5/2024 8:22:22 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-377 169	Rooms 22 23 Bldg Attic Classroom 22	Manual	9/5/2024 8:22:23 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-378 172	Rooms 22 23 Bldg Attic Classroom 23	Manual	9/5/2024 8:22:15 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-378 173	Rooms 22 23 Bldg Attic Classroom 23	Manual	9/5/2024 8:22:17 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-378 174	Rooms 22 23 Bldg Attic Classroom 23	Manual	9/5/2024 8:22:18 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-274 164	Rooms 22 23 Bldg Classroom 22	Manual	9/5/2024 1:24:33 PM
		Visual Inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-272 161	Rooms 22 23 Bldg Classroom 22	Manual	9/5/2024 1:24:54 PM
		Visual Inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-273 162	Rooms 22 23 Bldg Classroom 22	Manual	9/5/2024 1:24:57 PM
		Visual Inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-275 163	Rooms 22 23 Bldg Classroom 22	Manual	9/5/2024 1:25:28 PM
		Visual Inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-276 165	Rooms 22 23 Bldg Classroom 23	Manual	9/5/2024 1:25:44 PM
		Visual Inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-277 166	Rooms 22 23 Bldg Classroom 23	Manual	9/5/2024 1:26:06 PM
		Visual Inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-279 167	Rooms 22 23 Bldg Classroom 23	Manual	9/5/2024 1:26:10 PM
		Visual Inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-278 168	Rooms 22 23 Bldg Classroom 23	Manual	9/5/2024 1:26:15 PM
		Visual Inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-153 063	Rooms 3 4 Bldgs Attic Classroom 3	Manual	9/5/2024 8:23:15 PM
		Visual Inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-153 061	Rooms 3 4 Bldgs Attic Classroom 3	Manual	9/5/2024 8:23:17 PM
		Visual Inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-153 062	Rooms 3 4 Bldgs Attic Classroom 3	Manual	9/5/2024 8:23:18 PM
		Visual Inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-154 064	Rooms 3 4 Bldgs Attic Classroom 4	Manual	9/5/2024 8:23:19 PM
		Visual Inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-154 065	Rooms 3 4 Bldgs Attic Classroom 4	Manual	9/5/2024 8:23:21 PM
		Visual Inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-053 052	Rooms 3 4 Bldgs Classroom 3	Manual	9/5/2024 12:51:00 PM
		Visual Inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-052 053	Rooms 3 4 Bldgs Classroom 3	Manual	9/5/2024 12:51:18 PM
		Visual Inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-054 051	Rooms 3 4 Bldgs Classroom 3	Manual	9/5/2024 12:51:48 PM
		Visual Inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-051 054	Rooms 3 4 Bldgs Classroom 3	Manual	9/5/2024 12:52:03 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-055 055	Rooms 3 4 Bldgs Classroom 4	Manual	9/5/2024 12:49:37 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-060 058	Rooms 3 4 Bldgs Classroom 4	Manual	9/5/2024 12:49:47 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-057 057	Rooms 3 4 Bldgs Classroom 4	Manual	9/5/2024 12:50:34 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-056 056	Rooms 3 4 Bldgs Classroom 4	Manual	9/5/2024 12:50:48 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-059 060	Rooms 3 4 Bldgs Classroom 4 RR	Manual	9/5/2024 12:49:59 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-058 059	Rooms 3 4 Bldgs Classroom 4 RR	Manual	9/5/2024 12:50:07 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-156 090	Rooms 5-9 Bldg Attic Classroom 5	Manual	9/5/2024 8:23:22 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-155 089	Rooms 5-9 Bldg Attic Classroom 5	Manual	9/5/2024 8:23:23 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-157 091	Rooms 5-9 Bldg Attic Classroom 6	Manual	9/5/2024 8:22:35 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-158 092	Rooms 5-9 Bldg Attic Classroom 6	Manual	9/5/2024 8:22:36 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-160 094	Rooms 5-9 Bldg Attic Classroom 7	Manual	9/5/2024 8:22:38 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-159 093	Rooms 5-9 Bldg Attic Classroom 7	Manual	9/5/2024 8:22:43 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-161 095	Rooms 5-9 Bldg Attic Classroom 8	Manual	9/5/2024 8:22:39 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-162 096	Rooms 5-9 Bldg Attic Classroom 8	Manual	9/5/2024 8:22:41 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-163 097	Rooms 5-9 Bldg Attic Classroom 9	Manual	9/5/2024 8:22:42 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-164 098	Rooms 5-9 Bldg Attic Classroom 9	Manual	9/5/2024 8:22:46 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-063 071	Rooms 5-9 Bldg Classroom 5	Manual	9/5/2024 12:41:34 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-064 070	Rooms 5-9 Bldg Classroom 5	Manual	9/5/2024 12:41:51 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-062 069	Rooms 5-9 Bldg Classroom 5	Manual	9/5/2024 12:42:13 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-061 072	Rooms 5-9 Bldg Classroom 5	Manual	9/5/2024 12:42:31 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-067 075	Rooms 5-9 Bldg Classroom 6	Manual	9/5/2024 12:42:56 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-068 074	Rooms 5-9 Bldg Classroom 6	Manual	9/5/2024 12:43:15 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-066 073	Rooms 5-9 Bldg Classroom 6	Manual	9/5/2024 12:43:25 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-065 076	Rooms 5-9 Bldg Classroom 6	Manual	9/5/2024 12:43:42 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-071 077	Rooms 5-9 Bldg Classroom 7	Manual	9/5/2024 12:45:18 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-072 078	Rooms 5-9 Bldg Classroom 7	Manual	9/5/2024 12:45:34 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-070 079	Rooms 5-9 Bldg Classroom 7	Manual	9/5/2024 12:45:46 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-069 080	Rooms 5-9 Bldg Classroom 7	Manual	9/5/2024 12:46:00 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-074 083	Rooms 5-9 Bldg Classroom 8	Manual	9/5/2024 12:46:28 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-076 082	Rooms 5-9 Bldg Classroom 8	Manual	9/5/2024 12:46:42 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-075 081	Rooms 5-9 Bldg Classroom 8	Manual	9/5/2024 12:46:57 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-073 084	Rooms 5-9 Bldg Classroom 8	Manual	9/5/2024 12:47:13 PM
		Visual Inspection	Passed (Manual)	
Smoke Detector - General	2-079 086	Rooms 5-9 Bldg Classroom 9	Manual	9/5/2024 12:47:44 PM
		Visual Inspection	Passed (Manual)	
Smoke Detector - General	2-080 085	Rooms 5-9 Bldg Classroom 9	Manual	9/5/2024 12:48:01 PM
		Visual Inspection	Passed (Manual)	
Smoke Detector - General	2-078 088	Rooms 5-9 Bldg Classroom 9	Manual	9/5/2024 12:48:18 PM
		Visual Inspection	Passed (Manual)	
Smoke Detector - General	2-077 087	Rooms 5-9 Bldg Classroom 9	Manual	9/5/2024 12:48:32 PM
		Visual Inspection	Passed (Manual)	

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-138 233	Multi-Purpose Bldg Attic MP Room	Manual	9/5/2024 8:24:05 PM
Heat Detector - Restorable Spot	2-138 232	Multi-Purpose Bldg Attic MP Room	Manual	9/5/2024 8:24:09 PM
Heat Detector - Restorable Spot	2-137 231	Multi-Purpose Bldg Attic MP Room	Manual	9/5/2024 8:24:11 PM
Heat Detector - Restorable Spot	2-137 230	Multi-Purpose Bldg Attic MP Room	Manual	9/5/2024 8:24:14 PM

Failed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - Duct	2-144 243	Multi-Purpose Bldg Boiler Room	Manual	9/5/2024 1:41:22 PM
		Visual Inspection	Failed (Manual)	
Smoke Detector - Duct	2-143 242	Multi-Purpose Bldg Boiler Room	Manual	9/5/2024 1:41:42 PM
		Visual Inspection	Failed (Manual)	

Device/Equipment Details

Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Audible And Visible					
018	Admin Area Front Office				
019	Admin Area Copy Room				
020	Admin Area Secretary Office				
021	Admin Area Secretary Office RR				
022	Admin Area Principals Office				
023	Admin Area Mail Room				
024	Admin Area Admin Office Hall				
025	Admin Area Admin Office Hall				
026	Admin Area Break Rm Kitchenette				
027	Admin Area Mens Staff Restroom				
028	Admin Area Womens Staff RR				
047	Rooms 1 2 Bldg Classroom 1				
048	Rooms 1 2 Bldg Classroom 1 RR				
049	Rooms 1 2 Bldg Classroom 2				
050	Rooms 1 2 Bldg Classroom 2 RR				
067	Rooms 3 4 Bldgs Classroom 3				
068	Rooms 3 4 Bldgs Classroom 4				
101	Rooms 5-9 Bldg Classroom 5				
102	Rooms 5-9 Bldg Classroom 6				
103	Rooms 5-9 Bldg Classroom 7				
104	Rooms 5-9 Bldg Classroom 8				
105	Rooms 5-9 Bldg Classroom 9				
131	Rooms 10-13 Bldg Classroom 10				
132	Rooms 10-13 Bldg Classroom 11				
133	Rooms 10-13 Bldg Classroom 12				
134	Rooms 10-13 Bldg Classroom 13				
144	Rooms 14-17 Bldg Classroom 14				
145	Rooms 14-17 Bldg Classroom 15				
146	Rooms 14-17 Bldg Classroom 16				
147	Rooms 14-17 Bldg Classroom 17				
157	Rooms 18-21 Bldg Classroom 18				
158	Rooms 18-21 Bldg Classroom 19				
159	Rooms 18-21 Bldg Classroom 20				
160	Rooms 18-21 Bldg Classroom 21				
175	Rooms 22 23 Bldg Classroom 22				
176	Rooms 22 23 Bldg Classroom 23				
197	Restroom Bldgs Womens Restroom				
198	Restroom Bldgs Staff Room				
199	Restroom Bldgs Custodial Office				
200	Restroom Bldgs Boys Restroom				
201	Restroom Bldgs Girls Restroom				
202	Restroom Bldgs Womens Staff RR				
203	Restroom Bldgs Mens Staff RR				
204	Restroom Bldgs Boys Restroom				
245	Multi-Purpose Bldg MP Room				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
246	Multi-Purpose Bldg MP Room				
247	Multi-Purpose Bldg Stage				
248	Multi-Purpose Bldg South Hall				
249	Multi-Purpose Bldg File Room				
250	Multi-Purpose Bldg MP Room Office				
251	Multi-Purpose Bldg Office East				
252	Multi-Purpose Bldg Kitchen				
253	Multi-Purpose Bldg Kitchen				

Audible

046	Rooms 1 2 Bldg South Exterior				
066	Rooms 3 4 Bldgs South Exterior				
099	Rooms 5-9 Bldg East Exterior				
100	Rooms 5-9 Bldg South Exterior				
130	Rooms 10-13 Bldg South Exterior				
143	Rooms 14-17 Bldg South Exterior				
156	Rooms 18-21 Bldg South Exterior				
195	Restroom Bldgs East Exterior				
196	Restroom Bldgs West Exterior				
244	Multi-Purpose Bldg West Exterior				

Visible

254	Multi-Purpose Bldg Stage				
255	Multi-Purpose Bldg Kitchen				

Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Remote Annunciator					
001	Admin Area Front Office				
NAC Power Extender Panel					
029	Admin Area Copy Room - P.E. "A"				
205	Restroom Bldgs Janitor Rm by Rm 13 - P.E. "B"				
206	Restroom Bldgs Storage by Rm 21 - P.E. "C"				
Fire Alarm Panel					
	Admin Area Copy Room	EST		3	

Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Manual Pull Station					
2-133 002	Admin Area Front Office				
2-135 207	Multi-Purpose Bldg MP Room North				
2-149 208	Multi-Purpose Bldg MP Room Northeast				
2-146 209	Multi-Purpose Bldg MP Room South				
Smoke Detector - General					
2-009 003	Admin Area Front Office				
2-005 004	Admin Area Above FACP copy Rm				
2-008 005	Admin Area Secretary Office				
2-007 006	Admin Area Secretary Office RR				
2-010 007	Admin Area Principals Office				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-006 008	Admin Area Mail Room				
2-035 009	Admin Area Admin Office Hall				
2-036 010	Admin Area Admin Office Hall				
2-013 011	Admin Area Admin Office Hall				
2-012 012	Admin Area Womens Staff RR				
2-014 013	Admin Area Mens Staff Restroom				
2-037 030	Rooms 1 2 Bldg Classroom 1				
2-038 031	Rooms 1 2 Bldg Classroom 1				
2-042 032	Rooms 1 2 Bldg Classroom 1				
2-041 033	Rooms 1 2 Bldg Classroom 1				
2-039 034	Rooms 1 2 Bldg Classroom 1 RR				
2-040 035	Rooms 1 2 Bldg Classrm 1 Coat Rm				
2-044 036	Rooms 1 2 Bldg Classroom 1 Storage				
2-048 037	Rooms 1 2 Bldg Classroom 2				
2-049 038	Rooms 1 2 Bldg Classroom 2				
2-047 039	Rooms 1 2 Bldg Classroom 2				
2-046 040	Rooms 1 2 Bldg Classroom 2				
2-045 041	Rooms 1 2 Bldg Classroom 2 RR				
2-054 051	Rooms 3 4 Bldgs Classroom 3				
2-053 052	Rooms 3 4 Bldgs Classroom 3				
2-052 053	Rooms 3 4 Bldgs Classroom 3				
2-051 054	Rooms 3 4 Bldgs Classroom 3				
2-055 055	Rooms 3 4 Bldgs Classroom 4				
2-056 056	Rooms 3 4 Bldgs Classroom 4				
2-057 057	Rooms 3 4 Bldgs Classroom 4				
2-060 058	Rooms 3 4 Bldgs Classroom 4				
2-058 059	Rooms 3 4 Bldgs Classroom 4 RR				
2-059 060	Rooms 3 4 Bldgs Classroom 4 RR				
2-062 069	Rooms 5-9 Bldg Classroom 5				
2-064 070	Rooms 5-9 Bldg Classroom 5				
2-063 071	Rooms 5-9 Bldg Classroom 5				
2-061 072	Rooms 5-9 Bldg Classroom 5				
2-066 073	Rooms 5-9 Bldg Classroom 6				
2-068 074	Rooms 5-9 Bldg Classroom 6				
2-067 075	Rooms 5-9 Bldg Classroom 6				
2-065 076	Rooms 5-9 Bldg Classroom 6				
2-071 077	Rooms 5-9 Bldg Classroom 7				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-072 078	Rooms 5-9 Bldg Classroom 7				
2-070 079	Rooms 5-9 Bldg Classroom 7				
2-069 080	Rooms 5-9 Bldg Classroom 7				
2-075 081	Rooms 5-9 Bldg Classroom 8				
2-076 082	Rooms 5-9 Bldg Classroom 8				
2-074 083	Rooms 5-9 Bldg Classroom 8				
2-073 084	Rooms 5-9 Bldg Classroom 8				
2-080 085	Rooms 5-9 Bldg Classroom 9				
2-079 086	Rooms 5-9 Bldg Classroom 9				
2-077 087	Rooms 5-9 Bldg Classroom 9				
2-078 088	Rooms 5-9 Bldg Classroom 9				
2-106 106	Rooms 10-13 Bldg Classroom 10				
2-103 107	Rooms 10-13 Bldg Classroom 10				
2-104 108	Rooms 10-13 Bldg Classroom 10				
2-105 109	Rooms 10-13 Bldg Classroom 10				
2-102 110	Rooms 10-13 Bldg Classroom 11				
2-099 111	Rooms 10-13 Bldg Classroom 11				
2-100 112	Rooms 10-13 Bldg Classroom 11				
2-101 113	Rooms 10-13 Bldg Classroom 11				
2-098 114	Rooms 10-13 Bldg Classroom 12				
2-095 115	Rooms 10-13 Bldg Classroom 12				
2-096 116	Rooms 10-13 Bldg Classroom 12				
2-097 117	Rooms 10-13 Bldg Classroom 12				
2-092 118	Rooms 10-13 Bldg Classroom 13				
2-094 119	Rooms 10-13 Bldg Classroom 13				
2-093 120	Rooms 10-13 Bldg Classroom 13				
2-091 121	Rooms 10-13 Bldg Classroom 13				
2-251 135	Rooms 14-17 Bldg Classroom 14				
2-252 136	Rooms 14-17 Bldg Classroom 14				
2-253 137	Rooms 14-17 Bldg Classroom 15				
2-254 138	Rooms 14-17 Bldg Classroom 15				
2-255 139	Rooms 14-17 Bldg Classroom 16				
2-256 140	Rooms 14-17 Bldg Classroom 16				
2-257 141	Rooms 14-17 Bldg Classroom 17				
2-258 142	Rooms 14-17 Bldg Classroom 17				
2-271 148	Rooms 18-21 Bldg Classroom 18				
2-270 149	Rooms 18-21 Bldg Classroom 18				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-269 150	Rooms 18-21 Bldg Classroom 19				
2-268 151	Rooms 18-21 Bldg Classroom 19				
2-267 152	Rooms 18-21 Bldg Classroom 20				
2-266 153	Rooms 18-21 Bldg Classroom 20				
2-265 154	Rooms 18-21 Bldg Classroom 21				
2-264 155	Rooms 18-21 Bldg Classroom 21				
2-272 161	Rooms 22 23 Bldg Classroom 22				
2-273 162	Rooms 22 23 Bldg Classroom 22				
2-275 163	Rooms 22 23 Bldg Classroom 22				
2-274 164	Rooms 22 23 Bldg Classroom 22				
2-276 165	Rooms 22 23 Bldg Classroom 23				
2-277 166	Rooms 22 23 Bldg Classroom 23				
2-279 167	Rooms 22 23 Bldg Classroom 23				
2-278 168	Rooms 22 23 Bldg Classroom 23				
2-083 177	Restroom Bldgs Womens RR by Rm 9				
2-082 178	Restroom Bldgs Staff Room by Rm 9				
2-085 179	Restroom Bldgs Staff Office Storage				
2-081 180	Restroom Bldgs Janitor Rm by Rm 13				
2-086 181	Restroom Bldgs Storage by Rm 13				
2-087 182	Restroom Bldgs Storage by Rm 13				
2-084 183	Restroom Bldgs Storage Closet				
2-088 184	Restroom Bldgs Custodial Office				
2-089 185	Restroom Bldgs Boys RR by Rm 13				
2-090 186	Restroom Bldgs Boys RR by Rm 13				
2-260 187	Restroom Bldgs Girls RR by Rm 21				
2-259 188	Restroom Bldgs Womens Staff RR				
2-263 189	Restroom Bldgs Mens Staff RR by 21				
2-262 190	Restroom Bldgs Boys RR by Rm 21				
2-261 191	Restroom Bldgs Storage by Rm 21				
2-023 210	Multi-Purpose Bldg MP Room				
2-022 211	Multi-Purpose Bldg MP Room				
2-020 212	Multi-Purpose Bldg MP Room				
2-024 213	Multi-Purpose Bldg MP Room				
2-025 214	Multi-Purpose Bldg MP Room				
2-021 215	Multi-Purpose Bldg MP Room				
2-019 216	Multi-Purpose Bldg MP Room Storage				
2-027 217	Multi-Purpose Bldg Stage				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-026 218	Multi-Purpose Bldg Stage				
2-030 219	Multi-Purpose Bldg South Hall				
2-031 220	Multi-Purpose Bldg South Hall				
2-032 221	Multi-Purpose Bldg File Room				
2-033 222	Multi-Purpose Bldg File Room				
2-034 223	Multi-Purpose Bldg MP Room Office				
2-028 224	Multi-Purpose Bldg Office East				
2-029 225	Multi-Purpose Bldg Boiler Room				
Heat Detector - Restorable Spot					
2-011 014	Admin Area Break Rm Kitchenette				
2-132 015	Admin Area Attic Admin Front Off				
2-134 016	Admin Area Attic North Hall West				
2-150 017	Admin Area Attic North Hall East				
2-043 042	Rooms 1 2 Bldg Classrm 1 O/S Strge				
2-151 043	Rooms 1 2 Bldg Attic Classroom 1				
2-151 044	Rooms 1 2 Bldg Attic Classroom 1				
2-152 045	Rooms 1 2 Bldg Attic Classroom 2				
2-153 061	Rooms 3 4 Bldgs Attic Classroom 3				
2-153 062	Rooms 3 4 Bldgs Attic Classroom 3				
2-153 063	Rooms 3 4 Bldgs Attic Classroom 3				
2-154 064	Rooms 3 4 Bldgs Attic Classroom 4				
2-154 065	Rooms 3 4 Bldgs Attic Classroom 4				
2-155 089	Rooms 5-9 Bldg Attic Classroom 5				
2-156 090	Rooms 5-9 Bldg Attic Classroom 5				
2-157 091	Rooms 5-9 Bldg Attic Classroom 6				
2-158 092	Rooms 5-9 Bldg Attic Classroom 6				
2-159 093	Rooms 5-9 Bldg Attic Classroom 7				
2-160 094	Rooms 5-9 Bldg Attic Classroom 7				
2-161 095	Rooms 5-9 Bldg Attic Classroom 8				
2-162 096	Rooms 5-9 Bldg Attic Classroom 8				
2-163 097	Rooms 5-9 Bldg Attic Classroom 9				
2-164 098	Rooms 5-9 Bldg Attic Classroom 9				
2-172 122	Rooms 10-13 Bldg Attic Classroom 10				
2-173 123	Rooms 10-13 Bldg Attic Classroom 10				
2-170 124	Rooms 10-13 Bldg Attic Classroom 11				
2-171 125	Rooms 10-13 Bldg Attic Classroom 11				
2-168 126	Rooms 10-13 Bldg Attic Classroom 12				
2-169 127	Rooms 10-13 Bldg Attic Classroom 12				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-166 128	Rooms 10-13 Bldg Attic Classroom 13				
2-167 129	Rooms 10-13 Bldg Attic Classroom 13				
2-377 169	Rooms 22 23 Bldg Attic Classroom 22				
2-377 170	Rooms 22 23 Bldg Attic Classroom 22				
2-377 171	Rooms 22 23 Bldg Attic Classroom 22				
2-378 172	Rooms 22 23 Bldg Attic Classroom 23				
2-378 173	Rooms 22 23 Bldg Attic Classroom 23				
2-378 174	Rooms 22 23 Bldg Attic Classroom 23				
2-173 192	Restroom Bldgs Girls RR Plumb Chse				
2-175 193	Restroom Bldgs Attic RR Hall by Staff				
2-165 194	Restroom Bldgs Boys RR Plumb Chse				
2-015 226	Multi-Purpose Bldg Kitchen				
2-016 227	Multi-Purpose Bldg Kitchen				
2-017 228	Multi-Purpose Bldg Kitchen Storage				
2-018 229	Multi-Purpose Bldg Kitchen Store Room				
2-137 230	Multi-Purpose Bldg Attic MP Room				
2-137 231	Multi-Purpose Bldg Attic MP Room				
2-138 232	Multi-Purpose Bldg Attic MP Room				
2-138 233	Multi-Purpose Bldg Attic MP Room				
2-139 234	Multi-Purpose Bldg Attic Stage				
2-139 235	Multi-Purpose Bldg Attic Stage				
2-140 236	Multi-Purpose Bldg Under Stage				
2-145 237	Multi-Purpose Bldg Attic South Hall				
2-147 238	Multi-Purpose Bldg Attic File Room				
2-148 239	Multi-Purpose Bldg Attic MP S Office				
2-141 240	Multi-Purpose Bldg Attic MP E Office				
2-136 241	Multi-Purpose Bldg Attic Kitchen				
Smoke Detector - Duct					
2-143 242	Multi-Purpose Bldg Boiler Room				
2-144 243	Multi-Purpose Bldg Boiler Room				