

# Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

WHITNEY AVE ELM

4248 WHITNEY AVE  
SACRAMENTO, California  
United States

This site has been inspected and tested in compliance with applicable standards.

Completed  
Tuesday, September 30, 2025

Test Session: 16 Sep 2025 18:45 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD  
5320 HEMLOCK ST  
SACRAMENTO, California  
United States

TESTED BY

Riley Goyet  
Western States Fire Protection-  
Sacramento  
188 Cirby Way  
Roseville, CA 95678  
United States



# Inspection Summary

## Building Information

PROPERTY	WHITNEY AVE ELM	CONTACT
ADDRESS	4248 WHITNEY AVE	PHONE
CITY/STATE	SACRAMENTO, California	MOBILE
COUNTRY	United States	EMAIL

## Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us


## Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Alarm Notification Appliance	77	77(100%)	77(100%)	0(0%)
Power Supplies	5	5(100%)	4(80%)	1(20%)
Fire Control Panel	6	6(100%)	6(100%)	0(0%)
Initiating Device	131	130(99%)	130(99%)	0(0%)

## Certification

The equipment specified here in was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Tuesday, September 30, 2025

ACCEPTED BY      09/30/2025  
  
Building Representative

  
TESTED BY      09/30/2025  
Riley Goyet  
Technician

# System Details

## Control Units

ADDRESS/ SCAN ADDRESS		DESCRIPTION	Building A A2B Office Storage
MANUFACTURER	EST	S/W VERSION	
MODEL	3	LAST UPDATE	
SERIAL NUMBER		S/W LOCATION	
INSTALL DATE			

## Secondary Power

TYPE	Battery - Sealed Lead-acid	DESCRIPTION	Building A A2B Office Storage - FACP
ADDRESS/ SCAN ADDRESS		NOMINAL VOLTAGE	12
Load Voltage		Amp Hours	55
Standby Hours		Alarm Minutes	
Battery Location		Charger Voltage	
TYPE	Battery - Sealed Lead-acid	DESCRIPTION	Building A A2B Office Storage - P.E. "B"
ADDRESS/ SCAN ADDRESS		NOMINAL VOLTAGE	12
Load Voltage		Amp Hours	8
Standby Hours		Alarm Minutes	
Battery Location		Charger Voltage	
TYPE	Battery - Sealed Lead-acid	DESCRIPTION	Building A A2B Office Storage - P.E. "Master"
ADDRESS/ SCAN ADDRESS		NOMINAL VOLTAGE	12
Load Voltage		Amp Hours	8
Standby Hours		Alarm Minutes	
Battery Location		Charger Voltage	
TYPE	Battery - Sealed Lead-acid	DESCRIPTION	Building C C1 Boiler Room - P.E. "C"
ADDRESS/ SCAN ADDRESS		NOMINAL VOLTAGE	12
Load Voltage		Amp Hours	8
Standby Hours		Alarm Minutes	
Battery Location		Charger Voltage	
TYPE	Battery - Sealed Lead-acid	DESCRIPTION	Building D D2 Custodial Closet - P.E. "D"
ADDRESS/ SCAN ADDRESS		NOMINAL VOLTAGE	12
Load Voltage		Amp Hours	8
Standby Hours		Alarm Minutes	
Battery Location		Charger Voltage	

# Open Corrective Action & Solution Summary

The following 1 corrective action(s) remain open following the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
Battery - Sealed Lead-acid	Created By: Creation Date: Corrective Action: Proposed Solution: Manufacturer: Model:	Building A A2B Office Storage - FACP  Riley Goyet 09/16/2025 Replace (2) 12V 55AH Batteries

# Resolved Corrective Action & Solution Summary

The following 2 corrective action(s) were resolved during the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
Manual Pull Station	2-131 002	Building A Reception

Created By: Michael Spencer  
 Creation Date: 11/01/2023  
 Corrective Action: Unable to test pull station. Plastic cover blocks key hole so I am unable to reset pull station after activation.  
 Resolution:  
 Resolved By: Riley Goyet  
 Resolved On: 09/16/2025  
 Manufacturer:  
 Model:

Battery - Sealed Lead-acid		Building A A2B Office Storage - P.E. "Master"
----------------------------	--	---

Created By: Michael Spencer  
 Creation Date: 11/01/2023  
 Corrective Action: Batteries are past 5yr old recommended replacement of batteries 12V8Ah  
 Resolution:  
 Resolved By: Riley Goyet  
 Resolved On: 09/16/2025  
 Manufacturer:  
 Model:



# Testing Details

## Alarm Notification Appliance

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	053	Building A A1 Reception	Manual	9/16/2025 6:49:20 PM
		Visual inspection	Passed (Manual)	
Visible	074	Building A A15 Girls Restroom	Manual	9/16/2025 6:48:47 PM
		Visual inspection	Passed (Manual)	
Visible	075	Building A A16 Boys Restroom	Manual	9/16/2025 6:48:44 PM
		Visual inspection	Passed (Manual)	
Visible	061	Building A A1B Principals Office	Manual	9/16/2025 6:49:07 PM
		Visual inspection	Passed (Manual)	
Visible	062	Building A A2 Office Hall	Manual	9/16/2025 6:49:05 PM
		Visual inspection	Passed (Manual)	
Visible	063	Building A A2A Office Restroom	Manual	9/16/2025 6:49:03 PM
		Visual inspection	Passed (Manual)	
Visible	065	Building A A2C Nurse Room	Manual	9/16/2025 6:49:00 PM
		Visual inspection	Passed (Manual)	
Visible	064	Building A A2C Nurse Room	Manual	9/16/2025 6:49:02 PM
		Visual inspection	Passed (Manual)	
Visible	066	Building A A2C1 Copy Room	Manual	9/16/2025 6:48:59 PM
		Visual inspection	Passed (Manual)	
Visible	067	Building A A2C2 Nurse Office	Manual	9/16/2025 6:48:56 PM
		Visual inspection	Passed (Manual)	
Visible	068	Building A A5 Staff Rm Entry	Manual	9/16/2025 6:48:53 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	054	Building A A5A Staff Room	Manual	9/16/2025 6:49:19 PM
		Visual inspection	Passed (Manual)	
Visible	069	Building A A6 Womens Staff RR	Manual	9/16/2025 6:48:55 PM
		Visual inspection	Passed (Manual)	
Visible	070	Building A A7 Adult Restroom	Manual	9/16/2025 6:48:52 PM
		Visual inspection	Passed (Manual)	
Audible	048	Building A East Exterior	Manual	9/16/2025 6:49:29 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	057	Building A Room A10	Manual	9/16/2025 6:49:13 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	058	Building A Room A11	Manual	9/16/2025 6:49:12 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	059	Building A Room A12	Manual	9/16/2025 6:49:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	060	Building A Room A13	Manual	9/16/2025 6:49:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	055	Building A Room A8	Manual	9/16/2025 6:49:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	071	Building A Room A8	Manual	9/16/2025 6:48:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	072	Building A Room A8A Storage	Manual	9/16/2025 6:48:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	073	Building A Room A8B RR	Manual	9/16/2025 6:48:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	056	Building A Room A9	Manual	9/16/2025 6:49:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	051	Building A South Exterior	Manual	9/16/2025 6:49:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	050	Building A South Exterior	Manual	9/16/2025 6:49:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	049	Building A South Exterior	Manual	9/16/2025 6:49:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	052	Building A West Exterior	Manual	9/16/2025 6:49:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	093	Building B B1 MP Room	Manual	9/16/2025 6:48:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	092	Building B B1 MP Room	Manual	9/16/2025 6:48:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	094	Building B B2 Kitchen	Manual	9/16/2025 6:48:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	096	Building B B2 Kitchen	Manual	9/16/2025 6:48:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	097	Building B B2A Kitchen Office	Manual	9/16/2025 6:48:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	095	Building B B3 Stage	Manual	9/16/2025 6:48:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	098	Building B East Exterior	Manual	9/16/2025 6:48:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible	091	Building B West Exterior	Manual	9/16/2025 6:48:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	131	Building C C1 Boiler Room	Manual	9/16/2025 6:48:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	125	Building C East Exterior	Manual	9/16/2025 6:48:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	140	Building C Room C2	Manual	9/16/2025 6:48:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	139	Building C Room C2	Manual	9/16/2025 6:48:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	132	Building C Room C4 East	Manual	9/16/2025 6:48:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	133	Building C Room C4 West	Manual	9/16/2025 6:48:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	141	Building C Room C4A Office	Manual	9/16/2025 6:48:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	134	Building C Room C5	Manual	9/16/2025 6:48:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	135	Building C Room C6	Manual	9/16/2025 6:48:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	136	Building C Room C7	Manual	9/16/2025 6:48:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	137	Building C Room C8	Manual	9/16/2025 6:48:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	138	Building C Room C9	Manual	9/16/2025 6:48:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	129	Building C South Exterior	Manual	9/16/2025 6:48:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	128	Building C South Exterior	Manual	9/16/2025 6:48:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	127	Building C South Exterior	Manual	9/16/2025 6:48:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	130	Building C West Exterior	Manual	9/16/2025 6:48:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	126	Building C West Exterior	Manual	9/16/2025 6:48:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	181	Building D D1 Girls Restroom	Manual	9/16/2025 6:47:46 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	182	Building D D3 Boys Restroom	Manual	9/16/2025 6:47:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	183	Building D D4 Custodian Office	Manual	9/16/2025 6:47:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	180	Building D Room D10	Manual	9/16/2025 6:47:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	175	Building D Room D5	Manual	9/16/2025 6:47:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	184	Building D Room D5A Office	Manual	9/16/2025 6:47:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	185	Building D Room D5B Storage	Manual	9/16/2025 6:47:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	176	Building D Room D6	Manual	9/16/2025 6:47:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	186	Building D Room D6A Office	Manual	9/16/2025 6:47:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	187	Building D Room D6B Storage	Manual	9/16/2025 6:47:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	188	Building D Room D6B1 Storage	Manual	9/16/2025 6:47:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	177	Building D Room D7	Manual	9/16/2025 6:47:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	189	Building D Room D7A Storage	Manual	9/16/2025 6:47:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	178	Building D Room D8	Manual	9/16/2025 6:47:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	179	Building D Room D9	Manual	9/16/2025 6:47:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	174	Building D South Exterior	Manual	9/16/2025 6:48:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	173	Building D South Exterior	Manual	9/16/2025 6:48:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	172	Building D South Exterior	Manual	9/16/2025 6:48:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	197	Building E Room E1	Manual	9/16/2025 6:47:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible	196	Building E West Exterior	Manual	9/16/2025 6:47:20 PM
		Visual inspection	Passed (Manual)	
Audible	202	Building F North Exterior	Manual	9/16/2025 6:47:17 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	203	Building F Room F1	Manual	9/16/2025 6:47:15 PM
		Visual inspection	Passed (Manual)	
Audible	208	Building H East Exterior	Manual	9/16/2025 6:47:13 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	209	Building H Room H1	Manual	9/16/2025 6:47:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

### Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Fire Alarm Panel		Building A A2B Office Storage	Manual	9/16/2025 8:22:54 PM
		Manufacturer	EST	
		Model	3	
		Visual inspection	Passed (Manual)	
NAC Power Extender Panel		Building A A2B Office Storage - P.E. "B"	Manual	9/16/2025 8:22:58 PM
		Visual inspection	Passed (Manual)	
NAC Power Extender Panel		Building A A2B Office Storage - P.E. "Master"	Manual	9/16/2025 8:22:56 PM
		Visual inspection	Passed (Manual)	
Remote Annunciator	001	Building A Reception	Manual	9/16/2025 8:23:02 PM
		Visual inspection	Passed (Manual)	
NAC Power Extender Panel		Building C C1 Boiler Room - P.E. "C"	Manual	9/16/2025 8:22:59 PM
		Visual inspection	Passed (Manual)	
NAC Power Extender Panel		Building D D2 Custodial Closet - P.E. "D"	Manual	9/16/2025 8:23:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

### Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-007 003	Building A A1 Reception	Manual	9/16/2025 6:51:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-037 035	Building A A14 Custodial Closet	Manual	9/16/2025 7:33:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-036 036	Building A A15 Girls Restroom	Manual	9/16/2025 7:34:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-138 046	Building A A15 Plumb Soffit	Manual	9/16/2025 7:50:04 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-038 037	Building A A16 Boys Restroom	Manual	9/16/2025 7:36:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-139 047	Building A A16 Water Soffit	Manual	9/16/2025 7:50:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-005 004	Building A A1A Closet	Manual	9/16/2025 8:50:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-006 005	Building A A1B Principals Office	Manual	9/16/2025 6:51:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-004 006	Building A A1B1 Princ. Off. Clst	Manual	9/16/2025 6:52:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-009 007	Building A A2 Office Hall	Manual	9/16/2025 6:53:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-008 008	Building A A2A Office Restroom	Manual	9/16/2025 6:52:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-130 039	Building A A2B HVAC Closet	Manual	9/16/2025 7:42:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-003 038	Building A A2B Office Storage	Manual	9/16/2025 7:42:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-002 009	Building A A2B Office Storage	Manual	9/16/2025 6:51:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-011 010	Building A A2C Nurse Room	Manual	9/16/2025 6:53:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-016 011	Building A A2C1 Copy Room	Manual	9/16/2025 6:55:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-010 012	Building A A2C2 Nurse Office	Manual	9/16/2025 6:55:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-013 015	Building A A5 Staff Rm Entry	Manual	9/16/2025 6:57:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-017 016	Building A A5A Staff Room	Manual	9/16/2025 6:56:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-018 017	Building A A5A Staff Room	Manual	9/16/2025 6:56:46 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	2-023 018	Building A A6 Womens Staff RR	Manual	9/16/2025 6:57:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-022 019	Building A A7 Adult Restroom	Manual	9/16/2025 6:59:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-131 002	Building A Reception	Manual	9/16/2025 8:50:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-029 028	Building A Room A10	Manual	9/16/2025 7:20:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-028 027	Building A Room A10	Manual	9/16/2025 7:20:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-134 042	Building A Room A10 HVAC Clst	Manual	9/16/2025 7:42:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-030 029	Building A Room A11	Manual	9/16/2025 7:25:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-031 030	Building A Room A11	Manual	9/16/2025 7:26:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-135 043	Building A Room A11 HVAC Clst	Manual	9/16/2025 7:42:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-032 031	Building A Room A12	Manual	9/16/2025 7:28:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-033 032	Building A Room A12	Manual	9/16/2025 7:28:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-136 044	Building A Room A12 HVAC Clst	Manual	9/16/2025 7:42:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-034 033	Building A Room A13	Manual	9/16/2025 7:28:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-035 034	Building A Room A13	Manual	9/16/2025 7:31:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-137 045	Building A Room A13 HVAC Clst	Manual	9/16/2025 7:42:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-015 013	Building A Room A3	Manual	9/16/2025 8:50:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-014 014	Building A Room A4	Manual	9/16/2025 6:58:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-020 022	Building A Room A8	Manual	9/16/2025 7:02:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-024 021	Building A Room A8	Manual	9/16/2025 7:02:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-025 020	Building A Room A8	Manual	9/16/2025 7:03:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-132 040	Building A Room A8 HVAC Clst	Manual	9/16/2025 7:18:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-019 023	Building A Room A8A Storage	Manual	9/16/2025 7:04:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-021 024	Building A Room A8B RR	Manual	9/16/2025 7:01:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-026 025	Building A Room A9	Manual	9/16/2025 7:13:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-027 026	Building A Room A9	Manual	9/16/2025 7:13:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-133 041	Building A Room A9 HVAC Clst	Manual	9/16/2025 7:18:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-140 087	Building B B1 Attic Chair Storage	Manual	9/16/2025 7:42:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-044 079	Building B B1 Chair Storage	Manual	9/16/2025 8:45:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Projected Beam	2-149 088	Building B B1 MP Room East	Manual	9/16/2025 9:00:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-158 076	Building B B1 MP Room N.E.	Manual	9/16/2025 9:00:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-157 077	Building B B1 MP Room S.E.	Manual	9/16/2025 9:00:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-156 078	Building B B1 MP Room S.W.	Manual	9/16/2025 9:00:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - Projected Beam	2-151 089	Building B B1 MP Room West	Manual	9/16/2025 9:00:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	2-159 090	Building B B1A Sports Room	Manual	9/16/2025 8:50:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-045 080	Building B B1A Sports Room	Manual	9/16/2025 8:46:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-042 086	Building B B2 Kitchen	Manual	9/16/2025 7:42:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-041 085	Building B B2 Kitchen	Manual	9/16/2025 7:42:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-040 084	Building B B2 Kitchen	Manual	9/16/2025 7:42:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-049 083	Building B B3 Stage	Manual	9/16/2025 8:50:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-050 082	Building B B3 Stage	Manual	9/16/2025 8:50:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-153 124	Building C Attic Room C2	Manual	9/16/2025 7:50:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-039 099	Building C C1 Boiler Room	Manual	9/16/2025 8:38:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-152 118	Building C Rm C4 E. HVAC Clst	Manual	9/16/2025 7:42:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-052 101	Building C Room C2	Manual	9/16/2025 8:05:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-053 100	Building C Room C2	Manual	9/16/2025 8:27:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-141 116	Building C Room C3	Manual	9/16/2025 7:49:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-054 104	Building C Room C4 East	Manual	9/16/2025 8:38:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-142 117	Building C Room C4 HVAC Clst	Manual	9/16/2025 7:42:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-056 103	Building C Room C4 West	Manual	9/16/2025 7:57:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-057 102	Building C Room C4 West	Manual	9/16/2025 8:27:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-051 105	Building C Room C4A Office	Manual	9/16/2025 8:38:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-058 106	Building C Room C5	Manual	9/16/2025 7:52:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-059 107	Building C Room C5	Manual	9/16/2025 7:52:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-143 119	Building C Room C5 HVAC Clst	Manual	9/16/2025 7:42:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-060 109	Building C Room C6	Manual	9/16/2025 7:49:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-061 108	Building C Room C6	Manual	9/16/2025 7:50:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-144 120	Building C Room C6 HVAC Clst	Manual	9/16/2025 7:42:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-062 110	Building C Room C7	Manual	9/16/2025 7:44:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-063 111	Building C Room C7	Manual	9/16/2025 7:45:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-145 121	Building C Room C7 HVAC Clst	Manual	9/16/2025 7:42:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-065 112	Building C Room C8	Manual	9/16/2025 7:41:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-064 113	Building C Room C8	Manual	9/16/2025 7:43:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-146 122	Building C Room C8 HVAC Clst	Manual	9/16/2025 7:42:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-066 114	Building C Room C9	Manual	9/16/2025 7:38:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-067 115	Building C Room C9	Manual	9/16/2025 7:38:58 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-147 123	Building C Room C9 HVAC Clst	Manual	9/16/2025 7:42:27 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-380 171	Building D Attic Room D6B	Manual	9/16/2025 7:42:44 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-376 170	Building D D1 & D3 Plumb Soffit	Manual	9/16/2025 7:50:03 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-253 142	Building D D1 Girls Restroom	Manual	9/16/2025 8:43:00 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-252 143	Building D D2 Custodial Closet	Manual	9/16/2025 8:42:05 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-254 144	Building D D3 Boys Restroom	Manual	9/16/2025 8:42:12 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-257 145	Building D D4 Custodian Office	Manual	9/16/2025 8:50:20 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-274 162	Building D Room D10	Manual	9/16/2025 8:23:47 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-275 163	Building D Room D10	Manual	9/16/2025 8:23:49 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-384 169	Building D Room D10 HVAC Clst	Manual	9/16/2025 7:42:16 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-260 147	Building D Room D5	Manual	9/16/2025 8:10:59 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-261 146	Building D Room D5	Manual	9/16/2025 8:11:18 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-378 164	Building D Room D5 HVAC Clst	Manual	9/16/2025 7:42:03 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-259 148	Building D Room D5A Office	Manual	9/16/2025 8:12:39 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-258 149	Building D Room D5B Storage	Manual	9/16/2025 8:13:07 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-262 150	Building D Room D6	Manual	9/16/2025 8:15:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-263 151	Building D Room D6	Manual	9/16/2025 8:15:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-379 165	Building D Room D6 HVAC Clst	Manual	9/16/2025 7:42:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-264 152	Building D Room D6A Office	Manual	9/16/2025 8:17:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-265 153	Building D Room D6B Storage	Manual	9/16/2025 8:16:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-266 154	Building D Room D6B1 Storage	Manual	9/16/2025 8:27:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-268 156	Building D Room D7	Manual	9/16/2025 8:18:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-269 155	Building D Room D7	Manual	9/16/2025 8:19:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-381 166	Building D Room D7 HVAC Clst	Manual	9/16/2025 7:42:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-267 157	Building D Room D7A Storage	Manual	9/16/2025 8:18:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-270 158	Building D Room D8	Manual	9/16/2025 8:20:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-271 159	Building D Room D8	Manual	9/16/2025 8:20:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-382 167	Building D Room D8 HVAC Clst	Manual	9/16/2025 7:42:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-273 160	Building D Room D9	Manual	9/16/2025 8:21:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-272 161	Building D Room D9	Manual	9/16/2025 8:22:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-383 168	Building D Room D9 HVAC Clst	Manual	9/16/2025 7:42:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-377 195	Building E Attic Room E1	Manual	9/16/2025 7:42:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-377 194	Building E Attic Room E1	Manual	9/16/2025 7:42:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-389 193	Building E E3 Maint. Shed	Manual	9/16/2025 7:50:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-389 192	Building E E3 Maint. Shed	Manual	9/16/2025 7:50:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-255 191	Building E Room E1	Manual	9/16/2025 8:39:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-256 190	Building E Room E1	Manual	9/16/2025 8:39:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-385 200	Building F Attic Room F1	Manual	9/16/2025 7:42:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-385 201	Building F Attic Room F1	Manual	9/16/2025 7:42:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-277 198	Building F Room F1	Manual	9/16/2025 8:24:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-276 199	Building F Room F1	Manual	9/16/2025 8:25:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-388 206	Building H Attic Room H1	Manual	9/16/2025 7:42:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-388 207	Building H Attic Room H1	Manual	9/16/2025 7:42:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-283 204	Building H Room H1	Manual	9/16/2025 8:28:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-282 205	Building H Room H1	Manual	9/16/2025 8:33:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-043 081	Building B B2A Kitchen Office	Manual	9/16/2025 8:50:34 PM

**Power Supplies**

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
----------------	---------	-------------	--------	-----------

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Battery - Sealed Lead-acid		Building A A2B Office Storage - P.E. "B"	Manual	9/16/2025 8:26:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	8	
		Nominal Voltage	12	
Battery - Sealed Lead-acid		Building A A2B Office Storage - P.E. "Master"	Manual	9/16/2025 8:26:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	8	
		Nominal Voltage	12	
Battery - Sealed Lead-acid		Building C C1 Boiler Room - P.E. "C"	Manual	9/16/2025 8:26:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	8	
		Nominal Voltage	12	
Battery - Sealed Lead-acid		Building D D2 Custodial Closet - P.E. "D"	Manual	9/16/2025 8:26:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	8	
		Nominal Voltage	12	

Failed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Battery - Sealed Lead-acid		Building A A2B Office Storage - FACP	Manual	9/16/2025 6:51:43 PM
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	
		Amp Hours	55	
		Nominal Voltage	12	

## Device/Equipment details

### Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Audible					
048	Building A East Exterior				
049	Building A South Exterior				
050	Building A South Exterior				
051	Building A South Exterior				
052	Building A West Exterior				
091	Building B West Exterior				
098	Building B East Exterior				
125	Building C East Exterior				
126	Building C West Exterior				
127	Building C South Exterior				
128	Building C South Exterior				
129	Building C South Exterior				
130	Building C West Exterior				
172	Building D South Exterior				
173	Building D South Exterior				
174	Building D South Exterior				
196	Building E West Exterior				
202	Building F North Exterior				
208	Building H East Exterior				
Audible And Visible					
053	Building A A1 Reception				
054	Building A A5A Staff Room				
055	Building A Room A8				
056	Building A Room A9				
057	Building A Room A10				
058	Building A Room A11				
059	Building A Room A12				
060	Building A Room A13				
092	Building B B1 MP Room				
093	Building B B1 MP Room				
094	Building B B2 Kitchen				
095	Building B B3 Stage				
131	Building C C1 Boiler Room				
132	Building C Room C4 East				
133	Building C Room C4 West				
134	Building C Room C5				
135	Building C Room C6				
136	Building C Room C7				
137	Building C Room C8				
138	Building C Room C9				
175	Building D Room D5				
176	Building D Room D6				
177	Building D Room D7				
178	Building D Room D8				
179	Building D Room D9				
180	Building D Room D10				
197	Building E Room E1				
203	Building F Room F1				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
209	Building H Room H1				
Visible					
061	Building A A1B Principals Office				
062	Building A A2 Office Hall				
063	Building A A2A Office Restroom				
064	Building A A2C Nurse Room				
065	Building A A2C Nurse Room				
066	Building A A2C1 Copy Room				
067	Building A A2C2 Nurse Office				
068	Building A A5 Staff Rm Entry				
069	Building A A6 Womens Staff RR				
070	Building A A7 Adult Restroom				
071	Building A Room A8				
072	Building A Room A8A Storage				
073	Building A Room A8B RR				
074	Building A A15 Girls Restroom				
075	Building A A16 Boys Restroom				
096	Building B B2 Kitchen				
097	Building B B2A Kitchen Office				
139	Building C Room C2				
140	Building C Room C2				
141	Building C Room C4A Office				
181	Building D D1 Girls Restroom				
182	Building D D3 Boys Restroom				
183	Building D D4 Custodian Office				
184	Building D Room D5A Office				
185	Building D Room D5B Storage				
186	Building D Room D6A Office				
187	Building D Room D6B Storage				
188	Building D Room D6B1 Storage				
189	Building D Room D7A Storage				

### Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Remote Annunciator					
001	Building A Reception				
Fire Alarm Panel					
	Building A A2B Office Storage	EST	3		
NAC Power Extender Panel					
	Building A A2B Office Storage - P.E. "Master"				
	Building A A2B Office Storage - P.E. "B"				
	Building C C1 Boiler Room - P.E. "C"				
	Building D D2 Custodial Closet - P.E. "D"				02/16/2019

### Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Manual Pull Station					
2-131 002	Building A Reception				
2-158 076	Building B B1 MP Room N.E.				
2-157 077	Building B B1 MP Room S.E.				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-156 078	Building B B1 MP Room S.W.				
Smoke Detector - General					
2-007 003	Building A A1 Reception				
2-005 004	Building A A1A Closet				
2-006 005	Building A A1B Principals Office				
2-004 006	Building A A1B1 Princ. Off. Clst				
2-009 007	Building A A2 Office Hall				
2-008 008	Building A A2A Office Restroom				
2-002 009	Building A A2B Office Storage				
2-011 010	Building A A2C Nurse Room				
2-016 011	Building A A2C1 Copy Room				
2-010 012	Building A A2C2 Nurse Office				
2-015 013	Building A Room A3				
2-014 014	Building A Room A4				
2-013 015	Building A A5 Staff Rm Entry				
2-017 016	Building A A5A Staff Room				
2-018 017	Building A A5A Staff Room				
2-023 018	Building A A6 Womens Staff RR				
2-022 019	Building A A7 Adult Restroom				
2-025 020	Building A Room A8				
2-024 021	Building A Room A8				
2-020 022	Building A Room A8				
2-019 023	Building A Room A8A Storage				
2-021 024	Building A Room A8B RR				
2-026 025	Building A Room A9				
2-027 026	Building A Room A9				
2-028 027	Building A Room A10				
2-029 028	Building A Room A10				
2-030 029	Building A Room A11				
2-031 030	Building A Room A11				
2-032 031	Building A Room A12				
2-033 032	Building A Room A12				
2-034 033	Building A Room A13				
2-035 034	Building A Room A13				
2-037 035	Building A A14 Custodial Closet				
2-036 036	Building A A15 Girls Restroom				
2-038 037	Building A A16 Boys Restroom				
2-044 079	Building B B1 Chair Storage				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-045 080	Building B B1A Sports Room				
2-043 081	Building B B2A Kitchen Office				
2-050 082	Building B B3 Stage				
2-049 083	Building B B3 Stage				
2-039 099	Building C C1 Boiler Room				
2-053 100	Building C Room C2				
2-052 101	Building C Room C2				
2-057 102	Building C Room C4 West				
2-056 103	Building C Room C4 West				
2-054 104	Building C Room C4 East				
2-051 105	Building C Room C4A Office				
2-058 106	Building C Room C5				
2-059 107	Building C Room C5				
2-061 108	Building C Room C6				
2-060 109	Building C Room C6				
2-062 110	Building C Room C7				
2-063 111	Building C Room C7				
2-065 112	Building C Room C8				
2-064 113	Building C Room C8				
2-066 114	Building C Room C9				
2-067 115	Building C Room C9				
2-253 142	Building D D1 Girls Restroom				
2-252 143	Building D D2 Custodial Closet				
2-254 144	Building D D3 Boys Restroom				
2-257 145	Building D D4 Custodian Office				
2-261 146	Building D Room D5				
2-260 147	Building D Room D5				
2-259 148	Building D Room D5A Office				
2-258 149	Building D Room D5B Storage				
2-262 150	Building D Room D6				
2-263 151	Building D Room D6				
2-264 152	Building D Room D6A Office				
2-265 153	Building D Room D6B Storage				
2-266 154	Building D Room D6B1 Storage				
2-269 155	Building D Room D7				
2-268 156	Building D Room D7				
2-267 157	Building D Room D7A Storage				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-270 158	Building D Room D8				
2-271 159	Building D Room D8				
2-273 160	Building D Room D9				
2-272 161	Building D Room D9				
2-274 162	Building D Room D10				
2-275 163	Building D Room D10				
2-256 190	Building E Room E1				
2-255 191	Building E Room E1				
2-277 198	Building F Room F1				
2-276 199	Building F Room F1				
2-283 204	Building H Room H1				
2-282 205	Building H Room H1				
Heat Detector - Restorable Spot					
2-003 038	Building A A2B Office Storage				
2-130 039	Building A A2B HVAC Closet				
2-132 040	Building A Room A8 HVAC Clst				
2-133 041	Building A Room A9 HVAC Clst				
2-134 042	Building A Room A10 HVAC Clst				
2-135 043	Building A Room A11 HVAC Clst				
2-136 044	Building A Room A12 HVAC Clst				
2-137 045	Building A Room A13 HVAC Clst				
2-138 046	Building A A15 Plumb Soffit				
2-139 047	Building A A16 Water Soffit				
2-040 084	Building B B2 Kitchen				
2-041 085	Building B B2 Kitchen				
2-042 086	Building B B2 Kitchen				
2-140 087	Building B B1 Attic Chair Storage				
2-141 116	Building C Room C3				
2-142 117	Building C Room C4 HVAC Clst				
2-152 118	Building C Rm C4 E. HVAC Clst				
2-143 119	Building C Room C5 HVAC Clst				
2-144 120	Building C Room C6 HVAC Clst				
2-145 121	Building C Room C7 HVAC Clst				
2-146 122	Building C Room C8 HVAC Clst				
2-147 123	Building C Room C9 HVAC Clst				
2-153 124	Building C Attic Room C2				
2-378 164	Building D Room D5 HVAC Clst				
2-379 165	Building D Room D6 HVAC Clst				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-381 166	Building D Room D7 HVAC Clst				
2-382 167	Building D Room D8 HVAC Clst				
2-383 168	Building D Room D9 HVAC Clst				
2-384 169	Building D Room D10 HVAC Clst				
2-376 170	Building D D1 & D3 Plumb Soffit				
2-380 171	Building D Attic Room D6B				
2-389 192	Building E E3 Maint. Shed				
2-389 193	Building E E3 Maint. Shed				
2-377 194	Building E Attic Room E1				
2-377 195	Building E Attic Room E1				
2-385 200	Building F Attic Room F1				
2-385 201	Building F Attic Room F1				
2-388 206	Building H Attic Room H1				
2-388 207	Building H Attic Room H1				
Smoke Detector - Projected Beam					
2-149 088	Building B B1 MP Room East				
2-151 089	Building B B1 MP Room West				
Mechanical, Electrosonic, or Pressure Waterflow Device					
2-159 090	Building B B1A Sports Room				

### Power Supplies

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Battery - Sealed Lead-acid					
	Building A A2B Office Storage - FACP				02/01/2019
	Building A A2B Office Storage - P.E. "Master"				04/01/2018
	Building A A2B Office Storage - P.E. "B"				04/01/2018
	Building C C1 Boiler Room - P.E. "C"				02/01/2019
	Building D D2 Custodial Closet - P.E. "D"				04/23/2018