

Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

PERSHING ELEMENTARY

9010 PERSHING AVE
ORANGEVALE, California 95662
United States

This site has been inspected and tested in compliance with applicable standards.

Completed
Tuesday, September 30, 2025

Test Session: 15 Sep 2025 15:14 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD
5320 HEMLOCK ST
SACRAMENTO, California
United States

TESTED BY

Riley Goyet
Western States Fire Protection-
Sacramento
188 Cirby Way
Roseville, CA 95678
United States



Inspection Summary

Building Information

PROPERTY	PERSHING ELEMENTARY	CONTACT
ADDRESS	9010 PERSHING AVE	PHONE
CITY/STATE	ORANGEVALE, California 95662	MOBILE
COUNTRY	United States	EMAIL

Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us

Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Alarm Notification Appliance	61	61(100%)	61(100%)	0(0%)
Initiating Device	161	161(100%)	160(99%)	1(1%)
Fire Control Panel	6	6(100%)	6(100%)	0(0%)

Certification

The equipment specified here in was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Tuesday, September 30, 2025

ACCEPTED BY 09/30/2025

Building Representative


TESTED BY 09/30/2025
Riley Goyet
Technician

Open Corrective Action & Solution Summary

The following 1 corrective action(s) remain open following the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
Smoke Detector - General	2-286 172	Multi-Purpose Bldg Stage Right Stairs
	Created By:	Riley Goyet
	Creation Date:	09/15/2025
	Corrective Action:	Taped
	Proposed Solution:	
	Manufacturer:	
	Model:	

Testing Details

Alarm Notification Appliance

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible	022	Admin Building Admin Reception	Manual	9/15/2025 3:15:54 PM
		Visual inspection	Passed (Manual)	
Audible	019	Admin Building East Exterior	Manual	9/15/2025 3:16:53 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	021	Admin Building Library	Manual	9/15/2025 3:16:37 PM
		Functional Inspection	Passed	
Visible	025	Admin Building Nurse Restroom	Manual	9/15/2025 3:15:49 PM
		Visual inspection	Passed (Manual)	
Visible	024	Admin Building Nurse Room	Manual	9/15/2025 3:15:51 PM
		Functional Inspection	Passed	
Visible	023	Admin Building Principals Office	Manual	9/15/2025 3:15:52 PM
		Visual inspection	Passed (Manual)	
Visible	026	Admin Building Speech Room	Manual	9/15/2025 3:15:45 PM
		Functional Inspection	Passed	
Visible	027	Admin Building Staff RR by Princ Off	Manual	9/15/2025 3:15:43 PM
		Visual inspection	Passed (Manual)	
Visible	028	Admin Building Staff RR by Work Rm	Manual	9/15/2025 3:15:42 PM
		Functional Inspection	Passed	
Audible And Visible	020	Admin Building Work Room	Manual	9/15/2025 3:16:39 PM
		Visual inspection	Passed (Manual)	
Visible	211	Discovery Club Boys Restroom	Manual	9/15/2025 3:15:22 PM
		Functional Inspection	Passed	
Audible And Visible	208	Discovery Club Classroom	Manual	9/15/2025 3:15:55 PM
		Visual inspection	Passed (Manual)	
Visible	210	Discovery Club Girls Restroom	Manual	9/15/2025 3:15:24 PM
		Functional Inspection	Passed	
Visible	209	Discovery Club Office	Manual	9/15/2025 3:15:25 PM
		Visual inspection	Passed (Manual)	
Audible	207	Discovery Club West Exterior	Manual	9/15/2025 3:16:40 PM
		Functional Inspection	Passed	
Audible	189	Multi-Purpose Bldg East Exterior	Manual	9/15/2025 3:16:41 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	192	Multi-Purpose Bldg Kitchen	Manual	9/15/2025 3:15:58 PM
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	195	Multi-Purpose Bldg Kitchen	Manual	9/15/2025 3:15:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	197	Multi-Purpose Bldg Kitchen Restroom	Manual	9/15/2025 3:15:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	196	Multi-Purpose Bldg Kitchen RR Entry	Manual	9/15/2025 3:15:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	191	Multi-Purpose Bldg MP Room	Manual	9/15/2025 3:16:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	190	Multi-Purpose Bldg MP Room	Manual	9/15/2025 3:16:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	193	Multi-Purpose Bldg Staff Lounge	Manual	9/15/2025 3:15:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	194	Multi-Purpose Bldg Stage	Manual	9/15/2025 3:15:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	164	Portables Classroom 19	Manual	9/15/2025 3:16:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	165	Portables Classroom 20	Manual	9/15/2025 3:16:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	166	Portables Classroom 21	Manual	9/15/2025 3:16:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	167	Portables Classroom 22	Manual	9/15/2025 3:16:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	168	Portables Classroom 23	Manual	9/15/2025 3:16:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	049	Rooms 1 2 Bldg Classroom 1	Manual	9/15/2025 3:16:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	051	Rooms 1 2 Bldg Classroom 1 2 Hall	Manual	9/15/2025 3:15:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	052	Rooms 1 2 Bldg Classroom 1 RR	Manual	9/15/2025 3:15:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	050	Rooms 1 2 Bldg Classroom 2	Manual	9/15/2025 3:16:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	053	Rooms 1 2 Bldg Classroom 2 RR	Manual	9/15/2025 3:15:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	048	Rooms 1 2 Bldg East Exterior	Manual	9/15/2025 3:16:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible	140	Rooms 11-18 Bldg Boys RR Near Rm 15	Manual	9/15/2025 3:15:32 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	131	Rooms 11-18 Bldg Classroom 11	Manual	9/15/2025 3:16:21 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	132	Rooms 11-18 Bldg Classroom 12	Manual	9/15/2025 3:16:19 PM
		Functional Inspection	Passed	
Audible And Visible	133	Rooms 11-18 Bldg Classroom 13	Manual	9/15/2025 3:16:18 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	134	Rooms 11-18 Bldg Classroom 14	Manual	9/15/2025 3:16:16 PM
		Functional Inspection	Passed	
Audible And Visible	135	Rooms 11-18 Bldg Classroom 15	Manual	9/15/2025 3:16:14 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	136	Rooms 11-18 Bldg Classroom 16	Manual	9/15/2025 3:16:13 PM
		Functional Inspection	Passed	
Audible And Visible	137	Rooms 11-18 Bldg Classroom 17	Manual	9/15/2025 3:16:11 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	138	Rooms 11-18 Bldg Classroom 18	Manual	9/15/2025 3:16:10 PM
		Functional Inspection	Passed	
Audible	129	Rooms 11-18 Bldg East Exterior	Manual	9/15/2025 3:16:44 PM
		Visual inspection	Passed (Manual)	
Visible	139	Rooms 11-18 Bldg Girls RR Near Rm 11	Manual	9/15/2025 3:15:34 PM
		Functional Inspection	Passed	
Audible	128	Rooms 11-18 Bldg North Exterior	Manual	9/15/2025 3:16:46 PM
		Visual inspection	Passed (Manual)	
Audible	130	Rooms 11-18 Bldg South Exterior	Manual	9/15/2025 3:16:43 PM
		Functional Inspection	Passed	
Visible	096	Rooms 3-10 Bldg Boys RR Near Rm 7	Manual	9/15/2025 3:15:35 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	094	Rooms 3-10 Bldg Classroom 10	Manual	9/15/2025 3:16:22 PM
		Functional Inspection	Passed	
Audible And Visible	087	Rooms 3-10 Bldg Classroom 3	Manual	9/15/2025 3:16:33 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	088	Rooms 3-10 Bldg Classroom 4	Manual	9/15/2025 3:16:31 PM
		Functional Inspection	Passed	
Audible And Visible	089	Rooms 3-10 Bldg Classroom 5	Manual	9/15/2025 3:16:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	090	Rooms 3-10 Bldg Classroom 6	Manual	9/15/2025 3:16:29 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	091	Rooms 3-10 Bldg Classroom 7	Manual	9/15/2025 3:16:27 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	092	Rooms 3-10 Bldg Classroom 8	Manual	9/15/2025 3:16:25 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	093	Rooms 3-10 Bldg Classroom 9	Manual	9/15/2025 3:16:24 PM
		Visual inspection	Passed (Manual)	
Audible	085	Rooms 3-10 Bldg East Exterior	Manual	9/15/2025 3:16:48 PM
		Visual inspection	Passed (Manual)	
Visible	095	Rooms 3-10 Bldg Girls RR Near Rm 3	Manual	9/15/2025 3:15:36 PM
		Visual inspection	Passed (Manual)	
Audible	084	Rooms 3-10 Bldg North Exterior	Manual	9/15/2025 3:16:50 PM
		Visual inspection	Passed (Manual)	
Audible	086	Rooms 3-10 Bldg South Exterior	Manual	9/15/2025 3:16:47 PM
		Visual inspection	Passed (Manual)	

Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Remote Annunciator	001	Admin Building Admin Reception	Manual	9/15/2025 5:42:07 PM
		Visual inspection	Passed (Manual)	
NAC Power Extender Panel	030	Admin Building HVAC Strg Near RR	Manual	9/15/2025 5:42:15 PM
		Visual inspection	Passed (Manual)	
NAC Power Extender Panel	029	Admin Building HVAC Strg Near RR	Manual	9/15/2025 5:42:17 PM
		Visual inspection	Passed (Manual)	
NAC Power Extender Panel	141	Rooms 11-18 Bldg Storage Near Rm 11	Manual	9/15/2025 5:42:09 PM
		Visual inspection	Passed (Manual)	
NAC Power Extender Panel	098	Rooms 3-10 Bldg Boiler Room	Manual	9/15/2025 5:42:11 PM
		Visual inspection	Passed (Manual)	
NAC Power Extender Panel	097	Rooms 3-10 Bldg Boiler Room	Manual	9/15/2025 5:42:13 PM
		Visual inspection	Passed (Manual)	

Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Manual Pull Station	2-381 002	Admin Building Admin Reception	Manual	9/15/2025 5:43:40 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-279 003	Admin Building Admin Reception	Manual	9/15/2025 5:45:12 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-376 018	Admin Building Attic Library	Manual	9/15/2025 5:42:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-272 017	Admin Building HVAC Strg Near RR	Manual	9/15/2025 5:44:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-269 013	Admin Building Library	Manual	9/15/2025 5:45:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-267 014	Admin Building Library	Manual	9/15/2025 5:45:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-268 016	Admin Building Library	Manual	9/15/2025 5:45:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-266 015	Admin Building Library	Manual	9/15/2025 5:45:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-274 008	Admin Building Nurse Restroom	Manual	9/15/2025 5:45:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-280 007	Admin Building Nurse Room	Manual	9/15/2025 5:45:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-276 004	Admin Building Principals Office	Manual	9/15/2025 5:45:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-271 011	Admin Building Resource Room	Manual	9/15/2025 5:45:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-270 012	Admin Building Speech Room	Manual	9/15/2025 5:45:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-278 009	Admin Building Staff RR by Princ Off	Manual	9/15/2025 5:45:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-277 010	Admin Building Staff RR by Work Rm	Manual	9/15/2025 5:45:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-275 005	Admin Building Work Room	Manual	9/15/2025 5:45:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-273 006	Admin Building Work Room Storage	Manual	9/15/2025 5:45:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-300	Discovery Club	Manual	9/15/2025 5:41:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-301	Discovery Club	Manual	9/15/2025 5:41:51 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-302	Discovery Club	Manual	9/15/2025 5:41:53 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-303	Discovery Club	Manual	9/15/2025 5:41:54 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-305	Discovery Club	Manual	9/15/2025 5:42:01 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-306	Discovery Club	Manual	9/15/2025 5:42:03 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-304	Discovery Club RR	Manual	9/15/2025 5:42:04 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - Projected Beam	2-385 188	Multi-Purpose Bldg Beam Detector Left	Manual	9/15/2025 5:43:49 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - Projected Beam	2-383 187	Multi-Purpose Bldg Beam Detector Right	Manual	9/15/2025 5:43:47 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-298 185	Multi-Purpose Bldg Kitchen	Manual	9/15/2025 5:43:03 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-297 184	Multi-Purpose Bldg Kitchen	Manual	9/15/2025 5:43:05 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-296 182	Multi-Purpose Bldg Kitchen Office	Manual	9/15/2025 6:44:49 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-294 181	Multi-Purpose Bldg Kitchen Restroom	Manual	9/15/2025 5:45:01 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-295 180	Multi-Purpose Bldg Kitchen RR Entry	Manual	9/15/2025 5:44:59 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Manual Pull Station	2-154 169	Multi-Purpose Bldg Northwest Exit	Manual	9/15/2025 5:43:39 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Manual Pull Station	2-156 171	Multi-Purpose Bldg Southeast Exit	Manual	9/15/2025 5:43:37 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Manual Pull Station	2-155 170	Multi-Purpose Bldg Southwest Exit	Manual	9/15/2025 5:43:42 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-299 183	Multi-Purpose Bldg Staff Lounge	Manual	9/15/2025 5:45:02 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-290 176	Multi-Purpose Bldg Stage	Manual	9/15/2025 5:44:46 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-289 175	Multi-Purpose Bldg Stage	Manual	9/15/2025 5:44:49 PM
		Functional Inspection	Passed	
Smoke Detector - General	2-291 177	Multi-Purpose Bldg Stage Left HVAC	Manual	9/15/2025 6:44:15 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-293 178	Multi-Purpose Bldg Stage Left Stairs	Manual	9/15/2025 5:44:56 PM
		Functional Inspection	Passed	
Smoke Detector - General	2-292 179	Multi-Purpose Bldg Stage Left Storage	Manual	9/15/2025 5:44:58 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-288 174	Multi-Purpose Bldg Stage Right HVAC	Manual	9/15/2025 6:44:14 PM
		Functional Inspection	Passed	
Smoke Detector - General	2-287 173	Multi-Purpose Bldg Stage Right Storage	Manual	9/15/2025 5:44:48 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	2-377 186	Multi-Purpose Bldg Wtr Htr O/S Kitchen	Manual	9/15/2025 5:42:37 PM
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-150 155	Portables Attic Classroom 19	Manual	9/15/2025 6:45:57 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	2-150 154	Portables Attic Classroom 19	Manual	9/15/2025 6:45:58 PM
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-149 157	Portables Attic Classroom 20	Manual	9/15/2025 5:43:17 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	2-149 156	Portables Attic Classroom 20	Manual	9/15/2025 5:43:18 PM
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-148 159	Portables Attic Classroom 21	Manual	9/15/2025 5:43:24 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	2-148 158	Portables Attic Classroom 21	Manual	9/15/2025 5:43:26 PM
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-147 161	Portables Attic Classroom 22	Manual	9/15/2025 5:43:31 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	2-147 160	Portables Attic Classroom 22	Manual	9/15/2025 5:43:32 PM
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-147 160	Portables Attic Classroom 22	Manual	9/15/2025 5:43:32 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	2-147 160	Portables Attic Classroom 22	Manual	9/15/2025 5:43:32 PM
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-146 163	Portables Attic Classroom 23	Manual	9/15/2025 5:43:34 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-146 162	Portables Attic Classroom 23	Manual	9/15/2025 5:43:36 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-161	Portables Attic Classroom 24	Manual	9/15/2025 6:45:47 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-162	Portables Attic Classroom 25	Manual	9/15/2025 6:45:46 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-163	Portables Attic Classroom 26	Manual	9/15/2025 5:43:46 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-164	Portables Attic Classroom 27	Manual	9/15/2025 5:43:44 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-160	Portables Attic RR	Manual	9/15/2025 5:42:36 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-052 144	Portables Classroom 19	Manual	9/15/2025 6:45:34 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-055 143	Portables Classroom 19	Manual	9/15/2025 6:45:36 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-054 142	Portables Classroom 19	Manual	9/15/2025 6:45:37 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-053 145	Portables Classroom 19	Manual	9/15/2025 6:45:38 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-050 146	Portables Classroom 20	Manual	9/15/2025 6:45:31 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-051 147	Portables Classroom 20	Manual	9/15/2025 6:45:32 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-048 148	Portables Classroom 21	Manual	9/15/2025 6:45:28 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-049 149	Portables Classroom 21	Manual	9/15/2025 6:45:30 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-046 150	Portables Classroom 22	Manual	9/15/2025 6:45:22 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-047 151	Portables Classroom 22	Manual	9/15/2025 6:45:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-044 152	Portables Classroom 23	Manual	9/15/2025 5:43:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-045 153	Portables Classroom 23	Manual	9/15/2025 5:43:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-065	Portables Classroom 24	Manual	9/15/2025 5:44:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-066	Portables Classroom 24	Manual	9/15/2025 5:44:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-067	Portables Classroom 25	Manual	9/15/2025 6:45:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-068	Portables Classroom 25	Manual	9/15/2025 6:45:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-070	Portables Classroom 26	Manual	9/15/2025 6:44:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-069	Portables Classroom 26	Manual	9/15/2025 6:44:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-072	Portables Classroom 27	Manual	9/15/2025 6:44:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-071	Portables Classroom 27	Manual	9/15/2025 6:44:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2.165	Portables Classroom 28	Manual	9/15/2025 5:42:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.080	Portables Classroom 28	Manual	9/15/2025 5:41:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.081	Portables Classroom 28	Manual	9/15/2025 5:41:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-061	Portables Men's RR	Manual	9/15/2025 5:44:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-062	Portables Unisex RR	Manual	9/15/2025 6:45:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-063	Portables Women's RR	Manual	9/15/2025 5:44:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-380 046	Rooms 1 2 Bldg Attic Rm 1 2 Soffit	Manual	9/15/2025 5:42:39 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-380 045	Rooms 1 2 Bldg Attic Rm 1 2 Soffit	Manual	9/15/2025 5:42:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-380 044	Rooms 1 2 Bldg Attic Rm 1 2 Soffit	Manual	9/15/2025 6:45:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-255 036	Rooms 1 2 Bldg Classrm 1 Hall Strg	Manual	9/15/2025 6:45:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-257 031	Rooms 1 2 Bldg Classroom 1	Manual	9/15/2025 5:45:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-258 034	Rooms 1 2 Bldg Classroom 1	Manual	9/15/2025 5:45:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-260 033	Rooms 1 2 Bldg Classroom 1	Manual	9/15/2025 5:45:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-259 032	Rooms 1 2 Bldg Classroom 1	Manual	9/15/2025 5:45:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-254 035	Rooms 1 2 Bldg Classroom 1 2 Hall	Manual	9/15/2025 5:45:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-256 037	Rooms 1 2 Bldg Classroom 1 RR	Manual	9/15/2025 5:45:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-263 039	Rooms 1 2 Bldg Classroom 2	Manual	9/15/2025 5:45:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-264 040	Rooms 1 2 Bldg Classroom 2	Manual	9/15/2025 5:45:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-262 041	Rooms 1 2 Bldg Classroom 2	Manual	9/15/2025 5:45:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-261 042	Rooms 1 2 Bldg Classroom 2	Manual	9/15/2025 5:45:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-252 043	Rooms 1 2 Bldg Classroom 2 RR	Manual	9/15/2025 5:45:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-253 038	Rooms 1 2 Bldg Cust Strg Near Rm 1	Manual	9/15/2025 5:45:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-379 047	Rooms 1 2 Bldg Duct Rm 1 2 Strg	Manual	9/15/2025 5:42:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-138 120	Rooms 11-18 Bldg Attic Classroom 11	Manual	9/15/2025 6:45:55 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-139 121	Rooms 11-18 Bldg Attic Classroom 12	Manual	9/15/2025 6:45:53 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-140 122	Rooms 11-18 Bldg Attic Classroom 13	Manual	9/15/2025 6:45:52 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-141 123	Rooms 11-18 Bldg Attic Classroom 14	Manual	9/15/2025 6:45:50 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-145 124	Rooms 11-18 Bldg Attic Classroom 15	Manual	9/15/2025 5:43:12 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-144 125	Rooms 11-18 Bldg Attic Classroom 16	Manual	9/15/2025 5:43:14 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-143 126	Rooms 11-18 Bldg Attic Classroom 17	Manual	9/15/2025 6:45:48 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-142 127	Rooms 11-18 Bldg Attic Classroom 18	Manual	9/15/2025 5:43:15 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-041 119	Rooms 11-18 Bldg Boys RR Near Rm 15	Manual	9/15/2025 6:45:21 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-024 100	Rooms 11-18 Bldg Classroom 11	Manual	9/15/2025 6:45:18 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-025 099	Rooms 11-18 Bldg Classroom 11	Manual	9/15/2025 6:45:19 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-026 101	Rooms 11-18 Bldg Classroom 12	Manual	9/15/2025 6:45:11 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-027 102	Rooms 11-18 Bldg Classroom 12	Manual	9/15/2025 6:45:13 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-028 103	Rooms 11-18 Bldg Classroom 13	Manual	9/15/2025 6:45:08 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-029 104	Rooms 11-18 Bldg Classroom 13	Manual	9/15/2025 6:45:10 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-030 105	Rooms 11-18 Bldg Classroom 14	Manual	9/15/2025 6:45:05 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-031 106	Rooms 11-18 Bldg Classroom 14	Manual	9/15/2025 6:45:07 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-039 108	Rooms 11-18 Bldg Classroom 15	Manual	9/15/2025 6:44:34 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-038 107	Rooms 11-18 Bldg Classroom 15	Manual	9/15/2025 6:44:36 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-036 109	Rooms 11-18 Bldg Classroom 16	Manual	9/15/2025 6:44:27 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-037 110	Rooms 11-18 Bldg Classroom 16	Manual	9/15/2025 6:44:33 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-034 111	Rooms 11-18 Bldg Classroom 17	Manual	9/15/2025 6:44:26 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-035 112	Rooms 11-18 Bldg Classroom 17	Manual	9/15/2025 6:44:31 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-033 114	Rooms 11-18 Bldg Classroom 18	Manual	9/15/2025 6:44:28 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-032 113	Rooms 11-18 Bldg Classroom 18	Manual	9/15/2025 6:44:30 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-040 117	Rooms 11-18 Bldg Cust Off Near Rm 15	Manual	9/15/2025 6:45:27 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-023 115	Rooms 11-18 Bldg Girls RR Near Rm 11	Manual	9/15/2025 6:45:16 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-022 116	Rooms 11-18 Bldg Storage Near Rm 11	Manual	9/15/2025 6:45:15 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-058 118	Rooms 11-18 Bldg Storage Near Rm 15	Manual	9/15/2025 6:45:25 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-134 083	Rooms 3-10 Bldg Attic Classroom 10	Manual	9/15/2025 5:42:49 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-130 076	Rooms 3-10 Bldg Attic Classroom 3	Manual	9/15/2025 4:00:20 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-131 077	Rooms 3-10 Bldg Attic Classroom 4	Manual	9/15/2025 5:42:42 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-132 078	Rooms 3-10 Bldg Attic Classroom 5	Manual	9/15/2025 5:42:45 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-133 079	Rooms 3-10 Bldg Attic Classroom 6	Manual	9/15/2025 5:42:47 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-137 080	Rooms 3-10 Bldg Attic Classroom 7	Manual	9/15/2025 5:42:57 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-136 081	Rooms 3-10 Bldg Attic Classroom 8	Manual	9/15/2025 5:42:54 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-135 082	Rooms 3-10 Bldg Attic Classroom 9	Manual	9/15/2025 5:42:52 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-004 071	Rooms 3-10 Bldg Boiler Room	Manual	9/15/2025 6:44:23 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-056 074	Rooms 3-10 Bldg Boys RR Near Rm 7	Manual	9/15/2025 6:44:54 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-014 068	Rooms 3-10 Bldg Classroom 10	Manual	9/15/2025 6:45:02 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-015 069	Rooms 3-10 Bldg Classroom 10	Manual	9/15/2025 6:45:04 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-006 055	Rooms 3-10 Bldg Classroom 3	Manual	9/15/2025 6:44:39 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-007 054	Rooms 3-10 Bldg Classroom 3	Manual	9/15/2025 6:44:40 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-009 056	Rooms 3-10 Bldg Classroom 4	Manual	9/15/2025 4:00:26 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-008 057	Rooms 3-10 Bldg Classroom 4	Manual	9/15/2025 6:44:42 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-011 058	Rooms 3-10 Bldg Classroom 5	Manual	9/15/2025 6:44:43 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-010 059	Rooms 3-10 Bldg Classroom 5	Manual	9/15/2025 6:44:44 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-012 061	Rooms 3-10 Bldg Classroom 6	Manual	9/15/2025 6:44:46 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-013 060	Rooms 3-10 Bldg Classroom 6	Manual	9/15/2025 6:44:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-020 063	Rooms 3-10 Bldg Classroom 7	Manual	9/15/2025 6:44:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-021 062	Rooms 3-10 Bldg Classroom 7	Manual	9/15/2025 6:44:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-018 065	Rooms 3-10 Bldg Classroom 8	Manual	9/15/2025 6:44:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-019 064	Rooms 3-10 Bldg Classroom 8	Manual	9/15/2025 6:44:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-016 066	Rooms 3-10 Bldg Classroom 9	Manual	9/15/2025 6:45:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-017 067	Rooms 3-10 Bldg Classroom 9	Manual	9/15/2025 6:45:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-003 075	Rooms 3-10 Bldg FACP Headend	Manual	9/15/2025 5:42:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-002 072	Rooms 3-10 Bldg FACP Headend	Manual	9/15/2025 6:44:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-005 070	Rooms 3-10 Bldg Girls RR Near Rm 3	Manual	9/15/2025 6:44:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-057 073	Rooms 3-10 Bldg Storage Near Rm 7	Manual	9/15/2025 6:44:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Failed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-286 172	Multi-Purpose Bldg Stage Right Stairs	Manual	9/15/2025 4:28:27 PM
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	

Device/Equipment details

Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Audible					
019	Admin Building East Exterior				
048	Rooms 1 2 Bldg East Exterior				
084	Rooms 3-10 Bldg North Exterior				
085	Rooms 3-10 Bldg East Exterior				
086	Rooms 3-10 Bldg South Exterior				
128	Rooms 11-18 Bldg North Exterior				
129	Rooms 11-18 Bldg East Exterior				
130	Rooms 11-18 Bldg South Exterior				
189	Multi-Purpose Bldg East Exterior				
207	Discovery Club West Exterior				
Audible And Visible					
020	Admin Building Work Room				
021	Admin Building Library				
049	Rooms 1 2 Bldg Classroom 1				
050	Rooms 1 2 Bldg Classroom 2				
087	Rooms 3-10 Bldg Classroom 3				
088	Rooms 3-10 Bldg Classroom 4				
089	Rooms 3-10 Bldg Classroom 5				
090	Rooms 3-10 Bldg Classroom 6				
091	Rooms 3-10 Bldg Classroom 7				
092	Rooms 3-10 Bldg Classroom 8				
093	Rooms 3-10 Bldg Classroom 9				
094	Rooms 3-10 Bldg Classroom 10				
131	Rooms 11-18 Bldg Classroom 11				
132	Rooms 11-18 Bldg Classroom 12				
133	Rooms 11-18 Bldg Classroom 13				
134	Rooms 11-18 Bldg Classroom 14				
135	Rooms 11-18 Bldg Classroom 15				
136	Rooms 11-18 Bldg Classroom 16				
137	Rooms 11-18 Bldg Classroom 17				
138	Rooms 11-18 Bldg Classroom 18				
164	Portables Classroom 19				
165	Portables Classroom 20				
166	Portables Classroom 21				
167	Portables Classroom 22				
168	Portables Classroom 23				
190	Multi-Purpose Bldg MP Room				
191	Multi-Purpose Bldg MP Room				
192	Multi-Purpose Bldg Kitchen				
193	Multi-Purpose Bldg Staff Lounge				
208	Discovery Club Classroom				
Visible					
022	Admin Building Admin Reception				
023	Admin Building Principals Office				
024	Admin Building Nurse Room				
025	Admin Building Nurse Restroom				
026	Admin Building Speech Room				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
027	Admin Building Staff RR by Princ Off				
028	Admin Building Staff RR by Work Rm				
051	Rooms 1 2 Bldg Classroom 1 2 Hall				
052	Rooms 1 2 Bldg Classroom 1 RR				
053	Rooms 1 2 Bldg Classroom 2 RR				
095	Rooms 3-10 Bldg Girls RR Near Rm 3				
096	Rooms 3-10 Bldg Boys RR Near Rm 7				
139	Rooms 11-18 Bldg Girls RR Near Rm 11				
140	Rooms 11-18 Bldg Boys RR Near Rm 15				
194	Multi-Purpose Bldg Stage				
195	Multi-Purpose Bldg Kitchen				
196	Multi-Purpose Bldg Kitchen RR Entry				
197	Multi-Purpose Bldg Kitchen Restroom				
209	Discovery Club Office				
210	Discovery Club Girls Restroom				
211	Discovery Club Boys Restroom				

Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Remote Annunciator					
001	Admin Building Admin Reception				
NAC Power Extender Panel					
029	Admin Building HVAC Strg Near RR				
030	Admin Building HVAC Strg Near RR				
097	Rooms 3-10 Bldg Boiler Room				
098	Rooms 3-10 Bldg Boiler Room				
141	Rooms 11-18 Bldg Storage Near Rm 11				

Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Manual Pull Station					
2-381 002	Admin Building Admin Reception				
2-154 169	Multi-Purpose Bldg Northwest Exit				
2-155 170	Multi-Purpose Bldg Southwest Exit				
2-156 171	Multi-Purpose Bldg Southeast Exit				
Smoke Detector - General					
2-279 003	Admin Building Admin Reception				
2-276 004	Admin Building Principals Office				
2-275 005	Admin Building Work Room				
2-273 006	Admin Building Work Room Storage				
2-280 007	Admin Building Nurse Room				
2-274 008	Admin Building Nurse Restroom				
2-278 009	Admin Building Staff RR by Princ Off				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-277 010	Admin Building Staff RR by Work Rm				
2-271 011	Admin Building Resource Room				
2-270 012	Admin Building Speech Room				
2-269 013	Admin Building Library				
2-267 014	Admin Building Library				
2-266 015	Admin Building Library				
2-268 016	Admin Building Library				
2-272 017	Admin Building HVAC Strg Near RR				
2-257 031	Rooms 1 2 Bldg Classroom 1				
2-259 032	Rooms 1 2 Bldg Classroom 1				
2-260 033	Rooms 1 2 Bldg Classroom 1				
2-258 034	Rooms 1 2 Bldg Classroom 1				
2-254 035	Rooms 1 2 Bldg Classroom 1 2 Hall				
2-255 036	Rooms 1 2 Bldg Classrm 1 Hall Strg				
2-256 037	Rooms 1 2 Bldg Classroom 1 RR				
2-253 038	Rooms 1 2 Bldg Cust Strg Near Rm 1				
2-263 039	Rooms 1 2 Bldg Classroom 2				
2-264 040	Rooms 1 2 Bldg Classroom 2				
2-262 041	Rooms 1 2 Bldg Classroom 2				
2-261 042	Rooms 1 2 Bldg Classroom 2				
2-252 043	Rooms 1 2 Bldg Classroom 2 RR				
2-007 054	Rooms 3-10 Bldg Classroom 3				
2-006 055	Rooms 3-10 Bldg Classroom 3				
2-009 056	Rooms 3-10 Bldg Classroom 4				
2-008 057	Rooms 3-10 Bldg Classroom 4				
2-011 058	Rooms 3-10 Bldg Classroom 5				
2-010 059	Rooms 3-10 Bldg Classroom 5				
2-013 060	Rooms 3-10 Bldg Classroom 6				
2-012 061	Rooms 3-10 Bldg Classroom 6				
2-021 062	Rooms 3-10 Bldg Classroom 7				
2-020 063	Rooms 3-10 Bldg Classroom 7				
2-019 064	Rooms 3-10 Bldg Classroom 8				
2-018 065	Rooms 3-10 Bldg Classroom 8				
2-016 066	Rooms 3-10 Bldg Classroom 9				
2-017 067	Rooms 3-10 Bldg Classroom 9				
2-014 068	Rooms 3-10 Bldg Classroom 10				
2-015 069	Rooms 3-10 Bldg Classroom 10				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-005 070	Rooms 3-10 Bldg Girls RR Near Rm 3				
2-004 071	Rooms 3-10 Bldg Boiler Room				
2-002 072	Rooms 3-10 Bldg FACP Headend				
2-057 073	Rooms 3-10 Bldg Storage Near Rm 7				
2-056 074	Rooms 3-10 Bldg Boys RR Near Rm 7				
2-025 099	Rooms 11-18 Bldg Classroom 11				
2-024 100	Rooms 11-18 Bldg Classroom 11				
2-026 101	Rooms 11-18 Bldg Classroom 12				
2-027 102	Rooms 11-18 Bldg Classroom 12				
2-028 103	Rooms 11-18 Bldg Classroom 13				
2-029 104	Rooms 11-18 Bldg Classroom 13				
2-030 105	Rooms 11-18 Bldg Classroom 14				
2-031 106	Rooms 11-18 Bldg Classroom 14				
2-038 107	Rooms 11-18 Bldg Classroom 15				
2-039 108	Rooms 11-18 Bldg Classroom 15				
2-036 109	Rooms 11-18 Bldg Classroom 16				
2-037 110	Rooms 11-18 Bldg Classroom 16				
2-034 111	Rooms 11-18 Bldg Classroom 17				
2-035 112	Rooms 11-18 Bldg Classroom 17				
2-032 113	Rooms 11-18 Bldg Classroom 18				
2-033 114	Rooms 11-18 Bldg Classroom 18				
2-023 115	Rooms 11-18 Bldg Girls RR Near Rm 11				
2-022 116	Rooms 11-18 Bldg Storage Near Rm 11				
2-040 117	Rooms 11-18 Bldg Cust Off Near Rm 15				
2-058 118	Rooms 11-18 Bldg Storage Near Rm 15				
2-041 119	Rooms 11-18 Bldg Boys RR Near Rm 15				
2-054 142	Portables Classroom 19				
2-055 143	Portables Classroom 19				
2-052 144	Portables Classroom 19				
2-053 145	Portables Classroom 19				
2-050 146	Portables Classroom 20				
2-051 147	Portables Classroom 20				
2-048 148	Portables Classroom 21				
2-049 149	Portables Classroom 21				
2-046 150	Portables Classroom 22				
2-047 151	Portables Classroom 22				
2-044 152	Portables Classroom 23				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-045 153	Portables Classroom 23				
2-286 172	Multi-Purpose Bldg Stage Right Stairs				
2-287 173	Multi-Purpose Bldg Stage Right Storage				
2-288 174	Multi-Purpose Bldg Stage Right HVAC				
2-289 175	Multi-Purpose Bldg Stage				
2-290 176	Multi-Purpose Bldg Stage				
2-291 177	Multi-Purpose Bldg Stage Left HVAC				
2-293 178	Multi-Purpose Bldg Stage Left Stairs				
2-292 179	Multi-Purpose Bldg Stage Left Storage				
2-295 180	Multi-Purpose Bldg Kitchen RR Entry				
2-294 181	Multi-Purpose Bldg Kitchen Restroom				
2-296 182	Multi-Purpose Bldg Kitchen Office				
2-299 183	Multi-Purpose Bldg Staff Lounge				
2-071	Portables Classroom 27				
2-072	Portables Classroom 27				
2-070	Portables Classroom 26				12/12/2018
2-069	Portables Classroom 26				12/12/2018
2-068	Portables Classroom 25				
2-067	Portables Classroom 25				12/12/2018
2-066	Portables Classroom 24				
2-065	Portables Classroom 24				
2-063	Portables Women's RR				
2-062	Portables Unisex RR				
2-061	Portables Men's RR				
2.080	Portables Classroom 28				
2.081	Portables Classroom 28				
2-300	Discovery Club				
2-303	Discovery Club				
2-302	Discovery Club				
2-301	Discovery Club				
2-304	Discovery Club RR				
2-305	Discovery Club				
2-306	Discovery Club				
Heat Detector - Restorable Spot					
2-376 018	Admin Building Attic Library				
2-380 044	Rooms 1 2 Bldg Attic Rm 1 2 Soffit				
2-380 045	Rooms 1 2 Bldg Attic Rm 1 2 Soffit				
2-380 046	Rooms 1 2 Bldg Attic Rm 1 2 Soffit				
2-003 075	Rooms 3-10 Bldg FACP Headend				
2-130 076	Rooms 3-10 Bldg Attic Classroom 3				
2-131 077	Rooms 3-10 Bldg Attic Classroom 4				
2-132 078	Rooms 3-10 Bldg Attic Classroom 5				
2-133 079	Rooms 3-10 Bldg Attic Classroom 6				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-137 080	Rooms 3-10 Bldg Attic Classroom 7				
2-136 081	Rooms 3-10 Bldg Attic Classroom 8				
2-135 082	Rooms 3-10 Bldg Attic Classroom 9				
2-134 083	Rooms 3-10 Bldg Attic Classroom 10				
2-138 120	Rooms 11-18 Bldg Attic Classroom 11				
2-139 121	Rooms 11-18 Bldg Attic Classroom 12				
2-140 122	Rooms 11-18 Bldg Attic Classroom 13				
2-141 123	Rooms 11-18 Bldg Attic Classroom 14				
2-145 124	Rooms 11-18 Bldg Attic Classroom 15				
2-144 125	Rooms 11-18 Bldg Attic Classroom 16				
2-143 126	Rooms 11-18 Bldg Attic Classroom 17				
2-142 127	Rooms 11-18 Bldg Attic Classroom 18				
2-150 154	Portables Attic Classroom 19				
2-150 155	Portables Attic Classroom 19				
2-149 156	Portables Attic Classroom 20				
2-149 157	Portables Attic Classroom 20				
2-148 158	Portables Attic Classroom 21				
2-148 159	Portables Attic Classroom 21				
2-147 160	Portables Attic Classroom 22				
2-147 161	Portables Attic Classroom 22				
2-146 162	Portables Attic Classroom 23				
2-146 163	Portables Attic Classroom 23				
2-297 184	Multi-Purpose Bldg Kitchen				
2-298 185	Multi-Purpose Bldg Kitchen				
2-377 186	Multi-Purpose Bldg Wtr Htr O/S Kitchen				
2-164	Portables Attic Classroom 27				
2-163	Portables Attic Classroom 26				
2-162	Portables Attic Classroom 25				12/12/2018
2-161	Portables Attic Classroom 24				
2-160	Portables Attic RR				
2.165	Portables Classroom 28				
Smoke Detector - Duct					
2-379 047	Rooms 1 2 Bldg Duct Rm 1 2 Strg				
Smoke Detector - Projected Beam					
2-383 187	Multi-Purpose Bldg Beam Detector Right				
2-385 188	Multi-Purpose Bldg Beam Detector Left				