

Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

TRAJAN ELEMENTARY

6601 TRAJAN DR
ORANGEVALE, California
United States

This site has been inspected and tested in compliance with applicable standards.

Completed
Tuesday, September 30, 2025

Test Session:22 Sep 2025 17:51 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD
5320 HEMLOCK ST
SACRAMENTO, California
United States

TESTED BY

Riley Goyet
Western States Fire Protection-
Sacramento
188 Cirby Way
Roseville, CA 95678
United States



Inspection Summary

Building Information

PROPERTY	TRAJAN ELEMENTARY	CONTACT
ADDRESS	6601 TRAJAN DR	PHONE
CITY/STATE	ORANGEVALE, California	MOBILE
COUNTRY	United States	EMAIL

Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us

Testing Summary


EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Alarm Notification Appliance	65	65(100%)	65(100%)	0(0%)
Power Supplies	7	7(100%)	7(100%)	0(0%)
Fire Control Panel	8	8(100%)	8(100%)	0(0%)
Initiating Device	177	177(100%)	177(100%)	0(0%)

Certification

The equipment specified here in was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Tuesday, September 30, 2025

ACCEPTED BY 09/30/2025

Building Representative


TESTED BY 09/30/2025
Riley Goyet
Technician

System Details

Control Units

ADDRESS/ SCAN ADDRESS		DESCRIPTION	A Wing MP Room A2B Storage
MANUFACTURER	EST	S/W VERSION	
MODEL	3	LAST UPDATE	
SERIAL NUMBER		S/W LOCATION	
INSTALL DATE			

Secondary Power

TYPE	Battery - Sealed Lead-acid	DESCRIPTION	A Wing MP Room A2B Storage
ADDRESS/ SCAN ADDRESS		NOMINAL VOLTAGE	12
Load Voltage		Amp Hours	55
Standby Hours		Alarm Minutes	
Battery Location		Charger Voltage	
TYPE	Battery - Sealed Lead-acid	DESCRIPTION	A Wing MP Room A2B Storage - P.E. "B"
ADDRESS/ SCAN ADDRESS		NOMINAL VOLTAGE	12
Load Voltage		Amp Hours	8
Standby Hours		Alarm Minutes	
Battery Location		Charger Voltage	
TYPE	Battery - Sealed Lead-acid	DESCRIPTION	A Wing MP Room A2B Storage - P.E. "Master"
ADDRESS/ SCAN ADDRESS		NOMINAL VOLTAGE	12
Load Voltage		Amp Hours	8
Standby Hours		Alarm Minutes	
Battery Location		Charger Voltage	
TYPE	Battery - Sealed Lead-acid	DESCRIPTION	C Wing Custodial Closet C3 - P.E. "C"
ADDRESS/ SCAN ADDRESS		NOMINAL VOLTAGE	12
Load Voltage		Amp Hours	8
Standby Hours		Alarm Minutes	
Battery Location		Charger Voltage	
TYPE	Battery - Sealed Lead-acid	DESCRIPTION	E Wing Restroom E5 - P.E. "E"
ADDRESS/ SCAN ADDRESS		NOMINAL VOLTAGE	12
Load Voltage		Amp Hours	8
Standby Hours		Alarm Minutes	
Battery Location		Charger Voltage	
TYPE	Battery - Sealed Lead-acid	DESCRIPTION	E Wing Restroom E5 - P.E. "F"
ADDRESS/ SCAN ADDRESS		NOMINAL VOLTAGE	12
Load Voltage		Amp Hours	8
Standby Hours		Alarm Minutes	
Battery Location		Charger Voltage	
TYPE	Battery - Sealed Lead-acid	DESCRIPTION	G Wing Classroom G4 Storage - P.E. "D"
ADDRESS/ SCAN ADDRESS		NOMINAL VOLTAGE	12
Load Voltage		Amp Hours	8

Standby Hours
Battery Location

Alarm Minutes
Charger Voltage

Resolved Corrective Action & Solution Summary

The following 2 corrective action(s) were resolved during the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
Battery - Sealed Lead-acid		A Wing MP Room A2B Storage

Created By: Riley Goyet
 Creation Date: 10/21/2024
 Corrective Action: Replace (2) 12V 55AH Batteries
 Resolution:
 Resolved By: Riley Goyet
 Resolved On: 09/25/2025
 Manufacturer:
 Model:

Battery - Sealed Lead-acid		A Wing MP Room A2B Storage - P.E. "B"
----------------------------	--	---------------------------------------

Created By: Riley Goyet
 Creation Date: 10/21/2024
 Corrective Action: Replace (2) 12V 8AH Batteries
 Resolution:
 Resolved By: Riley Goyet
 Resolved On: 09/25/2025
 Manufacturer:
 Model:

Testing Details

Alarm Notification Appliance

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	065	A Wing A9 Front Entrance	Manual	9/22/2025 5:52:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	071	A Wing Copy Room A2D	Manual	9/22/2025 5:52:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	062	A Wing East Exterior	Manual	9/22/2025 5:53:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	070	A Wing Kitchen	Manual	9/22/2025 5:52:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	077	A Wing Mens Restroom A5	Manual	9/22/2025 5:51:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	068	A Wing MP Room A2	Manual	9/22/2025 5:52:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	067	A Wing MP Room A2	Manual	9/22/2025 5:52:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	079	A Wing MP Room A2	Manual	9/22/2025 5:51:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	078	A Wing MP Room A2	Manual	9/22/2025 5:51:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	072	A Wing Nurse Station A1A	Manual	9/22/2025 5:51:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	073	A Wing Nurse Station RR	Manual	9/22/2025 5:51:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	064	A Wing Office A1	Manual	9/22/2025 5:52:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	075	A Wing Principals Office A1C	Manual	9/22/2025 5:51:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	074	A Wing Principals Office A1C	Manual	9/22/2025 5:51:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	069	A Wing Stage A2B	Manual	9/22/2025 5:52:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	066	A Wing Teachers Lounge A6	Manual	9/22/2025 5:52:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	063	A Wing West Exterior	Manual	9/22/2025 5:53:08 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	076	A Wing Womens Restrm A4	Manual	9/22/2025 5:51:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	092	B Wing Classroom B1	Manual	9/22/2025 5:52:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	093	B Wing Classroom B2	Manual	9/22/2025 5:52:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	094	B Wing Classroom B3	Manual	9/22/2025 5:52:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	090	B Wing North Exterior	Manual	9/22/2025 5:53:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	095	B Wing Room B2/B3 RR	Manual	9/22/2025 5:51:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	091	B Wing South Exterior	Manual	9/22/2025 5:53:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	115	C Wing Boys Restroom C6	Manual	9/22/2025 5:51:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	112	C Wing Classroom C1	Manual	9/22/2025 5:52:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	113	C Wing Classroom C2	Manual	9/22/2025 5:52:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	114	C Wing Girls Restroom C4	Manual	9/22/2025 5:51:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	110	C Wing North Exterior	Manual	9/22/2025 5:53:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	111	C Wing South Exterior	Manual	9/22/2025 5:53:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	132	D Wing Classroom D2	Manual	9/22/2025 5:52:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	133	D Wing Classroom D3	Manual	9/22/2025 5:52:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	134	D Wing Classroom D4	Manual	9/22/2025 5:52:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	131	D Wing Learning Center D1	Manual	9/22/2025 5:52:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	130	D Wing West Exterior	Manual	9/22/2025 5:52:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible	158	E Wing Boys Restroom E7	Manual	9/22/2025 5:51:33 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	153	E Wing Classroom E1	Manual	9/22/2025 5:52:20 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	154	E Wing Classroom E2	Manual	9/22/2025 5:52:19 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	155	E Wing Classroom E3	Manual	9/22/2025 5:52:17 PM
		Visual inspection	Passed (Manual)	
Visible	159	E Wing Girls Restroom E8	Manual	9/22/2025 5:51:32 PM
		Visual inspection	Passed (Manual)	
Audible	152	E Wing North Exterior	Manual	9/22/2025 5:52:56 PM
		Visual inspection	Passed (Manual)	
Visible	157	E Wing Restroom E5	Manual	9/22/2025 5:53:11 PM
		Visual inspection	Passed (Manual)	
Visible	156	E Wing Staff Restroom E4	Manual	9/22/2025 5:51:35 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	166	F Wing Classroom F1	Manual	9/22/2025 5:52:15 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	167	F Wing Classroom F2	Manual	9/22/2025 5:52:14 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	193	G Wing Classroom G1	Manual	9/22/2025 5:52:13 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	194	G Wing Classroom G2	Manual	9/22/2025 5:52:11 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	195	G Wing Classroom G3	Manual	9/22/2025 5:52:09 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	196	G Wing Classroom G4	Manual	9/22/2025 5:52:08 PM
		Visual inspection	Passed (Manual)	
Audible	192	G Wing East Exterior	Manual	9/22/2025 5:52:58 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	208	H Wing Classroom H1	Manual	9/22/2025 5:52:07 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	209	H Wing Classroom H2	Manual	9/22/2025 5:52:05 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	210	H Wing Classroom H3	Manual	9/22/2025 5:52:04 PM
		Visual inspection	Passed (Manual)	
Audible	206	H Wing Northwest Exterior	Manual	9/22/2025 5:52:54 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	207	H Wing Southwest Exterior	Manual	9/22/2025 5:52:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	236	I Wing Classroom I-1	Manual	9/22/2025 5:52:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	237	I Wing Classroom I-2	Manual	9/22/2025 5:52:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	238	I Wing Classroom I-3	Manual	9/22/2025 5:51:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	239	I Wing Classroom I-4	Manual	9/22/2025 5:51:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	240	I Wing Classroom I-5	Manual	9/22/2025 5:51:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	242	I Wing Library I-7	Manual	9/22/2025 5:51:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	233	I Wing North Exterior	Manual	9/22/2025 5:52:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	234	I Wing Southeast Exterior	Manual	9/22/2025 5:52:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	235	I Wing Southwest Exterior	Manual	9/22/2025 5:52:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	241	I Wing Tech Lab I-6	Manual	9/22/2025 5:51:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Fire Alarm Panel		A Wing MP Room A2B Storage	Manual	9/22/2025 7:43:54 PM
		Manufacturer	EST	
		Model	3	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		A Wing MP Room A2B Storage - P.E. "B"	Manual	9/22/2025 7:43:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		A Wing MP Room A2B Storage - P.E. "Master"	Manual	9/22/2025 7:43:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Remote Annunciator	001	A Wing Reception	Manual	9/22/2025 8:09:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		C Wing Custodial Closet C3 - P.E. "C"	Manual	9/22/2025 8:10:06 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
NAC Power Extender Panel		E Wing Restroom E5 - P.E. "E"	Manual	9/22/2025 8:10:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		E Wing Restroom E5 - P.E. "F"	Manual	9/22/2025 8:10:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		G Wing Classroom G4 Storage - P.E. "D"	Manual	9/22/2025 8:10:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Manual Pull Station	2-158 004	A Wing A9 Front Entrance	Manual	9/22/2025 8:10:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-131 052	A Wing Attic Kitchen	Manual	9/22/2025 8:48:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-133 055	A Wing Attic Office A1	Manual	9/22/2025 8:49:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-132 054	A Wing Attic Principals Office	Manual	9/22/2025 8:49:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-149	A Wing Attic Room A2D	Manual	9/22/2025 8:48:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-130 053	A Wing Attic Storage A2B	Manual	9/22/2025 8:49:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-135 059	A Wing Attic Storage A7	Manual	9/22/2025 8:49:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-134 058	A Wing Attic Teachers Lounge	Manual	9/22/2025 8:49:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-134 057	A Wing Attic Teachers Lounge	Manual	9/22/2025 8:49:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-134 056	A Wing Attic Teachers Lounge	Manual	9/22/2025 8:49:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-160 007	A Wing Copy Room A2D	Manual	9/22/2025 8:21:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-042 034	A Wing Copy Room A2D	Manual	9/22/2025 8:20:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-041 035	A Wing Copy Room A2D	Manual	9/22/2025 8:20:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-004 029	A Wing Custodial Office A2A	Manual	9/22/2025 8:16:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	061	A Wing Duct Dectecor RM A2	Manual	9/22/2025 8:04:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-036 037	A Wing Hall A2	Manual	9/22/2025 8:08:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-034 036	A Wing Hall A2	Manual	9/22/2025 8:09:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-020 050	A Wing Kitchen	Manual	9/22/2025 8:48:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-019 049	A Wing Kitchen	Manual	9/22/2025 8:48:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-159 003	A Wing Kitchen	Manual	9/22/2025 8:21:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-022 045	A Wing Kitchen	Manual	9/22/2025 8:17:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-021 051	A Wing Kitchen Storage A8A	Manual	9/22/2025 8:49:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-058 048	A Wing Mech RM A2D	Manual	9/22/2025 8:49:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-035 040	A Wing Mens Restroom A5	Manual	9/22/2025 8:11:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-013 022	A Wing MP Room A2	Manual	9/22/2025 7:44:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-009 016	A Wing MP Room A2	Manual	9/22/2025 7:44:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-010 017	A Wing MP Room A2	Manual	9/22/2025 7:44:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-007 015	A Wing MP Room A2	Manual	9/22/2025 7:44:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-012 018	A Wing MP Room A2	Manual	9/22/2025 7:44:11 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-018 019	A Wing MP Room A2	Manual	9/22/2025 7:44:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-016 020	A Wing MP Room A2	Manual	9/22/2025 7:44:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-014 021	A Wing MP Room A2	Manual	9/22/2025 7:44:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-017 026	A Wing MP Room A2	Manual	9/22/2025 7:44:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-008 023	A Wing MP Room A2	Manual	9/22/2025 7:44:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-015 024	A Wing MP Room A2	Manual	9/22/2025 7:44:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-011 025	A Wing MP Room A2	Manual	9/22/2025 7:44:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-003 047	A Wing MP Room A2B Storage	Manual	9/22/2025 7:44:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-002 028	A Wing MP Room A2B Storage	Manual	9/22/2025 7:44:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-006 027	A Wing MP Room A2B Storage	Manual	9/22/2025 7:44:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-157 005	A Wing Multi-Purpose East	Manual	9/22/2025 8:21:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-156 006	A Wing Multi-Purpose West	Manual	9/22/2025 8:16:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-033 010	A Wing Nurse Station A1A	Manual	9/22/2025 8:12:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-030 011	A Wing Nurse Station RR	Manual	9/22/2025 8:12:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-032 008	A Wing Office A1	Manual	9/22/2025 8:11:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-031 009	A Wing Office A1	Manual	9/22/2025 8:13:05 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	2-027 013	A Wing Principals Office A1C	Manual	9/22/2025 8:13:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-028 014	A Wing Principals Office A1C	Manual	9/22/2025 8:13:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-155 002	A Wing Reception	Manual	9/22/2025 8:21:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	2-144 060	A Wing Riser Room A2B	Manual	9/22/2025 8:48:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-024 032	A Wing Stage A2B	Manual	9/22/2025 8:18:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-023 031	A Wing Stage A2B	Manual	9/22/2025 8:18:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-026 033	A Wing Stage A2B	Manual	9/22/2025 8:19:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-025 030	A Wing Stage A2B	Manual	9/22/2025 8:19:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-029 012	A Wing Storage A1B	Manual	9/22/2025 8:13:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-045 046	A Wing Storage A2C	Manual	9/22/2025 8:11:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-037 038	A Wing Storage A3	Manual	9/22/2025 8:08:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-040 042	A Wing Teachers Lounge A6	Manual	9/22/2025 7:58:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-039 041	A Wing Teachers Lounge A6	Manual	9/22/2025 7:59:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-043 043	A Wing Water Storage A7	Manual	9/22/2025 7:21:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-044 044	A Wing Water Storage A7	Manual	9/22/2025 7:21:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-038 039	A Wing Womens Restroom A4	Manual	9/22/2025 8:11:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-137 087	B Wing Attic Classroom B1	Manual	9/22/2025 7:40:56 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-138 088	B Wing Attic Classroom B2	Manual	9/22/2025 7:40:52 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-139 089	B Wing Attic Classroom B3	Manual	9/22/2025 8:49:33 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-096 080	B Wing Classroom B1	Manual	9/22/2025 8:02:51 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-055 081	B Wing Classroom B1	Manual	9/22/2025 8:02:56 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-056 082	B Wing Classroom B2	Manual	9/22/2025 8:03:19 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-097 083	B Wing Classroom B2	Manual	9/22/2025 8:03:27 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-098 084	B Wing Classroom B3	Manual	9/22/2025 8:04:20 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-057 085	B Wing Classroom B3	Manual	9/22/2025 8:04:34 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-059 086	B Wing Room B2/B3 RR	Manual	9/22/2025 8:03:49 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-141 107	C Wing Attic Classroom C1	Manual	9/22/2025 8:49:30 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-140 108	C Wing Attic Classroom C2	Manual	9/22/2025 8:49:32 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-136 109	C Wing Attic Custodial Closet C5	Manual	9/22/2025 8:49:26 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-054 105	C Wing Boys Restroom C6	Manual	9/22/2025 8:02:34 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-053 104	C Wing Boys Restroom C6	Manual	9/22/2025 8:02:35 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-061 097	C Wing Classroom C1	Manual	9/22/2025 7:52:27 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-100 096	C Wing Classroom C1	Manual	9/22/2025 7:52:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-060 098	C Wing Classroom C2	Manual	9/22/2025 7:53:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-099 099	C Wing Classroom C2	Manual	9/22/2025 7:53:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-048 100	C Wing Custodial Closet C3	Manual	9/22/2025 7:54:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-052 106	C Wing Custodial Closet C5	Manual	9/22/2025 8:49:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-050 102	C Wing Girls Restroom C4	Manual	9/22/2025 8:02:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-051 103	C Wing Girls Restroom C4	Manual	9/22/2025 8:02:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-049 101	C Wing PE Storage C7	Manual	9/22/2025 8:05:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-142 123	D Wing Attic Rooms D1-D4	Manual	9/22/2025 8:01:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-142 122	D Wing Attic Rooms D1-D4	Manual	9/22/2025 8:01:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-142 124	D Wing Attic Rooms D1-D4	Manual	9/22/2025 8:01:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-142 125	D Wing Attic Rooms D1-D4	Manual	9/22/2025 8:01:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-142 126	D Wing Attic Rooms D1-D4	Manual	9/22/2025 8:02:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-142 129	D Wing Attic Rooms D1-D4	Manual	9/22/2025 8:02:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-142 128	D Wing Attic Rooms D1-D4	Manual	9/22/2025 8:02:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-142 127	D Wing Attic Rooms D1-D4	Manual	9/22/2025 8:02:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-070 119	D Wing Classroom D2	Manual	9/22/2025 7:51:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-069 120	D Wing Classroom D3	Manual	9/22/2025 7:24:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-068 121	D Wing Classroom D4	Manual	9/22/2025 7:57:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-066 117	D Wing Learning Center D1	Manual	9/22/2025 7:55:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-065 116	D Wing Learning Center D1	Manual	9/22/2025 7:56:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-067 118	D Wing Storage D1A	Manual	9/22/2025 7:56:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-379 148	E Wing Attic Classroom E1	Manual	9/22/2025 8:49:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-378 149	E Wing Attic Classroom E2	Manual	9/22/2025 8:49:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-377 150	E Wing Attic Classroom E3	Manual	9/22/2025 8:49:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-257 144	E Wing Boys Restroom E7	Manual	9/22/2025 7:49:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-258 145	E Wing Boys Restroom E7	Manual	9/22/2025 8:05:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-376 151	E Wing C/E Wing Breezeway	Manual	9/22/2025 8:49:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-263 136	E Wing Classroom E1	Manual	9/22/2025 7:40:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-281 135	E Wing Classroom E1	Manual	9/22/2025 7:41:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-262 138	E Wing Classroom E2	Manual	9/22/2025 7:43:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-280 137	E Wing Classroom E2	Manual	9/22/2025 7:43:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-261 140	E Wing Classroom E3	Manual	9/22/2025 7:45:00 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-279 139	E Wing Classroom E3	Manual	9/22/2025 7:45:13 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-254 143	E Wing Electrical Room E6	Manual	9/22/2025 7:47:58 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-260 146	E Wing Girls Restroom E8	Manual	9/22/2025 7:50:50 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-259 147	E Wing Girls Restroom E8	Manual	9/22/2025 8:05:09 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-255 142	E Wing Restroom E5	Manual	9/22/2025 7:46:56 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-256 141	E Wing Staff Restroom E4	Manual	9/22/2025 7:45:57 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-381 164	F Wing Attic Classroom F1	Manual	9/22/2025 8:48:28 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-380 165	F Wing Attic Classroom F2	Manual	9/22/2025 8:48:26 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-266 160	F Wing Classroom F1	Manual	9/22/2025 7:44:49 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-282 161	F Wing Classroom F1	Manual	9/22/2025 7:44:53 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-283 162	F Wing Classroom F2	Manual	9/22/2025 7:41:42 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-267 163	F Wing Classroom F2	Manual	9/22/2025 7:42:03 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-151 185	G Wing Attic Classroom G1	Manual	9/22/2025 8:48:13 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-151 184	G Wing Attic Classroom G1	Manual	9/22/2025 8:48:15 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-153 186	G Wing Attic Classroom G2	Manual	9/22/2025 8:48:16 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-153 187	G Wing Attic Classroom G2	Manual	9/22/2025 8:48:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-152 188	G Wing Attic Classroom G3	Manual	9/22/2025 8:48:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-152 189	G Wing Attic Classroom G3	Manual	9/22/2025 8:48:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-150 190	G Wing Attic Classroom G4	Manual	9/22/2025 7:32:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-150 191	G Wing Attic Classroom G4	Manual	9/22/2025 8:48:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-084 168	G Wing Classroom G1	Manual	9/22/2025 7:36:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-086 169	G Wing Classroom G1	Manual	9/22/2025 7:36:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-087 170	G Wing Classroom G1	Manual	9/22/2025 7:37:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-085 180	G Wing Classroom G1 Storage	Manual	9/22/2025 8:48:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-092 171	G Wing Classroom G2	Manual	9/22/2025 7:37:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-094 173	G Wing Classroom G2	Manual	9/22/2025 7:37:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-095 172	G Wing Classroom G2	Manual	9/22/2025 7:37:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-093 181	G Wing Classroom G2 Storage	Manual	9/22/2025 8:48:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-091 174	G Wing Classroom G3	Manual	9/22/2025 7:33:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-088 175	G Wing Classroom G3	Manual	9/22/2025 7:34:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-089 176	G Wing Classroom G3	Manual	9/22/2025 7:34:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-090 182	G Wing Classroom G3 Storage	Manual	9/22/2025 8:48:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-081 178	G Wing Classroom G4	Manual	9/22/2025 7:35:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-082 179	G Wing Classroom G4	Manual	9/22/2025 7:35:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-083 177	G Wing Classroom G4	Manual	9/22/2025 7:35:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-080 183	G Wing Classroom G4 Storage	Manual	9/22/2025 8:48:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-386 203	H Wing Attic Classroom H1	Manual	9/22/2025 8:49:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-387 204	H Wing Attic Classroom H2	Manual	9/22/2025 7:28:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-388 205	H Wing Attic Classroom H3	Manual	9/22/2025 7:29:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-276 197	H Wing Classroom H1	Manual	9/22/2025 7:27:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-288 198	H Wing Classroom H1	Manual	9/22/2025 7:27:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-289 200	H Wing Classroom H2	Manual	9/22/2025 7:28:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-277 199	H Wing Classroom H2	Manual	9/22/2025 7:29:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-290 202	H Wing Classroom H3	Manual	9/22/2025 7:29:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-278 201	H Wing Classroom H3	Manual	9/22/2025 7:29:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-148 225	I Wing Attic Classroom I-1	Manual	9/22/2025 8:49:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-149 226	I Wing Attic Classroom I-1	Manual	9/22/2025 8:49:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-147 227	I Wing Attic Classroom I-2	Manual	9/22/2025 8:49:06 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-146 228	I Wing Attic Classroom I-3	Manual	9/22/2025 8:48:56 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-382 229	I Wing Attic Classroom I-4	Manual	9/22/2025 8:48:59 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-383 230	I Wing Attic Classroom I-5	Manual	9/22/2025 8:49:00 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-385 232	I Wing Attic Library I-7	Manual	9/22/2025 8:48:57 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-384 231	I Wing Attic Tech Lab I-6	Manual	9/22/2025 8:49:01 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-075 211	I Wing Classroom I-1	Manual	9/22/2025 7:24:50 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-103 212	I Wing Classroom I-1	Manual	9/22/2025 7:24:52 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-074 214	I Wing Classroom I-2	Manual	9/22/2025 7:24:47 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-102 213	I Wing Classroom I-2	Manual	9/22/2025 7:24:48 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-101 215	I Wing Classroom I-3	Manual	9/22/2025 7:24:43 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-073 216	I Wing Classroom I-3	Manual	9/22/2025 7:24:45 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-284 218	I Wing Classroom I-4	Manual	9/22/2025 7:24:39 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-270 217	I Wing Classroom I-4	Manual	9/22/2025 7:24:41 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-271 219	I Wing Classroom I-5	Manual	9/22/2025 7:24:36 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-285 220	I Wing Classroom I-5	Manual	9/22/2025 7:24:37 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-287 224	I Wing Library I-7	Manual	9/22/2025 7:25:09 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-273 223	I Wing Library I-7	Manual	9/22/2025 7:25:10 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-286 222	I Wing Tech Lab I-6	Manual	9/22/2025 7:25:03 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-272 221	I Wing Tech Lab I-6	Manual	9/22/2025 7:25:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Power Supplies

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Battery - Sealed Lead-acid		A Wing MP Room A2B Storage	Manual	9/22/2025 8:48:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	55	
Battery - Sealed Lead-acid		A Wing MP Room A2B Storage - P.E. "B"	Manual	9/22/2025 8:48:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	8	
Battery - Sealed Lead-acid		A Wing MP Room A2B Storage - P.E. "Master"	Manual	9/22/2025 8:48:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	8	
Battery - Sealed Lead-acid		C Wing Custodial Closet C3 - P.E. "C"	Manual	9/22/2025 8:48:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	8	
Battery - Sealed Lead-acid		E Wing Restroom E5 - P.E. "E"	Manual	9/22/2025 8:48:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	8	
Battery - Sealed Lead-acid		E Wing Restroom E5 - P.E. "F"	Manual	9/22/2025 8:48:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	8	
Battery - Sealed Lead-acid		G Wing Classroom G4 Storage - P.E. "D"	Manual	9/22/2025 8:48:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	8	
		Nominal Voltage	12	

Device/Equipment details

Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Audible					
062	A Wing East Exterior				
063	A Wing West Exterior				
090	B Wing North Exterior				
091	B Wing South Exterior				
110	C Wing North Exterior				
111	C Wing South Exterior				
130	D Wing West Exterior				
152	E Wing North Exterior				
192	G Wing East Exterior				
206	H Wing Northwest Exterior				
207	H Wing Southwest Exterior				
233	I Wing North Exterior				
234	I Wing Southeast Exterior				
235	I Wing Southwest Exterior				
Audible And Visible					
064	A Wing Office A1				
065	A Wing A9 Front Entrance				
066	A Wing Teachers Lounge A6				
067	A Wing MP Room A2				
068	A Wing MP Room A2				
069	A Wing Stage A2B				
070	A Wing Kitchen				
071	A Wing Copy Room A2D				
092	B Wing Classroom B1				
093	B Wing Classroom B2				
094	B Wing Classroom B3				
112	C Wing Classroom C1				
113	C Wing Classroom C2				
131	D Wing Learning Center D1				
132	D Wing Classroom D2				
133	D Wing Classroom D3				
134	D Wing Classroom D4				
153	E Wing Classroom E1				
154	E Wing Classroom E2				
155	E Wing Classroom E3				
166	F Wing Classroom F1				
167	F Wing Classroom F2				
193	G Wing Classroom G1				
194	G Wing Classroom G2				
195	G Wing Classroom G3				
196	G Wing Classroom G4				
208	H Wing Classroom H1				
209	H Wing Classroom H2				
210	H Wing Classroom H3				
236	I Wing Classroom I-1				
237	I Wing Classroom I-2				
238	I Wing Classroom I-3				
239	I Wing Classroom I-4				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
240	I Wing Classroom I-5				
241	I Wing Tech Lab I-6				
242	I Wing Library I-7				
Visible					
072	A Wing Nurse Station A1A				
073	A Wing Nurse Station RR				
074	A Wing Principals Office A1C				
075	A Wing Principals Office A1C				
076	A Wing Womens Restrm A4				
077	A Wing Mens Restroom A5				
078	A Wing MP Room A2				
079	A Wing MP Room A2				
095	B Wing Room B2/B3 RR				
114	C Wing Girls Restroom C4				
115	C Wing Boys Restroom C6				
156	E Wing Staff Restroom E4				
157	E Wing Restroom E5				
158	E Wing Boys Restroom E7				
159	E Wing Girls Restroom E8				

Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Remote Annunciator					
001	A Wing Reception				
Fire Alarm Panel					
	A Wing MP Room A2B Storage	EST		3	
NAC Power Extender Panel					
	A Wing MP Room A2B Storage - P.E. "Master"				
	A Wing MP Room A2B Storage - P.E. "B"				
	C Wing Custodial Closet C3 - P.E. "C"				
	G Wing Classroom G4 Storage - P.E. "D"				
	E Wing Restroom E5 - P.E. "E"				
	E Wing Restroom E5 - P.E. "F"				

Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Heat Detector - Restorable Spot					
2-131 052	A Wing Attic Kitchen				
2-130 053	A Wing Attic Storage A2B				
2-132 054	A Wing Attic Principals Office				
2-133 055	A Wing Attic Office A1				
2-134 056	A Wing Attic Teachers Lounge				
2-134 057	A Wing Attic Teachers Lounge				
2-134 058	A Wing Attic Teachers Lounge				
2-135 059	A Wing Attic Storage A7				
2-137 087	B Wing Attic Classroom B1				
2-138 088	B Wing Attic Classroom B2				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-139 089	B Wing Attic Classroom B3				
2-052 106	C Wing Custodial Closet C5				
2-141 107	C Wing Attic Classroom C1				
2-140 108	C Wing Attic Classroom C2				
2-136 109	C Wing Attic Custodial Closet C5				
2-142 122	D Wing Attic Rooms D1-D4				
2-142 123	D Wing Attic Rooms D1-D4				
2-142 124	D Wing Attic Rooms D1-D4				
2-142 125	D Wing Attic Rooms D1-D4				
2-142 126	D Wing Attic Rooms D1-D4				
2-142 127	D Wing Attic Rooms D1-D4				
2-142 128	D Wing Attic Rooms D1-D4				
2-142 129	D Wing Attic Rooms D1-D4				
2-379 148	E Wing Attic Classroom E1				
2-378 149	E Wing Attic Classroom E2				
2-377 150	E Wing Attic Classroom E3				
2-376 151	E Wing C/E Wing Breezeway				
2-381 164	F Wing Attic Classroom F1				
2-380 165	F Wing Attic Classroom F2				
2-085 180	G Wing Classroom G1 Storage				
2-093 181	G Wing Classroom G2 Storage				
2-090 182	G Wing Classroom G3 Storage				
2-080 183	G Wing Classroom G4 Storage				
2-151 184	G Wing Attic Classroom G1				
2-151 185	G Wing Attic Classroom G1				
2-153 186	G Wing Attic Classroom G2				
2-153 187	G Wing Attic Classroom G2				
2-152 188	G Wing Attic Classroom G3				
2-152 189	G Wing Attic Classroom G3				
2-150 190	G Wing Attic Classroom G4				
2-150 191	G Wing Attic Classroom G4				
2-386 203	H Wing Attic Classroom H1				
2-387 204	H Wing Attic Classroom H2				
2-388 205	H Wing Attic Classroom H3				
2-148 225	I Wing Attic Classroom I-1				
2-149 226	I Wing Attic Classroom I-1				
2-147 227	I Wing Attic Classroom I-2				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-146 228	I Wing Attic Classroom I-3				
2-382 229	I Wing Attic Classroom I-4				
2-383 230	I Wing Attic Classroom I-5				
2-384 231	I Wing Attic Tech Lab I-6				
2-385 232	I Wing Attic Library I-7				
2-045 046	A Wing Storage A2C				
2-003 047	A Wing MP Room A2B Storage				
2-058 048	A Wing Mech RM A2D				
2-019 049	A Wing Kitchen				
2-020 050	A Wing Kitchen				
2-021 051	A Wing Kitchen Storage A8A				
2-149	A Wing Attic Room A2D				
Mechanical, Electrosonic, or Pressure Waterflow Device					
2-144 060	A Wing Riser Room A2B				
Smoke Detector - Duct					
061	A Wing Duct Dectecor RM A2				
Smoke Detector - General					
2-096 080	B Wing Classroom B1				
2-055 081	B Wing Classroom B1				
2-056 082	B Wing Classroom B2				
2-097 083	B Wing Classroom B2				
2-098 084	B Wing Classroom B3				
2-057 085	B Wing Classroom B3				
2-059 086	B Wing Room B2/B3 RR				
2-100 096	C Wing Classroom C1				
2-061 097	C Wing Classroom C1				
2-060 098	C Wing Classroom C2				
2-099 099	C Wing Classroom C2				
2-048 100	C Wing Custodial Closet C3				
2-049 101	C Wing PE Storage C7				
2-050 102	C Wing Girls Restroom C4				
2-051 103	C Wing Girls Restroom C4				
2-053 104	C Wing Boys Restroom C6				
2-054 105	C Wing Boys Restroom C6				
2-065 116	D Wing Learning Center D1				
2-066 117	D Wing Learning Center D1				
2-067 118	D Wing Storage D1A				
2-070 119	D Wing Classroom D2				
2-069 120	D Wing Classroom D3				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-068 121	D Wing Classroom D4				
2-281 135	E Wing Classroom E1				
2-263 136	E Wing Classroom E1				
2-280 137	E Wing Classroom E2				
2-262 138	E Wing Classroom E2				
2-279 139	E Wing Classroom E3				
2-261 140	E Wing Classroom E3				
2-256 141	E Wing Staff Restroom E4				
2-255 142	E Wing Restroom E5				
2-254 143	E Wing Electrical Room E6				
2-257 144	E Wing Boys Restroom E7				
2-258 145	E Wing Boys Restroom E7				
2-260 146	E Wing Girls Restroom E8				
2-259 147	E Wing Girls Restroom E8				
2-266 160	F Wing Classroom F1				
2-282 161	F Wing Classroom F1				
2-283 162	F Wing Classroom F2				
2-267 163	F Wing Classroom F2				
2-084 168	G Wing Classroom G1				
2-086 169	G Wing Classroom G1				
2-087 170	G Wing Classroom G1				
2-092 171	G Wing Classroom G2				
2-095 172	G Wing Classroom G2				
2-094 173	G Wing Classroom G2				
2-091 174	G Wing Classroom G3				
2-088 175	G Wing Classroom G3				
2-089 176	G Wing Classroom G3				
2-083 177	G Wing Classroom G4				
2-081 178	G Wing Classroom G4				
2-082 179	G Wing Classroom G4				
2-276 197	H Wing Classroom H1				
2-288 198	H Wing Classroom H1				
2-277 199	H Wing Classroom H2				
2-289 200	H Wing Classroom H2				
2-278 201	H Wing Classroom H3				
2-290 202	H Wing Classroom H3				
2-075 211	I Wing Classroom I-1				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-103 212	I Wing Classroom I-1				
2-102 213	I Wing Classroom I-2				
2-074 214	I Wing Classroom I-2				
2-101 215	I Wing Classroom I-3				
2-073 216	I Wing Classroom I-3				
2-270 217	I Wing Classroom I-4				
2-284 218	I Wing Classroom I-4				
2-271 219	I Wing Classroom I-5				
2-285 220	I Wing Classroom I-5				
2-272 221	I Wing Tech Lab I-6				
2-286 222	I Wing Tech Lab I-6				
2-273 223	I Wing Library I-7				
2-287 224	I Wing Library I-7				
2-032 008	A Wing Office A1				
2-031 009	A Wing Office A1				
2-033 010	A Wing Nurse Station A1A				
2-030 011	A Wing Nurse Station RR				
2-029 012	A Wing Storage A1B				
2-027 013	A Wing Principals Office A1C				
2-028 014	A Wing Principals Office A1C				
2-007 015	A Wing MP Room A2				
2-009 016	A Wing MP Room A2				
2-010 017	A Wing MP Room A2				
2-012 018	A Wing MP Room A2				
2-018 019	A Wing MP Room A2				
2-016 020	A Wing MP Room A2				
2-014 021	A Wing MP Room A2				
2-013 022	A Wing MP Room A2				
2-008 023	A Wing MP Room A2				
2-015 024	A Wing MP Room A2				
2-011 025	A Wing MP Room A2				
2-017 026	A Wing MP Room A2				
2-006 027	A Wing MP Room A2B Storage				
2-002 028	A Wing MP Room A2B Storage				
2-004 029	A Wing Custodial Office A2A				
2-025 030	A Wing Stage A2B				
2-023 031	A Wing Stage A2B				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-024 032	A Wing Stage A2B				
2-026 033	A Wing Stage A2B				
2-042 034	A Wing Copy Room A2D				
2-041 035	A Wing Copy Room A2D				
2-034 036	A Wing Hall A2				
2-036 037	A Wing Hall A2				
2-037 038	A Wing Storage A3				
2-038 039	A Wing Womens Restroom A4				
2-035 040	A Wing Mens Restroom A5				
2-039 041	A Wing Teachers Lounge A6				
2-040 042	A Wing Teachers Lounge A6				
2-043 043	A Wing Water Storage A7				
2-044 044	A Wing Water Storage A7				
2-022 045	A Wing Kitchen				

Manual Pull Station

2-155 002	A Wing Reception				
2-159 003	A Wing Kitchen				
2-158 004	A Wing A9 Front Entrance				
2-157 005	A Wing Multi-Purpose East				
2-156 006	A Wing Multi-Purpose West				
2-160 007	A Wing Copy Room A2D				

Power Supplies

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Battery - Sealed Lead-acid					
	A Wing MP Room A2B Storage				11/26/2019
	A Wing MP Room A2B Storage - P.E. "Master"				07/01/2019
	A Wing MP Room A2B Storage - P.E. "B"				11/17/2019
	C Wing Custodial Closet C3 - P.E. "C"				07/09/2012
	G Wing Classroom G4 Storage - P.E. "D"				04/04/2014
	E Wing Restroom E5 - P.E. "E"				01/11/2017
	E Wing Restroom E5 - P.E. "F"				01/11/2017