

Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

JAMES COWAN

3350 BACERRA WAY
SACRAMENTO, California 95821
United States

This site has been inspected and tested in compliance with applicable standards.

Completed
Tuesday, September 30, 2025

Test Session:22 Sep 2025 15:31 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD
5320 HEMLOCK ST
SACRAMENTO, California
United States

TESTED BY

Riley Goyet
Western States Fire Protection-
Sacramento
188 Cirby Way
Roseville, CA 95678
United States



Inspection Summary

Building Information

PROPERTY	JAMES COWAN	CONTACT
ADDRESS	3350 BACERRA WAY	PHONE
CITY/STATE	SACRAMENTO, California 95821	MOBILE
COUNTRY	United States	EMAIL

Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us

Testing Summary


EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Alarm Notification Appliance	68	68(100%)	68(100%)	0(0%)
Supervising Station Transmitting Equipment	1	1(100%)	1(100%)	0(0%)
Fire Control Panel	6	6(100%)	6(100%)	0(0%)
Initiating Device	179	176(98%)	174(97%)	2(1%)

Certification

The equipment specified here in was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Tuesday, September 30, 2025

ACCEPTED BY 09/30/2025

Building Representative


TESTED BY 09/30/2025
Riley Goyet
Technician

System Details

Control Units

ADDRESS/ SCAN ADDRESS		DESCRIPTION	Rooms 2-5 Bldg Storage Room A
MANUFACTURER	EST	S/W VERSION	
MODEL	3	LAST UPDATE	
SERIAL NUMBER		S/W LOCATION	
INSTALL DATE			

Monitoring Information

Rooms 2-5 Bldg Storage Room A - Dialer Panel			
TYPE	Digital Alarm Communicator Transmitter	INSTALL DATE	
MANUFACTURER	Bosch	TEST START	09/22/2025
MODEL	B9512G	TEST COMPLETE	09/30/2025
SERIAL NUMBER		Time to Transmit to Supervising Station	
MONITORING ORGANIZATION	Central Station / SJUSD Dispatch	ALARM SIGNAL	
MONITORING ORGANIZATION PHONE	CS - 916-480-4836 / SJUSD Dispatch - 916-971-7000	ALARM RESTORE	
MONITORING ORGANIZATION EMAIL		TROUBLE SIGNAL	
MONITORING ORGANIZATION ACCOUNT NUMBER	Central Station # 881-8009	TROUBLE RESTORE	
MONITORING PHONE LINE 1		SUPERVISORY SIGNAL	
MONITORING PHONE LINE 2		SUPERVISORY RESTORE	
MONITORING RETRANSMISSION ENTITY			

Open Corrective Action & Solution Summary

The following 1 corrective action(s) remain open following the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
Heat Detector - Restorable Spot	2-131 172	Portables Attic Classroom 15
	Created By:	Riley Goyet
	Creation Date:	09/22/2025
	Corrective Action:	Did not activate possibly damaged wire. Stick heat
	Proposed Solution:	
	Manufacturer:	
	Model:	

Testing Details

Alarm Notification Appliance

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	027	Admin Bldg Admin Office	Manual	9/22/2025 3:34:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	032	Admin Bldg Classroom 1	Manual	9/22/2025 3:32:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	029	Admin Bldg Copy Room	Manual	9/22/2025 3:34:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	025	Admin Bldg East Exterior	Manual	9/22/2025 3:34:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	031	Admin Bldg Learning Center	Manual	9/22/2025 3:34:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	037	Admin Bldg Mens Restroom	Manual	9/22/2025 3:32:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	024	Admin Bldg North Exterior	Manual	9/22/2025 3:34:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	028	Admin Bldg Nurse Office	Manual	9/22/2025 3:34:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	034	Admin Bldg Nurse Restroom	Manual	9/22/2025 3:32:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	033	Admin Bldg Principals Office	Manual	9/22/2025 3:32:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	036	Admin Bldg Speech Room	Manual	9/22/2025 3:32:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	030	Admin Bldg Staff Room	Manual	9/22/2025 3:32:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	035	Admin Bldg Staff Room Hall	Manual	9/22/2025 3:32:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	026	Admin Bldg West Exterior	Manual	9/22/2025 3:34:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	038	Admin Bldg Womens Restroom	Manual	9/22/2025 3:32:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	250	Multi-Purpose Bldg Kitchen	Manual	9/22/2025 3:32:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	252	Multi-Purpose Bldg Kitchen	Manual	9/22/2025 3:33:01 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	251	Multi-Purpose Bldg Kitchen	Manual	9/22/2025 3:33:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	249	Multi-Purpose Bldg MP Room	Manual	9/22/2025 3:32:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	248	Multi-Purpose Bldg MP Room	Manual	9/22/2025 3:32:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	247	Multi-Purpose Bldg West Exterior	Manual	9/22/2025 3:33:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	183	Portables Classrm 15 Boys RR	Manual	9/22/2025 3:33:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	184	Portables Classrm 15 Girls RR	Manual	9/22/2025 3:33:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	186	Portables Classrm 17 Boys RR	Manual	9/22/2025 3:33:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	187	Portables Classrm 17 Girls RR	Manual	9/22/2025 3:33:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	178	Portables Classroom 14	Manual	9/22/2025 3:33:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	179	Portables Classroom 15	Manual	9/22/2025 3:33:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	182	Portables Classroom 15 Office	Manual	9/22/2025 3:33:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	180	Portables Classroom 16	Manual	9/22/2025 3:33:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	181	Portables Classroom 17	Manual	9/22/2025 3:33:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	185	Portables Classroom 17 Office	Manual	9/22/2025 3:33:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	149	Rooms 10-13 Bldg Boys Restroom	Manual	9/22/2025 3:33:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	144	Rooms 10-13 Bldg Classroom 10	Manual	9/22/2025 3:33:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	145	Rooms 10-13 Bldg Classroom 11	Manual	9/22/2025 3:33:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	146	Rooms 10-13 Bldg Classroom 12	Manual	9/22/2025 3:33:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	147	Rooms 10-13 Bldg Classroom 13	Manual	9/22/2025 3:33:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	148	Rooms 10-13 Bldg Girls Restroom	Manual	9/22/2025 3:33:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	141	Rooms 10-13 Bldg Northeast Exterior	Manual	9/22/2025 3:34:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	142	Rooms 10-13 Bldg Northwest Exterior	Manual	9/22/2025 3:34:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	143	Rooms 10-13 Bldg South Exterior	Manual	9/22/2025 3:33:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	234	Rooms 18-21 Bldg Classrm 20 Boys RR	Manual	9/22/2025 3:33:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	235	Rooms 18-21 Bldg Classrm 20 Girls RR	Manual	9/22/2025 3:33:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	233	Rooms 18-21 Bldg Classrm 20 Hallway	Manual	9/22/2025 3:33:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	232	Rooms 18-21 Bldg Classrm 20 Work Rm	Manual	9/22/2025 3:33:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	229	Rooms 18-21 Bldg Classroom 18	Manual	9/22/2025 3:33:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	230	Rooms 18-21 Bldg Classroom 19	Manual	9/22/2025 3:33:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	231	Rooms 18-21 Bldg Classroom 20	Manual	9/22/2025 3:33:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	236	Rooms 18-21 Bldg Classroom 21	Manual	9/22/2025 3:33:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	227	Rooms 18-21 Bldg North Exterior	Manual	9/22/2025 3:33:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	226	Rooms 18-21 Bldg North Exterior	Manual	9/22/2025 3:33:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	228	Rooms 18-21 Bldg South Exterior	Manual	9/22/2025 3:33:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	068	Rooms 2-5 Bldg Classroom 2	Manual	9/22/2025 3:34:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	069	Rooms 2-5 Bldg Classroom 3	Manual	9/22/2025 3:34:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	070	Rooms 2-5 Bldg Classroom 4	Manual	9/22/2025 3:34:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	071	Rooms 2-5 Bldg Classroom 5	Manual	9/22/2025 3:34:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	065	Rooms 2-5 Bldg Northeast Exterior	Manual	9/22/2025 3:34:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	066	Rooms 2-5 Bldg Northwest Exterior	Manual	9/22/2025 3:34:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	067	Rooms 2-5 Bldg South Exterior	Manual	9/22/2025 3:34:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	111	Rooms 6-9 Bldg Boys Restroom	Manual	9/22/2025 3:34:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	106	Rooms 6-9 Bldg Classroom 6	Manual	9/22/2025 3:34:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	107	Rooms 6-9 Bldg Classroom 7	Manual	9/22/2025 3:34:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	108	Rooms 6-9 Bldg Classroom 8	Manual	9/22/2025 3:34:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	109	Rooms 6-9 Bldg Classroom 9	Manual	9/22/2025 3:34:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	110	Rooms 6-9 Bldg Girls Restroom	Manual	9/22/2025 3:34:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	102	Rooms 6-9 Bldg Northeast Exterior	Manual	9/22/2025 3:34:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	103	Rooms 6-9 Bldg Northwest Exterior	Manual	9/22/2025 3:34:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	104	Rooms 6-9 Bldg Southeast Exterior	Manual	9/22/2025 3:34:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	105	Rooms 6-9 Bldg Southwest Exterior	Manual	9/22/2025 3:34:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Remote Annunciator	001	Admin Bldg Admin Office	Manual	9/22/2025 5:03:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	150	Rooms 10-13 Bldg Custodial Closet - P.E. "D"	Manual	9/22/2025 5:03:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Fire Alarm Panel		Rooms 2-5 Bldg Storage Room A	Manual	9/22/2025 5:03:28 PM
		Manufacturer	EST	
		Model	3	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	072	Rooms 2-5 Bldg Storage Room A - P.E. "B"	Manual	9/22/2025 5:03:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	073	Rooms 2-5 Bldg Storage Room A - P.E. "C"	Manual	9/22/2025 5:03:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	112	Rooms 6-9 Bldg Custodial Closet - P.E. "E"	Manual	9/22/2025 5:03:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - Duct	2-392 023	Admin Bldg Admin Building	Manual	9/22/2025 5:03:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-376 002	Admin Bldg Admin Office	Manual	9/22/2025 4:39:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-258 003	Admin Bldg Admin Office	Manual	9/22/2025 4:38:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-263 015	Admin Bldg Classroom 1	Manual	9/22/2025 3:49:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-266 017	Admin Bldg Classroom 1	Manual	9/22/2025 3:51:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-264 016	Admin Bldg Classroom 1	Manual	9/22/2025 4:50:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-265 018	Admin Bldg Classroom 1	Manual	9/22/2025 4:51:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-268 020	Admin Bldg Classroom 1 RR	Manual	9/22/2025 4:52:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-267 019	Admin Bldg Classroom 1 Storage	Manual	9/22/2025 4:51:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-259 007	Admin Bldg Copy Room	Manual	9/22/2025 4:41:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-261 011	Admin Bldg Learning Center	Manual	9/22/2025 4:45:46 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	2-262 010	Admin Bldg Learning Center	Manual	9/22/2025 4:46:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-377 021	Admin Bldg Light Chase Room 1	Manual	9/22/2025 4:50:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-377 022	Admin Bldg Light Chase Room 1	Manual	9/22/2025 4:50:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-252 013	Admin Bldg Mens Restroom	Manual	9/22/2025 4:43:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-256 005	Admin Bldg Nurse Office	Manual	9/22/2025 4:40:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-255 006	Admin Bldg Nurse Restroom	Manual	9/22/2025 4:40:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-257 004	Admin Bldg Principals Office	Manual	9/22/2025 4:39:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-254 012	Admin Bldg Speech Room	Manual	9/22/2025 4:45:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-260 008	Admin Bldg Staff Room	Manual	9/22/2025 4:41:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-253 009	Admin Bldg Staff Room Hall	Manual	9/22/2025 4:42:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-251 014	Admin Bldg Womens Restroom	Manual	9/22/2025 4:43:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-034	Classroom 17	Manual	9/22/2025 4:11:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-136 243	Multi-Purpose Bldg Attic Kitchen	Manual	9/22/2025 5:46:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-137 244	Multi-Purpose Bldg Attic Kitchen	Manual	9/22/2025 5:46:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-039 242	Multi-Purpose Bldg Kitchen	Manual	9/22/2025 4:36:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-038 241	Multi-Purpose Bldg Kitchen	Manual	9/22/2025 4:36:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - Projected Beam	2-146 245	Multi-Purpose Bldg MP Room East	Manual	9/22/2025 4:36:13 PM
		Visual inspection	Passed (Manual)	
Manual Pull Station	2-135 238	Multi-Purpose Bldg MP Room Northeast	Manual	9/22/2025 4:36:14 PM
		Visual inspection	Passed (Manual)	
Manual Pull Station	2-134 237	Multi-Purpose Bldg MP Room Southwest	Manual	9/22/2025 4:36:16 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-043 239	Multi-Purpose Bldg MP Room Storage	Manual	9/22/2025 4:36:09 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - Projected Beam	2-148 246	Multi-Purpose Bldg MP Room West	Manual	9/22/2025 4:36:10 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-308	Portable rm 22	Manual	9/22/2025 4:54:19 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-307	Portable rm 22	Manual	9/22/2025 4:54:44 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-309	Portable rm 22	Manual	9/22/2025 4:55:09 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	2-130 168	Portables Attic Classroom 14	Manual	9/22/2025 4:00:10 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	2-130 169	Portables Attic Classroom 14	Manual	9/22/2025 4:00:12 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	2-130 170	Portables Attic Classroom 14	Manual	9/22/2025 4:00:14 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	2-132 174	Portables Attic Classroom 16	Manual	9/22/2025 4:08:17 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	2-132 173	Portables Attic Classroom 16	Manual	9/22/2025 4:08:20 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	2-133 177	Portables Attic Classroom 17	Manual	9/22/2025 5:50:21 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	2-133 176	Portables Attic Classroom 17	Manual	9/22/2025 5:50:23 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	2-133 175	Portables Attic Classroom 17	Manual	9/22/2025 5:50:24 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	2-388	Portables Attic Classroom 22	Manual	9/22/2025 4:56:26 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	2-027 158	Portables Classrm 15 Boys RR	Manual	9/22/2025 3:58:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-028 159	Portables Classrm 15 Girls RR	Manual	9/22/2025 3:57:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-032 165	Portables Classrm 17 Boys RR	Manual	9/22/2025 4:04:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-033 166	Portables Classrm 17 Girls RR	Manual	9/22/2025 4:04:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-023 152	Portables Classroom 14	Manual	9/22/2025 3:55:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-021 151	Portables Classroom 14	Manual	9/22/2025 3:56:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-020 154	Portables Classroom 14	Manual	9/22/2025 3:56:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-022 153	Portables Classroom 14	Manual	9/22/2025 3:56:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-026 155	Portables Classroom 15	Manual	9/22/2025 3:57:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-024 156	Portables Classroom 15	Manual	9/22/2025 3:58:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-025 157	Portables Classroom 15 Office	Manual	9/22/2025 3:59:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-030 160	Portables Classroom 16	Manual	9/22/2025 4:01:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-029 161	Portables Classroom 16	Manual	9/22/2025 4:01:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-036 162	Portables Classroom 17	Manual	9/22/2025 4:03:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-035 163	Portables Classroom 17	Manual	9/22/2025 4:03:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-037 164	Portables Classroom 17 Office	Manual	9/22/2025 4:03:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-290 129	Rooms 10-13 Bldg Boys Restroom	Manual	9/22/2025 4:19:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-293 113	Rooms 10-13 Bldg Classroom 10	Manual	9/22/2025 4:16:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-291 116	Rooms 10-13 Bldg Classroom 10	Manual	9/22/2025 4:16:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-292 115	Rooms 10-13 Bldg Classroom 10	Manual	9/22/2025 4:17:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-294 114	Rooms 10-13 Bldg Classroom 10	Manual	9/22/2025 4:17:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-295 117	Rooms 10-13 Bldg Classroom 11	Manual	9/22/2025 4:13:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-296 118	Rooms 10-13 Bldg Classroom 11	Manual	9/22/2025 4:13:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-298 119	Rooms 10-13 Bldg Classroom 11	Manual	9/22/2025 4:14:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-297 120	Rooms 10-13 Bldg Classroom 11	Manual	9/22/2025 4:15:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-301 121	Rooms 10-13 Bldg Classroom 12	Manual	9/22/2025 4:11:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-299 124	Rooms 10-13 Bldg Classroom 12	Manual	9/22/2025 4:11:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-300 123	Rooms 10-13 Bldg Classroom 12	Manual	9/22/2025 4:12:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-302 122	Rooms 10-13 Bldg Classroom 12	Manual	9/22/2025 4:12:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-304 126	Rooms 10-13 Bldg Classroom 13	Manual	9/22/2025 4:07:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-306 127	Rooms 10-13 Bldg Classroom 13	Manual	9/22/2025 4:08:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-303 125	Rooms 10-13 Bldg Classroom 13	Manual	9/22/2025 4:09:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-305 128	Rooms 10-13 Bldg Classroom 13	Manual	9/22/2025 4:10:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-288 130	Rooms 10-13 Bldg Custodial Closet	Manual	9/22/2025 4:18:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-289 131	Rooms 10-13 Bldg Girls Restroom	Manual	9/22/2025 4:18:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-384 132	Rooms 10-13 Bldg Light Chase Room 10	Manual	9/22/2025 4:20:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-384 133	Rooms 10-13 Bldg Light Chase Room 10	Manual	9/22/2025 4:20:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-385 135	Rooms 10-13 Bldg Light Chase Room 11	Manual	9/22/2025 4:18:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-385 134	Rooms 10-13 Bldg Light Chase Room 11	Manual	9/22/2025 4:18:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-386 136	Rooms 10-13 Bldg Light Chase Room 12	Manual	9/22/2025 4:16:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-386 137	Rooms 10-13 Bldg Light Chase Room 12	Manual	9/22/2025 4:16:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-387 139	Rooms 10-13 Bldg Light Chase Room 13	Manual	9/22/2025 4:14:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-387 138	Rooms 10-13 Bldg Light Chase Room 13	Manual	9/22/2025 4:14:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-126 210	Rooms 18-21 Bldg Attic Classroom 18	Manual	9/22/2025 5:14:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-128 213	Rooms 18-21 Bldg Attic Classroom 19	Manual	9/22/2025 5:14:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-130 215	Rooms 18-21 Bldg Attic Classroom 20	Manual	9/22/2025 5:14:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-133 221	Rooms 18-21 Bldg Attic Classroom 21	Manual	9/22/2025 5:14:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-132 217	Rooms 18-21 Bldg Attic Rm 20 Hallway	Manual	9/22/2025 5:30:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	4-132 218	Rooms 18-21 Bldg Attic Rm 20 RRs	Manual	9/22/2025 5:14:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-132 219	Rooms 18-21 Bldg Attic Rm 20 Storage	Manual	9/22/2025 5:14:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-132 216	Rooms 18-21 Bldg Attic Rm 20 Work Rm	Manual	9/22/2025 5:14:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-019 202	Rooms 18-21 Bldg Classrm 20 Boys RR	Manual	9/22/2025 5:06:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-020 203	Rooms 18-21 Bldg Classrm 20 Girls RR	Manual	9/22/2025 5:09:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-022 201	Rooms 18-21 Bldg Classrm 20 Hallway	Manual	9/22/2025 5:06:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-018 204	Rooms 18-21 Bldg Classrm 20 Storage	Manual	9/22/2025 5:06:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-023 200	Rooms 18-21 Bldg Classrm 20 Work Rm	Manual	9/22/2025 5:11:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-021 209	Rooms 18-21 Bldg Classrm 21 Storage	Manual	9/22/2025 5:10:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-005 189	Rooms 18-21 Bldg Classroom 18	Manual	9/22/2025 3:45:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-004 188	Rooms 18-21 Bldg Classroom 18	Manual	9/22/2025 5:02:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-006 190	Rooms 18-21 Bldg Classroom 18	Manual	9/22/2025 5:03:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-003 191	Rooms 18-21 Bldg Classroom 18	Manual	9/22/2025 5:03:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-127 222	Rooms 18-21 Bldg Classroom 18 HVAC	Manual	9/22/2025 5:02:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-008 195	Rooms 18-21 Bldg Classroom 19	Manual	9/22/2025 5:04:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-009 192	Rooms 18-21 Bldg Classroom 19	Manual	9/22/2025 5:04:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	4-010 193	Rooms 18-21 Bldg Classroom 19	Manual	9/22/2025 5:04:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-011 194	Rooms 18-21 Bldg Classroom 19	Manual	9/22/2025 5:04:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-129 223	Rooms 18-21 Bldg Classroom 19 HVAC	Manual	9/22/2025 5:05:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-015 199	Rooms 18-21 Bldg Classroom 20	Manual	9/22/2025 5:05:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-014 196	Rooms 18-21 Bldg Classroom 20	Manual	9/22/2025 5:06:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-016 197	Rooms 18-21 Bldg Classroom 20	Manual	9/22/2025 5:06:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-017 198	Rooms 18-21 Bldg Classroom 20	Manual	9/22/2025 5:06:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-131 224	Rooms 18-21 Bldg Classroom 20 HVAC	Manual	9/22/2025 5:06:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-026 205	Rooms 18-21 Bldg Classroom 21	Manual	9/22/2025 5:08:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-027 208	Rooms 18-21 Bldg Classroom 21	Manual	9/22/2025 5:08:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-029 207	Rooms 18-21 Bldg Classroom 21	Manual	9/22/2025 5:08:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-028 206	Rooms 18-21 Bldg Classroom 21	Manual	9/22/2025 5:09:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-134 225	Rooms 18-21 Bldg Classroom 21 HVAC	Manual	9/22/2025 5:47:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-004 040	Rooms 2-5 Bldg Classroom 2	Manual	9/22/2025 3:45:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-006 042	Rooms 2-5 Bldg Classroom 2	Manual	9/22/2025 3:46:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-007 039	Rooms 2-5 Bldg Classroom 2	Manual	9/22/2025 3:46:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-005 041	Rooms 2-5 Bldg Classroom 2	Manual	9/22/2025 5:02:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-009 043	Rooms 2-5 Bldg Classroom 3	Manual	9/22/2025 3:47:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-008 044	Rooms 2-5 Bldg Classroom 3	Manual	9/22/2025 3:47:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-011 046	Rooms 2-5 Bldg Classroom 3	Manual	9/22/2025 3:48:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-010 045	Rooms 2-5 Bldg Classroom 3	Manual	9/22/2025 3:48:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-015 047	Rooms 2-5 Bldg Classroom 4	Manual	9/22/2025 3:49:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-014 048	Rooms 2-5 Bldg Classroom 4	Manual	9/22/2025 3:49:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-012 049	Rooms 2-5 Bldg Classroom 4	Manual	9/22/2025 3:50:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-013 050	Rooms 2-5 Bldg Classroom 4	Manual	9/22/2025 3:50:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-017 051	Rooms 2-5 Bldg Classroom 5	Manual	9/22/2025 3:51:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-019 054	Rooms 2-5 Bldg Classroom 5	Manual	9/22/2025 3:52:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-018 053	Rooms 2-5 Bldg Classroom 5	Manual	9/22/2025 3:53:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-016 052	Rooms 2-5 Bldg Classroom 5	Manual	9/22/2025 3:53:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-126 058	Rooms 2-5 Bldg Light Chase Room 2	Manual	9/22/2025 3:46:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-126 057	Rooms 2-5 Bldg Light Chase Room 2	Manual	9/22/2025 3:46:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-127 059	Rooms 2-5 Bldg Light Chase Room 3	Manual	9/22/2025 3:49:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-127 060	Rooms 2-5 Bldg Light Chase Room 3	Manual	9/22/2025 3:49:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-128 062	Rooms 2-5 Bldg Light Chase Room 4	Manual	9/22/2025 3:51:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-128 061	Rooms 2-5 Bldg Light Chase Room 4	Manual	9/22/2025 3:51:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-129 063	Rooms 2-5 Bldg Light Chase Room 5	Manual	9/22/2025 5:50:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-129 064	Rooms 2-5 Bldg Light Chase Room 5	Manual	9/22/2025 5:50:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-002 055	Rooms 2-5 Bldg Storage Room A - Headend	Manual	9/22/2025 5:07:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-003 056	Rooms 2-5 Bldg Storage Room B	Manual	9/22/2025 4:28:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-271 090	Rooms 6-9 Bldg Boys Restroom	Manual	9/22/2025 4:49:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-274 074	Rooms 6-9 Bldg Classroom 6	Manual	9/22/2025 4:25:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-273 077	Rooms 6-9 Bldg Classroom 6	Manual	9/22/2025 4:26:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-272 076	Rooms 6-9 Bldg Classroom 6	Manual	9/22/2025 4:26:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-275 075	Rooms 6-9 Bldg Classroom 6	Manual	9/22/2025 4:27:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-276 078	Rooms 6-9 Bldg Classroom 7	Manual	9/22/2025 4:24:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-278 081	Rooms 6-9 Bldg Classroom 7	Manual	9/22/2025 4:24:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-279 080	Rooms 6-9 Bldg Classroom 7	Manual	9/22/2025 4:24:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-277 079	Rooms 6-9 Bldg Classroom 7	Manual	9/22/2025 4:25:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-282 082	Rooms 6-9 Bldg Classroom 8	Manual	9/22/2025 4:22:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-280 085	Rooms 6-9 Bldg Classroom 8	Manual	9/22/2025 4:22:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-281 084	Rooms 6-9 Bldg Classroom 8	Manual	9/22/2025 4:22:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-283 083	Rooms 6-9 Bldg Classroom 8	Manual	9/22/2025 4:23:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-284 086	Rooms 6-9 Bldg Classroom 9	Manual	9/22/2025 4:20:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-285 087	Rooms 6-9 Bldg Classroom 9	Manual	9/22/2025 4:20:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-287 088	Rooms 6-9 Bldg Classroom 9	Manual	9/22/2025 4:21:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-286 089	Rooms 6-9 Bldg Classroom 9	Manual	9/22/2025 4:21:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-269 091	Rooms 6-9 Bldg Custodial Closet	Manual	9/22/2025 4:47:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-270 092	Rooms 6-9 Bldg Girls Restroom	Manual	9/22/2025 4:47:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-378 093	Rooms 6-9 Bldg Light Chase Room 6	Manual	9/22/2025 4:28:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-378 094	Rooms 6-9 Bldg Light Chase Room 6	Manual	9/22/2025 4:28:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-380 096	Rooms 6-9 Bldg Light Chase Room 7	Manual	9/22/2025 4:26:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-380 095	Rooms 6-9 Bldg Light Chase Room 7	Manual	9/22/2025 4:26:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-381 097	Rooms 6-9 Bldg Light Chase Room 8	Manual	9/22/2025 4:24:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-381 098	Rooms 6-9 Bldg Light Chase Room 8	Manual	9/22/2025 4:24:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-382 099	Rooms 6-9 Bldg Light Chase Room 9	Manual	9/22/2025 4:22:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-382 100	Rooms 6-9 Bldg Light Chase Room 9	Manual	9/22/2025 4:22:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-042 240	Multi-Purpose Bldg Kitchen Storage	Manual	9/22/2025 5:07:40 PM
Heat Detector - Restorable Spot	2-383 140	Rooms 10-13 Bldg RR Plumb Chase	Manual	9/22/2025 3:37:53 PM
Heat Detector - Restorable Spot	2-379 101	Rooms 6-9 Bldg RR Plumb Chase	Manual	9/22/2025 3:37:57 PM

Failed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-131 172	Portables Attic Classroom 15	Manual	9/22/2025 6:09:42 PM
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	
Heat Detector - Restorable Spot	2-131 171	Portables Attic Classroom 15	Manual	9/22/2025 6:10:20 PM
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	

Supervising Station Transmitting Equipment

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Digital Alarm Communicator Transmitter		Rooms 2-5 Bldg Storage Room A - Dialer Panel	Manual	9/22/2025 5:03:21 PM
		Manufacturer	Bosch	
		Model	B9512G	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Monitoring Account Number	Central Station # 881-8009	
		Monitoring Organization	Central Station / SJUSD Dispatch	
		Monitoring Organization Phone	CS - 916-480-4836 / SJUSD Dispatch - 916-971-7000	

Device/Equipment details

Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Audible					
024	Admin Bldg North Exterior				
025	Admin Bldg East Exterior				
026	Admin Bldg West Exterior				
065	Rooms 2-5 Bldg Northeast Exterior				
066	Rooms 2-5 Bldg Northwest Exterior				
067	Rooms 2-5 Bldg South Exterior				
102	Rooms 6-9 Bldg Northeast Exterior				
103	Rooms 6-9 Bldg Northwest Exterior				
104	Rooms 6-9 Bldg Southeast Exterior				
105	Rooms 6-9 Bldg Southwest Exterior				
141	Rooms 10-13 Bldg Northeast Exterior				
142	Rooms 10-13 Bldg Northwest Exterior				
143	Rooms 10-13 Bldg South Exterior				
226	Rooms 18-21 Bldg North Exterior				
227	Rooms 18-21 Bldg North Exterior				
228	Rooms 18-21 Bldg South Exterior				
247	Multi-Purpose Bldg West Exterior				
Audible And Visible					
027	Admin Bldg Admin Office				
028	Admin Bldg Nurse Office				
029	Admin Bldg Copy Room				
030	Admin Bldg Staff Room				
031	Admin Bldg Learning Center				
032	Admin Bldg Classroom 1				
068	Rooms 2-5 Bldg Classroom 2				
069	Rooms 2-5 Bldg Classroom 3				
070	Rooms 2-5 Bldg Classroom 4				
071	Rooms 2-5 Bldg Classroom 5				
106	Rooms 6-9 Bldg Classroom 6				
107	Rooms 6-9 Bldg Classroom 7				
108	Rooms 6-9 Bldg Classroom 8				
109	Rooms 6-9 Bldg Classroom 9				
144	Rooms 10-13 Bldg Classroom 10				
145	Rooms 10-13 Bldg Classroom 11				
146	Rooms 10-13 Bldg Classroom 12				
147	Rooms 10-13 Bldg Classroom 13				
178	Portables Classroom 14				
179	Portables Classroom 15				
180	Portables Classroom 16				
181	Portables Classroom 17				
229	Rooms 18-21 Bldg Classroom 18				
230	Rooms 18-21 Bldg Classroom 19				
231	Rooms 18-21 Bldg Classroom 20				
232	Rooms 18-21 Bldg Classrm 20 Work Rm				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
233	Rooms 18-21 Bldg Classrm 20 Hallway				
234	Rooms 18-21 Bldg Classrm 20 Boys RR				
235	Rooms 18-21 Bldg Classrm 20 Girls RR				
236	Rooms 18-21 Bldg Classroom 21				
248	Multi-Purpose Bldg MP Room				
249	Multi-Purpose Bldg MP Room				
250	Multi-Purpose Bldg Kitchen				
Visible					
033	Admin Bldg Principals Office				
034	Admin Bldg Nurse Restroom				
035	Admin Bldg Staff Room Hall				
036	Admin Bldg Speech Room				
037	Admin Bldg Mens Restroom				
038	Admin Bldg Womens Restroom				
110	Rooms 6-9 Bldg Girls Restroom				
111	Rooms 6-9 Bldg Boys Restroom				
148	Rooms 10-13 Bldg Girls Restroom				
149	Rooms 10-13 Bldg Boys Restroom				
182	Portables Classroom 15 Office				
183	Portables Classrm 15 Boys RR				
184	Portables Classrm 15 Girls RR				
185	Portables Classroom 17 Office				
186	Portables Classrm 17 Boys RR				
187	Portables Classrm 17 Girls RR				
251	Multi-Purpose Bldg Kitchen				
252	Multi-Purpose Bldg Kitchen				

Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Remote Annunciator					
001	Admin Bldg Admin Office				
NAC Power Extender Panel					
072	Rooms 2-5 Bldg Storage Room A - P.E. "B"				
073	Rooms 2-5 Bldg Storage Room A - P.E. "C"				
112	Rooms 6-9 Bldg Custodial Closet - P.E. "E"				
150	Rooms 10-13 Bldg Custodial Closet - P.E. "D"				

Fire Alarm Panel

	Rooms 2-5 Bldg Storage Room A EST		3		
--	-----------------------------------	--	---	--	--

Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Manual Pull Station					
2-376 002	Admin Bldg Admin Office				
2-134 237	Multi-Purpose Bldg MP Room Southwest				
2-135 238	Multi-Purpose Bldg MP Room Northeast				
Smoke Detector - General					
2-258 003	Admin Bldg Admin Office				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-257 004	Admin Bldg Principals Office				
2-256 005	Admin Bldg Nurse Office				
2-255 006	Admin Bldg Nurse Restroom				
2-259 007	Admin Bldg Copy Room				
2-260 008	Admin Bldg Staff Room				
2-253 009	Admin Bldg Staff Room Hall				
2-262 010	Admin Bldg Learning Center				
2-261 011	Admin Bldg Learning Center				
2-254 012	Admin Bldg Speech Room				
2-252 013	Admin Bldg Mens Restroom				
2-251 014	Admin Bldg Womens Restroom				
2-263 015	Admin Bldg Classroom 1				
2-264 016	Admin Bldg Classroom 1				
2-266 017	Admin Bldg Classroom 1				
2-265 018	Admin Bldg Classroom 1				
2-267 019	Admin Bldg Classroom 1 Storage				
2-268 020	Admin Bldg Classroom 1 RR				
2-007 039	Rooms 2-5 Bldg Classroom 2				
2-004 040	Rooms 2-5 Bldg Classroom 2				
2-005 041	Rooms 2-5 Bldg Classroom 2				
2-006 042	Rooms 2-5 Bldg Classroom 2				
2-009 043	Rooms 2-5 Bldg Classroom 3				
2-008 044	Rooms 2-5 Bldg Classroom 3				
2-010 045	Rooms 2-5 Bldg Classroom 3				
2-011 046	Rooms 2-5 Bldg Classroom 3				
2-015 047	Rooms 2-5 Bldg Classroom 4				
2-014 048	Rooms 2-5 Bldg Classroom 4				
2-012 049	Rooms 2-5 Bldg Classroom 4				
2-013 050	Rooms 2-5 Bldg Classroom 4				
2-017 051	Rooms 2-5 Bldg Classroom 5				
2-016 052	Rooms 2-5 Bldg Classroom 5				
2-018 053	Rooms 2-5 Bldg Classroom 5				
2-019 054	Rooms 2-5 Bldg Classroom 5				
2-002 055	Rooms 2-5 Bldg Storage Room A - Headend				
2-003 056	Rooms 2-5 Bldg Storage Room B				
2-274 074	Rooms 6-9 Bldg Classroom 6				
2-275 075	Rooms 6-9 Bldg Classroom 6				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-272 076	Rooms 6-9 Bldg Classroom 6				
2-273 077	Rooms 6-9 Bldg Classroom 6				
2-276 078	Rooms 6-9 Bldg Classroom 7				
2-277 079	Rooms 6-9 Bldg Classroom 7				
2-279 080	Rooms 6-9 Bldg Classroom 7				
2-278 081	Rooms 6-9 Bldg Classroom 7				
2-282 082	Rooms 6-9 Bldg Classroom 8				
2-283 083	Rooms 6-9 Bldg Classroom 8				
2-281 084	Rooms 6-9 Bldg Classroom 8				
2-280 085	Rooms 6-9 Bldg Classroom 8				
2-284 086	Rooms 6-9 Bldg Classroom 9				
2-285 087	Rooms 6-9 Bldg Classroom 9				
2-287 088	Rooms 6-9 Bldg Classroom 9				
2-286 089	Rooms 6-9 Bldg Classroom 9				
2-271 090	Rooms 6-9 Bldg Boys Restroom				
2-269 091	Rooms 6-9 Bldg Custodial Closet				
2-270 092	Rooms 6-9 Bldg Girls Restroom				
2-293 113	Rooms 10-13 Bldg Classroom 10				
2-294 114	Rooms 10-13 Bldg Classroom 10				
2-292 115	Rooms 10-13 Bldg Classroom 10				
2-291 116	Rooms 10-13 Bldg Classroom 10				
2-295 117	Rooms 10-13 Bldg Classroom 11				
2-296 118	Rooms 10-13 Bldg Classroom 11				
2-298 119	Rooms 10-13 Bldg Classroom 11				
2-297 120	Rooms 10-13 Bldg Classroom 11				
2-301 121	Rooms 10-13 Bldg Classroom 12				
2-302 122	Rooms 10-13 Bldg Classroom 12				
2-300 123	Rooms 10-13 Bldg Classroom 12				
2-299 124	Rooms 10-13 Bldg Classroom 12				
2-303 125	Rooms 10-13 Bldg Classroom 13				
2-304 126	Rooms 10-13 Bldg Classroom 13				
2-306 127	Rooms 10-13 Bldg Classroom 13				
2-305 128	Rooms 10-13 Bldg Classroom 13				
2-290 129	Rooms 10-13 Bldg Boys Restroom				
2-288 130	Rooms 10-13 Bldg Custodial Closet				
2-289 131	Rooms 10-13 Bldg Girls Restroom				
2-021 151	Portables Classroom 14				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-023 152	Portables Classroom 14				
2-022 153	Portables Classroom 14				
2-020 154	Portables Classroom 14				
2-026 155	Portables Classroom 15				
2-024 156	Portables Classroom 15				
2-025 157	Portables Classroom 15 Office				
2-027 158	Portables Classrm 15 Boys RR				
2-028 159	Portables Classrm 15 Girls RR				
2-030 160	Portables Classroom 16				
2-029 161	Portables Classroom 16				
2-036 162	Portables Classroom 17				
2-035 163	Portables Classroom 17				
2-037 164	Portables Classroom 17 Office				
2-032 165	Portables Classrm 17 Boys RR				
2-033 166	Portables Classrm 17 Girls RR				
4-004 188	Rooms 18-21 Bldg Classroom 18				
4-005 189	Rooms 18-21 Bldg Classroom 18				
4-006 190	Rooms 18-21 Bldg Classroom 18				
4-003 191	Rooms 18-21 Bldg Classroom 18				
4-009 192	Rooms 18-21 Bldg Classroom 19				
4-010 193	Rooms 18-21 Bldg Classroom 19				
4-011 194	Rooms 18-21 Bldg Classroom 19				
4-008 195	Rooms 18-21 Bldg Classroom 19				
4-014 196	Rooms 18-21 Bldg Classroom 20				
4-016 197	Rooms 18-21 Bldg Classroom 20				
4-017 198	Rooms 18-21 Bldg Classroom 20				
4-015 199	Rooms 18-21 Bldg Classroom 20				
4-023 200	Rooms 18-21 Bldg Classrm 20 Work Rm				
4-022 201	Rooms 18-21 Bldg Classrm 20 Hallway				
4-019 202	Rooms 18-21 Bldg Classrm 20 Boys RR				
4-020 203	Rooms 18-21 Bldg Classrm 20 Girls RR				
4-018 204	Rooms 18-21 Bldg Classrm 20 Storage				
4-026 205	Rooms 18-21 Bldg Classroom 21				
4-028 206	Rooms 18-21 Bldg Classroom 21				
4-029 207	Rooms 18-21 Bldg Classroom 21				
4-027 208	Rooms 18-21 Bldg Classroom 21				
4-021 209	Rooms 18-21 Bldg Classrm 21 Storage				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-043 239	Multi-Purpose Bldg MP Room Storage				
2-042 240	Multi-Purpose Bldg Kitchen Storage				
2-309	Portable rm 22				12/04/2019
2-308	Portable rm 22				12/04/2019
2-307	Portable rm 22				12/04/2019
Heat Detector - Restorable Spot					
2-377 021	Admin Bldg Light Chase Room 1				
2-377 022	Admin Bldg Light Chase Room 1				
2-126 057	Rooms 2-5 Bldg Light Chase Room 2				
2-126 058	Rooms 2-5 Bldg Light Chase Room 2				
2-127 059	Rooms 2-5 Bldg Light Chase Room 3				
2-127 060	Rooms 2-5 Bldg Light Chase Room 3				
2-128 061	Rooms 2-5 Bldg Light Chase Room 4				
2-128 062	Rooms 2-5 Bldg Light Chase Room 4				
2-129 063	Rooms 2-5 Bldg Light Chase Room 5				
2-129 064	Rooms 2-5 Bldg Light Chase Room 5				
2-378 093	Rooms 6-9 Bldg Light Chase Room 6				
2-378 094	Rooms 6-9 Bldg Light Chase Room 6				
2-380 095	Rooms 6-9 Bldg Light Chase Room 7				
2-380 096	Rooms 6-9 Bldg Light Chase Room 7				
2-381 097	Rooms 6-9 Bldg Light Chase Room 8				
2-381 098	Rooms 6-9 Bldg Light Chase Room 8				
2-382 099	Rooms 6-9 Bldg Light Chase Room 9				
2-382 100	Rooms 6-9 Bldg Light Chase Room 9				
2-379 101	Rooms 6-9 Bldg RR Plumb Chase				
2-384 132	Rooms 10-13 Bldg Light Chase Room 10				
2-384 133	Rooms 10-13 Bldg Light Chase Room 10				
2-385 134	Rooms 10-13 Bldg Light Chase Room 11				
2-385 135	Rooms 10-13 Bldg Light Chase Room 11				
2-386 136	Rooms 10-13 Bldg Light Chase Room 12				
2-386 137	Rooms 10-13 Bldg Light Chase Room 12				
2-387 138	Rooms 10-13 Bldg Light Chase Room 13				
2-387 139	Rooms 10-13 Bldg Light Chase Room 13				
2-383 140	Rooms 10-13 Bldg RR Plumb Chase				
2-130 168	Portables Attic Classroom 14				
2-130 169	Portables Attic Classroom 14				
2-130 170	Portables Attic Classroom 14				
2-131 171	Portables Attic Classroom 15				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-131 172	Portables Attic Classroom 15				
2-132 173	Portables Attic Classroom 16				
2-132 174	Portables Attic Classroom 16				
2-133 175	Portables Attic Classroom 17				
2-133 176	Portables Attic Classroom 17				
2-133 177	Portables Attic Classroom 17				
4-126 210	Rooms 18-21 Bldg Attic Classroom 18				
4-128 213	Rooms 18-21 Bldg Attic Classroom 19				
4-130 215	Rooms 18-21 Bldg Attic Classroom 20				
4-132 216	Rooms 18-21 Bldg Attic Rm 20 Work Rm				
4-132 217	Rooms 18-21 Bldg Attic Rm 20 Hallway				
4-132 218	Rooms 18-21 Bldg Attic Rm 20 RRs				
4-132 219	Rooms 18-21 Bldg Attic Rm 20 Storage				
4-133 221	Rooms 18-21 Bldg Attic Classroom 21				
4-127 222	Rooms 18-21 Bldg Classroom 18 HVAC				
4-129 223	Rooms 18-21 Bldg Classroom 19 HVAC				
4-131 224	Rooms 18-21 Bldg Classroom 20 HVAC				
4-134 225	Rooms 18-21 Bldg Classroom 21 HVAC				
2-038 241	Multi-Purpose Bldg Kitchen				
2-039 242	Multi-Purpose Bldg Kitchen				
2-136 243	Multi-Purpose Bldg Attic Kitchen				
2-137 244	Multi-Purpose Bldg Attic Kitchen				
2-034	Classroom 17				12/04/2019
2-388	Portables Attic Classroom 22				12/04/2019
Smoke Detector - Duct					
2-392 023	Admin Bldg Admin Building				
Smoke Detector - Projected Beam					
2-146 245	Multi-Purpose Bldg MP Room East				
2-148 246	Multi-Purpose Bldg MP Room West				
Supervising Station Transmitting Equipment					
ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Digital Alarm Communicator Transmitter					
	Rooms 2-5 Bldg Storage Room A - Dialer Panel	Bosch	B9512G		