

Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

RIO AMERICANO HIGH

4540 AMERICAN RIVER DR
SACRAMENTO, California 95864
United States

This site has been inspected and tested in compliance with applicable standards.

Completed

Tuesday, September 30, 2025

Test Session:08 Sep 2025 15:42 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD
5320 HEMLOCK ST
SACRAMENTO, California
United States

TESTED BY

Riley Goyet
Western States Fire Protection-
Sacramento
188 Cirby Way
Roseville, CA 95678
United States



Inspection Summary

Building Information

PROPERTY	RIO AMERICANO HIGH	CONTACT
ADDRESS	4540 AMERICAN RIVER DR	PHONE
CITY/STATE	SACRAMENTO, California 95864	MOBILE
COUNTRY	United States	EMAIL

Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us

Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Ventilation and Cooking Equipment	5	0(0%)	0(0%)	0(0%)
Power Supplies	1	1(100%)	1(100%)	0(0%)
Fire Control Panel	19	19(100%)	16(84%)	3(16%)
Initiating Device	661	661(100%)	661(100%)	0(0%)

Certification

The equipment specified here in was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Tuesday, September 30, 2025

ACCEPTED BY 09/30/2025

Building Representative



TESTED BY 09/30/2025

Riley Goyet
Technician

System Details

Control Units

ADDRESS/ SCAN ADDRESS	DESCRIPTION	New Theater Building IDF/FACP Room
MANUFACTURER	S/W VERSION	
MODEL	LAST UPDATE	
SERIAL NUMBER	S/W LOCATION	
INSTALL DATE		

Secondary Power

Open Corrective Action & Solution Summary

The following 5 corrective action(s) remain open following the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
NAC Power Extender Panel	338	Portables Classroom P8 - P.E. "P"
	Created By:	Riley Goyet
	Creation Date:	10/15/2024
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
NAC Power Extender Panel	399	Cafeteria Bldgs Telecom Room - P.E."E"
	Created By:	Riley Goyet
	Creation Date:	10/15/2024
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	Fire Lite
	Model:	
NAC Power Extender Panel	400	Cafeteria Bldgs Telecom Room - P.E."F"
	Created By:	Riley Goyet
	Creation Date:	10/15/2024
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	Fire Lite
	Model:	
NAC Power Extender Panel		New Theater Building FACP Room - P.E. "A"
	Created By:	Riley Goyet
	Creation Date:	10/15/2024
	Corrective Action:	Replace (2) 12V 7AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
FACP		H Wing Room H5 Telecom Rm
	Created By:	Riley Goyet
	Creation Date:	10/15/2024
	Corrective Action:	Replace (2) 12V 55AH Batteries
	Proposed Solution:	
	Manufacturer:	Fire Lite
	Model:	

Resolved Corrective Action & Solution Summary

The following 2 corrective action(s) were resolved during the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
NAC Power Extender Panel	237	H Wing Room H5 Telecom Rm - P.E. "G"

Created By: Riley Goyet
 Creation Date: 10/15/2024
 Corrective Action: Replace (2) 12V 8AH Batteries
 Resolution:
 Resolved By: Riley Goyet
 Resolved On: 09/11/2025
 Manufacturer: Fire Lite
 Model:

Fire Alarm Panel		New Theater Building IDF/FACP Room
------------------	--	------------------------------------

Created By: Riley Goyet
 Creation Date: 10/15/2024
 Corrective Action: Replace (2) 12V 55AH Batteries
 Resolution:
 Resolved By: Riley Goyet
 Resolved On: 09/11/2025
 Manufacturer:
 Model:

Testing Details

Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
NAC Power Extender Panel	054	Admin Library Bldg FACP Room - P.E. "B"	Manual	9/11/2025 9:37:31 AM
		Manufacturer	Fire Lite	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	053	Admin Library Bldg FACP Room - P.E. "Master"	Manual	9/11/2025 9:37:29 AM
		Manufacturer	Fire Lite	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Remote Annunciator	001	Admin Library Bldg Secretary Desk	Manual	9/10/2025 7:36:54 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	398	Cafeteria Bldgs Telecom Room - P.E. "C"	Manual	9/11/2025 9:37:47 AM
		Manufacturer	Fire Lite	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	574	Gym Locker Bldgs Hall Equip Rm by Small Gym - P.E "Q"	Manual	9/10/2025 7:37:00 PM
		Manufacturer	Fire Lite	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	575	Gym Locker Bldgs Hall Equip Rm by Small Gym - P.E "R"	Manual	9/11/2025 9:38:10 AM
		Manufacturer	Fire Lite	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	576	Gym Locker Bldgs Hall Equip Rm by Small Gym - P.E "T"	Manual	9/11/2025 9:38:09 AM
		Manufacturer	Fire Lite	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	577	Gym Locker Bldgs Hall Equip Rm by Small Gym - P.E "V"	Manual	9/11/2025 9:38:07 AM
		Manufacturer	Fire Lite	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	237	H Wing Room H5 Telecom Rm - P.E. "G"	Manual	9/11/2025 9:37:42 AM
		Manufacturer	Fire Lite	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	260	I Wing Classroom I 4 - P.E. "I"	Manual	9/11/2025 9:37:45 AM
		Manufacturer	Fire Lite	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	261	I Wing Classroom I 4 - P.E. "J"	Manual	9/11/2025 9:37:44 AM
		Manufacturer	Fire Lite	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		New Theater Building FACP Room - P.E. "A"	Manual	9/11/2025 9:38:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Fire Alarm Panel		New Theater Building IDF/FACP Room	Manual	9/11/2025 9:38:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	473	Theater Building Equipment Room - P.E. "K"	Manual	9/11/2025 9:37:35 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	474	Theater Building Equipment Room - P.E. "L"	Manual	9/11/2025 9:37:33 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	475	Theater Building Equipment Room - P.E. "N"	Manual	9/11/2025 9:37:32 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Failed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
NAC Power Extender Panel	399	Cafeteria Bldgs Telecom Room - P.E."E"	Manual	9/10/2025 7:37:39 PM
		Manufacturer	Fire Lite	
		Visual inspection	Failed (Manual)	
NAC Power Extender Panel	400	Cafeteria Bldgs Telecom Room - P.E."F"	Manual	9/10/2025 7:37:29 PM
		Manufacturer	Fire Lite	
		Visual inspection	Failed (Manual)	
NAC Power Extender Panel	338	Portables Classroom P8 - P.E. "P"	Manual	9/10/2025 7:37:25 PM
		Visual inspection	Failed (Manual)	

Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2 3 383	A Wing Attic Classroom A11	Manual	9/9/2025 5:07:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 3 383 085	A Wing Attic Classroom A11	Manual	9/9/2025 5:07:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 3 384 083	A Wing Attic Classroom A4A	Manual	9/9/2025 5:07:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 3 384 084	A Wing Attic Classroom A4A	Manual	9/9/2025 5:07:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 341 056	A Wing Classroom A1	Manual	9/9/2025 5:08:23 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 320 055	A Wing Classroom A1	Manual	9/9/2025 5:08:26 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 311 073	A Wing Classroom A10	Manual	9/9/2025 5:07:37 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2 3 310 074	A Wing Classroom A10	Manual	9/9/2025 5:07:51 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 315 075	A Wing Classroom A11	Manual	9/9/2025 5:07:43 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 314 076	A Wing Classroom A11	Manual	9/9/2025 5:07:58 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 313 077	A Wing Classroom A12	Manual	9/9/2025 5:07:38 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 312 078	A Wing Classroom A12	Manual	9/9/2025 5:08:00 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 317 080	A Wing Classroom A13	Manual	9/9/2025 5:07:40 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 316 079	A Wing Classroom A13	Manual	9/9/2025 5:07:41 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 319 081	A Wing Classroom A14	Manual	9/9/2025 5:07:46 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 318 082	A Wing Classroom A14	Manual	9/9/2025 5:07:48 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 342 058	A Wing Classroom A2	Manual	9/9/2025 5:08:20 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 321 057	A Wing Classroom A2	Manual	9/9/2025 5:08:22 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 322 060	A Wing Classroom A3	Manual	9/9/2025 5:08:17 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 343 059	A Wing Classroom A3	Manual	9/9/2025 5:08:19 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2 3 323 061	A Wing Classroom A4A	Manual	9/9/2025 5:08:09 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 325 062	A Wing Classroom A4A	Manual	9/9/2025 5:08:10 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 327 064	A Wing Classroom A4B	Manual	9/9/2025 5:08:14 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 326 063	A Wing Classroom A4B	Manual	9/9/2025 5:08:15 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 344 066	A Wing Classroom A5	Manual	9/9/2025 5:08:06 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 328 065	A Wing Classroom A5	Manual	9/9/2025 5:08:07 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 345 068	A Wing Classroom A6	Manual	9/9/2025 5:08:03 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 329 067	A Wing Classroom A6	Manual	9/9/2025 5:08:04 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 324 069	A Wing Classroom A7	Manual	9/9/2025 5:08:11 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 330 070	A Wing Classroom A7	Manual	9/9/2025 5:08:13 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 308 071	A Wing Classroom A8	Manual	9/9/2025 5:08:01 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 309 072	A Wing Classroom A9	Manual	9/9/2025 5:07:49 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 039 012	Admin Library Bldg Admin Athletic Office	Manual	9/9/2025 5:09:42 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	1 2 002 013	Admin Library Bldg Admin Front Hall	Manual	9/9/2025 5:09:40 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 009 024	Admin Library Bldg Attendance Office	Manual	9/9/2025 5:09:24 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 134 047	Admin Library Bldg Attic Conference Room	Manual	9/11/2025 9:39:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 131 051	Admin Library Bldg Attic Library Computer Lab	Manual	9/9/2025 5:15:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 130 052	Admin Library Bldg Attic Library N. Book Storage	Manual	9/9/2025 5:15:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 132 050	Admin Library Bldg Attic Library Office	Manual	9/9/2025 5:16:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 133 048	Admin Library Bldg Attic Principals Office	Manual	9/11/2025 9:39:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 135 046	Admin Library Bldg Attic Secretary Desk	Manual	9/9/2025 5:16:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 137 049	Admin Library Bldg Attic West Restroom	Manual	9/9/2025 5:16:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 006 018	Admin Library Bldg Back VP Office	Manual	9/9/2025 5:09:31 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 040 015	Admin Library Bldg Campus Monitor Office	Manual	9/9/2025 5:09:37 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 026 007	Admin Library Bldg Conference Room	Manual	9/9/2025 5:09:46 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 027 008	Admin Library Bldg Conference Room Closet	Manual	9/10/2025 7:34:05 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 023 025	Admin Library Bldg Copy Room	Manual	9/9/2025 5:09:54 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 001 021	Admin Library Bldg FACP Room	Manual	9/9/2025 5:09:25 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 028 009	Admin Library Bldg Front Door Closet	Manual	9/9/2025 5:16:04 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 003 014	Admin Library Bldg Front Restroom	Manual	9/9/2025 5:09:39 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 004 016	Admin Library Bldg Front VP Office	Manual	9/9/2025 5:09:35 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 014 033	Admin Library Bldg Library	Manual	9/9/2025 5:16:08 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 013 036	Admin Library Bldg Library	Manual	9/9/2025 5:16:09 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 018 035	Admin Library Bldg Library	Manual	9/9/2025 5:16:11 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 017 034	Admin Library Bldg Library	Manual	9/9/2025 5:16:12 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 016 031	Admin Library Bldg Library	Manual	9/10/2025 7:36:02 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 015 032	Admin Library Bldg Library	Manual	9/10/2025 7:36:13 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 012 040	Admin Library Bldg Library Computer Lab	Manual	9/9/2025 5:09:58 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 008 042	Admin Library Bldg Library E. Book Store Rm	Manual	9/10/2025 7:33:19 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 036 043	Admin Library Bldg Library East Office	Manual	9/10/2025 7:35:56 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 020 038	Admin Library Bldg Library Finance Office	Manual	9/10/2025 7:33:25 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 011 041	Admin Library Bldg Library N. Book Store Rm	Manual	9/9/2025 5:09:59 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	1 2 145 003	Admin Library Bldg Library NW Exit	Manual	9/9/2025 5:16:15 PM
		Manufacturer	FCI	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 021 037	Admin Library Bldg Library Office	Manual	9/10/2025 7:33:20 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 022 044	Admin Library Bldg Library SE Corner Office	Manual	9/9/2025 5:09:56 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	1 2 148 004	Admin Library Bldg Library SW Exit	Manual	9/10/2025 7:36:59 PM
		Manufacturer	FCI	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 019 039	Admin Library Bldg Library W. Corner Office	Manual	9/9/2025 5:16:22 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 031 027	Admin Library Bldg Mid Hall Restroom	Manual	9/9/2025 5:09:50 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 034 029	Admin Library Bldg Mid Hall Restroom	Manual	9/9/2025 5:09:52 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 032 026	Admin Library Bldg Middle Hall	Manual	9/9/2025 5:09:49 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 033 028	Admin Library Bldg Middle Hall Closet	Manual	9/9/2025 5:16:14 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 005 017	Admin Library Bldg Middle VP Office	Manual	9/9/2025 5:09:34 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 041 019	Admin Library Bldg North Hall	Manual	9/9/2025 5:09:33 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 035 030	Admin Library Bldg Phone Room	Manual	9/9/2025 5:09:53 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 025 006	Admin Library Bldg Principals Office	Manual	9/9/2025 5:09:44 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 030 010	Admin Library Bldg Room at Safe	Manual	9/9/2025 5:09:47 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 037 011	Admin Library Bldg Safe Room	Manual	9/9/2025 5:16:06 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	1 2 136 002	Admin Library Bldg Secretary Desk	Manual	9/10/2025 7:36:48 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 029 005	Admin Library Bldg Secretary Desk	Manual	9/9/2025 5:09:43 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 024 045	Admin Library Bldg Staff Room	Manual	9/11/2025 9:39:54 AM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 038 022	Admin Library Bldg Storage Rm by FACP	Manual	9/9/2025 5:09:28 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 007 020	Admin Library Bldg Suspension Room	Manual	9/9/2025 5:09:27 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 010 023	Admin Library Bldg VP Secretary Office	Manual	9/9/2025 5:09:30 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 3 380 116	B Wing Attic Classroom B12	Manual	9/9/2025 5:06:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 3 380 115	B Wing Attic Classroom B12	Manual	9/9/2025 5:06:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 3 385 114	B Wing Attic Classroom B4A	Manual	9/9/2025 5:06:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 3 385	B Wing Attic Classroom B4B	Manual	9/9/2025 5:06:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2 3 346 086	B Wing Classroom B1	Manual	9/9/2025 5:06:12 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 333 087	B Wing Classroom B1	Manual	9/9/2025 5:06:14 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 291 105	B Wing Classroom B10	Manual	9/9/2025 5:06:35 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 297 107	B Wing Classroom B11	Manual	9/9/2025 5:06:46 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 298 106	B Wing Classroom B11	Manual	9/9/2025 5:06:50 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 295 109	B Wing Classroom B12	Manual	9/9/2025 5:06:41 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 296 108	B Wing Classroom B12	Manual	9/9/2025 5:06:45 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 301 111	B Wing Classroom B13	Manual	9/9/2025 5:06:48 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 302 110	B Wing Classroom B13	Manual	9/9/2025 5:06:49 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 300 112	B Wing Classroom B14	Manual	9/9/2025 5:06:38 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 299 113	B Wing Classroom B15	Manual	9/9/2025 5:06:39 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 347 088	B Wing Classroom B2	Manual	9/9/2025 5:06:16 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 332 089	B Wing Classroom B2	Manual	9/9/2025 5:06:17 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2 3 348 091	B Wing Classroom B3	Manual	9/9/2025 5:06:19 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 331 090	B Wing Classroom B3	Manual	9/9/2025 5:06:20 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 334 092	B Wing Classroom B4A	Manual	9/9/2025 5:06:21 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 335 093	B Wing Classroom B4A	Manual	9/9/2025 5:06:23 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 336 094	B Wing Classroom B4B	Manual	9/9/2025 5:06:09 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 337 095	B Wing Classroom B4C	Manual	9/9/2025 5:06:11 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 349 097	B Wing Classroom B5	Manual	9/9/2025 5:06:07 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 340 096	B Wing Classroom B5	Manual	9/9/2025 5:06:08 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 350 098	B Wing Classroom B6	Manual	9/9/2025 5:06:27 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 339 099	B Wing Classroom B6	Manual	9/9/2025 5:06:29 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 338 100	B Wing Classroom B7	Manual	9/9/2025 5:06:24 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 351 101	B Wing Classroom B7	Manual	9/9/2025 5:06:25 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 294 102	B Wing Classroom B8	Manual	9/9/2025 5:06:04 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2 3 293 103	B Wing Classroom B8	Manual	9/9/2025 5:06:05 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 292 104	B Wing Classroom B9	Manual	9/9/2025 5:06:37 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 3 133 136	C Wing Attic Classroom C12B	Manual	9/11/2025 9:39:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 102 133	C Wing C Bldg Center Storage	Manual	9/11/2025 9:38:43 AM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 101 134	C Wing C Bldg Center Storage	Manual	9/11/2025 9:38:46 AM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 103 135	C Wing C Bldg Center Storage	Manual	9/11/2025 9:38:51 AM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 099 132	C Wing C Bldg Storage	Manual	9/11/2025 9:39:15 AM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 097 131	C Wing C Bldg Storage	Manual	9/11/2025 9:39:16 AM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 086 120	C Wing Classroom C10	Manual	9/11/2025 9:38:36 AM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 087 119	C Wing Classroom C10	Manual	9/11/2025 9:38:38 AM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 092 121	C Wing Classroom C11	Manual	9/11/2025 9:38:49 AM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 098 122	C Wing Classroom C11A	Manual	9/11/2025 9:38:48 AM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 096 124	C Wing Classroom C11B	Manual	9/11/2025 9:38:39 AM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2 3 095 123	C Wing Classroom C11B	Manual	9/11/2025 9:39:14 AM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 093 126	C Wing Classroom C12A	Manual	9/11/2025 9:38:42 AM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 094 125	C Wing Classroom C12A	Manual	9/11/2025 9:38:45 AM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 091 127	C Wing Classroom C13	Manual	9/11/2025 9:39:00 AM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 090 128	C Wing Classroom C14	Manual	9/11/2025 9:38:58 AM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 088 129	C Wing Classroom C15	Manual	9/11/2025 9:38:56 AM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 089 130	C Wing Classroom C15	Manual	9/11/2025 9:38:57 AM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 084 117	C Wing Classroom C8	Manual	9/11/2025 9:38:53 AM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 085 118	C Wing Classroom C9	Manual	9/11/2025 9:38:54 AM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 289 380	Cafeteria Bldgs Attendance E Office	Manual	9/9/2025 5:04:29 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 290 381	Cafeteria Bldgs Attendance E Office	Manual	9/9/2025 5:04:31 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 288 379	Cafeteria Bldgs Attendance E Office	Manual	9/9/2025 5:04:39 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 287 378	Cafeteria Bldgs Attendance Front Off	Manual	9/9/2025 5:04:32 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2 3 286 377	Cafeteria Bldgs Attendance Front Off	Manual	9/9/2025 5:04:33 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 285 376	Cafeteria Bldgs Attendance W Office	Manual	9/9/2025 5:04:35 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 283 375	Cafeteria Bldgs Attendance W Office	Manual	9/9/2025 5:04:36 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 284 374	Cafeteria Bldgs Attendance W Office	Manual	9/9/2025 5:04:38 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 3 379 396	Cafeteria Bldgs Attic Attend E Office	Manual	9/9/2025 5:05:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 3 378 395	Cafeteria Bldgs Attic Attend W Office	Manual	9/9/2025 5:05:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 3 381 397	Cafeteria Bldgs Attic Kitch Food Storage	Manual	9/9/2025 5:05:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 3 377 392	Cafeteria Bldgs Attic Staff Room	Manual	9/9/2025 5:05:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 3 377 393	Cafeteria Bldgs Attic Staff Room	Manual	9/9/2025 5:05:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 3 377 394	Cafeteria Bldgs Attic Staff Room	Manual	9/9/2025 5:05:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 3 376 391	Cafeteria Bldgs Attic West Hall	Manual	9/9/2025 5:05:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 3 382 390	Cafeteria Bldgs Boiler Room	Manual	9/9/2025 5:05:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 3 382 389	Cafeteria Bldgs Boiler Room	Manual	9/9/2025 5:05:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 282 373	Cafeteria Bldgs Boys W Restroom	Manual	9/9/2025 5:05:19 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 268 359	Cafeteria Bldgs Cafe E. Hall Entry	Manual	9/9/2025 5:04:56 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	2 3 269 358	Cafeteria Bldgs Cafe E. Restroom	Manual	9/9/2025 5:04:57 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 271 360	Cafeteria Bldgs Cafe Mid Hall E. Closet	Manual	9/9/2025 5:04:45 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 270 361	Cafeteria Bldgs Cafe Mid Hall E. Closet	Manual	9/9/2025 5:04:47 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 278 369	Cafeteria Bldgs Cafe Mid Hall W. Closet	Manual	9/9/2025 5:04:51 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 279 370	Cafeteria Bldgs Cafe Mid Hall W. Closet	Manual	9/9/2025 5:04:53 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 273 363	Cafeteria Bldgs Cafe Middle Hall	Manual	9/9/2025 5:04:43 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 277 367	Cafeteria Bldgs Cafe Middle Hall	Manual	9/9/2025 5:04:50 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 272 362	Cafeteria Bldgs Cafe Middle Hall RR	Manual	9/9/2025 5:04:48 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 276 368	Cafeteria Bldgs Cafe Middle Hall RR	Manual	9/9/2025 5:05:22 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 275 365	Cafeteria Bldgs Cafe Staff Room	Manual	9/9/2025 5:04:41 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 274 364	Cafeteria Bldgs Cafe Staff Room	Manual	9/9/2025 5:04:42 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 281 372	Cafeteria Bldgs Cafe W. Hall Entry	Manual	9/9/2025 5:05:18 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 267 356	Cafeteria Bldgs Cafeteria Closet	Manual	9/9/2025 5:05:29 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Manual Pull Station	2 3 392 341	Cafeteria Bldgs Cafeteria NE Exit	Manual	9/9/2025 5:05:51 PM
		Manufacturer	FCI	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2 3 389 340	Cafeteria Bldgs Cafeteria NW Exit	Manual	9/9/2025 5:05:52 PM
		Manufacturer	FCI	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 280 371	Cafeteria Bldgs Cafeteria Restroom	Manual	9/9/2025 5:05:21 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2 3 391 342	Cafeteria Bldgs Cafeteria SE Exit	Manual	9/9/2025 5:05:55 PM
		Manufacturer	FCI	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2 3 390 339	Cafeteria Bldgs Cafeteria SW Exit	Manual	9/9/2025 5:05:54 PM
		Manufacturer	FCI	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 352 366	Cafeteria Bldgs E. Girls Restroom	Manual	9/9/2025 5:05:23 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 3 253 387	Cafeteria Bldgs Food Booth	Manual	9/9/2025 5:05:34 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 3 307 388	Cafeteria Bldgs Kitchen	Manual	9/9/2025 5:05:43 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 305 382	Cafeteria Bldgs Kitchen	Manual	9/9/2025 5:05:26 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 303 385	Cafeteria Bldgs Kitchen Food Storage	Manual	9/9/2025 5:05:31 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 304 384	Cafeteria Bldgs Kitchen Hall	Manual	9/9/2025 5:05:25 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 306 383	Cafeteria Bldgs Kitchen Restroom	Manual	9/9/2025 5:05:28 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 266 355	Cafeteria Bldgs Main Cafeteria Room	Manual	9/9/2025 5:04:54 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	2 3 265 353	Cafeteria Bldgs Main Cafeteria Room	Manual	9/9/2025 5:04:58 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 259 354	Cafeteria Bldgs Main Cafeteria Room	Manual	9/9/2025 5:05:00 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 258 343	Cafeteria Bldgs Main Cafeteria Room	Manual	9/9/2025 5:05:01 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 264 352	Cafeteria Bldgs Main Cafeteria Room	Manual	9/9/2025 5:05:02 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 263 351	Cafeteria Bldgs Main Cafeteria Room	Manual	9/9/2025 5:05:04 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 257 344	Cafeteria Bldgs Main Cafeteria Room	Manual	9/9/2025 5:05:05 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 256 345	Cafeteria Bldgs Main Cafeteria Room	Manual	9/9/2025 5:05:07 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 262 350	Cafeteria Bldgs Main Cafeteria Room	Manual	9/9/2025 5:05:08 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 261 349	Cafeteria Bldgs Main Cafeteria Room	Manual	9/9/2025 5:05:11 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 255 346	Cafeteria Bldgs Main Cafeteria Room	Manual	9/9/2025 5:05:12 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 254 347	Cafeteria Bldgs Main Cafeteria Room	Manual	9/9/2025 5:05:13 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 260 348	Cafeteria Bldgs Main Cafeteria Room	Manual	9/9/2025 5:05:15 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 3 252 386	Cafeteria Bldgs Sales Booth	Manual	9/9/2025 5:05:32 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	2 3 251 357	Cafeteria Bldgs Telecom Room	Manual	9/9/2025 5:05:16 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 3 132 168	D Wing Attic Classrm D10	Manual	9/8/2025 4:14:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 3 131 169	D Wing Attic Classrm D11B	Manual	9/8/2025 4:14:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 3 130 170	D Wing Attic Classrm D12	Manual	9/8/2025 4:14:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 3 128 166	D Wing Attic Classrm D4A	Manual	9/8/2025 4:14:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 3 129 167	D Wing Attic Classrm D4B	Manual	9/8/2025 4:14:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 047 137	D Wing Classroom D1	Manual	9/8/2025 4:13:35 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 048 138	D Wing Classroom D1	Manual	9/8/2025 4:13:40 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 060 154	D Wing Classroom D10	Manual	9/8/2025 4:14:21 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 067 155	D Wing Classroom D10A	Manual	9/8/2025 4:14:36 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 068 157	D Wing Classroom D11	Manual	9/8/2025 4:14:33 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 065 158	D Wing Classroom D12	Manual	9/8/2025 4:14:28 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 064 159	D Wing Classroom D12	Manual	9/8/2025 4:14:30 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 3 070 165	D Wing Classroom D13	Manual	9/8/2025 4:14:38 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 3 069 164	D Wing Classroom D13	Manual	9/8/2025 4:14:52 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 071 160	D Wing Classroom D14	Manual	9/8/2025 4:13:34 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 072 161	D Wing Classroom D15	Manual	9/8/2025 4:13:29 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 045 139	D Wing Classroom D2	Manual	9/8/2025 4:13:45 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 046 140	D Wing Classroom D2	Manual	9/8/2025 4:13:47 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 100 141	D Wing Classroom D3	Manual	9/8/2025 4:13:52 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 044 142	D Wing Classroom D3	Manual	9/8/2025 4:14:05 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 057 143	D Wing Classroom D4A	Manual	9/8/2025 4:13:49 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 056 144	D Wing Classroom D4A	Manual	9/8/2025 4:13:50 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 059 145	D Wing Classroom D4B	Manual	9/8/2025 4:13:42 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 058 146	D Wing Classroom D4B	Manual	9/8/2025 4:13:44 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 050 148	D Wing Classroom D5	Manual	9/8/2025 4:13:37 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 049 147	D Wing Classroom D5	Manual	9/8/2025 4:13:38 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	2 3 052 150	D Wing Classroom D6	Manual	9/8/2025 4:14:09 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 051 149	D Wing Classroom D6	Manual	9/8/2025 4:14:14 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 053 151	D Wing Classroom D7	Manual	9/8/2025 4:14:16 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 055 152	D Wing Classroom D7	Manual	9/8/2025 4:14:18 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 3 063 162	D Wing Classroom D8	Manual	9/8/2025 4:14:55 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 3 062 163	D Wing Classroom D8	Manual	9/8/2025 4:14:57 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 061 153	D Wing Classroom D9	Manual	9/8/2025 4:14:24 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 066 156	D Wing Storage D10B	Manual	9/8/2025 4:14:31 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 3 142 182	E Wing Attic Closet	Manual	9/11/2025 9:40:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 079 179	E Wing Boys Restroom	Manual	9/10/2025 7:35:55 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 080 178	E Wing Boys Restroom Entry	Manual	9/10/2025 7:35:53 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 082 172	E Wing Classroom E1	Manual	9/10/2025 7:35:49 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 081 171	E Wing Classroom E1	Manual	9/11/2025 9:39:01 AM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2 3 073 174	E Wing Classroom E2	Manual	9/10/2025 7:35:43 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 074 173	E Wing Classroom E2	Manual	9/10/2025 7:35:44 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 078 177	E Wing E Bldg Closet	Manual	9/10/2025 7:35:48 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 075 176	E Wing E Bldg Hall	Manual	9/10/2025 7:35:46 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 083 175	E Wing E Bldg Hall	Manual	9/11/2025 9:39:46 AM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 077 181	E Wing Girls Restroom	Manual	9/10/2025 7:35:52 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 076 180	E Wing Girls Restroom Entry	Manual	9/10/2025 7:35:50 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 389 591	Football Stadium Attic Snack Bar RRs	Manual	9/11/2025 9:40:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 389 592	Football Stadium Attic Snack Bar RRs	Manual	9/11/2025 9:40:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 389 593	Football Stadium Attic Snack Bar RRs	Manual	9/11/2025 9:40:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 345 588	Football Stadium Mens Restroom	Manual	9/11/2025 9:39:43 AM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 343 590	Football Stadium Snack Bar	Manual	9/11/2025 9:40:08 AM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 344 589	Football Stadium Womens Restroom	Manual	9/11/2025 9:39:45 AM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 381 570	Gym Locker Bldgs Attic Lrg Gym Foyer	Manual	9/10/2025 9:40:03 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 377 569	Gym Locker Bldgs Boiler Rm Outside Girls Locker	Manual	9/10/2025 7:37:02 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 379 553	Gym Locker Bldgs Boys Coach Off RR	Manual	9/10/2025 9:40:32 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 379 554	Gym Locker Bldgs Boys Coach Off RR	Manual	9/10/2025 9:40:34 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 263 537	Gym Locker Bldgs Boys Coach Office	Manual	9/10/2025 7:33:35 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 266 536	Gym Locker Bldgs Boys Locker Closet	Manual	9/10/2025 9:42:00 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 267 546	Gym Locker Bldgs Boys Locker Entry	Manual	9/10/2025 7:37:04 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 380 548	Gym Locker Bldgs Boys Locker Room	Manual	9/10/2025 7:37:05 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 380 547	Gym Locker Bldgs Boys Locker Room	Manual	9/10/2025 7:37:07 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 269 550	Gym Locker Bldgs Boys Locker Room	Manual	9/10/2025 7:37:09 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 271 551	Gym Locker Bldgs Boys Locker Room	Manual	9/10/2025 9:42:24 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 376 545	Gym Locker Bldgs Boys Locker Room RR	Manual	9/10/2025 9:40:26 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 268 534	Gym Locker Bldgs Boys Locker Storage	Manual	9/10/2025 7:33:38 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 252 544	Gym Locker Bldgs E. Storage Outside Girls Locker	Manual	9/10/2025 9:42:11 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 378 566	Gym Locker Bldgs Football Storage Rm	Manual	9/10/2025 9:40:38 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 379 555	Gym Locker Bldgs Girls Coach Off RR	Manual	9/10/2025 9:40:35 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 262 538	Gym Locker Bldgs Girls Coach Office	Manual	9/10/2025 7:33:33 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 255 540	Gym Locker Bldgs Girls Lock Hall Closet	Manual	9/10/2025 9:40:45 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 259 542	Gym Locker Bldgs Girls Lock O S Strg	Manual	9/10/2025 9:42:12 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 253 539	Gym Locker Bldgs Girls Locker Restroom	Manual	9/10/2025 9:40:46 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 254 562	Gym Locker Bldgs Girls Locker Rm Hall	Manual	9/10/2025 9:40:36 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 256 563	Gym Locker Bldgs Girls Locker Room	Manual	9/10/2025 9:40:24 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 378 565	Gym Locker Bldgs Girls Locker Room	Manual	9/10/2025 9:40:40 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 378 564	Gym Locker Bldgs Girls Locker Room	Manual	9/10/2025 9:40:42 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 258 568	Gym Locker Bldgs Girls Locker Room	Manual	9/10/2025 9:42:14 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 257 567	Gym Locker Bldgs Girls Locker Room	Manual	9/10/2025 9:42:15 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 260 543	Gym Locker Bldgs Girls Locker Storage	Manual	9/10/2025 9:40:48 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	1 2 261 541	Gym Locker Bldgs Girls Locker Storage	Manual	9/10/2025 9:41:58 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 387 557	Gym Locker Bldgs Gym Locker Hallway	Manual	9/10/2025 9:42:04 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 387 558	Gym Locker Bldgs Gym Locker Hallway	Manual	9/10/2025 9:42:05 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 387 560	Gym Locker Bldgs Gym Locker Hallway	Manual	9/10/2025 9:42:07 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 387 559	Gym Locker Bldgs Gym Locker Hallway	Manual	9/10/2025 9:42:08 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 387 561	Gym Locker Bldgs Gym Locker Hallway	Manual	9/10/2025 9:42:10 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 265 535	Gym Locker Bldgs Hall Entry Boys Locker	Manual	9/10/2025 7:33:36 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 251 498	Gym Locker Bldgs Hall Equip Rm by Small Gym	Manual	9/10/2025 7:33:28 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 302 511	Gym Locker Bldgs Large Gym	Manual	9/10/2025 7:34:35 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 301 512	Gym Locker Bldgs Large Gym	Manual	9/10/2025 7:34:36 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 300 519	Gym Locker Bldgs Large Gym	Manual	9/10/2025 7:34:39 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 291 522	Gym Locker Bldgs Large Gym	Manual	9/10/2025 7:34:40 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 287 526	Gym Locker Bldgs Large Gym	Manual	9/10/2025 9:41:03 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	1 2 295 514	Gym Locker Bldgs Large Gym	Manual	9/10/2025 9:41:05 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 294 513	Gym Locker Bldgs Large Gym	Manual	9/10/2025 9:41:08 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 288 525	Gym Locker Bldgs Large Gym	Manual	9/10/2025 9:41:14 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 303 510	Gym Locker Bldgs Large Gym	Manual	9/10/2025 9:41:16 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 296 515	Gym Locker Bldgs Large Gym	Manual	9/10/2025 9:41:17 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 297 516	Gym Locker Bldgs Large Gym	Manual	9/10/2025 9:41:19 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 290 523	Gym Locker Bldgs Large Gym	Manual	9/10/2025 9:41:20 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 305 508	Gym Locker Bldgs Large Gym	Manual	9/10/2025 9:41:22 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 304 509	Gym Locker Bldgs Large Gym	Manual	9/10/2025 9:41:23 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 292 521	Gym Locker Bldgs Large Gym	Manual	9/10/2025 9:41:24 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 298 517	Gym Locker Bldgs Large Gym	Manual	9/10/2025 9:41:26 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 299 518	Gym Locker Bldgs Large Gym	Manual	9/10/2025 9:41:27 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 306 507	Gym Locker Bldgs Large Gym	Manual	9/10/2025 9:41:29 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	1 2 313 504	Gym Locker Bldgs Large Gym	Manual	9/10/2025 9:41:32 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 311 502	Gym Locker Bldgs Large Gym	Manual	9/10/2025 9:41:33 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 312 503	Gym Locker Bldgs Large Gym	Manual	9/10/2025 9:41:46 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 310 501	Gym Locker Bldgs Large Gym	Manual	9/10/2025 9:41:48 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 309 500	Gym Locker Bldgs Large Gym	Manual	9/10/2025 9:41:49 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 314 505	Gym Locker Bldgs Large Gym	Manual	9/10/2025 9:41:50 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 308 499	Gym Locker Bldgs Large Gym	Manual	9/10/2025 9:41:52 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 307 506	Gym Locker Bldgs Large Gym	Manual	9/10/2025 9:41:54 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 293 520	Gym Locker Bldgs Large Gym	Manual	9/10/2025 9:41:55 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 289 524	Gym Locker Bldgs Large Gym	Manual	9/10/2025 9:42:02 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	1 2 383 572	Gym Locker Bldgs Large Gym Foyer	Manual	9/10/2025 9:40:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	1 2 384 573	Gym Locker Bldgs Large Gym Foyer	Manual	9/11/2025 9:37:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	1 2 382 571	Gym Locker Bldgs Large Gym Foyer	Manual	9/11/2025 9:37:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	1 2 401 482	Gym Locker Bldgs Large Gym Lobby	Manual	9/10/2025 7:33:41 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Manufacturer	FCI	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	1 2 400 481	Gym Locker Bldgs Large Gym Lobby	Manual	9/10/2025 7:33:44 PM
		Manufacturer	FCI	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 317 529	Gym Locker Bldgs Large Gym Lobby	Manual	9/10/2025 7:33:39 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 318 530	Gym Locker Bldgs Large Gym Lobby	Manual	9/10/2025 7:33:47 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 316 532	Gym Locker Bldgs Large Gym Mens RR	Manual	9/10/2025 7:33:42 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	1 2 399 483	Gym Locker Bldgs Large Gym NW	Manual	9/10/2025 9:42:17 PM
		Manufacturer	FCI	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 321 528	Gym Locker Bldgs Large Gym Storage	Manual	9/10/2025 7:33:48 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 315 527	Gym Locker Bldgs Large Gym Storage	Manual	9/10/2025 9:41:56 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	1 2 398 480	Gym Locker Bldgs Large Gym SW	Manual	9/10/2025 9:42:18 PM
		Manufacturer	FCI	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 319 531	Gym Locker Bldgs Large Gym Ticket Booth	Manual	9/10/2025 9:40:43 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 320 533	Gym Locker Bldgs Large Gym Womens RR	Manual	9/10/2025 7:33:45 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 270 549	Gym Locker Bldgs NE Entry Boys Locker	Manual	9/10/2025 9:42:25 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 272 556	Gym Locker Bldgs Pool Training Room	Manual	9/11/2025 9:40:13 AM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 284 488	Gym Locker Bldgs Small Gym	Manual	9/10/2025 7:34:42 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 275 493	Gym Locker Bldgs Small Gym	Manual	9/10/2025 9:40:50 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 276 494	Gym Locker Bldgs Small Gym	Manual	9/10/2025 9:40:51 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 277 495	Gym Locker Bldgs Small Gym	Manual	9/10/2025 9:40:53 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 278 496	Gym Locker Bldgs Small Gym	Manual	9/10/2025 9:40:54 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 280 484	Gym Locker Bldgs Small Gym	Manual	9/10/2025 9:40:56 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 281 485	Gym Locker Bldgs Small Gym	Manual	9/10/2025 9:40:57 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 282 486	Gym Locker Bldgs Small Gym	Manual	9/10/2025 9:40:58 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 283 487	Gym Locker Bldgs Small Gym	Manual	9/10/2025 9:41:00 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 274 492	Gym Locker Bldgs Small Gym	Manual	9/10/2025 9:41:01 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 286 490	Gym Locker Bldgs Small Gym	Manual	9/10/2025 9:41:06 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 285 489	Gym Locker Bldgs Small Gym	Manual	9/10/2025 9:41:10 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 279 497	Gym Locker Bldgs Small Gym	Manual	9/10/2025 9:41:11 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 273 491	Gym Locker Bldgs Small Gym	Manual	9/10/2025 9:41:13 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	1 2 397 476	Gym Locker Bldgs Small Gym North	Manual	9/10/2025 9:42:20 PM
		Manufacturer	FCI	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	1 2 396 477	Gym Locker Bldgs Small Gym NW	Manual	9/10/2025 9:42:21 PM
		Manufacturer	FCI	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	1 2 394 479	Gym Locker Bldgs Small Gym South	Manual	9/10/2025 9:40:25 PM
		Manufacturer	FCI	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	1 2 395 478	Gym Locker Bldgs Small Gym SW	Manual	9/10/2025 9:42:22 PM
		Manufacturer	FCI	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 379 552	Gym Locker Bldgs Telcom Rm by Boys Locker Rm	Manual	9/10/2025 9:40:31 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 2 126 235	H Wing Attic Classroom H10	Manual	9/8/2025 4:35:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 2 126 236	H Wing Attic Classroom H10	Manual	9/8/2025 4:35:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 2 127 234	H Wing Attic Classroom H3	Manual	9/8/2025 4:35:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 028 211	H Wing Classrm H6 Storage	Manual	9/8/2025 4:33:56 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 002 184	H Wing Classroom H1	Manual	9/8/2025 4:34:16 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 003 183	H Wing Classroom H1	Manual	9/8/2025 4:34:40 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 023 224	H Wing Classroom H10	Manual	9/8/2025 4:35:05 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 024 225	H Wing Classroom H10A	Manual	9/8/2025 4:34:56 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2 2 025 226	H Wing Classroom H10A	Manual	9/8/2025 4:35:10 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 032 230	H Wing Classroom H11	Manual	9/8/2025 4:34:57 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 033 227	H Wing Classroom H11	Manual	9/8/2025 4:34:59 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 031 228	H Wing Classroom H11	Manual	9/8/2025 4:35:00 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 030 229	H Wing Classroom H11	Manual	9/8/2025 4:35:02 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 012 186	H Wing Classroom H1A	Manual	9/8/2025 4:34:07 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 011 185	H Wing Classroom H1A	Manual	9/8/2025 4:34:09 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 007 189	H Wing Classroom H3	Manual	9/8/2025 4:34:20 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 008 188	H Wing Classroom H3	Manual	9/8/2025 4:34:34 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 006 190	H Wing Classroom H3	Manual	9/8/2025 4:34:36 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 048 195	H Wing Classroom H3	Manual	9/8/2025 4:34:42 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 047 192	H Wing Classroom H3	Manual	9/8/2025 4:34:43 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 051 191	H Wing Classroom H3	Manual	9/8/2025 4:34:45 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2 2 049 194	H Wing Classroom H3	Manual	9/8/2025 4:34:48 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 004 198	H Wing Classroom H3 Hall	Manual	9/8/2025 4:34:17 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 005 197	H Wing Classroom H3 Hall	Manual	9/8/2025 4:34:19 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 009 196	H Wing Classroom H3 Lab	Manual	9/8/2025 4:34:22 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 050 193	H Wing Classroom H3 Storage	Manual	9/8/2025 4:34:46 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 015 199	H Wing Classroom H4	Manual	9/8/2025 4:34:06 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 013 200	H Wing Classroom H4	Manual	9/8/2025 4:35:31 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 043 208	H Wing Classroom H5	Manual	9/8/2025 4:33:42 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 042 207	H Wing Classroom H5	Manual	9/8/2025 4:33:45 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 040 203	H Wing Classroom H5	Manual	9/8/2025 4:33:47 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 041 204	H Wing Classroom H5	Manual	9/8/2025 4:33:50 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 039 201	H Wing Classroom H5	Manual	9/8/2025 4:33:51 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 038 202	H Wing Classroom H5	Manual	9/8/2025 4:33:53 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2 2 044 205	H Wing Classroom H5	Manual	9/8/2025 4:35:30 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 045 206	H Wing Classroom H5	Manual	9/8/2025 4:35:36 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 027 210	H Wing Classroom H6	Manual	9/8/2025 4:34:04 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 2 018 233	H Wing Classroom H7	Manual	9/8/2025 4:35:33 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 017 213	H Wing Classroom H7	Manual	9/8/2025 4:35:15 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 016 212	H Wing Classroom H7	Manual	9/8/2025 4:35:18 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 014 214	H Wing Classroom H7	Manual	9/8/2025 4:35:20 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 035 216	H Wing Classroom H8	Manual	9/8/2025 4:34:50 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 036 218	H Wing Classroom H8	Manual	9/8/2025 4:34:51 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 037 219	H Wing Classroom H8	Manual	9/8/2025 4:34:53 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 034 217	H Wing Classroom H8	Manual	9/8/2025 4:34:54 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 022 220	H Wing Classroom H9	Manual	9/8/2025 4:35:03 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 020 223	H Wing Classroom H9	Manual	9/8/2025 4:35:06 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2 2 021 221	H Wing Classroom H9	Manual	9/8/2025 4:35:08 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 019 222	H Wing Classroom H9	Manual	9/8/2025 4:35:39 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 046 232	H Wing Girls Restroom	Manual	9/8/2025 4:33:41 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 010 231	H Wing Mens Restroom	Manual	9/8/2025 4:35:38 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 029 187	H Wing Rm H2 Computer Rm	Manual	9/8/2025 4:34:13 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 001 209	H Wing Rm H5 Telecom Rm	Manual	9/8/2025 4:33:55 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 026 215	H Wing Rm H7 H8 Storage	Manual	9/8/2025 4:35:28 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 2 129 257	I Wing Attic Classroom I 1	Manual	9/10/2025 9:40:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 2 128 258	I Wing Attic Classroom I 2	Manual	9/10/2025 9:40:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 2 130 259	I Wing Attic Classroom I 4	Manual	9/10/2025 9:40:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 057 238	I Wing Classroom I 1	Manual	9/10/2025 7:34:44 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 059 241	I Wing Classroom I 1	Manual	9/10/2025 7:34:46 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 058 240	I Wing Classroom I 1	Manual	9/10/2025 7:34:47 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 056 239	I Wing Classroom I 1	Manual	9/10/2025 7:34:49 PM
		Manufacturer	EST	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 055 242	I Wing Classroom I 2	Manual	9/10/2025 7:34:55 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 053 243	I Wing Classroom I 2	Manual	9/10/2025 7:34:57 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 052 244	I Wing Classroom I 2	Manual	9/10/2025 7:34:58 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 054 245	I Wing Classroom I 2	Manual	9/10/2025 7:35:00 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 061 247	I Wing Classroom I 4	Manual	9/10/2025 7:34:51 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 060 246	I Wing Classroom I 4	Manual	9/10/2025 7:34:54 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 069 248	I Wing Classroom I 5	Manual	9/10/2025 7:35:01 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 067 249	I Wing Classroom I 5	Manual	9/10/2025 7:35:03 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 066 250	I Wing Classroom I 5	Manual	9/10/2025 7:35:04 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 068 251	I Wing Classroom I 5	Manual	9/10/2025 7:35:06 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 064 252	I Wing Classroom I 6	Manual	9/10/2025 7:35:09 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 062 254	I Wing Classroom I 6	Manual	9/10/2025 7:35:11 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 063 255	I Wing Classroom I 6	Manual	9/10/2025 7:35:12 PM
		Manufacturer	EST	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 065 253	I Wing Classroom I 6	Manual	9/10/2025 7:35:14 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 071 256	I Wing Custodial Room	Manual	9/10/2025 7:34:50 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 2 131 300	J Wing Attic Classroom J5	Manual	9/9/2025 5:03:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 2 132 301	J Wing Attic Rm J7 Auto Shop	Manual	9/9/2025 5:03:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 2 081 290	J Wing Classroom J1	Manual	9/9/2025 5:03:35 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 2 082 291	J Wing Classroom J1	Manual	9/9/2025 5:03:36 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 2 083 292	J Wing Classroom J1	Manual	9/9/2025 5:03:38 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 2 086 262	J Wing Classroom J1 Saw Rm	Manual	9/9/2025 5:03:39 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 2 084 293	J Wing Classroom J1 Storage	Manual	9/9/2025 5:03:47 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 075 263	J Wing Classroom J2	Manual	9/9/2025 5:03:23 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 106 270	J Wing Classroom J2	Manual	9/9/2025 5:03:44 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 107 266	J Wing Classroom J2	Manual	9/9/2025 5:03:46 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 076 264	J Wing Classroom J2	Manual	9/9/2025 5:04:04 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2 2 077 269	J Wing Classroom J2	Manual	9/9/2025 5:04:06 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 079 268	J Wing Classroom J2	Manual	9/9/2025 5:04:07 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 080 267	J Wing Classroom J2	Manual	9/9/2025 5:04:08 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 078 265	J Wing Classroom J2	Manual	9/9/2025 5:04:15 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 089 271	J Wing Classroom J2 Storage	Manual	9/9/2025 5:04:03 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 073 275	J Wing Classroom J3	Manual	9/9/2025 5:03:58 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 070 273	J Wing Classroom J3	Manual	9/9/2025 5:03:59 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 074 272	J Wing Classroom J3	Manual	9/9/2025 5:04:01 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 072 274	J Wing Classroom J3	Manual	9/9/2025 5:04:16 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 088 276	J Wing Classroom J4 Office	Manual	9/9/2025 5:04:10 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 094 277	J Wing Classroom J5	Manual	9/9/2025 5:03:55 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 093 279	J Wing Classroom J5 Closet	Manual	9/9/2025 5:03:19 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 092 278	J Wing Classroom J5 Storage	Manual	9/9/2025 5:03:56 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2 2 090 280	J Wing Classroom J7 Closet	Manual	9/9/2025 5:03:41 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 087 281	J Wing Classroom J7 Closet	Manual	9/9/2025 5:04:11 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 099 283	J Wing Classroom J8	Manual	9/9/2025 5:03:48 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 100 282	J Wing Classroom J8	Manual	9/9/2025 5:03:50 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 105 285	J Wing Classroom J8 Storage	Manual	9/9/2025 5:04:13 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 091 284	J Wing Classroom J8 Storage	Manual	9/9/2025 5:04:18 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 097 286	J Wing Classroom J9	Manual	9/9/2025 5:03:42 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 095 287	J Wing Classroom J9	Manual	9/9/2025 5:03:52 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 096 288	J Wing Classroom J9	Manual	9/9/2025 5:03:53 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 2 098 289	J Wing Classroom J9	Manual	9/9/2025 5:04:19 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 2 137 294	J Wing J1 Paint Room	Manual	9/9/2025 5:03:33 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 2 085 299	J Wing J7 Outside Closet	Manual	9/9/2025 5:03:25 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 2 103 297	J Wing Room J7 Auto Shop	Manual	9/9/2025 5:03:21 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2 2 101 295	J Wing Room J7 Auto Shop	Manual	9/9/2025 5:03:29 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 2 102 296	J Wing Room J7 Auto Shop	Manual	9/9/2025 5:03:30 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 2 104 298	J Wing Room J7 Auto Shop	Manual	9/9/2025 5:03:32 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.2.059	New Theater Building 1st Floor Elevator Lobby	Manual	9/8/2025 4:10:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.2.065	New Theater Building 2nd Floor Elevator Lobby	Manual	9/8/2025 4:11:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.2.062	New Theater Building 2nd Floor North Lobby	Manual	9/8/2025 4:10:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.2.069	New Theater Building 2nd Floor Recording Rm	Manual	9/8/2025 4:10:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.2.070	New Theater Building 2nd Floor Roof Access	Manual	9/8/2025 4:10:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.2.071	New Theater Building 2nd Floor Vestibule	Manual	9/8/2025 4:10:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.2.155	New Theater Building Attic 2nd Floor Elevator Lobby	Manual	9/8/2025 4:10:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.2.146	New Theater Building Attic 2nd Floor Recording Rm	Manual	9/10/2025 3:27:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.2.157	New Theater Building Attic 2nd Floor Vestibule	Manual	9/10/2025 9:40:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.2.133	New Theater Building Attic Chair Stage Storage	Manual	9/10/2025 3:26:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.2.142	New Theater Building Attic Classroom M1	Manual	9/10/2025 3:26:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.2.142	New Theater Building Attic Classroom M1	Manual	9/10/2025 3:26:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.2.190	New Theater Building Attic Classroom M1/M2 Hall	Manual	9/10/2025 3:26:43 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.2.190	New Theater Building Attic Classroom M1/M2 Office	Manual	9/10/2025 3:26:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.2.141	New Theater Building Attic Classroom M1/M2 Storage	Manual	9/10/2025 3:26:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.2.136	New Theater Building Attic Classroom M2	Manual	9/10/2025 3:26:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.2.136	New Theater Building Attic Classroom M2	Manual	9/10/2025 3:26:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.2.159	New Theater Building Attic East Janitor Rm	Manual	9/8/2025 4:11:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.2.160	New Theater Building Attic East Vestibule	Manual	9/10/2025 3:27:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.2.143	New Theater Building Attic Elevator Shaft	Manual	9/8/2025 4:10:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.2.134	New Theater Building Attic Hall & Stage Vestibule	Manual	9/10/2025 3:26:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.2.131	New Theater Building Attic Hall & Stage Vestibule South	Manual	9/10/2025 3:26:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.2.132	New Theater Building Attic Hall Between Classrooms & Stage	Manual	9/10/2025 3:26:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.2.132	New Theater Building Attic Hall Between Classrooms & Stage	Manual	9/10/2025 3:26:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.2.140	New Theater Building Attic M1/M2 Practice Rm M123	Manual	9/10/2025 3:26:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.2.139	New Theater Building Attic M1/M2 Practice Rm M124	Manual	9/10/2025 3:27:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.2.138	New Theater Building Attic M1/M2 Practice Rm M125	Manual	9/10/2025 3:27:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.2.137	New Theater Building Attic M1/M2 Practice Rm M126	Manual	9/10/2025 3:26:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.2.148	New Theater Building Attic Stage Above Seating	Manual	9/10/2025 3:26:48 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.2.148	New Theater Building Attic Stage Above Seating	Manual	9/10/2025 3:26:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.2.158	New Theater Building Attic Stage Piano Storage	Manual	9/8/2025 4:11:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.2.161	New Theater Building Attic Ticket Booth	Manual	9/10/2025 3:27:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.2.130	New Theater Building Attic West Boys Restroom	Manual	9/8/2025 4:11:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.2.012	New Theater Building Chair Stage Storage	Manual	9/8/2025 4:10:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.2.029	New Theater Building Classroom M1	Manual	9/8/2025 3:49:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.2.027	New Theater Building Classroom M1	Manual	9/8/2025 3:49:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.2.028	New Theater Building Classroom M1	Manual	9/8/2025 3:49:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.2.030	New Theater Building Classroom M1	Manual	9/8/2025 3:50:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.2.024	New Theater Building Classroom M1/M2 Hallway	Manual	9/8/2025 3:50:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.2.019	New Theater Building Classroom M1/M2 Hallway	Manual	9/8/2025 4:10:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.2.025	New Theater Building Classroom M1/M2 Office	Manual	9/8/2025 3:50:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.2.026	New Theater Building Classroom M1/M2 Storage	Manual	9/8/2025 3:50:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.2.018	New Theater Building Classroom M2	Manual	9/8/2025 4:09:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.2.017	New Theater Building Classroom M2	Manual	9/8/2025 4:09:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.2.016	New Theater Building Classroom M2	Manual	9/8/2025 4:09:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.2.015	New Theater Building Classroom M2	Manual	9/8/2025 4:09:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3.2.079	New Theater Building East Boys Restroom	Manual	9/8/2025 4:10:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.2.074	New Theater Building East Girls Restroom	Manual	9/8/2025 4:10:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.2.078	New Theater Building East Hallway	Manual	9/8/2025 4:10:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.2.075	New Theater Building East Janitor Rm	Manual	9/8/2025 4:11:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.2.076	New Theater Building East Vestibule	Manual	9/8/2025 4:10:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.2.077	New Theater Building East Vestibule	Manual	9/8/2025 4:10:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.2.005	New Theater Building Electrical Room	Manual	9/8/2025 4:10:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.2.060	New Theater Building Elevator Equipment Rm	Manual	9/8/2025 4:10:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.2.013	New Theater Building Hall & Stage Vestibule	Manual	9/8/2025 4:10:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3.2.011	New Theater Building Hall & Stage Vestibule South	Manual	9/8/2025 4:11:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.2.014	New Theater Building Hall Between Classrooms & Stage	Manual	9/8/2025 4:09:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.2.010	New Theater Building Hall Between Classrooms & Stage	Manual	9/8/2025 4:09:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.2.008	New Theater Building Hall Between Classrooms & Stage	Manual	9/8/2025 4:10:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.2.004	New Theater Building IDF/FACP Room	Manual	9/8/2025 4:10:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.2.023	New Theater Building M1/M2 Practice Rm M123	Manual	9/8/2025 4:09:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.2.022	New Theater Building M1/M2 Practice Rm M124	Manual	9/8/2025 4:09:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.2.021	New Theater Building M1/M2 Practice Rm M125	Manual	9/8/2025 4:09:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3.2.020	New Theater Building M1/M2 Practice Rm M126	Manual	9/8/2025 4:09:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	3.2.149	New Theater Building North Lobby	Manual	9/8/2025 4:10:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.2.058	New Theater Building North Lobby	Manual	9/8/2025 4:10:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.2.063	New Theater Building North Lobby	Manual	9/8/2025 4:10:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.2.064	New Theater Building North Lobby	Manual	9/8/2025 4:10:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	3.2.128	New Theater Building Riser Room	Manual	9/10/2025 3:26:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.2.006	New Theater Building Riser Room	Manual	9/8/2025 4:10:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Projected Beam	3.2.182	New Theater Building Stage Beam 1	Manual	9/8/2025 4:09:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Projected Beam	3.2.184	New Theater Building Stage Beam 2	Manual	9/8/2025 4:09:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Projected Beam	3.2.186	New Theater Building Stage Beam 3	Manual	9/8/2025 4:09:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Projected Beam	3.2.188	New Theater Building Stage Beam 4	Manual	9/11/2025 9:38:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.2.034	New Theater Building Stage Curtain Storage East	Manual	9/8/2025 4:11:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.2.039	New Theater Building Stage Curtain Storage West	Manual	9/8/2025 4:11:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.2.072	New Theater Building Stage Piano Storage	Manual	9/8/2025 4:10:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.2.073	New Theater Building Stage Piano Storage	Manual	9/8/2025 4:10:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.2.080	New Theater Building Ticket Booth	Manual	9/8/2025 4:11:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.2.007	New Theater Building West Boys Restroom	Manual	9/8/2025 4:10:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Valve Tamper Switch	3.2.162	New Theater Building West Exterior - P.I.V.	Manual	9/11/2025 9:38:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3.2.009	New Theater Building West Girls Restroom	Manual	9/8/2025 4:10:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 043 318	Portables APE Bldg Room	Manual	9/10/2025 7:34:31 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 042 319	Portables APE Bldg Room	Manual	9/10/2025 7:34:33 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 147 337	Portables Attic APE Bldg	Manual	9/10/2025 7:35:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 147 336	Portables Attic APE Bldg	Manual	9/10/2025 7:35:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 140 320	Portables Attic Room P1	Manual	9/10/2025 7:34:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 140 321	Portables Attic Room P1	Manual	9/10/2025 7:35:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 139 323	Portables Attic Room P2	Manual	9/10/2025 7:35:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 139 322	Portables Attic Room P2	Manual	9/10/2025 7:35:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 138 324	Portables Attic Room P3	Manual	9/10/2025 7:35:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 138 325	Portables Attic Room P3	Manual	9/10/2025 7:35:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 144 327	Portables Attic Room P4	Manual	9/10/2025 7:35:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 144 326	Portables Attic Room P4	Manual	9/10/2025 7:35:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 142 329	Portables Attic Room P5	Manual	9/10/2025 7:35:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 142 328	Portables Attic Room P5	Manual	9/10/2025 7:35:21 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 141 331	Portables Attic Room P6	Manual	9/10/2025 7:35:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 141 330	Portables Attic Room P6	Manual	9/10/2025 7:35:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 143 333	Portables Attic Room P7	Manual	9/10/2025 7:35:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 143 332	Portables Attic Room P7	Manual	9/10/2025 7:35:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 146 335	Portables Attic Room P8	Manual	9/10/2025 7:35:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 146 334	Portables Attic Room P8	Manual	9/10/2025 7:35:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 059 302	Portables Room P1	Manual	9/10/2025 7:34:13 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 058 303	Portables Room P1	Manual	9/10/2025 7:34:15 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 057 304	Portables Room P2	Manual	9/10/2025 7:34:16 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 056 305	Portables Room P2	Manual	9/10/2025 7:34:18 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 055 306	Portables Room P3	Manual	9/10/2025 7:34:19 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 054 307	Portables Room P3	Manual	9/10/2025 7:34:21 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 052 308	Portables Room P4	Manual	9/10/2025 7:34:22 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 053 309	Portables Room P4	Manual	9/10/2025 7:34:24 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	1 2 063 310	Portables Room P5	Manual	9/10/2025 7:34:08 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 060 311	Portables Room P5	Manual	9/10/2025 7:34:09 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 061 313	Portables Room P6	Manual	9/10/2025 7:34:10 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 062 312	Portables Room P6	Manual	9/10/2025 7:34:12 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 051 314	Portables Room P7	Manual	9/10/2025 7:34:25 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 050 315	Portables Room P7	Manual	9/10/2025 7:34:26 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 049 317	Portables Room P8	Manual	9/10/2025 7:34:28 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 048 316	Portables Room P8	Manual	9/10/2025 7:34:29 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2 3 149 404	Theater Building 2nd Floor Booth	Manual	9/11/2025 9:38:33 AM
		Manufacturer	FCI	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 023 417	Theater Building 2nd Floor Booth	Manual	9/10/2025 7:36:14 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 024 418	Theater Building 2nd Floor Booth	Manual	9/10/2025 7:36:16 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 030 419	Theater Building 2nd Floor Booth	Manual	9/10/2025 7:36:17 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 3 143 464	Theater Building Attic Counselor Hall	Manual	9/11/2025 9:39:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2 3 127 463	Theater Building Attic Theat Staff Rm	Manual	9/10/2025 9:40:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 3 127 462	Theater Building Attic Theat Staff Rm	Manual	9/10/2025 9:40:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 3 127 461	Theater Building Attic Theat Staff Rm	Manual	9/10/2025 9:40:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 3 127 460	Theater Building Attic Theat Staff Rm	Manual	9/10/2025 9:40:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 3 126 459	Theater Building Attic Theater Prep Rm	Manual	9/10/2025 9:40:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2 3 152 412	Theater Building Boys RR by D Hall	Manual	9/11/2025 9:38:35 AM
		Manufacturer	FCI	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2 3 156 409	Theater Building CD Conference Room	Manual	9/11/2025 9:38:25 AM
		Manufacturer	FCI	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 026 442	Theater Building Coed Restroom	Manual	9/10/2025 3:30:30 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 029 439	Theater Building Coed Restroom	Manual	9/10/2025 3:30:31 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2 3 157 408	Theater Building Counseling E Entry	Manual	9/11/2025 9:38:32 AM
		Manufacturer	FCI	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2 3 159 411	Theater Building Counseling ROP Office	Manual	9/11/2025 9:38:29 AM
		Manufacturer	FCI	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2 3 158 410	Theater Building Counseling W Entry	Manual	9/11/2025 9:38:30 AM
		Manufacturer	FCI	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 040 451	Theater Building Counselor Office 501	Manual	9/11/2025 9:39:06 AM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 039 449	Theater Building Counselor Office 502	Manual	9/11/2025 9:39:10 AM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2 3 041 453	Theater Building Counselor Office 503	Manual	9/11/2025 9:39:08 AM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 042 452	Theater Building Counselor Office 504	Manual	9/11/2025 9:39:05 AM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 035 447	Theater Building Counselor Office 506	Manual	9/10/2025 3:27:12 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 034 454	Theater Building Counselor Office 507	Manual	9/10/2025 3:27:14 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 033 445	Theater Building Counselor Office 531	Manual	9/10/2025 3:27:15 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 043 455	Theater Building Counselor South RR	Manual	9/11/2025 9:39:19 AM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 036 446	Theater Building Counselors Hall	Manual	9/10/2025 3:27:09 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 038 450	Theater Building Counselors Hall	Manual	9/11/2025 9:39:09 AM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 105	Theater Building Dressing Room	Manual	9/10/2025 3:30:33 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2 3 134 465	Theater Building Duct Smoke 1	Manual	9/11/2025 9:38:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2 3 135 466	Theater Building Duct Smoke 2	Manual	9/11/2025 9:38:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2 3 136 467	Theater Building Duct Smoke 3	Manual	9/11/2025 9:37:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2 3 137 468	Theater Building Duct Smoke 4	Manual	9/11/2025 9:37:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2 3 138 469	Theater Building Duct Smoke 5	Manual	9/11/2025 9:37:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - Duct	2 3 139 470	Theater Building Duct Smoke 6	Manual	9/11/2025 9:37:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2 3 140 471	Theater Building Duct Smoke 7	Manual	9/11/2025 9:37:53 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2 3 141 472	Theater Building Duct Smoke 8	Manual	9/11/2025 9:37:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 019 457	Theater Building E Girls Restroom	Manual	9/11/2025 9:39:22 AM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 017 456	Theater Building E Girls Restroom	Manual	9/11/2025 9:39:24 AM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 001 435	Theater Building Equipment Room	Manual	9/10/2025 7:36:56 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2 3 153 413	Theater Building Girls RR by D Hall	Manual	9/11/2025 9:38:26 AM
		Manufacturer	FCI	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 014 432	Theater Building Large Storage Room	Manual	9/11/2025 9:39:03 AM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 006 425	Theater Building Little Theater	Manual	9/10/2025 7:35:57 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 010 421	Theater Building Little Theater	Manual	9/10/2025 7:35:59 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 013 426	Theater Building Little Theater	Manual	9/10/2025 7:36:01 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 008 422	Theater Building Little Theater	Manual	9/10/2025 7:36:05 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 009 423	Theater Building Little Theater	Manual	9/10/2025 7:36:07 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 011 420	Theater Building Little Theater	Manual	9/10/2025 7:36:08 PM
		Manufacturer	EST	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 007 424	Theater Building Little Theater	Manual	9/10/2025 7:36:10 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 004 427	Theater Building Little Theater	Manual	9/10/2025 7:36:19 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 003 429	Theater Building Little Theater	Manual	9/10/2025 7:36:46 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 002 428	Theater Building Little Theater	Manual	9/10/2025 7:36:53 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 015 416	Theater Building Little Theater Stairway	Manual	9/10/2025 7:36:11 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 016 431	Theater Building Little Theater Storage	Manual	9/10/2025 7:36:03 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 005 430	Theater Building Little Theatre	Manual	9/10/2025 7:36:20 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 037 448	Theater Building Main Lobby	Manual	9/11/2025 9:39:12 AM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 028 438	Theater Building North Hall	Manual	9/11/2025 9:39:42 AM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 031 440	Theater Building North Hall Closet	Manual	9/11/2025 9:39:25 AM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 032 436	Theater Building North Restroom	Manual	9/11/2025 9:39:18 AM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 018 434	Theater Building North Storage Room	Manual	9/10/2025 3:30:37 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2 3 148 402	Theater Building NW Exit	Manual	9/10/2025 9:40:22 PM
		Manufacturer	FCI	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 020 433	Theater Building Prep Room	Manual	9/10/2025 3:30:35 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 054 414	Theater Building SE Entry	Manual	9/10/2025 7:36:57 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 104 415	Theater Building SE Entry Storage	Manual	9/10/2025 3:30:36 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2 3 150 401	Theater Building SE Exit	Manual	9/10/2025 9:40:19 PM
		Manufacturer	FCI	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2 3 012 458	Theater Building Snack Bar	Manual	9/11/2025 9:39:57 AM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2 3 151 405	Theater Building Snack Bar	Manual	9/11/2025 9:38:28 AM
		Manufacturer	FCI	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 025 441	Theater Building South Hall	Manual	9/10/2025 3:27:17 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2 3 147 403	Theater Building SW Exit	Manual	9/10/2025 9:40:20 PM
		Manufacturer	FCI	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 027 437	Theater Building Teachers Room	Manual	9/10/2025 3:27:08 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2 3 154 407	Theater Building Teachers Room N	Manual	9/11/2025 9:38:23 AM
		Manufacturer	FCI	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2 3 155 406	Theater Building Teachers Room S	Manual	9/10/2025 9:40:16 PM
		Manufacturer	FCI	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 021 443	Theater Building W Boys Restroom	Manual	9/10/2025 3:27:10 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2 3 022 444	Theater Building W Boys Restroom	Manual	9/11/2025 9:39:21 AM
		Manufacturer	EST	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 388 587	Weight Room Attic Weight Room	Manual	9/11/2025 9:40:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 388 586	Weight Room Attic Weight Room	Manual	9/11/2025 9:40:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 388 585	Weight Room Attic Weight Room	Manual	9/11/2025 9:40:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	1 2 388 584	Weight Room Attic Weight Room	Manual	9/11/2025 9:40:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 340 578	Weight Room Weight Room	Manual	9/10/2025 7:33:50 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 341 581	Weight Room Weight Room	Manual	9/10/2025 7:33:52 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 342 582	Weight Room Weight Room	Manual	9/10/2025 7:33:53 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 339 583	Weight Room Weight Room	Manual	9/10/2025 7:33:55 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 338 580	Weight Room Weight Room	Manual	9/10/2025 7:33:56 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	1 2 337 579	Weight Room Weight Room	Manual	9/10/2025 7:34:00 PM
		Manufacturer	EST	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Power Supplies

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
FACP		H Wing Room H5 Telecom Rm	Manual	9/8/2025 4:35:45 PM
		Manufacturer	Fire Lite	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Ventilation and Cooking Equipment

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Cooking Equipment	Appliances		Manual	9/9/2025 5:08:34 PM
Fusible Links	Fusible Links		Manual	9/9/2025 5:08:36 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Range Hood	Hood		Manual	9/9/2025 5:08:39 PM
Range Suppression	Fire Suppression		Manual	9/9/2025 5:08:44 PM
Range Suppression Tank	WHDR400M Cylinder		Manual	9/9/2025 5:08:47 PM

Device/Equipment details

Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Remote Annunciator					
001	Admin Library Bldg Secretary Desk	EST			
NAC Power Extender Panel					
053	Admin Library Bldg FACP Room - Fire Lite P.E. "Master"				
054	Admin Library Bldg FACP Room - Fire Lite P.E. "B"				
237	H Wing Room H5 Telecom Rm - Fire Lite P.E. "G"				
260	I Wing Classroom I 4 - P.E. "I"	Fire Lite			
261	I Wing Classroom I 4 - P.E. "J"	Fire Lite			
338	Portables Classroom P8 - P.E. "P"				
398	Cafeteria Bldgs Telecom Room - Fire Lite P.E. "C"	Fire Lite			
399	Cafeteria Bldgs Telecom Room - Fire Lite P.E. "E"	Fire Lite			
400	Cafeteria Bldgs Telecom Room - Fire Lite P.E. "F"	Fire Lite			
473	Theater Building Equipment Room - P.E. "K"				
474	Theater Building Equipment Room - P.E. "L"				
475	Theater Building Equipment Room - P.E. "N"				
574	Gym Locker Bldgs Hall Equip Rm by Small Gym - P.E "Q"	Fire Lite			
575	Gym Locker Bldgs Hall Equip Rm by Small Gym - P.E "R"	Fire Lite			
576	Gym Locker Bldgs Hall Equip Rm by Small Gym - P.E "T"	Fire Lite			
577	Gym Locker Bldgs Hall Equip Rm by Small Gym - P.E "V"	Fire Lite			
	New Theater Building FACP Room - P.E. "A"				

Fire Alarm Panel

New Theater Building IDF/FACP Room

Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Manual Pull Station					
1 2 136 002	Admin Library Bldg Secretary Desk	EST			
1 2 145 003	Admin Library Bldg Library NW Exit	FCI			
1 2 148 004	Admin Library Bldg Library SW Exit	FCI			
2 3 390 339	Cafeteria Bldgs Cafeteria SW Exit	FCI			
2 3 389 340	Cafeteria Bldgs Cafeteria NW Exit	FCI			
2 3 392 341	Cafeteria Bldgs Cafeteria NE Exit	FCI			
2 3 391 342	Cafeteria Bldgs Cafeteria SE Exit	FCI			
2 3 150 401	Theater Building SE Exit	FCI			
2 3 148 402	Theater Building NW Exit	FCI			
2 3 147 403	Theater Building SW Exit	FCI			
2 3 149 404	Theater Building 2nd Floor Booth	FCI			
2 3 151 405	Theater Building Snack Bar	FCI			

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2 3 155 406	Theater Building Teachers Room S	FCI			
2 3 154 407	Theater Building Teachers Room N	FCI			
2 3 157 408	Theater Building Counseling E Entry	FCI			
2 3 156 409	Theater Building CD Conference Room	FCI			
2 3 158 410	Theater Building Counseling W Entry	FCI			
2 3 159 411	Theater Building Counseling ROP Office	FCI			
2 3 152 412	Theater Building Boys RR by D Hall	FCI			
2 3 153 413	Theater Building Girls RR by D Hall	FCI			
1 2 397 476	Gym Locker Bldgs Small Gym North	FCI			
1 2 396 477	Gym Locker Bldgs Small Gym NW	FCI			
1 2 395 478	Gym Locker Bldgs Small Gym SW	FCI			
1 2 394 479	Gym Locker Bldgs Small Gym South	FCI			
1 2 398 480	Gym Locker Bldgs Large Gym SW	FCI			
1 2 400 481	Gym Locker Bldgs Large Gym Lobby	FCI			
1 2 401 482	Gym Locker Bldgs Large Gym Lobby	FCI			
1 2 399 483	Gym Locker Bldgs Large Gym NW	FCI			
3.2.149	New Theater Building North Lobby				
Smoke Detector - General					
1 2 029 005	Admin Library Bldg Secretary Desk	EST			
1 2 025 006	Admin Library Bldg Principals Office	EST			
1 2 026 007	Admin Library Bldg Conference Room	EST			
1 2 027 008	Admin Library Bldg Conference Room Closet	EST			
1 2 028 009	Admin Library Bldg Front Door Closet	EST			
1 2 030 010	Admin Library Bldg Room at Safe	EST			
1 2 037 011	Admin Library Bldg Safe Room	EST			
1 2 039 012	Admin Library Bldg Admin Athletic Office	EST			
1 2 002 013	Admin Library Bldg Admin Front Hall	EST			
1 2 003 014	Admin Library Bldg Front Restroom	EST			
1 2 040 015	Admin Library Bldg Campus Monitor Office	EST			
1 2 004 016	Admin Library Bldg Front VP Office	EST			
1 2 005 017	Admin Library Bldg Middle VP Office	EST			
1 2 006 018	Admin Library Bldg Back VP Office	EST			
1 2 041 019	Admin Library Bldg North Hall	EST			
1 2 007 020	Admin Library Bldg Suspension Room	EST			
1 2 001 021	Admin Library Bldg FACP Room	EST			
1 2 038 022	Admin Library Bldg Storage Rm by FACP	EST			
1 2 010 023	Admin Library Bldg VP Secretary Office	EST			
1 2 009 024	Admin Library Bldg Attendance Office	EST			

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
1 2 023 025	Admin Library Bldg Copy Room	EST			
1 2 032 026	Admin Library Bldg Middle Hall	EST			
1 2 031 027	Admin Library Bldg Mid Hall Restroom	EST			
1 2 033 028	Admin Library Bldg Middle Hall Closet	EST			
1 2 034 029	Admin Library Bldg Mid Hall Restroom	EST			
1 2 035 030	Admin Library Bldg Phone Room	EST			
1 2 016 031	Admin Library Bldg Library	EST			
1 2 015 032	Admin Library Bldg Library	EST			
1 2 014 033	Admin Library Bldg Library	EST			
1 2 017 034	Admin Library Bldg Library	EST			
1 2 018 035	Admin Library Bldg Library	EST			
1 2 013 036	Admin Library Bldg Library	EST			
1 2 021 037	Admin Library Bldg Library Office	EST			
1 2 020 038	Admin Library Bldg Library Finance Office	EST			
1 2 019 039	Admin Library Bldg Library W. Corner Office	EST			
1 2 012 040	Admin Library Bldg Library Computer Lab	EST			
1 2 011 041	Admin Library Bldg Library N. Book Store Rm	EST			
1 2 008 042	Admin Library Bldg Library E. Book Store Rm	EST			
1 2 036 043	Admin Library Bldg Library East Office	EST			
1 2 022 044	Admin Library Bldg Library SE Corner Office	EST			
2 3 320 055	A Wing Classroom A1	EST			
2 3 341 056	A Wing Classroom A1	EST			
2 3 321 057	A Wing Classroom A2	EST			
2 3 342 058	A Wing Classroom A2	EST			
2 3 343 059	A Wing Classroom A3	EST			
2 3 322 060	A Wing Classroom A3	EST			
2 3 323 061	A Wing Classroom A4A	EST			
2 3 325 062	A Wing Classroom A4A	EST			
2 3 326 063	A Wing Classroom A4B	EST			
2 3 327 064	A Wing Classroom A4B	EST			
2 3 328 065	A Wing Classroom A5	EST			
2 3 344 066	A Wing Classroom A5	EST			
2 3 329 067	A Wing Classroom A6	EST			
2 3 345 068	A Wing Classroom A6	EST			
2 3 324 069	A Wing Classroom A7	EST			
2 3 330 070	A Wing Classroom A7	EST			
2 3 308 071	A Wing Classroom A8	EST			

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2 3 309 072	A Wing Classroom A9	EST			
2 3 311 073	A Wing Classroom A10	EST			
2 3 310 074	A Wing Classroom A10	EST			
2 3 315 075	A Wing Classroom A11	EST			
2 3 314 076	A Wing Classroom A11	EST			
2 3 313 077	A Wing Classroom A12	EST			
2 3 312 078	A Wing Classroom A12	EST			
2 3 316 079	A Wing Classroom A13	EST			
2 3 317 080	A Wing Classroom A13	EST			
2 3 319 081	A Wing Classroom A14	EST			
2 3 318 082	A Wing Classroom A14	EST			
2 3 346 086	B Wing Classroom B1	EST			
2 3 333 087	B Wing Classroom B1	EST			
2 3 347 088	B Wing Classroom B2	EST			
2 3 332 089	B Wing Classroom B2	EST			
2 3 331 090	B Wing Classroom B3	EST			
2 3 348 091	B Wing Classroom B3	EST			
2 3 334 092	B Wing Classroom B4A	EST			
2 3 335 093	B Wing Classroom B4A	EST			
2 3 336 094	B Wing Classroom B4B	EST			
2 3 337 095	B Wing Classroom B4C	EST			
2 3 340 096	B Wing Classroom B5	EST			
2 3 349 097	B Wing Classroom B5	EST			
2 3 350 098	B Wing Classroom B6	EST			
2 3 339 099	B Wing Classroom B6	EST			
2 3 338 100	B Wing Classroom B7	EST			
2 3 351 101	B Wing Classroom B7	EST			
2 3 294 102	B Wing Classroom B8	EST			
2 3 293 103	B Wing Classroom B8	EST			
2 3 292 104	B Wing Classroom B9	EST			
2 3 291 105	B Wing Classroom B10	EST			
2 3 298 106	B Wing Classroom B11	EST			
2 3 297 107	B Wing Classroom B11	EST			
2 3 296 108	B Wing Classroom B12	EST			
2 3 295 109	B Wing Classroom B12	EST			
2 3 302 110	B Wing Classroom B13	EST			
2 3 301 111	B Wing Classroom B13	EST			

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2 3 300 112	B Wing Classroom B14	EST			
2 3 299 113	B Wing Classroom B15	EST			
2 3 084 117	C Wing Classroom C8	EST			
2 3 085 118	C Wing Classroom C9	EST			
2 3 087 119	C Wing Classroom C10	EST			
2 3 086 120	C Wing Classroom C10	EST			
2 3 092 121	C Wing Classroom C11	EST			
2 3 098 122	C Wing Classroom C11A	EST			
2 3 095 123	C Wing Classroom C11B	EST			
2 3 096 124	C Wing Classroom C11B	EST			
2 3 094 125	C Wing Classroom C12A	EST			
2 3 093 126	C Wing Classroom C12A	EST			
2 3 091 127	C Wing Classroom C13	EST			
2 3 090 128	C Wing Classroom C14	EST			
2 3 088 129	C Wing Classroom C15	EST			
2 3 089 130	C Wing Classroom C15	EST			
2 3 097 131	C Wing C Bldg Storage	EST			
2 3 099 132	C Wing C Bldg Storage	EST			
2 3 102 133	C Wing C Bldg Center Storage	EST			
2 3 101 134	C Wing C Bldg Center Storage	EST			
2 3 103 135	C Wing C Bldg Center Storage	EST			
2 3 047 137	D Wing Classroom D1	EST			
2 3 048 138	D Wing Classroom D1	EST			
2 3 045 139	D Wing Classroom D2	EST			
2 3 046 140	D Wing Classroom D2	EST			
2 3 100 141	D Wing Classroom D3	EST			
2 3 044 142	D Wing Classroom D3	EST			
2 3 057 143	D Wing Classroom D4A	EST			
2 3 056 144	D Wing Classroom D4A	EST			
2 3 059 145	D Wing Classroom D4B	EST			
2 3 058 146	D Wing Classroom D4B	EST			
2 3 049 147	D Wing Classroom D5	EST			
2 3 050 148	D Wing Classroom D5	EST			
2 3 051 149	D Wing Classroom D6	EST			
2 3 052 150	D Wing Classroom D6	EST			
2 3 053 151	D Wing Classroom D7	EST			
2 3 055 152	D Wing Classroom D7	EST			

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2 3 061 153	D Wing Classroom D9	EST			
2 3 060 154	D Wing Classroom D10	EST			
2 3 067 155	D Wing Classroom D10A	EST			
2 3 066 156	D Wing Storage D10B	EST			
2 3 068 157	D Wing Classroom D11	EST			
2 3 065 158	D Wing Classroom D12	EST			
2 3 064 159	D Wing Classroom D12	EST			
2 3 071 160	D Wing Classroom D14	EST			
2 3 072 161	D Wing Classroom D15	EST			
2 3 081 171	E Wing Classroom E1	EST			
2 3 082 172	E Wing Classroom E1	EST			
2 3 074 173	E Wing Classroom E2	EST			
2 3 073 174	E Wing Classroom E2	EST			
2 3 083 175	E Wing E Bldg Hall	EST			
2 3 075 176	E Wing E Bldg Hall	EST			
2 3 078 177	E Wing E Bldg Closet	EST			
2 3 080 178	E Wing Boys Restroom Entry	EST			
2 3 079 179	E Wing Boys Restroom	EST			
2 3 076 180	E Wing Girls Restroom Entry	EST			
2 3 077 181	E Wing Girls Restroom	EST			
2 2 003 183	H Wing Classroom H1	EST			
2 2 002 184	H Wing Classroom H1	EST			
2 2 011 185	H Wing Classroom H1A	EST			
2 2 012 186	H Wing Classroom H1A	EST			
2 2 029 187	H Wing Rm H2 Computer Rm	EST			
2 2 008 188	H Wing Classroom H3	EST			
2 2 007 189	H Wing Classroom H3	EST			
2 2 006 190	H Wing Classroom H3	EST			
2 2 051 191	H Wing Classroom H3	EST			
2 2 047 192	H Wing Classroom H3	EST			
2 2 050 193	H Wing Classroom H3 Storage	EST			
2 2 049 194	H Wing Classroom H3	EST			
2 2 048 195	H Wing Classroom H3	EST			
2 2 009 196	H Wing Classroom H3 Lab	EST			
2 2 005 197	H Wing Classroom H3 Hall	EST			
2 2 004 198	H Wing Classroom H3 Hall	EST			
2 2 015 199	H Wing Classroom H4	EST			

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2 2 013 200	H Wing Classroom H4	EST			
2 2 039 201	H Wing Classroom H5	EST			
2 2 038 202	H Wing Classroom H5	EST			
2 2 040 203	H Wing Classroom H5	EST			
2 2 041 204	H Wing Classroom H5	EST			
2 2 044 205	H Wing Classroom H5	EST			
2 2 045 206	H Wing Classroom H5	EST			
2 2 042 207	H Wing Classroom H5	EST			
2 2 043 208	H Wing Classroom H5	EST			
2 2 001 209	H Wing Rm H5 Telecom Rm	EST			
2 2 027 210	H Wing Classroom H6	EST			
2 2 028 211	H Wing Classrm H6 Storage	EST			
2 2 016 212	H Wing Classroom H7	EST			
2 2 017 213	H Wing Classroom H7	EST			
2 2 014 214	H Wing Classroom H7	EST			
2 2 026 215	H Wing Rm H7 H8 Storage	EST			
2 2 035 216	H Wing Classroom H8	EST			
2 2 034 217	H Wing Classroom H8	EST			
2 2 036 218	H Wing Classroom H8	EST			
2 2 037 219	H Wing Classroom H8	EST			
2 2 022 220	H Wing Classroom H9	EST			
2 2 021 221	H Wing Classroom H9	EST			
2 2 019 222	H Wing Classroom H9	EST			
2 2 020 223	H Wing Classroom H9	EST			
2 2 023 224	H Wing Classroom H10	EST			
2 2 024 225	H Wing Classroom H10A	EST			
2 2 025 226	H Wing Classroom H10A	EST			
2 2 033 227	H Wing Classroom H11	EST			
2 2 031 228	H Wing Classroom H11	EST			
2 2 030 229	H Wing Classroom H11	EST			
2 2 032 230	H Wing Classroom H11	EST			
2 2 010 231	H Wing Mens Restroom	EST			
2 2 046 232	H Wing Girls Restroom	EST			
2 2 057 238	I Wing Classroom I 1	EST			
2 2 056 239	I Wing Classroom I 1	EST			
2 2 058 240	I Wing Classroom I 1	EST			
2 2 059 241	I Wing Classroom I 1	EST			

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2 2 055 242	I Wing Classroom I 2	EST			
2 2 053 243	I Wing Classroom I 2	EST			
2 2 052 244	I Wing Classroom I 2	EST			
2 2 054 245	I Wing Classroom I 2	EST			
2 2 060 246	I Wing Classroom I 4	EST			
2 2 061 247	I Wing Classroom I 4	EST			
2 2 069 248	I Wing Classroom I 5	EST			
2 2 067 249	I Wing Classroom I 5	EST			
2 2 066 250	I Wing Classroom I 5	EST			
2 2 068 251	I Wing Classroom I 5	EST			
2 2 064 252	I Wing Classroom I 6	EST			
2 2 065 253	I Wing Classroom I 6	EST			
2 2 062 254	I Wing Classroom I 6	EST			
2 2 063 255	I Wing Classroom I 6	EST			
2 2 071 256	I Wing Custodial Room	EST			
2 2 075 263	J Wing Classroom J2	EST			
2 2 076 264	J Wing Classroom J2	EST			
2 2 078 265	J Wing Classroom J2	EST			
2 2 107 266	J Wing Classroom J2	EST			
2 2 080 267	J Wing Classroom J2	EST			
2 2 079 268	J Wing Classroom J2	EST			
2 2 077 269	J Wing Classroom J2	EST			
2 2 106 270	J Wing Classroom J2	EST			
2 2 089 271	J Wing Classroom J2 Storage	EST			
2 2 074 272	J Wing Classroom J3	EST			
2 2 070 273	J Wing Classroom J3	EST			
2 2 072 274	J Wing Classroom J3	EST			
2 2 073 275	J Wing Classroom J3	EST			
2 2 088 276	J Wing Classroom J4 Office	EST			
2 2 094 277	J Wing Classroom J5	EST			
2 2 092 278	J Wing Classroom J5 Storage	EST			
2 2 093 279	J Wing Classroom J5 Closet	EST			
2 2 090 280	J Wing Classroom J7 Closet	EST			
2 2 087 281	J Wing Classroom J7 Closet	EST			
2 2 100 282	J Wing Classroom J8	EST			
2 2 099 283	J Wing Classroom J8	EST			
2 2 091 284	J Wing Classroom J8 Storage	EST			

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2 2 105 285	J Wing Classroom J8 Storage	EST			
2 2 097 286	J Wing Classroom J9	EST			
2 2 095 287	J Wing Classroom J9	EST			
2 2 096 288	J Wing Classroom J9	EST			
2 2 098 289	J Wing Classroom J9	EST			
1 2 059 302	Portables Room P1	EST			
1 2 058 303	Portables Room P1	EST			
1 2 057 304	Portables Room P2	EST			
1 2 056 305	Portables Room P2	EST			
1 2 055 306	Portables Room P3	EST			
1 2 054 307	Portables Room P3	EST			
1 2 052 308	Portables Room P4	EST			
1 2 053 309	Portables Room P4	EST			
1 2 063 310	Portables Room P5	EST			
1 2 060 311	Portables Room P5	EST			
1 2 062 312	Portables Room P6	EST			
1 2 061 313	Portables Room P6	EST			
1 2 051 314	Portables Room P7	EST			
1 2 050 315	Portables Room P7	EST			
1 2 048 316	Portables Room P8	EST			
1 2 049 317	Portables Room P8	EST			
1 2 043 318	Portables APE Bldg Room	EST			
1 2 042 319	Portables APE Bldg Room	EST			
2 3 258 343	Cafeteria Bldgs Main Cafeteria Room	EST			
2 3 257 344	Cafeteria Bldgs Main Cafeteria Room	EST			
2 3 256 345	Cafeteria Bldgs Main Cafeteria Room	EST			
2 3 255 346	Cafeteria Bldgs Main Cafeteria Room	EST			
2 3 254 347	Cafeteria Bldgs Main Cafeteria Room	EST			
2 3 260 348	Cafeteria Bldgs Main Cafeteria Room	EST			
2 3 261 349	Cafeteria Bldgs Main Cafeteria Room	EST			
2 3 262 350	Cafeteria Bldgs Main Cafeteria Room	EST			
2 3 263 351	Cafeteria Bldgs Main Cafeteria Room	EST			
2 3 264 352	Cafeteria Bldgs Main Cafeteria Room	EST			
2 3 265 353	Cafeteria Bldgs Main Cafeteria Room	EST			
2 3 259 354	Cafeteria Bldgs Main Cafeteria Room	EST			
2 3 266 355	Cafeteria Bldgs Main Cafeteria Room	EST			
2 3 267 356	Cafeteria Bldgs Cafeteria Closet	EST			

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2 3 251 357	Cafeteria Bldgs Telecom Room	EST			
2 3 269 358	Cafeteria Bldgs Cafe E. Restroom	EST			
2 3 268 359	Cafeteria Bldgs Cafe E. Hall Entry	EST			
2 3 271 360	Cafeteria Bldgs Cafe Mid Hall E. Closet	EST			
2 3 270 361	Cafeteria Bldgs Cafe Mid Hall E. Closet	EST			
2 3 272 362	Cafeteria Bldgs Cafe Middle Hall RR	EST			
2 3 273 363	Cafeteria Bldgs Cafe Middle Hall	EST			
2 3 274 364	Cafeteria Bldgs Cafe Staff Room	EST			
2 3 275 365	Cafeteria Bldgs Cafe Staff Room	EST			
2 3 352 366	Cafeteria Bldgs E. Girls Restroom	EST			
2 3 277 367	Cafeteria Bldgs Cafe Middle Hall	EST			
2 3 276 368	Cafeteria Bldgs Cafe Middle Hall RR	EST			
2 3 278 369	Cafeteria Bldgs Cafe Mid Hall W. Closet	EST			
2 3 279 370	Cafeteria Bldgs Cafe Mid Hall W. Closet	EST			
2 3 280 371	Cafeteria Bldgs Cafeteria Restroom	EST			
2 3 281 372	Cafeteria Bldgs Cafe W. Hall Entry	EST			
2 3 282 373	Cafeteria Bldgs Boys W Restroom	EST			
2 3 284 374	Cafeteria Bldgs Attendance W Office	EST			
2 3 283 375	Cafeteria Bldgs Attendance W Office	EST			
2 3 285 376	Cafeteria Bldgs Attendance W Office	EST			
2 3 286 377	Cafeteria Bldgs Attendance Front Off	EST			
2 3 287 378	Cafeteria Bldgs Attendance Front Off	EST			
2 3 288 379	Cafeteria Bldgs Attendance E Office	EST			
2 3 289 380	Cafeteria Bldgs Attendance E Office	EST			
2 3 290 381	Cafeteria Bldgs Attendance E Office	EST			
2 3 305 382	Cafeteria Bldgs Kitchen	EST			
2 3 306 383	Cafeteria Bldgs Kitchen Restroom	EST			
2 3 304 384	Cafeteria Bldgs Kitchen Hall	EST			
2 3 303 385	Cafeteria Bldgs Kitchen Food Storage	EST			
2 3 054 414	Theater Building SE Entry	EST			
2 3 104 415	Theater Building SE Entry Storage	EST			
2 3 015 416	Theater Building Little Theater Stairway	EST			
2 3 023 417	Theater Building 2nd Floor Booth	EST			
2 3 024 418	Theater Building 2nd Floor Booth	EST			
2 3 030 419	Theater Building 2nd Floor Booth	EST			
2 3 011 420	Theater Building Little Theater	EST			
2 3 010 421	Theater Building Little Theater	EST			

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2 3 008 422	Theater Building Little Theater	EST			
2 3 009 423	Theater Building Little Theater	EST			
2 3 007 424	Theater Building Little Theater	EST			
2 3 006 425	Theater Building Little Theater	EST			
2 3 013 426	Theater Building Little Theater	EST			
2 3 004 427	Theater Building Little Theater	EST			
2 3 002 428	Theater Building Little Theater	EST			
2 3 003 429	Theater Building Little Theater	EST			
2 3 005 430	Theater Building Little Theatre	EST			
2 3 016 431	Theater Building Little Theater Storage	EST			
2 3 014 432	Theater Building Large Storage Room	EST			
2 3 020 433	Theater Building Prep Room	EST			
2 3 018 434	Theater Building North Storage Room	EST			
2 3 001 435	Theater Building Equipment Room	EST			
2 3 032 436	Theater Building North Restroom	EST			
2 3 027 437	Theater Building Teachers Room	EST			
2 3 028 438	Theater Building North Hall	EST			
2 3 029 439	Theater Building Coed Restroom	EST			
2 3 031 440	Theater Building North Hall Closet	EST			
2 3 025 441	Theater Building South Hall	EST			
2 3 026 442	Theater Building Coed Restroom	EST			
2 3 021 443	Theater Building W Boys Restroom	EST			
2 3 022 444	Theater Building W Boys Restroom	EST			
2 3 033 445	Theater Building Counselor Office 531	EST			
2 3 036 446	Theater Building Counselors Hall	EST			
2 3 035 447	Theater Building Counselor Office 506	EST			
2 3 037 448	Theater Building Main Lobby	EST			
2 3 039 449	Theater Building Counselor Office 502	EST			
2 3 038 450	Theater Building Counselors Hall	EST			
2 3 040 451	Theater Building Counselor Office 501	EST			
2 3 042 452	Theater Building Counselor Office 504	EST			
2 3 041 453	Theater Building Counselor Office 503	EST			
2 3 034 454	Theater Building Counselor Office 507	EST			
2 3 043 455	Theater Building Counselor South RR	EST			
2 3 017 456	Theater Building E Girls Restroom	EST			
2 3 019 457	Theater Building E Girls Restroom	EST			
1 2 280 484	Gym Locker Bldgs Small Gym	EST			

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
1 2 281 485	Gym Locker Bldgs Small Gym	EST			
1 2 282 486	Gym Locker Bldgs Small Gym	EST			
1 2 283 487	Gym Locker Bldgs Small Gym	EST			
1 2 284 488	Gym Locker Bldgs Small Gym	EST			
1 2 285 489	Gym Locker Bldgs Small Gym	EST			
1 2 286 490	Gym Locker Bldgs Small Gym	EST			
1 2 273 491	Gym Locker Bldgs Small Gym	EST			
1 2 274 492	Gym Locker Bldgs Small Gym	EST			
1 2 275 493	Gym Locker Bldgs Small Gym	EST			
1 2 276 494	Gym Locker Bldgs Small Gym	EST			
1 2 277 495	Gym Locker Bldgs Small Gym	EST			
1 2 278 496	Gym Locker Bldgs Small Gym	EST			
1 2 279 497	Gym Locker Bldgs Small Gym	EST			
1 2 251 498	Gym Locker Bldgs Hall Equip Rm by Small Gym	EST			
1 2 308 499	Gym Locker Bldgs Large Gym	EST			
1 2 309 500	Gym Locker Bldgs Large Gym	EST			
1 2 310 501	Gym Locker Bldgs Large Gym	EST			
1 2 311 502	Gym Locker Bldgs Large Gym	EST			
1 2 312 503	Gym Locker Bldgs Large Gym	EST			
1 2 313 504	Gym Locker Bldgs Large Gym	EST			
1 2 314 505	Gym Locker Bldgs Large Gym	EST			
1 2 307 506	Gym Locker Bldgs Large Gym	EST			
1 2 306 507	Gym Locker Bldgs Large Gym	EST			
1 2 305 508	Gym Locker Bldgs Large Gym	EST			
1 2 304 509	Gym Locker Bldgs Large Gym	EST			
1 2 303 510	Gym Locker Bldgs Large Gym	EST			
1 2 302 511	Gym Locker Bldgs Large Gym	EST			
1 2 301 512	Gym Locker Bldgs Large Gym	EST			
1 2 294 513	Gym Locker Bldgs Large Gym	EST			
1 2 295 514	Gym Locker Bldgs Large Gym	EST			
1 2 296 515	Gym Locker Bldgs Large Gym	EST			
1 2 297 516	Gym Locker Bldgs Large Gym	EST			
1 2 298 517	Gym Locker Bldgs Large Gym	EST			
1 2 299 518	Gym Locker Bldgs Large Gym	EST			
1 2 300 519	Gym Locker Bldgs Large Gym	EST			
1 2 293 520	Gym Locker Bldgs Large Gym	EST			
1 2 292 521	Gym Locker Bldgs Large Gym	EST			

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
1 2 291 522	Gym Locker Bldgs Large Gym	EST			
1 2 290 523	Gym Locker Bldgs Large Gym	EST			
1 2 289 524	Gym Locker Bldgs Large Gym	EST			
1 2 288 525	Gym Locker Bldgs Large Gym	EST			
1 2 287 526	Gym Locker Bldgs Large Gym	EST			
1 2 315 527	Gym Locker Bldgs Large Gym Storage	EST			
1 2 321 528	Gym Locker Bldgs Large Gym Storage	EST			
1 2 317 529	Gym Locker Bldgs Large Gym Lobby	EST			
1 2 318 530	Gym Locker Bldgs Large Gym Lobby	EST			
1 2 319 531	Gym Locker Bldgs Large Gym Ticket Booth	EST			
1 2 316 532	Gym Locker Bldgs Large Gym Mens RR	EST			
1 2 320 533	Gym Locker Bldgs Large Gym Womens RR	EST			
1 2 268 534	Gym Locker Bldgs Boys Locker Storage	EST			
1 2 265 535	Gym Locker Bldgs Hall Entry Boys Locker	EST			
1 2 266 536	Gym Locker Bldgs Boys Locker Closet	EST			
1 2 263 537	Gym Locker Bldgs Boys Coach Office	EST			
1 2 262 538	Gym Locker Bldgs Girls Coach Office	EST			
1 2 253 539	Gym Locker Bldgs Girls Locker Restroom	EST			
1 2 255 540	Gym Locker Bldgs Girls Lock Hall Closet	EST			
1 2 261 541	Gym Locker Bldgs Girls Locker Storage	EST			
1 2 259 542	Gym Locker Bldgs Girls Lock O S Strg	EST			
1 2 260 543	Gym Locker Bldgs Girls Locker Storage	EST			
1 2 252 544	Gym Locker Bldgs E. Storage Outside Girls Locker	EST			
1 2 340 578	Weight Room Weight Room	EST			
1 2 337 579	Weight Room Weight Room	EST			
1 2 338 580	Weight Room Weight Room	EST			
1 2 341 581	Weight Room Weight Room	EST			
1 2 342 582	Weight Room Weight Room	EST			
1 2 339 583	Weight Room Weight Room	EST			
1 2 345 588	Football Stadium Mens Restroom	EST			
1 2 344 589	Football Stadium Womens Restroom	EST			
3.2.030	New Theater Building Classroom M1				
3.2.028	New Theater Building Classroom M1				
3.2.027	New Theater Building Classroom M1				
3.2.029	New Theater Building Classroom M1				
3.2.026	New Theater Building Classroom M1/M2 Storage				
3.2.025	New Theater Building Classroom M1/M2 Office				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3.2.015	New Theater Building Classroom M2				
3.2.016	New Theater Building Classroom M2				
3.2.017	New Theater Building Classroom M2				
3.2.018	New Theater Building Classroom M2				
3.2.024	New Theater Building Classroom M1/M2 Hallway				
3.2.019	New Theater Building Classroom M1/M2 Hallway				
3.2.020	New Theater Building M1/M2 Practice Rm M126				
3.2.021	New Theater Building M1/M2 Practice Rm M125				
3.2.022	New Theater Building M1/M2 Practice Rm M124				
3.2.023	New Theater Building M1/M2 Practice Rm M123				
3.2.008	New Theater Building Hall Between Classrooms & Stage				
3.2.010	New Theater Building Hall Between Classrooms & Stage				
3.2.014	New Theater Building Hall Between Classrooms & Stage				
3.2.009	New Theater Building West Girls Restroom				
3.2.007	New Theater Building West Boys Restroom				
3.2.012	New Theater Building Chair Stage Storage				
3.2.013	New Theater Building Hall & Stage Vestibule				
3.2.039	New Theater Building Stage Curtain Storage West				
3.2.034	New Theater Building Stage Curtain Storage East				
3.2.072	New Theater Building Stage Piano Storage				
3.2.073	New Theater Building Stage Piano Storage				
3.2.076	New Theater Building East Vestibule				
3.2.077	New Theater Building East Vestibule				
3.2.078	New Theater Building East Hallway				
3.2.079	New Theater Building East Boys Restroom				
3.2.075	New Theater Building East Janitor Rm				
3.2.074	New Theater Building East Girls Restroom				
3.2.064	New Theater Building North Lobby				
3.2.063	New Theater Building North Lobby				
3.2.062	New Theater Building 2nd Floor North Lobby				
3.2.058	New Theater Building North Lobby				
3.2.059	New Theater Building 1st Floor Elevator Lobby				
3.2.060	New Theater Building Elevator Equipment Rm				
3.2.080	New Theater Building Ticket Booth				
3.2.065	New Theater Building 2nd Floor Elevator Lobby				
3.2.071	New Theater Building 2nd Floor Vestibule				
3.2.069	New Theater Building 2nd Floor Recording Rm				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3.2.070	New Theater Building 2nd Floor Roof Access				
3.2.130	New Theater Building Attic West Boys Restroom				
3.2.006	New Theater Building Riser Room				
3.2.005	New Theater Building Electrical Room				
3.2.004	New Theater Building IDF/FACP Room				
2 3 105	Theater Building Dressing Room	EST			
Heat Detector - Restorable Spot					
1 2 024 045	Admin Library Bldg Staff Room	EST			
1 2 135 046	Admin Library Bldg Attic Secretary Desk				
1 2 134 047	Admin Library Bldg Attic Conference Room				
1 2 133 048	Admin Library Bldg Attic Principals Office				
1 2 137 049	Admin Library Bldg Attic West Restroom				
1 2 132 050	Admin Library Bldg Attic Library Office				
1 2 131 051	Admin Library Bldg Attic Library Computer Lab				
1 2 130 052	Admin Library Bldg Attic Library N. Book Storage				
2 3 384 083	A Wing Attic Classroom A4A				
2 3 384 084	A Wing Attic Classroom A4A				
2 3 383 085	A Wing Attic Classroom A11				
2 3 385 114	B Wing Attic Classroom B4A				
2 3 380 115	B Wing Attic Classroom B12				
2 3 380 116	B Wing Attic Classroom B12				
2 3 133 136	C Wing Attic Classroom C12B				
2 3 063 162	D Wing Classroom D8	EST			
2 3 062 163	D Wing Classroom D8	EST			
2 3 069 164	D Wing Classroom D13	EST			
2 3 070 165	D Wing Classroom D13	EST			
2 3 128 166	D Wing Attic Classrm D4A				
2 3 129 167	D Wing Attic Classrm D4B				
2 3 132 168	D Wing Attic Classrm D10				
2 3 131 169	D Wing Attic Classrm D11B				
2 3 130 170	D Wing Attic Classrm D12				
2 3 142 182	E Wing Attic Closet				
2 2 018 233	H Wing Classroom H7	EST			
2 2 127 234	H Wing Attic Classroom H3				
2 2 126 235	H Wing Attic Classroom H10				
2 2 126 236	H Wing Attic Classroom H10				
2 2 129 257	I Wing Attic Classroom I 1				
2 2 128 258	I Wing Attic Classroom I 2				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2 2 130 259	I Wing Attic Classroom I 4				
2 2 086 262	J Wing Classroom J1 Saw Rm	EST			
2 2 081 290	J Wing Classroom J1	EST			
2 2 082 291	J Wing Classroom J1	EST			
2 2 083 292	J Wing Classroom J1	EST			
2 2 084 293	J Wing Classroom J1 Storage	EST			
2 2 137 294	J Wing J1 Paint Room	EST			
2 2 101 295	J Wing Room J7 Auto Shop	EST			
2 2 102 296	J Wing Room J7 Auto Shop	EST			
2 2 103 297	J Wing Room J7 Auto Shop	EST			
2 2 104 298	J Wing Room J7 Auto Shop	EST			
2 2 085 299	J Wing J7 Outside Closet	EST			
2 2 131 300	J Wing Attic Classroom J5				
2 2 132 301	J Wing Attic Rm J7 Auto Shop				
1 2 140 320	Portables Attic Room P1				
1 2 140 321	Portables Attic Room P1				
1 2 139 322	Portables Attic Room P2				
1 2 139 323	Portables Attic Room P2				
1 2 138 324	Portables Attic Room P3				
1 2 138 325	Portables Attic Room P3				
1 2 144 326	Portables Attic Room P4				
1 2 144 327	Portables Attic Room P4				
1 2 142 328	Portables Attic Room P5				
1 2 142 329	Portables Attic Room P5				
1 2 141 330	Portables Attic Room P6				
1 2 141 331	Portables Attic Room P6				
1 2 143 332	Portables Attic Room P7				
1 2 143 333	Portables Attic Room P7				
1 2 146 334	Portables Attic Room P8				
1 2 146 335	Portables Attic Room P8				
1 2 147 336	Portables Attic APE Bldg				
1 2 147 337	Portables Attic APE Bldg				
2 3 252 386	Cafeteria Bldgs Sales Booth	EST			
2 3 253 387	Cafeteria Bldgs Food Booth	EST			
2 3 307 388	Cafeteria Bldgs Kitchen	EST			
2 3 382 389	Cafeteria Bldgs Boiler Room				
2 3 382 390	Cafeteria Bldgs Boiler Room				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2 3 376 391	Cafeteria Bldgs Attic West Hall				
2 3 377 392	Cafeteria Bldgs Attic Staff Room				
2 3 377 393	Cafeteria Bldgs Attic Staff Room				
2 3 377 394	Cafeteria Bldgs Attic Staff Room				
2 3 378 395	Cafeteria Bldgs Attic Attend W Office				
2 3 379 396	Cafeteria Bldgs Attic Attend E Office				
2 3 381 397	Cafeteria Bldgs Attic Kitch Food Storage				
2 3 012 458	Theater Building Snack Bar	EST			
2 3 126 459	Theater Building Attic Theater Prep Rm				
2 3 127 460	Theater Building Attic Theat Staff Rm				
2 3 127 461	Theater Building Attic Theat Staff Rm				
2 3 127 462	Theater Building Attic Theat Staff Rm				
2 3 127 463	Theater Building Attic Theat Staff Rm				
2 3 143 464	Theater Building Attic Counselor Hall				
1 2 376 545	Gym Locker Bldgs Boys Locker Room RR	EST			
1 2 267 546	Gym Locker Bldgs Boys Locker Entry	EST			
1 2 380 547	Gym Locker Bldgs Boys Locker Room	EST			
1 2 380 548	Gym Locker Bldgs Boys Locker Room	EST			
1 2 270 549	Gym Locker Bldgs NE Entry Boys Locker	EST			
1 2 269 550	Gym Locker Bldgs Boys Locker Room	EST			
1 2 271 551	Gym Locker Bldgs Boys Locker Room	EST			
1 2 379 552	Gym Locker Bldgs Telcom Rm by Boys Locker Rm	EST			
1 2 379 553	Gym Locker Bldgs Boys Coach Off RR	EST			
1 2 379 554	Gym Locker Bldgs Boys Coach Off RR	EST			
1 2 379 555	Gym Locker Bldgs Girls Coach Off RR	EST			
1 2 272 556	Gym Locker Bldgs Pool Training Room	EST			
1 2 387 557	Gym Locker Bldgs Gym Locker Hallway	EST			
1 2 387 558	Gym Locker Bldgs Gym Locker Hallway	EST			
1 2 387 559	Gym Locker Bldgs Gym Locker Hallway	EST			
1 2 387 560	Gym Locker Bldgs Gym Locker Hallway	EST			
1 2 387 561	Gym Locker Bldgs Gym Locker Hallway	EST			
1 2 254 562	Gym Locker Bldgs Girls Locker Rm Hall	EST			
1 2 256 563	Gym Locker Bldgs Girls Locker Room	EST			
1 2 378 564	Gym Locker Bldgs Girls Locker Room	EST			
1 2 378 565	Gym Locker Bldgs Girls Locker Room	EST			
1 2 378 566	Gym Locker Bldgs Football Storage Rm	EST			
1 2 257 567	Gym Locker Bldgs Girls Locker Room	EST			

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
1 2 258 568	Gym Locker Bldgs Girls Locker Room	EST			
1 2 377 569	Gym Locker Bldgs Boiler Rm Outside Girls Locker	EST			
1 2 381 570	Gym Locker Bldgs Attic Lrg Gym Foyer				
1 2 388 584	Weight Room Attic Weight Room				
1 2 388 585	Weight Room Attic Weight Room				
1 2 388 586	Weight Room Attic Weight Room				
1 2 388 587	Weight Room Attic Weight Room				
1 2 343 590	Football Stadium Snack Bar	EST			
1 2 389 591	Football Stadium Attic Snack Bar RRs				
1 2 389 592	Football Stadium Attic Snack Bar RRs				
1 2 389 593	Football Stadium Attic Snack Bar RRs				
2 3 385	B Wing Attic Classroom B4B				
2 3 383	A Wing Attic Classroom A11				
3.2.142	New Theater Building Attic Classroom M1				
3.2.142	New Theater Building Attic Classroom M1				
3.2.136	New Theater Building Attic Classroom M2				
3.2.136	New Theater Building Attic Classroom M2				
3.2.141	New Theater Building Attic Classroom M1/M2 Storage				
3.2.190	New Theater Building Attic Classroom M1/M2 Office				
3.2.190	New Theater Building Attic Classroom M1/M2 Hall				
3.2.140	New Theater Building Attic M1/M2 Practice Rm M123				
3.2.139	New Theater Building Attic M1/M2 Practice Rm M124				
3.2.138	New Theater Building Attic M1/M2 Practice Rm M125				
3.2.137	New Theater Building Attic M1/M2 Practice Rm M126				
3.2.132	New Theater Building Attic Hall Between Classrooms & Stage				
3.2.132	New Theater Building Attic Hall Between Classrooms & Stage				
3.2.134	New Theater Building Attic Hall & Stage Vestibule				
3.2.131	New Theater Building Attic Hall & Stage Vestibule South				
3.2.133	New Theater Building Attic Chair Stage Storage				
3.2.158	New Theater Building Attic Stage Piano Storage				
3.2.160	New Theater Building Attic East Vestibule				
3.2.159	New Theater Building Attic East Janitor Rm				
3.2.161	New Theater Building Attic Ticket Booth				
3.2.157	New Theater Building Attic 2nd Floor Vestibule				
3.2.146	New Theater Building Attic 2nd Floor Recording Rm				
3.2.155	New Theater Building Attic 2nd Floor Elevator Lobby				
3.2.143	New Theater Building Attic Elevator Shaft				
3.2.011	New Theater Building Hall & Stage Vestibule South				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3.2.148	New Theater Building Attic Stage Above Seating				
3.2.148	New Theater Building Attic Stage Above Seating				
Smoke Detector - Duct					
2 3 134 465	Theater Building Duct Smoke 1				
2 3 135 466	Theater Building Duct Smoke 2				
2 3 136 467	Theater Building Duct Smoke 3				
2 3 137 468	Theater Building Duct Smoke 4				
2 3 138 469	Theater Building Duct Smoke 5				
2 3 139 470	Theater Building Duct Smoke 6				
2 3 140 471	Theater Building Duct Smoke 7				
2 3 141 472	Theater Building Duct Smoke 8				
1 2 382 571	Gym Locker Bldgs Large Gym Foyer				
1 2 383 572	Gym Locker Bldgs Large Gym Foyer				
1 2 384 573	Gym Locker Bldgs Large Gym Foyer				
Smoke Detector - Projected Beam					
3.2.182	New Theater Building Stage Beam 1				
3.2.184	New Theater Building Stage Beam 2				
3.2.186	New Theater Building Stage Beam 3				
3.2.188	New Theater Building Stage Beam 4				
Mechanical, Electrosonic, or Pressure Waterflow Device					
3.2.128	New Theater Building Riser Room				
Valve Tamper Switch					
3.2.162	New Theater Building West Exterior - P.I.V.				
Power Supplies					
ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
FACP					
	H Wing Room H5 Telecom Rm	Fire Lite			
Ventilation and Cooking Equipment					
ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Range Suppression Tank					
	WHDR400M Cylinder				01/01/2024
Range Suppression					
	Fire Suppression				01/01/2024
Range Hood					
	Hood				01/01/2024
Fusible Links					
	Fusible Links				01/01/2024
Cooking Equipment					
	Appliances				01/01/2024