

Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

MISSION AVE ELEMENTARY

2925 MISSION AVE
CARMICHAEL, California 95608
United States

This site has been inspected and tested in compliance with applicable standards.

Completed
Tuesday, September 30, 2025

Test Session: 17 Sep 2025 18:18 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD
5320 HEMLOCK ST
SACRAMENTO, California
United States

TESTED BY

Riley Goyet
Western States Fire Protection-
Sacramento
188 Cirby Way
Roseville, CA 95678
United States



Inspection Summary

Building Information

PROPERTY	MISSION AVE ELEMENTARY	CONTACT
ADDRESS	2925 MISSION AVE	PHONE
CITY/STATE	CARMICHAEL, California 95608	MOBILE
COUNTRY	United States	EMAIL

Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us

Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Alarm Notification Appliance	54	54(100%)	54(100%)	0(0%)
Power Supplies	10	10(100%)	10(100%)	0(0%)
Fire Control Panel	6	6(100%)	6(100%)	0(0%)
Initiating Device	128	125(98%)	125(98%)	0(0%)

Certification

The equipment specified here in was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Tuesday, September 30, 2025

ACCEPTED BY 09/30/2025

Building Representative

TESTED BY



09/30/2025

Riley Goyet

Technician

System Details

Control Units

ADDRESS/ SCAN ADDRESS	DESCRIPTION	Building D Room D1
MANUFACTURER	S/W VERSION	
MODEL	LAST UPDATE	
SERIAL NUMBER	S/W LOCATION	
INSTALL DATE		

Secondary Power

TYPE	Battery - Sealed Lead-acid	DESCRIPTION	Building D Room D1 - Right Battery
ADDRESS/ SCAN ADDRESS		NOMINAL VOLTAGE	12
Load Voltage		Amp Hours	55
Standby Hours		Alarm Minutes	
Battery Location		Charger Voltage	
TYPE	Battery - Sealed Lead-acid	DESCRIPTION	Building D Room D1 - Left Battery
ADDRESS/ SCAN ADDRESS		NOMINAL VOLTAGE	12
Load Voltage		Amp Hours	55
Standby Hours		Alarm Minutes	
Battery Location		Charger Voltage	
TYPE	Battery - Sealed Lead-acid	DESCRIPTION	Building D Room D1 - P.E. "B" - Right Battery
ADDRESS/ SCAN ADDRESS		NOMINAL VOLTAGE	12
Load Voltage		Amp Hours	8
Standby Hours		Alarm Minutes	
Battery Location		Charger Voltage	
TYPE	Battery - Sealed Lead-acid	DESCRIPTION	Building D Room D1 - P.E. "C" - Right Battery
ADDRESS/ SCAN ADDRESS		NOMINAL VOLTAGE	12
Load Voltage		Amp Hours	8
Standby Hours		Alarm Minutes	
Battery Location		Charger Voltage	
TYPE	Battery - Sealed Lead-acid	DESCRIPTION	Building D Room D1 - P.E. "D" - Right Battery
ADDRESS/ SCAN ADDRESS		NOMINAL VOLTAGE	12
Load Voltage		Amp Hours	8
Standby Hours		Alarm Minutes	
Battery Location		Charger Voltage	
TYPE	Battery - Sealed Lead-acid	DESCRIPTION	Building D Room D1 - P.E. "Master" - Right Battery
ADDRESS/ SCAN ADDRESS		NOMINAL VOLTAGE	12
Load Voltage		Amp Hours	8
Standby Hours		Alarm Minutes	
Battery Location		Charger Voltage	
TYPE	Battery - Sealed Lead-acid	DESCRIPTION	Building D Room D1 - P.E. "C" - Left Battery
ADDRESS/ SCAN ADDRESS		NOMINAL VOLTAGE	12
Load Voltage		Amp Hours	8

Standby Hours		Alarm Minutes	
Battery Location		Charger Voltage	
TYPE	Battery - Sealed Lead-acid	DESCRIPTION	Building D Room D1 - P.E. "D" - Left Battery
ADDRESS/ SCAN ADDRESS		NOMINAL VOLTAGE	12
Load Voltage		Amp Hours	8
Standby Hours		Alarm Minutes	
Battery Location		Charger Voltage	
TYPE	Battery - Sealed Lead-acid	DESCRIPTION	Building D Room D1 - P.E. "Master" - Left Battery
ADDRESS/ SCAN ADDRESS		NOMINAL VOLTAGE	12
Load Voltage		Amp Hours	8
Standby Hours		Alarm Minutes	
Battery Location		Charger Voltage	
TYPE	Battery - Sealed Lead-acid	DESCRIPTION	Building D Room D1 - P.E. "B" - Left Battery
ADDRESS/ SCAN ADDRESS		NOMINAL VOLTAGE	
Load Voltage		Amp Hours	
Standby Hours		Alarm Minutes	
Battery Location		Charger Voltage	

Testing Details

Alarm Notification Appliance

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible	016	Building A Admin Reception A1	Manual	9/17/2025 8:41:48 PM
		Visual inspection	Passed (Manual)	
Visible	017	Building A Room A1A	Manual	9/17/2025 8:41:47 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	015	Building A Room A2	Manual	9/17/2025 8:42:24 PM
		Functional Inspection	Passed	
Visible	020	Building A Room A3 RR	Manual	9/17/2025 8:41:36 PM
		Visual inspection	Passed (Manual)	
Visible	021	Building A Room A4 RR	Manual	9/17/2025 8:41:35 PM
		Functional Inspection	Passed	
Audible And Visible	014	Building A Room A6	Manual	9/17/2025 8:42:25 PM
		Visual inspection	Passed (Manual)	
Visible	018	Building A Room A6	Manual	9/17/2025 8:41:40 PM
		Functional Inspection	Passed	
Visible	019	Building A Room A6A RR	Manual	9/17/2025 8:41:39 PM
		Visual inspection	Passed (Manual)	
Visible	062	Building B Boys RR B7	Manual	9/17/2025 8:41:58 PM
		Functional Inspection	Passed	
Visible	059	Building B Classroom B1	Manual	9/17/2025 8:42:03 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	055	Building B Classroom B2	Manual	9/17/2025 8:43:05 PM
		Functional Inspection	Passed	
Visible	060	Building B Classroom B2A Storage	Manual	9/17/2025 8:42:01 PM
		Visual inspection	Passed (Manual)	
Visible	061	Building B Classroom B2B Storage	Manual	9/17/2025 8:42:00 PM
		Functional Inspection	Passed	
Audible And Visible	056	Building B Classroom B3	Manual	9/17/2025 8:43:04 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	057	Building B Classroom B4	Manual	9/17/2025 8:43:02 PM
		Functional Inspection	Passed	
Audible And Visible	058	Building B Classroom B5	Manual	9/17/2025 8:43:01 PM
		Visual inspection	Passed (Manual)	
Visible	063	Building B Girls RR B9	Manual	9/17/2025 8:41:57 PM
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	051	Building B North Exterior	Manual	9/17/2025 8:42:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	052	Building B South Exterior	Manual	9/17/2025 8:42:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	053	Building B Southwest Exterior	Manual	9/17/2025 8:42:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	054	Building B West Exterior	Manual	9/17/2025 8:42:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	077	Building C Classroom C1	Manual	9/17/2025 8:42:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	078	Building C Classroom C2	Manual	9/17/2025 8:42:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	076	Building C North Exterior	Manual	9/17/2025 8:42:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	104	Building D Classroom D3	Manual	9/17/2025 8:42:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	105	Building D Classroom D4	Manual	9/17/2025 8:42:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	106	Building D Classroom D5	Manual	9/17/2025 8:42:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	107	Building D Classroom D6	Manual	9/17/2025 8:42:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	108	Building D Classroom D7	Manual	9/17/2025 8:42:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	109	Building D MDF Classroom D2	Manual	9/17/2025 8:41:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	102	Building D North Exterior	Manual	9/17/2025 8:42:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	103	Building D South Exterior	Manual	9/17/2025 8:42:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	135	Building E Classroom E1	Manual	9/17/2025 8:42:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	141	Building E Classroom E1/E2	Manual	9/17/2025 8:41:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	140	Building E Classroom E1/E2	Manual	9/17/2025 8:41:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	136	Building E Classroom E2	Manual	9/17/2025 8:42:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	137	Building E Classroom E3	Manual	9/17/2025 8:42:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	138	Building E Classroom E4	Manual	9/17/2025 8:42:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	139	Building E Classroom E5	Manual	9/17/2025 8:42:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	132	Building E Northwest Exterior	Manual	9/17/2025 8:42:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	133	Building E South Exterior	Manual	9/17/2025 8:42:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	134	Building E West Exterior	Manual	9/17/2025 8:42:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	171	Building F Boys RR	Manual	9/17/2025 8:41:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	172	Building F Girls RR	Manual	9/17/2025 8:41:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	169	Building F Kitchen F7	Manual	9/17/2025 8:42:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	168	Building F Kitchen F7	Manual	9/17/2025 8:42:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	166	Building F MP Room	Manual	9/17/2025 8:42:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	165	Building F MP Room	Manual	9/17/2025 8:42:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	170	Building F Room F3	Manual	9/17/2025 8:42:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	164	Building F South Exterior	Manual	9/17/2025 8:42:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	167	Building F Stage	Manual	9/17/2025 8:42:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	182	Building G Classroom G1	Manual	9/17/2025 8:42:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	183	Building G Classroom G2	Manual	9/17/2025 8:42:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	181	Building G South Exterior	Manual	9/17/2025 8:42:04 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Remote Annunciator	001	Building A Admin Reception A1	Manual	9/17/2025 8:41:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Fire Alarm Panel		Building D Room D1	Manual	9/18/2025 2:50:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Building D Room D1 - P.E. "B"	Manual	9/18/2025 2:50:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Building D Room D1 - P.E. "C"	Manual	9/18/2025 2:50:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Building D Room D1 - P.E. "D"	Manual	9/18/2025 2:50:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Building D Room D1 - P.E. "Master"	Manual	9/18/2025 2:50:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Manual Pull Station	2-137 002	Building A Admin Reception A1	Manual	9/17/2025 6:43:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-140 013	Building A Attic Room A1A	Manual	9/18/2025 2:33:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-045 012	Building A Custodial Closet A5	Manual	9/17/2025 6:46:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-037 003	Building A Room A1	Manual	9/17/2025 6:43:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-039 004	Building A Room A1A	Manual	9/17/2025 6:43:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-044 008	Building A Room A2	Manual	9/17/2025 6:44:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-043 009	Building A Room A2	Manual	9/17/2025 6:44:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-047 010	Building A Room A3 RR	Manual	9/17/2025 6:46:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-046 011	Building A Room A4 RR	Manual	9/17/2025 6:46:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-041 006	Building A Room A6	Manual	9/17/2025 6:44:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-040 005	Building A Room A6	Manual	9/17/2025 6:45:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-042 007	Building A Room A6A RR	Manual	9/17/2025 6:45:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-052 046	Building B Boys RR B7	Manual	9/17/2025 7:11:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-049 022	Building B Classroom B1	Manual	9/17/2025 6:55:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-062 026	Building B Classroom B2	Manual	9/17/2025 6:52:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-066 025	Building B Classroom B2	Manual	9/17/2025 6:52:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-067 024	Building B Classroom B2	Manual	9/17/2025 6:52:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-061 023	Building B Classroom B2	Manual	9/17/2025 6:52:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-063 027	Building B Classroom B2	Manual	9/17/2025 6:53:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-064 028	Building B Classroom B2A Storage	Manual	9/17/2025 6:54:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-065 029	Building B Classroom B2B Storage	Manual	9/17/2025 6:53:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-059 030	Building B Classroom B3	Manual	9/17/2025 6:57:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-060 033	Building B Classroom B3	Manual	9/17/2025 6:58:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-068 032	Building B Classroom B3	Manual	9/17/2025 6:58:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-069 031	Building B Classroom B3	Manual	9/17/2025 6:58:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-058 034	Building B Classroom B4	Manual	9/17/2025 7:00:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-070 037	Building B Classroom B4	Manual	9/17/2025 7:00:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-071 035	Building B Classroom B4	Manual	9/17/2025 7:00:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-057 036	Building B Classroom B4	Manual	9/17/2025 7:00:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-055 038	Building B Classroom B5	Manual	9/17/2025 7:01:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-073 039	Building B Classroom B5	Manual	9/17/2025 7:01:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-072 040	Building B Classroom B5	Manual	9/17/2025 7:02:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-056 041	Building B Classroom B5	Manual	9/17/2025 7:02:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-054 042	Building B Classroom B6	Manual	9/17/2025 7:03:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-074 045	Building B Classroom B6	Manual	9/17/2025 7:03:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-075 044	Building B Classroom B6	Manual	9/17/2025 7:03:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-053 043	Building B Classroom B6	Manual	9/17/2025 7:04:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-051 048	Building B Girls RR B9	Manual	9/17/2025 7:12:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-050 047	Building B Storage Room B8	Manual	9/17/2025 7:10:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-138 072	Building C Attic Classroom C1	Manual	9/18/2025 2:50:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-138 073	Building C Attic Classroom C1	Manual	9/18/2025 2:50:09 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	2-139 074	Building C Attic Classroom C2	Manual	9/18/2025 2:50:04 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	2-139 075	Building C Attic Classroom C2	Manual	9/18/2025 2:50:06 PM
		Functional Inspection	Passed	
Smoke Detector - General	2-079 064	Building C Classroom C1	Manual	9/17/2025 7:06:06 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-078 066	Building C Classroom C1	Manual	9/17/2025 7:06:23 PM
		Functional Inspection	Passed	
Smoke Detector - General	2-077 065	Building C Classroom C1	Manual	9/17/2025 7:06:25 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-080 067	Building C Classroom C1	Manual	9/17/2025 7:07:09 PM
		Functional Inspection	Passed	
Smoke Detector - General	2-081 068	Building C Classroom C2	Manual	9/17/2025 7:08:32 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-082 069	Building C Classroom C2	Manual	9/17/2025 7:08:37 PM
		Functional Inspection	Passed	
Smoke Detector - General	2-084 070	Building C Classroom C2	Manual	9/17/2025 7:08:55 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-083 071	Building C Classroom C2	Manual	9/17/2025 7:09:24 PM
		Functional Inspection	Passed	
Smoke Detector - General	2-023 084	Building D Classroom D3	Manual	9/17/2025 7:22:33 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-024 081	Building D Classroom D3	Manual	9/17/2025 7:22:49 PM
		Functional Inspection	Passed	
Smoke Detector - General	2-005 082	Building D Classroom D3	Manual	9/17/2025 7:23:06 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-006 083	Building D Classroom D3	Manual	9/17/2025 7:23:25 PM
		Functional Inspection	Passed	
Smoke Detector - General	2-022 085	Building D Classroom D4	Manual	9/17/2025 7:21:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-021 088	Building D Classroom D4	Manual	9/17/2025 7:21:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-008 087	Building D Classroom D4	Manual	9/17/2025 7:21:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-007 086	Building D Classroom D4	Manual	9/17/2025 7:21:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-010 091	Building D Classroom D5	Manual	9/17/2025 7:19:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-009 090	Building D Classroom D5	Manual	9/17/2025 7:19:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-020 089	Building D Classroom D5	Manual	9/17/2025 7:19:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-019 092	Building D Classroom D5	Manual	9/17/2025 7:20:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-018 093	Building D Classroom D6	Manual	9/17/2025 7:17:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-011 094	Building D Classroom D6	Manual	9/17/2025 7:17:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-012 095	Building D Classroom D6	Manual	9/17/2025 7:18:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-017 096	Building D Classroom D6	Manual	9/17/2025 7:18:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-015 097	Building D Classroom D7	Manual	9/17/2025 7:14:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-016 100	Building D Classroom D7	Manual	9/17/2025 7:14:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-013 099	Building D Classroom D7	Manual	9/17/2025 7:14:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-014 098	Building D Classroom D7	Manual	9/17/2025 7:14:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-004 080	Building D MDF Classroom D2	Manual	9/17/2025 7:24:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-003 101	Building D Room D1	Manual	9/18/2025 2:33:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-002 079	Building D Room D1	Manual	9/17/2025 7:25:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-277 110	Building E Classroom E1	Manual	9/17/2025 7:26:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-276 113	Building E Classroom E1	Manual	9/17/2025 7:26:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-275 112	Building E Classroom E1	Manual	9/17/2025 7:27:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-278 111	Building E Classroom E1	Manual	9/17/2025 7:27:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-279 114	Building E Classroom E1	Manual	9/17/2025 7:28:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-274 115	Building E Classroom E2	Manual	9/17/2025 7:28:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-273 116	Building E Classroom E2	Manual	9/17/2025 7:28:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-258 117	Building E Classroom E2	Manual	9/17/2025 7:29:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-259 118	Building E Classroom E2	Manual	9/17/2025 7:29:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-272 119	Building E Classroom E2	Manual	9/17/2025 7:29:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-271 120	Building E Classroom E3	Manual	9/17/2025 7:30:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-260 121	Building E Classroom E3	Manual	9/17/2025 7:31:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-261 122	Building E Classroom E3	Manual	9/17/2025 7:31:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-270 123	Building E Classroom E3	Manual	9/17/2025 7:31:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-263 125	Building E Classroom E4	Manual	9/17/2025 7:32:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-262 126	Building E Classroom E4	Manual	9/17/2025 7:32:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-269 127	Building E Classroom E4	Manual	9/17/2025 7:33:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-268 124	Building E Classroom E4	Manual	9/17/2025 7:33:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-264 129	Building E Classroom E5	Manual	9/17/2025 7:34:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-265 130	Building E Classroom E5	Manual	9/17/2025 7:34:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-266 131	Building E Classroom E5	Manual	9/17/2025 7:35:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-267 128	Building E Classroom E5	Manual	9/17/2025 7:35:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Projected Beam	2-133 162	Building F Beam Left	Manual	9/17/2025 8:41:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Projected Beam	2-135 163	Building F Beam Right	Manual	9/17/2025 8:41:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-256 149	Building F Boys RR	Manual	9/17/2025 7:42:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-254 150	Building F Girls RR	Manual	9/17/2025 7:45:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-032 154	Building F Kitchen F7	Manual	9/18/2025 2:45:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-033 155	Building F Kitchen F7	Manual	9/18/2025 2:45:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-145 143	Building F MP Room Northeast	Manual	9/17/2025 8:41:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-144 142	Building F MP Room Northwest	Manual	9/17/2025 8:41:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Manual Pull Station	2-146 144	Building F MP Room Southeast	Manual	9/17/2025 8:41:12 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-130 159	Building F MP Under Stage	Manual	9/18/2025 2:33:04 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-130 157	Building F MP Under Stage	Manual	9/18/2025 2:33:05 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-130 158	Building F MP Under Stage	Manual	9/18/2025 2:33:07 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-130 160	Building F MP Under Stage	Manual	9/18/2025 2:33:08 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-130 156	Building F MP Under Stage	Manual	9/18/2025 2:33:09 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-252 147	Building F Room F2	Manual	9/17/2025 7:47:00 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-253 148	Building F Room F3	Manual	9/17/2025 7:45:25 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-255 151	Building F Room F5	Manual	9/17/2025 7:43:15 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-034 153	Building F Room F7A	Manual	9/17/2025 7:51:07 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-035 152	Building F Room F7A1	Manual	9/17/2025 7:51:08 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-027 145	Building F Stage F8	Manual	9/17/2025 7:48:13 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-026 146	Building F Stage F8	Manual	9/17/2025 7:48:43 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-377 178	Building G Attic Classroom G1	Manual	9/18/2025 2:42:11 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-377 177	Building G Attic Classroom G1	Manual	9/18/2025 2:42:12 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-378 179	Building G Attic Classroom G2	Manual	9/18/2025 2:39:41 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-378 180	Building G Attic Classroom G2	Manual	9/18/2025 2:39:43 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-282 174	Building G Classroom G1	Manual	9/17/2025 7:40:56 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-281 173	Building G Classroom G1	Manual	9/17/2025 7:40:57 PM
		Functional Inspection	Passed	
Smoke Detector - General	2-284 175	Building G Classroom G2	Manual	9/17/2025 7:38:55 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-283 176	Building G Classroom G2	Manual	9/17/2025 7:40:10 PM
		Functional Inspection	Passed	

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-132 049	Building B Boys RR Plumb Chase	Manual	9/18/2025 2:26:23 PM
Heat Detector - Restorable Spot	2-131 050	Building B Girls RR Plumb Chase	Manual	9/18/2025 2:26:26 PM
Heat Detector - Restorable Spot	2-376 161	Building F Girls RR Plumb Chase	Manual	9/18/2025 2:26:29 PM

Power Supplies

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Battery - Sealed Lead-acid		Building D Room D1 - Left Battery	Manual	9/17/2025 8:41:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	55	
		Nominal Voltage	12	
Battery - Sealed Lead-acid		Building D Room D1 - P.E. "B" - Left Battery	Manual	9/17/2025 8:41:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Battery - Sealed Lead-acid		Building D Room D1 - P.E. "B" - Right Battery	Manual	9/17/2025 8:41:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	8	
		Nominal Voltage	12	
Battery - Sealed Lead-acid		Building D Room D1 - P.E. "C" - Left Battery	Manual	9/17/2025 8:41:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	8	
		Nominal Voltage	12	
Battery - Sealed Lead-acid		Building D Room D1 - P.E. "C" - Right Battery	Manual	9/17/2025 8:41:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	8	
		Nominal Voltage	12	
Battery - Sealed Lead-acid		Building D Room D1 - P.E. "D" - Left Battery	Manual	9/17/2025 8:41:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Amp Hours	8	
		Nominal Voltage	12	
Battery - Sealed Lead-acid		Building D Room D1 - P.E. "D" - Right Battery	Manual	9/17/2025 8:41:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	8	
		Nominal Voltage	12	
Battery - Sealed Lead-acid		Building D Room D1 - P.E. "Master" - Left Battery	Manual	9/17/2025 8:41:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	8	
		Nominal Voltage	12	
Battery - Sealed Lead-acid		Building D Room D1 - P.E. "Master" - Right Battery	Manual	9/17/2025 8:41:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	8	
		Nominal Voltage	12	
Battery - Sealed Lead-acid		Building D Room D1 - Right Battery	Manual	9/17/2025 8:41:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	55	
		Nominal Voltage	12	

Device/Equipment details

Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Audible					
051	Building B North Exterior				
052	Building B South Exterior				
053	Building B Southwest Exterior				
054	Building B West Exterior				
076	Building C North Exterior				
102	Building D North Exterior				
103	Building D South Exterior				
132	Building E Northwest Exterior				
133	Building E South Exterior				
134	Building E West Exterior				
164	Building F South Exterior				
181	Building G South Exterior				
Audible And Visible					
055	Building B Classroom B2				
056	Building B Classroom B3				
057	Building B Classroom B4				
058	Building B Classroom B5				
077	Building C Classroom C1				
078	Building C Classroom C2				
104	Building D Classroom D3				
105	Building D Classroom D4				
106	Building D Classroom D5				
107	Building D Classroom D6				
108	Building D Classroom D7				
135	Building E Classroom E1				
136	Building E Classroom E2				
137	Building E Classroom E3				
138	Building E Classroom E4				
139	Building E Classroom E5				
165	Building F MP Room				
166	Building F MP Room				
167	Building F Stage				
168	Building F Kitchen F7				
169	Building F Kitchen F7				
170	Building F Room F3				
182	Building G Classroom G1				
183	Building G Classroom G2				
014	Building A Room A6				
015	Building A Room A2				
Visible					
059	Building B Classroom B1				
060	Building B Classroom B2A Storage				
061	Building B Classroom B2B Storage				
062	Building B Boys RR B7				
063	Building B Girls RR B9				
109	Building D MDF Classroom D2				
140	Building E Classroom E1/E2				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
141	Building E Classroom E1/E2				
171	Building F Boys RR				
172	Building F Girls RR				
016	Building A Admin Reception A1				
017	Building A Room A1A				
018	Building A Room A6				
019	Building A Room A6A RR				
020	Building A Room A3 RR				
021	Building A Room A4 RR				

Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Remote Annunciator					
001	Building A Admin Reception A1				
Fire Alarm Panel					
	Building D Room D1				
NAC Power Extender Panel					
	Building D Room D1 - P.E. "Master"				
	Building D Room D1 - P.E. "B"				
	Building D Room D1 - P.E. "C"				
	Building D Room D1 - P.E. "D"				

Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Smoke Detector - General					
2-079 064	Building C Classroom C1				
2-077 065	Building C Classroom C1				
2-078 066	Building C Classroom C1				
2-080 067	Building C Classroom C1				
2-081 068	Building C Classroom C2				
2-082 069	Building C Classroom C2				
2-084 070	Building C Classroom C2				
2-083 071	Building C Classroom C2				
2-002 079	Building D Room D1				
2-004 080	Building D MDF Classroom D2				
2-024 081	Building D Classroom D3				
2-005 082	Building D Classroom D3				
2-006 083	Building D Classroom D3				
2-023 084	Building D Classroom D3				
2-022 085	Building D Classroom D4				
2-007 086	Building D Classroom D4				
2-008 087	Building D Classroom D4				
2-021 088	Building D Classroom D4				
2-020 089	Building D Classroom D5				
2-009 090	Building D Classroom D5				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-010 091	Building D Classroom D5				
2-019 092	Building D Classroom D5				
2-018 093	Building D Classroom D6				
2-011 094	Building D Classroom D6				
2-012 095	Building D Classroom D6				
2-017 096	Building D Classroom D6				
2-015 097	Building D Classroom D7				
2-014 098	Building D Classroom D7				
2-013 099	Building D Classroom D7				
2-016 100	Building D Classroom D7				
2-277 110	Building E Classroom E1				
2-278 111	Building E Classroom E1				
2-275 112	Building E Classroom E1				
2-276 113	Building E Classroom E1				
2-279 114	Building E Classroom E1				
2-274 115	Building E Classroom E2				
2-273 116	Building E Classroom E2				
2-258 117	Building E Classroom E2				
2-259 118	Building E Classroom E2				
2-272 119	Building E Classroom E2				
2-271 120	Building E Classroom E3				
2-260 121	Building E Classroom E3				
2-261 122	Building E Classroom E3				
2-270 123	Building E Classroom E3				
2-268 124	Building E Classroom E4				
2-263 125	Building E Classroom E4				
2-262 126	Building E Classroom E4				
2-269 127	Building E Classroom E4				
2-267 128	Building E Classroom E5				
2-264 129	Building E Classroom E5				
2-265 130	Building E Classroom E5				
2-266 131	Building E Classroom E5				
2-027 145	Building F Stage F8				
2-026 146	Building F Stage F8				
2-252 147	Building F Room F2				
2-253 148	Building F Room F3				
2-256 149	Building F Boys RR				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-254 150	Building F Girls RR				
2-255 151	Building F Room F5				
2-035 152	Building F Room F7A1				
2-034 153	Building F Room F7A				
2-281 173	Building G Classroom G1				
2-282 174	Building G Classroom G1				
2-284 175	Building G Classroom G2				
2-283 176	Building G Classroom G2				
2-037 003	Building A Room A1				
2-039 004	Building A Room A1A				
2-040 005	Building A Room A6				
2-041 006	Building A Room A6				
2-042 007	Building A Room A6A RR				
2-044 008	Building A Room A2				
2-043 009	Building A Room A2				
2-047 010	Building A Room A3 RR				
2-046 011	Building A Room A4 RR				
2-045 012	Building A Custodial Closet A5				
2-049 022	Building B Classroom B1				
2-061 023	Building B Classroom B2				
2-067 024	Building B Classroom B2				
2-066 025	Building B Classroom B2				
2-062 026	Building B Classroom B2				
2-063 027	Building B Classroom B2				
2-064 028	Building B Classroom B2A Storage				
2-065 029	Building B Classroom B2B Storage				
2-059 030	Building B Classroom B3				
2-069 031	Building B Classroom B3				
2-068 032	Building B Classroom B3				
2-060 033	Building B Classroom B3				
2-058 034	Building B Classroom B4				
2-071 035	Building B Classroom B4				
2-057 036	Building B Classroom B4				
2-070 037	Building B Classroom B4				
2-055 038	Building B Classroom B5				
2-073 039	Building B Classroom B5				
2-072 040	Building B Classroom B5				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-056 041	Building B Classroom B5				
2-054 042	Building B Classroom B6				
2-053 043	Building B Classroom B6				
2-075 044	Building B Classroom B6				
2-074 045	Building B Classroom B6				
2-052 046	Building B Boys RR B7				
2-050 047	Building B Storage Room B8				
2-051 048	Building B Girls RR B9				
Heat Detector - Restorable Spot					
2-138 072	Building C Attic Classroom C1				
2-138 073	Building C Attic Classroom C1				
2-139 074	Building C Attic Classroom C2				
2-139 075	Building C Attic Classroom C2				
2-003 101	Building D Room D1				
2-032 154	Building F Kitchen F7				
2-033 155	Building F Kitchen F7				
2-130 156	Building F MP Under Stage				
2-130 157	Building F MP Under Stage				
2-130 158	Building F MP Under Stage				
2-130 159	Building F MP Under Stage				
2-130 160	Building F MP Under Stage				
2-376 161	Building F Girls RR Plumb Chase				
2-377 177	Building G Attic Classroom G1				
2-377 178	Building G Attic Classroom G1				
2-378 179	Building G Attic Classroom G2				
2-378 180	Building G Attic Classroom G2				
2-140 013	Building A Attic Room A1A				
2-132 049	Building B Boys RR Plumb Chase				
2-131 050	Building B Girls RR Plumb Chase				
Manual Pull Station					
2-144 142	Building F MP Room Northwest				
2-145 143	Building F MP Room Northeast				
2-146 144	Building F MP Room Southeast				
2-137 002	Building A Admin Reception A1				
Smoke Detector - Projected Beam					
2-133 162	Building F Beam Left				
2-135 163	Building F Beam Right				
Power Supplies					
ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE

Battery - Sealed Lead-acid	
Building D Room D1 - Left Battery	09/22/2014
Building D Room D1 - Right Battery	09/22/2014
Building D Room D1 - P.E. "Master" - Left Battery	01/12/2016
Building D Room D1 - P.E. "Master" - Right Battery	01/12/2016
Building D Room D1 - P.E. "B" - Left Battery	01/12/2016
Building D Room D1 - P.E. "B" - Right Battery	01/12/2016
Building D Room D1 - P.E. "C" - Left Battery	01/12/2016
Building D Room D1 - P.E. "C" - Right Battery	01/12/2016
Building D Room D1 - P.E. "D" - Left Battery	01/12/2016
Building D Room D1 - P.E. "D" - Right Battery	01/12/2016