

Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

PASADENA AVE ELEM

4330 PASADENA AVE
SACRAMENTO, California
United States

This site has been inspected and tested in compliance with applicable standards.

Completed
Tuesday, September 30, 2025

Test Session: 17 Sep 2025 15:57 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD
5320 HEMLOCK ST
SACRAMENTO, California
United States

TESTED BY

Riley Goyet
Western States Fire Protection-
Sacramento
188 Cirby Way
Roseville, CA 95678
United States



Inspection Summary

Building Information

PROPERTY	PASADENA AVE ELEM	CONTACT
ADDRESS	4330 PASADENA AVE	PHONE
CITY/STATE	SACRAMENTO, California	MOBILE
COUNTRY	United States	EMAIL

Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us

Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Alarm Notification Appliance	61	61(100%)	61(100%)	0(0%)
Fire Control Panel	6	6(100%)	6(100%)	0(0%)
Initiating Device	156	155(99%)	155(99%)	0(0%)

Certification

The equipment specified here in was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Tuesday, September 30, 2025

ACCEPTED BY 09/30/2025

Building Representative

TESTED BY 09/30/2025

Riley Goyet
Technician



System Details

Control Units

ADDRESS/ SCAN ADDRESS		DESCRIPTION	Rooms 1-4 Bldg Cust Office/Headend
MANUFACTURER	EST	S/W VERSION	
MODEL	3	LAST UPDATE	
SERIAL NUMBER		S/W LOCATION	
INSTALL DATE			

Open Corrective Action & Solution Summary

The following 1 corrective action(s) remain open following the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
NAC Power Extender Panel	044	Rooms 1-4 Bldg Cust Office/Headend - P.E. "A"
	Created By:	Riley Goyet
	Creation Date:	09/17/2025
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	

Testing Details

Alarm Notification Appliance

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible	016	Admin Building NE Office 1	Manual	9/17/2025 4:19:56 PM
		Visual inspection	Passed (Manual)	
Visible	015	Admin Building Nurse Restroom	Manual	9/17/2025 4:19:57 PM
		Visual inspection	Passed (Manual)	
Visible	014	Admin Building Nurses Office	Manual	9/17/2025 4:19:58 PM
		Visual inspection	Passed (Manual)	
Visible	017	Admin Building Principal Office	Manual	9/17/2025 4:19:54 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	012	Admin Building Reception	Manual	9/17/2025 4:20:46 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	013	Admin Building SE Office 2	Manual	9/17/2025 4:20:43 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	196	Multi-Purpose Bldg Kitchen	Manual	9/17/2025 4:20:00 PM
		Visual inspection	Passed (Manual)	
Visible	199	Multi-Purpose Bldg Kitchen Restroom	Manual	9/17/2025 4:19:35 PM
		Visual inspection	Passed (Manual)	
Visible	197	Multi-Purpose Bldg Kitchen Scullary	Manual	9/17/2025 4:19:38 PM
		Visual inspection	Passed (Manual)	
Visible	198	Multi-Purpose Bldg Kitchen Wash Room	Manual	9/17/2025 4:19:37 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	195	Multi-Purpose Bldg MP Room	Manual	9/17/2025 4:20:01 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	194	Multi-Purpose Bldg MP Room	Manual	9/17/2025 4:20:03 PM
		Visual inspection	Passed (Manual)	
Audible	193	Multi-Purpose Bldg West Exterior	Manual	9/17/2025 4:20:49 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	170	Preschool Bldg Preschool	Manual	9/17/2025 4:20:07 PM
		Visual inspection	Passed (Manual)	
Visible	171	Preschool Bldg Preschool Restroom	Manual	9/17/2025 4:19:39 PM
		Visual inspection	Passed (Manual)	
Audible	168	Preschool Bldg South Exterior	Manual	9/17/2025 4:20:52 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible	169	Preschool Bldg West Exterior	Manual	9/17/2025 4:20:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	131	Room 15 Bldg East Office	Manual	9/17/2025 4:19:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	130	Room 15 Bldg Office Entry	Manual	9/17/2025 4:20:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	133	Room 15 Bldg Restroom	Manual	9/17/2025 4:19:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	132	Room 15 Bldg West Office	Manual	9/17/2025 4:19:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	149	Room 18 Bldg Classroom 18	Manual	9/17/2025 4:20:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	119	Rooms 11-14 Bldg Classroom 11	Manual	9/17/2025 4:20:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	120	Rooms 11-14 Bldg Classroom 12	Manual	9/17/2025 4:20:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	121	Rooms 11-14 Bldg Classroom 13	Manual	9/17/2025 4:20:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	122	Rooms 11-14 Bldg Classroom 14	Manual	9/17/2025 4:20:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	117	Rooms 11-14 Bldg North Exterior	Manual	9/17/2025 4:21:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	118	Rooms 11-14 Bldg South Exterior	Manual	9/17/2025 4:20:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	038	Rooms 1-4 Bldg Classroom 1	Manual	9/17/2025 4:20:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	039	Rooms 1-4 Bldg Classroom 2	Manual	9/17/2025 4:20:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	040	Rooms 1-4 Bldg Classroom 3	Manual	9/17/2025 4:20:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	041	Rooms 1-4 Bldg Classroom 4	Manual	9/17/2025 4:20:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	036	Rooms 1-4 Bldg South Exterior	Manual	9/17/2025 4:21:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	035	Rooms 1-4 Bldg South Exterior	Manual	9/17/2025 4:21:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	034	Rooms 1-4 Bldg South Exterior	Manual	9/17/2025 4:21:19 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	042	Rooms 1-4 Bldg Unisex RR by Rm 1	Manual	9/17/2025 4:19:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	037	Rooms 1-4 Bldg West Exterior	Manual	9/17/2025 4:21:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	043	Rooms 1-4 Bldg Womens RR by Rm 1	Manual	9/17/2025 4:19:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	143	Rooms 16 & 17 Bldg Classroom 16	Manual	9/17/2025 4:20:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	144	Rooms 16 & 17 Bldg Classroom 17	Manual	9/17/2025 4:20:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	142	Rooms 16 & 17 Bldg East Exterior	Manual	9/17/2025 4:20:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	159	Rooms 19 & 20 Bldg Classroom 19	Manual	9/17/2025 4:20:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	160	Rooms 19 & 20 Bldg Classroom 20	Manual	9/17/2025 4:20:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	158	Rooms 19 & 20 Bldg South Exterior	Manual	9/17/2025 4:20:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	069	Rooms 5-8 Bldg Boys RR by Rm 5	Manual	9/17/2025 4:19:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	065	Rooms 5-8 Bldg Classroom 5	Manual	9/17/2025 4:20:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	066	Rooms 5-8 Bldg Classroom 6	Manual	9/17/2025 4:20:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	067	Rooms 5-8 Bldg Classroom 7	Manual	9/17/2025 4:20:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	068	Rooms 5-8 Bldg Classroom 8	Manual	9/17/2025 4:20:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	070	Rooms 5-8 Bldg Girls RR by Rm 5	Manual	9/17/2025 4:19:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	063	Rooms 5-8 Bldg South Exterior	Manual	9/17/2025 4:21:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	062	Rooms 5-8 Bldg South Exterior	Manual	9/17/2025 4:21:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	061	Rooms 5-8 Bldg South Exterior	Manual	9/17/2025 4:21:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible	064	Rooms 5-8 Bldg West Exterior	Manual	9/17/2025 4:21:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	084	Rooms 9 & 10 Bldg Classroom 10	Manual	9/17/2025 4:20:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	083	Rooms 9 & 10 Bldg Classroom 9	Manual	9/17/2025 4:20:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	081	Rooms 9 & 10 Bldg North Exterior	Manual	9/17/2025 4:21:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	082	Rooms 9 & 10 Bldg South Exterior	Manual	9/17/2025 4:21:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	205	RR Bldg by Rm 5 Boys Restroom	Manual	9/17/2025 4:19:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	206	RR Bldg by Rm 5 Girls Restroom	Manual	9/17/2025 4:19:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	204	RR Bldg by Rm 6 West Exterior	Manual	9/17/2025 4:20:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
NAC Power Extender Panel	018	Admin Building O/S Storage West - P.E. "B"	Manual	9/17/2025 5:51:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Remote Annunciator	001	Admin Building Reception	Manual	9/17/2025 5:03:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	123	Rooms 11-14 Bldg Classroom 11 - P.E. "D"	Manual	9/17/2025 5:51:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Fire Alarm Panel		Rooms 1-4 Bldg Cust Office/Headend	Manual	9/17/2025 5:03:48 PM
		Manufacturer	EST	
		Model	3	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	044	Rooms 1-4 Bldg Cust Office/Headend - P.E. "A"	Manual	9/17/2025 5:03:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	161	Rooms 19 & 20 Bldg Classroom 19 - P.E. "C"	Manual	9/17/2025 5:51:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-136 011	Admin Building Above Ceiling Nurse	Manual	9/17/2025 5:00:13 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	2-027 004	Admin Building NE Office 1	Manual	9/17/2025 5:51:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-031 007	Admin Building Nurse Restroom	Manual	9/17/2025 5:49:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-032 008	Admin Building Nurse Storage	Manual	9/17/2025 5:50:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-030 006	Admin Building Nurses Office	Manual	9/17/2025 5:49:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-033 010	Admin Building O/S Storage West	Manual	9/17/2025 6:08:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-029 009	Admin Building Principal Office	Manual	9/17/2025 5:48:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-135 002	Admin Building Reception	Manual	9/17/2025 5:07:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-028 003	Admin Building Reception	Manual	9/17/2025 5:49:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-026 005	Admin Building SE Office 2	Manual	9/17/2025 5:50:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-151 190	Multi-Purpose Bldg Above Ceiling S. Storage	Manual	9/17/2025 5:00:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-045 188	Multi-Purpose Bldg Kitchen	Manual	9/17/2025 5:00:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-047 187	Multi-Purpose Bldg Kitchen	Manual	9/17/2025 5:00:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-042 185	Multi-Purpose Bldg Kitchen Restroom	Manual	9/17/2025 5:57:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-046 189	Multi-Purpose Bldg Kitchen Scullary	Manual	9/17/2025 6:09:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-043 184	Multi-Purpose Bldg Kitchen Wash Room	Manual	9/17/2025 5:57:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-035 180	Multi-Purpose Bldg MP Room	Manual	9/17/2025 5:46:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-034 179	Multi-Purpose Bldg MP Room	Manual	9/17/2025 5:46:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-038 178	Multi-Purpose Bldg MP Room	Manual	9/17/2025 5:46:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-036 177	Multi-Purpose Bldg MP Room	Manual	9/17/2025 5:46:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-037 176	Multi-Purpose Bldg MP Room	Manual	9/17/2025 5:46:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-039 175	Multi-Purpose Bldg MP Room	Manual	9/17/2025 5:46:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-040 181	Multi-Purpose Bldg MP Room Storage	Manual	9/17/2025 5:57:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-137 172	Multi-Purpose Bldg NE Entrance	Manual	9/17/2025 5:07:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-041 186	Multi-Purpose Bldg O/S Storage SW	Manual	9/17/2025 6:05:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-138 174	Multi-Purpose Bldg SE Entrance	Manual	9/17/2025 5:07:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-053 182	Multi-Purpose Bldg South Storage	Manual	9/17/2025 5:19:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-139 191	Multi-Purpose Bldg Southeast Unit	Manual	9/17/2025 5:07:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-140 192	Multi-Purpose Bldg Southwest Unit	Manual	9/17/2025 5:07:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-141 173	Multi-Purpose Bldg SW Entrance	Manual	9/17/2025 5:07:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-142 166	Preschool Bldg Lite Soffit Preschool	Manual	9/17/2025 4:50:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-049 162	Preschool Bldg Preschool	Manual	9/17/2025 5:46:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-050 163	Preschool Bldg Preschool	Manual	9/17/2025 5:46:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-051 164	Preschool Bldg Preschool	Manual	9/17/2025 5:46:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-048 165	Preschool Bldg Preschool Restroom	Manual	9/17/2025 5:47:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-256 125	Room 15 Bldg East Office	Manual	9/17/2025 5:36:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-261 128	Room 15 Bldg Hall Closet	Manual	9/17/2025 5:36:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-257 124	Room 15 Bldg Office Entry	Manual	9/17/2025 5:36:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-260 129	Room 15 Bldg Restroom	Manual	9/17/2025 5:37:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-258 127	Room 15 Bldg Restroom Hall	Manual	9/17/2025 5:36:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-259 126	Room 15 Bldg West Office	Manual	9/17/2025 5:36:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-380	Room 18 Bldg Above Ceiling Rm 18	Manual	9/17/2025 4:36:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-380 148	Room 18 Bldg Above Ceiling Rm 18	Manual	9/17/2025 4:36:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-380 147	Room 18 Bldg Above Ceiling Rm 18	Manual	9/17/2025 4:36:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-267 145	Room 18 Bldg Classroom 18	Manual	9/17/2025 5:39:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-266 146	Room 18 Bldg Classroom 18	Manual	9/17/2025 5:39:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-381 101	Rooms 11-14 Bldg Above Ceiling Rm 11	Manual	9/17/2025 4:25:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-381 102	Rooms 11-14 Bldg Above Ceiling Rm 11	Manual	9/17/2025 4:25:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-381 103	Rooms 11-14 Bldg Above Ceiling Rm 11	Manual	9/17/2025 4:25:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-381 104	Rooms 11-14 Bldg Above Ceiling Rm 11	Manual	9/17/2025 4:25:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-381	Rooms 11-14 Bldg Above Ceiling Rm 11	Manual	9/17/2025 4:26:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-381	Rooms 11-14 Bldg Above Ceiling Rm 11	Manual	9/17/2025 4:26:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-382 105	Rooms 11-14 Bldg Above Ceiling Rm 12	Manual	9/17/2025 4:27:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-382 106	Rooms 11-14 Bldg Above Ceiling Rm 12	Manual	9/17/2025 4:27:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-382 107	Rooms 11-14 Bldg Above Ceiling Rm 12	Manual	9/17/2025 4:27:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-382 108	Rooms 11-14 Bldg Above Ceiling Rm 12	Manual	9/17/2025 4:27:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-382	Rooms 11-14 Bldg Above Ceiling Rm 12	Manual	9/17/2025 4:27:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-382	Rooms 11-14 Bldg Above Ceiling Rm 12	Manual	9/17/2025 4:27:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-383 109	Rooms 11-14 Bldg Above Ceiling Rm 13	Manual	9/17/2025 4:29:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-383 110	Rooms 11-14 Bldg Above Ceiling Rm 13	Manual	9/17/2025 4:29:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-383 111	Rooms 11-14 Bldg Above Ceiling Rm 13	Manual	9/17/2025 4:29:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-383 112	Rooms 11-14 Bldg Above Ceiling Rm 13	Manual	9/17/2025 4:29:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-383	Rooms 11-14 Bldg Above Ceiling Rm 13	Manual	9/17/2025 4:29:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-383	Rooms 11-14 Bldg Above Ceiling Rm 13	Manual	9/17/2025 4:29:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-384 113	Rooms 11-14 Bldg Above Ceiling Rm 14	Manual	9/17/2025 4:32:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-384 114	Rooms 11-14 Bldg Above Ceiling Rm 14	Manual	9/17/2025 4:32:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-384 115	Rooms 11-14 Bldg Above Ceiling Rm 14	Manual	9/17/2025 4:32:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-384 116	Rooms 11-14 Bldg Above Ceiling Rm 14	Manual	9/17/2025 4:32:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-384	Rooms 11-14 Bldg Above Ceiling Rm 14	Manual	9/17/2025 4:32:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-384	Rooms 11-14 Bldg Above Ceiling Rm 14	Manual	9/17/2025 4:32:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-271 085	Rooms 11-14 Bldg Classroom 11	Manual	9/17/2025 5:27:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-270 088	Rooms 11-14 Bldg Classroom 11	Manual	9/17/2025 5:27:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-269 087	Rooms 11-14 Bldg Classroom 11	Manual	9/17/2025 5:28:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-268 086	Rooms 11-14 Bldg Classroom 11	Manual	9/17/2025 5:28:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-273 091	Rooms 11-14 Bldg Classroom 12	Manual	9/17/2025 5:30:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-274 090	Rooms 11-14 Bldg Classroom 12	Manual	9/17/2025 5:30:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-275 089	Rooms 11-14 Bldg Classroom 12	Manual	9/17/2025 5:30:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-272 092	Rooms 11-14 Bldg Classroom 12	Manual	9/17/2025 5:30:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-278 094	Rooms 11-14 Bldg Classroom 13	Manual	9/17/2025 5:31:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-277 095	Rooms 11-14 Bldg Classroom 13	Manual	9/17/2025 5:31:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-279 093	Rooms 11-14 Bldg Classroom 13	Manual	9/17/2025 5:31:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-276 096	Rooms 11-14 Bldg Classroom 13	Manual	9/17/2025 5:31:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-282 098	Rooms 11-14 Bldg Classroom 14	Manual	9/17/2025 5:33:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-283 097	Rooms 11-14 Bldg Classroom 14	Manual	9/17/2025 5:33:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-280 100	Rooms 11-14 Bldg Classroom 14	Manual	9/17/2025 5:35:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-281 099	Rooms 11-14 Bldg Classroom 14	Manual	9/17/2025 5:35:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-005 020	Rooms 1-4 Bldg Classroom 1	Manual	9/17/2025 5:08:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-006 019	Rooms 1-4 Bldg Classroom 1	Manual	9/17/2025 5:08:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-008 021	Rooms 1-4 Bldg Classroom 2	Manual	9/17/2025 5:08:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-007 022	Rooms 1-4 Bldg Classroom 2	Manual	9/17/2025 5:08:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-009 024	Rooms 1-4 Bldg Classroom 3	Manual	9/17/2025 5:09:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-010 023	Rooms 1-4 Bldg Classroom 3	Manual	9/17/2025 5:09:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-012 025	Rooms 1-4 Bldg Classroom 4	Manual	9/17/2025 5:59:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-011 026	Rooms 1-4 Bldg Classroom 4	Manual	9/17/2025 5:59:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-002 029	Rooms 1-4 Bldg Cust Office/Headend	Manual	9/17/2025 5:08:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-126 030	Rooms 1-4 Bldg Lite Soffit Classrm 1	Manual	9/17/2025 4:07:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-127 031	Rooms 1-4 Bldg Lite Soffit Classrm 2	Manual	9/17/2025 4:07:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-128 032	Rooms 1-4 Bldg Lite Soffit Classrm 3	Manual	9/17/2025 4:08:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-129 033	Rooms 1-4 Bldg Lite Soffit Classrm 4	Manual	9/17/2025 4:10:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-003 027	Rooms 1-4 Bldg Unisex RR by Rm 1	Manual	9/17/2025 5:08:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-004 028	Rooms 1-4 Bldg Womens RR by Rm 1	Manual	9/17/2025 5:08:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-378 138	Rooms 16 & 17 Bldg Above Ceiling Rm 16	Manual	9/17/2025 4:42:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-378	Rooms 16 & 17 Bldg Above Ceiling Rm 16	Manual	9/17/2025 4:42:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-378 139	Rooms 16 & 17 Bldg Above Ceiling Rm 16	Manual	9/17/2025 4:42:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-378	Rooms 16 & 17 Bldg Above Ceiling Rm 16	Manual	9/17/2025 4:42:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-379	Rooms 16 & 17 Bldg Above Ceiling Rm 17	Manual	9/17/2025 4:40:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-379 140	Rooms 16 & 17 Bldg Above Ceiling Rm 17	Manual	9/17/2025 4:40:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-379 141	Rooms 16 & 17 Bldg Above Ceiling Rm 17	Manual	9/17/2025 4:40:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-379	Rooms 16 & 17 Bldg Above Ceiling Rm 17	Manual	9/17/2025 4:40:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-263 134	Rooms 16 & 17 Bldg Classroom 16	Manual	9/17/2025 5:41:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-262 135	Rooms 16 & 17 Bldg Classroom 16	Manual	9/17/2025 5:41:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-264 136	Rooms 16 & 17 Bldg Classroom 17	Manual	9/17/2025 5:40:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-265 137	Rooms 16 & 17 Bldg Classroom 17	Manual	9/17/2025 5:40:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-376 155	Rooms 19 & 20 Bldg Above Ceiling Rm 19	Manual	9/17/2025 4:45:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-376 154	Rooms 19 & 20 Bldg Above Ceiling Rm 19	Manual	9/17/2025 4:45:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-376	Rooms 19 & 20 Bldg Above Ceiling Rm 19	Manual	9/17/2025 4:45:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-376	Rooms 19 & 20 Bldg Above Ceiling Rm 19	Manual	9/17/2025 4:45:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-377	Rooms 19 & 20 Bldg Above Ceiling Rm 20	Manual	9/17/2025 4:48:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-377	Rooms 19 & 20 Bldg Above Ceiling Rm 20	Manual	9/17/2025 4:48:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-377 157	Rooms 19 & 20 Bldg Above Ceiling Rm 20	Manual	9/17/2025 4:48:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-377 156	Rooms 19 & 20 Bldg Above Ceiling Rm 20	Manual	9/17/2025 4:48:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-253 150	Rooms 19 & 20 Bldg Classroom 19	Manual	9/17/2025 5:43:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-252 151	Rooms 19 & 20 Bldg Classroom 19	Manual	9/17/2025 5:45:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-255 152	Rooms 19 & 20 Bldg Classroom 20	Manual	9/17/2025 5:45:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-254 153	Rooms 19 & 20 Bldg Classroom 20	Manual	9/17/2025 5:45:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-016 053	Rooms 5-8 Bldg Boys RR by Rm 5	Manual	9/17/2025 5:17:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-017 045	Rooms 5-8 Bldg Classroom 5	Manual	9/17/2025 5:14:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-018 046	Rooms 5-8 Bldg Classroom 5	Manual	9/17/2025 5:15:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-020 047	Rooms 5-8 Bldg Classroom 6	Manual	9/17/2025 5:13:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-019 048	Rooms 5-8 Bldg Classroom 6	Manual	9/17/2025 5:13:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-021 050	Rooms 5-8 Bldg Classroom 7	Manual	9/17/2025 5:12:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-022 049	Rooms 5-8 Bldg Classroom 7	Manual	9/17/2025 5:12:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-023 051	Rooms 5-8 Bldg Classroom 8	Manual	9/17/2025 5:11:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-024 052	Rooms 5-8 Bldg Classroom 8	Manual	9/17/2025 5:11:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-014 054	Rooms 5-8 Bldg Cust Clst by Rm 5	Manual	9/17/2025 4:19:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-015 055	Rooms 5-8 Bldg Girls RR by Rm 5	Manual	9/17/2025 5:16:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-131 056	Rooms 5-8 Bldg Lite Soffit Classrm 5	Manual	9/17/2025 4:17:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-132 057	Rooms 5-8 Bldg Lite Soffit Classrm 6	Manual	9/17/2025 4:15:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-133 058	Rooms 5-8 Bldg Lite Soffit Classrm 7	Manual	9/17/2025 4:14:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-134 059	Rooms 5-8 Bldg Lite Soffit Classrm 8	Manual	9/17/2025 4:12:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-130 060	Rooms 5-8 Bldg RR Plumbing Chase by Rm 5	Manual	9/17/2025 4:48:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-385 078	Rooms 9 & 10 Bldg Above Ceiling Rm 10	Manual	9/17/2025 4:23:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-385 079	Rooms 9 & 10 Bldg Above Ceiling Rm 10	Manual	9/17/2025 4:23:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-385 080	Rooms 9 & 10 Bldg Above Ceiling Rm 10	Manual	9/17/2025 4:23:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-387 075	Rooms 9 & 10 Bldg Above Ceiling Rm 9	Manual	9/17/2025 4:21:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-387 077	Rooms 9 & 10 Bldg Above Ceiling Rm 9	Manual	9/17/2025 4:21:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-387 076	Rooms 9 & 10 Bldg Above Ceiling Rm 9	Manual	9/17/2025 4:21:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-286 073	Rooms 9 & 10 Bldg Classroom 10	Manual	9/17/2025 5:25:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-284 074	Rooms 9 & 10 Bldg Classroom 10	Manual	9/17/2025 5:26:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-287 071	Rooms 9 & 10 Bldg Classroom 9	Manual	9/17/2025 5:23:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-288 072	Rooms 9 & 10 Bldg Classroom 9	Manual	9/17/2025 5:24:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-289 201	RR Bldg by Rm 5 Boys Restroom	Manual	9/17/2025 5:22:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-290 200	RR Bldg by Rm 5 Boys Restroom	Manual	9/17/2025 5:22:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-292 202	RR Bldg by Rm 5 Girls Restroom	Manual	9/17/2025 5:20:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-291 203	RR Bldg by Rm 5 Girls Restroom	Manual	9/17/2025 5:20:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Skipped				
EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-044 183	Multi-Purpose Bldg Kitchen Dry Storage	Manual	9/17/2025 6:00:20 PM
	Comment:	No access		

Device/Equipment details

Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Audible And Visible					
012	Admin Building Reception				
013	Admin Building SE Office 2				
038	Rooms 1-4 Bldg Classroom 1				
039	Rooms 1-4 Bldg Classroom 2				
040	Rooms 1-4 Bldg Classroom 3				
041	Rooms 1-4 Bldg Classroom 4				
065	Rooms 5-8 Bldg Classroom 5				
066	Rooms 5-8 Bldg Classroom 6				
067	Rooms 5-8 Bldg Classroom 7				
068	Rooms 5-8 Bldg Classroom 8				
083	Rooms 9 & 10 Bldg Classroom 9				
084	Rooms 9 & 10 Bldg Classroom 10				
119	Rooms 11-14 Bldg Classroom 11				
120	Rooms 11-14 Bldg Classroom 12				
121	Rooms 11-14 Bldg Classroom 13				
122	Rooms 11-14 Bldg Classroom 14				
130	Room 15 Bldg Office Entry				
143	Rooms 16 & 17 Bldg Classroom 16				
144	Rooms 16 & 17 Bldg Classroom 17				
149	Room 18 Bldg Classroom 18				
159	Rooms 19 & 20 Bldg Classroom 19				
160	Rooms 19 & 20 Bldg Classroom 20				
170	Preschool Bldg Preschool				
194	Multi-Purpose Bldg MP Room				
195	Multi-Purpose Bldg MP Room				
196	Multi-Purpose Bldg Kitchen				
Visible					
014	Admin Building Nurses Office				
015	Admin Building Nurse Restroom				
016	Admin Building NE Office 1				
017	Admin Building Principal Office				
042	Rooms 1-4 Bldg Unisex RR by Rm 1				
043	Rooms 1-4 Bldg Womens RR by Rm 1				
069	Rooms 5-8 Bldg Boys RR by Rm 5				
070	Rooms 5-8 Bldg Girls RR by Rm 5				
131	Room 15 Bldg East Office				
132	Room 15 Bldg West Office				
133	Room 15 Bldg Restroom				
171	Preschool Bldg Preschool Restroom				
197	Multi-Purpose Bldg Kitchen Scullary				
198	Multi-Purpose Bldg Kitchen Wash Room				
199	Multi-Purpose Bldg Kitchen Restroom				
205	RR Bldg by Rm 5 Boys Restroom				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
206	RR Bldg by Rm 5 Girls Restroom				
Audible					
034	Rooms 1-4 Bldg South Exterior				
035	Rooms 1-4 Bldg South Exterior				
036	Rooms 1-4 Bldg South Exterior				
037	Rooms 1-4 Bldg West Exterior				
061	Rooms 5-8 Bldg South Exterior				
062	Rooms 5-8 Bldg South Exterior				
063	Rooms 5-8 Bldg South Exterior				
064	Rooms 5-8 Bldg West Exterior				
081	Rooms 9 & 10 Bldg North Exterior				
082	Rooms 9 & 10 Bldg South Exterior				
117	Rooms 11-14 Bldg North Exterior				
118	Rooms 11-14 Bldg South Exterior				
142	Rooms 16 & 17 Bldg East Exterior				
158	Rooms 19 & 20 Bldg South Exterior				
168	Preschool Bldg South Exterior				
169	Preschool Bldg West Exterior				
193	Multi-Purpose Bldg West Exterior				
204	RR Bldg by Rm 6 West Exterior				

Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Remote Annunciator					
001	Admin Building Reception				
NAC Power Extender Panel					
018	Admin Building O/S Storage West - P.E. "B"				
044	Rooms 1-4 Bldg Cust Office/Headend - P.E. "A"				
123	Rooms 11-14 Bldg Classroom 11 - P.E. "D"				
161	Rooms 19 & 20 Bldg Classroom 19 - P.E. "C"				

Fire Alarm Panel

	Rooms 1-4 Bldg Cust Office/Headend	EST	3		
--	------------------------------------	-----	---	--	--

Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Manual Pull Station					
2-135 002	Admin Building Reception				
2-137 172	Multi-Purpose Bldg NE Entrance				
2-141 173	Multi-Purpose Bldg SW Entrance				
2-138 174	Multi-Purpose Bldg SE Entrance				
Smoke Detector - General					
2-028 003	Admin Building Reception				
2-027 004	Admin Building NE Office 1				
2-026 005	Admin Building SE Office 2				
2-030 006	Admin Building Nurses Office				
2-031 007	Admin Building Nurse Restroom				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-032 008	Admin Building Nurse Storage				
2-029 009	Admin Building Principal Office				
2-033 010	Admin Building O/S Storage West				
2-006 019	Rooms 1-4 Bldg Classroom 1				
2-005 020	Rooms 1-4 Bldg Classroom 1				
2-008 021	Rooms 1-4 Bldg Classroom 2				
2-007 022	Rooms 1-4 Bldg Classroom 2				
2-010 023	Rooms 1-4 Bldg Classroom 3				
2-009 024	Rooms 1-4 Bldg Classroom 3				
2-012 025	Rooms 1-4 Bldg Classroom 4				
2-011 026	Rooms 1-4 Bldg Classroom 4				
2-003 027	Rooms 1-4 Bldg Unisex RR by Rm 1				
2-004 028	Rooms 1-4 Bldg Womens RR by Rm 1				
2-002 029	Rooms 1-4 Bldg Cust Office/Headend				
2-017 045	Rooms 5-8 Bldg Classroom 5				
2-018 046	Rooms 5-8 Bldg Classroom 5				
2-020 047	Rooms 5-8 Bldg Classroom 6				
2-019 048	Rooms 5-8 Bldg Classroom 6				
2-022 049	Rooms 5-8 Bldg Classroom 7				
2-021 050	Rooms 5-8 Bldg Classroom 7				
2-023 051	Rooms 5-8 Bldg Classroom 8				
2-024 052	Rooms 5-8 Bldg Classroom 8				
2-016 053	Rooms 5-8 Bldg Boys RR by Rm 5				
2-015 055	Rooms 5-8 Bldg Girls RR by Rm 5				
2-287 071	Rooms 9 & 10 Bldg Classroom 9				
2-288 072	Rooms 9 & 10 Bldg Classroom 9				
2-286 073	Rooms 9 & 10 Bldg Classroom 10				
2-284 074	Rooms 9 & 10 Bldg Classroom 10				
2-271 085	Rooms 11-14 Bldg Classroom 11				
2-268 086	Rooms 11-14 Bldg Classroom 11				
2-269 087	Rooms 11-14 Bldg Classroom 11				
2-270 088	Rooms 11-14 Bldg Classroom 11				
2-275 089	Rooms 11-14 Bldg Classroom 12				
2-274 090	Rooms 11-14 Bldg Classroom 12				
2-273 091	Rooms 11-14 Bldg Classroom 12				
2-272 092	Rooms 11-14 Bldg Classroom 12				
2-279 093	Rooms 11-14 Bldg Classroom 13				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-278 094	Rooms 11-14 Bldg Classroom 13				
2-277 095	Rooms 11-14 Bldg Classroom 13				
2-276 096	Rooms 11-14 Bldg Classroom 13				
2-283 097	Rooms 11-14 Bldg Classroom 14				
2-282 098	Rooms 11-14 Bldg Classroom 14				
2-281 099	Rooms 11-14 Bldg Classroom 14				
2-280 100	Rooms 11-14 Bldg Classroom 14				
2-257 124	Room 15 Bldg Office Entry				
2-256 125	Room 15 Bldg East Office				
2-259 126	Room 15 Bldg West Office				
2-258 127	Room 15 Bldg Restroom Hall				
2-261 128	Room 15 Bldg Hall Closet				
2-260 129	Room 15 Bldg Restroom				
2-263 134	Rooms 16 & 17 Bldg Classroom 16				
2-262 135	Rooms 16 & 17 Bldg Classroom 16				
2-264 136	Rooms 16 & 17 Bldg Classroom 17				
2-265 137	Rooms 16 & 17 Bldg Classroom 17				
2-267 145	Room 18 Bldg Classroom 18				
2-266 146	Room 18 Bldg Classroom 18				
2-253 150	Rooms 19 & 20 Bldg Classroom 19				
2-252 151	Rooms 19 & 20 Bldg Classroom 19				
2-255 152	Rooms 19 & 20 Bldg Classroom 20				
2-254 153	Rooms 19 & 20 Bldg Classroom 20				
2-049 162	Preschool Bldg Preschool				
2-050 163	Preschool Bldg Preschool				
2-051 164	Preschool Bldg Preschool				
2-048 165	Preschool Bldg Preschool Restroom				
2-039 175	Multi-Purpose Bldg MP Room				
2-037 176	Multi-Purpose Bldg MP Room				
2-036 177	Multi-Purpose Bldg MP Room				
2-038 178	Multi-Purpose Bldg MP Room				
2-034 179	Multi-Purpose Bldg MP Room				
2-035 180	Multi-Purpose Bldg MP Room				
2-040 181	Multi-Purpose Bldg MP Room Storage				
2-053 182	Multi-Purpose Bldg South Storage				
2-044 183	Multi-Purpose Bldg Kitchen Dry Storage				
2-043 184	Multi-Purpose Bldg Kitchen Wash Room				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-042 185	Multi-Purpose Bldg Kitchen Restroom				
2-041 186	Multi-Purpose Bldg O/S Storage SW				
2-290 200	RR Bldg by Rm 5 Boys Restroom				
2-289 201	RR Bldg by Rm 5 Boys Restroom				
2-292 202	RR Bldg by Rm 5 Girls Restroom				
2-291 203	RR Bldg by Rm 5 Girls Restroom				
Heat Detector - Restorable Spot					
2-136 011	Admin Building Above Ceiling Nurse				
2-126 030	Rooms 1-4 Bldg Lite Soffit Classrm 1				
2-127 031	Rooms 1-4 Bldg Lite Soffit Classrm 2				
2-128 032	Rooms 1-4 Bldg Lite Soffit Classrm 3				
2-129 033	Rooms 1-4 Bldg Lite Soffit Classrm 4				
2-014 054	Rooms 5-8 Bldg Cust Clst by Rm 5				
2-131 056	Rooms 5-8 Bldg Lite Soffit Classrm 5				
2-132 057	Rooms 5-8 Bldg Lite Soffit Classrm 6				
2-133 058	Rooms 5-8 Bldg Lite Soffit Classrm 7				
2-134 059	Rooms 5-8 Bldg Lite Soffit Classrm 8				
2-130 060	Rooms 5-8 Bldg RR Plumbing Chase by Rm 5				
2-387 075	Rooms 9 & 10 Bldg Above Ceiling Rm 9				
2-387 076	Rooms 9 & 10 Bldg Above Ceiling Rm 9				
2-387 077	Rooms 9 & 10 Bldg Above Ceiling Rm 9				
2-385 078	Rooms 9 & 10 Bldg Above Ceiling Rm 10				
2-385 079	Rooms 9 & 10 Bldg Above Ceiling Rm 10				
2-385 080	Rooms 9 & 10 Bldg Above Ceiling Rm 10				
2-381 101	Rooms 11-14 Bldg Above Ceiling Rm 11				
2-381 102	Rooms 11-14 Bldg Above Ceiling Rm 11				
2-381 103	Rooms 11-14 Bldg Above Ceiling Rm 11				
2-381 104	Rooms 11-14 Bldg Above Ceiling Rm 11				
2-382 105	Rooms 11-14 Bldg Above Ceiling Rm 12				
2-382 106	Rooms 11-14 Bldg Above Ceiling Rm 12				
2-382 107	Rooms 11-14 Bldg Above Ceiling Rm 12				
2-382 108	Rooms 11-14 Bldg Above Ceiling Rm 12				
2-383 109	Rooms 11-14 Bldg Above Ceiling Rm 13				
2-383 110	Rooms 11-14 Bldg Above Ceiling Rm 13				
2-383 111	Rooms 11-14 Bldg Above Ceiling Rm 13				
2-383 112	Rooms 11-14 Bldg Above Ceiling Rm 13				
2-384 113	Rooms 11-14 Bldg Above Ceiling Rm 14				
2-384 114	Rooms 11-14 Bldg Above Ceiling Rm 14				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-384 115	Rooms 11-14 Bldg Above Ceiling Rm 14				
2-384 116	Rooms 11-14 Bldg Above Ceiling Rm 14				
2-378 138	Rooms 16 & 17 Bldg Above Ceiling Rm 16				
2-378 139	Rooms 16 & 17 Bldg Above Ceiling Rm 16				
2-379 140	Rooms 16 & 17 Bldg Above Ceiling Rm 17				
2-379 141	Rooms 16 & 17 Bldg Above Ceiling Rm 17				
2-380 147	Room 18 Bldg Above Ceiling Rm 18				
2-380 148	Room 18 Bldg Above Ceiling Rm 18				
2-376 154	Rooms 19 & 20 Bldg Above Ceiling Rm 19				
2-376 155	Rooms 19 & 20 Bldg Above Ceiling Rm 19				
2-377 156	Rooms 19 & 20 Bldg Above Ceiling Rm 20				
2-377 157	Rooms 19 & 20 Bldg Above Ceiling Rm 20				
2-142 166	Preschool Bldg Lite Soffit Preschool				
2-047 187	Multi-Purpose Bldg Kitchen				
2-045 188	Multi-Purpose Bldg Kitchen				
2-046 189	Multi-Purpose Bldg Kitchen Scullary				
2-151 190	Multi-Purpose Bldg Above Ceiling S. Storage				
2-376	Rooms 19 & 20 Bldg Above Ceiling Rm 19				
2-376	Rooms 19 & 20 Bldg Above Ceiling Rm 19				
2-377	Rooms 19 & 20 Bldg Above Ceiling Rm 20				
2-377	Rooms 19 & 20 Bldg Above Ceiling Rm 20				
2-380	Room 18 Bldg Above Ceiling Rm 18				
2-378	Rooms 16 & 17 Bldg Above Ceiling Rm 16				
2-378	Rooms 16 & 17 Bldg Above Ceiling Rm 16				
2-379	Rooms 16 & 17 Bldg Above Ceiling Rm 17				
2-379	Rooms 16 & 17 Bldg Above Ceiling Rm 17				
2-384	Rooms 11-14 Bldg Above Ceiling Rm 14				
2-384	Rooms 11-14 Bldg Above Ceiling Rm 14				
2-383	Rooms 11-14 Bldg Above Ceiling Rm 13				
2-383	Rooms 11-14 Bldg Above Ceiling Rm 13				
2-382	Rooms 11-14 Bldg Above Ceiling Rm 12				
2-382	Rooms 11-14 Bldg Above Ceiling Rm 12				
2-381	Rooms 11-14 Bldg Above Ceiling Rm 11				
2-381	Rooms 11-14 Bldg Above Ceiling Rm 11				
Smoke Detector - Duct					
2-139 191	Multi-Purpose Bldg Southeast Unit				
2-140 192	Multi-Purpose Bldg Southwest Unit				