

# Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

CAMBRIDGE HEIGHTS ELEMENT

5555 FLEETWOOD DR  
CITRUS HEIGHTS, California 95621  
United States

This site has been inspected and tested in compliance with applicable standards.

Completed

Tuesday, September 30, 2025

Test Session: 24 Sep 2025 14:06 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD  
5320 HEMLOCK ST  
SACRAMENTO, California  
United States

TESTED BY

Riley Goyet  
Western States Fire Protection-  
Sacramento  
188 Cirby Way  
Roseville, CA 95678  
United States



# Inspection Summary

## Building Information

PROPERTY	CAMBRIDGE HEIGHTS ELEMENT	CONTACT
ADDRESS	5555 FLEETWOOD DR	PHONE
CITY/STATE	CITRUS?HEIGHTS, California 95621	MOBILE
COUNTRY	United States	EMAIL

## Inspector Information

COMPANY	Western States Fire Protection- Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us


## Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Alarm Notification Appliance	80	80(100%)	80(100%)	0(0%)
Fire Control Panel	8	8(100%)	5(63%)	3(38%)
Initiating Device	260	259(100%)	257(99%)	2(1%)

## Certification

The equipment specified here in was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Tuesday, September 30, 2025

ACCEPTED BY      09/30/2025  
  
Building Representative

  
TESTED BY      09/30/2025  
Riley Goyet  
Technician

# System Details

## Control Units

ADDRESS/ SCAN ADDRESS		DESCRIPTION	Pod A A8A Elect Room
MANUFACTURER	EST	S/W VERSION	
MODEL	3	LAST UPDATE	
SERIAL NUMBER		S/W LOCATION	
INSTALL DATE			

# Open Corrective Action & Solution Summary

The following 11 corrective action(s) remain open following the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
Manual Pull Station	2-189 007	Pod A Classroom A5
	Created By:	
	Creation Date:	12/20/2019
	Corrective Action:	Covered by cabinet. Cabinet needs to be moved
	Proposed Solution:	
	Manufacturer:	
	Model:	
	Created By:	Riley Goyet
	Creation Date:	11/03/2021
	Corrective Action:	Covered by cabinet. Cabinet needs to be removed
	Proposed Solution:	
	Manufacturer:	
	Model:	
	Created By:	Riley Goyet
	Creation Date:	10/10/2023
	Corrective Action:	Covered by cabinet.
	Proposed Solution:	
	Manufacturer:	
	Model:	
	Created By:	Riley Goyet
	Creation Date:	10/02/2024
	Corrective Action:	Need to move cabinet covering pull station.
	Proposed Solution:	
	Manufacturer:	
	Model:	
Fire Alarm Panel		Pod A A8A Elect Room
	Created By:	Riley Goyet
	Creation Date:	10/10/2023
	Corrective Action:	Need to replace (2) 12V 55AH batteries
	Proposed Solution:	
	Manufacturer:	EST
	Model:	3
	Created By:	Riley Goyet
	Creation Date:	10/02/2024
	Corrective Action:	Need to replace (2) 12V 55AH batteries
	Proposed Solution:	
	Manufacturer:	EST
	Model:	3
NAC Power Extender Panel		Pod A A8A Elect Room - P.E. "B"
	Created By:	Riley Goyet
	Creation Date:	10/10/2023
	Corrective Action:	Need to replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
	Created By:	Riley Goyet
	Creation Date:	10/02/2024
	Corrective Action:	Need to replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
----------------	---------	-------------

Model:

Heat Detector - Restorable Spot	2-148 261	Library Area Attic Library (near 2-061 smoke) middle library
---------------------------------	--------------	--

Created By: Riley Goyet  
 Creation Date: 10/02/2024  
 Corrective Action: Wires are chewed did not activate. Stick heat.  
 Proposed Solution:  
 Manufacturer:  
 Model:

Created By: Riley Goyet  
 Creation Date: 09/24/2025  
 Corrective Action: Stick heat chewed up  
 Proposed Solution:  
 Manufacturer:  
 Model:

NAC Power Extender Panel		Pod A A8A Elect Room - P.E. "C"
--------------------------	--	---------------------------------

Created By: Riley Goyet  
 Creation Date: 09/24/2025  
 Corrective Action: Replace (2) 12V 8AH Batteries  
 Proposed Solution:  
 Manufacturer:  
 Model:

# Testing Details

## Alarm Notification Appliance

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible	292	Discovery Club Boys Restroom	Manual	9/24/2025 2:10:26 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	290	Discovery Club Classroom	Manual	9/24/2025 2:11:25 PM
		Visual inspection	Passed (Manual)	
Visible	291	Discovery Club Girls Restroom	Manual	9/24/2025 2:10:24 PM
		Visual inspection	Passed (Manual)	
Audible	289	Discovery Club South Exterior	Manual	9/24/2025 2:11:04 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	278	G Portables Classroom G1	Manual	9/24/2025 2:11:26 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	279	G Portables Classroom G2	Manual	9/24/2025 2:11:29 PM
		Visual inspection	Passed (Manual)	
Audible	277	G Portables North Exterior	Manual	9/24/2025 2:11:03 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	268	Library Area East Interior	Manual	9/24/2025 2:11:31 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	267	Library Area West Interior	Manual	9/24/2025 2:11:33 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	266	Library Area West Interior	Manual	9/24/2025 2:11:34 PM
		Visual inspection	Passed (Manual)	
Visible	343	Multi-Purpose Bldg Boys Restroom	Manual	9/24/2025 2:10:23 PM
		Visual inspection	Passed (Manual)	
Visible	344	Multi-Purpose Bldg Girls Restroom	Manual	9/24/2025 2:10:21 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	341	Multi-Purpose Bldg Kitchen	Manual	9/24/2025 2:11:20 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	338	Multi-Purpose Bldg MP Room	Manual	9/24/2025 2:11:23 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	339	Multi-Purpose Bldg MP Room	Manual	9/24/2025 2:11:28 PM
		Visual inspection	Passed (Manual)	
Audible	346	Multi-Purpose Bldg Northwest Exterior	Manual	9/24/2025 2:10:58 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	340	Multi-Purpose Bldg Restroom Hallway	Manual	9/24/2025 2:11:22 PM
		Visual inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	336	Multi-Purpose Bldg South Exterior	Manual	9/24/2025 2:11:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	342	Multi-Purpose Bldg Stage	Manual	9/24/2025 2:11:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	345	Multi-Purpose Bldg Stage Stairway West	Manual	9/24/2025 2:10:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	337	Multi-Purpose Bldg West Exterior	Manual	9/24/2025 2:11:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	084	Pod A Admin Mens RR	Manual	9/24/2025 2:10:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	085	Pod A Admin Womens RR	Manual	9/24/2025 2:10:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	079	Pod A Computer Lab	Manual	9/24/2025 2:12:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	081	Pod A Cougar Cave A7	Manual	9/24/2025 2:11:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	066	Pod A East Exterior	Manual	9/24/2025 2:11:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	070	Pod A Faculty Break Room	Manual	9/24/2025 2:12:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	074	Pod A Hallway	Manual	9/24/2025 2:12:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	073	Pod A Hallway	Manual	9/24/2025 2:12:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	072	Pod A Hallway	Manual	9/24/2025 2:12:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	071	Pod A Hallway	Manual	9/24/2025 2:12:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	076	Pod A Kindergarten A6 N	Manual	9/24/2025 2:12:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	075	Pod A Kindergarten A6 N	Manual	9/24/2025 2:12:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	078	Pod A Kindergarten A6 S	Manual	9/24/2025 2:12:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	077	Pod A Kindergarten A6 S	Manual	9/24/2025 2:12:04 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Visible	087	Pod A Kindergarten RR	Manual	9/24/2025 2:10:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	086	Pod A Kindergarten RR	Manual	9/24/2025 2:10:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	083	Pod A Main Office	Manual	9/24/2025 2:10:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	082	Pod A Principals Office	Manual	9/24/2025 2:10:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	080	Pod A Room A1	Manual	9/24/2025 2:12:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	068	Pod A Room A2C	Manual	9/24/2025 2:12:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	067	Pod A South Exterior	Manual	9/24/2025 2:11:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	069	Pod A Work Room	Manual	9/24/2025 2:12:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	155	Pod B Boys Restroom	Manual	9/24/2025 2:10:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	154	Pod B Boys Restroom Hall	Manual	9/24/2025 2:10:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	152	Pod B Girls Restroom	Manual	9/24/2025 2:10:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	151	Pod B Girls Restroom Hall	Manual	9/24/2025 2:10:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	150	Pod B Pod B Classrooms	Manual	9/24/2025 2:11:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	149	Pod B Pod B Classrooms	Manual	9/24/2025 2:11:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	148	Pod B Pod B Classrooms	Manual	9/24/2025 2:11:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	147	Pod B Pod B Classrooms	Manual	9/24/2025 2:11:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	145	Pod B Room B13	Manual	9/24/2025 2:11:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	144	Pod B Room B13	Manual	9/24/2025 2:11:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible	153	Pod B Room B8	Manual	9/24/2025 2:10:45 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible	142	Pod B South Exterior	Manual	9/24/2025 2:11:13 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	146	Pod B Speech Room B14	Manual	9/24/2025 2:11:53 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible	143	Pod B West Exterior	Manual	9/24/2025 2:11:12 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Visible	203	Pod C Boys Restroom	Manual	9/24/2025 2:10:36 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Visible	202	Pod C Boys Restroom Hall	Manual	9/24/2025 2:10:37 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Visible	200	Pod C Girls Restroom	Manual	9/24/2025 2:10:40 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Visible	199	Pod C Girls Restroom Hall	Manual	9/24/2025 2:10:41 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	198	Pod C Pod C Classrooms	Manual	9/24/2025 2:11:42 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	197	Pod C Pod C Classrooms	Manual	9/24/2025 2:11:43 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	196	Pod C Pod C Classrooms	Manual	9/24/2025 2:11:45 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	195	Pod C Pod C Classrooms	Manual	9/24/2025 2:11:46 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Visible	201	Pod C Room C10	Manual	9/24/2025 2:10:38 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Visible	204	Pod C Room C7	Manual	9/24/2025 2:10:34 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible	194	Pod C West Exterior	Manual	9/24/2025 2:11:11 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Visible	251	Pod D Boys Restroom	Manual	9/24/2025 2:10:27 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Visible	250	Pod D Boys Restroom Hall	Manual	9/24/2025 2:10:28 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible	241	Pod D East Exterior	Manual	9/24/2025 2:11:07 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Visible	248	Pod D Girls Restroom	Manual	9/24/2025 2:10:31 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	247	Pod D Girls Restroom Hall	Manual	9/24/2025 2:10:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	240	Pod D North Exterior	Manual	9/24/2025 2:11:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	246	Pod D Pod D Classrooms	Manual	9/24/2025 2:11:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	245	Pod D Pod D Classrooms	Manual	9/24/2025 2:11:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	244	Pod D Pod D Classrooms	Manual	9/24/2025 2:11:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	243	Pod D Pod D Classrooms	Manual	9/24/2025 2:11:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	249	Pod D Room D9	Manual	9/24/2025 2:10:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	242	Pod D West Exterior	Manual	9/24/2025 2:11:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

### Fire Control Panel

#### Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
NAC Power Extender Panel	347	Multi-Purpose Bldg Storage Room E1A - P.E. "G"	Manual	9/24/2025 5:05:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Pod A A8A Elect Room - P.E. "E"	Manual	9/24/2025 4:39:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Pod A A8A Elect Room - P.E. "F"	Manual	9/24/2025 4:39:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Pod A A8A Elect Room - P.E. "Master"	Manual	9/24/2025 4:39:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Remote Annunciator	001	Pod A Reception	Manual	9/24/2025 4:38:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

#### Failed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Fire Alarm Panel		Pod A A8A Elect Room	Manual	9/24/2025 4:38:32 PM
		Manufacturer	EST	
		Model	3	
		Visual inspection	Failed (Manual)	
NAC Power Extender Panel		Pod A A8A Elect Room - P.E. "B"	Manual	9/24/2025 4:39:29 PM
		Visual inspection	Failed (Manual)	
NAC Power Extender Panel		Pod A A8A Elect Room - P.E. "C"	Manual	9/24/2025 4:39:51 PM
		Visual inspection	Failed (Manual)	

## Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-380 288	Discovery Club Attic Discovery Club	Manual	9/24/2025 5:04:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-380 286	Discovery Club Attic Discovery Club	Manual	9/24/2025 5:05:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-380 287	Discovery Club Attic Discovery Club	Manual	9/24/2025 5:05:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-285 285	Discovery Club Boys Restroom	Manual	9/24/2025 5:18:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-287 282	Discovery Club Classroom	Manual	9/24/2025 5:18:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-194 280	Discovery Club F1 North Exit	Manual	9/24/2025 4:24:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-193 281	Discovery Club F1 South Exit	Manual	9/24/2025 4:25:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-286 284	Discovery Club Girls Restroom	Manual	9/24/2025 5:18:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-288 283	Discovery Club Storage	Manual	9/24/2025 5:18:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-381 273	G Portables Attic Classroom G1	Manual	9/24/2025 4:51:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-381 274	G Portables Attic Classroom G1	Manual	9/24/2025 4:51:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-382 275	G Portables Attic Classroom G2	Manual	9/24/2025 4:52:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-382 276	G Portables Attic Classroom G2	Manual	9/24/2025 4:52:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-283 271	G Portables Classroom G1	Manual	9/24/2025 4:20:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-170 269	G Portables Classroom G1	Manual	9/24/2025 4:36:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-284 272	G Portables Classroom G2	Manual	9/24/2025 4:18:37 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-169 270	G Portables Classroom G2	Manual	9/24/2025 4:36:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-148 264	Library Area Attic Library	Manual	9/24/2025 4:19:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-148 263	Library Area Attic Library	Manual	9/24/2025 4:19:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-148 262	Library Area Attic Library	Manual	9/24/2025 4:19:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-148 265	Library Area Attic Library	Manual	9/24/2025 4:19:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-063 260	Library Area Landing	Manual	9/24/2025 3:44:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-060 254	Library Area Library	Manual	9/24/2025 3:39:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-053 258	Library Area Library	Manual	9/24/2025 3:42:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-058 256	Library Area Library	Manual	9/24/2025 3:42:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-061 257	Library Area Library	Manual	9/24/2025 3:42:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-059 255	Library Area Library	Manual	9/24/2025 3:52:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-054 259	Library Area Library	Manual	9/24/2025 3:57:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-172 252	Library Area Northeast Corner	Manual	9/24/2025 3:44:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-161 253	Library Area Southwest Corner	Manual	9/24/2025 4:37:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-146 323	Multi-Purpose Bldg Attic Boys Restroom	Manual	9/24/2025 4:37:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-146 329	Multi-Purpose Bldg Attic Fire Riser Room	Manual	9/24/2025 4:37:04 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-146 324	Multi-Purpose Bldg Attic Girls Restroom	Manual	9/24/2025 4:37:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-146 326	Multi-Purpose Bldg Attic Kitchen	Manual	9/24/2025 4:37:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-146 328	Multi-Purpose Bldg Attic Kitchen	Manual	9/24/2025 4:37:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-146 327	Multi-Purpose Bldg Attic Kitchen	Manual	9/24/2025 4:37:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-146 325	Multi-Purpose Bldg Attic Restroom Hall	Manual	9/24/2025 4:37:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-146 332	Multi-Purpose Bldg Attic Stage Stairs E	Manual	9/24/2025 4:37:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-146 331	Multi-Purpose Bldg Attic Stage Stairs E	Manual	9/24/2025 4:37:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-146 330	Multi-Purpose Bldg Attic Stage Stairs W	Manual	9/24/2025 4:37:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-146 315	Multi-Purpose Bldg Boys Restroom	Manual	9/24/2025 4:37:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-146 317	Multi-Purpose Bldg Custodial Room	Manual	9/24/2025 4:37:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-146 320	Multi-Purpose Bldg Fire Riser Room	Manual	9/24/2025 4:37:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-146 316	Multi-Purpose Bldg Girls Restroom	Manual	9/24/2025 4:37:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-146 319	Multi-Purpose Bldg Kitchen	Manual	9/24/2025 4:37:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-146 318	Multi-Purpose Bldg Kitchen	Manual	9/24/2025 4:37:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-182 297	Multi-Purpose Bldg Kitchen	Manual	9/24/2025 4:40:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-070 302	Multi-Purpose Bldg MP Room	Manual	9/24/2025 4:12:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-067 303	Multi-Purpose Bldg MP Room	Manual	9/24/2025 4:12:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-074 304	Multi-Purpose Bldg MP Room	Manual	9/24/2025 4:13:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-064 305	Multi-Purpose Bldg MP Room	Manual	9/24/2025 4:13:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-066 306	Multi-Purpose Bldg MP Room	Manual	9/24/2025 4:13:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-068 307	Multi-Purpose Bldg MP Room	Manual	9/24/2025 4:13:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-071 308	Multi-Purpose Bldg MP Room	Manual	9/24/2025 4:13:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-075 309	Multi-Purpose Bldg MP Room	Manual	9/24/2025 4:13:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-073 301	Multi-Purpose Bldg MP Room	Manual	9/24/2025 4:28:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-072 300	Multi-Purpose Bldg MP Room	Manual	9/24/2025 4:28:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-069 299	Multi-Purpose Bldg MP Room	Manual	9/24/2025 4:28:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-065 298	Multi-Purpose Bldg MP Room	Manual	9/24/2025 4:28:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-181 293	Multi-Purpose Bldg MP Room Hall E2	Manual	9/24/2025 4:02:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-183 296	Multi-Purpose Bldg MP Room NE	Manual	9/24/2025 4:00:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-184 295	Multi-Purpose Bldg MP Room SE	Manual	9/24/2025 4:40:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-185 294	Multi-Purpose Bldg MP Room SW	Manual	9/24/2025 4:00:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Valve Tamper Switch	2-145 335	Multi-Purpose Bldg PIV NW Exterior	Manual	9/24/2025 4:51:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-079 310	Multi-Purpose Bldg Restroom Hallway	Manual	9/24/2025 4:12:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-077 312	Multi-Purpose Bldg Stage	Manual	9/24/2025 4:13:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-076 313	Multi-Purpose Bldg Stage	Manual	9/24/2025 4:14:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-146 322	Multi-Purpose Bldg Stage Stairs East	Manual	9/24/2025 4:37:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-146 321	Multi-Purpose Bldg Stage Stairs East	Manual	9/24/2025 4:37:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-078 311	Multi-Purpose Bldg Stage Stairway	Manual	9/24/2025 4:14:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-084 314	Multi-Purpose Bldg Storage Room E1A	Manual	9/24/2025 4:21:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	2-144 334	Multi-Purpose Bldg Westside of Stage	Manual	9/24/2025 4:51:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-268 045	Pod A A11 Storage Room	Manual	9/24/2025 5:18:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-048 043	Pod A A8A Elect Room	Manual	9/24/2025 5:20:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-260 031	Pod A A8A Elect Room	Manual	9/24/2025 3:58:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-275 036	Pod A Admin Mens RR	Manual	9/24/2025 5:18:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-192 004	Pod A Admin Office A2	Manual	9/24/2025 3:38:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-272 014	Pod A Admin Storage	Manual	9/24/2025 3:35:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-276 035	Pod A Admin Womens RR	Manual	9/24/2025 4:17:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-279 016	Pod A Admin Work Room	Manual	9/24/2025 3:35:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-377 051	Pod A Attic A8A Elect Rm	Manual	9/24/2025 4:19:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-377 049	Pod A Attic Admin	Manual	9/24/2025 4:19:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-377 050	Pod A Attic Admin	Manual	9/24/2025 4:19:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-377 048	Pod A Attic Admin	Manual	9/24/2025 4:19:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-377 052	Pod A Attic Computer Lab	Manual	9/24/2025 4:19:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-378 054	Pod A Attic Faculty Room	Manual	9/24/2025 3:36:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-378 053	Pod A Attic Faculty Room	Manual	9/24/2025 3:36:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-378 055	Pod A Attic Faculty Room	Manual	9/24/2025 3:36:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-378 056	Pod A Attic Faculty Room	Manual	9/24/2025 3:36:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-379 060	Pod A Attic Hall by Rm A5	Manual	9/24/2025 3:36:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-379 057	Pod A Attic Hall by RRs	Manual	9/24/2025 3:36:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-385 065	Pod A Attic Kinder Rm A6	Manual	9/24/2025 3:37:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-385 064	Pod A Attic Kinder Rm A6	Manual	9/24/2025 3:37:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-385 063	Pod A Attic Kinder Rm A6	Manual	9/24/2025 3:37:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-385 062	Pod A Attic Kinder Rm A6	Manual	9/24/2025 3:37:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-379 058	Pod A Attic Platform Hall	Manual	9/24/2025 3:36:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-379 059	Pod A Attic Platform Hall	Manual	9/24/2025 3:36:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-383 046	Pod A Attic Room A1	Manual	9/24/2025 3:38:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-379 061	Pod A Attic Room A5	Manual	9/24/2025 3:36:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-383 047	Pod A Attic Room A7	Manual	9/24/2025 3:38:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-191 005	Pod A Classroom A3	Manual	9/24/2025 3:38:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-190 006	Pod A Classroom A4	Manual	9/24/2025 4:12:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-188 008	Pod A Classroom A6	Manual	9/24/2025 3:37:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-187 009	Pod A Classroom A6	Manual	9/24/2025 3:37:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-261 030	Pod A Computer Lab	Manual	9/24/2025 3:38:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-266 029	Pod A Computer Lab	Manual	9/24/2025 3:38:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-166 010	Pod A Cougar Cave A7	Manual	9/24/2025 4:14:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-290 032	Pod A Cougar Cave A7	Manual	9/24/2025 3:39:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-289 033	Pod A Cougar Cave A7	Manual	9/24/2025 3:39:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-273 044	Pod A Custodial Office A9A	Manual	9/24/2025 5:14:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-282 017	Pod A Faculty Break Room	Manual	9/24/2025 3:36:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-267 028	Pod A Hall by A10	Manual	9/24/2025 3:36:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-274 018	Pod A Hall by Faculty Room	Manual	9/24/2025 3:36:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-262 026	Pod A Hall Outside A6	Manual	9/24/2025 3:36:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-256 039	Pod A Kinder PE Storage	Manual	9/24/2025 5:19:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-259 020	Pod A Kindergarten A6	Manual	9/24/2025 3:37:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-254 022	Pod A Kindergarten A6	Manual	9/24/2025 3:37:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-253 023	Pod A Kindergarten A6	Manual	9/24/2025 3:37:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-257 024	Pod A Kindergarten A6	Manual	9/24/2025 3:38:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-258 021	Pod A Kindergarten A6	Manual	9/24/2025 3:38:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-263 025	Pod A Kindergarten Hallway	Manual	9/24/2025 3:36:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-255 041	Pod A Kindergarten RR	Manual	9/24/2025 5:19:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-252 042	Pod A Kindergarten RR	Manual	9/24/2025 5:19:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-376 002	Pod A Main Office	Manual	9/24/2025 3:38:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-278 012	Pod A Main Office	Manual	9/24/2025 3:35:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-281 034	Pod A Nurse Restroom	Manual	9/24/2025 5:13:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-280 015	Pod A Nurses Office	Manual	9/24/2025 3:36:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-277 013	Pod A Principals Office	Manual	9/24/2025 3:35:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Manual Pull Station	2-171 003	Pod A Room A1	Manual	9/24/2025 4:13:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-265 011	Pod A Room A1	Manual	9/24/2025 3:39:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-271 037	Pod A Room A4	Manual	9/24/2025 5:18:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-270 038	Pod A Room A4A Closet	Manual	9/24/2025 5:20:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-251 040	Pod A Room A6D	Manual	9/24/2025 5:20:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-264 019	Pod A Speech Room A5	Manual	9/24/2025 3:37:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-269 027	Pod A Storage Room A9	Manual	9/24/2025 3:37:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-134 121	Pod B Attic Above Ramp	Manual	9/24/2025 3:41:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-134 122	Pod B Attic Above Stairs	Manual	9/24/2025 3:41:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-131 141	Pod B Attic Boys RR Hall	Manual	9/24/2025 5:12:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-131 140	Pod B Attic Girls RR Hall	Manual	9/24/2025 5:12:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-133 139	Pod B Attic Pod B Classrms	Manual	9/24/2025 3:38:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-133 138	Pod B Attic Pod B Classrms	Manual	9/24/2025 3:39:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-133 137	Pod B Attic Pod B Classrms	Manual	9/24/2025 3:39:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-133 130	Pod B Attic Pod B Classrms	Manual	9/24/2025 3:39:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-133 136	Pod B Attic Pod B Classrms	Manual	9/24/2025 3:39:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-133 135	Pod B Attic Pod B Classrms	Manual	9/24/2025 3:39:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-133 134	Pod B Attic Pod B Classrms	Manual	9/24/2025 3:39:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-133 133	Pod B Attic Pod B Classrms	Manual	9/24/2025 3:39:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-133 132	Pod B Attic Pod B Classrms	Manual	9/24/2025 3:39:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-133 131	Pod B Attic Pod B Classrms	Manual	9/24/2025 3:39:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-139 128	Pod B Attic Rm B13 Stairs	Manual	9/24/2025 3:38:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-134 123	Pod B Attic Room B10	Manual	9/24/2025 3:41:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-134 124	Pod B Attic Room B11	Manual	9/24/2025 3:41:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-134 125	Pod B Attic Room B12	Manual	9/24/2025 3:41:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-139 126	Pod B Attic Room B13	Manual	9/24/2025 3:38:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-139 127	Pod B Attic Room B13	Manual	9/24/2025 3:38:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-139 129	Pod B Attic Room B14	Manual	9/24/2025 3:39:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-082 099	Pod B B2 Fire Doors	Manual	9/24/2025 3:39:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-036 118	Pod B Boys Restroom	Manual	9/24/2025 4:51:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-037 117	Pod B Boys Restroom Hall	Manual	9/24/2025 4:17:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-167 093	Pod B Classroom B1	Manual	9/24/2025 3:40:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Manual Pull Station	2-168 094	Pod B Classroom B2	Manual	9/24/2025 4:13:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-163 097	Pod B Classroom B5	Manual	9/24/2025 3:40:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-162 098	Pod B Classroom B6	Manual	9/24/2025 3:41:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-057 111	Pod B Copier Room B12	Manual	9/24/2025 3:39:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-035 120	Pod B Custodial Room	Manual	9/24/2025 4:14:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-041 116	Pod B Girls Restroom	Manual	9/24/2025 5:12:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-040 115	Pod B Girls Restroom Hall	Manual	9/24/2025 5:13:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-042 119	Pod B PE Storage	Manual	9/24/2025 5:13:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-052 101	Pod B Pod B Classrooms	Manual	9/24/2025 3:40:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-049 103	Pod B Pod B Classrooms	Manual	9/24/2025 3:40:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-045 107	Pod B Pod B Classrooms	Manual	9/24/2025 3:40:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-044 104	Pod B Pod B Classrooms	Manual	9/24/2025 3:40:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-043 105	Pod B Pod B Classrooms	Manual	9/24/2025 3:41:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-046 106	Pod B Pod B Classrooms	Manual	9/24/2025 3:41:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-050 108	Pod B Pod B Classrooms	Manual	9/24/2025 3:41:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-051 100	Pod B Pod B Classrooms	Manual	9/24/2025 3:41:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-047 102	Pod B Pod B Classrooms	Manual	9/24/2025 3:41:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-165 095	Pod B Rm B2 by Girls RR	Manual	9/24/2025 3:40:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-164 096	Pod B Rm B5 by Boys RR	Manual	9/24/2025 3:40:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-055 113	Pod B Room B10	Manual	9/24/2025 3:41:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-056 114	Pod B Room B11	Manual	9/24/2025 3:41:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-038 109	Pod B Room B8	Manual	9/24/2025 3:40:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-039 110	Pod B Room B8	Manual	9/24/2025 3:57:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-062 112	Pod B Speech Room B14	Manual	9/24/2025 3:39:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-137 192	Pod C Attic Boys RR Hall	Manual	9/24/2025 5:19:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-137 191	Pod C Attic Girls RR Hall	Manual	9/24/2025 5:19:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-135 186	Pod C Attic Pod C Classrms	Manual	9/24/2025 3:43:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-135 184	Pod C Attic Pod C Classrms	Manual	9/24/2025 3:43:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-135 185	Pod C Attic Pod C Classrms	Manual	9/24/2025 3:43:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-135 182	Pod C Attic Pod C Classrms	Manual	9/24/2025 3:43:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-135 181	Pod C Attic Pod C Classrms	Manual	9/24/2025 3:43:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-135 183	Pod C Attic Pod C Classrms	Manual	9/24/2025 3:43:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-135 187	Pod C Attic Pod C Classrms	Manual	9/24/2025 3:43:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-135 188	Pod C Attic Pod C Classrms	Manual	9/24/2025 3:43:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-135 189	Pod C Attic Pod C Classrms	Manual	9/24/2025 3:43:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-135 190	Pod C Attic Pod C Classrms	Manual	9/24/2025 3:43:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-150 193	Pod C Attic Room C7	Manual	9/24/2025 3:51:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-024 178	Pod C Boys Restroom	Manual	9/24/2025 4:26:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-023 177	Pod C Boys Restroom Hall	Manual	9/24/2025 4:51:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-160 156	Pod C Classroom C1	Manual	9/24/2025 3:42:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-159 157	Pod C Classroom C2	Manual	9/24/2025 3:43:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-156 160	Pod C Classroom C5	Manual	9/24/2025 3:44:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-155 161	Pod C Classroom C6	Manual	9/24/2025 3:42:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-025 180	Pod C Custodial Room	Manual	9/24/2025 4:36:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-019 176	Pod C Girls Restroom	Manual	9/24/2025 4:24:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-020 175	Pod C Girls Restroom Hall	Manual	9/24/2025 4:51:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-018 179	Pod C PE Storage	Manual	9/24/2025 4:22:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-033 171	Pod C Pod C Classrooms	Manual	9/24/2025 3:42:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-034 170	Pod C Pod C Classrooms	Manual	9/24/2025 3:42:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-030 168	Pod C Pod C Classrooms	Manual	9/24/2025 3:42:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-031 169	Pod C Pod C Classrooms	Manual	9/24/2025 3:42:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-032 163	Pod C Pod C Classrooms	Manual	9/24/2025 3:42:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-029 164	Pod C Pod C Classrooms	Manual	9/24/2025 3:42:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-026 165	Pod C Pod C Classrooms	Manual	9/24/2025 3:43:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-027 166	Pod C Pod C Classrooms	Manual	9/24/2025 3:43:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-028 167	Pod C Pod C Classrooms	Manual	9/24/2025 3:43:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-158 158	Pod C Rm C2 by Girls RR	Manual	9/24/2025 4:13:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-157 159	Pod C Rm C5 by Boys RR	Manual	9/24/2025 3:43:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-021 173	Pod C Room C10	Manual	9/24/2025 3:43:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-022 174	Pod C Room C10	Manual	9/24/2025 3:43:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-154 162	Pod C Room C7	Manual	9/24/2025 3:44:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-081 172	Pod C Room C7 The Box	Manual	9/24/2025 3:44:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-143 238	Pod D Attic Boys RR Hall	Manual	9/24/2025 4:12:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-143 239	Pod D Attic Girls RR Hall	Manual	9/24/2025 4:12:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-140 237	Pod D Attic Pod D Classrms	Manual	9/24/2025 3:57:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-140 236	Pod D Attic Pod D Classrms	Manual	9/24/2025 3:57:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-140 235	Pod D Attic Pod D Classrms	Manual	9/24/2025 3:57:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-140 234	Pod D Attic Pod D Classrms	Manual	9/24/2025 3:57:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-140 233	Pod D Attic Pod D Classrms	Manual	9/24/2025 3:57:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-140 232	Pod D Attic Pod D Classrms	Manual	9/24/2025 3:57:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-140 231	Pod D Attic Pod D Classrms	Manual	9/24/2025 3:57:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-140 230	Pod D Attic Pod D Classrms	Manual	9/24/2025 3:57:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-140 229	Pod D Attic Pod D Classrms	Manual	9/24/2025 3:57:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-140 228	Pod D Attic Pod D Classrms	Manual	9/24/2025 3:57:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-016 223	Pod D Boys Restroom	Manual	9/24/2025 5:22:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-015 222	Pod D Boys Restroom Hall	Manual	9/24/2025 4:13:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-178 205	Pod D Classroom D1	Manual	9/24/2025 4:37:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-177 206	Pod D Classroom D2	Manual	9/24/2025 3:46:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-174 207	Pod D Classroom D5	Manual	9/24/2025 3:45:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-173 209	Pod D Classroom D6	Manual	9/24/2025 3:44:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-017 227	Pod D Custodial Room	Manual	9/24/2025 5:24:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-011 225	Pod D Girls Restroom	Manual	9/24/2025 5:27:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-012 224	Pod D Girls Restroom Hall	Manual	9/24/2025 4:12:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-010 226	Pod D PE Storage	Manual	9/24/2025 5:27:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-002 212	Pod D Pod D Classrooms	Manual	9/24/2025 3:44:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-006 213	Pod D Pod D Classrooms	Manual	9/24/2025 3:44:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-005 214	Pod D Pod D Classrooms	Manual	9/24/2025 3:44:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-003 211	Pod D Pod D Classrooms	Manual	9/24/2025 3:44:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-008 217	Pod D Pod D Classrooms	Manual	9/24/2025 3:44:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-009 216	Pod D Pod D Classrooms	Manual	9/24/2025 3:44:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-007 218	Pod D Pod D Classrooms	Manual	9/24/2025 3:45:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-004 215	Pod D Pod D Classrooms	Manual	9/24/2025 3:47:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-080 219	Pod D Pod D Classrooms	Manual	9/24/2025 3:48:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-175 208	Pod D Rm D5 by Boys RR	Manual	9/24/2025 3:45:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-176 210	Pod D Rm D8 by Girls RR	Manual	9/24/2025 3:45:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-014 220	Pod D Room D9	Manual	9/24/2025 3:45:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-013 221	Pod D Room D9	Manual	9/24/2025 3:45:16 PM

Visual inspection Passed (Manual)  
 Functional Inspection Passed

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - Duct	2-147 333	Multi-Purpose Bldg Stage East	Manual	9/24/2025 5:05:08 PM

Visual inspection Passed (Manual)  
 Functional Inspection Passed

Failed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-148 261	Library Area Attic Library (near 2-061 smoke) middle library	Manual	9/24/2025 4:36:01 PM

Visual inspection Failed (Manual)  
 Functional Inspection Failed

Manual Pull Station	2-189 007	Pod A Classroom A5	Manual	9/24/2025 4:02:45 PM
---------------------	--------------	--------------------	--------	----------------------

Visual inspection Failed (Manual)  
 Functional Inspection Failed

## Device/Equipment details

### Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Audible					
066	Pod A East Exterior				
067	Pod A South Exterior				
142	Pod B South Exterior				
143	Pod B West Exterior				
194	Pod C West Exterior				
240	Pod D North Exterior				
241	Pod D East Exterior				
242	Pod D West Exterior				
277	G Portables North Exterior				
289	Discovery Club South Exterior				
336	Multi-Purpose Bldg South Exterior				
337	Multi-Purpose Bldg West Exterior				
346	Multi-Purpose Bldg Northwest Exterior				
Audible And Visible					
068	Pod A Room A2C				
069	Pod A Work Room				
070	Pod A Faculty Break Room				
071	Pod A Hallway				
072	Pod A Hallway				
073	Pod A Hallway				
074	Pod A Hallway				
075	Pod A Kindergarten A6 N				
076	Pod A Kindergarten A6 N				
077	Pod A Kindergarten A6 S				
078	Pod A Kindergarten A6 S				
079	Pod A Computer Lab				
080	Pod A Room A1				
081	Pod A Cougar Cave A7				
144	Pod B Room B13				
145	Pod B Room B13				
146	Pod B Speech Room B14				
147	Pod B Pod B Classrooms				
148	Pod B Pod B Classrooms				
149	Pod B Pod B Classrooms				
150	Pod B Pod B Classrooms				
195	Pod C Pod C Classrooms				
196	Pod C Pod C Classrooms				
197	Pod C Pod C Classrooms				
198	Pod C Pod C Classrooms				
243	Pod D Pod D Classrooms				
244	Pod D Pod D Classrooms				
245	Pod D Pod D Classrooms				
246	Pod D Pod D Classrooms				
266	Library Area West Interior				
267	Library Area West Interior				
268	Library Area East Interior				
278	G Portables Classroom G1				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
279	G Portables Classroom G2				
290	Discovery Club Classroom				
338	Multi-Purpose Bldg MP Room				
339	Multi-Purpose Bldg MP Room				
340	Multi-Purpose Bldg Restroom Hallway				
341	Multi-Purpose Bldg Kitchen				
342	Multi-Purpose Bldg Stage				
Visible					
082	Pod A Principals Office				
083	Pod A Main Office				
084	Pod A Admin Mens RR				
085	Pod A Admin Womens RR				
086	Pod A Kindergarten RR				
087	Pod A Kindergarten RR				
151	Pod B Girls Restroom Hall				
152	Pod B Girls Restroom				
153	Pod B Room B8				
154	Pod B Boys Restroom Hall				
155	Pod B Boys Restroom				
199	Pod C Girls Restroom Hall				
200	Pod C Girls Restroom				
201	Pod C Room C10				
202	Pod C Boys Restroom Hall				
203	Pod C Boys Restroom				
204	Pod C Room C7				
247	Pod D Girls Restroom Hall				
248	Pod D Girls Restroom				
249	Pod D Room D9				
250	Pod D Boys Restroom Hall				
251	Pod D Boys Restroom				
291	Discovery Club Girls Restroom				
292	Discovery Club Boys Restroom				
343	Multi-Purpose Bldg Boys Restroom				
344	Multi-Purpose Bldg Girls Restroom				
345	Multi-Purpose Bldg Stage Stairway West				

### Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
NAC Power Extender Panel					
347	Multi-Purpose Bldg Storage Room E1A - P.E. "G"				
	Pod A A8A Elect Room - P.E. "Master"				
	Pod A A8A Elect Room - P.E. "B"				
	Pod A A8A Elect Room - P.E. "C"				
	Pod A A8A Elect Room - P.E. "E"				
	Pod A A8A Elect Room - P.E. "F"				

### Remote Annunciator

001	Pod A Reception				
-----	-----------------	--	--	--	--

### Fire Alarm Panel

	Pod A A8A Elect Room	EST	3		
--	----------------------	-----	---	--	--

### Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Heat Detector - Restorable Spot					
2-377 049	Pod A Attic Admin				
2-377 050	Pod A Attic Admin				
2-377 051	Pod A Attic A8A Elect Rm				
2-377 052	Pod A Attic Computer Lab				
2-378 053	Pod A Attic Faculty Room				
2-378 054	Pod A Attic Faculty Room				
2-378 055	Pod A Attic Faculty Room				
2-378 056	Pod A Attic Faculty Room				
2-379 057	Pod A Attic Hall by RRs				
2-379 058	Pod A Attic Platform Hall				
2-379 059	Pod A Attic Platform Hall				
2-379 060	Pod A Attic Hall by Rm A5				
2-379 061	Pod A Attic Room A5				
2-385 062	Pod A Attic Kinder Rm A6				
2-385 063	Pod A Attic Kinder Rm A6				
2-385 064	Pod A Attic Kinder Rm A6				
2-385 065	Pod A Attic Kinder Rm A6				
2-055 113	Pod B Room B10				
2-056 114	Pod B Room B11				
2-040 115	Pod B Girls Restroom Hall				
2-041 116	Pod B Girls Restroom				
2-037 117	Pod B Boys Restroom Hall				
2-036 118	Pod B Boys Restroom				
2-042 119	Pod B PE Storage				
2-035 120	Pod B Custodial Room				
2-134 121	Pod B Attic Above Ramp				
2-134 122	Pod B Attic Above Stairs				
2-134 123	Pod B Attic Room B10				
2-134 124	Pod B Attic Room B11				
2-134 125	Pod B Attic Room B12				
2-139 126	Pod B Attic Room B13				
2-139 127	Pod B Attic Room B13				
2-139 128	Pod B Attic Rm B13 Stairs				
2-139 129	Pod B Attic Room B14				
2-133 130	Pod B Attic Pod B Classrms				
2-133 131	Pod B Attic Pod B Classrms				
2-133 132	Pod B Attic Pod B Classrms				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-133 133	Pod B Attic Pod B Classrms				
2-133 134	Pod B Attic Pod B Classrms				
2-133 135	Pod B Attic Pod B Classrms				
2-133 136	Pod B Attic Pod B Classrms				
2-133 137	Pod B Attic Pod B Classrms				
2-133 138	Pod B Attic Pod B Classrms				
2-133 139	Pod B Attic Pod B Classrms				
2-131 140	Pod B Attic Girls RR Hall				
2-131 141	Pod B Attic Boys RR Hall				
2-020 175	Pod C Girls Restroom Hall				
2-019 176	Pod C Girls Restroom				
2-023 177	Pod C Boys Restroom Hall				
2-024 178	Pod C Boys Restroom				
2-018 179	Pod C PE Storage				
2-025 180	Pod C Custodial Room				
2-135 181	Pod C Attic Pod C Classrms				
2-135 182	Pod C Attic Pod C Classrms				
2-135 183	Pod C Attic Pod C Classrms				
2-135 184	Pod C Attic Pod C Classrms				
2-135 185	Pod C Attic Pod C Classrms				
2-135 186	Pod C Attic Pod C Classrms				
2-135 187	Pod C Attic Pod C Classrms				
2-135 188	Pod C Attic Pod C Classrms				
2-135 189	Pod C Attic Pod C Classrms				
2-135 190	Pod C Attic Pod C Classrms				
2-137 191	Pod C Attic Girls RR Hall				
2-137 192	Pod C Attic Boys RR Hall				
2-150 193	Pod C Attic Room C7				
2-015 222	Pod D Boys Restroom Hall				
2-016 223	Pod D Boys Restroom				
2-012 224	Pod D Girls Restroom Hall				
2-011 225	Pod D Girls Restroom				
2-010 226	Pod D PE Storage				
2-017 227	Pod D Custodial Room				
2-140 228	Pod D Attic Pod D Classrms				
2-140 229	Pod D Attic Pod D Classrms				
2-140 230	Pod D Attic Pod D Classrms				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-140 231	Pod D Attic Pod D Classrms				
2-140 232	Pod D Attic Pod D Classrms				
2-140 233	Pod D Attic Pod D Classrms				
2-140 234	Pod D Attic Pod D Classrms				
2-140 235	Pod D Attic Pod D Classrms				
2-140 236	Pod D Attic Pod D Classrms				
2-140 237	Pod D Attic Pod D Classrms				
2-143 238	Pod D Attic Boys RR Hall				
2-143 239	Pod D Attic Girls RR Hall				
2-148 261	Library Area Attic Library (near 2-061 smoke) middle library				
2-148 262	Library Area Attic Library				
2-148 263	Library Area Attic Library				
2-148 264	Library Area Attic Library				
2-148 265	Library Area Attic Library				
2-283 271	G Portables Classroom G1				
2-284 272	G Portables Classroom G2				
2-381 273	G Portables Attic Classroom G1				
2-381 274	G Portables Attic Classroom G1				
2-382 275	G Portables Attic Classroom G2				
2-382 276	G Portables Attic Classroom G2				
2-287 282	Discovery Club Classroom				
2-288 283	Discovery Club Storage				
2-286 284	Discovery Club Girls Restroom				
2-285 285	Discovery Club Boys Restroom				
2-380 286	Discovery Club Attic Discovery Club				
2-380 287	Discovery Club Attic Discovery Club				
2-380 288	Discovery Club Attic Discovery Club				
2-146 315	Multi-Purpose Bldg Boys Restroom				
2-146 316	Multi-Purpose Bldg Girls Restroom				
2-146 317	Multi-Purpose Bldg Custodial Room				
2-146 318	Multi-Purpose Bldg Kitchen				
2-146 319	Multi-Purpose Bldg Kitchen				
2-146 320	Multi-Purpose Bldg Fire Riser Room				
2-146 321	Multi-Purpose Bldg Stage Stairs East				
2-146 322	Multi-Purpose Bldg Stage Stairs East				
2-146 323	Multi-Purpose Bldg Attic Boys Restroom				
2-146 324	Multi-Purpose Bldg Attic Girls Restroom				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-146 325	Multi-Purpose Bldg Attic Restroom Hall				
2-146 326	Multi-Purpose Bldg Attic Kitchen				
2-146 327	Multi-Purpose Bldg Attic Kitchen				
2-146 328	Multi-Purpose Bldg Attic Kitchen				
2-146 329	Multi-Purpose Bldg Attic Fire Riser Room				
2-146 330	Multi-Purpose Bldg Attic Stage Stairs W				
2-146 331	Multi-Purpose Bldg Attic Stage Stairs E				
2-146 332	Multi-Purpose Bldg Attic Stage Stairs E				
2-281 034	Pod A Nurse Restroom				
2-276 035	Pod A Admin Womens RR				
2-275 036	Pod A Admin Mens RR				
2-271 037	Pod A Room A4				
2-270 038	Pod A Room A4A Closet				
2-256 039	Pod A Kinder PE Storage				
2-251 040	Pod A Room A6D				
2-255 041	Pod A Kindergarten RR				
2-252 042	Pod A Kindergarten RR				
2-048 043	Pod A A8A Elect Room				
2-273 044	Pod A Custodial Office A9A				
2-268 045	Pod A A11 Storage Room				
2-383 046	Pod A Attic Room A1				
2-383 047	Pod A Attic Room A7				
2-377 048	Pod A Attic Admin				
<b>Manual Pull Station</b>					
2-167 093	Pod B Classroom B1				
2-168 094	Pod B Classroom B2				
2-165 095	Pod B Rm B2 by Girls RR				
2-164 096	Pod B Rm B5 by Boys RR				
2-163 097	Pod B Classroom B5				
2-162 098	Pod B Classroom B6				
2-160 156	Pod C Classroom C1				
2-159 157	Pod C Classroom C2				
2-158 158	Pod C Rm C2 by Girls RR				
2-157 159	Pod C Rm C5 by Boys RR				
2-156 160	Pod C Classroom C5				
2-155 161	Pod C Classroom C6				
2-154 162	Pod C Room C7				
2-178 205	Pod D Classroom D1				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-177 206	Pod D Classroom D2				
2-174 207	Pod D Classroom D5				
2-175 208	Pod D Rm D5 by Boys RR				
2-173 209	Pod D Classroom D6				
2-176 210	Pod D Rm D8 by Girls RR				
2-172 252	Library Area Northeast Corner				
2-161 253	Library Area Southwest Corner				
2-170 269	G Portables Classroom G1				
2-169 270	G Portables Classroom G2				
2-194 280	Discovery Club F1 North Exit				
2-193 281	Discovery Club F1 South Exit				
2-181 293	Multi-Purpose Bldg MP Room Hall E2				
2-185 294	Multi-Purpose Bldg MP Room SW				
2-184 295	Multi-Purpose Bldg MP Room SE				
2-183 296	Multi-Purpose Bldg MP Room NE				
2-182 297	Multi-Purpose Bldg Kitchen				
2-376 002	Pod A Main Office				
2-171 003	Pod A Room A1				
2-192 004	Pod A Admin Office A2				
2-191 005	Pod A Classroom A3				
2-190 006	Pod A Classroom A4				
2-189 007	Pod A Classroom A5				
2-188 008	Pod A Classroom A6				
2-187 009	Pod A Classroom A6				
2-166 010	Pod A Cougar Cave A7				
Smoke Detector - General					
2-082 099	Pod B B2 Fire Doors				
2-051 100	Pod B Pod B Classrooms				
2-052 101	Pod B Pod B Classrooms				
2-047 102	Pod B Pod B Classrooms				
2-049 103	Pod B Pod B Classrooms				
2-044 104	Pod B Pod B Classrooms				
2-043 105	Pod B Pod B Classrooms				
2-046 106	Pod B Pod B Classrooms				
2-045 107	Pod B Pod B Classrooms				
2-050 108	Pod B Pod B Classrooms				
2-038 109	Pod B Room B8				
2-039 110	Pod B Room B8				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-057 111	Pod B Copier Room B12				
2-062 112	Pod B Speech Room B14				
2-032 163	Pod C Pod C Classrooms				
2-029 164	Pod C Pod C Classrooms				
2-026 165	Pod C Pod C Classrooms				
2-027 166	Pod C Pod C Classrooms				
2-028 167	Pod C Pod C Classrooms				
2-030 168	Pod C Pod C Classrooms				
2-031 169	Pod C Pod C Classrooms				
2-034 170	Pod C Pod C Classrooms				
2-033 171	Pod C Pod C Classrooms				
2-081 172	Pod C Room C7 The Box				
2-021 173	Pod C Room C10				
2-022 174	Pod C Room C10				
2-003 211	Pod D Pod D Classrooms				
2-002 212	Pod D Pod D Classrooms				
2-006 213	Pod D Pod D Classrooms				
2-005 214	Pod D Pod D Classrooms				
2-004 215	Pod D Pod D Classrooms				
2-009 216	Pod D Pod D Classrooms				
2-008 217	Pod D Pod D Classrooms				
2-007 218	Pod D Pod D Classrooms				
2-080 219	Pod D Pod D Classrooms				
2-014 220	Pod D Room D9				
2-013 221	Pod D Room D9				
2-060 254	Library Area Library				
2-059 255	Library Area Library				
2-058 256	Library Area Library				
2-061 257	Library Area Library				
2-053 258	Library Area Library				
2-054 259	Library Area Library				
2-063 260	Library Area Landing				
2-065 298	Multi-Purpose Bldg MP Room				
2-069 299	Multi-Purpose Bldg MP Room				
2-072 300	Multi-Purpose Bldg MP Room				
2-073 301	Multi-Purpose Bldg MP Room				
2-070 302	Multi-Purpose Bldg MP Room				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-067 303	Multi-Purpose Bldg MP Room				
2-074 304	Multi-Purpose Bldg MP Room				
2-064 305	Multi-Purpose Bldg MP Room				
2-066 306	Multi-Purpose Bldg MP Room				
2-068 307	Multi-Purpose Bldg MP Room				
2-071 308	Multi-Purpose Bldg MP Room				
2-075 309	Multi-Purpose Bldg MP Room				
2-079 310	Multi-Purpose Bldg Restroom Hallway				
2-078 311	Multi-Purpose Bldg Stage Stairway				
2-077 312	Multi-Purpose Bldg Stage				
2-076 313	Multi-Purpose Bldg Stage				
2-084 314	Multi-Purpose Bldg Storage Room E1A				
2-265 011	Pod A Room A1				
2-278 012	Pod A Main Office				
2-277 013	Pod A Principals Office				
2-272 014	Pod A Admin Storage				
2-280 015	Pod A Nurses Office				
2-279 016	Pod A Admin Work Room				
2-282 017	Pod A Faculty Break Room				
2-274 018	Pod A Hall by Faculty Room				
2-264 019	Pod A Speech Room A5				
2-259 020	Pod A Kindergarten A6				
2-258 021	Pod A Kindergarten A6				
2-254 022	Pod A Kindergarten A6				
2-253 023	Pod A Kindergarten A6				
2-257 024	Pod A Kindergarten A6				
2-263 025	Pod A Kindergarten Hallway				
2-262 026	Pod A Hall Outside A6				
2-269 027	Pod A Storage Room A9				
2-267 028	Pod A Hall by A10				
2-266 029	Pod A Computer Lab				
2-261 030	Pod A Computer Lab				
2-260 031	Pod A A8A Elect Room				
2-290 032	Pod A Cougar Cave A7				
2-289 033	Pod A Cougar Cave A7				
Smoke Detector - Duct					
2-147 333	Multi-Purpose Bldg Stage East				
Mechanical, Electrosonic, or Pressure Waterflow Device					

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-144 334	Multi-Purpose Bldg Westside of Stage				
	Valve Tamper Switch				
2-145 335	Multi-Purpose Bldg PIV NW Exterior				