

# Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

SCHWELTZER ALBERT ELEMENT

4350 GLENRIDGE DR  
CARMICHAEL, California  
United States

This site has been inspected and tested in compliance with applicable standards.

Completed

Tuesday, September 30, 2025

Test Session:29 Sep 2025 15:38 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD  
5320 HEMLOCK ST  
SACRAMENTO, California  
United States

TESTED BY

Riley Goyet  
Western States Fire Protection-  
Sacramento  
188 Cirby Way  
Roseville, CA 95678  
United States



# Inspection Summary

## Building Information

PROPERTY	SCHWELTZER ALBERT ELEMENT	CONTACT
ADDRESS	4350 GLENRIDGE DR	PHONE
CITY/STATE	CARMICHAEL, California	MOBILE
COUNTRY	United States	EMAIL

## Inspector Information

COMPANY	Western States Fire Protection- Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us

## Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Alarm Notification Appliance	73	73(100%)	73(100%)	0(0%)
Fire Control Panel	8	8(100%)	8(100%)	0(0%)
Initiating Device	175	175(100%)	175(100%)	0(0%)

## Certification

The equipment specified here in was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Tuesday, September 30, 2025

ACCEPTED BY      09/30/2025  
  
Building Representative

  
TESTED BY      09/30/2025  
Riley Goyet  
Technician

# System Details

## Control Units

ADDRESS/ SCAN ADDRESS

DESCRIPTION

Multi-Purpose Bldg MP  
Storage/Headend

MANUFACTURER

S/W VERSION

MODEL

LAST UPDATE

SERIAL NUMBER

S/W LOCATION

INSTALL DATE

# Open Corrective Action & Solution Summary

The following 1 corrective action(s) remain open following the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
NAC Power Extender Panel	132	Rooms 9-14 Bldg Electrical Room (Extender C)
	Created By:	Riley Goyet
	Creation Date:	09/29/2025
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	

# Testing Details

## Alarm Notification Appliance

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible	031	Admin/Library Bldg Admin Copy Room	Manual	9/29/2025 3:38:46 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	024	Admin/Library Bldg Computer Lab	Manual	9/29/2025 3:38:37 PM
		Visual inspection	Passed (Manual)	
Audible	020	Admin/Library Bldg East Exterior	Manual	9/29/2025 3:38:31 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	023	Admin/Library Bldg Library	Manual	9/29/2025 3:38:35 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	021	Admin/Library Bldg Lounge Admin Office	Manual	9/29/2025 3:38:32 PM
		Visual inspection	Passed (Manual)	
Visible	025	Admin/Library Bldg Mens Restroom	Manual	9/29/2025 3:38:38 PM
		Visual inspection	Passed (Manual)	
Visible	028	Admin/Library Bldg Nurse Office	Manual	9/29/2025 3:38:42 PM
		Visual inspection	Passed (Manual)	
Visible	029	Admin/Library Bldg Nurse Restroom	Manual	9/29/2025 3:38:43 PM
		Visual inspection	Passed (Manual)	
Visible	027	Admin/Library Bldg Principals Office	Manual	9/29/2025 3:38:41 PM
		Visual inspection	Passed (Manual)	
Visible	030	Admin/Library Bldg Reception	Manual	9/29/2025 3:38:45 PM
		Visual inspection	Passed (Manual)	
Visible	032	Admin/Library Bldg Speech Room	Manual	9/29/2025 3:38:47 PM
		Visual inspection	Passed (Manual)	
Visible	026	Admin/Library Bldg Womens Restroom	Manual	9/29/2025 3:38:39 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	022	Admin/Library Bldg WrkRm Admin Office	Manual	9/29/2025 3:38:34 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	246	Multi-Purpose Bldg Kitchen	Manual	9/29/2025 3:41:34 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	247	Multi-Purpose Bldg Kitchen	Manual	9/29/2025 3:41:37 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	244	Multi-Purpose Bldg MP Room	Manual	9/29/2025 3:41:31 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	245	Multi-Purpose Bldg MP Room	Manual	9/29/2025 3:41:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	242	Multi-Purpose Bldg North Exterior	Manual	9/29/2025 3:41:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	243	Multi-Purpose Bldg South Exterior	Manual	9/29/2025 3:41:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	249	Multi-Purpose Bldg Stage	Manual	9/29/2025 3:41:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	250	Multi-Purpose Bldg Stage	Manual	9/29/2025 3:41:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	251	Multi-Purpose Bldg Stage	Manual	9/29/2025 3:41:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	248	Multi-Purpose Bldg Storage Room	Manual	9/29/2025 3:41:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	207	Portables Classrm 19 Boys RR	Manual	9/29/2025 3:41:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	208	Portables Classrm 19 Girls RR	Manual	9/29/2025 3:41:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	209	Portables Classrm 20 Boys RR	Manual	9/29/2025 3:41:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	210	Portables Classrm 20 Girls RR	Manual	9/29/2025 3:41:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	205	Portables Classroom 19	Manual	9/29/2025 3:41:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	206	Portables Classroom 20	Manual	9/29/2025 3:41:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	204	Portables North Exterior Rm 20	Manual	9/29/2025 3:41:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	078	Rooms 1-8 Bldg Classroom 1	Manual	9/29/2025 3:38:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	079	Rooms 1-8 Bldg Classroom 2	Manual	9/29/2025 3:38:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	080	Rooms 1-8 Bldg Classroom 3	Manual	9/29/2025 3:38:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	092	Rooms 1-8 Bldg Classroom 3	Manual	9/29/2025 3:39:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	081	Rooms 1-8 Bldg Classroom 4	Manual	9/29/2025 3:38:55 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	082	Rooms 1-8 Bldg Classroom 5	Manual	9/29/2025 3:38:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	083	Rooms 1-8 Bldg Classroom 6	Manual	9/29/2025 3:38:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	084	Rooms 1-8 Bldg Classroom 7	Manual	9/29/2025 3:38:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	085	Rooms 1-8 Bldg Classroom 8	Manual	9/29/2025 3:39:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	086	Rooms 1-8 Bldg Rm 1 8 RR Entry	Manual	9/29/2025 3:39:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	087	Rooms 1-8 Bldg Rm 1 and 8 Restroom	Manual	9/29/2025 3:39:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	088	Rooms 1-8 Bldg Rm 1 and 8 Restroom	Manual	9/29/2025 3:39:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	089	Rooms 1-8 Bldg Rm 2 7 RR Entry	Manual	9/29/2025 3:39:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	090	Rooms 1-8 Bldg Rm 2 and 7 Restroom	Manual	9/29/2025 3:39:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	091	Rooms 1-8 Bldg Rm 2 and 7 Restroom	Manual	9/29/2025 3:39:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	093	Rooms 1-8 Bldg Rm 3 6 RR Entry	Manual	9/29/2025 3:39:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	094	Rooms 1-8 Bldg Rm 3 and 6 Restroom	Manual	9/29/2025 3:39:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	095	Rooms 1-8 Bldg Rm 3 and 6 Restroom	Manual	9/29/2025 3:39:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	096	Rooms 1-8 Bldg Rm 4 5 RR Entry	Manual	9/29/2025 3:39:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	097	Rooms 1-8 Bldg Rm 4 and 5 Restroom	Manual	9/29/2025 3:39:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	098	Rooms 1-8 Bldg Rm 4 and 5 Restroom	Manual	9/29/2025 3:39:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	077	Rooms 1-8 Bldg West Exterior	Manual	9/29/2025 3:38:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	180	Rooms 22-26 Bldg Boys Restroom	Manual	9/29/2025 3:41:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	175	Rooms 22-26 Bldg Classroom 22	Manual	9/29/2025 3:39:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	176	Rooms 22-26 Bldg Classroom 23	Manual	9/29/2025 3:39:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	177	Rooms 22-26 Bldg Classroom 24	Manual	9/29/2025 3:40:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	178	Rooms 22-26 Bldg Classroom 25	Manual	9/29/2025 3:41:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	179	Rooms 22-26 Bldg Classroom 26	Manual	9/29/2025 3:41:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	173	Rooms 22-26 Bldg East Exterior	Manual	9/29/2025 3:39:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	181	Rooms 22-26 Bldg Girls Restroom	Manual	9/29/2025 3:41:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	172	Rooms 22-26 Bldg North Exterior	Manual	9/29/2025 3:39:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	174	Rooms 22-26 Bldg South Exterior	Manual	9/29/2025 3:39:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	130	Rooms 9-14 Bldg Boys Restroom	Manual	9/29/2025 3:39:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	125	Rooms 9-14 Bldg Classroom 10	Manual	9/29/2025 3:39:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	126	Rooms 9-14 Bldg Classroom 11	Manual	9/29/2025 3:39:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	127	Rooms 9-14 Bldg Classroom 12	Manual	9/29/2025 3:39:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	128	Rooms 9-14 Bldg Classroom 13	Manual	9/29/2025 3:39:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	129	Rooms 9-14 Bldg Classroom 14	Manual	9/29/2025 3:39:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	124	Rooms 9-14 Bldg Classroom 9	Manual	9/29/2025 3:39:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	122	Rooms 9-14 Bldg East Exterior	Manual	9/29/2025 3:39:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	131	Rooms 9-14 Bldg Girls Restroom	Manual	9/29/2025 3:39:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	121	Rooms 9-14 Bldg North Exterior	Manual	9/29/2025 3:39:22 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	123	Rooms 9-14 Bldg West Exterior	Manual	9/29/2025 3:39:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

**Fire Control Panel**

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Remote Annunciator	001	Admin/Library Bldg Reception	Manual	9/29/2025 6:02:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Fire Alarm Panel		Multi-Purpose Bldg MP Storage/Headend	Manual	9/29/2025 5:15:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	254	Multi-Purpose Bldg MP Storage/Headend	Manual	9/29/2025 5:14:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	252	Multi-Purpose Bldg MP Storage/Headend - P.E. B	Manual	9/29/2025 5:15:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	253	Multi-Purpose Bldg MP Storage/Headend Master P/E	Manual	9/29/2025 5:13:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	182	Rooms 22-26 Bldg Electrical Room	Manual	9/29/2025 5:13:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	133	Rooms 9-14 Bldg Electrical Room	Manual	9/29/2025 5:14:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	132	Rooms 9-14 Bldg Electrical Room (Extender C)	Manual	9/29/2025 5:14:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

**Initiating Device**

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-028 012	Admin/Library Bldg Admin Copy Room	Manual	9/29/2025 4:08:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-032 009	Admin/Library Bldg Admin Off Work Rm	Manual	9/29/2025 4:13:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-037 004	Admin/Library Bldg Admin Office	Manual	9/29/2025 4:08:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-036 003	Admin/Library Bldg Admin Office	Manual	9/29/2025 4:08:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-039 006	Admin/Library Bldg Admin Office	Manual	9/29/2025 4:15:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-035 018	Admin/Library Bldg Computer Lab	Manual	9/29/2025 4:20:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-034 017	Admin/Library Bldg Computer Lab	Manual	9/29/2025 4:20:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-030 014	Admin/Library Bldg Library	Manual	9/29/2025 4:09:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-031 015	Admin/Library Bldg Library	Manual	9/29/2025 4:10:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-029 013	Admin/Library Bldg Library	Manual	9/29/2025 4:10:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-025 019	Admin/Library Bldg Lounge Admin Office	Manual	9/30/2025 4:04:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-023 010	Admin/Library Bldg Lounge Mens RR	Manual	9/29/2025 4:05:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-024 011	Admin/Library Bldg Lounge Womens RR	Manual	9/29/2025 4:03:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-026 007	Admin/Library Bldg Nurse Office	Manual	9/29/2025 4:14:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-027 008	Admin/Library Bldg Nurse Restroom	Manual	9/29/2025 5:58:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-038 005	Admin/Library Bldg Principals Office	Manual	9/29/2025 4:12:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-131 002	Admin/Library Bldg Reception	Manual	9/29/2025 6:02:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-033 016	Admin/Library Bldg Speech Room	Manual	9/29/2025 5:55:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-017 240	Multi-Purpose Bldg Janitors Closet	Manual	9/30/2025 4:13:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-021 237	Multi-Purpose Bldg Kitchen	Manual	9/30/2025 4:13:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-022 236	Multi-Purpose Bldg Kitchen	Manual	9/30/2025 4:13:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-018 239	Multi-Purpose Bldg Kitchen Office	Manual	9/30/2025 4:13:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-019 238	Multi-Purpose Bldg Kitchen Storage	Manual	9/30/2025 4:13:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-016 226	Multi-Purpose Bldg MP Room	Manual	9/29/2025 3:53:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-011 227	Multi-Purpose Bldg MP Room	Manual	9/29/2025 3:53:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-010 223	Multi-Purpose Bldg MP Room	Manual	9/29/2025 3:54:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-115 224	Multi-Purpose Bldg MP Room	Manual	9/29/2025 3:55:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-015 225	Multi-Purpose Bldg MP Room	Manual	9/29/2025 3:56:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-014 220	Multi-Purpose Bldg MP Room	Manual	9/29/2025 3:56:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-009 222	Multi-Purpose Bldg MP Room	Manual	9/29/2025 3:57:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-008 217	Multi-Purpose Bldg MP Room	Manual	9/29/2025 3:58:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-113 218	Multi-Purpose Bldg MP Room	Manual	9/29/2025 3:59:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-013 219	Multi-Purpose Bldg MP Room	Manual	9/29/2025 3:59:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-012 214	Multi-Purpose Bldg MP Room	Manual	9/29/2025 4:00:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-112 215	Multi-Purpose Bldg MP Room	Manual	9/29/2025 4:00:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-007 216	Multi-Purpose Bldg MP Room	Manual	9/29/2025 4:01:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-116 228	Multi-Purpose Bldg MP Room	Manual	9/29/2025 5:10:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-114 221	Multi-Purpose Bldg MP Room	Manual	9/29/2025 5:37:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-141 211	Multi-Purpose Bldg MP Room Northeast	Manual	9/29/2025 4:02:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-142 212	Multi-Purpose Bldg MP Room Northwest	Manual	9/29/2025 4:02:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-143 213	Multi-Purpose Bldg MP Room South	Manual	9/29/2025 4:02:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-076 233	Multi-Purpose Bldg MP Storage	Manual	9/29/2025 5:12:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-003 235	Multi-Purpose Bldg MP Storage/Headend	Manual	9/29/2025 4:17:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-002 234	Multi-Purpose Bldg MP Storage/Headend	Manual	9/29/2025 3:50:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-077 232	Multi-Purpose Bldg South Entrance	Manual	9/29/2025 6:00:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-005 230	Multi-Purpose Bldg Stage	Manual	9/29/2025 4:17:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-004 231	Multi-Purpose Bldg Stage	Manual	9/29/2025 4:17:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-006 229	Multi-Purpose Bldg Stage Entry	Manual	9/29/2025 4:16:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-130 241	Multi-Purpose Bldg Water Heater Closet	Manual	9/30/2025 4:13:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-376 197	Portables Attic Classroom 19	Manual	9/30/2025 4:03:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-376 198	Portables Attic Classroom 19	Manual	9/30/2025 4:03:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-376 199	Portables Attic Classroom 19	Manual	9/30/2025 4:03:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-377 200	Portables Attic Classroom 20	Manual	9/30/2025 4:04:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-377 202	Portables Attic Classroom 20	Manual	9/30/2025 4:04:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-377 201	Portables Attic Classroom 20	Manual	9/30/2025 4:04:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-264 196	Portables Boys Restroom	Manual	9/29/2025 5:05:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-256 189	Portables Boys Restroom	Manual	9/29/2025 5:08:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-253 187	Portables Classrm 19 Storage	Manual	9/29/2025 5:08:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-261 194	Portables Classrm 20 Storage	Manual	9/29/2025 5:05:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-252 185	Portables Classroom 19	Manual	9/29/2025 5:07:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-257 184	Portables Classroom 19	Manual	9/29/2025 5:07:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-265 186	Portables Classroom 19	Manual	9/29/2025 5:07:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-255 183	Portables Classroom 19	Manual	9/29/2025 5:37:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-258 192	Portables Classroom 20	Manual	9/29/2025 5:05:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-259 193	Portables Classroom 20	Manual	9/29/2025 5:05:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-262 191	Portables Classroom 20	Manual	9/29/2025 5:34:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-260 190	Portables Classroom 20	Manual	9/29/2025 5:35:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-263 195	Portables Girls Restroom	Manual	9/29/2025 5:05:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-254 188	Portables Girls Restroom	Manual	9/29/2025 5:08:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-378 203	Portables Water Heater Closet	Manual	9/30/2025 4:04:52 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-132 069	Rooms 1-8 Bldg Attic Classroom 1	Manual	9/30/2025 3:43:38 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-133 070	Rooms 1-8 Bldg Attic Classroom 2	Manual	9/30/2025 3:43:46 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-134 071	Rooms 1-8 Bldg Attic Classroom 3	Manual	9/30/2025 3:43:50 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-135 072	Rooms 1-8 Bldg Attic Classroom 4	Manual	9/30/2025 3:43:54 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-135 073	Rooms 1-8 Bldg Attic Classroom 5	Manual	9/30/2025 3:43:52 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-134 074	Rooms 1-8 Bldg Attic Classroom 6	Manual	9/30/2025 3:43:48 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-133 075	Rooms 1-8 Bldg Attic Classroom 7	Manual	9/30/2025 3:43:44 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-132 076	Rooms 1-8 Bldg Attic Classroom 8	Manual	9/30/2025 3:43:37 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-042 033	Rooms 1-8 Bldg Classroom 1	Manual	9/29/2025 4:22:02 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-040 035	Rooms 1-8 Bldg Classroom 1	Manual	9/29/2025 4:22:08 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-041 034	Rooms 1-8 Bldg Classroom 1	Manual	9/29/2025 4:22:17 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-049 041	Rooms 1-8 Bldg Classroom 2	Manual	9/29/2025 4:38:39 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-050 039	Rooms 1-8 Bldg Classroom 2	Manual	9/29/2025 4:39:00 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-051 040	Rooms 1-8 Bldg Classroom 2	Manual	9/29/2025 4:39:18 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-059 045	Rooms 1-8 Bldg Classroom 3	Manual	9/29/2025 4:27:05 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-060 046	Rooms 1-8 Bldg Classroom 3	Manual	9/29/2025 4:27:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-058 047	Rooms 1-8 Bldg Classroom 3	Manual	9/29/2025 4:35:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-068 051	Rooms 1-8 Bldg Classroom 4	Manual	9/29/2025 4:27:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-069 052	Rooms 1-8 Bldg Classroom 4	Manual	9/29/2025 4:28:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-067 053	Rooms 1-8 Bldg Classroom 4	Manual	9/29/2025 4:28:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-074 057	Rooms 1-8 Bldg Classroom 5	Manual	9/29/2025 4:30:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-075 058	Rooms 1-8 Bldg Classroom 5	Manual	9/29/2025 4:30:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-073 059	Rooms 1-8 Bldg Classroom 5	Manual	9/29/2025 4:31:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-065 060	Rooms 1-8 Bldg Classroom 6	Manual	9/29/2025 4:32:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-066 061	Rooms 1-8 Bldg Classroom 6	Manual	9/29/2025 4:32:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-064 062	Rooms 1-8 Bldg Classroom 6	Manual	9/29/2025 4:33:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-056 063	Rooms 1-8 Bldg Classroom 7	Manual	9/29/2025 4:37:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-057 064	Rooms 1-8 Bldg Classroom 7	Manual	9/29/2025 4:37:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-055 065	Rooms 1-8 Bldg Classroom 7	Manual	9/29/2025 4:37:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-046 068	Rooms 1-8 Bldg Classroom 8	Manual	9/29/2025 4:23:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-047 066	Rooms 1-8 Bldg Classroom 8	Manual	9/29/2025 4:24:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-048 067	Rooms 1-8 Bldg Classroom 8	Manual	9/29/2025 4:24:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-043 036	Rooms 1-8 Bldg Rm 1 8 RR Entry	Manual	9/29/2025 4:22:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-044 038	Rooms 1-8 Bldg Rm 1 Rm 8 RR	Manual	9/29/2025 4:23:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-045 037	Rooms 1-8 Bldg Rm 1 Rm 8 RR	Manual	9/29/2025 4:23:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-052 042	Rooms 1-8 Bldg Rm 2 7 RR Entry	Manual	9/29/2025 4:37:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-054 043	Rooms 1-8 Bldg Rm 2 Rm 7 RR	Manual	9/29/2025 4:38:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-053 044	Rooms 1-8 Bldg Rm 2 Rm 7 RR	Manual	9/29/2025 4:38:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-062 048	Rooms 1-8 Bldg Rm 3 6 RR Entry	Manual	9/29/2025 4:34:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-063 050	Rooms 1-8 Bldg Rm 3 Rm 6 RR	Manual	9/29/2025 4:34:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-061 049	Rooms 1-8 Bldg Rm 3 Rm 6 RR	Manual	9/29/2025 4:34:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-071 054	Rooms 1-8 Bldg Rm 4 5 RR Entry	Manual	9/29/2025 4:29:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-070 056	Rooms 1-8 Bldg Rm 4 Rm 5 RR	Manual	9/29/2025 4:29:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-072 055	Rooms 1-8 Bldg Rm 4 Rm 5 RR	Manual	9/29/2025 4:29:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-379 169	Rooms 22-26 Bldg Attic Boys Restroom	Manual	9/30/2025 4:03:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-381 148	Rooms 22-26 Bldg Attic Classroom 22	Manual	9/30/2025 4:03:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-381 149	Rooms 22-26 Bldg Attic Classroom 22	Manual	9/30/2025 4:03:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-381 151	Rooms 22-26 Bldg Attic Classroom 22	Manual	9/30/2025 4:03:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-381 150	Rooms 22-26 Bldg Attic Classroom 22	Manual	9/30/2025 4:03:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-382 155	Rooms 22-26 Bldg Attic Classroom 23	Manual	9/30/2025 4:03:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-382 154	Rooms 22-26 Bldg Attic Classroom 23	Manual	9/30/2025 4:03:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-382 153	Rooms 22-26 Bldg Attic Classroom 23	Manual	9/30/2025 4:03:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-382 152	Rooms 22-26 Bldg Attic Classroom 23	Manual	9/30/2025 4:03:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-384 157	Rooms 22-26 Bldg Attic Classroom 24	Manual	9/30/2025 4:03:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-384 156	Rooms 22-26 Bldg Attic Classroom 24	Manual	9/30/2025 4:03:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-384 158	Rooms 22-26 Bldg Attic Classroom 24	Manual	9/30/2025 4:03:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-384 159	Rooms 22-26 Bldg Attic Classroom 24	Manual	9/30/2025 4:03:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-387 160	Rooms 22-26 Bldg Attic Classroom 25	Manual	9/30/2025 4:03:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-387 161	Rooms 22-26 Bldg Attic Classroom 25	Manual	9/30/2025 4:03:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-387 162	Rooms 22-26 Bldg Attic Classroom 25	Manual	9/30/2025 4:03:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-387 163	Rooms 22-26 Bldg Attic Classroom 25	Manual	9/30/2025 4:03:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-388 164	Rooms 22-26 Bldg Attic Classroom 26	Manual	9/30/2025 4:04:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-388 166	Rooms 22-26 Bldg Attic Classroom 26	Manual	9/30/2025 4:04:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-388 165	Rooms 22-26 Bldg Attic Classroom 26	Manual	9/30/2025 4:04:03 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-388 167	Rooms 22-26 Bldg Attic Classroom 26	Manual	9/30/2025 4:04:04 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-380 171	Rooms 22-26 Bldg Attic Girls Restroom	Manual	9/30/2025 4:04:45 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-268 144	Rooms 22-26 Bldg Boys RR by Rm 24	Manual	9/29/2025 4:50:45 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-279 134	Rooms 22-26 Bldg Classroom 22	Manual	9/29/2025 4:53:55 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-278 135	Rooms 22-26 Bldg Classroom 22	Manual	9/29/2025 4:54:02 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-277 136	Rooms 22-26 Bldg Classroom 23	Manual	9/29/2025 4:52:49 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-276 137	Rooms 22-26 Bldg Classroom 23	Manual	9/29/2025 4:53:04 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-275 138	Rooms 22-26 Bldg Classroom 24	Manual	9/29/2025 4:51:14 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-274 139	Rooms 22-26 Bldg Classroom 24	Manual	9/29/2025 4:51:29 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-271 140	Rooms 22-26 Bldg Classroom 25	Manual	9/29/2025 4:58:03 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-270 141	Rooms 22-26 Bldg Classroom 25	Manual	9/29/2025 4:58:11 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-284 142	Rooms 22-26 Bldg Classroom 26	Manual	9/29/2025 4:55:41 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-283 143	Rooms 22-26 Bldg Classroom 26	Manual	9/29/2025 4:56:20 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-280 146	Rooms 22-26 Bldg Custodial Closet	Manual	9/29/2025 5:01:30 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-267 145	Rooms 22-26 Bldg E Strg By Rm 24	Manual	9/29/2025 5:02:14 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-296 147	Rooms 22-26 Bldg Girls RR by Rm 25	Manual	9/29/2025 6:05:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-379 168	Rooms 22-26 Bldg Plumbing Chase Boys	Manual	9/30/2025 4:03:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-380 170	Rooms 22-26 Bldg Plumbing Chase Girls	Manual	9/30/2025 4:04:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-082 119	Rooms 9-14 Bldg Boys RR by Rm 14	Manual	9/29/2025 4:44:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-087 103	Rooms 9-14 Bldg Classroom 10	Manual	9/29/2025 5:24:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-088 104	Rooms 9-14 Bldg Classroom 10	Manual	9/29/2025 5:24:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-086 102	Rooms 9-14 Bldg Classroom 10	Manual	9/29/2025 5:24:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-091 106	Rooms 9-14 Bldg Classroom 11	Manual	9/29/2025 5:26:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-089 105	Rooms 9-14 Bldg Classroom 11	Manual	9/29/2025 5:27:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-090 107	Rooms 9-14 Bldg Classroom 11	Manual	9/29/2025 5:35:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-100 109	Rooms 9-14 Bldg Classroom 12	Manual	9/29/2025 4:48:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-098 110	Rooms 9-14 Bldg Classroom 12	Manual	9/29/2025 4:49:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-099 108	Rooms 9-14 Bldg Classroom 12	Manual	9/29/2025 6:00:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-097 112	Rooms 9-14 Bldg Classroom 13	Manual	9/29/2025 4:46:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-096 111	Rooms 9-14 Bldg Classroom 13	Manual	9/29/2025 4:47:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-095 113	Rooms 9-14 Bldg Classroom 13	Manual	9/29/2025 4:47:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-094 114	Rooms 9-14 Bldg Classroom 14	Manual	9/29/2025 4:45:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-092 116	Rooms 9-14 Bldg Classroom 14	Manual	9/29/2025 4:45:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-093 115	Rooms 9-14 Bldg Classroom 14	Manual	9/29/2025 4:46:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-084 099	Rooms 9-14 Bldg Classroom 9	Manual	9/29/2025 5:20:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-085 100	Rooms 9-14 Bldg Classroom 9	Manual	9/29/2025 5:21:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-083 101	Rooms 9-14 Bldg Classroom 9	Manual	9/29/2025 5:21:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-079 118	Rooms 9-14 Bldg Custodial Office	Manual	9/29/2025 4:43:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-081 120	Rooms 9-14 Bldg Electrical Room	Manual	9/30/2025 4:04:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-080 117	Rooms 9-14 Bldg Girls RR by Rm 9	Manual	9/29/2025 4:42:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-269	RR By Rm 25	Manual	9/29/2025 5:00:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

## Device/Equipment details

### Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Audible					
020	Admin/Library Bldg East Exterior				
077	Rooms 1-8 Bldg West Exterior				
121	Rooms 9-14 Bldg North Exterior				
122	Rooms 9-14 Bldg East Exterior				
123	Rooms 9-14 Bldg West Exterior				
172	Rooms 22-26 Bldg North Exterior				
173	Rooms 22-26 Bldg East Exterior				
174	Rooms 22-26 Bldg South Exterior				
204	Portables North Exterior Rm 20				
242	Multi-Purpose Bldg North Exterior				
243	Multi-Purpose Bldg South Exterior				
Audible And Visible					
021	Admin/Library Bldg Lounge Admin Office				
022	Admin/Library Bldg WrkRm Admin Office				
023	Admin/Library Bldg Library				
024	Admin/Library Bldg Computer Lab				
078	Rooms 1-8 Bldg Classroom 1				
079	Rooms 1-8 Bldg Classroom 2				
080	Rooms 1-8 Bldg Classroom 3				
081	Rooms 1-8 Bldg Classroom 4				
082	Rooms 1-8 Bldg Classroom 5				
083	Rooms 1-8 Bldg Classroom 6				
084	Rooms 1-8 Bldg Classroom 7				
085	Rooms 1-8 Bldg Classroom 8				
124	Rooms 9-14 Bldg Classroom 9				
125	Rooms 9-14 Bldg Classroom 10				
126	Rooms 9-14 Bldg Classroom 11				
127	Rooms 9-14 Bldg Classroom 12				
128	Rooms 9-14 Bldg Classroom 13				
129	Rooms 9-14 Bldg Classroom 14				
175	Rooms 22-26 Bldg Classroom 22				
176	Rooms 22-26 Bldg Classroom 23				
177	Rooms 22-26 Bldg Classroom 24				
178	Rooms 22-26 Bldg Classroom 25				
179	Rooms 22-26 Bldg Classroom 26				
205	Portables Classroom 19				
206	Portables Classroom 20				
244	Multi-Purpose Bldg MP Room				
245	Multi-Purpose Bldg MP Room				
246	Multi-Purpose Bldg Kitchen				
247	Multi-Purpose Bldg Kitchen				
248	Multi-Purpose Bldg Storage Room				
Visible					
025	Admin/Library Bldg Mens Restroom				
026	Admin/Library Bldg Womens Restroom				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
027	Admin/Library Bldg Principals Office				
028	Admin/Library Bldg Nurse Office				
029	Admin/Library Bldg Nurse Restroom				
030	Admin/Library Bldg Reception				
031	Admin/Library Bldg Admin Copy Room				
032	Admin/Library Bldg Speech Room				
086	Rooms 1-8 Bldg Rm 1 8 RR Entry				
087	Rooms 1-8 Bldg Rm 1 and 8 Restroom				
088	Rooms 1-8 Bldg Rm 1 and 8 Restroom				
089	Rooms 1-8 Bldg Rm 2 7 RR Entry				
090	Rooms 1-8 Bldg Rm 2 and 7 Restroom				
091	Rooms 1-8 Bldg Rm 2 and 7 Restroom				
092	Rooms 1-8 Bldg Classroom 3				
093	Rooms 1-8 Bldg Rm 3 6 RR Entry				
094	Rooms 1-8 Bldg Rm 3 and 6 Restroom				
095	Rooms 1-8 Bldg Rm 3 and 6 Restroom				
096	Rooms 1-8 Bldg Rm 4 5 RR Entry				
097	Rooms 1-8 Bldg Rm 4 and 5 Restroom				
098	Rooms 1-8 Bldg Rm 4 and 5 Restroom				
130	Rooms 9-14 Bldg Boys Restroom				
131	Rooms 9-14 Bldg Girls Restroom				
180	Rooms 22-26 Bldg Boys Restroom				
181	Rooms 22-26 Bldg Girls Restroom				
207	Portables Classrm 19 Boys RR				
208	Portables Classrm 19 Girls RR				
209	Portables Classrm 20 Boys RR				
210	Portables Classrm 20 Girls RR				
249	Multi-Purpose Bldg Stage				
250	Multi-Purpose Bldg Stage				
251	Multi-Purpose Bldg Stage				

### Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Remote Annunciator					
001	Admin/Library Bldg Reception				
NAC Power Extender Panel					
132	Rooms 9-14 Bldg Electrical Room (Extender C)				
133	Rooms 9-14 Bldg Electrical Room				
182	Rooms 22-26 Bldg Electrical Room				
252	Multi-Purpose Bldg MP Storage/Headend - P.E. B				
253	Multi-Purpose Bldg MP Storage/Headend Master P/E				
254	Multi-Purpose Bldg MP Storage/Headend				

### Fire Alarm Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
	Multi-Purpose Bldg MP Storage/Headend				
<b>Initiating Device</b>					
ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Manual Pull Station					
2-131 002	Admin/Library Bldg Reception				
2-141 211	Multi-Purpose Bldg MP Room Northeast				
2-142 212	Multi-Purpose Bldg MP Room Northwest				
2-143 213	Multi-Purpose Bldg MP Room South				
Smoke Detector - General					
2-036 003	Admin/Library Bldg Admin Office				
2-037 004	Admin/Library Bldg Admin Office				
2-038 005	Admin/Library Bldg Principals Office				
2-039 006	Admin/Library Bldg Admin Office				
2-026 007	Admin/Library Bldg Nurse Office				
2-027 008	Admin/Library Bldg Nurse Restroom				
2-032 009	Admin/Library Bldg Admin Off Work Rm				
2-023 010	Admin/Library Bldg Lounge Mens RR				
2-024 011	Admin/Library Bldg Lounge Womens RR				
2-028 012	Admin/Library Bldg Admin Copy Room				
2-029 013	Admin/Library Bldg Library				
2-030 014	Admin/Library Bldg Library				
2-031 015	Admin/Library Bldg Library				
2-033 016	Admin/Library Bldg Speech Room				
2-034 017	Admin/Library Bldg Computer Lab				
2-035 018	Admin/Library Bldg Computer Lab				
2-042 033	Rooms 1-8 Bldg Classroom 1				
2-041 034	Rooms 1-8 Bldg Classroom 1				
2-040 035	Rooms 1-8 Bldg Classroom 1				
2-043 036	Rooms 1-8 Bldg Rm 1 8 RR Entry				
2-045 037	Rooms 1-8 Bldg Rm 1 Rm 8 RR				
2-044 038	Rooms 1-8 Bldg Rm 1 Rm 8 RR				
2-050 039	Rooms 1-8 Bldg Classroom 2				
2-051 040	Rooms 1-8 Bldg Classroom 2				
2-049 041	Rooms 1-8 Bldg Classroom 2				
2-052 042	Rooms 1-8 Bldg Rm 2 7 RR Entry				
2-054 043	Rooms 1-8 Bldg Rm 2 Rm 7 RR				
2-053 044	Rooms 1-8 Bldg Rm 2 Rm 7 RR				
2-059 045	Rooms 1-8 Bldg Classroom 3				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-060 046	Rooms 1-8 Bldg Classroom 3				
2-058 047	Rooms 1-8 Bldg Classroom 3				
2-062 048	Rooms 1-8 Bldg Rm 3 6 RR Entry				
2-061 049	Rooms 1-8 Bldg Rm 3 Rm 6 RR				
2-063 050	Rooms 1-8 Bldg Rm 3 Rm 6 RR				
2-068 051	Rooms 1-8 Bldg Classroom 4				
2-069 052	Rooms 1-8 Bldg Classroom 4				
2-067 053	Rooms 1-8 Bldg Classroom 4				
2-071 054	Rooms 1-8 Bldg Rm 4 5 RR Entry				
2-072 055	Rooms 1-8 Bldg Rm 4 Rm 5 RR				
2-070 056	Rooms 1-8 Bldg Rm 4 Rm 5 RR				
2-074 057	Rooms 1-8 Bldg Classroom 5				
2-075 058	Rooms 1-8 Bldg Classroom 5				
2-073 059	Rooms 1-8 Bldg Classroom 5				
2-065 060	Rooms 1-8 Bldg Classroom 6				
2-066 061	Rooms 1-8 Bldg Classroom 6				
2-064 062	Rooms 1-8 Bldg Classroom 6				
2-056 063	Rooms 1-8 Bldg Classroom 7				
2-057 064	Rooms 1-8 Bldg Classroom 7				
2-055 065	Rooms 1-8 Bldg Classroom 7				
2-047 066	Rooms 1-8 Bldg Classroom 8				
2-048 067	Rooms 1-8 Bldg Classroom 8				
2-046 068	Rooms 1-8 Bldg Classroom 8				
2-084 099	Rooms 9-14 Bldg Classroom 9				
2-085 100	Rooms 9-14 Bldg Classroom 9				
2-083 101	Rooms 9-14 Bldg Classroom 9				
2-086 102	Rooms 9-14 Bldg Classroom 10				
2-087 103	Rooms 9-14 Bldg Classroom 10				
2-088 104	Rooms 9-14 Bldg Classroom 10				
2-089 105	Rooms 9-14 Bldg Classroom 11				
2-091 106	Rooms 9-14 Bldg Classroom 11				
2-090 107	Rooms 9-14 Bldg Classroom 11				
2-099 108	Rooms 9-14 Bldg Classroom 12				
2-100 109	Rooms 9-14 Bldg Classroom 12				
2-098 110	Rooms 9-14 Bldg Classroom 12				
2-096 111	Rooms 9-14 Bldg Classroom 13				
2-097 112	Rooms 9-14 Bldg Classroom 13				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-095 113	Rooms 9-14 Bldg Classroom 13				
2-094 114	Rooms 9-14 Bldg Classroom 14				
2-093 115	Rooms 9-14 Bldg Classroom 14				
2-092 116	Rooms 9-14 Bldg Classroom 14				
2-080 117	Rooms 9-14 Bldg Girls RR by Rm 9				
2-079 118	Rooms 9-14 Bldg Custodial Office				
2-082 119	Rooms 9-14 Bldg Boys RR by Rm 14				
2-279 134	Rooms 22-26 Bldg Classroom 22				
2-278 135	Rooms 22-26 Bldg Classroom 22				
2-277 136	Rooms 22-26 Bldg Classroom 23				
2-276 137	Rooms 22-26 Bldg Classroom 23				
2-275 138	Rooms 22-26 Bldg Classroom 24				
2-274 139	Rooms 22-26 Bldg Classroom 24				
2-271 140	Rooms 22-26 Bldg Classroom 25				
2-270 141	Rooms 22-26 Bldg Classroom 25				
2-284 142	Rooms 22-26 Bldg Classroom 26				
2-283 143	Rooms 22-26 Bldg Classroom 26				
2-268 144	Rooms 22-26 Bldg Boys RR by Rm 24				
2-267 145	Rooms 22-26 Bldg E Strg By Rm 24				
2-280 146	Rooms 22-26 Bldg Custodial Closet				
2-296 147	Rooms 22-26 Bldg Girls RR by Rm 25				
2-255 183	Portables Classroom 19				
2-257 184	Portables Classroom 19				
2-252 185	Portables Classroom 19				
2-265 186	Portables Classroom 19				
2-253 187	Portables Classrm 19 Storage				
2-254 188	Portables Girls Restroom				
2-256 189	Portables Boys Restroom				
2-260 190	Portables Classroom 20				
2-262 191	Portables Classroom 20				
2-258 192	Portables Classroom 20				
2-259 193	Portables Classroom 20				
2-261 194	Portables Classrm 20 Storage				
2-263 195	Portables Girls Restroom				
2-264 196	Portables Boys Restroom				
2-012 214	Multi-Purpose Bldg MP Room				
2-112 215	Multi-Purpose Bldg MP Room				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-007 216	Multi-Purpose Bldg MP Room				
2-008 217	Multi-Purpose Bldg MP Room				
2-113 218	Multi-Purpose Bldg MP Room				
2-013 219	Multi-Purpose Bldg MP Room				
2-014 220	Multi-Purpose Bldg MP Room				
2-114 221	Multi-Purpose Bldg MP Room				
2-009 222	Multi-Purpose Bldg MP Room				
2-010 223	Multi-Purpose Bldg MP Room				
2-115 224	Multi-Purpose Bldg MP Room				
2-015 225	Multi-Purpose Bldg MP Room				
2-016 226	Multi-Purpose Bldg MP Room				
2-011 227	Multi-Purpose Bldg MP Room				
2-116 228	Multi-Purpose Bldg MP Room				
2-006 229	Multi-Purpose Bldg Stage Entry				
2-005 230	Multi-Purpose Bldg Stage				
2-004 231	Multi-Purpose Bldg Stage				
2-077 232	Multi-Purpose Bldg South Entrance				
2-076 233	Multi-Purpose Bldg MP Storage				
2-002 234	Multi-Purpose Bldg MP Storage/Headend				
2-269	RR By Rm 25				
Heat Detector - Restorable Spot					
2-025 019	Admin/Library Bldg Lounge Admin Office				
2-132 069	Rooms 1-8 Bldg Attic Classroom 1				
2-133 070	Rooms 1-8 Bldg Attic Classroom 2				
2-134 071	Rooms 1-8 Bldg Attic Classroom 3				
2-135 072	Rooms 1-8 Bldg Attic Classroom 4				
2-135 073	Rooms 1-8 Bldg Attic Classroom 5				
2-134 074	Rooms 1-8 Bldg Attic Classroom 6				
2-133 075	Rooms 1-8 Bldg Attic Classroom 7				
2-132 076	Rooms 1-8 Bldg Attic Classroom 8				
2-081 120	Rooms 9-14 Bldg Electrical Room				
2-381 148	Rooms 22-26 Bldg Attic Classroom 22				
2-381 149	Rooms 22-26 Bldg Attic Classroom 22				
2-381 150	Rooms 22-26 Bldg Attic Classroom 22				
2-381 151	Rooms 22-26 Bldg Attic Classroom 22				
2-382 152	Rooms 22-26 Bldg Attic Classroom 23				
2-382 153	Rooms 22-26 Bldg Attic Classroom 23				
2-382 154	Rooms 22-26 Bldg Attic Classroom 23				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-382 155	Rooms 22-26 Bldg Attic Classroom 23				
2-384 156	Rooms 22-26 Bldg Attic Classroom 24				
2-384 157	Rooms 22-26 Bldg Attic Classroom 24				
2-384 158	Rooms 22-26 Bldg Attic Classroom 24				
2-384 159	Rooms 22-26 Bldg Attic Classroom 24				
2-387 160	Rooms 22-26 Bldg Attic Classroom 25				
2-387 161	Rooms 22-26 Bldg Attic Classroom 25				
2-387 162	Rooms 22-26 Bldg Attic Classroom 25				
2-387 163	Rooms 22-26 Bldg Attic Classroom 25				
2-388 164	Rooms 22-26 Bldg Attic Classroom 26				
2-388 165	Rooms 22-26 Bldg Attic Classroom 26				
2-388 166	Rooms 22-26 Bldg Attic Classroom 26				
2-388 167	Rooms 22-26 Bldg Attic Classroom 26				
2-379 168	Rooms 22-26 Bldg Plumbing Chase Boys				
2-379 169	Rooms 22-26 Bldg Attic Boys Restroom				
2-380 170	Rooms 22-26 Bldg Plumbing Chase Girls				
2-380 171	Rooms 22-26 Bldg Attic Girls Restroom				
2-376 197	Portables Attic Classroom 19				
2-376 198	Portables Attic Classroom 19				
2-376 199	Portables Attic Classroom 19				
2-377 200	Portables Attic Classroom 20				
2-377 201	Portables Attic Classroom 20				
2-377 202	Portables Attic Classroom 20				
2-378 203	Portables Water Heater Closet				
2-003 235	Multi-Purpose Bldg MP Storage/Headend				
2-022 236	Multi-Purpose Bldg Kitchen				
2-021 237	Multi-Purpose Bldg Kitchen				
2-019 238	Multi-Purpose Bldg Kitchen Storage				
2-018 239	Multi-Purpose Bldg Kitchen Office				
2-017 240	Multi-Purpose Bldg Janitors Closet				
2-130 241	Multi-Purpose Bldg Water Heater Closet				