

# Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

OAKVIEW ELEMENTARY

7229 BEACH AVE  
ORANGEVALE, California 95662  
United States

This site has been inspected and tested in compliance with applicable standards.

Completed

Thursday, October 09, 2025

Test Session:30 Sep 2025 16:48 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD  
5320 HEMLOCK ST  
SACRAMENTO, California  
United States

TESTED BY

Riley Goyet  
Western States Fire Protection-  
Sacramento  
188 Cirby Way  
Roseville, CA 95678  
United States



# Inspection Summary

## Building Information

PROPERTY	OAKVIEW ELEMENTARY	CONTACT
ADDRESS	7229 BEACH AVE	PHONE
CITY/STATE	ORANGEVALE, California 95662	MOBILE
COUNTRY	United States	EMAIL

## Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us

## Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Alarm Notification Appliance	74	74(100%)	74(100%)	0(0%)
Fire Control Panel	6	6(100%)	1(17%)	5(83%)
Initiating Device	171	171(100%)	171(100%)	0(0%)

## Certification

The equipment specified here in was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Thursday, October 09, 2025

ACCEPTED BY      10/09/2025  
  
Building Representative

  
TESTED BY      10/09/2025  
Riley Goyet  
Technician

# System Details

## Control Units

ADDRESS/ SCAN ADDRESS		DESCRIPTION	Rooms 7-12 Bldg Room 12A Headend
MANUFACTURER	EST	S/W VERSION	
MODEL	3	LAST UPDATE	
SERIAL NUMBER		S/W LOCATION	
INSTALL DATE			

# Open Corrective Action & Solution Summary

The following 6 corrective action(s) remain open following the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
Fire Alarm Panel		Rooms 7-12 Bldg Room 12A Headend
	Created By:	Riley Goyet
	Creation Date:	01/06/2022
	Corrective Action:	Replace (2) 12V 55AH Duracell ultra Deep Cycle Batteries
	Proposed Solution:	
	Manufacturer:	EST
	Model:	3
	Created By:	Hobart Kuebler
	Creation Date:	10/11/2022
	Corrective Action:	Replace (2) 12V 55AH
	Proposed Solution:	
	Manufacturer:	EST
	Model:	3
NAC Power Extender Panel		Rooms 7-12 Bldg Room 12A - P.E. "Master"
	Created By:	Riley Goyet
	Creation Date:	09/30/2025
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
NAC Power Extender Panel		Rooms 7-12 Bldg Room 12A - P.E. "C"
	Created By:	Riley Goyet
	Creation Date:	09/30/2025
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
NAC Power Extender Panel		Rooms 7-12 Bldg Room 12A - P.E. "E"
	Created By:	Riley Goyet
	Creation Date:	09/30/2025
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
NAC Power Extender Panel		Rooms 13-18 Bldg Cust Rm by Rm 13 - P.E. "B"
	Created By:	Riley Goyet
	Creation Date:	09/30/2025
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	

# Testing Details

## Alarm Notification Appliance

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible	015	Admin Bldg East Exterior	Manual	9/30/2025 4:50:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	020	Admin Bldg Nurse Restroom	Manual	9/30/2025 4:51:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	017	Admin Bldg Nurse Room	Manual	9/30/2025 4:49:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	019	Admin Bldg Principals Office	Manual	9/30/2025 4:51:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	016	Admin Bldg Reception	Manual	9/30/2025 4:49:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	022	Admin Bldg Staff Restroom	Manual	9/30/2025 4:51:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	021	Admin Bldg Student Restroom	Manual	9/30/2025 4:51:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	018	Admin Bldg Work Room MDF	Manual	9/30/2025 4:49:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	043	Kindergarten Bldg Kindergarten A	Manual	9/30/2025 4:49:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	046	Kindergarten Bldg Kindergarten A RR	Manual	9/30/2025 4:51:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	045	Kindergarten Bldg Kindergarten A/B Hall	Manual	9/30/2025 4:49:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	044	Kindergarten Bldg Kindergarten B	Manual	9/30/2025 4:49:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	047	Kindergarten Bldg Kindergarten B RR	Manual	9/30/2025 4:51:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	042	Kindergarten Bldg South Exterior	Manual	9/30/2025 4:50:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	243	Multi-Purpose Bldg Head Custodian Off	Manual	9/30/2025 4:50:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	244	Multi-Purpose Bldg Kitchen	Manual	9/30/2025 4:50:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	245	Multi-Purpose Bldg Kitchen	Manual	9/30/2025 4:50:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	246	Multi-Purpose Bldg Kitchen Restroom	Manual	9/30/2025 4:51:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	240	Multi-Purpose Bldg MP Room	Manual	9/30/2025 4:50:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	241	Multi-Purpose Bldg MP Room	Manual	9/30/2025 4:50:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	242	Multi-Purpose Bldg Stage	Manual	9/30/2025 4:50:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	239	Multi-Purpose Bldg West Exterior	Manual	9/30/2025 4:50:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	205	Portables Classroom 19	Manual	9/30/2025 4:50:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	206	Portables Classroom 20	Manual	9/30/2025 4:50:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	207	Portables Classroom 21	Manual	9/30/2025 4:50:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	208	Portables Classroom 22	Manual	9/30/2025 4:50:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	209	Portables Classroom 23	Manual	9/30/2025 4:50:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	210	Portables Classroom 24	Manual	9/30/2025 4:50:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	212	Portables Classroom 25	Manual	9/30/2025 4:50:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	211	Portables Classroom 25	Manual	9/30/2025 4:50:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	202	Portables North Exterior	Manual	9/30/2025 4:50:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	203	Portables North Exterior	Manual	9/30/2025 4:50:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	204	Portables North Exterior	Manual	9/30/2025 4:50:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	156	Rooms 13-18 Bldg Boys Restroom	Manual	9/30/2025 4:51:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	157	Rooms 13-18 Bldg Boys Restroom	Manual	9/30/2025 4:51:42 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	149	Rooms 13-18 Bldg Classroom 13	Manual	9/30/2025 4:50:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	150	Rooms 13-18 Bldg Classroom 14	Manual	9/30/2025 4:50:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	151	Rooms 13-18 Bldg Classroom 15	Manual	9/30/2025 4:50:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	152	Rooms 13-18 Bldg Classroom 16	Manual	9/30/2025 4:50:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	153	Rooms 13-18 Bldg Classroom 17	Manual	9/30/2025 4:50:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	154	Rooms 13-18 Bldg Classroom 18	Manual	9/30/2025 4:50:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	159	Rooms 13-18 Bldg Cust Rm by Rm 13	Manual	9/30/2025 4:51:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	146	Rooms 13-18 Bldg East Exterior	Manual	9/30/2025 4:50:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	158	Rooms 13-18 Bldg Girls Restroom	Manual	9/30/2025 4:51:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	155	Rooms 13-18 Bldg Room 16A	Manual	9/30/2025 4:51:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	147	Rooms 13-18 Bldg South Exterior	Manual	9/30/2025 4:50:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	148	Rooms 13-18 Bldg West Exterior	Manual	9/30/2025 4:50:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	083	Rooms 1-6 Bldg Boys Restroom	Manual	9/30/2025 4:51:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	084	Rooms 1-6 Bldg Boys Restroom	Manual	9/30/2025 4:51:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	076	Rooms 1-6 Bldg Classroom 1	Manual	9/30/2025 4:49:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	077	Rooms 1-6 Bldg Classroom 2	Manual	9/30/2025 4:49:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	078	Rooms 1-6 Bldg Classroom 3	Manual	9/30/2025 4:49:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	079	Rooms 1-6 Bldg Classroom 4	Manual	9/30/2025 4:49:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	080	Rooms 1-6 Bldg Classroom 5	Manual	9/30/2025 4:49:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	081	Rooms 1-6 Bldg Classroom 6	Manual	9/30/2025 4:49:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	085	Rooms 1-6 Bldg Custodial Room	Manual	9/30/2025 4:51:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	073	Rooms 1-6 Bldg East Exterior	Manual	9/30/2025 4:50:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	086	Rooms 1-6 Bldg Girls Restroom	Manual	9/30/2025 4:51:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	082	Rooms 1-6 Bldg Room 3A	Manual	9/30/2025 4:51:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	074	Rooms 1-6 Bldg South Exterior	Manual	9/30/2025 4:50:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	075	Rooms 1-6 Bldg West Exterior	Manual	9/30/2025 4:50:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	120	Rooms 7-12 Bldg Boys RR 7-12 Wing	Manual	9/30/2025 4:51:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	121	Rooms 7-12 Bldg Boys RR 7-12 Wing	Manual	9/30/2025 4:51:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	116	Rooms 7-12 Bldg Classroom 10	Manual	9/30/2025 4:50:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	117	Rooms 7-12 Bldg Classroom 11	Manual	9/30/2025 4:50:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	118	Rooms 7-12 Bldg Classroom 12	Manual	9/30/2025 4:50:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	114	Rooms 7-12 Bldg Classroom 8	Manual	9/30/2025 4:49:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	115	Rooms 7-12 Bldg Classroom 9	Manual	9/30/2025 4:50:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	110	Rooms 7-12 Bldg East Exterior	Manual	9/30/2025 4:50:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	122	Rooms 7-12 Bldg Girls RR 7-12 Wing	Manual	9/30/2025 4:51:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	113	Rooms 7-12 Bldg Room 7 Staff	Manual	9/30/2025 4:51:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	111	Rooms 7-12 Bldg South Exterior	Manual	9/30/2025 4:50:46 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	119	Rooms 7-12 Bldg Storage Room 9A	Manual	9/30/2025 4:51:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	112	Rooms 7-12 Bldg West Exterior	Manual	9/30/2025 4:50:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

### Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Remote Annunciator	001	Admin Bldg Reception	Manual	9/30/2025 7:34:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Failed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
NAC Power Extender Panel		Rooms 13-18 Bldg Cust Rm by Rm 13 - P.E. "B"	Manual	9/30/2025 7:38:18 PM
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	
NAC Power Extender Panel		Rooms 7-12 Bldg Room 12A - P.E. "C"	Manual	9/30/2025 7:35:52 PM
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	
NAC Power Extender Panel		Rooms 7-12 Bldg Room 12A - P.E. "E"	Manual	9/30/2025 7:36:08 PM
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	
NAC Power Extender Panel		Rooms 7-12 Bldg Room 12A - P.E. "Master"	Manual	9/30/2025 7:35:14 PM
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	
Fire Alarm Panel		Rooms 7-12 Bldg Room 12A Headend	Manual	9/30/2025 7:34:43 PM
		Manufacturer	EST	
		Model	3	
		Visual inspection	Failed (Manual)	

### Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-056 006	Admin Bldg Front Area-Reception	Manual	9/30/2025 8:24:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-051 012	Admin Bldg Nurse Restroom	Manual	9/30/2025 6:57:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-161 004	Admin Bldg Nurse Room	Manual	9/30/2025 8:31:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-052 007	Admin Bldg Nurse Room	Manual	9/30/2025 8:24:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-057 010	Admin Bldg Office Closet	Manual	9/30/2025 8:31:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-054 008	Admin Bldg Office Closet	Manual	9/30/2025 8:37:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-058 011	Admin Bldg Principals Office	Manual	9/30/2025 8:31:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-160 003	Admin Bldg Reception	Manual	9/30/2025 8:25:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-126 002	Admin Bldg Reception	Manual	9/30/2025 8:29:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-050 014	Admin Bldg Staff Restroom	Manual	9/30/2025 6:56:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-053 013	Admin Bldg Student Restroom	Manual	9/30/2025 6:55:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-162 005	Admin Bldg Work Room MDF	Manual	9/30/2025 8:28:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-055 009	Admin Bldg Work Room MDF	Manual	9/30/2025 8:27:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-164 025	Kindergarten Bldg Kinder A/B Hall East	Manual	9/30/2025 7:58:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-165 026	Kindergarten Bldg Kinder A/B Hall West	Manual	9/30/2025 9:29:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-163 023	Kindergarten Bldg Kindergarten A	Manual	9/30/2025 8:02:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-034 027	Kindergarten Bldg Kindergarten A	Manual	9/30/2025 7:56:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-032 028	Kindergarten Bldg Kindergarten A	Manual	9/30/2025 7:56:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-033 030	Kindergarten Bldg Kindergarten A	Manual	9/30/2025 7:56:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-031 029	Kindergarten Bldg Kindergarten A	Manual	9/30/2025 7:56:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-029 031	Kindergarten Bldg Kindergarten A RR	Manual	9/30/2025 7:57:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-030 040	Kindergarten Bldg Kindergarten A Storage	Manual	9/30/2025 8:44:19 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-028 037	Kindergarten Bldg Kindergarten A/B Hall	Manual	9/30/2025 7:57:35 PM
		Functional Inspection	Passed	
Smoke Detector - General	2-027 038	Kindergarten Bldg Kindergarten A/B Hall	Manual	9/30/2025 7:57:56 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-026 039	Kindergarten Bldg Kindergarten A/B Hall	Manual	9/30/2025 7:58:10 PM
		Functional Inspection	Passed	
Manual Pull Station	2-166 024	Kindergarten Bldg Kindergarten B	Manual	9/30/2025 8:00:53 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-023 032	Kindergarten Bldg Kindergarten B	Manual	9/30/2025 7:59:05 PM
		Functional Inspection	Passed	
Smoke Detector - General	2-035 033	Kindergarten Bldg Kindergarten B	Manual	9/30/2025 7:59:38 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-022 035	Kindergarten Bldg Kindergarten B	Manual	9/30/2025 7:59:57 PM
		Functional Inspection	Passed	
Smoke Detector - General	2-036 034	Kindergarten Bldg Kindergarten B	Manual	9/30/2025 8:00:16 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-025 036	Kindergarten Bldg Kindergarten B RR	Manual	9/30/2025 7:58:33 PM
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-024 041	Kindergarten Bldg Kindergarten B Storage	Manual	9/30/2025 8:32:09 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	2-378 238	Multi-Purpose Bldg Attic Kitchen	Manual	9/30/2025 8:32:18 PM
		Functional Inspection	Passed	
Smoke Detector - General	2-251 228	Multi-Purpose Bldg Head Custodian Office	Manual	9/30/2025 7:50:19 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	2-266 233	Multi-Purpose Bldg Kitchen	Manual	9/30/2025 6:47:37 PM
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-265 232	Multi-Purpose Bldg Kitchen	Manual	9/30/2025 6:52:20 PM
		Visual inspection	Passed (Manual)	
Manual Pull Station	2-384 217	Multi-Purpose Bldg Kitchen	Manual	9/30/2025 6:46:53 PM
		Functional Inspection	Passed	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-268 235	Multi-Purpose Bldg Kitchen Restroom	Manual	9/30/2025 6:49:31 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-267 234	Multi-Purpose Bldg Kitchen Storage	Manual	9/30/2025 6:51:16 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-258 224	Multi-Purpose Bldg MP Room	Manual	9/30/2025 7:48:15 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-259 225	Multi-Purpose Bldg MP Room	Manual	9/30/2025 7:48:21 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-257 221	Multi-Purpose Bldg MP Room	Manual	9/30/2025 7:48:40 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-256 223	Multi-Purpose Bldg MP Room	Manual	9/30/2025 7:48:52 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-254 222	Multi-Purpose Bldg MP Room	Manual	9/30/2025 7:49:04 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-255 220	Multi-Purpose Bldg MP Room	Manual	9/30/2025 7:49:19 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-253 219	Multi-Purpose Bldg MP Room	Manual	9/30/2025 7:49:34 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-252 218	Multi-Purpose Bldg MP Room	Manual	9/30/2025 7:49:52 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Manual Pull Station	2-380 213	Multi-Purpose Bldg MP Room NW	Manual	9/30/2025 6:39:44 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Manual Pull Station	2-383 215	Multi-Purpose Bldg MP Room SE	Manual	9/30/2025 6:34:47 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Manual Pull Station	2-381 214	Multi-Purpose Bldg MP Room SW	Manual	9/30/2025 6:40:29 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-271 236	Multi-Purpose Bldg O/S Kitchen Storage	Manual	9/30/2025 6:46:06 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-269 237	Multi-Purpose Bldg O/S Wtr Htr Closet	Manual	9/30/2025 6:38:50 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Manual Pull Station	2-382 216	Multi-Purpose Bldg Stage	Manual	9/30/2025 6:40:47 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-260 227	Multi-Purpose Bldg Stage	Manual	9/30/2025 7:51:31 PM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-261 226	Multi-Purpose Bldg Stage	Manual	9/30/2025 7:51:46 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	2-263 230	Multi-Purpose Bldg Stage Closet North	Manual	9/30/2025 9:28:58 PM
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-262 231	Multi-Purpose Bldg Stage Closet South	Manual	9/30/2025 6:41:53 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	2-264 229	Multi-Purpose Bldg Stage Stairs	Manual	9/30/2025 8:32:14 PM
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-137 190	Portables Attic Classroom 21	Manual	9/30/2025 9:29:06 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	2-137 189	Portables Attic Classroom 21	Manual	9/30/2025 9:29:07 PM
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-138 191	Portables Attic Classroom 22	Manual	9/30/2025 9:29:03 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	2-138 192	Portables Attic Classroom 22	Manual	9/30/2025 9:29:04 PM
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-139 193	Portables Attic Classroom 23	Manual	9/30/2025 9:29:00 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	2-139 194	Portables Attic Classroom 23	Manual	9/30/2025 9:29:02 PM
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-140 195	Portables Attic Classroom 24	Manual	9/30/2025 9:29:16 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	2-140 196	Portables Attic Classroom 24	Manual	9/30/2025 9:29:18 PM
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-141 198	Portables Attic Classroom 25	Manual	9/30/2025 9:29:19 PM
		Visual inspection	Passed (Manual)	
Heat Detector - Restorable Spot	2-141 197	Portables Attic Classroom 25	Manual	9/30/2025 9:29:21 PM
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-127 186	Portables Attic Rm 19 Media Center	Manual	9/30/2025 9:29:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-127 185	Portables Attic Rm 19 Media Center	Manual	9/30/2025 9:29:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-127 184	Portables Attic Rm 19 Media Center	Manual	9/30/2025 9:29:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-128 187	Portables Attic Rm 20 Tech Lab	Manual	9/30/2025 9:29:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-128 188	Portables Attic Rm 20 Tech Lab	Manual	9/30/2025 9:29:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-042 168	Portables Classrm 19 Media Center	Manual	9/30/2025 8:09:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-041 169	Portables Classrm 19 Media Center	Manual	9/30/2025 8:09:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-040 170	Portables Classrm 19 Media Center	Manual	9/30/2025 8:09:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-043 171	Portables Classrm 19 Media Center	Manual	9/30/2025 8:09:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-150 162	Portables Classrm 20 Tech Lab	Manual	9/30/2025 8:13:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-045 172	Portables Classrm 20 Tech Lab	Manual	9/30/2025 8:12:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-044 173	Portables Classrm 20 Tech Lab	Manual	9/30/2025 8:12:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-149 163	Portables Classroom 21	Manual	9/30/2025 8:16:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-059 174	Portables Classroom 21	Manual	9/30/2025 8:17:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-060 175	Portables Classroom 21	Manual	9/30/2025 8:17:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-148 164	Portables Classroom 22	Manual	9/30/2025 8:18:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-061 176	Portables Classroom 22	Manual	9/30/2025 8:19:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-062 177	Portables Classroom 22	Manual	9/30/2025 8:19:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-147 165	Portables Classroom 23	Manual	9/30/2025 8:20:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-063 178	Portables Classroom 23	Manual	9/30/2025 8:21:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-064 179	Portables Classroom 23	Manual	9/30/2025 8:21:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-152 166	Portables Classroom 24	Manual	9/30/2025 8:07:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-067 180	Portables Classroom 24	Manual	9/30/2025 8:06:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-068 181	Portables Classroom 24	Manual	9/30/2025 8:06:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	2-143 199	Portables Classroom 24 & 25	Manual	9/30/2025 8:53:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-146 167	Portables Classroom 25	Manual	9/30/2025 8:05:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-066 183	Portables Classroom 25	Manual	9/30/2025 8:04:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-065 182	Portables Classroom 25	Manual	9/30/2025 8:04:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Valve Tamper Switch	2-142 200	Portables PIV Southeast	Manual	9/30/2025 8:09:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-151 160	Portables Rm 19 Media Center North	Manual	9/30/2025 8:08:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-175 161	Portables Rm 19 Media Center South	Manual	9/30/2025 8:13:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Valve Tamper Switch	2-144 201	Portables Sec Valve Room 25	Manual	9/30/2025 8:44:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-376 140	Rooms 13-18 Bldg Attic Classroom 13	Manual	9/30/2025 6:13:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-376 141	Rooms 13-18 Bldg Attic Classroom 14	Manual	9/30/2025 6:13:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-376 142	Rooms 13-18 Bldg Attic Classroom 15	Manual	9/30/2025 6:13:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-377 143	Rooms 13-18 Bldg Attic Classroom 16	Manual	9/30/2025 6:22:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-377 144	Rooms 13-18 Bldg Attic Classroom 17	Manual	9/30/2025 6:22:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-377 145	Rooms 13-18 Bldg Attic Classroom 18	Manual	9/30/2025 6:22:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-281 138	Rooms 13-18 Bldg Boys RR 13-18 Wing	Manual	9/30/2025 6:37:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-284 131	Rooms 13-18 Bldg Classroom 13	Manual	9/30/2025 6:07:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-385 123	Rooms 13-18 Bldg Classroom 13	Manual	9/30/2025 9:29:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-286 132	Rooms 13-18 Bldg Classroom 14	Manual	9/30/2025 6:09:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-386 124	Rooms 13-18 Bldg Classroom 14	Manual	9/30/2025 6:08:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-288 133	Rooms 13-18 Bldg Classroom 15	Manual	9/30/2025 6:15:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-391 125	Rooms 13-18 Bldg Classroom 15	Manual	9/30/2025 6:16:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-285 134	Rooms 13-18 Bldg Classroom 16	Manual	9/30/2025 6:30:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-389 126	Rooms 13-18 Bldg Classroom 16	Manual	9/30/2025 6:29:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-287 136	Rooms 13-18 Bldg Classroom 17	Manual	9/30/2025 6:23:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-388 128	Rooms 13-18 Bldg Classroom 17	Manual	9/30/2025 6:25:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-289 137	Rooms 13-18 Bldg Classroom 18	Manual	9/30/2025 6:19:32 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Manual Pull Station	2-387 129	Rooms 13-18 Bldg Classroom 18	Manual	9/30/2025 9:29:43 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-280 130	Rooms 13-18 Bldg Cust Rm by Rm 13	Manual	9/30/2025 8:35:50 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-282 139	Rooms 13-18 Bldg Girls RR 13-18 Wing	Manual	9/30/2025 6:36:55 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-283 135	Rooms 13-18 Bldg Room 16A	Manual	9/30/2025 8:32:21 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Manual Pull Station	2-390 127	Rooms 13-18 Bldg Room 16A	Manual	9/30/2025 6:35:34 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-129 067	Rooms 1-6 Bldg Attic Classroom 1	Manual	9/30/2025 5:46:14 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-129 068	Rooms 1-6 Bldg Attic Classroom 2	Manual	9/30/2025 5:46:12 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-129 069	Rooms 1-6 Bldg Attic Classroom 3	Manual	9/30/2025 5:46:11 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-130 070	Rooms 1-6 Bldg Attic Classroom 4	Manual	9/30/2025 5:35:49 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-130 071	Rooms 1-6 Bldg Attic Classroom 5	Manual	9/30/2025 5:35:47 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-130 072	Rooms 1-6 Bldg Attic Classroom 6	Manual	9/30/2025 5:35:46 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-014 064	Rooms 1-6 Bldg Boys Restroom	Manual	9/30/2025 5:57:17 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-020 057	Rooms 1-6 Bldg Classroom 1	Manual	9/30/2025 5:44:29 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Manual Pull Station	2-167 048	Rooms 1-6 Bldg Classroom 1	Manual	9/30/2025 5:43:36 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-018 058	Rooms 1-6 Bldg Classroom 2	Manual	9/30/2025 5:48:06 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Manual Pull Station	2-168 049	Rooms 1-6 Bldg Classroom 2	Manual	9/30/2025 5:49:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-016 059	Rooms 1-6 Bldg Classroom 3	Manual	9/30/2025 5:52:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-169 050	Rooms 1-6 Bldg Classroom 3	Manual	9/30/2025 5:51:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-021 061	Rooms 1-6 Bldg Classroom 4	Manual	9/30/2025 5:39:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-172 052	Rooms 1-6 Bldg Classroom 4	Manual	9/30/2025 5:38:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-019 062	Rooms 1-6 Bldg Classroom 5	Manual	9/30/2025 8:32:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-173 053	Rooms 1-6 Bldg Classroom 5	Manual	9/30/2025 5:33:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-017 063	Rooms 1-6 Bldg Classroom 6	Manual	9/30/2025 5:31:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-174 054	Rooms 1-6 Bldg Classroom 6	Manual	9/30/2025 5:28:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-012 065	Rooms 1-6 Bldg Cust Rm by RRs	Manual	9/30/2025 5:55:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-013 066	Rooms 1-6 Bldg Girls Restroom	Manual	9/30/2025 5:56:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-011 060	Rooms 1-6 Bldg Room 3A	Manual	9/30/2025 5:54:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-170 051	Rooms 1-6 Bldg Room 3A	Manual	9/30/2025 5:53:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-171 055	Rooms 1-6 Bldg Speech Room	Manual	9/30/2025 5:24:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-015 056	Rooms 1-6 Bldg Speech Room	Manual	9/30/2025 8:41:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-132 107	Rooms 7-12 Bldg Attic Classroom 10	Manual	9/30/2025 4:57:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-132 108	Rooms 7-12 Bldg Attic Classroom 11	Manual	9/30/2025 4:57:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-132 109	Rooms 7-12 Bldg Attic Classroom 12	Manual	9/30/2025 4:56:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-131 104	Rooms 7-12 Bldg Attic Classroom 7	Manual	9/30/2025 5:12:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-131 105	Rooms 7-12 Bldg Attic Classroom 8	Manual	9/30/2025 5:12:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-131 106	Rooms 7-12 Bldg Attic Classroom 9	Manual	9/30/2025 5:12:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-002 102	Rooms 7-12 Bldg Boys RR 7-12 Wing	Manual	9/30/2025 6:01:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-010 099	Rooms 7-12 Bldg Classroom 10	Manual	9/30/2025 5:04:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-157 091	Rooms 7-12 Bldg Classroom 10	Manual	9/30/2025 5:04:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-008 100	Rooms 7-12 Bldg Classroom 11	Manual	9/30/2025 4:59:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-158 092	Rooms 7-12 Bldg Classroom 11	Manual	9/30/2025 4:57:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-006 101	Rooms 7-12 Bldg Classroom 12	Manual	9/30/2025 4:52:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-159 093	Rooms 7-12 Bldg Classroom 12	Manual	9/30/2025 4:52:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-007 096	Rooms 7-12 Bldg Classroom 8	Manual	9/30/2025 5:18:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-154 088	Rooms 7-12 Bldg Classroom 8	Manual	9/30/2025 5:16:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-005 097	Rooms 7-12 Bldg Classroom 9	Manual	9/30/2025 5:20:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-155 089	Rooms 7-12 Bldg Classroom 9	Manual	9/30/2025 5:19:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-003 103	Rooms 7-12 Bldg Girls RR 7-12 Wing	Manual	9/30/2025 6:00:57 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-001 094	Rooms 7-12 Bldg Room 12A Headend	Manual	9/30/2025 8:34:27 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-009 095	Rooms 7-12 Bldg Room 7 Staff	Manual	9/30/2025 5:08:06 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Manual Pull Station	2-153 087	Rooms 7-12 Bldg Room 7 Staff	Manual	9/30/2025 5:09:34 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Manual Pull Station	2-156 090	Rooms 7-12 Bldg Room 9A	Manual	9/30/2025 5:22:07 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-004 098	Rooms 7-12 Bldg Storage Room 9A	Manual	9/30/2025 5:21:30 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

## Device/Equipment details

### Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Audible					
015	Admin Bldg East Exterior				
042	Kindergarten Bldg South Exterior				
073	Rooms 1-6 Bldg East Exterior				
074	Rooms 1-6 Bldg South Exterior				
075	Rooms 1-6 Bldg West Exterior				
110	Rooms 7-12 Bldg East Exterior				
111	Rooms 7-12 Bldg South Exterior				
112	Rooms 7-12 Bldg West Exterior				
146	Rooms 13-18 Bldg East Exterior				
147	Rooms 13-18 Bldg South Exterior				
148	Rooms 13-18 Bldg West Exterior				
202	Portables North Exterior				
203	Portables North Exterior				
204	Portables North Exterior				
212	Portables Classroom 25				
239	Multi-Purpose Bldg West Exterior				
Audible And Visible					
016	Admin Bldg Reception				
017	Admin Bldg Nurse Room				
018	Admin Bldg Work Room MDF				
043	Kindergarten Bldg Kindergarten A				
044	Kindergarten Bldg Kindergarten B				
045	Kindergarten Bldg Kindergarten A/B Hall				
076	Rooms 1-6 Bldg Classroom 1				
077	Rooms 1-6 Bldg Classroom 2				
078	Rooms 1-6 Bldg Classroom 3				
079	Rooms 1-6 Bldg Classroom 4				
080	Rooms 1-6 Bldg Classroom 5				
081	Rooms 1-6 Bldg Classroom 6				
113	Rooms 7-12 Bldg Room 7 Staff				
114	Rooms 7-12 Bldg Classroom 8				
115	Rooms 7-12 Bldg Classroom 9				
116	Rooms 7-12 Bldg Classroom 10				
117	Rooms 7-12 Bldg Classroom 11				
118	Rooms 7-12 Bldg Classroom 12				
149	Rooms 13-18 Bldg Classroom 13				
150	Rooms 13-18 Bldg Classroom 14				
151	Rooms 13-18 Bldg Classroom 15				
152	Rooms 13-18 Bldg Classroom 16				
153	Rooms 13-18 Bldg Classroom 17				
154	Rooms 13-18 Bldg Classroom 18				
205	Portables Classroom 19				
206	Portables Classroom 20				
207	Portables Classroom 21				
208	Portables Classroom 22				
209	Portables Classroom 23				
210	Portables Classroom 24				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
211	Portables Classroom 25				
240	Multi-Purpose Bldg MP Room				
241	Multi-Purpose Bldg MP Room				
242	Multi-Purpose Bldg Stage				
243	Multi-Purpose Bldg Head Custodian Off				
244	Multi-Purpose Bldg Kitchen				
245	Multi-Purpose Bldg Kitchen				
Visible					
019	Admin Bldg Principals Office				
020	Admin Bldg Nurse Restroom				
021	Admin Bldg Student Restroom				
022	Admin Bldg Staff Restroom				
046	Kindergarten Bldg Kindergarten A RR				
047	Kindergarten Bldg Kindergarten B RR				
082	Rooms 1-6 Bldg Room 3A				
083	Rooms 1-6 Bldg Boys Restroom				
084	Rooms 1-6 Bldg Boys Restroom				
085	Rooms 1-6 Bldg Custodial Room				
086	Rooms 1-6 Bldg Girls Restroom				
119	Rooms 7-12 Bldg Storage Room 9A				
120	Rooms 7-12 Bldg Boys RR 7-12 Wing				
121	Rooms 7-12 Bldg Boys RR 7-12 Wing				
122	Rooms 7-12 Bldg Girls RR 7-12 Wing				
155	Rooms 13-18 Bldg Room 16A				
156	Rooms 13-18 Bldg Boys Restroom				
157	Rooms 13-18 Bldg Boys Restroom				
158	Rooms 13-18 Bldg Girls Restroom				
159	Rooms 13-18 Bldg Cust Rm by Rm 13				
246	Multi-Purpose Bldg Kitchen Restroom				

**Fire Control Panel**

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
---------	-------------	--------------	-------	--------	--------------

Remote Annunciator

001	Admin Bldg Reception				
-----	----------------------	--	--	--	--

Fire Alarm Panel

	Rooms 7-12 Bldg Room 12A Headend	EST	3		
--	----------------------------------	-----	---	--	--

NAC Power Extender Panel

	Rooms 7-12 Bldg Room 12A - P.E. "Master"				
	Rooms 7-12 Bldg Room 12A - P.E. "C"				
	Rooms 7-12 Bldg Room 12A - P.E. "E"				
	Rooms 13-18 Bldg Cust Rm by Rm 13 - P.E. "B"				

**Initiating Device**

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
---------	-------------	--------------	-------	--------	--------------

Manual Pull Station

2-126 002	Admin Bldg Reception				
--------------	----------------------	--	--	--	--

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-160 003	Admin Bldg Reception				
2-161 004	Admin Bldg Nurse Room				
2-162 005	Admin Bldg Work Room MDF				
2-163 023	Kindergarten Bldg Kindergarten A				
2-166 024	Kindergarten Bldg Kindergarten B				
2-164 025	Kindergarten Bldg Kinder A/B Hall East				
2-165 026	Kindergarten Bldg Kinder A/B Hall West				
2-167 048	Rooms 1-6 Bldg Classroom 1				
2-168 049	Rooms 1-6 Bldg Classroom 2				
2-169 050	Rooms 1-6 Bldg Classroom 3				
2-170 051	Rooms 1-6 Bldg Room 3A				
2-172 052	Rooms 1-6 Bldg Classroom 4				
2-173 053	Rooms 1-6 Bldg Classroom 5				
2-174 054	Rooms 1-6 Bldg Classroom 6				
2-171 055	Rooms 1-6 Bldg Speech Room				
2-153 087	Rooms 7-12 Bldg Room 7 Staff				
2-154 088	Rooms 7-12 Bldg Classroom 8				
2-155 089	Rooms 7-12 Bldg Classroom 9				
2-156 090	Rooms 7-12 Bldg Room 9A				
2-157 091	Rooms 7-12 Bldg Classroom 10				
2-158 092	Rooms 7-12 Bldg Classroom 11				
2-159 093	Rooms 7-12 Bldg Classroom 12				
2-385 123	Rooms 13-18 Bldg Classroom 13				
2-386 124	Rooms 13-18 Bldg Classroom 14				
2-391 125	Rooms 13-18 Bldg Classroom 15				
2-389 126	Rooms 13-18 Bldg Classroom 16				
2-390 127	Rooms 13-18 Bldg Room 16A				
2-388 128	Rooms 13-18 Bldg Classroom 17				
2-387 129	Rooms 13-18 Bldg Classroom 18				
2-151 160	Portables Rm 19 Media Center North				
2-175 161	Portables Rm 19 Media Center South				
2-150 162	Portables Classrm 20 Tech Lab				
2-149 163	Portables Classroom 21				
2-148 164	Portables Classroom 22				
2-147 165	Portables Classroom 23				
2-152 166	Portables Classroom 24				
2-146 167	Portables Classroom 25				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-380 213	Multi-Purpose Bldg MP Room NW				
2-381 214	Multi-Purpose Bldg MP Room SW				
2-383 215	Multi-Purpose Bldg MP Room SE				
2-382 216	Multi-Purpose Bldg Stage				
2-384 217	Multi-Purpose Bldg Kitchen				
Smoke Detector - General					
2-056 006	Admin Bldg Front Area-Reception				
2-052 007	Admin Bldg Nurse Room				
2-054 008	Admin Bldg Office Closet				
2-055 009	Admin Bldg Work Room MDF				
2-034 027	Kindergarten Bldg Kindergarten A				
2-032 028	Kindergarten Bldg Kindergarten A				
2-031 029	Kindergarten Bldg Kindergarten A				
2-033 030	Kindergarten Bldg Kindergarten A				
2-029 031	Kindergarten Bldg Kindergarten A RR				
2-023 032	Kindergarten Bldg Kindergarten B				
2-035 033	Kindergarten Bldg Kindergarten B				
2-036 034	Kindergarten Bldg Kindergarten B				
2-022 035	Kindergarten Bldg Kindergarten B				
2-025 036	Kindergarten Bldg Kindergarten B RR				
2-028 037	Kindergarten Bldg Kindergarten A/B Hall				
2-027 038	Kindergarten Bldg Kindergarten A/B Hall				
2-026 039	Kindergarten Bldg Kindergarten A/B Hall				
2-015 056	Rooms 1-6 Bldg Speech Room				
2-001 094	Rooms 7-12 Bldg Room 12A Headend				
2-280 130	Rooms 13-18 Bldg Cust Rm by Rm 13				
2-042 168	Portables Classrm 19 Media Center				
2-041 169	Portables Classrm 19 Media Center				
2-040 170	Portables Classrm 19 Media Center				
2-043 171	Portables Classrm 19 Media Center				
2-045 172	Portables Classrm 20 Tech Lab				
2-044 173	Portables Classrm 20 Tech Lab				
2-059 174	Portables Classroom 21				
2-060 175	Portables Classroom 21				
2-061 176	Portables Classroom 22				
2-062 177	Portables Classroom 22				
2-063 178	Portables Classroom 23				
2-064 179	Portables Classroom 23				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-067 180	Portables Classroom 24				
2-068 181	Portables Classroom 24				
2-065 182	Portables Classroom 25				
2-066 183	Portables Classroom 25				
2-252 218	Multi-Purpose Bldg MP Room				
2-253 219	Multi-Purpose Bldg MP Room				
2-255 220	Multi-Purpose Bldg MP Room				
2-257 221	Multi-Purpose Bldg MP Room				
2-254 222	Multi-Purpose Bldg MP Room				
2-256 223	Multi-Purpose Bldg MP Room				
2-258 224	Multi-Purpose Bldg MP Room				
2-259 225	Multi-Purpose Bldg MP Room				
2-261 226	Multi-Purpose Bldg Stage				
2-260 227	Multi-Purpose Bldg Stage				
2-251 228	Multi-Purpose Bldg Head Custodian Office				
Heat Detector - Restorable Spot					
2-057 010	Admin Bldg Office Closet				
2-058 011	Admin Bldg Principals Office				
2-051 012	Admin Bldg Nurse Restroom				
2-053 013	Admin Bldg Student Restroom				
2-050 014	Admin Bldg Staff Restroom				
2-030 040	Kindergarten Bldg Kindergarten A Storage				
2-024 041	Kindergarten Bldg Kindergarten B Storage				
2-020 057	Rooms 1-6 Bldg Classroom 1				
2-018 058	Rooms 1-6 Bldg Classroom 2				
2-016 059	Rooms 1-6 Bldg Classroom 3				
2-011 060	Rooms 1-6 Bldg Room 3A				
2-021 061	Rooms 1-6 Bldg Classroom 4				
2-019 062	Rooms 1-6 Bldg Classroom 5				
2-017 063	Rooms 1-6 Bldg Classroom 6				
2-014 064	Rooms 1-6 Bldg Boys Restroom				
2-012 065	Rooms 1-6 Bldg Cust Rm by RRs				
2-013 066	Rooms 1-6 Bldg Girls Restroom				
2-129 067	Rooms 1-6 Bldg Attic Classroom 1				
2-129 068	Rooms 1-6 Bldg Attic Classroom 2				
2-129 069	Rooms 1-6 Bldg Attic Classroom 3				
2-130 070	Rooms 1-6 Bldg Attic Classroom 4				
2-130 071	Rooms 1-6 Bldg Attic Classroom 5				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-130 072	Rooms 1-6 Bldg Attic Classroom 6				
2-009 095	Rooms 7-12 Bldg Room 7 Staff				
2-007 096	Rooms 7-12 Bldg Classroom 8				
2-005 097	Rooms 7-12 Bldg Classroom 9				
2-004 098	Rooms 7-12 Bldg Storage Room 9A				
2-010 099	Rooms 7-12 Bldg Classroom 10				
2-008 100	Rooms 7-12 Bldg Classroom 11				
2-006 101	Rooms 7-12 Bldg Classroom 12				
2-002 102	Rooms 7-12 Bldg Boys RR 7-12 Wing				
2-003 103	Rooms 7-12 Bldg Girls RR 7-12 Wing				
2-131 104	Rooms 7-12 Bldg Attic Classroom 7				
2-131 105	Rooms 7-12 Bldg Attic Classroom 8				
2-131 106	Rooms 7-12 Bldg Attic Classroom 9				
2-132 107	Rooms 7-12 Bldg Attic Classroom 10				
2-132 108	Rooms 7-12 Bldg Attic Classroom 11				
2-132 109	Rooms 7-12 Bldg Attic Classroom 12				
2-284 131	Rooms 13-18 Bldg Classroom 13				
2-286 132	Rooms 13-18 Bldg Classroom 14				
2-288 133	Rooms 13-18 Bldg Classroom 15				
2-285 134	Rooms 13-18 Bldg Classroom 16				
2-283 135	Rooms 13-18 Bldg Room 16A				
2-287 136	Rooms 13-18 Bldg Classroom 17				
2-289 137	Rooms 13-18 Bldg Classroom 18				
2-281 138	Rooms 13-18 Bldg Boys RR 13-18 Wing				
2-282 139	Rooms 13-18 Bldg Girls RR 13-18 Wing				
2-376 140	Rooms 13-18 Bldg Attic Classroom 13				
2-376 141	Rooms 13-18 Bldg Attic Classroom 14				
2-376 142	Rooms 13-18 Bldg Attic Classroom 15				
2-377 143	Rooms 13-18 Bldg Attic Classroom 16				
2-377 144	Rooms 13-18 Bldg Attic Classroom 17				
2-377 145	Rooms 13-18 Bldg Attic Classroom 18				
2-127 184	Portables Attic Rm 19 Media Center				
2-127 185	Portables Attic Rm 19 Media Center				
2-127 186	Portables Attic Rm 19 Media Center				
2-128 187	Portables Attic Rm 20 Tech Lab				
2-128 188	Portables Attic Rm 20 Tech Lab				
2-137 189	Portables Attic Classroom 21				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-137 190	Portables Attic Classroom 21				
2-138 191	Portables Attic Classroom 22				
2-138 192	Portables Attic Classroom 22				
2-139 193	Portables Attic Classroom 23				
2-139 194	Portables Attic Classroom 23				
2-140 195	Portables Attic Classroom 24				
2-140 196	Portables Attic Classroom 24				
2-141 197	Portables Attic Classroom 25				
2-141 198	Portables Attic Classroom 25				
2-264 229	Multi-Purpose Bldg Stage Stairs				
2-263 230	Multi-Purpose Bldg Stage Closet North				
2-262 231	Multi-Purpose Bldg Stage Closet South				
2-265 232	Multi-Purpose Bldg Kitchen				
2-266 233	Multi-Purpose Bldg Kitchen				
2-267 234	Multi-Purpose Bldg Kitchen Storage				
2-268 235	Multi-Purpose Bldg Kitchen Restroom				
2-271 236	Multi-Purpose Bldg O/S Kitchen Storage				
2-269 237	Multi-Purpose Bldg O/S Wtr Htr Closet				
2-378 238	Multi-Purpose Bldg Attic Kitchen				
Mechanical, Electrosonic, or Pressure Waterflow Device					
2-143 199	Portables Classroom 24 & 25				
Valve Tamper Switch					
2-142 200	Portables PIV Southeast				
2-144 201	Portables Sec Valve Room 25				