

Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

GARFIELD ENROLLMENT CTR

3700 GARFIELD AVE
CARMICHAEL, California
United States

This site has been inspected and tested in compliance with applicable standards.

Completed

Thursday, October 09, 2025

Test Session:07 Oct 2025 14:25 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD
5320 HEMLOCK ST
SACRAMENTO, California
United States

TESTED BY

Riley Goyet
Western States Fire Protection-
Sacramento
188 Cirby Way
Roseville, CA 95678
United States



Inspection Summary

Building Information

PROPERTY	GARFIELD ENROLLMENT CTR	CONTACT
ADDRESS	3700 GARFIELD AVE	PHONE
CITY/STATE	CARMICHAEL, California	MOBILE
COUNTRY	United States	EMAIL

Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us

Testing Summary


EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Alarm Notification Appliance	57	57(100%)	57(100%)	0(0%)
Supervising Station Transmitting Equipment	1	1(100%)	1(100%)	0(0%)
Fire Control Panel	7	7(100%)	5(71%)	2(29%)
Initiating Device	209	207(99%)	206(99%)	1(0%)

Certification

The equipment specified here in was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Thursday, October 09, 2025

ACCEPTED BY 10/09/2025

Building Representative

TESTED BY 
10/09/2025
Riley Goyet
Technician

System Details

Control Units

ADDRESS/ SCAN ADDRESS		DESCRIPTION	Admin/Rms 1-3 Bldg Admin Server Room
MANUFACTURER	EST	S/W VERSION	
MODEL	3	LAST UPDATE	
SERIAL NUMBER		S/W LOCATION	
INSTALL DATE			

Monitoring Information

Admin/Rms 1-3 Bldg Admin Server Room			
TYPE	Digital Alarm Communicator Transmitter	INSTALL DATE	
MANUFACTURER	Bosch	TEST START	10/07/2025
MODEL	B9512G	TEST COMPLETE	10/09/2025
SERIAL NUMBER		Time to Transmit to Supervising Station	
MONITORING ORGANIZATION	Central Station / SJUSD Dispatch	ALARM SIGNAL	
MONITORING ORGANIZATION PHONE	CS - 916-480-4836 / SJUSD Dispatch - 916-971-7000	ALARM RESTORE	
MONITORING ORGANIZATION EMAIL		TROUBLE SIGNAL	
MONITORING ORGANIZATION ACCOUNT NUMBER	Central Station # 881-8015	TROUBLE RESTORE	
MONITORING PHONE LINE 1		SUPERVISORY SIGNAL	
MONITORING PHONE LINE 2		SUPERVISORY RESTORE	
MONITORING RETRANSMISSION ENTITY			

Open Corrective Action & Solution Summary

The following 3 corrective action(s) remain open following the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
Smoke Detector - General	2-089 058	Rooms 4-8 Bldg Classroom 4
	Created By:	Riley Goyet
	Creation Date:	10/07/2025
	Corrective Action:	Smoke is in trouble on the panel.
	Proposed Solution:	
	Manufacturer:	
	Model:	
NAC Power Extender Panel		Speech Building Storage by Speech - P.E. "D"
	Created By:	Riley Goyet
	Creation Date:	10/07/2025
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
NAC Power Extender Panel		Restroom Bldgs Storage by Restroom - P.E. "E"
	Created By:	Riley Goyet
	Creation Date:	10/07/2025
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	

Resolved Corrective Action & Solution Summary

The following 1 corrective action(s) were resolved during the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
Heat Detector - Restorable Spot	2-135 093	Rooms 4-8 Bldg Room 8 HVAC Closet
	Created By:	Riley Goyet
	Creation Date:	11/07/2024
	Corrective Action:	Stick Heat is hanging
	Resolution:	
	Resolved By:	Riley Goyet
	Resolved On:	10/07/2025
	Manufacturer:	
	Model:	

Testing Details

Alarm Notification Appliance

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible	055	Admin/Rms 1-3 Bldg Admin Office Hall	Manual	10/7/2025 2:28:18 PM
		Visual inspection	Passed (Manual)	
Visible	057	Admin/Rms 1-3 Bldg Admin Work Room	Manual	10/7/2025 2:28:15 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	050	Admin/Rms 1-3 Bldg Classroom 1	Manual	10/7/2025 2:28:26 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	051	Admin/Rms 1-3 Bldg Classroom 2	Manual	10/7/2025 2:28:24 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	052	Admin/Rms 1-3 Bldg Classroom 3	Manual	10/7/2025 2:28:22 PM
		Visual inspection	Passed (Manual)	
Visible	054	Admin/Rms 1-3 Bldg Directors Office	Manual	10/7/2025 2:28:20 PM
		Visual inspection	Passed (Manual)	
Visible	053	Admin/Rms 1-3 Bldg Office by Reception	Manual	10/7/2025 2:28:21 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	049	Admin/Rms 1-3 Bldg Old Nurse Room	Manual	10/7/2025 2:28:27 PM
		Visual inspection	Passed (Manual)	
Visible	056	Admin/Rms 1-3 Bldg Old Nurse Room	Manual	10/7/2025 2:28:17 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	048	Admin/Rms 1-3 Bldg Reception	Manual	10/7/2025 2:28:29 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	269	Multi-Purpose Bldg Kitchen	Manual	10/7/2025 2:27:14 PM
		Visual inspection	Passed (Manual)	
Visible	272	Multi-Purpose Bldg Kitchen	Manual	10/7/2025 2:27:09 PM
		Visual inspection	Passed (Manual)	
Visible	274	Multi-Purpose Bldg Kitchen Restroom	Manual	10/7/2025 2:27:06 PM
		Visual inspection	Passed (Manual)	
Visible	273	Multi-Purpose Bldg Kitchen Restroom	Manual	10/7/2025 2:27:07 PM
		Visual inspection	Passed (Manual)	
Visible	276	Multi-Purpose Bldg Mens Restroom	Manual	10/7/2025 2:27:03 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	268	Multi-Purpose Bldg MP Room	Manual	10/7/2025 2:27:15 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible	270	Multi-Purpose Bldg MP Room	Manual	10/7/2025 2:27:13 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible	267	Multi-Purpose Bldg Northwest Exterior	Manual	10/7/2025 2:27:17 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Visible	275	Multi-Purpose Bldg Resource Room	Manual	10/7/2025 2:27:04 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Visible	271	Multi-Purpose Bldg Stage	Manual	10/7/2025 2:27:11 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Visible	277	Multi-Purpose Bldg Womens Restroom	Manual	10/7/2025 2:27:01 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Visible	218	Restroom Bldgs Boys Restroom	Manual	10/7/2025 2:27:28 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible	216	Restroom Bldgs East Exterior	Manual	10/7/2025 2:27:32 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible	215	Restroom Bldgs East Exterior	Manual	10/7/2025 2:27:35 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Visible	219	Restroom Bldgs Girls Restroom	Manual	10/7/2025 2:27:27 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Visible	220	Restroom Bldgs Mens Restroom	Manual	10/7/2025 2:27:26 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible	217	Restroom Bldgs West Exterior	Manual	10/7/2025 2:27:30 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Visible	221	Restroom Bldgs Womens Restroom	Manual	10/7/2025 2:27:23 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	205	Rms KA & KB Bldg Classroom KA	Manual	10/7/2025 2:27:41 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Visible	207	Rms KA & KB Bldg Classroom KA	Manual	10/7/2025 2:27:39 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	206	Rms KA & KB Bldg Classroom KB	Manual	10/7/2025 2:27:38 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Visible	208	Rms KA & KB Bldg Classroom KB	Manual	10/7/2025 2:27:36 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible	203	Rms KA & KB Bldg South Exterior	Manual	10/7/2025 2:27:44 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible	204	Rms KA & KB Bldg West Exterior	Manual	10/7/2025 2:27:42 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	179	Rooms 14-18 Bldg Classroom 14	Manual	10/7/2025 2:27:51 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	180	Rooms 14-18 Bldg Classroom 15	Manual	10/7/2025 2:27:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	181	Rooms 14-18 Bldg Classroom 16	Manual	10/7/2025 2:27:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	182	Rooms 14-18 Bldg Classroom 17	Manual	10/7/2025 2:27:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	183	Rooms 14-18 Bldg Classroom 18	Manual	10/7/2025 2:27:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	178	Rooms 14-18 Bldg North Exterior	Manual	10/7/2025 2:27:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	096	Rooms 4-8 Bldg Classroom 4	Manual	10/7/2025 2:28:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	097	Rooms 4-8 Bldg Classroom 5	Manual	10/7/2025 2:28:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	098	Rooms 4-8 Bldg Classroom 6	Manual	10/7/2025 2:28:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	099	Rooms 4-8 Bldg Classroom 7	Manual	10/7/2025 2:28:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	100	Rooms 4-8 Bldg Classroom 8	Manual	10/7/2025 2:28:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	094	Rooms 4-8 Bldg North Exterior	Manual	10/7/2025 2:28:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	095	Rooms 4-8 Bldg West Exterior	Manual	10/7/2025 2:28:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	138	Rooms 9-13 Bldg Classroom 10	Manual	10/7/2025 2:27:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	139	Rooms 9-13 Bldg Classroom 11	Manual	10/7/2025 2:27:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	140	Rooms 9-13 Bldg Classroom 12	Manual	10/7/2025 2:27:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	141	Rooms 9-13 Bldg Classroom 13	Manual	10/7/2025 2:27:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	137	Rooms 9-13 Bldg Classroom 9	Manual	10/7/2025 2:28:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	142	Rooms 9-13 Bldg Classroom 9 Office	Manual	10/7/2025 2:27:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible	136	Rooms 9-13 Bldg North Exterior	Manual	10/7/2025 2:28:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	228	Speech Building Office by Speech Rm	Manual	10/7/2025 2:27:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	229	Speech Building Speech Room	Manual	10/7/2025 2:27:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	227	Speech Building West Exterior	Manual	10/7/2025 2:27:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Fire Alarm Panel		Admin/Rms 1-3 Bldg Admin Server Room	Manual	10/7/2025 7:43:57 PM
		Manufacturer	EST	
		Model	3	
		Visual inspection	Passed (Manual)	
NAC Power Extender Panel		Admin/Rms 1-3 Bldg Admin Server Room - P.E. "B"	Manual	10/7/2025 6:59:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Admin/Rms 1-3 Bldg Admin Server Room - P.E. "C"	Manual	10/7/2025 6:59:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Admin/Rms 1-3 Bldg Admin Server Room - P.E. "Master"	Manual	10/7/2025 6:59:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Remote Annunciator	001	Admin/Rms 1-3 Bldg Reception	Manual	10/7/2025 7:44:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Failed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
NAC Power Extender Panel		Restroom Bldgs Storage by Restroom - P.E. "E"	Manual	10/7/2025 7:42:57 PM
		Visual inspection	Failed (Manual)	
NAC Power Extender Panel		Speech Building Storage by Speech - P.E. "D"	Manual	10/7/2025 7:43:24 PM
		Visual inspection	Failed (Manual)	

Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-009 012	Admin/Rms 1-3 Bldg Admin Office Hall	Manual	10/7/2025 7:06:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-008 011	Admin/Rms 1-3 Bldg Admin Office Hall	Manual	10/7/2025 7:08:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-003 041	Admin/Rms 1-3 Bldg Admin Server Room	Manual	10/7/2025 7:56:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-002 018	Admin/Rms 1-3 Bldg Admin Server Room	Manual	10/7/2025 7:06:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-018 019	Admin/Rms 1-3 Bldg Admin Work Room	Manual	10/7/2025 7:06:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-019 020	Admin/Rms 1-3 Bldg Admin Work Room	Manual	10/7/2025 7:06:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-020 021	Admin/Rms 1-3 Bldg Admin Work Room	Manual	10/7/2025 7:06:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-130 042	Admin/Rms 1-3 Bldg Attic Hall Restroom	Manual	10/7/2025 7:44:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-131 043	Admin/Rms 1-3 Bldg Attic Old Nurse RR	Manual	10/7/2025 7:44:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-042 022	Admin/Rms 1-3 Bldg Classroom 1	Manual	10/7/2025 6:59:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-022 023	Admin/Rms 1-3 Bldg Classroom 1	Manual	10/7/2025 6:59:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-041 025	Admin/Rms 1-3 Bldg Classroom 1	Manual	10/7/2025 7:00:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-023 024	Admin/Rms 1-3 Bldg Classroom 1	Manual	10/7/2025 7:00:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-024 027	Admin/Rms 1-3 Bldg Classroom 1	Manual	10/7/2025 7:00:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-040 026	Admin/Rms 1-3 Bldg Classroom 1	Manual	10/7/2025 7:00:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-021 028	Admin/Rms 1-3 Bldg Classroom 1 Closet	Manual	10/7/2025 7:15:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-037 029	Admin/Rms 1-3 Bldg Classroom 2	Manual	10/7/2025 6:58:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-027 030	Admin/Rms 1-3 Bldg Classroom 2	Manual	10/7/2025 6:58:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-038 031	Admin/Rms 1-3 Bldg Classroom 2	Manual	10/7/2025 6:58:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-026 032	Admin/Rms 1-3 Bldg Classroom 2	Manual	10/7/2025 6:58:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-025 034	Admin/Rms 1-3 Bldg Classroom 2	Manual	10/7/2025 6:58:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-039 033	Admin/Rms 1-3 Bldg Classroom 2	Manual	10/7/2025 6:58:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-033 035	Admin/Rms 1-3 Bldg Classroom 3	Manual	10/7/2025 6:57:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-028 036	Admin/Rms 1-3 Bldg Classroom 3	Manual	10/7/2025 6:57:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-032 038	Admin/Rms 1-3 Bldg Classroom 3	Manual	10/7/2025 6:57:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-029 037	Admin/Rms 1-3 Bldg Classroom 3	Manual	10/7/2025 6:58:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-030 039	Admin/Rms 1-3 Bldg Classroom 3	Manual	10/7/2025 6:58:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-031 040	Admin/Rms 1-3 Bldg Classroom 3	Manual	10/7/2025 6:58:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-115 010	Admin/Rms 1-3 Bldg Directors Off Closet	Manual	10/7/2025 7:08:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-006 008	Admin/Rms 1-3 Bldg Directors Office	Manual	10/7/2025 7:05:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-005 009	Admin/Rms 1-3 Bldg Directors Office	Manual	10/7/2025 7:06:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-004 013	Admin/Rms 1-3 Bldg Hall Restroom	Manual	10/7/2025 7:06:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-014 003	Admin/Rms 1-3 Bldg Office by Reception	Manual	10/7/2025 7:05:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-007 007	Admin/Rms 1-3 Bldg Office Closet	Manual	10/7/2025 7:06:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-013 017	Admin/Rms 1-3 Bldg Old Nurse Restroom	Manual	10/7/2025 7:05:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - Duct	2-140 047	Admin/Rms 1-3 Bldg Old Nurse Room	Manual	10/7/2025 7:07:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-016 015	Admin/Rms 1-3 Bldg Old Nurse Room	Manual	10/7/2025 7:06:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-017 014	Admin/Rms 1-3 Bldg Old Nurse Room	Manual	10/7/2025 7:06:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-015 016	Admin/Rms 1-3 Bldg Old Nurse Room	Manual	10/7/2025 7:08:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-144 002	Admin/Rms 1-3 Bldg Reception	Manual	10/7/2025 7:43:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-012 004	Admin/Rms 1-3 Bldg Reception	Manual	10/7/2025 7:05:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-011 005	Admin/Rms 1-3 Bldg Reception	Manual	10/7/2025 7:05:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-010 006	Admin/Rms 1-3 Bldg Reception	Manual	10/7/2025 7:05:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-132 044	Admin/Rms 1-3 Bldg Room 1 HVAC Closet	Manual	10/7/2025 7:42:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-133 045	Admin/Rms 1-3 Bldg Room 2 HVAC Closet	Manual	10/7/2025 7:42:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-134 046	Admin/Rms 1-3 Bldg Room 3 HVAC Closet	Manual	10/7/2025 7:42:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-141 249	Multi-Purpose Bldg Attic Kitchen	Manual	10/7/2025 7:43:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-141 250	Multi-Purpose Bldg Attic Kitchen	Manual	10/7/2025 7:43:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-141 251	Multi-Purpose Bldg Attic Kitchen	Manual	10/7/2025 7:43:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-153 266	Multi-Purpose Bldg Boiler Room	Manual	10/7/2025 7:43:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-097 241	Multi-Purpose Bldg Boiler Room	Manual	10/7/2025 8:01:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-100 248	Multi-Purpose Bldg Kitchen	Manual	10/7/2025 8:01:17 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-101 246	Multi-Purpose Bldg Kitchen	Manual	10/7/2025 8:01:20 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-099 247	Multi-Purpose Bldg Kitchen	Manual	10/7/2025 8:01:23 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-102 245	Multi-Purpose Bldg Kitchen	Manual	10/7/2025 8:01:24 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-098 238	Multi-Purpose Bldg Kitchen Restroom	Manual	10/7/2025 7:43:32 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-091 239	Multi-Purpose Bldg Kitchen Restroom	Manual	10/7/2025 7:43:34 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-096 240	Multi-Purpose Bldg Kitchen Storage	Manual	10/7/2025 8:01:22 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-092 237	Multi-Purpose Bldg Kitchen Storage	Manual	10/7/2025 6:50:18 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-095 244	Multi-Purpose Bldg Mens Restroom	Manual	10/7/2025 6:50:21 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - Projected Beam	2-147 264	Multi-Purpose Bldg MP Room Center	Manual	10/7/2025 7:13:01 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - Projected Beam	2-145 263	Multi-Purpose Bldg MP Room Left	Manual	10/7/2025 7:13:03 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Manual Pull Station	2-160 230	Multi-Purpose Bldg MP Room NW	Manual	10/7/2025 7:44:07 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - Projected Beam	2-149 265	Multi-Purpose Bldg MP Room Right	Manual	10/7/2025 7:12:57 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Manual Pull Station	2-158 232	Multi-Purpose Bldg MP Room SE	Manual	10/7/2025 7:44:06 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Manual Pull Station	2-159 231	Multi-Purpose Bldg MP Room SW	Manual	10/7/2025 7:44:04 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-093 242	Multi-Purpose Bldg Resource Room	Manual	10/7/2025 6:50:37 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-109 235	Multi-Purpose Bldg Stage	Manual	10/7/2025 6:50:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-110 234	Multi-Purpose Bldg Stage	Manual	10/7/2025 6:50:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-111 233	Multi-Purpose Bldg Stage	Manual	10/7/2025 6:50:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-108 236	Multi-Purpose Bldg Storage by Stage	Manual	10/7/2025 7:15:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-094 243	Multi-Purpose Bldg Womens Restroom	Manual	10/7/2025 6:50:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-034 209	Restroom Bldgs Boys Restroom	Manual	10/7/2025 6:57:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-036 211	Restroom Bldgs Girls Restroom	Manual	10/7/2025 6:57:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-285 212	Restroom Bldgs Mens Restroom	Manual	10/7/2025 6:53:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-286 213	Restroom Bldgs Storage by Restroom	Manual	10/7/2025 6:53:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-035 210	Restroom Bldgs Storage by Restroom	Manual	10/7/2025 6:57:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-287 214	Restroom Bldgs Womens Restroom	Manual	10/7/2025 6:53:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-047 191	Rms KA & KB Bldg Classrm KA Restroom	Manual	10/7/2025 7:15:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-046 190	Rms KA & KB Bldg Classrm KA Restroom	Manual	10/7/2025 7:15:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-048 199	Rms KA & KB Bldg Classrm KB Restroom	Manual	10/7/2025 7:12:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-049 200	Rms KA & KB Bldg Classrm KB Restroom	Manual	10/7/2025 7:12:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-057 189	Rms KA & KB Bldg Classroom KA	Manual	10/7/2025 7:13:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-044 188	Rms KA & KB Bldg Classroom KA	Manual	10/7/2025 7:13:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-060 185	Rms KA & KB Bldg Classroom KA	Manual	10/7/2025 7:15:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-059 184	Rms KA & KB Bldg Classroom KA	Manual	10/7/2025 7:15:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-043 186	Rms KA & KB Bldg Classroom KA	Manual	10/7/2025 7:15:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-058 187	Rms KA & KB Bldg Classroom KA	Manual	10/7/2025 7:15:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-056 198	Rms KA & KB Bldg Classroom KB	Manual	10/7/2025 7:08:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-051 197	Rms KA & KB Bldg Classroom KB	Manual	10/7/2025 7:08:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-052 196	Rms KA & KB Bldg Classroom KB	Manual	10/7/2025 7:08:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-055 195	Rms KA & KB Bldg Classroom KB	Manual	10/7/2025 7:08:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-053 193	Rms KA & KB Bldg Classroom KB	Manual	10/7/2025 7:12:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-054 194	Rms KA & KB Bldg Classroom KB	Manual	10/7/2025 7:12:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-045 192	Rms KA & KB Bldg Closet by Classroom KA	Manual	10/7/2025 7:13:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-050 201	Rms KA & KB Bldg Closet by Classroom KB	Manual	10/7/2025 7:15:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-151 202	Rms KA & KB Bldg Room KA HVAC Closet	Manual	10/7/2025 7:42:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-300 143	Rooms 14-18 Bldg Classroom 14	Manual	10/7/2025 6:53:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-305 144	Rooms 14-18 Bldg Classroom 14	Manual	10/7/2025 6:53:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-304 146	Rooms 14-18 Bldg Classroom 14	Manual	10/7/2025 6:53:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-301 145	Rooms 14-18 Bldg Classroom 14	Manual	10/7/2025 6:53:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-303 148	Rooms 14-18 Bldg Classroom 14	Manual	10/7/2025 6:53:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-302 147	Rooms 14-18 Bldg Classroom 14	Manual	10/7/2025 6:53:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-297 149	Rooms 14-18 Bldg Classroom 15	Manual	10/7/2025 6:53:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-308 150	Rooms 14-18 Bldg Classroom 15	Manual	10/7/2025 6:53:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-307 151	Rooms 14-18 Bldg Classroom 15	Manual	10/7/2025 6:53:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-298 152	Rooms 14-18 Bldg Classroom 15	Manual	10/7/2025 6:53:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-299 153	Rooms 14-18 Bldg Classroom 15	Manual	10/7/2025 6:53:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-306 154	Rooms 14-18 Bldg Classroom 15	Manual	10/7/2025 6:54:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-309 156	Rooms 14-18 Bldg Classroom 16	Manual	10/7/2025 6:54:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-296 155	Rooms 14-18 Bldg Classroom 16	Manual	10/7/2025 6:54:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-310 158	Rooms 14-18 Bldg Classroom 16	Manual	10/7/2025 6:54:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-295 157	Rooms 14-18 Bldg Classroom 16	Manual	10/7/2025 6:54:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-311 159	Rooms 14-18 Bldg Classroom 16	Manual	10/7/2025 6:54:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-294 160	Rooms 14-18 Bldg Classroom 16	Manual	10/7/2025 6:54:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-291 161	Rooms 14-18 Bldg Classroom 17	Manual	10/7/2025 6:54:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-314 162	Rooms 14-18 Bldg Classroom 17	Manual	10/7/2025 6:54:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-313 163	Rooms 14-18 Bldg Classroom 17	Manual	10/7/2025 6:54:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-312 165	Rooms 14-18 Bldg Classroom 17	Manual	10/7/2025 6:54:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-293 166	Rooms 14-18 Bldg Classroom 17	Manual	10/7/2025 6:54:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-292 164	Rooms 14-18 Bldg Classroom 17	Manual	10/7/2025 6:54:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-290 167	Rooms 14-18 Bldg Classroom 18	Manual	10/7/2025 6:54:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-315 168	Rooms 14-18 Bldg Classroom 18	Manual	10/7/2025 6:55:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-316 169	Rooms 14-18 Bldg Classroom 18	Manual	10/7/2025 6:55:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-289 170	Rooms 14-18 Bldg Classroom 18	Manual	10/7/2025 6:55:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-288 171	Rooms 14-18 Bldg Classroom 18	Manual	10/7/2025 6:55:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-317 172	Rooms 14-18 Bldg Classroom 18	Manual	10/7/2025 6:55:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-383 174	Rooms 14-18 Bldg Room 15 HVAC Closet	Manual	10/7/2025 7:41:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-384 175	Rooms 14-18 Bldg Room 16 HVAC Closet	Manual	10/7/2025 7:41:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-385 176	Rooms 14-18 Bldg Room 17 HVAC Closet	Manual	10/7/2025 7:41:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-386 177	Rooms 14-18 Bldg Room 18 HVAC Closet	Manual	10/7/2025 7:41:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-088 059	Rooms 4-8 Bldg Classroom 4	Manual	10/7/2025 6:55:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-087 061	Rooms 4-8 Bldg Classroom 4	Manual	10/7/2025 6:55:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-090 060	Rooms 4-8 Bldg Classroom 4	Manual	10/7/2025 6:55:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-086 063	Rooms 4-8 Bldg Classroom 4	Manual	10/7/2025 6:55:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-061 062	Rooms 4-8 Bldg Classroom 4	Manual	10/7/2025 6:55:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-064 064	Rooms 4-8 Bldg Classroom 5	Manual	10/7/2025 6:55:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-083 065	Rooms 4-8 Bldg Classroom 5	Manual	10/7/2025 6:55:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-084 067	Rooms 4-8 Bldg Classroom 5	Manual	10/7/2025 6:56:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-063 066	Rooms 4-8 Bldg Classroom 5	Manual	10/7/2025 6:56:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-085 068	Rooms 4-8 Bldg Classroom 5	Manual	10/7/2025 6:56:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-062 069	Rooms 4-8 Bldg Classroom 5	Manual	10/7/2025 6:56:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-065 070	Rooms 4-8 Bldg Classroom 6	Manual	10/7/2025 6:56:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-082 071	Rooms 4-8 Bldg Classroom 6	Manual	10/7/2025 6:56:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-081 072	Rooms 4-8 Bldg Classroom 6	Manual	10/7/2025 6:56:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-066 073	Rooms 4-8 Bldg Classroom 6	Manual	10/7/2025 6:56:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-080 074	Rooms 4-8 Bldg Classroom 6	Manual	10/7/2025 6:56:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-067 075	Rooms 4-8 Bldg Classroom 6	Manual	10/7/2025 6:56:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-070 076	Rooms 4-8 Bldg Classroom 7	Manual	10/7/2025 6:56:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-077 077	Rooms 4-8 Bldg Classroom 7	Manual	10/7/2025 6:56:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-069 079	Rooms 4-8 Bldg Classroom 7	Manual	10/7/2025 6:56:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-078 078	Rooms 4-8 Bldg Classroom 7	Manual	10/7/2025 6:56:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-079 081	Rooms 4-8 Bldg Classroom 7	Manual	10/7/2025 6:56:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-068 080	Rooms 4-8 Bldg Classroom 7	Manual	10/7/2025 6:56:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-071 082	Rooms 4-8 Bldg Classroom 8	Manual	10/7/2025 6:57:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-076 083	Rooms 4-8 Bldg Classroom 8	Manual	10/7/2025 6:57:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-072 085	Rooms 4-8 Bldg Classroom 8	Manual	10/7/2025 6:57:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-074 087	Rooms 4-8 Bldg Classroom 8	Manual	10/7/2025 6:57:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-073 086	Rooms 4-8 Bldg Classroom 8	Manual	10/7/2025 6:57:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-075 084	Rooms 4-8 Bldg Classroom 8	Manual	10/7/2025 6:57:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-103 088	Rooms 4-8 Bldg Cust Off By Rm 4	Manual	10/7/2025 6:50:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-139 089	Rooms 4-8 Bldg Room 4 HVAC Closet	Manual	10/7/2025 7:41:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-138 090	Rooms 4-8 Bldg Room 5 HVAC Closet	Manual	10/7/2025 7:41:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-137 091	Rooms 4-8 Bldg Room 6 HVAC Closet	Manual	10/7/2025 7:41:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-136 092	Rooms 4-8 Bldg Room 7 HVAC Closet	Manual	10/7/2025 7:41:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-135 093	Rooms 4-8 Bldg Room 8 HVAC Closet	Manual	10/7/2025 7:41:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-265 112	Rooms 9-13 Bldg Classroom 10	Manual	10/7/2025 6:51:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-274 111	Rooms 9-13 Bldg Classroom 10	Manual	10/7/2025 6:51:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-275 110	Rooms 9-13 Bldg Classroom 10	Manual	10/7/2025 6:51:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-264 109	Rooms 9-13 Bldg Classroom 10	Manual	10/7/2025 6:51:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-263 114	Rooms 9-13 Bldg Classroom 11	Manual	10/7/2025 6:51:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-276 113	Rooms 9-13 Bldg Classroom 11	Manual	10/7/2025 6:51:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-327 116	Rooms 9-13 Bldg Classroom 11	Manual	10/7/2025 6:52:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-277 118	Rooms 9-13 Bldg Classroom 11	Manual	10/7/2025 6:52:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-261 117	Rooms 9-13 Bldg Classroom 11	Manual	10/7/2025 6:52:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-262 115	Rooms 9-13 Bldg Classroom 11	Manual	10/7/2025 6:52:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-258 119	Rooms 9-13 Bldg Classroom 12	Manual	10/7/2025 6:52:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-280 120	Rooms 9-13 Bldg Classroom 12	Manual	10/7/2025 6:52:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-259 121	Rooms 9-13 Bldg Classroom 12	Manual	10/7/2025 6:52:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-279 122	Rooms 9-13 Bldg Classroom 12	Manual	10/7/2025 6:52:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-260 123	Rooms 9-13 Bldg Classroom 12	Manual	10/7/2025 6:52:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-278 124	Rooms 9-13 Bldg Classroom 12	Manual	10/7/2025 6:52:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-257 125	Rooms 9-13 Bldg Classroom 13	Manual	10/7/2025 6:52:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-281 126	Rooms 9-13 Bldg Classroom 13	Manual	10/7/2025 6:52:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-282 128	Rooms 9-13 Bldg Classroom 13	Manual	10/7/2025 6:52:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-256 127	Rooms 9-13 Bldg Classroom 13	Manual	10/7/2025 6:52:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-284 129	Rooms 9-13 Bldg Classroom 13	Manual	10/7/2025 6:53:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-283 130	Rooms 9-13 Bldg Classroom 13	Manual	10/7/2025 6:53:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-269 101	Rooms 9-13 Bldg Classroom 9	Manual	10/7/2025 6:50:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-270 102	Rooms 9-13 Bldg Classroom 9	Manual	10/7/2025 6:51:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-268 104	Rooms 9-13 Bldg Classroom 9	Manual	10/7/2025 6:51:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-271 103	Rooms 9-13 Bldg Classroom 9	Manual	10/7/2025 6:51:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-272 105	Rooms 9-13 Bldg Classroom 9	Manual	10/7/2025 6:51:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-267 106	Rooms 9-13 Bldg Classroom 9	Manual	10/7/2025 6:51:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-273 107	Rooms 9-13 Bldg Classroom 9 Office	Manual	10/7/2025 6:51:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-266 108	Rooms 9-13 Bldg Classroom 9 Office	Manual	10/7/2025 6:51:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-378 132	Rooms 9-13 Bldg Room 10 HVAC Closet	Manual	10/7/2025 7:41:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-379 133	Rooms 9-13 Bldg Room 11 HVAC Closet	Manual	10/7/2025 7:41:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-380 134	Rooms 9-13 Bldg Room 12 HVAC Closet	Manual	10/7/2025 7:41:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-381 135	Rooms 9-13 Bldg Room 13 HVAC Closet	Manual	10/7/2025 7:41:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-392 131	Rooms 9-13 Bldg Room 9 HVAC Closet	Manual	10/7/2025 7:41:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-376 225	Speech Building Attic Food Closet	Manual	10/7/2025 7:44:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-377 226	Speech Building Attic Speech Room	Manual	10/7/2025 7:43:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-252 222	Speech Building Food Closet	Manual	10/7/2025 6:50:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-254 224	Speech Building Speech Room	Manual	10/7/2025 6:50:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-253 223	Speech Building Storage by Speech	Manual	10/7/2025 6:50:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-143 252	Multi-Purpose Bldg Attic Walk-in Freezer	Manual	10/7/2025 7:44:22 PM
Heat Detector - Restorable Spot	2-382 173	Rooms 14-18 Bldg Room 14 HVAC Closet	Manual	10/7/2025 7:41:48 PM
	Comment:	Door is blocked		

Failed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-089 058	Rooms 4-8 Bldg Classroom 4	Manual	10/7/2025 7:55:58 PM
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	

Supervising Station Transmitting Equipment

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Digital Alarm Communicator Transmitter		Admin/Rms 1-3 Bldg Admin Server Room	Manual	10/7/2025 7:43:56 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Manufacturer	Bosch	
		Model	B9512G	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Monitoring Account Number	Central Station # 881-8015	
		Monitoring Organization	Central Station / SJUSD Dispatch	
		Monitoring Organization Phone	CS - 916-480-4836 / SJUSD Dispatch - 916-971-7000	

Device/Equipment details

Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Audible And Visible					
048	Admin/Rms 1-3 Bldg Reception				
049	Admin/Rms 1-3 Bldg Old Nurse Room				
050	Admin/Rms 1-3 Bldg Classroom 1				
051	Admin/Rms 1-3 Bldg Classroom 2				
052	Admin/Rms 1-3 Bldg Classroom 3				
096	Rooms 4-8 Bldg Classroom 4				
097	Rooms 4-8 Bldg Classroom 5				
098	Rooms 4-8 Bldg Classroom 6				
099	Rooms 4-8 Bldg Classroom 7				
100	Rooms 4-8 Bldg Classroom 8				
137	Rooms 9-13 Bldg Classroom 9				
138	Rooms 9-13 Bldg Classroom 10				
139	Rooms 9-13 Bldg Classroom 11				
140	Rooms 9-13 Bldg Classroom 12				
141	Rooms 9-13 Bldg Classroom 13				
179	Rooms 14-18 Bldg Classroom 14				
180	Rooms 14-18 Bldg Classroom 15				
181	Rooms 14-18 Bldg Classroom 16				
182	Rooms 14-18 Bldg Classroom 17				
183	Rooms 14-18 Bldg Classroom 18				
205	Rms KA & KB Bldg Classroom KA				
206	Rms KA & KB Bldg Classroom KB				
268	Multi-Purpose Bldg MP Room				
269	Multi-Purpose Bldg Kitchen				
Visible					
053	Admin/Rms 1-3 Bldg Office by Reception				
054	Admin/Rms 1-3 Bldg Directors Office				
055	Admin/Rms 1-3 Bldg Admin Office Hall				
056	Admin/Rms 1-3 Bldg Old Nurse Room				
057	Admin/Rms 1-3 Bldg Admin Work Room				
142	Rooms 9-13 Bldg Classroom 9 Office				
207	Rms KA & KB Bldg Classroom KA				
208	Rms KA & KB Bldg Classroom KB				
218	Restroom Bldgs Boys Restroom				
219	Restroom Bldgs Girls Restroom				
220	Restroom Bldgs Mens Restroom				
221	Restroom Bldgs Womens Restroom				
228	Speech Building Office by Speech Rm				
229	Speech Building Speech Room				
270	Multi-Purpose Bldg MP Room				
271	Multi-Purpose Bldg Stage				
272	Multi-Purpose Bldg Kitchen				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
273	Multi-Purpose Bldg Kitchen Restroom				
274	Multi-Purpose Bldg Kitchen Restroom				
275	Multi-Purpose Bldg Resource Room				
276	Multi-Purpose Bldg Mens Restroom				
277	Multi-Purpose Bldg Womens Restroom				

Audible

094	Rooms 4-8 Bldg North Exterior				
095	Rooms 4-8 Bldg West Exterior				
136	Rooms 9-13 Bldg North Exterior				
178	Rooms 14-18 Bldg North Exterior				
203	Rms KA & KB Bldg South Exterior				
204	Rms KA & KB Bldg West Exterior				
215	Restroom Bldgs East Exterior				
216	Restroom Bldgs East Exterior				
217	Restroom Bldgs West Exterior				
227	Speech Building West Exterior				
267	Multi-Purpose Bldg Northwest Exterior				

Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
---------	-------------	--------------	-------	--------	--------------

Remote Annunciator

001	Admin/Rms 1-3 Bldg Reception				
-----	------------------------------	--	--	--	--

Fire Alarm Panel

	Admin/Rms 1-3 Bldg Admin Server Room	EST	3		
--	--------------------------------------	-----	---	--	--

NAC Power Extender Panel

	Admin/Rms 1-3 Bldg Admin Server Room - P.E. "Master"				
	Admin/Rms 1-3 Bldg Admin Server Room - P.E. "B"				
	Admin/Rms 1-3 Bldg Admin Server Room - P.E. "C"				
	Speech Building Storage by Speech - P.E. "D"				
	Restroom Bldgs Storage by Restroom - P.E. "E"				

Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
---------	-------------	--------------	-------	--------	--------------

Heat Detector - Restorable Spot

2-134 046	Admin/Rms 1-3 Bldg Room 3 HVAC Closet				
2-139 089	Rooms 4-8 Bldg Room 4 HVAC Closet				
2-138 090	Rooms 4-8 Bldg Room 5 HVAC Closet				
2-137 091	Rooms 4-8 Bldg Room 6 HVAC Closet				
2-136 092	Rooms 4-8 Bldg Room 7 HVAC Closet				
2-135 093	Rooms 4-8 Bldg Room 8 HVAC Closet				
2-392 131	Rooms 9-13 Bldg Room 9 HVAC Closet				
2-378 132	Rooms 9-13 Bldg Room 10 HVAC Closet				
2-379 133	Rooms 9-13 Bldg Room 11 HVAC Closet				
2-380 134	Rooms 9-13 Bldg Room 12 HVAC Closet				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-381 135	Rooms 9-13 Bldg Room 13 HVAC Closet				
2-382 173	Rooms 14-18 Bldg Room 14 HVAC Closet				
2-383 174	Rooms 14-18 Bldg Room 15 HVAC Closet				
2-384 175	Rooms 14-18 Bldg Room 16 HVAC Closet				
2-385 176	Rooms 14-18 Bldg Room 17 HVAC Closet				
2-386 177	Rooms 14-18 Bldg Room 18 HVAC Closet				
2-151 202	Rms KA & KB Bldg Room KA HVAC Closet				
2-376 225	Speech Building Attic Food Closet				
2-377 226	Speech Building Attic Speech Room				
2-096 240	Multi-Purpose Bldg Kitchen Storage				
2-102 245	Multi-Purpose Bldg Kitchen				
2-101 246	Multi-Purpose Bldg Kitchen				
2-099 247	Multi-Purpose Bldg Kitchen				
2-100 248	Multi-Purpose Bldg Kitchen				
2-141 249	Multi-Purpose Bldg Attic Kitchen				
2-141 250	Multi-Purpose Bldg Attic Kitchen				
2-141 251	Multi-Purpose Bldg Attic Kitchen				
2-143 252	Multi-Purpose Bldg Attic Walk-in Freezer				
2-003 041	Admin/Rms 1-3 Bldg Admin Server Room				
2-130 042	Admin/Rms 1-3 Bldg Attic Hall Restroom				
2-131 043	Admin/Rms 1-3 Bldg Attic Old Nurse RR				
2-132 044	Admin/Rms 1-3 Bldg Room 1 HVAC Closet				
2-133 045	Admin/Rms 1-3 Bldg Room 2 HVAC Closet				
Smoke Detector - Duct					
2-140 047	Admin/Rms 1-3 Bldg Old Nurse Room				
2-153 266	Multi-Purpose Bldg Boiler Room				
Smoke Detector - General					
2-089 058	Rooms 4-8 Bldg Classroom 4				
2-088 059	Rooms 4-8 Bldg Classroom 4				
2-090 060	Rooms 4-8 Bldg Classroom 4				
2-087 061	Rooms 4-8 Bldg Classroom 4				
2-061 062	Rooms 4-8 Bldg Classroom 4				
2-086 063	Rooms 4-8 Bldg Classroom 4				
2-064 064	Rooms 4-8 Bldg Classroom 5				
2-083 065	Rooms 4-8 Bldg Classroom 5				
2-063 066	Rooms 4-8 Bldg Classroom 5				
2-084 067	Rooms 4-8 Bldg Classroom 5				
2-085 068	Rooms 4-8 Bldg Classroom 5				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-062 069	Rooms 4-8 Bldg Classroom 5				
2-065 070	Rooms 4-8 Bldg Classroom 6				
2-082 071	Rooms 4-8 Bldg Classroom 6				
2-081 072	Rooms 4-8 Bldg Classroom 6				
2-066 073	Rooms 4-8 Bldg Classroom 6				
2-080 074	Rooms 4-8 Bldg Classroom 6				
2-067 075	Rooms 4-8 Bldg Classroom 6				
2-070 076	Rooms 4-8 Bldg Classroom 7				
2-077 077	Rooms 4-8 Bldg Classroom 7				
2-078 078	Rooms 4-8 Bldg Classroom 7				
2-069 079	Rooms 4-8 Bldg Classroom 7				
2-068 080	Rooms 4-8 Bldg Classroom 7				
2-079 081	Rooms 4-8 Bldg Classroom 7				
2-071 082	Rooms 4-8 Bldg Classroom 8				
2-076 083	Rooms 4-8 Bldg Classroom 8				
2-075 084	Rooms 4-8 Bldg Classroom 8				
2-072 085	Rooms 4-8 Bldg Classroom 8				
2-073 086	Rooms 4-8 Bldg Classroom 8				
2-074 087	Rooms 4-8 Bldg Classroom 8				
2-103 088	Rooms 4-8 Bldg Cust Off By Rm 4				
2-269 101	Rooms 9-13 Bldg Classroom 9				
2-270 102	Rooms 9-13 Bldg Classroom 9				
2-271 103	Rooms 9-13 Bldg Classroom 9				
2-268 104	Rooms 9-13 Bldg Classroom 9				
2-272 105	Rooms 9-13 Bldg Classroom 9				
2-267 106	Rooms 9-13 Bldg Classroom 9				
2-273 107	Rooms 9-13 Bldg Classroom 9 Office				
2-266 108	Rooms 9-13 Bldg Classroom 9 Office				
2-264 109	Rooms 9-13 Bldg Classroom 10				
2-275 110	Rooms 9-13 Bldg Classroom 10				
2-274 111	Rooms 9-13 Bldg Classroom 10				
2-265 112	Rooms 9-13 Bldg Classroom 10				
2-276 113	Rooms 9-13 Bldg Classroom 11				
2-263 114	Rooms 9-13 Bldg Classroom 11				
2-262 115	Rooms 9-13 Bldg Classroom 11				
2-327 116	Rooms 9-13 Bldg Classroom 11				
2-261 117	Rooms 9-13 Bldg Classroom 11				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-277 118	Rooms 9-13 Bldg Classroom 11				
2-258 119	Rooms 9-13 Bldg Classroom 12				
2-280 120	Rooms 9-13 Bldg Classroom 12				
2-259 121	Rooms 9-13 Bldg Classroom 12				
2-279 122	Rooms 9-13 Bldg Classroom 12				
2-260 123	Rooms 9-13 Bldg Classroom 12				
2-278 124	Rooms 9-13 Bldg Classroom 12				
2-257 125	Rooms 9-13 Bldg Classroom 13				
2-281 126	Rooms 9-13 Bldg Classroom 13				
2-256 127	Rooms 9-13 Bldg Classroom 13				
2-282 128	Rooms 9-13 Bldg Classroom 13				
2-284 129	Rooms 9-13 Bldg Classroom 13				
2-283 130	Rooms 9-13 Bldg Classroom 13				
2-300 143	Rooms 14-18 Bldg Classroom 14				
2-305 144	Rooms 14-18 Bldg Classroom 14				
2-301 145	Rooms 14-18 Bldg Classroom 14				
2-304 146	Rooms 14-18 Bldg Classroom 14				
2-302 147	Rooms 14-18 Bldg Classroom 14				
2-303 148	Rooms 14-18 Bldg Classroom 14				
2-297 149	Rooms 14-18 Bldg Classroom 15				
2-308 150	Rooms 14-18 Bldg Classroom 15				
2-307 151	Rooms 14-18 Bldg Classroom 15				
2-298 152	Rooms 14-18 Bldg Classroom 15				
2-299 153	Rooms 14-18 Bldg Classroom 15				
2-306 154	Rooms 14-18 Bldg Classroom 15				
2-296 155	Rooms 14-18 Bldg Classroom 16				
2-309 156	Rooms 14-18 Bldg Classroom 16				
2-295 157	Rooms 14-18 Bldg Classroom 16				
2-310 158	Rooms 14-18 Bldg Classroom 16				
2-311 159	Rooms 14-18 Bldg Classroom 16				
2-294 160	Rooms 14-18 Bldg Classroom 16				
2-291 161	Rooms 14-18 Bldg Classroom 17				
2-314 162	Rooms 14-18 Bldg Classroom 17				
2-313 163	Rooms 14-18 Bldg Classroom 17				
2-292 164	Rooms 14-18 Bldg Classroom 17				
2-312 165	Rooms 14-18 Bldg Classroom 17				
2-293 166	Rooms 14-18 Bldg Classroom 17				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-290 167	Rooms 14-18 Bldg Classroom 18				
2-315 168	Rooms 14-18 Bldg Classroom 18				
2-316 169	Rooms 14-18 Bldg Classroom 18				
2-289 170	Rooms 14-18 Bldg Classroom 18				
2-288 171	Rooms 14-18 Bldg Classroom 18				
2-317 172	Rooms 14-18 Bldg Classroom 18				
2-059 184	Rms KA & KB Bldg Classroom KA				
2-060 185	Rms KA & KB Bldg Classroom KA				
2-043 186	Rms KA & KB Bldg Classroom KA				
2-058 187	Rms KA & KB Bldg Classroom KA				
2-044 188	Rms KA & KB Bldg Classroom KA				
2-057 189	Rms KA & KB Bldg Classroom KA				
2-046 190	Rms KA & KB Bldg Classrm KA Restroom				
2-047 191	Rms KA & KB Bldg Classrm KA Restroom				
2-045 192	Rms KA & KB Bldg Closet by Classroom KA				
2-053 193	Rms KA & KB Bldg Classroom KB				
2-054 194	Rms KA & KB Bldg Classroom KB				
2-055 195	Rms KA & KB Bldg Classroom KB				
2-052 196	Rms KA & KB Bldg Classroom KB				
2-051 197	Rms KA & KB Bldg Classroom KB				
2-056 198	Rms KA & KB Bldg Classroom KB				
2-048 199	Rms KA & KB Bldg Classrm KB Restroom				
2-049 200	Rms KA & KB Bldg Classrm KB Restroom				
2-050 201	Rms KA & KB Bldg Closet by Classroom KB				
2-034 209	Restroom Bldgs Boys Restroom				
2-035 210	Restroom Bldgs Storage by Restroom				
2-036 211	Restroom Bldgs Girls Restroom				
2-285 212	Restroom Bldgs Mens Restroom				
2-286 213	Restroom Bldgs Storage by Restroom				
2-287 214	Restroom Bldgs Womens Restroom				
2-252 222	Speech Building Food Closet				
2-253 223	Speech Building Storage by Speech				
2-254 224	Speech Building Speech Room				
2-111 233	Multi-Purpose Bldg Stage				
2-110 234	Multi-Purpose Bldg Stage				
2-109 235	Multi-Purpose Bldg Stage				
2-108 236	Multi-Purpose Bldg Storage by Stage				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-092 237	Multi-Purpose Bldg Kitchen Storage				
2-098 238	Multi-Purpose Bldg Kitchen Restroom				
2-091 239	Multi-Purpose Bldg Kitchen Restroom				
2-097 241	Multi-Purpose Bldg Boiler Room				
2-093 242	Multi-Purpose Bldg Resource Room				
2-094 243	Multi-Purpose Bldg Womens Restroom				
2-095 244	Multi-Purpose Bldg Mens Restroom				
2-014 003	Admin/Rms 1-3 Bldg Office by Reception				
2-012 004	Admin/Rms 1-3 Bldg Reception				
2-011 005	Admin/Rms 1-3 Bldg Reception				
2-010 006	Admin/Rms 1-3 Bldg Reception				
2-007 007	Admin/Rms 1-3 Bldg Office Closet				
2-006 008	Admin/Rms 1-3 Bldg Directors Office				
2-005 009	Admin/Rms 1-3 Bldg Directors Office				
2-115 010	Admin/Rms 1-3 Bldg Directors Off Closet				
2-008 011	Admin/Rms 1-3 Bldg Admin Office Hall				
2-009 012	Admin/Rms 1-3 Bldg Admin Office Hall				
2-004 013	Admin/Rms 1-3 Bldg Hall Restroom				
2-017 014	Admin/Rms 1-3 Bldg Old Nurse Room				
2-016 015	Admin/Rms 1-3 Bldg Old Nurse Room				
2-015 016	Admin/Rms 1-3 Bldg Old Nurse Room				
2-013 017	Admin/Rms 1-3 Bldg Old Nurse Restroom				
2-002 018	Admin/Rms 1-3 Bldg Admin Server Room				
2-018 019	Admin/Rms 1-3 Bldg Admin Work Room				
2-019 020	Admin/Rms 1-3 Bldg Admin Work Room				
2-020 021	Admin/Rms 1-3 Bldg Admin Work Room				
2-042 022	Admin/Rms 1-3 Bldg Classroom 1				
2-022 023	Admin/Rms 1-3 Bldg Classroom 1				
2-023 024	Admin/Rms 1-3 Bldg Classroom 1				
2-041 025	Admin/Rms 1-3 Bldg Classroom 1				
2-040 026	Admin/Rms 1-3 Bldg Classroom 1				
2-024 027	Admin/Rms 1-3 Bldg Classroom 1				
2-021 028	Admin/Rms 1-3 Bldg Classroom 1 Closet				
2-037 029	Admin/Rms 1-3 Bldg Classroom 2				
2-027 030	Admin/Rms 1-3 Bldg Classroom 2				
2-038 031	Admin/Rms 1-3 Bldg Classroom 2				
2-026 032	Admin/Rms 1-3 Bldg Classroom 2				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-039 033	Admin/Rms 1-3 Bldg Classroom 2				
2-025 034	Admin/Rms 1-3 Bldg Classroom 2				
2-033 035	Admin/Rms 1-3 Bldg Classroom 3				
2-028 036	Admin/Rms 1-3 Bldg Classroom 3				
2-029 037	Admin/Rms 1-3 Bldg Classroom 3				
2-032 038	Admin/Rms 1-3 Bldg Classroom 3				
2-030 039	Admin/Rms 1-3 Bldg Classroom 3				
2-031 040	Admin/Rms 1-3 Bldg Classroom 3				

Manual Pull Station

2-160 230	Multi-Purpose Bldg MP Room NW				
2-159 231	Multi-Purpose Bldg MP Room SW				
2-158 232	Multi-Purpose Bldg MP Room SE				
2-144 002	Admin/Rms 1-3 Bldg Reception				

Smoke Detector - Projected Beam

2-145 263	Multi-Purpose Bldg MP Room Left				
2-147 264	Multi-Purpose Bldg MP Room Center				
2-149 265	Multi-Purpose Bldg MP Room Right				

Supervising Station Transmitting Equipment

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Digital Alarm Communicator Transmitter					
	Admin/Rms 1-3 Bldg Admin Server Room	Bosch	B9512G		