

Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

WOODSIDE ELEMENTARY

8248 VILLA OAK DR
CITRUS HEIGHTS, California
United States

This site has been inspected and tested in compliance with applicable standards.

Completed

Thursday, October 30, 2025

Test Session:09 Oct 2025 12:31 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD
5320 HEMLOCK ST
SACRAMENTO, California
United States

TESTED BY

Riley Goyet
Western States Fire Protection-
Sacramento
188 Cirby Way
Roseville, CA 95678
United States



Inspection Summary

Building Information

PROPERTY	WOODSIDE ELEMENTARY	CONTACT
ADDRESS	8248 VILLA OAK DR	PHONE
CITY/STATE	CITRUS HEIGHTS, California	MOBILE
COUNTRY	United States	EMAIL

Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us

Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Alarm Notification Appliance	77	77(100%)	77(100%)	0(0%)
Power Supplies	8	8(100%)	8(100%)	0(0%)
Fire Control Panel	9	9(100%)	9(100%)	0(0%)
Initiating Device	165	165(100%)	164(99%)	1(1%)

Certification

The equipment specified here in was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Thursday, October 30, 2025

ACCEPTED BY 10/30/2025

Building Representative


TESTED BY 10/30/2025
Riley Goyet
Technician

System Details

Control Units

ADDRESS/ SCAN ADDRESS		DESCRIPTION	Building A Room A7A MDF
MANUFACTURER	EST	S/W VERSION	
MODEL	3	LAST UPDATE	
SERIAL NUMBER		S/W LOCATION	
INSTALL DATE			

Secondary Power

TYPE	Battery - Sealed Lead-acid	DESCRIPTION	Building A Room A7A MDF - FACP
ADDRESS/ SCAN ADDRESS		NOMINAL VOLTAGE	12
Load Voltage		Amp Hours	55
Standby Hours		Alarm Minutes	
Battery Location		Charger Voltage	
TYPE	Battery - Sealed Lead-acid	DESCRIPTION	Building A Room A7A MDF - P.E. "B"
ADDRESS/ SCAN ADDRESS		NOMINAL VOLTAGE	12
Load Voltage		Amp Hours	8
Standby Hours		Alarm Minutes	
Battery Location		Charger Voltage	
TYPE	Battery - Sealed Lead-acid	DESCRIPTION	Building A Room A7A MDF - P.E. "H"
ADDRESS/ SCAN ADDRESS		NOMINAL VOLTAGE	12
Load Voltage		Amp Hours	8
Standby Hours		Alarm Minutes	
Battery Location		Charger Voltage	
TYPE	Battery - Sealed Lead-acid	DESCRIPTION	Building A Room A7A MDF - P.E. "Master"
ADDRESS/ SCAN ADDRESS		NOMINAL VOLTAGE	12
Load Voltage		Amp Hours	8
Standby Hours		Alarm Minutes	
Battery Location		Charger Voltage	
TYPE	Battery - Sealed Lead-acid	DESCRIPTION	Building B MP Cust Office B4 - P.E. "G"
ADDRESS/ SCAN ADDRESS		NOMINAL VOLTAGE	12
Load Voltage		Amp Hours	8
Standby Hours		Alarm Minutes	
Battery Location		Charger Voltage	
TYPE	Battery - Sealed Lead-acid	DESCRIPTION	Building C Room C5A - P.E. "C"
ADDRESS/ SCAN ADDRESS		NOMINAL VOLTAGE	12
Load Voltage		Amp Hours	8
Standby Hours		Alarm Minutes	
Battery Location		Charger Voltage	
TYPE	Battery - Sealed Lead-acid	DESCRIPTION	Building D Room D6A - P.E. - "D"
ADDRESS/ SCAN ADDRESS		NOMINAL VOLTAGE	12
Load Voltage		Amp Hours	8

Standby Hours

Alarm Minutes

Battery Location

Charger Voltage

TYPE

Battery - Sealed Lead-acid

DESCRIPTION

Building F F1C Closet - P.E. "F"

ADDRESS/ SCAN ADDRESS

NOMINAL VOLTAGE

12

Load Voltage

Amp Hours

8

Standby Hours

Alarm Minutes

Battery Location

Charger Voltage

Open Corrective Action & Solution Summary

The following 1 corrective action(s) remain open following the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
Manual Pull Station	2-377 103	Building B MP Room NE

Created By: Riley Goyet
Creation Date: 10/14/2025
Corrective Action: Key broke off inside pull. FCI Model MS-2
Proposed Solution:
Manufacturer:
Model:



Resolved Corrective Action & Solution Summary

The following 1 corrective action(s) were resolved during the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
Battery - Sealed Lead-acid		Building F F1C Closet - P.E. "F"

Created By: Riley Goyet
Creation Date: 11/11/2024
Corrective Action: Replace (2) 12V 8AH Batteries
Resolution:
Resolved By: Riley Goyet
Resolved On: 10/30/2025
Manufacturer:
Model:

Testing Details

Alarm Notification Appliance

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible	079	Building A Conference Rm A1B	Manual	10/9/2025 12:34:01 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	067	Building A Main Office A1	Manual	10/9/2025 12:34:03 PM
		Functional Inspection	Passed	
Audible	063	Building A Northeast Exterior	Manual	10/9/2025 12:33:31 PM
		Visual inspection	Passed (Manual)	
Audible	097	Building A Northeast Exterior - Electric Bell	Manual	10/9/2025 12:33:24 PM
		Functional Inspection	Passed	
Audible	066	Building A Northwest Exterior	Manual	10/9/2025 12:33:58 PM
		Visual inspection	Passed (Manual)	
Visible	082	Building A Nurses Office A1E	Manual	10/9/2025 12:33:48 PM
		Functional Inspection	Passed	
Visible	083	Building A Nurses Office RR	Manual	10/9/2025 12:33:47 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	068	Building A Office Hallway	Manual	10/9/2025 12:33:59 PM
		Functional Inspection	Passed	
Visible	081	Building A Office Restroom A1D	Manual	10/9/2025 12:33:45 PM
		Visual inspection	Passed (Manual)	
Visible	078	Building A Principals Office A1A	Manual	10/9/2025 12:33:49 PM
		Functional Inspection	Passed	
Visible	094	Building A Rm A11A Restroom	Manual	10/9/2025 12:33:29 PM
		Visual inspection	Passed (Manual)	
Visible	095	Building A Rm A13A Restroom	Manual	10/9/2025 12:33:26 PM
		Functional Inspection	Passed	
Visible	080	Building A Rm A1C Copier Rm	Manual	10/9/2025 12:33:51 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	072	Building A Rm A6 Media Center	Manual	10/9/2025 12:34:04 PM
		Functional Inspection	Passed	
Visible	085	Building A Rm A6 Media Center	Manual	10/9/2025 12:33:40 PM
		Visual inspection	Passed (Manual)	
Visible	089	Building A Rm A7C Boys RR	Manual	10/9/2025 12:33:38 PM
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible	090	Building A Rm A9A Girls RR	Manual	10/9/2025 12:33:37 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Visible	092	Building A Room A10	Manual	10/9/2025 12:33:34 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	075	Building A Room A11	Manual	10/9/2025 12:34:12 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Visible	093	Building A Room A11 North	Manual	10/9/2025 12:33:32 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	076	Building A Room A13	Manual	10/9/2025 12:33:57 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Visible	096	Building A Room A14	Manual	10/9/2025 12:33:27 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	077	Building A Room A15	Manual	10/9/2025 12:33:53 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	070	Building A Room A3	Manual	10/9/2025 12:34:10 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Visible	084	Building A Room A4	Manual	10/9/2025 12:33:35 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	071	Building A Room A5	Manual	10/9/2025 12:34:07 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	073	Building A Room A6B Speech	Manual	10/9/2025 12:34:13 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Visible	086	Building A Room A6D	Manual	10/9/2025 12:33:42 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Visible	087	Building A Room A7	Manual	10/9/2025 12:33:44 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Visible	088	Building A Room A7 Hallway	Manual	10/9/2025 12:33:41 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	074	Building A Room A9	Manual	10/9/2025 12:34:05 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Visible	091	Building A Room A9B Hallway	Manual	10/9/2025 12:33:22 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible	064	Building A Southeast Exterior	Manual	10/9/2025 12:33:55 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible	065	Building A Southwest Exterior	Manual	10/9/2025 12:33:52 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	069	Building A Work Room A2	Manual	10/9/2025 12:34:08 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	137	Building B MP Boys RR B1A	Manual	10/9/2025 12:33:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	140	Building B MP Coach Office B3B	Manual	10/9/2025 12:33:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	138	Building B MP Girls RR B1B	Manual	10/9/2025 12:33:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	135	Building B MP Kitchen B2	Manual	10/9/2025 12:33:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	136	Building B MP Rm B1 SW Entry	Manual	10/9/2025 12:33:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	134	Building B MP Room B1	Manual	10/9/2025 12:33:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	132	Building B MP Room B1	Manual	10/9/2025 12:33:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	133	Building B MP Room B1	Manual	10/9/2025 12:33:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	131	Building B MP Room B1	Manual	10/9/2025 12:33:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	139	Building B MP Stage B3	Manual	10/9/2025 12:33:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	130	Building B Northeast Exterior	Manual	10/9/2025 12:33:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	129	Building B Northwest Exterior	Manual	10/9/2025 12:33:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	141	Building B Southeast Exterior - Electric Bell	Manual	10/9/2025 12:33:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Building C Exterior of Room C3	Manual	10/9/2025 12:34:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	170	Building C Room C1	Manual	10/9/2025 12:33:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	171	Building C Room C2	Manual	10/9/2025 12:32:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	172	Building C Room C3	Manual	10/9/2025 12:32:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	173	Building C Room C4	Manual	10/9/2025 12:32:55 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Audible And Visible	174	Building C Room C5	Manual	10/9/2025 12:32:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	169	Building C West Exterior	Manual	10/9/2025 12:33:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	207	Building D North Exterior	Manual	10/9/2025 12:32:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	210	Building D Room D1	Manual	10/9/2025 12:32:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	211	Building D Room D2	Manual	10/9/2025 12:32:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	212	Building D Room D3	Manual	10/9/2025 12:32:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	213	Building D Room D4	Manual	10/9/2025 12:32:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	214	Building D Room D5	Manual	10/9/2025 12:32:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	215	Building D Room D6	Manual	10/9/2025 12:32:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	208	Building D Southwest Exterior	Manual	10/9/2025 12:32:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	209	Building D West Exterior	Manual	10/9/2025 12:32:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	220	Building E Boys Restroom	Manual	10/9/2025 12:32:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	221	Building E Girls Restroom	Manual	10/9/2025 12:32:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	219	Building E North Exterior	Manual	10/9/2025 12:32:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	239	Building F East Exterior	Manual	10/9/2025 12:32:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	243	Building F F1A Girls Restroom	Manual	10/9/2025 12:32:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	244	Building F F1B Hallway	Manual	10/9/2025 12:32:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	246	Building F F4A Boys Restroom	Manual	10/9/2025 12:32:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible	247	Building F F4B Hallway	Manual	10/9/2025 12:32:22 PM
		Visual inspection	Passed (Manual)	
Audible	248	Building F Northeast Exterior - Electric Bell	Manual	10/9/2025 12:32:20 PM
		Visual inspection	Passed (Manual)	
Visible	242	Building F Room F1	Manual	10/9/2025 12:32:29 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	240	Building F Room F2	Manual	10/9/2025 12:32:34 PM
		Visual inspection	Passed (Manual)	
Visible	245	Building F Room F3	Manual	10/9/2025 12:32:25 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	241	Building F Room F4	Manual	10/9/2025 12:32:31 PM
		Visual inspection	Passed (Manual)	

Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Remote Annunciator	001	Building A Main Office A1	Manual	10/30/2025 9:56:46 AM
		Visual inspection	Passed (Manual)	
Fire Alarm Panel		Building A Room A7A MDF	Manual	10/30/2025 9:56:45 AM
		Manufacturer	EST	
NAC Power Extender Panel	099	Building A Room A7A MDF - P.E. "B"	Manual	10/30/2025 9:56:39 AM
		Visual inspection	Passed (Manual)	
NAC Power Extender Panel	100	Building A Room A7A MDF - P.E. "H"	Manual	10/30/2025 9:56:38 AM
		Visual inspection	Passed (Manual)	
NAC Power Extender Panel	098	Building A Room A7A MDF - P.E. "Master"	Manual	10/30/2025 9:56:41 AM
		Visual inspection	Passed (Manual)	
NAC Power Extender Panel	142	Building B MP Cust Office B4 - P.E. "G"	Manual	10/30/2025 9:56:34 AM
		Visual inspection	Passed (Manual)	
NAC Power Extender Panel	175	Building C Room C5A - P.E. "C"	Manual	10/30/2025 9:56:32 AM
		Visual inspection	Passed (Manual)	
NAC Power Extender Panel	216	Building D Room D6A - P.E. - "D"	Manual	10/30/2025 9:56:35 AM
		Visual inspection	Passed (Manual)	
NAC Power Extender Panel	249	Building F F1C Closet - P.E. "F"	Manual	10/30/2025 9:56:42 AM
		Visual inspection	Passed (Manual)	

Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
----------------	---------	-------------	--------	-----------

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-057 005	Building A Conference Rm A1B	Manual	10/30/2025 9:57:37 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Manual Pull Station	2-145 002	Building A Main Office A1	Manual	10/9/2025 2:27:02 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-026 003	Building A Main Office A1	Manual	10/30/2025 9:57:32 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-076 007	Building A Nurses Office A1E	Manual	10/30/2025 9:57:30 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-075 008	Building A Nurses Office RR	Manual	10/30/2025 9:57:29 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-073 009	Building A Office Hallway	Manual	10/30/2025 9:57:34 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-074 006	Building A Office Restroom A1D	Manual	10/30/2025 9:57:33 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-072 004	Building A Principals Office A1A	Manual	10/30/2025 9:57:36 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-043 049	Building A Rm A11A Restroom	Manual	10/30/2025 9:56:59 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-044 050	Building A Rm A12 Electrical	Manual	10/30/2025 9:57:21 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-047 053	Building A Rm A13A Restroom	Manual	10/30/2025 9:57:01 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-071 058	Building A Rm A1C Copier Rm	Manual	10/9/2025 1:52:34 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - Duct	2-146 060	Building A Rm A1C Copier Rm	Manual	10/30/2025 9:57:18 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-065 017	Building A Rm A4C Girls RR	Manual	10/30/2025 9:56:50 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-064 018	Building A Rm A4C1 Custodial	Manual	10/30/2025 9:57:10 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-063 021	Building A Rm A5A Boys RR	Manual	10/30/2025 9:57:11 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-061 022	Building A Rm A5B Hallway	Manual	10/30/2025 9:57:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-052 026	Building A Rm A6 Media Center	Manual	10/30/2025 9:57:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-051 028	Building A Rm A6 Media Center	Manual	10/30/2025 9:57:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-050 029	Building A Rm A6 Media Center	Manual	10/30/2025 9:57:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-053 027	Building A Rm A6 Media Center	Manual	10/30/2025 9:58:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-059 024	Building A Rm A6 Media Cnt Hall	Manual	10/30/2025 9:58:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-058 025	Building A Rm A6 Media Cnt Hall	Manual	10/30/2025 9:58:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-056 030	Building A Rm A6A Speech Closet	Manual	10/30/2025 9:58:01 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-034 037	Building A Rm A7C Boys RR	Manual	10/30/2025 9:58:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-035 038	Building A Rm A8 Custodial	Manual	10/30/2025 9:56:36 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-036 041	Building A Rm A9A Girls RR	Manual	10/30/2025 9:58:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-092 045	Building A Room A10	Manual	10/30/2025 9:58:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-040 044	Building A Room A10	Manual	10/30/2025 9:58:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-045 048	Building A Room A11 North	Manual	10/30/2025 9:56:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-042 047	Building A Room A11 North	Manual	10/30/2025 9:56:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-041 046	Building A Room A11 South	Manual	10/30/2025 9:57:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-049 052	Building A Room A13 North	Manual	10/30/2025 9:56:48 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-048 051	Building A Room A13 South	Manual	10/30/2025 9:57:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-077 055	Building A Room A14	Manual	10/30/2025 9:57:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-088 054	Building A Room A14	Manual	10/30/2025 9:57:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-089 057	Building A Room A15	Manual	10/30/2025 9:58:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-046 056	Building A Room A15	Manual	10/30/2025 9:58:19 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-069 012	Building A Room A3	Manual	10/30/2025 9:57:44 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-085 011	Building A Room A3 South	Manual	10/30/2025 9:57:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-086 013	Building A Room A4	Manual	10/30/2025 9:57:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-068 014	Building A Room A4	Manual	10/30/2025 9:57:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	2-130 061	Building A Room A4A Closet	Manual	10/30/2025 9:56:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-067 015	Building A Room A4A Closet	Manual	10/30/2025 9:56:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Valve Tamper Switch	2-131 062	Building A Room A4A Closet	Manual	10/30/2025 9:56:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-066 016	Building A Room A4B Hallway	Manual	10/30/2025 9:56:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-062 019	Building A Room A5	Manual	10/30/2025 9:57:55 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-087 020	Building A Room A5	Manual	10/30/2025 9:57:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-060 023	Building A Room A5C Closet	Manual	10/30/2025 9:57:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-054 031	Building A Room A6B Speech	Manual	10/30/2025 9:58:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-055 032	Building A Room A6D	Manual	10/30/2025 9:58:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-033 033	Building A Room A7	Manual	10/30/2025 9:58:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-090 034	Building A Room A7	Manual	10/30/2025 9:58:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-032 036	Building A Room A7 Hallway	Manual	10/30/2025 9:58:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-031 059	Building A Room A7A MDF	Manual	10/9/2025 1:52:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-001 035	Building A Room A7A MDF	Manual	10/30/2025 9:58:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-039 039	Building A Room A9	Manual	10/30/2025 9:58:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-091 040	Building A Room A9	Manual	10/30/2025 9:58:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-037 042	Building A Room A9B Hallway	Manual	10/30/2025 9:58:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-038 043	Building A Room A9C Closet	Manual	10/30/2025 9:58:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-070 010	Building A Work Room A2	Manual	10/30/2025 9:57:39 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-390 125	Building B HVAC East Roof	Manual	10/30/2025 9:57:20 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-387 126	Building B HVAC MP B1 S?	Manual	10/30/2025 9:57:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-277 116	Building B Kitchen Storage B2	Manual	10/30/2025 10:00:30 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-279 110	Building B MP B1 North Middle	Manual	10/30/2025 10:00:27 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-280 109	Building B MP B1 Northeast	Manual	10/30/2025 10:00:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-278 111	Building B MP B1 Northwest	Manual	10/30/2025 10:00:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-288 107	Building B MP B1 South Middle	Manual	10/30/2025 10:00:16 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-287 108	Building B MP B1 Southeast	Manual	10/30/2025 10:00:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-289 106	Building B MP B1 Southwest	Manual	10/30/2025 10:00:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-272 112	Building B MP Boys RR B1A	Manual	10/30/2025 10:00:35 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-281 115	Building B MP Chair Storage B1D	Manual	10/30/2025 10:00:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-286 120	Building B MP Coach Office B3B	Manual	10/30/2025 10:00:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	2-388 127	Building B MP Cust Office B4	Manual	10/30/2025 9:53:32 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-290 122	Building B MP Cust Office B4	Manual	10/30/2025 9:58:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Valve Tamper Switch	2-389 128	Building B MP Cust Office B4	Manual	10/30/2025 9:56:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-273 114	Building B MP Custodian B1C	Manual	10/30/2025 10:00:32 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-274 113	Building B MP Girls RR B1B	Manual	10/30/2025 10:00:33 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-276 123	Building B MP Kitchen B2	Manual	10/9/2025 2:10:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-275 124	Building B MP Mech Rm South	Manual	10/9/2025 2:10:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-282 121	Building B MP Prop Storage B3C	Manual	10/30/2025 10:00:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-378 104	Building B MP Room NW	Manual	10/9/2025 2:26:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-379 102	Building B MP Room SE	Manual	10/9/2025 2:26:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-381 105	Building B MP Room Stage	Manual	10/9/2025 2:26:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-380 101	Building B MP Room SW	Manual	10/9/2025 2:26:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-283 117	Building B MP Stage B3 North	Manual	10/30/2025 10:00:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-284 118	Building B MP Stage B3 South	Manual	10/30/2025 10:00:10 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-285 119	Building B MP Stage Closet B3A	Manual	10/30/2025 10:00:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-144 154	Building C Attic Room C1	Manual	10/9/2025 1:53:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-144 155	Building C Attic Room C1	Manual	10/9/2025 1:53:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-144 156	Building C Attic Room C1	Manual	10/9/2025 1:53:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-143 157	Building C Attic Room C2	Manual	10/9/2025 1:53:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-143 158	Building C Attic Room C2	Manual	10/9/2025 1:53:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-143 159	Building C Attic Room C2	Manual	10/9/2025 1:53:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-142 160	Building C Attic Room C3	Manual	10/9/2025 1:53:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-142 161	Building C Attic Room C3	Manual	10/9/2025 1:53:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-142 162	Building C Attic Room C3	Manual	10/9/2025 1:53:06 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-141 163	Building C Attic Room C4	Manual	10/9/2025 1:52:56 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-141 164	Building C Attic Room C4	Manual	10/9/2025 1:52:58 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-141 165	Building C Attic Room C4	Manual	10/9/2025 1:53:01 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-138 168	Building C Attic Room C5	Manual	10/9/2025 1:53:17 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-138 167	Building C Attic Room C5	Manual	10/9/2025 1:53:20 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-138 166	Building C Attic Room C5	Manual	10/9/2025 1:53:23 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-025 144	Building C Room C1	Manual	10/30/2025 9:59:22 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-024 143	Building C Room C1	Manual	10/30/2025 9:59:24 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-022 146	Building C Room C2	Manual	10/30/2025 9:59:19 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-023 145	Building C Room C2	Manual	10/30/2025 9:59:21 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-021 148	Building C Room C3	Manual	10/30/2025 9:59:11 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-020 147	Building C Room C3	Manual	10/30/2025 9:59:17 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-018 150	Building C Room C4	Manual	10/30/2025 9:59:08 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-019 149	Building C Room C4	Manual	10/30/2025 9:59:09 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-017 151	Building C Room C5	Manual	10/30/2025 9:58:50 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-016 152	Building C Room C5	Manual	10/30/2025 9:58:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-015 153	Building C Room C5A	Manual	10/30/2025 9:58:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-137 191	Building D Attic Room D1	Manual	10/9/2025 1:52:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-137 190	Building D Attic Room D1	Manual	10/9/2025 1:52:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-137 189	Building D Attic Room D1	Manual	10/9/2025 1:52:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-136 194	Building D Attic Room D2	Manual	10/9/2025 1:52:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-136 192	Building D Attic Room D2	Manual	10/9/2025 1:52:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-136 193	Building D Attic Room D2	Manual	10/9/2025 1:52:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-135 197	Building D Attic Room D3	Manual	10/9/2025 1:52:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-135 196	Building D Attic Room D3	Manual	10/9/2025 1:52:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-135 195	Building D Attic Room D3	Manual	10/9/2025 1:52:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-134 199	Building D Attic Room D4	Manual	10/9/2025 1:52:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-134 198	Building D Attic Room D4	Manual	10/9/2025 1:52:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-134 200	Building D Attic Room D4	Manual	10/9/2025 1:52:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-133 203	Building D Attic Room D5	Manual	10/9/2025 1:49:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-133 202	Building D Attic Room D5	Manual	10/9/2025 1:49:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-133 201	Building D Attic Room D5	Manual	10/9/2025 1:49:45 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-132 204	Building D Attic Room D6	Manual	10/9/2025 1:49:28 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-132 205	Building D Attic Room D6	Manual	10/9/2025 1:49:30 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-132 206	Building D Attic Room D6	Manual	10/9/2025 1:49:31 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-014 177	Building D Room D1	Manual	10/30/2025 9:58:46 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-013 176	Building D Room D1	Manual	10/30/2025 9:58:48 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-012 179	Building D Room D2	Manual	10/30/2025 9:58:44 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-011 178	Building D Room D2	Manual	10/30/2025 9:58:45 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-009 180	Building D Room D3	Manual	10/30/2025 9:58:41 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-010 181	Building D Room D3	Manual	10/30/2025 9:58:42 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-008 183	Building D Room D4	Manual	10/30/2025 9:58:38 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-007 182	Building D Room D4	Manual	10/30/2025 9:58:40 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-005 184	Building D Room D5	Manual	10/30/2025 9:58:36 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-006 185	Building D Room D5	Manual	10/30/2025 9:58:37 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-003 187	Building D Room D6	Manual	10/30/2025 9:58:33 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-004 186	Building D Room D6	Manual	10/30/2025 9:58:34 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-002 188	Building D Room D6A	Manual	10/30/2025 9:57:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-105 217	Building E Boys Restroom	Manual	10/9/2025 2:10:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-104 218	Building E Girls Restroom	Manual	10/9/2025 2:10:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-099 224	Building F F1A Girls Restroom	Manual	10/30/2025 9:59:36 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-100 225	Building F F1B Hallway	Manual	10/30/2025 9:59:38 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-101 226	Building F F1C Closet	Manual	10/30/2025 9:59:39 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-097 233	Building F F4A Boys Restroom	Manual	10/30/2025 9:59:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-096 234	Building F F4B Hallway	Manual	10/30/2025 9:59:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	2-152 237	Building F F4C Closet	Manual	10/30/2025 9:56:08 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-095 235	Building F F4C Closet	Manual	10/30/2025 9:59:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Valve Tamper Switch	2-153 238	Building F F4C Closet	Manual	10/30/2025 9:56:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-098 236	Building F F5 Custodial	Manual	10/30/2025 9:57:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-079 222	Building F Room F1 North	Manual	10/30/2025 9:59:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-080 223	Building F Room F1 South	Manual	10/30/2025 9:59:44 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-081 227	Building F Room F2 North	Manual	10/30/2025 9:59:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-082 228	Building F Room F2 South	Manual	10/30/2025 9:59:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-083 230	Building F Room F3 North	Manual	10/30/2025 9:59:50 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-084 229	Building F Room F3 South	Manual	10/30/2025 9:59:48 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-093 232	Building F Room F4 North	Manual	10/30/2025 10:00:02 AM
		Visual inspection	Passed (Manual)	
Smoke Detector - General	2-094 231	Building F Room F4 South	Manual	10/30/2025 10:00:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Functional Inspection	Passed	

Failed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Manual Pull Station	2-377 103	Building B MP Room NE	Manual	10/9/2025 2:24:10 PM
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	

Power Supplies

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Battery - Sealed Lead-acid		Building A Room A7A MDF - FACP	Manual	10/30/2025 9:56:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	55	
Battery - Sealed Lead-acid		Nominal Voltage	12	
		Building A Room A7A MDF - P.E. "B"	Manual	10/30/2025 9:56:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Battery - Sealed Lead-acid		Amp Hours	8	
		Nominal Voltage	12	
		Building A Room A7A MDF - P.E. "H"	Manual	10/30/2025 9:56:28 AM
		Visual inspection	Passed (Manual)	
Battery - Sealed Lead-acid		Functional Inspection	Passed	
		Amp Hours	8	
		Nominal Voltage	12	
		Building A Room A7A MDF - P.E. "Master"	Manual	10/30/2025 9:56:25 AM
Battery - Sealed Lead-acid		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	8	
		Nominal Voltage	12	
Battery - Sealed Lead-acid		Building B MP Cust Office B4 - P.E. "G"	Manual	10/30/2025 9:56:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	8	
Battery - Sealed Lead-acid		Nominal Voltage	12	
		Building C Room C5A - P.E. "C"	Manual	10/30/2025 9:56:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Battery - Sealed Lead-acid		Amp Hours	8	
		Nominal Voltage	12	
		Building D Room D6A - P.E. - "D"	Manual	10/30/2025 9:56:16 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Amp Hours	8	
		Nominal Voltage	12	
Battery - Sealed Lead-acid		Building F F1C Closet - P.E. "F"	Manual	10/30/2025 9:56:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	8	
		Nominal Voltage	12	

Device/Equipment details

Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Audible					
063	Building A Northeast Exterior				
064	Building A Southeast Exterior				
065	Building A Southwest Exterior				
066	Building A Northwest Exterior				
097	Building A Northeast Exterior - Electric Bell				
129	Building B Northwest Exterior				
130	Building B Northeast Exterior				
141	Building B Southeast Exterior - Electric Bell				
169	Building C West Exterior				
207	Building D North Exterior				
208	Building D Southwest Exterior				
209	Building D West Exterior				
219	Building E North Exterior				
239	Building F East Exterior				
248	Building F Northeast Exterior - Electric Bell Building C Exterior of Room C3				
Audible And Visible					
067	Building A Main Office A1				
068	Building A Office Hallway				
069	Building A Work Room A2				
070	Building A Room A3				
071	Building A Room A5				
072	Building A Rm A6 Media Center				
073	Building A Room A6B Speech				
074	Building A Room A9				
075	Building A Room A11				
076	Building A Room A13				
077	Building A Room A15				
131	Building B MP Room B1				
132	Building B MP Room B1				
133	Building B MP Room B1				
134	Building B MP Room B1				
135	Building B MP Kitchen B2				
170	Building C Room C1				
171	Building C Room C2				
172	Building C Room C3				
173	Building C Room C4				
174	Building C Room C5				
210	Building D Room D1				
211	Building D Room D2				
212	Building D Room D3				
213	Building D Room D4				
214	Building D Room D5				
215	Building D Room D6				
240	Building F Room F2				
241	Building F Room F4				
Visible					

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
078	Building A Principals Office A1A				
079	Building A Conference Rm A1B				
080	Building A Rm A1C Copier Rm				
081	Building A Office Restroom A1D				
082	Building A Nurses Office A1E				
083	Building A Nurses Office RR				
084	Building A Room A4				
085	Building A Rm A6 Media Center				
086	Building A Room A6D				
087	Building A Room A7				
088	Building A Room A7 Hallway				
089	Building A Rm A7C Boys RR				
090	Building A Rm A9A Girls RR				
091	Building A Room A9B Hallway				
092	Building A Room A10				
093	Building A Room A11 North				
094	Building A Rm A11A Restroom				
095	Building A Rm A13A Restroom				
096	Building A Room A14				
136	Building B MP Rm B1 SW Entry				
137	Building B MP Boys RR B1A				
138	Building B MP Girls RR B1B				
139	Building B MP Stage B3				
140	Building B MP Coach Office B3B				
220	Building E Boys Restroom				
221	Building E Girls Restroom				
242	Building F Room F1				
243	Building F F1A Girls Restroom				
244	Building F F1B Hallway				
245	Building F Room F3				
246	Building F F4A Boys Restroom				
247	Building F F4B Hallway				

Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
NAC Power Extender Panel					
098	Building A Room A7A MDF - P.E. "Master"				
099	Building A Room A7A MDF - P.E. "B"				
100	Building A Room A7A MDF - P.E. "H"				
142	Building B MP Cust Office B4 - P.E. "G"				
175	Building C Room C5A - P.E. "C"				
216	Building D Room D6A - P.E. - "D"				
249	Building F F1C Closet - P.E. "F"				
Remote Annunciator					
001	Building A Main Office A1				
Fire Alarm Panel					
	Building A Room A7A MDF	EST	3		

Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Smoke Detector - General					

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-044 050	Building A Rm A12 Electrical				
2-048 051	Building A Room A13 South				
2-049 052	Building A Room A13 North				
2-047 053	Building A Rm A13A Restroom				
2-088 054	Building A Room A14				
2-077 055	Building A Room A14				
2-046 056	Building A Room A15				
2-089 057	Building A Room A15				
2-289 106	Building B MP B1 Southwest				
2-288 107	Building B MP B1 South Middle				
2-287 108	Building B MP B1 Southeast				
2-280 109	Building B MP B1 Northeast				
2-279 110	Building B MP B1 North Middle				
2-278 111	Building B MP B1 Northwest				
2-272 112	Building B MP Boys RR B1A				
2-274 113	Building B MP Girls RR B1B				
2-273 114	Building B MP Custodian B1C				
2-281 115	Building B MP Chair Storage B1D				
2-277 116	Building B Kitchen Storage B2				
2-283 117	Building B MP Stage B3 North				
2-284 118	Building B MP Stage B3 South				
2-285 119	Building B MP Stage Closet B3A				
2-286 120	Building B MP Coach Office B3B				
2-282 121	Building B MP Prop Storage B3C				
2-290 122	Building B MP Cust Office B4				
2-024 143	Building C Room C1				
2-025 144	Building C Room C1				
2-023 145	Building C Room C2				
2-022 146	Building C Room C2				
2-020 147	Building C Room C3				
2-021 148	Building C Room C3				
2-019 149	Building C Room C4				
2-018 150	Building C Room C4				
2-017 151	Building C Room C5				
2-016 152	Building C Room C5				
2-015 153	Building C Room C5A				
2-013 176	Building D Room D1				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-014 177	Building D Room D1				
2-011 178	Building D Room D2				
2-012 179	Building D Room D2				
2-009 180	Building D Room D3				
2-010 181	Building D Room D3				
2-007 182	Building D Room D4				
2-008 183	Building D Room D4				
2-005 184	Building D Room D5				
2-006 185	Building D Room D5				
2-004 186	Building D Room D6				
2-003 187	Building D Room D6				
2-002 188	Building D Room D6A				
2-079 222	Building F Room F1 North				
2-080 223	Building F Room F1 South				
2-099 224	Building F F1A Girls Restroom				
2-100 225	Building F F1B Hallway				
2-101 226	Building F F1C Closet				
2-081 227	Building F Room F2 North				
2-082 228	Building F Room F2 South				
2-084 229	Building F Room F3 South				
2-083 230	Building F Room F3 North				
2-094 231	Building F Room F4 South				
2-093 232	Building F Room F4 North				
2-097 233	Building F F4A Boys Restroom				
2-096 234	Building F F4B Hallway				
2-095 235	Building F F4C Closet				
2-098 236	Building F F5 Custodial				
2-026 003	Building A Main Office A1				
2-072 004	Building A Principals Office A1A				
2-057 005	Building A Conference Rm A1B				
2-074 006	Building A Office Restroom A1D				
2-076 007	Building A Nurses Office A1E				
2-075 008	Building A Nurses Office RR				
2-073 009	Building A Office Hallway				
2-070 010	Building A Work Room A2				
2-085 011	Building A Room A3 South				
2-069 012	Building A Room A3				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-086 013	Building A Room A4				
2-068 014	Building A Room A4				
2-067 015	Building A Room A4A Closet				
2-066 016	Building A Room A4B Hallway				
2-065 017	Building A Rm A4C Girls RR				
2-064 018	Building A Rm A4C1 Custodial				
2-062 019	Building A Room A5				
2-087 020	Building A Room A5				
2-063 021	Building A Rm A5A Boys RR				
2-061 022	Building A Rm A5B Hallway				
2-060 023	Building A Room A5C Closet				
2-059 024	Building A Rm A6 Media Cnt Hall				
2-058 025	Building A Rm A6 Media Cnt Hall				
2-052 026	Building A Rm A6 Media Center				
2-053 027	Building A Rm A6 Media Center				
2-051 028	Building A Rm A6 Media Center				
2-050 029	Building A Rm A6 Media Center				
2-056 030	Building A Rm A6A Speech Closet				
2-054 031	Building A Room A6B Speech				
2-055 032	Building A Room A6D				
2-033 033	Building A Room A7				
2-090 034	Building A Room A7				
2-001 035	Building A Room A7A MDF				
2-032 036	Building A Room A7 Hallway				
2-034 037	Building A Rm A7C Boys RR				
2-035 038	Building A Rm A8 Custodial				
2-039 039	Building A Room A9				
2-091 040	Building A Room A9				
2-036 041	Building A Rm A9A Girls RR				
2-037 042	Building A Room A9B Hallway				
2-038 043	Building A Room A9C Closet				
2-040 044	Building A Room A10				
2-092 045	Building A Room A10				
2-041 046	Building A Room A11 South				
2-042 047	Building A Room A11 North				
2-045 048	Building A Room A11 North				
2-043 049	Building A Rm A11A Restroom				
Heat Detector - Restorable Spot					

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-071 058	Building A Rm A1C Copier Rm				
2-031 059	Building A Room A7A MDF				
2-276 123	Building B MP Kitchen B2				
2-275 124	Building B MP Mech Rm South				
2-144 154	Building C Attic Room C1				
2-144 155	Building C Attic Room C1				
2-144 156	Building C Attic Room C1				
2-143 157	Building C Attic Room C2				
2-143 158	Building C Attic Room C2				
2-143 159	Building C Attic Room C2				
2-142 160	Building C Attic Room C3				
2-142 161	Building C Attic Room C3				
2-142 162	Building C Attic Room C3				
2-141 163	Building C Attic Room C4				
2-141 164	Building C Attic Room C4				
2-141 165	Building C Attic Room C4				
2-138 166	Building C Attic Room C5				
2-138 167	Building C Attic Room C5				
2-138 168	Building C Attic Room C5				
2-137 189	Building D Attic Room D1				
2-137 190	Building D Attic Room D1				
2-137 191	Building D Attic Room D1				
2-136 192	Building D Attic Room D2				
2-136 193	Building D Attic Room D2				
2-136 194	Building D Attic Room D2				
2-135 195	Building D Attic Room D3				
2-135 196	Building D Attic Room D3				
2-135 197	Building D Attic Room D3				
2-134 198	Building D Attic Room D4				
2-134 199	Building D Attic Room D4				
2-134 200	Building D Attic Room D4				
2-133 201	Building D Attic Room D5				
2-133 202	Building D Attic Room D5				
2-133 203	Building D Attic Room D5				
2-132 204	Building D Attic Room D6				
2-132 205	Building D Attic Room D6				
2-132 206	Building D Attic Room D6				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-105 217	Building E Boys Restroom				
2-104 218	Building E Girls Restroom				
Smoke Detector - Duct					
2-146 060	Building A Rm A1C Copier Rm				
2-390 125	Building B HVAC East Roof				
2-387 126	Building B HVAC MP B1 S?				
Mechanical, Electrosonic, or Pressure Waterflow Device					
2-130 061	Building A Room A4A Closet				
2-388 127	Building B MP Cust Office B4				
2-152 237	Building F F4C Closet				
Valve Tamper Switch					
2-131 062	Building A Room A4A Closet				
2-389 128	Building B MP Cust Office B4				
2-153 238	Building F F4C Closet				
Manual Pull Station					
2-380 101	Building B MP Room SW				
2-379 102	Building B MP Room SE				
2-377 103	Building B MP Room NE				
2-378 104	Building B MP Room NW				
2-381 105	Building B MP Room Stage				
2-145 002	Building A Main Office A1				

Power Supplies

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Battery - Sealed Lead-acid					
	Building A Room A7A MDF - FACP				03/01/2018
	Building A Room A7A MDF - P.E. "Master"				12/07/2018
	Building A Room A7A MDF - P.E. "B"				12/07/2018
	Building A Room A7A MDF - P.E. "H"				12/07/2018
	Building B MP Cust Office B4 - P.E. "G"				07/25/2016
	Building C Room C5A - P.E. "C"				03/21/2019
	Building D Room D6A - P.E. - "D"				02/24/2020
	Building F F1C Closet - P.E. "F"				08/24/2018