

Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

COYLE AVE ELEMENTARY

6330 COYLE AVE
CARMICHAEL, California
United States

This site has been inspected and tested in compliance with applicable standards.

Completed

Thursday, October 09, 2025

Test Session:06 Oct 2025 7:00 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD
5320 HEMLOCK ST
SACRAMENTO, California
United States

TESTED BY

Riley Goyet
Western States Fire Protection-
Sacramento
188 Cirby Way
Roseville, CA 95678
United States



Inspection Summary

Building Information

PROPERTY	COYLE AVE ELEMENTARY	CONTACT
ADDRESS	6330 COYLE AVE	PHONE
CITY/STATE	CARMICHAEL, California	MOBILE
COUNTRY	United States	EMAIL

Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us

Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Alarm Notification Appliance	72	72(100%)	72(100%)	0(0%)
Fire Control Panel	9	9(100%)	8(89%)	1(11%)
Initiating Device	190	185(97%)	185(97%)	0(0%)

Certification

The equipment specified here in was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Thursday, October 09, 2025

ACCEPTED BY 10/09/2025

Building Representative


TESTED BY 10/09/2025
Riley Goyet
Technician

System Details

Control Units

ADDRESS/ SCAN ADDRESS	DESCRIPTION	Rooms 1-6 Bldg Custodial Storage
MANUFACTURER	S/W VERSION	
MODEL	LAST UPDATE	
SERIAL NUMBER	S/W LOCATION	
INSTALL DATE		

Open Corrective Action & Solution Summary

The following 2 corrective action(s) remain open following the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
NAC Power Extender Panel	092	Rooms 1-6 Bldg Custodial Storage - P.E. D
	Created By:	
	Creation Date:	12/19/2023
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
NAC Power Extender Panel	089	Rooms 1-6 Bldg Custodial Storage P/E C
	Created By:	Riley Goyet
	Creation Date:	10/06/2025
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	

Resolved Corrective Action & Solution Summary

The following 1 corrective action(s) were resolved during the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
Fire Alarm Panel		Rooms 1-6 Bldg Custodial Storage

Created By:
Creation Date: 03/26/2020
Corrective Action: 01/13 12V 55AH

FLAT BATTERIES

WERKER Deep Cycle Batteries

Resolution:
Resolved By: Riley Goyet
Resolved On: 10/06/2025
Manufacturer:
Model:

Testing Details

Alarm Notification Appliance

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible	029	Admin Building ADS Restroom	Manual	10/6/2025 2:29:02 PM
		Visual inspection	Passed (Manual)	
Visible	028	Admin Building Back Office Restroom	Manual	10/6/2025 2:29:00 PM
		Visual inspection	Passed (Manual)	
Visible	025	Admin Building Hall	Manual	10/6/2025 2:29:36 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	022	Admin Building Meeting Room	Manual	10/6/2025 2:27:54 PM
		Visual inspection	Passed (Manual)	
Visible	027	Admin Building Nurse Room	Manual	10/6/2025 2:29:37 PM
		Visual inspection	Passed (Manual)	
Visible	026	Admin Building Office Restroom	Manual	10/6/2025 2:28:59 PM
		Visual inspection	Passed (Manual)	
Visible	023	Admin Building Principals Office	Manual	10/6/2025 2:29:33 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	020	Admin Building Reception	Manual	10/6/2025 2:29:54 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	021	Admin Building Staff Room	Manual	10/6/2025 2:29:56 PM
		Visual inspection	Passed (Manual)	
Visible	024	Admin Building Work Room	Manual	10/6/2025 2:29:35 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	040	Kindergarten Bldg Room K1	Manual	10/6/2025 2:27:56 PM
		Visual inspection	Passed (Manual)	
Visible	042	Kindergarten Bldg Room K1 Restroom	Manual	10/6/2025 2:29:04 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	041	Kindergarten Bldg Room K2	Manual	10/6/2025 2:27:58 PM
		Visual inspection	Passed (Manual)	
Visible	043	Kindergarten Bldg Room K2 Restroom	Manual	10/6/2025 2:29:05 PM
		Visual inspection	Passed (Manual)	
Audible	039	Kindergarten Bldg South Exterior	Manual	10/6/2025 2:27:55 PM
		Visual inspection	Passed (Manual)	
Visible	262	Multi-Purpose Bldg Boys Restroom	Manual	10/6/2025 2:29:26 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	260	Multi-Purpose Bldg Bridges Room	Manual	10/6/2025 2:28:54 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	255	Multi-Purpose Bldg East Exterior	Manual	10/6/2025 2:28:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	263	Multi-Purpose Bldg Girls Restroom	Manual	10/6/2025 2:28:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	259	Multi-Purpose Bldg Kitchen	Manual	10/6/2025 2:28:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	265	Multi-Purpose Bldg Kitchen	Manual	10/6/2025 2:28:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	264	Multi-Purpose Bldg Kitchen	Manual	10/6/2025 2:29:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	266	Multi-Purpose Bldg Kitchen Restroom	Manual	10/6/2025 2:29:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	267	Multi-Purpose Bldg Kitchen Restroom	Manual	10/6/2025 2:29:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	261	Multi-Purpose Bldg MP Hall	Manual	10/6/2025 2:29:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	256	Multi-Purpose Bldg MP Room	Manual	10/6/2025 2:28:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	257	Multi-Purpose Bldg MP Room	Manual	10/6/2025 2:28:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	258	Multi-Purpose Bldg Stage	Manual	10/6/2025 2:28:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	215	Rms 19 20 Bldg Classroom 19	Manual	10/6/2025 2:28:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	216	Rms 19 20 Bldg Classroom 20	Manual	10/6/2025 2:28:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	212	Rms 19 20 Bldg East Exterior	Manual	10/6/2025 2:28:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	213	Rms 19 20 Bldg Library	Manual	10/6/2025 2:28:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	214	Rms 19 20 Bldg Library	Manual	10/6/2025 2:28:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	181	Rooms 13-18 Bldg Boys Restroom	Manual	10/6/2025 2:29:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	171	Rooms 13-18 Bldg Classroom 13	Manual	10/6/2025 2:28:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	172	Rooms 13-18 Bldg Classroom 14	Manual	10/6/2025 2:28:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	173	Rooms 13-18 Bldg Classroom 15	Manual	10/6/2025 2:28:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	174	Rooms 13-18 Bldg Classroom 16	Manual	10/6/2025 2:28:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	175	Rooms 13-18 Bldg Classroom 17	Manual	10/6/2025 2:28:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	176	Rooms 13-18 Bldg Classroom 18	Manual	10/6/2025 2:28:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	177	Rooms 13-18 Bldg Computer Lab	Manual	10/6/2025 2:28:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	178	Rooms 13-18 Bldg Computer Lab	Manual	10/6/2025 2:28:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	182	Rooms 13-18 Bldg Girls Restroom	Manual	10/6/2025 2:29:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	183	Rooms 13-18 Bldg Mens Restroom	Manual	10/6/2025 2:29:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	169	Rooms 13-18 Bldg North Exterior	Manual	10/6/2025 2:28:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	180	Rooms 13-18 Bldg Pysch Room	Manual	10/6/2025 2:28:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	170	Rooms 13-18 Bldg South Exterior	Manual	10/6/2025 2:28:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	179	Rooms 13-18 Bldg Speech Room	Manual	10/6/2025 2:28:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	184	Rooms 13-18 Bldg Womens Restroom	Manual	10/6/2025 2:29:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	087	Rooms 1-6 Bldg Boys Restroom	Manual	10/6/2025 2:29:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	081	Rooms 1-6 Bldg Classroom 1	Manual	10/6/2025 2:28:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	082	Rooms 1-6 Bldg Classroom 2	Manual	10/6/2025 2:28:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	083	Rooms 1-6 Bldg Classroom 3	Manual	10/6/2025 2:28:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	084	Rooms 1-6 Bldg Classroom 4	Manual	10/6/2025 2:28:05 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	085	Rooms 1-6 Bldg Classroom 5	Manual	10/6/2025 2:28:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	086	Rooms 1-6 Bldg Classroom 6	Manual	10/6/2025 2:28:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	088	Rooms 1-6 Bldg Girls Restroom	Manual	10/6/2025 2:29:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	080	Rooms 1-6 Bldg South Exterior	Manual	10/6/2025 2:27:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	139	Rooms 7-12 Bldg Boys RR at Room 12	Manual	10/6/2025 2:29:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	136	Rooms 7-12 Bldg Classroom 10	Manual	10/6/2025 2:28:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	137	Rooms 7-12 Bldg Classroom 11	Manual	10/6/2025 2:28:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	138	Rooms 7-12 Bldg Classroom 12	Manual	10/6/2025 2:28:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	133	Rooms 7-12 Bldg Classroom 7	Manual	10/6/2025 2:28:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	134	Rooms 7-12 Bldg Classroom 8	Manual	10/6/2025 2:28:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	135	Rooms 7-12 Bldg Classroom 9	Manual	10/6/2025 2:28:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	140	Rooms 7-12 Bldg Girls RR at Room 9	Manual	10/6/2025 2:29:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	141	Rooms 7-12 Bldg PE Storage Room	Manual	10/6/2025 2:29:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	131	Rooms 7-12 Bldg South Exterior	Manual	10/6/2025 2:28:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	142	Rooms 7-12 Bldg Storage at PE Rm	Manual	10/6/2025 2:29:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	143	Rooms 7-12 Bldg Storage at PE Rm	Manual	10/6/2025 2:29:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	144	Rooms 7-12 Bldg Storage at PE Rm	Manual	10/6/2025 2:29:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	132	Rooms 7-12 Bldg West Exterior	Manual	10/6/2025 2:28:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Remote Annunciator	001	Admin Building Reception	Manual	10/6/2025 4:15:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	268	Multi-Purpose Bldg MP Hall Storage	Manual	10/6/2025 3:46:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	185	Rooms 13-18 Bldg Project Area Storage	Manual	10/6/2025 4:09:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	186	Rooms 13-18 Bldg Project Area Storage	Manual	10/6/2025 4:09:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Fire Alarm Panel		Rooms 1-6 Bldg Custodial Storage	Manual	10/6/2025 4:09:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	091	Rooms 1-6 Bldg Custodial Storage	Manual	10/6/2025 4:09:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	090	Rooms 1-6 Bldg Custodial Storage	Manual	10/6/2025 4:09:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	092	Rooms 1-6 Bldg Custodial Storage - P.E. D	Manual	10/6/2025 4:08:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Failed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
NAC Power Extender Panel	089	Rooms 1-6 Bldg Custodial Storage P/E C	Manual	10/6/2025 4:08:52 PM
		Visual inspection	Failed (Manual)	

Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-055 018	Admin Building ADS Restroom	Manual	10/6/2025 4:11:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-056 007	Admin Building Back Office Restroom	Manual	10/6/2025 3:47:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-050 013	Admin Building Hall	Manual	10/6/2025 3:47:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-049 014	Admin Building Hall Closet	Manual	10/6/2025 3:48:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-057 016	Admin Building Meeting Room	Manual	10/6/2025 3:47:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-054 017	Admin Building Meeting Room Closet	Manual	10/6/2025 4:11:07 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-053 006	Admin Building Nurse Room	Manual	10/6/2025 3:45:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-052 015	Admin Building Office Restroom	Manual	10/6/2025 3:47:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-051 005	Admin Building Principals Off Closet	Manual	10/6/2025 4:10:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-047 004	Admin Building Principals Office	Manual	10/6/2025 3:47:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-142 002	Admin Building Reception	Manual	10/6/2025 3:45:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-048 003	Admin Building Reception	Manual	10/6/2025 3:45:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-043 011	Admin Building Staff Room	Manual	10/6/2025 3:44:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-045 010	Admin Building Staff Room	Manual	10/6/2025 3:45:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-046 009	Admin Building Staff Room	Manual	10/6/2025 4:10:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-042 012	Admin Building Staff Room	Manual	10/6/2025 4:10:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-044 008	Admin Building Work Room	Manual	10/6/2025 3:45:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-035 030	Kindergarten Bldg Room K1	Manual	10/6/2025 3:50:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-036 031	Kindergarten Bldg Room K1	Manual	10/6/2025 3:50:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-034 032	Kindergarten Bldg Room K1 Closet	Manual	10/6/2025 3:51:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-033 033	Kindergarten Bldg Room K1 Restroom	Manual	10/6/2025 3:50:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-039 034	Kindergarten Bldg Room K2	Manual	10/6/2025 3:52:08 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	2-040 035	Kindergarten Bldg Room K2	Manual	10/6/2025 3:52:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-038 036	Kindergarten Bldg Room K2 Closet	Manual	10/6/2025 3:53:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-037 037	Kindergarten Bldg Room K2 Restroom	Manual	10/6/2025 3:52:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-138 241	Multi-Purpose Bldg Attic Hall	Manual	10/6/2025 3:46:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-141 242	Multi-Purpose Bldg Attic Kitchen	Manual	10/6/2025 3:46:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-062 228	Multi-Purpose Bldg Boys Restroom	Manual	10/6/2025 3:34:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-067 231	Multi-Purpose Bldg Bridges Rm Closet	Manual	10/6/2025 3:46:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-059 232	Multi-Purpose Bldg Bridges Rm Closet	Manual	10/6/2025 3:46:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-066 230	Multi-Purpose Bldg Bridges Room	Manual	10/6/2025 3:33:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-063 227	Multi-Purpose Bldg Girls Restroom	Manual	10/6/2025 3:33:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-065 237	Multi-Purpose Bldg Kitchen	Manual	10/6/2025 3:30:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-071 238	Multi-Purpose Bldg Kitchen	Manual	10/6/2025 3:31:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-064 236	Multi-Purpose Bldg Kitchen	Manual	10/6/2025 3:31:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-072 239	Multi-Purpose Bldg Kitchen Office	Manual	10/6/2025 3:32:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-073 240	Multi-Purpose Bldg Kitchen OS Wtr Htr	Manual	10/6/2025 3:46:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-070 233	Multi-Purpose Bldg Kitchen Restroom	Manual	10/6/2025 3:36:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-069 234	Multi-Purpose Bldg Kitchen Restroom	Manual	10/6/2025 3:36:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-061 226	Multi-Purpose Bldg MP Hall	Manual	10/6/2025 3:46:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-060 229	Multi-Purpose Bldg MP Hall Storage	Manual	10/6/2025 3:35:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Projected Beam	2-149 253	Multi-Purpose Bldg MP Room Center	Manual	10/6/2025 3:46:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Projected Beam	2-151 252	Multi-Purpose Bldg MP Room Left	Manual	10/6/2025 3:46:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-159 220	Multi-Purpose Bldg MP Room NE	Manual	10/6/2025 3:45:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-157 219	Multi-Purpose Bldg MP Room NW	Manual	10/6/2025 3:45:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Projected Beam	2-140 254	Multi-Purpose Bldg MP Room Right	Manual	10/6/2025 3:46:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-160 217	Multi-Purpose Bldg MP Room SE	Manual	10/6/2025 3:45:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-158 218	Multi-Purpose Bldg MP Room SW	Manual	10/6/2025 3:45:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-161 221	Multi-Purpose Bldg Stage	Manual	10/6/2025 3:45:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-075 223	Multi-Purpose Bldg Stage	Manual	10/6/2025 3:44:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-076 224	Multi-Purpose Bldg Stage	Manual	10/6/2025 3:44:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-144 250	Multi-Purpose Bldg Stage Left	Manual	10/6/2025 3:46:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-145 251	Multi-Purpose Bldg Stage Right	Manual	10/6/2025 3:46:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-077 225	Multi-Purpose Bldg Stage Steps	Manual	10/6/2025 3:44:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-074 222	Multi-Purpose Bldg Stage Steps	Manual	10/6/2025 3:44:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-147 247	Multi-Purpose Bldg Under Stage	Manual	10/6/2025 3:46:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-147 244	Multi-Purpose Bldg Under Stage	Manual	10/6/2025 3:46:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-147 245	Multi-Purpose Bldg Under Stage	Manual	10/6/2025 3:46:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-147 249	Multi-Purpose Bldg Under Stage	Manual	10/6/2025 3:46:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-147 248	Multi-Purpose Bldg Under Stage	Manual	10/6/2025 3:46:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-147 246	Multi-Purpose Bldg Under Stage	Manual	10/6/2025 3:46:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Valve Tamper Switch	2-387 270	NW Parking Lot OSY	Manual	10/6/2025 4:33:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Valve Tamper Switch	2-387 269	NW Parking Lot OSY	Manual	10/6/2025 4:33:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-322 198	Rms 19 20 Bldg Classroom 19	Manual	10/6/2025 2:53:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-321 202	Rms 19 20 Bldg Classroom 19	Manual	10/6/2025 2:53:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-320 201	Rms 19 20 Bldg Classroom 19	Manual	10/6/2025 2:54:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-319 200	Rms 19 20 Bldg Classroom 19	Manual	10/6/2025 2:54:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-323 199	Rms 19 20 Bldg Classroom 19	Manual	10/6/2025 4:34:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-327 203	Rms 19 20 Bldg Classroom 20	Manual	10/6/2025 2:50:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-326 207	Rms 19 20 Bldg Classroom 20	Manual	10/6/2025 2:51:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-325 206	Rms 19 20 Bldg Classroom 20	Manual	10/6/2025 2:51:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-324 205	Rms 19 20 Bldg Classroom 20	Manual	10/6/2025 2:51:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-328 204	Rms 19 20 Bldg Classroom 20	Manual	10/6/2025 4:34:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-314 192	Rms 19 20 Bldg Library	Manual	10/6/2025 2:56:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-315 194	Rms 19 20 Bldg Library	Manual	10/6/2025 2:56:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-316 195	Rms 19 20 Bldg Library	Manual	10/6/2025 2:56:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-317 196	Rms 19 20 Bldg Library	Manual	10/6/2025 2:57:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-318 193	Rms 19 20 Bldg Library	Manual	10/6/2025 2:57:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-312 191	Rms 19 20 Bldg Library	Manual	10/6/2025 2:57:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-313 189	Rms 19 20 Bldg Library	Manual	10/6/2025 2:58:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-310 188	Rms 19 20 Bldg Library	Manual	10/6/2025 2:58:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-311 190	Rms 19 20 Bldg Library	Manual	10/6/2025 4:34:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-309 187	Rms 19 20 Bldg Library	Manual	10/6/2025 4:34:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-384 209	Rms 19 20 Bldg Library HVAC Closet	Manual	10/6/2025 4:34:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-383 208	Rms 19 20 Bldg Library HVAC Closet	Manual	10/6/2025 4:34:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-308 197	Rms 19 20 Bldg Library IDF Room	Manual	10/6/2025 4:33:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-385 210	Rms 19 20 Bldg Room 19 HVAC Clst	Manual	10/6/2025 4:33:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-386 211	Rms 19 20 Bldg Room 20 HVAC Clst	Manual	10/6/2025 4:34:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-382 168	Rooms 13-18 Bldg Attic Project Area	Manual	10/6/2025 4:10:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-285 166	Rooms 13-18 Bldg Boys Restroom	Manual	10/6/2025 3:26:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-288 145	Rooms 13-18 Bldg Classroom 13	Manual	10/6/2025 3:14:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-289 146	Rooms 13-18 Bldg Classroom 13	Manual	10/6/2025 3:14:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-290 147	Rooms 13-18 Bldg Classroom 14	Manual	10/6/2025 3:12:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-291 148	Rooms 13-18 Bldg Classroom 14	Manual	10/6/2025 3:12:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-292 149	Rooms 13-18 Bldg Classroom 15	Manual	10/6/2025 3:10:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-293 150	Rooms 13-18 Bldg Classroom 15	Manual	10/6/2025 3:11:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-305 152	Rooms 13-18 Bldg Classroom 16	Manual	10/6/2025 4:19:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-306 151	Rooms 13-18 Bldg Classroom 16	Manual	10/6/2025 4:19:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-303 153	Rooms 13-18 Bldg Classroom 17	Manual	10/6/2025 3:06:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-302 154	Rooms 13-18 Bldg Classroom 17	Manual	10/6/2025 3:06:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-299 155	Rooms 13-18 Bldg Classroom 18	Manual	10/6/2025 3:08:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-300 156	Rooms 13-18 Bldg Classroom 18	Manual	10/6/2025 3:08:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-298 157	Rooms 13-18 Bldg Computer Room	Manual	10/6/2025 3:05:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-301 158	Rooms 13-18 Bldg Computer Room	Manual	10/6/2025 3:05:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-297 164	Rooms 13-18 Bldg Custodial Closet	Manual	10/6/2025 4:33:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-284 167	Rooms 13-18 Bldg Girls Restroom	Manual	10/6/2025 3:27:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-294 162	Rooms 13-18 Bldg Mens Restroom	Manual	10/6/2025 3:00:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-304 159	Rooms 13-18 Bldg Project Area	Manual	10/6/2025 3:05:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-287 160	Rooms 13-18 Bldg Project Area Storage	Manual	10/6/2025 3:07:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-296 161	Rooms 13-18 Bldg Pysch Room	Manual	10/6/2025 3:02:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-286 165	Rooms 13-18 Bldg Speech Room	Manual	10/6/2025 3:07:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-295 163	Rooms 13-18 Bldg Womens Restroom	Manual	10/6/2025 4:33:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-030 068	Rooms 1-6 Bldg Boys Restroom	Manual	10/6/2025 4:05:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-027 046	Rooms 1-6 Bldg Classroom 1	Manual	10/6/2025 4:01:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-025 047	Rooms 1-6 Bldg Classroom 1	Manual	10/6/2025 4:02:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-026 045	Rooms 1-6 Bldg Classroom 1	Manual	10/6/2025 4:02:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-028 044	Rooms 1-6 Bldg Classroom 1	Manual	10/6/2025 4:02:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-135 074	Rooms 1-6 Bldg Classroom 1 Soffit	Manual	10/6/2025 4:03:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-024 048	Rooms 1-6 Bldg Classroom 2	Manual	10/6/2025 3:58:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-022 049	Rooms 1-6 Bldg Classroom 2	Manual	10/6/2025 3:58:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-023 050	Rooms 1-6 Bldg Classroom 2	Manual	10/6/2025 3:59:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-021 051	Rooms 1-6 Bldg Classroom 2	Manual	10/6/2025 3:59:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-134 075	Rooms 1-6 Bldg Classroom 2 Soffit	Manual	10/6/2025 4:00:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-019 054	Rooms 1-6 Bldg Classroom 3	Manual	10/6/2025 3:55:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-017 055	Rooms 1-6 Bldg Classroom 3	Manual	10/6/2025 3:56:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-018 053	Rooms 1-6 Bldg Classroom 3	Manual	10/6/2025 3:56:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-020 052	Rooms 1-6 Bldg Classroom 3	Manual	10/6/2025 3:56:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-133 076	Rooms 1-6 Bldg Classroom 3 Soffit	Manual	10/6/2025 3:57:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-007 059	Rooms 1-6 Bldg Classroom 4	Manual	10/6/2025 4:15:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-005 058	Rooms 1-6 Bldg Classroom 4	Manual	10/6/2025 4:16:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-006 057	Rooms 1-6 Bldg Classroom 4	Manual	10/6/2025 4:16:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-008 056	Rooms 1-6 Bldg Classroom 4	Manual	10/6/2025 4:17:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-130 077	Rooms 1-6 Bldg Classroom 4 Soffit	Manual	10/6/2025 4:17:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-012 060	Rooms 1-6 Bldg Classroom 5	Manual	10/6/2025 4:15:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-010 063	Rooms 1-6 Bldg Classroom 5	Manual	10/6/2025 4:15:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-011 061	Rooms 1-6 Bldg Classroom 5	Manual	10/6/2025 4:15:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-009 062	Rooms 1-6 Bldg Classroom 5	Manual	10/6/2025 4:17:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-015 067	Rooms 1-6 Bldg Classroom 6	Manual	10/6/2025 4:11:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-013 066	Rooms 1-6 Bldg Classroom 6	Manual	10/6/2025 4:11:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-014 065	Rooms 1-6 Bldg Classroom 6	Manual	10/6/2025 4:12:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-016 064	Rooms 1-6 Bldg Classroom 6	Manual	10/6/2025 4:12:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-132 079	Rooms 1-6 Bldg Classroom 6 Soffit	Manual	10/6/2025 4:13:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-003 072	Rooms 1-6 Bldg Custodial Storage	Manual	10/6/2025 4:10:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-002 070	Rooms 1-6 Bldg Custodial Storage	Manual	10/6/2025 4:03:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-004 071	Rooms 1-6 Bldg Girls Restroom	Manual	10/6/2025 4:37:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-031 073	Rooms 1-6 Bldg Storage Near Room 1	Manual	10/6/2025 4:05:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-029 069	Rooms 1-6 Bldg Storage Room	Manual	10/6/2025 4:07:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-269 119	Rooms 7-12 Bldg Boys RR at Room 12	Manual	10/6/2025 4:34:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-268 118	Rooms 7-12 Bldg Boys RR at Room 12	Manual	10/6/2025 4:34:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-279 108	Rooms 7-12 Bldg Classroom 10	Manual	10/6/2025 3:24:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-281 107	Rooms 7-12 Bldg Classroom 10	Manual	10/6/2025 3:25:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-282 106	Rooms 7-12 Bldg Classroom 10	Manual	10/6/2025 3:25:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-280 105	Rooms 7-12 Bldg Classroom 10	Manual	10/6/2025 3:25:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-381 128	Rooms 7-12 Bldg Classroom 10 Soffit	Manual	10/6/2025 3:24:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-275 112	Rooms 7-12 Bldg Classroom 11	Manual	10/6/2025 3:22:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-277 111	Rooms 7-12 Bldg Classroom 11	Manual	10/6/2025 3:22:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-278 110	Rooms 7-12 Bldg Classroom 11	Manual	10/6/2025 3:22:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-276 109	Rooms 7-12 Bldg Classroom 11	Manual	10/6/2025 3:23:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-380 129	Rooms 7-12 Bldg Classroom 11 Soffit	Manual	10/6/2025 3:21:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-272 113	Rooms 7-12 Bldg Classroom 12	Manual	10/6/2025 3:17:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-271 116	Rooms 7-12 Bldg Classroom 12	Manual	10/6/2025 3:17:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-273 115	Rooms 7-12 Bldg Classroom 12	Manual	10/6/2025 3:17:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-274 114	Rooms 7-12 Bldg Classroom 12	Manual	10/6/2025 3:18:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-270 117	Rooms 7-12 Bldg Classroom 12 RR	Manual	10/6/2025 4:38:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-379 130	Rooms 7-12 Bldg Classroom 12 Soffit	Manual	10/6/2025 3:19:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-252 096	Rooms 7-12 Bldg Classroom 7	Manual	10/6/2025 2:41:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-253 093	Rooms 7-12 Bldg Classroom 7	Manual	10/6/2025 2:41:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-254 095	Rooms 7-12 Bldg Classroom 7	Manual	10/6/2025 2:41:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-255 094	Rooms 7-12 Bldg Classroom 7	Manual	10/6/2025 2:41:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-376 125	Rooms 7-12 Bldg Classroom 7 Soffit	Manual	10/6/2025 2:43:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-258 099	Rooms 7-12 Bldg Classroom 8	Manual	10/6/2025 2:44:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-256 100	Rooms 7-12 Bldg Classroom 8	Manual	10/6/2025 2:44:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-257 097	Rooms 7-12 Bldg Classroom 8	Manual	10/6/2025 2:45:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-259 098	Rooms 7-12 Bldg Classroom 8	Manual	10/6/2025 2:45:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-377 126	Rooms 7-12 Bldg Classroom 8 Soffit	Manual	10/6/2025 2:45:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-261 103	Rooms 7-12 Bldg Classroom 9	Manual	10/6/2025 2:47:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-330 104	Rooms 7-12 Bldg Classroom 9	Manual	10/6/2025 2:47:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-260 101	Rooms 7-12 Bldg Classroom 9	Manual	10/6/2025 2:47:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-262 102	Rooms 7-12 Bldg Classroom 9	Manual	10/6/2025 2:48:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-378 127	Rooms 7-12 Bldg Classroom 9 Soffit	Manual	10/6/2025 2:48:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-264 124	Rooms 7-12 Bldg Girls RR at Room 9	Manual	10/6/2025 4:33:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-263 120	Rooms 7-12 Bldg PE Storage Room	Manual	10/6/2025 4:33:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-265 123	Rooms 7-12 Bldg Storage at PE Rm	Manual	10/6/2025 4:33:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-266 122	Rooms 7-12 Bldg Storage at PE Rm	Manual	10/6/2025 4:42:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-267 121	Rooms 7-12 Bldg Storage at PE Rm	Manual	10/6/2025 4:42:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-146 019	Admin Building Attic Meeting Room	Manual	10/6/2025 4:10:10 PM
Heat Detector - Restorable Spot	2-136 038	Kindergarten Bldg Attic Room K1 RR	Manual	10/6/2025 4:10:20 PM
Heat Detector - Restorable Spot	2-143 243	Multi-Purpose Bldg Attic Kitchen Storage	Manual	10/6/2025 3:46:20 PM
Smoke Detector - General	2-068 235	Multi-Purpose Bldg Kitchen Storage	Manual	10/6/2025 3:45:59 PM
Heat Detector - Restorable Spot	2-131 078	Rooms 1-6 Bldg Classroom 5 Soffit	Manual	10/6/2025 4:34:02 PM

Device/Equipment details

Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Audible And Visible					
020	Admin Building Reception				
021	Admin Building Staff Room				
022	Admin Building Meeting Room				
040	Kindergarten Bldg Room K1				
041	Kindergarten Bldg Room K2				
081	Rooms 1-6 Bldg Classroom 1				
082	Rooms 1-6 Bldg Classroom 2				
083	Rooms 1-6 Bldg Classroom 3				
084	Rooms 1-6 Bldg Classroom 4				
085	Rooms 1-6 Bldg Classroom 5				
086	Rooms 1-6 Bldg Classroom 6				
133	Rooms 7-12 Bldg Classroom 7				
134	Rooms 7-12 Bldg Classroom 8				
135	Rooms 7-12 Bldg Classroom 9				
136	Rooms 7-12 Bldg Classroom 10				
137	Rooms 7-12 Bldg Classroom 11				
138	Rooms 7-12 Bldg Classroom 12				
171	Rooms 13-18 Bldg Classroom 13				
172	Rooms 13-18 Bldg Classroom 14				
173	Rooms 13-18 Bldg Classroom 15				
174	Rooms 13-18 Bldg Classroom 16				
175	Rooms 13-18 Bldg Classroom 17				
176	Rooms 13-18 Bldg Classroom 18				
177	Rooms 13-18 Bldg Computer Lab				
178	Rooms 13-18 Bldg Computer Lab				
179	Rooms 13-18 Bldg Speech Room				
180	Rooms 13-18 Bldg Pysch Room				
213	Rms 19 20 Bldg Library				
214	Rms 19 20 Bldg Library				
215	Rms 19 20 Bldg Classroom 19				
216	Rms 19 20 Bldg Classroom 20				
256	Multi-Purpose Bldg MP Room				
257	Multi-Purpose Bldg MP Room				
258	Multi-Purpose Bldg Stage				
259	Multi-Purpose Bldg Kitchen				
260	Multi-Purpose Bldg Bridges Room				
Visible					
023	Admin Building Principals Office				
024	Admin Building Work Room				
025	Admin Building Hall				
026	Admin Building Office Restroom				
027	Admin Building Nurse Room				
028	Admin Building Back Office Restroom				
029	Admin Building ADS Restroom				
042	Kindergarten Bldg Room K1 Restroom				
043	Kindergarten Bldg Room K2 Restroom				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
087	Rooms 1-6 Bldg Boys Restroom				
088	Rooms 1-6 Bldg Girls Restroom				
139	Rooms 7-12 Bldg Boys RR at Room 12				
140	Rooms 7-12 Bldg Girls RR at Room 9				
141	Rooms 7-12 Bldg PE Storage Room				
142	Rooms 7-12 Bldg Storage at PE Rm				
143	Rooms 7-12 Bldg Storage at PE Rm				
144	Rooms 7-12 Bldg Storage at PE Rm				
181	Rooms 13-18 Bldg Boys Restroom				
182	Rooms 13-18 Bldg Girls Restroom				
183	Rooms 13-18 Bldg Mens Restroom				
184	Rooms 13-18 Bldg Womens Restroom				
261	Multi-Purpose Bldg MP Hall				
262	Multi-Purpose Bldg Boys Restroom				
263	Multi-Purpose Bldg Girls Restroom				
264	Multi-Purpose Bldg Kitchen				
265	Multi-Purpose Bldg Kitchen				
266	Multi-Purpose Bldg Kitchen Restroom				
267	Multi-Purpose Bldg Kitchen Restroom				
Audible					
039	Kindergarten Bldg South Exterior				
080	Rooms 1-6 Bldg South Exterior				
131	Rooms 7-12 Bldg South Exterior				
132	Rooms 7-12 Bldg West Exterior				
169	Rooms 13-18 Bldg North Exterior				
170	Rooms 13-18 Bldg South Exterior				
212	Rms 19 20 Bldg East Exterior				
255	Multi-Purpose Bldg East Exterior				

Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Remote Annunciator					
001	Admin Building Reception				
NAC Power Extender Panel					
089	Rooms 1-6 Bldg Custodial Storage P/E C				
090	Rooms 1-6 Bldg Custodial Storage				
091	Rooms 1-6 Bldg Custodial Storage				
092	Rooms 1-6 Bldg Custodial Storage - P.E. D				
185	Rooms 13-18 Bldg Project Area Storage				
186	Rooms 13-18 Bldg Project Area Storage				
268	Multi-Purpose Bldg MP Hall Storage				
Fire Alarm Panel					
	Rooms 1-6 Bldg Custodial Storage				

Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Manual Pull Station					
2-142 002	Admin Building Reception				
2-160 217	Multi-Purpose Bldg MP Room SE				
2-158 218	Multi-Purpose Bldg MP Room SW				
2-157 219	Multi-Purpose Bldg MP Room NW				
2-159 220	Multi-Purpose Bldg MP Room NE				
2-161 221	Multi-Purpose Bldg Stage				
Smoke Detector - General					
2-048 003	Admin Building Reception				
2-047 004	Admin Building Principals Office				
2-051 005	Admin Building Principals Off Closet				
2-053 006	Admin Building Nurse Room				
2-056 007	Admin Building Back Office Restroom				
2-044 008	Admin Building Work Room				
2-046 009	Admin Building Staff Room				
2-045 010	Admin Building Staff Room				
2-043 011	Admin Building Staff Room				
2-042 012	Admin Building Staff Room				
2-050 013	Admin Building Hall				
2-049 014	Admin Building Hall Closet				
2-052 015	Admin Building Office Restroom				
2-057 016	Admin Building Meeting Room				
2-054 017	Admin Building Meeting Room Closet				
2-055 018	Admin Building ADS Restroom				
2-035 030	Kindergarten Bldg Room K1				
2-036 031	Kindergarten Bldg Room K1				
2-034 032	Kindergarten Bldg Room K1 Closet				
2-033 033	Kindergarten Bldg Room K1 Restroom				
2-039 034	Kindergarten Bldg Room K2				
2-040 035	Kindergarten Bldg Room K2				
2-038 036	Kindergarten Bldg Room K2 Closet				
2-037 037	Kindergarten Bldg Room K2 Restroom				
2-028 044	Rooms 1-6 Bldg Classroom 1				
2-026 045	Rooms 1-6 Bldg Classroom 1				
2-027 046	Rooms 1-6 Bldg Classroom 1				
2-025 047	Rooms 1-6 Bldg Classroom 1				
2-024 048	Rooms 1-6 Bldg Classroom 2				
2-022 049	Rooms 1-6 Bldg Classroom 2				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-023 050	Rooms 1-6 Bldg Classroom 2				
2-021 051	Rooms 1-6 Bldg Classroom 2				
2-020 052	Rooms 1-6 Bldg Classroom 3				
2-018 053	Rooms 1-6 Bldg Classroom 3				
2-019 054	Rooms 1-6 Bldg Classroom 3				
2-017 055	Rooms 1-6 Bldg Classroom 3				
2-008 056	Rooms 1-6 Bldg Classroom 4				
2-006 057	Rooms 1-6 Bldg Classroom 4				
2-005 058	Rooms 1-6 Bldg Classroom 4				
2-007 059	Rooms 1-6 Bldg Classroom 4				
2-012 060	Rooms 1-6 Bldg Classroom 5				
2-011 061	Rooms 1-6 Bldg Classroom 5				
2-009 062	Rooms 1-6 Bldg Classroom 5				
2-010 063	Rooms 1-6 Bldg Classroom 5				
2-016 064	Rooms 1-6 Bldg Classroom 6				
2-014 065	Rooms 1-6 Bldg Classroom 6				
2-013 066	Rooms 1-6 Bldg Classroom 6				
2-015 067	Rooms 1-6 Bldg Classroom 6				
2-030 068	Rooms 1-6 Bldg Boys Restroom				
2-029 069	Rooms 1-6 Bldg Storage Room				
2-002 070	Rooms 1-6 Bldg Custodial Storage				
2-004 071	Rooms 1-6 Bldg Girls Restroom				
2-253 093	Rooms 7-12 Bldg Classroom 7				
2-255 094	Rooms 7-12 Bldg Classroom 7				
2-254 095	Rooms 7-12 Bldg Classroom 7				
2-252 096	Rooms 7-12 Bldg Classroom 7				
2-257 097	Rooms 7-12 Bldg Classroom 8				
2-259 098	Rooms 7-12 Bldg Classroom 8				
2-258 099	Rooms 7-12 Bldg Classroom 8				
2-256 100	Rooms 7-12 Bldg Classroom 8				
2-260 101	Rooms 7-12 Bldg Classroom 9				
2-262 102	Rooms 7-12 Bldg Classroom 9				
2-261 103	Rooms 7-12 Bldg Classroom 9				
2-330 104	Rooms 7-12 Bldg Classroom 9				
2-280 105	Rooms 7-12 Bldg Classroom 10				
2-282 106	Rooms 7-12 Bldg Classroom 10				
2-281 107	Rooms 7-12 Bldg Classroom 10				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-279 108	Rooms 7-12 Bldg Classroom 10				
2-276 109	Rooms 7-12 Bldg Classroom 11				
2-278 110	Rooms 7-12 Bldg Classroom 11				
2-277 111	Rooms 7-12 Bldg Classroom 11				
2-275 112	Rooms 7-12 Bldg Classroom 11				
2-272 113	Rooms 7-12 Bldg Classroom 12				
2-274 114	Rooms 7-12 Bldg Classroom 12				
2-273 115	Rooms 7-12 Bldg Classroom 12				
2-271 116	Rooms 7-12 Bldg Classroom 12				
2-270 117	Rooms 7-12 Bldg Classroom 12 RR				
2-268 118	Rooms 7-12 Bldg Boys RR at Room 12				
2-269 119	Rooms 7-12 Bldg Boys RR at Room 12				
2-263 120	Rooms 7-12 Bldg PE Storage Room				
2-267 121	Rooms 7-12 Bldg Storage at PE Rm				
2-266 122	Rooms 7-12 Bldg Storage at PE Rm				
2-265 123	Rooms 7-12 Bldg Storage at PE Rm				
2-264 124	Rooms 7-12 Bldg Girls RR at Room 9				
2-288 145	Rooms 13-18 Bldg Classroom 13				
2-289 146	Rooms 13-18 Bldg Classroom 13				
2-290 147	Rooms 13-18 Bldg Classroom 14				
2-291 148	Rooms 13-18 Bldg Classroom 14				
2-292 149	Rooms 13-18 Bldg Classroom 15				
2-293 150	Rooms 13-18 Bldg Classroom 15				
2-306 151	Rooms 13-18 Bldg Classroom 16				
2-305 152	Rooms 13-18 Bldg Classroom 16				
2-303 153	Rooms 13-18 Bldg Classroom 17				
2-302 154	Rooms 13-18 Bldg Classroom 17				
2-299 155	Rooms 13-18 Bldg Classroom 18				
2-300 156	Rooms 13-18 Bldg Classroom 18				
2-298 157	Rooms 13-18 Bldg Computer Room				
2-301 158	Rooms 13-18 Bldg Computer Room				
2-304 159	Rooms 13-18 Bldg Project Area				
2-287 160	Rooms 13-18 Bldg Project Area Storage				
2-296 161	Rooms 13-18 Bldg Pysch Room				
2-294 162	Rooms 13-18 Bldg Mens Restroom				
2-295 163	Rooms 13-18 Bldg Womens Restroom				
2-297 164	Rooms 13-18 Bldg Custodial Closet				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-286 165	Rooms 13-18 Bldg Speech Room				
2-285 166	Rooms 13-18 Bldg Boys Restroom				
2-284 167	Rooms 13-18 Bldg Girls Restroom				
2-309 187	Rms 19 20 Bldg Library				
2-310 188	Rms 19 20 Bldg Library				
2-313 189	Rms 19 20 Bldg Library				
2-311 190	Rms 19 20 Bldg Library				
2-312 191	Rms 19 20 Bldg Library				
2-314 192	Rms 19 20 Bldg Library				
2-318 193	Rms 19 20 Bldg Library				
2-315 194	Rms 19 20 Bldg Library				
2-316 195	Rms 19 20 Bldg Library				
2-317 196	Rms 19 20 Bldg Library				
2-308 197	Rms 19 20 Bldg Library IDF Room				
2-322 198	Rms 19 20 Bldg Classroom 19				
2-323 199	Rms 19 20 Bldg Classroom 19				
2-319 200	Rms 19 20 Bldg Classroom 19				
2-320 201	Rms 19 20 Bldg Classroom 19				
2-321 202	Rms 19 20 Bldg Classroom 19				
2-327 203	Rms 19 20 Bldg Classroom 20				
2-328 204	Rms 19 20 Bldg Classroom 20				
2-324 205	Rms 19 20 Bldg Classroom 20				
2-325 206	Rms 19 20 Bldg Classroom 20				
2-326 207	Rms 19 20 Bldg Classroom 20				
2-074 222	Multi-Purpose Bldg Stage Steps				
2-075 223	Multi-Purpose Bldg Stage				
2-076 224	Multi-Purpose Bldg Stage				
2-077 225	Multi-Purpose Bldg Stage Steps				
2-061 226	Multi-Purpose Bldg MP Hall				
2-063 227	Multi-Purpose Bldg Girls Restroom				
2-062 228	Multi-Purpose Bldg Boys Restroom				
2-060 229	Multi-Purpose Bldg MP Hall Storage				
2-066 230	Multi-Purpose Bldg Bridges Room				
2-067 231	Multi-Purpose Bldg Bridges Rm Closet				
2-059 232	Multi-Purpose Bldg Bridges Rm Closet				
2-070 233	Multi-Purpose Bldg Kitchen Restroom				
2-069 234	Multi-Purpose Bldg Kitchen Restroom				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-068 235	Multi-Purpose Bldg Kitchen Storage				
Heat Detector - Restorable Spot					
2-146 019	Admin Building Attic Meeting Room				
2-136 038	Kindergarten Bldg Attic Room K1 RR				
2-003 072	Rooms 1-6 Bldg Custodial Storage				
2-031 073	Rooms 1-6 Bldg Storage Near Room 1				
2-135 074	Rooms 1-6 Bldg Classroom 1 Soffit				
2-134 075	Rooms 1-6 Bldg Classroom 2 Soffit				
2-133 076	Rooms 1-6 Bldg Classroom 3 Soffit				
2-130 077	Rooms 1-6 Bldg Classroom 4 Soffit				
2-131 078	Rooms 1-6 Bldg Classroom 5 Soffit				
2-132 079	Rooms 1-6 Bldg Classroom 6 Soffit				
2-376 125	Rooms 7-12 Bldg Classroom 7 Soffit				
2-377 126	Rooms 7-12 Bldg Classroom 8 Soffit				
2-378 127	Rooms 7-12 Bldg Classroom 9 Soffit				
2-381 128	Rooms 7-12 Bldg Classroom 10 Soffit				
2-380 129	Rooms 7-12 Bldg Classroom 11 Soffit				
2-379 130	Rooms 7-12 Bldg Classroom 12 Soffit				
2-382 168	Rooms 13-18 Bldg Attic Project Area				
2-383 208	Rms 19 20 Bldg Library HVAC Closet				
2-384 209	Rms 19 20 Bldg Library HVAC Closet				
2-385 210	Rms 19 20 Bldg Room 19 HVAC Clst				
2-386 211	Rms 19 20 Bldg Room 20 HVAC Clst				
2-064 236	Multi-Purpose Bldg Kitchen				
2-065 237	Multi-Purpose Bldg Kitchen				
2-071 238	Multi-Purpose Bldg Kitchen				
2-072 239	Multi-Purpose Bldg Kitchen Office				
2-073 240	Multi-Purpose Bldg Kitchen OS Wtr Htr				
2-138 241	Multi-Purpose Bldg Attic Hall				
2-141 242	Multi-Purpose Bldg Attic Kitchen				
2-143 243	Multi-Purpose Bldg Attic Kitchen Storage				
2-147 244	Multi-Purpose Bldg Under Stage				
2-147 245	Multi-Purpose Bldg Under Stage				
2-147 246	Multi-Purpose Bldg Under Stage				
2-147 247	Multi-Purpose Bldg Under Stage				
2-147 248	Multi-Purpose Bldg Under Stage				
2-147 249	Multi-Purpose Bldg Under Stage				
Smoke Detector - Duct					

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-144 250	Multi-Purpose Bldg Stage Left				
2-145 251	Multi-Purpose Bldg Stage Right				
Smoke Detector - Projected Beam					
2-151 252	Multi-Purpose Bldg MP Room Left				
2-149 253	Multi-Purpose Bldg MP Room Center				
2-140 254	Multi-Purpose Bldg MP Room Right				
Valve Tamper Switch					
2-387 269	NW Parking Lot OSY				
2-387 270	NW Parking Lot OSY				