

Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

COTTAGE ELEMENTARY

2221 MORSE AVE
SACRAMENTO, California
United States

This site has been inspected and tested in compliance with applicable standards.

Completed

Thursday, October 09, 2025

Test Session:07 Oct 2025 14:22 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD
5320 HEMLOCK ST
SACRAMENTO, California
United States

TESTED BY

Riley Goyet
Western States Fire Protection-
Sacramento
188 Cirby Way
Roseville, CA 95678
United States



Inspection Summary

Building Information

PROPERTY	COTTAGE ELEMENTARY	CONTACT
ADDRESS	2221 MORSE AVE	PHONE
CITY/STATE	SACRAMENTO, California	MOBILE
COUNTRY	United States	EMAIL

Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us

Testing Summary


EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Alarm Notification Appliance	69	69(100%)	69(100%)	0(0%)
Power Supplies	1	1(100%)	1(100%)	0(0%)
Fire Control Panel	6	6(100%)	6(100%)	0(0%)
Initiating Device	110	109(99%)	109(99%)	0(0%)

Certification

The equipment specified here in was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Thursday, October 09, 2025

ACCEPTED BY 10/09/2025

Building Representative

TESTED BY 10/09/2025

Riley Goyet
Technician

System Details

Control Units

ADDRESS/ SCAN ADDRESS	DESCRIPTION	Building A Storage A5
MANUFACTURER	S/W VERSION	
MODEL	LAST UPDATE	
SERIAL NUMBER	S/W LOCATION	
INSTALL DATE		

Secondary Power

TYPE	Battery - Sealed Lead-acid	DESCRIPTION	Building A Storage A5 - Fire Panel Batteries
ADDRESS/ SCAN ADDRESS		NOMINAL VOLTAGE	
Load Voltage		Amp Hours	
Standby Hours		Alarm Minutes	
Battery Location		Charger Voltage	

Testing Details

Alarm Notification Appliance

Passed				
EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	019	Building A Admin A1 Reception	Manual	10/7/2025 2:23:14 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	020	Building A Admin Nurse Off A2	Manual	10/7/2025 2:23:15 PM
		Visual inspection	Passed (Manual)	
Visible	022	Building A Admin Office RR A2A	Manual	10/7/2025 2:23:18 PM
		Visual inspection	Passed (Manual)	
Visible	023	Building A Admin Princ Off A1A	Manual	10/7/2025 2:23:20 PM
		Visual inspection	Passed (Manual)	
Visible	025	Building A Admin RR A4A	Manual	10/7/2025 2:23:22 PM
		Visual inspection	Passed (Manual)	
Visible	026	Building A Library A4	Manual	10/7/2025 2:23:24 PM
		Visual inspection	Passed (Manual)	
Audible	017	Building A North Exterior	Manual	10/7/2025 2:24:32 PM
		Visual inspection	Passed (Manual)	
Visible	024	Building A Storage A1B	Manual	10/7/2025 2:23:21 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	021	Building A Storage A5	Manual	10/7/2025 2:23:17 PM
		Visual inspection	Passed (Manual)	
Audible	018	Building A West Exterior	Manual	10/7/2025 2:24:33 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	042	Building B Classroom B1	Manual	10/7/2025 2:23:25 PM
		Visual inspection	Passed (Manual)	
Visible	044	Building B Classroom B1 RR	Manual	10/7/2025 2:23:28 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	043	Building B Classroom B2	Manual	10/7/2025 2:23:27 PM
		Visual inspection	Passed (Manual)	
Visible	045	Building B Classroom B2 RR	Manual	10/7/2025 2:23:29 PM
		Visual inspection	Passed (Manual)	
Audible	040	Building B North Exterior	Manual	10/7/2025 2:24:36 PM
		Visual inspection	Passed (Manual)	
Audible	041	Building B South Exterior	Manual	10/7/2025 2:24:34 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	049	Building C Classroom C1	Manual	10/7/2025 2:23:31 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	048	Building C South Exterior	Manual	10/7/2025 2:24:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	059	Building D Classroom D1	Manual	10/7/2025 2:23:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	060	Building D Classroom D2	Manual	10/7/2025 2:23:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	061	Building D Classroom D3	Manual	10/7/2025 2:23:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	056	Building D North Exterior	Manual	10/7/2025 2:24:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	057	Building D South Exterior	Manual	10/7/2025 2:24:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	058	Building D West Exterior	Manual	10/7/2025 2:24:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	077	Building E Boys Restroom E4	Manual	10/7/2025 2:23:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	074	Building E Classroom E1	Manual	10/7/2025 2:23:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	075	Building E Classroom E2	Manual	10/7/2025 2:23:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	076	Building E Classroom E3	Manual	10/7/2025 2:23:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	078	Building E Girls Restroom E6	Manual	10/7/2025 2:23:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	071	Building E North Exterior	Manual	10/7/2025 2:24:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	072	Building E South Exterior	Manual	10/7/2025 2:24:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	073	Building E West Exterior	Manual	10/7/2025 2:24:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	091	Building F Discov Club F1 Off	Manual	10/7/2025 2:23:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	090	Building F Discovery Club F1	Manual	10/7/2025 2:23:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	092	Building F Discovery Club F1 RR	Manual	10/7/2025 2:23:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible	093	Building F Discovery Club F1 RR	Manual	10/7/2025 2:23:34 PM
		Visual inspection	Passed (Manual)	
Audible	089	Building F West Exterior	Manual	10/7/2025 2:24:48 PM
		Visual inspection	Passed (Manual)	
Audible	089	Functional Inspection	Passed	
		Building G Boys Restroom G3	Manual	10/7/2025 2:24:03 PM
Visible	106	Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	104	Building G Classroom G1	Manual	10/7/2025 2:24:00 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	104	Functional Inspection	Passed	
		Building G Classroom G2	Manual	10/7/2025 2:24:01 PM
Audible And Visible	105	Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	102	Building G East Exterior	Manual	10/7/2025 2:24:50 PM
		Visual inspection	Passed (Manual)	
Visible	107	Functional Inspection	Passed	
		Building G Girls Restroom G5	Manual	10/7/2025 2:24:04 PM
Visible	107	Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	101	Building G North Exterior	Manual	10/7/2025 2:24:49 PM
		Visual inspection	Passed (Manual)	
Audible	101	Functional Inspection	Passed	
		Building G South Exterior	Manual	10/7/2025 2:24:52 PM
Audible	103	Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	115	Building H Classroom H1	Manual	10/7/2025 2:24:06 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	115	Functional Inspection	Passed	
		Building H Classroom H2	Manual	10/7/2025 2:24:08 PM
Audible And Visible	116	Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	114	Building H South Exterior	Manual	10/7/2025 2:24:53 PM
		Visual inspection	Passed (Manual)	
Visible	134	Functional Inspection	Passed	
		Building I Boys Restroom I6	Manual	10/7/2025 2:24:14 PM
Visible	134	Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	131	Building I Classroom I1	Manual	10/7/2025 2:24:10 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	131	Functional Inspection	Passed	
		Building I Classroom I2	Manual	10/7/2025 2:24:09 PM
Audible And Visible	132	Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	133	Building I Classroom I3	Manual	10/7/2025 2:24:12 PM
		Visual inspection	Passed (Manual)	
Audible	127	Functional Inspection	Passed	
		Building I East Exterior	Manual	10/7/2025 2:24:56 PM
Audible	127	Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	135	Building I Girls Restroom I4	Manual	10/7/2025 2:24:15 PM
		Visual inspection	Passed (Manual)	
Visible	135	Functional Inspection	Passed	
		Building I North Exterior	Manual	10/7/2025 2:24:54 PM
Audible	126			

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	128	Building I Southeast Exterior	Manual	10/7/2025 2:24:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	129	Building I Southwest Exterior	Manual	10/7/2025 2:24:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	130	Building I West Exterior	Manual	10/7/2025 2:25:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	168	Building J Kitchen	Manual	10/7/2025 2:24:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	170	Building J Kitchen	Manual	10/7/2025 2:24:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	171	Building J Kitchen Restroom	Manual	10/7/2025 2:24:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	172	Building J Kitchen Restroom	Manual	10/7/2025 2:24:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	166	Building J MP Room	Manual	10/7/2025 2:24:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	167	Building J MP Room	Manual	10/7/2025 2:24:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	169	Building J MP Room Hall	Manual	10/7/2025 2:24:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	173	Building J MP Room Staff RR	Manual	10/7/2025 2:24:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	174	Building J MP Room Staff RR	Manual	10/7/2025 2:24:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	164	Building J South Exterior	Manual	10/7/2025 2:25:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	165	Building J West Exterior	Manual	10/7/2025 2:25:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	175	Building J Work Room J4	Manual	10/7/2025 2:24:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Remote Annunciator	001	Building A Admin A1 Reception	Manual	10/7/2025 4:36:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Fire Alarm Panel		Building A Storage A5	Manual	10/7/2025 4:36:06 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
NAC Power Extender Panel	027	Building A Storage A5	Manual	10/7/2025 4:35:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	079	Building E Custodial Closet E5	Manual	10/7/2025 4:35:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	109	Building G Custodial Closet G4	Manual	10/7/2025 4:35:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	108	Building G Custodial Closet G4	Manual	10/7/2025 4:35:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Manual Pull Station	2-126 002	Building A Admin A1 Reception	Manual	10/7/2025 5:06:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-003 003	Building A Admin A1 Reception	Manual	10/7/2025 4:51:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-002 004	Building A Admin Closet A1	Manual	10/7/2025 4:50:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-010 012	Building A Admin Hall A4A	Manual	10/7/2025 4:52:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-006 008	Building A Admin Nurse Off A2	Manual	10/7/2025 4:49:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-005 009	Building A Admin Office RR A2A	Manual	10/7/2025 4:49:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-004 005	Building A Admin Princ Off A1A	Manual	10/7/2025 4:49:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-007 013	Building A Admin RR A4A	Manual	10/7/2025 4:51:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-127 016	Building A Attic Admin Hall A4A	Manual	10/7/2025 5:09:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-011 014	Building A Hall Closet A4A2	Manual	10/7/2025 4:51:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-013 011	Building A Library A4	Manual	10/7/2025 4:10:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-012 010	Building A Library A4	Manual	10/7/2025 4:38:56 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-009 006	Building A Storage A1B	Manual	10/7/2025 4:50:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-008 007	Building A Storage A1B	Manual	10/7/2025 4:52:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-001 015	Building A Storage A5	Manual	10/7/2025 4:51:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-021 030	Building B Classroom B1	Manual	10/7/2025 4:40:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-022 031	Building B Classroom B1	Manual	10/7/2025 4:41:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-062 032	Building B Classroom B1	Manual	10/7/2025 4:41:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-024 029	Building B Classroom B1	Manual	10/7/2025 4:42:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-063 028	Building B Classroom B1	Manual	10/7/2025 4:42:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-023 033	Building B Classroom B1 RR	Manual	10/7/2025 4:43:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-016 038	Building B Classroom B2	Manual	10/7/2025 4:07:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-019 037	Building B Classroom B2	Manual	10/7/2025 4:44:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-017 034	Building B Classroom B2	Manual	10/7/2025 4:45:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-015 035	Building B Classroom B2	Manual	10/7/2025 4:45:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-018 036	Building B Classroom B2	Manual	10/7/2025 4:45:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-020 039	Building B Classroom B2 RR	Manual	10/7/2025 4:43:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-044 047	Building C Classroom C1	Manual	10/7/2025 4:28:42 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	2-045 046	Building C Classroom C1	Manual	10/7/2025 4:29:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-056 051	Building D Classroom D1	Manual	10/7/2025 4:21:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-055 050	Building D Classroom D1	Manual	10/7/2025 4:21:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-058 053	Building D Classroom D2	Manual	10/7/2025 4:22:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-057 052	Building D Classroom D2	Manual	10/7/2025 4:23:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-060 055	Building D Classroom D3	Manual	10/7/2025 4:23:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-059 054	Building D Classroom D3	Manual	10/7/2025 4:24:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-048 068	Building E Boys Restroom E4	Manual	10/7/2025 4:27:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-050 063	Building E Classroom E1	Manual	10/7/2025 4:19:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-049 062	Building E Classroom E1	Manual	10/7/2025 4:19:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-051 064	Building E Classroom E2	Manual	10/7/2025 4:18:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-052 065	Building E Classroom E2	Manual	10/7/2025 4:18:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-053 067	Building E Classroom E3	Manual	10/7/2025 4:16:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-053 066	Building E Classroom E3	Manual	10/7/2025 4:17:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-046 069	Building E Custodial Closet E5	Manual	10/7/2025 4:26:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-047 070	Building E Girls Restroom E6	Manual	10/7/2025 4:26:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-377 087	Building F Attic F1	Manual	10/7/2025 5:06:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-377 086	Building F Attic F1	Manual	10/7/2025 5:06:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-378 088	Building F Attic F1 Office	Manual	10/7/2025 5:01:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-376 085	Building F Attic F1 RR	Manual	10/7/2025 5:06:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-263 082	Building F Discov Club F1 Off	Manual	10/7/2025 4:02:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-261 080	Building F Discovery Club F1	Manual	10/7/2025 4:01:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-262 081	Building F Discovery Club F1	Manual	10/7/2025 4:02:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-260 083	Building F Discovery Club F1 RR	Manual	10/7/2025 4:02:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-259 084	Building F Discovery Club F1 RR	Manual	10/7/2025 4:05:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-253 098	Building G Boys Restroom G3	Manual	10/7/2025 3:59:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-257 094	Building G Classroom G1	Manual	10/7/2025 3:54:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-256 095	Building G Classroom G1	Manual	10/7/2025 3:55:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-255 096	Building G Classroom G2	Manual	10/7/2025 3:57:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-254 097	Building G Classroom G2	Manual	10/7/2025 3:58:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-251 099	Building G Custodial Closet G4	Manual	10/7/2025 4:01:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-252 100	Building G Girls Restroom G5	Manual	10/7/2025 3:59:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-267 111	Building H Classroom H1	Manual	10/7/2025 3:48:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-268 110	Building H Classroom H1	Manual	10/7/2025 3:48:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-265 113	Building H Classroom H2	Manual	10/7/2025 3:48:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-266 112	Building H Classroom H2	Manual	10/7/2025 3:48:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-276 125	Building I Boys Restroom I6	Manual	10/7/2025 4:52:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-269 117	Building I Classroom I1	Manual	10/7/2025 3:54:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-270 118	Building I Classroom I1	Manual	10/7/2025 3:54:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-271 119	Building I Classroom I2	Manual	10/7/2025 3:51:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-272 120	Building I Classroom I2	Manual	10/7/2025 3:51:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-273 121	Building I Classroom I3	Manual	10/7/2025 3:48:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-274 122	Building I Classroom I3	Manual	10/7/2025 3:49:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-277 123	Building I Girls Restroom I4	Manual	10/7/2025 4:52:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-275 124	Building I Storage Room I5	Manual	10/7/2025 4:50:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-135 162	Building J Attic Kitchen	Manual	10/7/2025 5:17:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-131 161	Building J Attic Kitchen	Manual	10/7/2025 5:17:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-134 163	Building J Attic Kitchen RR	Manual	10/7/2025 5:06:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-130 159	Building J Attic MP Room Hall	Manual	10/7/2025 5:08:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-133 160	Building J Attic MP Room RR	Manual	10/7/2025 5:06:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-038 157	Building J Kitchen	Manual	10/7/2025 4:54:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-039 158	Building J Kitchen	Manual	10/7/2025 4:54:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-033 156	Building J Kitchen	Manual	10/7/2025 4:54:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-042 149	Building J Kitchen RR	Manual	10/7/2025 4:35:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-041 150	Building J Kitchen RR	Manual	10/7/2025 4:35:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-034 148	Building J MP Rm Hall Storage	Manual	10/7/2025 4:50:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-026 139	Building J MP Room	Manual	10/7/2025 4:31:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-027 140	Building J MP Room	Manual	10/7/2025 4:31:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-028 141	Building J MP Room	Manual	10/7/2025 4:32:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-029 142	Building J MP Room	Manual	10/7/2025 4:32:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-067 144	Building J MP Room	Manual	10/7/2025 4:32:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-066 143	Building J MP Room	Manual	10/7/2025 4:33:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-030 145	Building J MP Room	Manual	10/7/2025 4:33:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-031 146	Building J MP Room	Manual	10/7/2025 4:33:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-032 147	Building J MP Room Hall	Manual	10/7/2025 4:34:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-132 138	Building J MP Room Northeast	Manual	10/7/2025 5:06:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-128 137	Building J MP Room Southeast	Manual	10/7/2025 5:06:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-129 136	Building J MP Room Southwest	Manual	10/7/2025 5:06:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-035 154	Building J MP Room Staff RR	Manual	10/7/2025 4:37:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-036 155	Building J MP Room Staff RR	Manual	10/7/2025 4:37:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-065 152	Building J Storage J3	Manual	10/7/2025 4:50:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-037 153	Building J Work Room J4	Manual	10/7/2025 4:48:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-006	Rm K1	Manual	10/7/2025 4:16:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-005	Rm K1	Manual	10/7/2025 4:16:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-008	Rm K2	Manual	10/7/2025 4:16:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-007	Rm K2	Manual	10/7/2025 4:16:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-010	Rm K3	Manual	10/7/2025 4:16:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-009	Rm K3	Manual	10/7/2025 4:16:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-012	Rm K4	Manual	10/7/2025 4:12:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-011	Rm K4	Manual	10/7/2025 4:12:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-009	Room K3	Manual	10/7/2025 4:16:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-040 151	Building J Kitchen Office	Manual	10/7/2025 4:50:32 PM

Power Supplies

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Battery - Sealed Lead-acid		Building A Storage A5 - Fire Panel Batteries	Manual	10/7/2025 4:36:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Device/Equipment details

Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Audible					
017	Building A North Exterior				
018	Building A West Exterior				
040	Building B North Exterior				
041	Building B South Exterior				
048	Building C South Exterior				
056	Building D North Exterior				
057	Building D South Exterior				
058	Building D West Exterior				
071	Building E North Exterior				
072	Building E South Exterior				
073	Building E West Exterior				
089	Building F West Exterior				
101	Building G North Exterior				
102	Building G East Exterior				
103	Building G South Exterior				
114	Building H South Exterior				
126	Building I North Exterior				
127	Building I East Exterior				
128	Building I Southeast Exterior				
129	Building I Southwest Exterior				
130	Building I West Exterior				
164	Building J South Exterior				
165	Building J West Exterior				
Audible And Visible					
019	Building A Admin A1 Reception				
020	Building A Admin Nurse Off A2				
021	Building A Storage A5				
042	Building B Classroom B1				
043	Building B Classroom B2				
049	Building C Classroom C1				
059	Building D Classroom D1				
060	Building D Classroom D2				
061	Building D Classroom D3				
074	Building E Classroom E1				
075	Building E Classroom E2				
076	Building E Classroom E3				
090	Building F Discovery Club F1				
104	Building G Classroom G1				
105	Building G Classroom G2				
115	Building H Classroom H1				
116	Building H Classroom H2				
131	Building I Classroom I1				
132	Building I Classroom I2				
133	Building I Classroom I3				
166	Building J MP Room				
167	Building J MP Room				
Visible					
022	Building A Admin Office RR A2A				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
023	Building A Admin Princ Off A1A				
024	Building A Storage A1B				
025	Building A Admin RR A4A				
026	Building A Library A4				
044	Building B Classroom B1 RR				
045	Building B Classroom B2 RR				
077	Building E Boys Restroom E4				
078	Building E Girls Restroom E6				
091	Building F Discov Club F1 Off				
092	Building F Discovery Club F1 RR				
093	Building F Discovery Club F1 RR				
106	Building G Boys Restroom G3				
107	Building G Girls Restroom G5				
134	Building I Boys Restroom I6				
135	Building I Girls Restroom I4				
168	Building J Kitchen				
169	Building J MP Room Hall				
170	Building J Kitchen				
171	Building J Kitchen Restroom				
172	Building J Kitchen Restroom				
173	Building J MP Room Staff RR				
174	Building J MP Room Staff RR				
175	Building J Work Room J4				

Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Remote Annunciator					
001	Building A Admin A1 Reception				
NAC Power Extender Panel					
027	Building A Storage A5				
079	Building E Custodial Closet E5				
108	Building G Custodial Closet G4				
109	Building G Custodial Closet G4				

Fire Alarm Panel

Building A Storage A5

Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Manual Pull Station					
2-126 002	Building A Admin A1 Reception				
2-129 136	Building J MP Room Southwest				
2-128 137	Building J MP Room Southeast				
2-132 138	Building J MP Room Northeast				
Smoke Detector - General					
2-003 003	Building A Admin A1 Reception				
2-002 004	Building A Admin Closet A1				
2-004 005	Building A Admin Princ Off A1A				
2-009 006	Building A Storage A1B				
2-008 007	Building A Storage A1B				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-006 008	Building A Admin Nurse Off A2				
2-005 009	Building A Admin Office RR A2A				
2-012 010	Building A Library A4				
2-013 011	Building A Library A4				
2-010 012	Building A Admin Hall A4A				
2-007 013	Building A Admin RR A4A				
2-011 014	Building A Hall Closet A4A2				
2-001 015	Building A Storage A5				
2-063 028	Building B Classroom B1				
2-024 029	Building B Classroom B1				
2-021 030	Building B Classroom B1				
2-022 031	Building B Classroom B1				
2-062 032	Building B Classroom B1				
2-023 033	Building B Classroom B1 RR				
2-017 034	Building B Classroom B2				
2-015 035	Building B Classroom B2				
2-018 036	Building B Classroom B2				
2-019 037	Building B Classroom B2				
2-016 038	Building B Classroom B2				
2-020 039	Building B Classroom B2 RR				
2-045 046	Building C Classroom C1				
2-044 047	Building C Classroom C1				
2-055 050	Building D Classroom D1				
2-056 051	Building D Classroom D1				
2-057 052	Building D Classroom D2				
2-058 053	Building D Classroom D2				
2-059 054	Building D Classroom D3				
2-060 055	Building D Classroom D3				
2-049 062	Building E Classroom E1				
2-050 063	Building E Classroom E1				
2-051 064	Building E Classroom E2				
2-052 065	Building E Classroom E2				
2-053 066	Building E Classroom E3				
2-053 067	Building E Classroom E3				
2-048 068	Building E Boys Restroom E4				
2-046 069	Building E Custodial Closet E5				
2-047 070	Building E Girls Restroom E6				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-261 080	Building F Discovery Club F1				
2-262 081	Building F Discovery Club F1				
2-263 082	Building F Discov Club F1 Off				
2-260 083	Building F Discovery Club F1 RR				
2-259 084	Building F Discovery Club F1 RR				
2-257 094	Building G Classroom G1				
2-256 095	Building G Classroom G1				
2-255 096	Building G Classroom G2				
2-254 097	Building G Classroom G2				
2-253 098	Building G Boys Restroom G3				
2-251 099	Building G Custodial Closet G4				
2-252 100	Building G Girls Restroom G5				
2-268 110	Building H Classroom H1				
2-267 111	Building H Classroom H1				
2-266 112	Building H Classroom H2				
2-265 113	Building H Classroom H2				
2-269 117	Building I Classroom I1				
2-270 118	Building I Classroom I1				
2-271 119	Building I Classroom I2				
2-272 120	Building I Classroom I2				
2-273 121	Building I Classroom I3				
2-274 122	Building I Classroom I3				
2-277 123	Building I Girls Restroom I4				
2-275 124	Building I Storage Room I5				
2-276 125	Building I Boys Restroom I6				
2-026 139	Building J MP Room				
2-027 140	Building J MP Room				
2-028 141	Building J MP Room				
2-029 142	Building J MP Room				
2-066 143	Building J MP Room				
2-067 144	Building J MP Room				
2-030 145	Building J MP Room				
2-031 146	Building J MP Room				
2-032 147	Building J MP Room Hall				
2-034 148	Building J MP Rm Hall Storage				
2-042 149	Building J Kitchen RR				
2-041 150	Building J Kitchen RR				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-040 151	Building J Kitchen Office				
2-065 152	Building J Storage J3				
2-037 153	Building J Work Room J4				
2-035 154	Building J MP Room Staff RR				
2-036 155	Building J MP Room Staff RR				
4-005	Rm K1				
4-006	Rm K1				
4-008	Rm K2				
4-007	Rm K2				
4-010	Rm K3				
4-009	Rm K3				
4-011	Rm K4				
4-012	Rm K4				
4-009	Room K3				12/22/2023
Heat Detector - Restorable Spot					
2-127 016	Building A Attic Admin Hall A4A				
2-376 085	Building F Attic F1 RR				
2-377 086	Building F Attic F1				
2-377 087	Building F Attic F1				
2-378 088	Building F Attic F1 Office				
2-033 156	Building J Kitchen				
2-038 157	Building J Kitchen				
2-039 158	Building J Kitchen				
2-130 159	Building J Attic MP Room Hall				
2-133 160	Building J Attic MP Room RR				
2-131 161	Building J Attic Kitchen				
2-135 162	Building J Attic Kitchen				
2-134 163	Building J Attic Kitchen RR				

Power Supplies

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Battery - Sealed Lead-acid					
	Building A Storage A5 - Fire Panel Batteries				