

# Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

ORANGEVALE OPEN

5630 ILLINOIS AVE  
FAIR OAKS, California  
United States

This site has been inspected and tested in compliance with applicable standards.

Completed

Thursday, October 30, 2025

Test Session: 27 Oct 2025 15:35 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD  
5320 HEMLOCK ST  
SACRAMENTO, California  
United States

TESTED BY

Riley Goyet  
Western States Fire Protection-  
Sacramento  
188 Cirby Way  
Roseville, CA 95678  
United States



# Inspection Summary

## Building Information

PROPERTY	ORANGEVALE OPEN	CONTACT
ADDRESS	5630 ILLINOIS AVE	PHONE
CITY/STATE	FAIR OAKS, California	MOBILE
COUNTRY	United States	EMAIL

## Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us

## Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Alarm Notification Appliance	77	77(100%)	77(100%)	0(0%)
Fire Control Panel	7	7(100%)	1(14%)	6(86%)
Initiating Device	165	165(100%)	165(100%)	0(0%)

## Certification

The equipment specified here in was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Thursday, October 30, 2025

ACCEPTED BY 10/30/2025

Building Representative



TESTED BY 10/30/2025

Riley Goyet  
Technician

# System Details

## Control Units

ADDRESS/ SCAN ADDRESS	DESCRIPTION	Rooms 2-5 Bldg Custodial Office
MANUFACTURER	S/W VERSION	
MODEL	LAST UPDATE	
SERIAL NUMBER	S/W LOCATION	
INSTALL DATE		

# Open Corrective Action & Solution Summary

The following 11 corrective action(s) remain open following the system inspection, testing or maintenance activities

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
NAC Power Extender Panel	246	Multi-Purpose Bldg Media Office - P.E. "E"
	Created By:	Riley Goyet
	Creation Date:	10/12/2023
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
	Created By:	Riley Goyet
	Creation Date:	10/28/2025
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
NAC Power Extender Panel	247	Multi-Purpose Bldg Media Office - P.E. "F"
	Created By:	Riley Goyet
	Creation Date:	10/12/2023
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
	Created By:	Riley Goyet
	Creation Date:	10/28/2025
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
Fire Alarm Panel		Rooms 2-5 Bldg Custodial Office
	Created By:	Riley Goyet
	Creation Date:	10/12/2023
	Corrective Action:	Replace (2) 12V 55AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
	Created By:	Riley Goyet
	Creation Date:	11/04/2024
	Corrective Action:	Replace (2) 12V 55AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
	Created By:	Riley Goyet
	Creation Date:	10/28/2025
	Corrective Action:	Replace (2) 12V 55AH Batteries
	Proposed Solution:	
	Manufacturer:	
	Model:	
NAC Power Extender Panel	069	Rooms 2-5 Bldg Custodial Office - P.E. "Master"
	Created By:	Riley Goyet
	Creation Date:	11/04/2024
	Corrective Action:	Replace (2) 12V 8AH Batteries
	Proposed Solution:	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION
----------------	---------	-------------

Manufacturer:  
Model:

Created By: Riley Goyet  
 Creation Date: 10/28/2025  
 Corrective Action: Replace (2) 12V 8AH Batteries  
 Proposed Solution:  
 Manufacturer:  
 Model:

NAC Power Extender Panel	070	Rooms 2-5 Bldg Custodial Office - P.E. "B"
--------------------------	-----	--

Created By: Riley Goyet  
 Creation Date: 10/28/2025  
 Corrective Action: Replace (2) 12V 8AH Batteries  
 Proposed Solution:  
 Manufacturer:  
 Model:

NAC Power Extender Panel	071	Rooms 2-5 Bldg Custodial Office - P.E. "C"
--------------------------	-----	--

Created By: Riley Goyet  
 Creation Date: 10/28/2025  
 Corrective Action: Replace (2) 12V 8AH Batteries  
 Proposed Solution:  
 Manufacturer:  
 Model:

# Testing Details

## Alarm Notification Appliance

Passed				
EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible	020	Admin Building Admin Reception	Manual	10/28/2025 3:38:44 PM
		Visual inspection	Passed (Manual)	
Visible	026	Admin Building O/S Staff Restroom	Manual	10/28/2025 3:38:38 PM
		Visual inspection	Passed (Manual)	
Visible	021	Admin Building Principals Office	Manual	10/28/2025 3:38:46 PM
		Visual inspection	Passed (Manual)	
Visible	022	Admin Building Principals Office RR	Manual	10/28/2025 3:38:33 PM
		Visual inspection	Passed (Manual)	
Audible	017	Admin Building South Exterior	Manual	10/28/2025 3:40:56 PM
		Visual inspection	Passed (Manual)	
Visible	025	Admin Building Staff Restroom	Manual	10/28/2025 3:38:40 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	019	Admin Building Staff Workroom	Manual	10/28/2025 3:39:51 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	018	Admin Building Supply Storage	Manual	10/28/2025 3:40:10 PM
		Visual inspection	Passed (Manual)	
Visible	024	Admin Building Supply Storage RR	Manual	10/28/2025 3:38:41 PM
		Visual inspection	Passed (Manual)	
Visible	023	Admin Building VP Office	Manual	10/28/2025 3:38:42 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	032	Kindergarten Bldg Room K1	Manual	10/28/2025 3:39:42 PM
		Visual inspection	Passed (Manual)	
Visible	034	Kindergarten Bldg Room K1 Restroom	Manual	10/28/2025 3:38:30 PM
		Visual inspection	Passed (Manual)	
Visible	033	Kindergarten Bldg Room K1 Storage	Manual	10/28/2025 3:38:36 PM
		Visual inspection	Passed (Manual)	
Audible	031	Kindergarten Bldg West Exterior	Manual	10/28/2025 3:41:02 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	240	Multi-Purpose Bldg Intervention Room	Manual	10/28/2025 3:40:11 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	237	Multi-Purpose Bldg Kitchen	Manual	10/28/2025 3:39:14 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	238	Multi-Purpose Bldg Kitchen	Manual	10/28/2025 3:39:53 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	243	Multi-Purpose Bldg Kitchen Restroom	Manual	10/28/2025 3:38:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	242	Multi-Purpose Bldg Kitchen RR Entry	Manual	10/28/2025 3:38:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	239	Multi-Purpose Bldg Library	Manual	10/28/2025 3:40:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	244	Multi-Purpose Bldg Media Office	Manual	10/28/2025 3:38:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	235	Multi-Purpose Bldg MP Room	Manual	10/28/2025 3:40:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	234	Multi-Purpose Bldg MP Room	Manual	10/28/2025 3:40:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	245	Multi-Purpose Bldg Music Office	Manual	10/28/2025 3:38:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	230	Multi-Purpose Bldg North Exterior	Manual	10/28/2025 3:41:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	233	Multi-Purpose Bldg Resource Rm by MP	Manual	10/28/2025 3:40:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	232	Multi-Purpose Bldg Speech Rm by MP	Manual	10/28/2025 3:40:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	236	Multi-Purpose Bldg Stage	Manual	10/28/2025 3:40:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	241	Multi-Purpose Bldg Stage	Manual	10/28/2025 3:38:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	231	Multi-Purpose Bldg West Exterior	Manual	10/28/2025 3:41:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	185	Portables East Exterior	Manual	10/28/2025 3:40:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	187	Portables Room 20	Manual	10/28/2025 3:40:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	188	Portables Room 21	Manual	10/28/2025 3:40:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	189	Portables Room 22	Manual	10/28/2025 3:40:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	186	Portables South Exterior	Manual	10/28/2025 3:41:10 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Visible	172	Restroom Bldg Boys Restroom	Manual	10/28/2025 3:38:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	169	Restroom Bldg East Exterior	Manual	10/28/2025 3:41:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	171	Restroom Bldg Girls Restroom	Manual	10/28/2025 3:38:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	170	Restroom Bldg West Exterior	Manual	10/28/2025 3:41:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	142	Rooms 11-15 Bldg Boys RR by Rm 11	Manual	10/28/2025 3:38:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	141	Rooms 11-15 Bldg Girls RR by Rm 11	Manual	10/28/2025 3:38:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	136	Rooms 11-15 Bldg Room 11	Manual	10/28/2025 3:40:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	137	Rooms 11-15 Bldg Room 12	Manual	10/28/2025 3:40:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	138	Rooms 11-15 Bldg Room 13	Manual	10/28/2025 3:39:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	139	Rooms 11-15 Bldg Room 14	Manual	10/28/2025 3:40:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	140	Rooms 11-15 Bldg Room 15	Manual	10/28/2025 3:40:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	135	Rooms 11-15 Bldg South Exterior	Manual	10/28/2025 3:40:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	134	Rooms 11-15 Bldg South Exterior	Manual	10/28/2025 3:41:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	161	Rooms 16-19 Bldg Room 16	Manual	10/28/2025 3:40:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	162	Rooms 16-19 Bldg Room 17	Manual	10/28/2025 3:40:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	163	Rooms 16-19 Bldg Room 18	Manual	10/28/2025 3:40:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	164	Rooms 16-19 Bldg Room 19	Manual	10/28/2025 3:40:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	160	Rooms 16-19 Bldg South Exterior	Manual	10/28/2025 3:41:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible	159	Rooms 16-19 Bldg South Exterior	Manual	10/28/2025 3:41:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	067	Rooms 2-5 Bldg Boys RR by Rm 5	Manual	10/28/2025 3:38:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	068	Rooms 2-5 Bldg Custodial Office	Manual	10/28/2025 3:38:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	058	Rooms 2-5 Bldg East Exterior	Manual	10/28/2025 3:40:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	066	Rooms 2-5 Bldg Girls RR by Rm 5	Manual	10/28/2025 3:38:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	057	Rooms 2-5 Bldg North Exterior	Manual	10/28/2025 3:41:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	061	Rooms 2-5 Bldg Room 2	Manual	10/28/2025 3:39:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	063	Rooms 2-5 Bldg Room 3	Manual	10/28/2025 3:39:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	064	Rooms 2-5 Bldg Room 4	Manual	10/28/2025 3:39:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	065	Rooms 2-5 Bldg Room 5	Manual	10/28/2025 3:39:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	060	Rooms 2-5 Bldg South Exterior	Manual	10/28/2025 3:40:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	059	Rooms 2-5 Bldg South Exterior	Manual	10/28/2025 3:40:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	062	Rooms 2-5 Bldg Staff Room	Manual	10/28/2025 3:39:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	108	Rooms 6-10 Bldg Boys RR by Rm 10	Manual	10/28/2025 3:39:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	106	Rooms 6-10 Bldg Conf Rm by Rm 6	Manual	10/28/2025 3:39:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	098	Rooms 6-10 Bldg East Exterior	Manual	10/28/2025 3:40:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	107	Rooms 6-10 Bldg Girls RR by Rm 10	Manual	10/28/2025 3:39:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	104	Rooms 6-10 Bldg Room 10	Manual	10/28/2025 3:39:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	100	Rooms 6-10 Bldg Room 6	Manual	10/28/2025 3:39:10 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	105	Rooms 6-10 Bldg Room 6 Storage	Manual	10/28/2025 3:38:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	101	Rooms 6-10 Bldg Room 7	Manual	10/28/2025 3:39:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	102	Rooms 6-10 Bldg Room 8	Manual	10/28/2025 3:39:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	103	Rooms 6-10 Bldg Room 9	Manual	10/28/2025 3:39:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	099	Rooms 6-10 Bldg South Exterior	Manual	10/28/2025 3:40:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

### Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Remote Annunciator	001	Admin Building Admin Reception	Manual	10/28/2025 4:26:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Failed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
NAC Power Extender Panel	246	Multi-Purpose Bldg Media Office - P.E. "E"	Manual	10/28/2025 4:08:07 PM
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	
NAC Power Extender Panel	247	Multi-Purpose Bldg Media Office - P.E. "F"	Manual	10/28/2025 4:07:54 PM
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	
Fire Alarm Panel		Rooms 2-5 Bldg Custodial Office	Manual	10/28/2025 4:08:38 PM
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	
NAC Power Extender Panel	070	Rooms 2-5 Bldg Custodial Office - P.E. "B"	Manual	10/28/2025 4:07:35 PM
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	
NAC Power Extender Panel	071	Rooms 2-5 Bldg Custodial Office - P.E. "C"	Manual	10/28/2025 4:08:17 PM
		Visual inspection	Failed (Manual)	
		Functional Inspection	Failed	
NAC Power Extender Panel	069	Rooms 2-5 Bldg Custodial Office - P.E. "Master"	Manual	10/28/2025 4:07:25 PM
		Visual inspection	Failed (Manual)	

### Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Manual Pull Station	2-131 002	Admin Building Admin Reception	Manual	10/28/2025 4:26:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-042 004	Admin Building Admin Reception	Manual	10/27/2025 3:38:51 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	2-040 003	Admin Building Admin Reception	Manual	10/28/2025 4:15:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-030 016	Admin Building O/S Staff Restroom	Manual	10/27/2025 3:45:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-043 005	Admin Building Principals Office	Manual	10/27/2025 3:39:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-044 006	Admin Building Principals Office RR	Manual	10/27/2025 3:39:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-032 015	Admin Building Staff Restroom	Manual	10/27/2025 3:44:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-037 013	Admin Building Staff Workrm Closet	Manual	10/27/2025 3:43:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-038 012	Admin Building Staff Workroom	Manual	10/27/2025 3:43:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-035 010	Admin Building Supply Storage Clst	Manual	10/27/2025 3:42:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-034 009	Admin Building Supply Storage East	Manual	10/27/2025 3:41:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-031 011	Admin Building Supply Storage RR	Manual	10/27/2025 3:41:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-036 008	Admin Building Supply Storage West	Manual	10/27/2025 3:41:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-033 014	Admin Building Telecom Room	Manual	10/27/2025 3:43:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-039 007	Admin Building VP Office	Manual	10/27/2025 3:40:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-007 027	Kindergarten Bldg Room K1	Manual	10/27/2025 4:13:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-005 028	Kindergarten Bldg Room K1	Manual	10/27/2025 4:13:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-006 030	Kindergarten Bldg Room K1 Restroom	Manual	10/27/2025 4:14:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-004 029	Kindergarten Bldg Room K1 Storage	Manual	10/27/2025 4:14:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2.301	media back hall	Manual	10/28/2025 4:15:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-377 227	Multi-Purpose Bldg Attic Media Office	Manual	10/28/2025 4:35:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-382 226	Multi-Purpose Bldg Attic Stage East	Manual	10/28/2025 4:33:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-381 225	Multi-Purpose Bldg Attic Stage West	Manual	10/28/2025 4:33:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-269 192	Multi-Purpose Bldg Custodial Storage by MP	Manual	10/27/2025 4:42:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-277 215	Multi-Purpose Bldg Front Hall	Manual	10/27/2025 4:38:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-380 229	Multi-Purpose Bldg HVAC Soffit East	Manual	10/28/2025 4:33:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-376 228	Multi-Purpose Bldg HVAC Soffit West	Manual	10/28/2025 4:33:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-279 223	Multi-Purpose Bldg Intervention Room	Manual	10/27/2025 4:28:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-278 221	Multi-Purpose Bldg Intervention Room	Manual	10/27/2025 4:29:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-306 222	Multi-Purpose Bldg Intervention Room	Manual	10/27/2025 4:29:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-284 224	Multi-Purpose Bldg Kitchen	Manual	10/28/2025 3:41:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-286 211	Multi-Purpose Bldg Kitchen	Manual	10/27/2025 4:42:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-288 213	Multi-Purpose Bldg Kitchen Restroom	Manual	10/27/2025 4:42:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-287 212	Multi-Purpose Bldg Kitchen RR Entry	Manual	10/27/2025 4:42:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-285 214	Multi-Purpose Bldg Kitchen Storage	Manual	10/27/2025 4:44:32 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-274 219	Multi-Purpose Bldg Library	Manual	10/27/2025 4:29:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-272 220	Multi-Purpose Bldg Library	Manual	10/27/2025 4:29:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-275 217	Multi-Purpose Bldg Media Office	Manual	10/27/2025 4:33:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-298 197	Multi-Purpose Bldg MP Room	Manual	10/27/2025 4:16:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-299 195	Multi-Purpose Bldg MP Room	Manual	10/27/2025 4:16:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-300 196	Multi-Purpose Bldg MP Room	Manual	10/27/2025 4:17:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-297 200	Multi-Purpose Bldg MP Room	Manual	10/27/2025 4:20:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-296 199	Multi-Purpose Bldg MP Room	Manual	10/27/2025 4:20:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-295 198	Multi-Purpose Bldg MP Room	Manual	10/27/2025 4:20:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-292 203	Multi-Purpose Bldg MP Room	Manual	10/27/2025 4:21:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-293 202	Multi-Purpose Bldg MP Room	Manual	10/27/2025 4:21:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-294 201	Multi-Purpose Bldg MP Room	Manual	10/27/2025 4:21:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-291 206	Multi-Purpose Bldg MP Room	Manual	10/27/2025 4:22:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-290 205	Multi-Purpose Bldg MP Room	Manual	10/27/2025 4:22:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-289 204	Multi-Purpose Bldg MP Room	Manual	10/27/2025 4:23:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-129 191	Multi-Purpose Bldg MP Room NE Exit	Manual	10/28/2025 4:26:37 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Manual Pull Station	2-132 190	Multi-Purpose Bldg MP Room NW Exit	Manual	10/28/2025 4:26:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-273 218	Multi-Purpose Bldg Music Office	Manual	10/27/2025 4:31:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-276 216	Multi-Purpose Bldg PE Office	Manual	10/27/2025 4:38:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-271 194	Multi-Purpose Bldg Resource Rm by MP	Manual	10/28/2025 4:15:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-270 193	Multi-Purpose Bldg Speech Rm by MP	Manual	10/28/2025 4:15:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-282 208	Multi-Purpose Bldg Stage	Manual	10/27/2025 4:24:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-281 209	Multi-Purpose Bldg Stage	Manual	10/27/2025 4:24:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-280 207	Multi-Purpose Bldg Stage	Manual	10/27/2025 4:25:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-283 210	Multi-Purpose Bldg Stage	Manual	10/27/2025 4:25:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-378 180	Portables Attic Room 20	Manual	10/28/2025 4:57:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-378 179	Portables Attic Room 20	Manual	10/28/2025 4:57:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-379 182	Portables Attic Room 21	Manual	10/28/2025 4:56:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-379 181	Portables Attic Room 21	Manual	10/28/2025 4:57:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-383 183	Portables Attic Room 22	Manual	10/28/2025 4:56:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-383 184	Portables Attic Room 22	Manual	10/28/2025 4:56:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-303 174	Portables Room 20	Manual	10/28/2025 4:25:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-302 173	Portables Room 20	Manual	10/28/2025 4:26:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-305 176	Portables Room 21	Manual	10/28/2025 4:24:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-304 175	Portables Room 21	Manual	10/28/2025 4:25:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-309 177	Portables Room 22	Manual	10/28/2025 4:21:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-308 178	Portables Room 22	Manual	10/28/2025 4:23:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-087 167	Restroom Bldg Boys Restroom	Manual	10/28/2025 3:59:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-088 166	Restroom Bldg Custodian Closet	Manual	10/28/2025 4:00:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-090 165	Restroom Bldg Girls Restroom	Manual	10/28/2025 4:00:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-089 168	Restroom Bldg Storage by Boys RR	Manual	10/28/2025 4:56:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-076 132	Rooms 11-15 Bldg Boys RR by Rm 11	Manual	10/27/2025 4:44:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-073 129	Rooms 11-15 Bldg Girls RR by Rm 11	Manual	10/27/2025 4:18:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-100 109	Rooms 11-15 Bldg Room 11	Manual	10/27/2025 4:48:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-099 112	Rooms 11-15 Bldg Room 11	Manual	10/27/2025 4:48:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-078 111	Rooms 11-15 Bldg Room 11	Manual	10/27/2025 4:48:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-077 110	Rooms 11-15 Bldg Room 11	Manual	10/27/2025 4:49:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-097 116	Rooms 11-15 Bldg Room 12	Manual	10/27/2025 4:50:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-080 115	Rooms 11-15 Bldg Room 12	Manual	10/27/2025 4:50:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-079 114	Rooms 11-15 Bldg Room 12	Manual	10/27/2025 4:51:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-098 113	Rooms 11-15 Bldg Room 12	Manual	10/28/2025 3:47:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-096 117	Rooms 11-15 Bldg Room 13	Manual	10/28/2025 3:52:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-095 120	Rooms 11-15 Bldg Room 13	Manual	10/28/2025 3:53:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-082 119	Rooms 11-15 Bldg Room 13	Manual	10/28/2025 3:54:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-081 118	Rooms 11-15 Bldg Room 13	Manual	10/28/2025 3:54:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-083 122	Rooms 11-15 Bldg Room 14	Manual	10/28/2025 4:33:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-084 123	Rooms 11-15 Bldg Room 14	Manual	10/28/2025 4:33:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-093 124	Rooms 11-15 Bldg Room 14	Manual	10/28/2025 4:33:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-094 121	Rooms 11-15 Bldg Room 14	Manual	10/28/2025 4:33:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-091 128	Rooms 11-15 Bldg Room 15	Manual	10/27/2025 4:44:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-092 125	Rooms 11-15 Bldg Room 15	Manual	10/28/2025 3:56:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-086 127	Rooms 11-15 Bldg Room 15	Manual	10/28/2025 3:56:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-085 126	Rooms 11-15 Bldg Room 15	Manual	10/28/2025 3:57:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-130 133	Rooms 11-15 Bldg Storage Behind Rm 11	Manual	10/28/2025 3:41:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-075 131	Rooms 11-15 Bldg Storage by Boys RR	Manual	10/27/2025 4:45:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-074 130	Rooms 11-15 Bldg Storage by Girls RR	Manual	10/27/2025 4:46:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-267 143	Rooms 16-19 Bldg Room 16	Manual	10/28/2025 4:12:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-266 146	Rooms 16-19 Bldg Room 16	Manual	10/28/2025 4:13:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-265 145	Rooms 16-19 Bldg Room 16	Manual	10/28/2025 4:13:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-264 144	Rooms 16-19 Bldg Room 16	Manual	10/28/2025 4:13:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-252 147	Rooms 16-19 Bldg Room 17	Manual	10/28/2025 4:10:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-253 148	Rooms 16-19 Bldg Room 17	Manual	10/28/2025 4:11:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-262 149	Rooms 16-19 Bldg Room 17	Manual	10/28/2025 4:11:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-263 150	Rooms 16-19 Bldg Room 17	Manual	10/28/2025 4:11:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-254 154	Rooms 16-19 Bldg Room 18	Manual	10/28/2025 4:09:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-261 153	Rooms 16-19 Bldg Room 18	Manual	10/28/2025 4:09:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-260 152	Rooms 16-19 Bldg Room 18	Manual	10/28/2025 4:09:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-255 151	Rooms 16-19 Bldg Room 18	Manual	10/28/2025 4:14:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-256 155	Rooms 16-19 Bldg Room 19	Manual	10/28/2025 4:01:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-257 156	Rooms 16-19 Bldg Room 19	Manual	10/28/2025 4:01:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-259 158	Rooms 16-19 Bldg Room 19	Manual	10/28/2025 4:15:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-258 157	Rooms 16-19 Bldg Room 19	Manual	10/28/2025 4:15:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-021 054	Rooms 2-5 Bldg Boys RR by Rm 5	Manual	10/27/2025 4:01:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-002 056	Rooms 2-5 Bldg Custodial Office	Manual	10/27/2025 3:37:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-003 055	Rooms 2-5 Bldg Custodial Office	Manual	10/27/2025 3:37:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-018 051	Rooms 2-5 Bldg Girls RR by Rm 5	Manual	10/27/2025 4:03:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-010 036	Rooms 2-5 Bldg Room 2	Manual	10/27/2025 4:11:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-009 035	Rooms 2-5 Bldg Room 2	Manual	10/27/2025 4:11:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-027 039	Rooms 2-5 Bldg Room 3	Manual	10/27/2025 4:08:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-026 042	Rooms 2-5 Bldg Room 3	Manual	10/27/2025 4:09:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-013 041	Rooms 2-5 Bldg Room 3	Manual	10/27/2025 4:09:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-012 040	Rooms 2-5 Bldg Room 3	Manual	10/27/2025 4:09:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-025 043	Rooms 2-5 Bldg Room 4	Manual	10/27/2025 4:06:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-024 046	Rooms 2-5 Bldg Room 4	Manual	10/27/2025 4:06:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-015 045	Rooms 2-5 Bldg Room 4	Manual	10/27/2025 4:06:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-014 044	Rooms 2-5 Bldg Room 4	Manual	10/27/2025 4:07:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-023 047	Rooms 2-5 Bldg Room 5	Manual	10/27/2025 4:04:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-022 050	Rooms 2-5 Bldg Room 5	Manual	10/27/2025 4:04:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-017 049	Rooms 2-5 Bldg Room 5	Manual	10/27/2025 4:05:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-016 048	Rooms 2-5 Bldg Room 5	Manual	10/27/2025 4:05:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-028 037	Rooms 2-5 Bldg Staff Room	Manual	10/27/2025 4:10:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-011 038	Rooms 2-5 Bldg Staff Room	Manual	10/27/2025 4:11:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-020 053	Rooms 2-5 Bldg Storage by Boys RR	Manual	10/27/2025 3:53:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-019 052	Rooms 2-5 Bldg Storage by Girls RR	Manual	10/27/2025 4:02:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-062 097	Rooms 6-10 Bldg Boys RR by Rm 10	Manual	10/27/2025 4:00:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-048 077	Rooms 6-10 Bldg Conference Rm by Rm 6	Manual	10/27/2025 3:48:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-059 094	Rooms 6-10 Bldg Girls RR by Rm 10	Manual	10/27/2025 3:58:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-064 090	Rooms 6-10 Bldg Room 10	Manual	10/27/2025 3:56:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-063 093	Rooms 6-10 Bldg Room 10	Manual	10/27/2025 3:56:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-058 092	Rooms 6-10 Bldg Room 10	Manual	10/27/2025 3:57:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-057 091	Rooms 6-10 Bldg Room 10	Manual	10/27/2025 3:57:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-046 072	Rooms 6-10 Bldg Room 6	Manual	10/27/2025 3:47:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-071 075	Rooms 6-10 Bldg Room 6	Manual	10/27/2025 3:47:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-050 074	Rooms 6-10 Bldg Room 6	Manual	10/27/2025 3:47:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-049 073	Rooms 6-10 Bldg Room 6	Manual	10/27/2025 3:48:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-047 076	Rooms 6-10 Bldg Room 6 Storage	Manual	10/27/2025 3:46:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-070 078	Rooms 6-10 Bldg Room 7	Manual	10/27/2025 3:49:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-069 081	Rooms 6-10 Bldg Room 7	Manual	10/27/2025 3:50:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-052 080	Rooms 6-10 Bldg Room 7	Manual	10/27/2025 3:50:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-051 079	Rooms 6-10 Bldg Room 7	Manual	10/27/2025 3:50:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-068 082	Rooms 6-10 Bldg Room 8	Manual	10/27/2025 3:52:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-067 085	Rooms 6-10 Bldg Room 8	Manual	10/27/2025 3:52:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-053 083	Rooms 6-10 Bldg Room 8	Manual	10/27/2025 3:53:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-054 084	Rooms 6-10 Bldg Room 8	Manual	10/27/2025 3:53:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-066 086	Rooms 6-10 Bldg Room 9	Manual	10/27/2025 3:54:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-065 089	Rooms 6-10 Bldg Room 9	Manual	10/27/2025 3:54:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-056 088	Rooms 6-10 Bldg Room 9	Manual	10/27/2025 3:55:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-055 087	Rooms 6-10 Bldg Room 9	Manual	10/27/2025 3:55:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-061 096	Rooms 6-10 Bldg Storage by Boys RR	Manual	10/27/2025 3:59:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-060 095	Rooms 6-10 Bldg Storage by Girls RR	Manual	10/27/2025 3:58:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

## Device/Equipment details

### Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Visible					
106	Rooms 6-10 Bldg Conf Rm by Rm 6				
107	Rooms 6-10 Bldg Girls RR by Rm 10				
108	Rooms 6-10 Bldg Boys RR by Rm 10				
141	Rooms 11-15 Bldg Girls RR by Rm 11				
142	Rooms 11-15 Bldg Boys RR by Rm 11				
171	Restroom Bldg Girls Restroom				
172	Restroom Bldg Boys Restroom				
241	Multi-Purpose Bldg Stage				
242	Multi-Purpose Bldg Kitchen RR Entry				
243	Multi-Purpose Bldg Kitchen Restroom				
244	Multi-Purpose Bldg Media Office				
245	Multi-Purpose Bldg Music Office				
020	Admin Building Admin Reception				
021	Admin Building Principals Office				
022	Admin Building Principals Office RR				
023	Admin Building VP Office				
024	Admin Building Supply Storage RR				
025	Admin Building Staff Restroom				
026	Admin Building O/S Staff Restroom				
033	Kindergarten Bldg Room K1 Storage				
034	Kindergarten Bldg Room K1 Restroom				
066	Rooms 2-5 Bldg Girls RR by Rm 5				
067	Rooms 2-5 Bldg Boys RR by Rm 5				
068	Rooms 2-5 Bldg Custodial Office				
105	Rooms 6-10 Bldg Room 6 Storage				
Audible					
134	Rooms 11-15 Bldg South Exterior				
135	Rooms 11-15 Bldg South Exterior				
159	Rooms 16-19 Bldg South Exterior				
160	Rooms 16-19 Bldg South Exterior				
169	Restroom Bldg East Exterior				
170	Restroom Bldg West Exterior				
185	Portables East Exterior				
186	Portables South Exterior				
230	Multi-Purpose Bldg North Exterior				
231	Multi-Purpose Bldg West Exterior				
017	Admin Building South Exterior				
031	Kindergarten Bldg West Exterior				
057	Rooms 2-5 Bldg North Exterior				
058	Rooms 2-5 Bldg East Exterior				
059	Rooms 2-5 Bldg South Exterior				
060	Rooms 2-5 Bldg South Exterior				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
098	Rooms 6-10 Bldg East Exterior				
099	Rooms 6-10 Bldg South Exterior				
Audible And Visible					
136	Rooms 11-15 Bldg Room 11				
137	Rooms 11-15 Bldg Room 12				
138	Rooms 11-15 Bldg Room 13				
139	Rooms 11-15 Bldg Room 14				
140	Rooms 11-15 Bldg Room 15				
161	Rooms 16-19 Bldg Room 16				
162	Rooms 16-19 Bldg Room 17				
163	Rooms 16-19 Bldg Room 18				
164	Rooms 16-19 Bldg Room 19				
187	Portables Room 20				
188	Portables Room 21				
189	Portables Room 22				
232	Multi-Purpose Bldg Speech Rm by MP				
233	Multi-Purpose Bldg Resource Rm by MP				
234	Multi-Purpose Bldg MP Room				
235	Multi-Purpose Bldg MP Room				
236	Multi-Purpose Bldg Stage				
237	Multi-Purpose Bldg Kitchen				
238	Multi-Purpose Bldg Kitchen				
239	Multi-Purpose Bldg Library				
240	Multi-Purpose Bldg Intervention Room				
018	Admin Building Supply Storage				
019	Admin Building Staff Workroom				
032	Kindergarten Bldg Room K1				
061	Rooms 2-5 Bldg Room 2				
062	Rooms 2-5 Bldg Staff Room				
063	Rooms 2-5 Bldg Room 3				
064	Rooms 2-5 Bldg Room 4				
065	Rooms 2-5 Bldg Room 5				
100	Rooms 6-10 Bldg Room 6				
101	Rooms 6-10 Bldg Room 7				
102	Rooms 6-10 Bldg Room 8				
103	Rooms 6-10 Bldg Room 9				
104	Rooms 6-10 Bldg Room 10				
<b>Fire Control Panel</b>					
ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
NAC Power Extender Panel					
246	Multi-Purpose Bldg Media Office - P.E. "E"				
247	Multi-Purpose Bldg Media Office - P.E. "F"				
069	Rooms 2-5 Bldg Custodial Office - P.E. "Master"				
070	Rooms 2-5 Bldg Custodial Office - P.E. "B"				
071	Rooms 2-5 Bldg Custodial Office - P.E. "C"				
Remote Annunciator					
001	Admin Building Admin Reception				
Fire Alarm Panel					

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
	Rooms 2-5 Bldg Custodial Office				
<b>Initiating Device</b>					
ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Smoke Detector - General					
2-100 109	Rooms 11-15 Bldg Room 11				
2-077 110	Rooms 11-15 Bldg Room 11				
2-078 111	Rooms 11-15 Bldg Room 11				
2-099 112	Rooms 11-15 Bldg Room 11				
2-098 113	Rooms 11-15 Bldg Room 12				
2-079 114	Rooms 11-15 Bldg Room 12				
2-080 115	Rooms 11-15 Bldg Room 12				
2-097 116	Rooms 11-15 Bldg Room 12				
2-096 117	Rooms 11-15 Bldg Room 13				
2-081 118	Rooms 11-15 Bldg Room 13				
2-082 119	Rooms 11-15 Bldg Room 13				
2-095 120	Rooms 11-15 Bldg Room 13				
2-094 121	Rooms 11-15 Bldg Room 14				
2-083 122	Rooms 11-15 Bldg Room 14				
2-084 123	Rooms 11-15 Bldg Room 14				
2-093 124	Rooms 11-15 Bldg Room 14				
2-092 125	Rooms 11-15 Bldg Room 15				
2-085 126	Rooms 11-15 Bldg Room 15				
2-086 127	Rooms 11-15 Bldg Room 15				
2-091 128	Rooms 11-15 Bldg Room 15				
2-073 129	Rooms 11-15 Bldg Girls RR by Rm 11				
2-074 130	Rooms 11-15 Bldg Storage by Girls RR				
2-075 131	Rooms 11-15 Bldg Storage by Boys RR				
2-076 132	Rooms 11-15 Bldg Boys RR by Rm 11				
2-267 143	Rooms 16-19 Bldg Room 16				
2-264 144	Rooms 16-19 Bldg Room 16				
2-265 145	Rooms 16-19 Bldg Room 16				
2-266 146	Rooms 16-19 Bldg Room 16				
2-252 147	Rooms 16-19 Bldg Room 17				
2-253 148	Rooms 16-19 Bldg Room 17				
2-262 149	Rooms 16-19 Bldg Room 17				
2-263 150	Rooms 16-19 Bldg Room 17				
2-255 151	Rooms 16-19 Bldg Room 18				
2-260 152	Rooms 16-19 Bldg Room 18				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-261 153	Rooms 16-19 Bldg Room 18				
2-254 154	Rooms 16-19 Bldg Room 18				
2-256 155	Rooms 16-19 Bldg Room 19				
2-257 156	Rooms 16-19 Bldg Room 19				
2-258 157	Rooms 16-19 Bldg Room 19				
2-259 158	Rooms 16-19 Bldg Room 19				
2-090 165	Restroom Bldg Girls Restroom				
2-088 166	Restroom Bldg Custodian Closet				
2-087 167	Restroom Bldg Boys Restroom				
2-302 173	Portables Room 20				
2-303 174	Portables Room 20				
2-304 175	Portables Room 21				
2-305 176	Portables Room 21				
2-309 177	Portables Room 22				
2-308 178	Portables Room 22				
2-269 192	Multi-Purpose Bldg Custodial Storage by MP				
2-270 193	Multi-Purpose Bldg Speech Rm by MP				
2-271 194	Multi-Purpose Bldg Resource Rm by MP				
2-299 195	Multi-Purpose Bldg MP Room				
2-300 196	Multi-Purpose Bldg MP Room				
2-298 197	Multi-Purpose Bldg MP Room				
2-295 198	Multi-Purpose Bldg MP Room				
2-296 199	Multi-Purpose Bldg MP Room				
2-297 200	Multi-Purpose Bldg MP Room				
2-294 201	Multi-Purpose Bldg MP Room				
2-293 202	Multi-Purpose Bldg MP Room				
2-292 203	Multi-Purpose Bldg MP Room				
2-289 204	Multi-Purpose Bldg MP Room				
2-290 205	Multi-Purpose Bldg MP Room				
2-291 206	Multi-Purpose Bldg MP Room				
2-280 207	Multi-Purpose Bldg Stage				
2-282 208	Multi-Purpose Bldg Stage				
2-281 209	Multi-Purpose Bldg Stage				
2-283 210	Multi-Purpose Bldg Stage				
2-286 211	Multi-Purpose Bldg Kitchen				
2-287 212	Multi-Purpose Bldg Kitchen RR Entry				
2-288 213	Multi-Purpose Bldg Kitchen Restroom				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-285 214	Multi-Purpose Bldg Kitchen Storage				
2-277 215	Multi-Purpose Bldg Front Hall				
2-276 216	Multi-Purpose Bldg PE Office				
2-275 217	Multi-Purpose Bldg Media Office				
2-273 218	Multi-Purpose Bldg Music Office				
2-274 219	Multi-Purpose Bldg Library				
2-272 220	Multi-Purpose Bldg Library				
2-278 221	Multi-Purpose Bldg Intervention Room				
2-306 222	Multi-Purpose Bldg Intervention Room				
2-279 223	Multi-Purpose Bldg Intervention Room				
2-040 003	Admin Building Admin Reception				
2-042 004	Admin Building Admin Reception				
2-043 005	Admin Building Principals Office				
2-044 006	Admin Building Principals Office RR				
2-039 007	Admin Building VP Office				
2-036 008	Admin Building Supply Storage West				
2-034 009	Admin Building Supply Storage East				
2-035 010	Admin Building Supply Storage Clst				
2-031 011	Admin Building Supply Storage RR				
2-038 012	Admin Building Staff Workroom				
2-037 013	Admin Building Staff Workrm Closet				
2-033 014	Admin Building Telecom Room				
2-032 015	Admin Building Staff Restroom				
2-030 016	Admin Building O/S Staff Restroom				
2-007 027	Kindergarten Bldg Room K1				
2-005 028	Kindergarten Bldg Room K1				
2-004 029	Kindergarten Bldg Room K1 Storage				
2-006 030	Kindergarten Bldg Room K1 Restroom				
2-009 035	Rooms 2-5 Bldg Room 2				
2-010 036	Rooms 2-5 Bldg Room 2				
2-028 037	Rooms 2-5 Bldg Staff Room				
2-011 038	Rooms 2-5 Bldg Staff Room				
2-027 039	Rooms 2-5 Bldg Room 3				
2-012 040	Rooms 2-5 Bldg Room 3				
2-013 041	Rooms 2-5 Bldg Room 3				
2-026 042	Rooms 2-5 Bldg Room 3				
2-025 043	Rooms 2-5 Bldg Room 4				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-014 044	Rooms 2-5 Bldg Room 4				
2-015 045	Rooms 2-5 Bldg Room 4				
2-024 046	Rooms 2-5 Bldg Room 4				
2-023 047	Rooms 2-5 Bldg Room 5				
2-016 048	Rooms 2-5 Bldg Room 5				
2-017 049	Rooms 2-5 Bldg Room 5				
2-022 050	Rooms 2-5 Bldg Room 5				
2-018 051	Rooms 2-5 Bldg Girls RR by Rm 5				
2-019 052	Rooms 2-5 Bldg Storage by Girls RR				
2-020 053	Rooms 2-5 Bldg Storage by Boys RR				
2-021 054	Rooms 2-5 Bldg Boys RR by Rm 5				
2-003 055	Rooms 2-5 Bldg Custodial Office				
2-002 056	Rooms 2-5 Bldg Custodial Office				
2-046 072	Rooms 6-10 Bldg Room 6				
2-049 073	Rooms 6-10 Bldg Room 6				
2-050 074	Rooms 6-10 Bldg Room 6				
2-071 075	Rooms 6-10 Bldg Room 6				
2-047 076	Rooms 6-10 Bldg Room 6 Storage				
2-048 077	Rooms 6-10 Bldg Conference Rm by Rm 6				
2-070 078	Rooms 6-10 Bldg Room 7				
2-051 079	Rooms 6-10 Bldg Room 7				
2-052 080	Rooms 6-10 Bldg Room 7				
2-069 081	Rooms 6-10 Bldg Room 7				
2-068 082	Rooms 6-10 Bldg Room 8				
2-053 083	Rooms 6-10 Bldg Room 8				
2-054 084	Rooms 6-10 Bldg Room 8				
2-067 085	Rooms 6-10 Bldg Room 8				
2-066 086	Rooms 6-10 Bldg Room 9				
2-055 087	Rooms 6-10 Bldg Room 9				
2-056 088	Rooms 6-10 Bldg Room 9				
2-065 089	Rooms 6-10 Bldg Room 9				
2-064 090	Rooms 6-10 Bldg Room 10				
2-057 091	Rooms 6-10 Bldg Room 10				
2-058 092	Rooms 6-10 Bldg Room 10				
2-063 093	Rooms 6-10 Bldg Room 10				
2-059 094	Rooms 6-10 Bldg Girls RR by Rm 10				
2-060 095	Rooms 6-10 Bldg Storage by Girls RR				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-061 096	Rooms 6-10 Bldg Storage by Boys RR				
2-062 097	Rooms 6-10 Bldg Boys RR by Rm 10				
2.301	media back hall				
Heat Detector - Restorable Spot					
2-130 133	Rooms 11-15 Bldg Storage Behind Rm 11				
2-089 168	Restroom Bldg Storage by Boys RR				
2-378 179	Portables Attic Room 20				
2-378 180	Portables Attic Room 20				
2-379 181	Portables Attic Room 21				
2-379 182	Portables Attic Room 21				
2-383 183	Portables Attic Room 22				
2-383 184	Portables Attic Room 22				
2-284 224	Multi-Purpose Bldg Kitchen				
2-381 225	Multi-Purpose Bldg Attic Stage West				
2-382 226	Multi-Purpose Bldg Attic Stage East				
2-377 227	Multi-Purpose Bldg Attic Media Office				
Manual Pull Station					
2-132 190	Multi-Purpose Bldg MP Room NW Exit				
2-129 191	Multi-Purpose Bldg MP Room NE Exit				
2-131 002	Admin Building Admin Reception				
Smoke Detector - Duct					
2-376 228	Multi-Purpose Bldg HVAC Soffit West				
2-380 229	Multi-Purpose Bldg HVAC Soffit East				