

# Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

MIRA LOMA HIGH

4000 EDISON AVE  
SACRAMENTO, California  
United States

This site has been inspected and tested in compliance with applicable standards.

Completed

Wednesday, November 19, 2025

Test Session:03 Nov 2025 14:32 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD  
5320 HEMLOCK ST  
SACRAMENTO, California  
United States

TESTED BY

Riley Goyet  
Western States Fire Protection-  
Sacramento  
188 Cirby Way  
Roseville, CA 95678  
United States



# Inspection Summary

## Building Information

PROPERTY	MIRA LOMA HIGH	CONTACT
ADDRESS	4000 EDISON AVE	PHONE
CITY/STATE	SACRAMENTO, California	MOBILE
COUNTRY	United States	EMAIL

## Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us


## Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Alarm Notification Appliance	178	178(100%)	178(100%)	0(0%)
Ventilation and Cooking Equipment	5	0(0%)	0(0%)	0(0%)
Fire Control Panel	15	15(100%)	15(100%)	0(0%)
Initiating Device	679	674(99%)	674(99%)	0(0%)

## Certification

The equipment specified here in was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Wednesday, November 19, 2025

ACCEPTED BY      11/19/2025  
  
Building Representative

  
TESTED BY      11/19/2025  
Riley Goyet  
Technician

# System Details

## Control Units

ADDRESS/ SCAN ADDRESS	DESCRIPTION	Building A Data Rm by Library
MANUFACTURER	S/W VERSION	
MODEL	LAST UPDATE	
SERIAL NUMBER	S/W LOCATION	
INSTALL DATE		

# Testing Details

## Alarm Notification Appliance

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	236	Building A 1st Floor Hallway	Manual	11/4/2025 3:20:11 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	237	Building A 1st Floor Hallway	Manual	11/4/2025 3:20:14 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	238	Building A 1st Floor Hallway	Manual	11/4/2025 3:20:16 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	239	Building A 1st Floor Hallway	Manual	11/4/2025 3:20:17 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	240	Building A 1st Floor Hallway	Manual	11/4/2025 3:20:20 PM
		Visual inspection	Passed (Manual)	
Visible	274	Building A 1st Floor Hallway	Manual	11/4/2025 3:23:40 PM
		Visual inspection	Passed (Manual)	
Audible	234	Building A 1st Flr O/S Boys RR	Manual	11/4/2025 3:20:12 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	256	Building A 2nd Floor Hallway	Manual	11/4/2025 3:20:41 PM
		Visual inspection	Passed (Manual)	
Visible	283	Building A 2nd Floor Hallway	Manual	11/4/2025 3:23:54 PM
		Visual inspection	Passed (Manual)	
Visible	284	Building A 2nd Floor Hallway	Manual	11/4/2025 3:23:56 PM
		Visual inspection	Passed (Manual)	
Audible	235	Building A 2nd Flr O/S Boys RR	Manual	11/4/2025 3:20:13 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	242	Building A Admin Hallway	Manual	11/4/2025 3:20:22 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	253	Building A Confernce Rm A116	Manual	11/4/2025 3:20:37 PM
		Visual inspection	Passed (Manual)	
Visible	282	Building A Copier Room A126A	Manual	11/4/2025 3:23:52 PM
		Visual inspection	Passed (Manual)	
Visible	279	Building A Coun Office RR	Manual	11/4/2025 3:23:48 PM
		Visual inspection	Passed (Manual)	
Audible And Visible	254	Building A Counsel Recep A120	Manual	11/4/2025 3:20:39 PM
		Visual inspection	Passed (Manual)	
Visible	276	Building A Exterior Boy RR A103	Manual	11/4/2025 3:23:44 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	277	Building A Girls RR by Rm A111	Manual	11/4/2025 3:23:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	252	Building A Libr REF Rm A114A	Manual	11/4/2025 3:20:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	251	Building A Library A114	Manual	11/4/2025 3:20:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	278	Building A Library A114	Manual	11/4/2025 3:23:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	241	Building A Reception Area A101	Manual	11/4/2025 3:20:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	243	Building A Room A104	Manual	11/4/2025 3:20:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	244	Building A Room A105	Manual	11/4/2025 3:20:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	245	Building A Room A106	Manual	11/4/2025 3:20:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	246	Building A Room A107	Manual	11/4/2025 3:20:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	247	Building A Room A108	Manual	11/4/2025 3:20:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	248	Building A Room A109	Manual	11/4/2025 3:20:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	249	Building A Room A110	Manual	11/4/2025 3:20:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	250	Building A Room A111	Manual	11/4/2025 3:20:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	257	Building A Room A201	Manual	11/4/2025 3:20:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	258	Building A Room A202	Manual	11/4/2025 3:20:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	259	Building A Room A204	Manual	11/4/2025 3:20:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	260	Building A Room A205	Manual	11/4/2025 3:20:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	261	Building A Room A206	Manual	11/4/2025 3:20:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	262	Building A Room A207	Manual	11/4/2025 3:20:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	263	Building A Room A208	Manual	11/4/2025 3:20:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	264	Building A Room A209	Manual	11/4/2025 3:20:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	265	Building A Room A210	Manual	11/4/2025 3:20:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	285	Building A Room A211 Girls RR	Manual	11/4/2025 3:23:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	266	Building A Room A212	Manual	11/4/2025 3:20:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	267	Building A Room A213	Manual	11/4/2025 3:20:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	268	Building A Room A214	Manual	11/4/2025 3:21:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	269	Building A Room A215	Manual	11/4/2025 3:21:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	270	Building A Room A216	Manual	11/4/2025 3:21:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	271	Building A Room A217	Manual	11/4/2025 3:21:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	272	Building A Room A218	Manual	11/4/2025 3:21:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	273	Building A Room A219	Manual	11/4/2025 3:21:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	286	Building A Room A220 Boys RR	Manual	11/4/2025 3:23:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	233	Building A South Exterior	Manual	11/4/2025 3:20:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	287	Building A South Exterior	Manual	11/4/2025 3:21:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	280	Building A Staff Mens RR A122	Manual	11/4/2025 3:23:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	255	Building A Staff Room A126	Manual	11/4/2025 3:20:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	281	Building A Staff Wom RR A123	Manual	11/4/2025 3:23:51 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	275	Building A VP Recept A101K	Manual	11/4/2025 3:23:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	359	Building B Boys Restroom B11	Manual	11/4/2025 3:24:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	360	Building B Girls Restroom B13	Manual	11/4/2025 3:24:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	348	Building B Northwest Exterior	Manual	11/4/2025 3:21:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	349	Building B Room B1	Manual	11/4/2025 3:21:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	358	Building B Room B10	Manual	11/4/2025 3:21:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	350	Building B Room B2	Manual	11/4/2025 3:21:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	351	Building B Room B3	Manual	11/4/2025 3:21:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	352	Building B Room B4	Manual	11/4/2025 3:21:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	353	Building B Room B5	Manual	11/4/2025 3:21:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	354	Building B Room B6	Manual	11/4/2025 3:21:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	355	Building B Room B7	Manual	11/4/2025 3:21:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	356	Building B Room B8	Manual	11/4/2025 3:21:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	357	Building B Room B9	Manual	11/4/2025 3:21:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	410	Building C North Exterior	Manual	11/4/2025 3:21:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	412	Building C Room C1	Manual	11/4/2025 3:21:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	413	Building C Room C3	Manual	11/4/2025 3:21:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	414	Building C Room C4	Manual	11/4/2025 3:21:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	415	Building C Room C5	Manual	11/4/2025 3:21:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	416	Building C Room C6	Manual	11/4/2025 3:21:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	417	Building C Room C7	Manual	11/4/2025 3:21:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	418	Building C Room C8	Manual	11/4/2025 3:21:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	411	Building C South Exterior	Manual	11/4/2025 3:21:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	419	Building C Study Room C1B	Manual	11/4/2025 3:24:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	484	Building D Boys Restroom D9	Manual	11/4/2025 3:24:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	485	Building D Girls Restroom D11	Manual	11/4/2025 3:24:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	473	Building D North Exterior	Manual	11/4/2025 3:21:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	476	Building D Room D1	Manual	11/4/2025 3:21:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	477	Building D Room D2	Manual	11/4/2025 3:21:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	478	Building D Room D3	Manual	11/4/2025 3:21:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	479	Building D Room D4	Manual	11/4/2025 3:21:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	480	Building D Room D5	Manual	11/4/2025 3:21:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	481	Building D Room D6	Manual	11/4/2025 3:21:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	482	Building D Room D7	Manual	11/4/2025 3:21:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	483	Building D Room D8	Manual	11/4/2025 3:21:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	474	Building D South Exterior	Manual	11/4/2025 3:21:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	475	Building D West Exterior	Manual	11/4/2025 3:21:44 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	585	Building E Ceramics Room E8	Manual	11/4/2025 3:22:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	595	Building E Ceramics Room E8	Manual	11/4/2025 3:24:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	593	Building E Lecture Room E2C	Manual	11/4/2025 3:24:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	577	Building E North Exterior	Manual	11/4/2025 3:21:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	578	Building E North Exterior	Manual	11/4/2025 3:21:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	587	Building E Office Room E12	Manual	11/4/2025 3:22:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	588	Building E Office Room E13	Manual	11/4/2025 3:22:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	592	Building E Office Room E2B	Manual	11/4/2025 3:24:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	589	Building E Room E14	Manual	11/4/2025 3:22:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	590	Building E Room E15	Manual	11/4/2025 3:22:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	591	Building E Room E16	Manual	11/4/2025 3:22:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	580	Building E Room E3	Manual	11/4/2025 3:22:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	581	Building E Room E4	Manual	11/4/2025 3:22:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	582	Building E Room E5	Manual	11/4/2025 3:22:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	594	Building E Room E5	Manual	11/4/2025 3:24:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	586	Building E Room E9	Manual	11/4/2025 3:22:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	579	Building E Waiting Area Rm E2	Manual	11/4/2025 3:22:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	583	Building E Wood Shop Rm E7	Manual	11/4/2025 3:22:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	584	Building E Wood Shop Rm E7	Manual	11/4/2025 3:22:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	596	Building E Work Room E15A	Manual	11/4/2025 3:24:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	725	Building F Boys Restroom F7C	Manual	11/4/2025 3:24:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	706	Building F Cafeteria Room F7	Manual	11/4/2025 3:23:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	707	Building F Cafeteria Room F7	Manual	11/4/2025 3:23:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	723	Building F Cafeteria Room F7	Manual	11/4/2025 3:24:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	724	Building F Cafeteria Room F7	Manual	11/4/2025 3:24:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	714	Building F Computer Room F2B	Manual	11/4/2025 3:24:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	719	Building F East Entrance F2G	Manual	11/4/2025 3:24:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	728	Building F Girls Restroom F7E	Manual	11/4/2025 3:24:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	731	Building F Hall by Room F13B	Manual	11/4/2025 3:24:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	732	Building F Hall by Room F13B	Manual	11/4/2025 3:24:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	708	Building F Hall Room F7D	Manual	11/4/2025 3:23:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	710	Building F Hall South Entr F9	Manual	11/4/2025 3:23:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	711	Building F Kitchen Room F13	Manual	11/4/2025 3:23:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	702	Building F Main Entrance F2	Manual	11/4/2025 3:22:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	733	Building F Northeast Exterior	Manual	11/4/2025 3:23:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	718	Building F Practice Room 1 F2F	Manual	11/4/2025 3:24:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	717	Building F Practice Room 2 F2E	Manual	11/4/2025 3:24:23 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	716	Building F Practice Room 3 F2D	Manual	11/4/2025 3:24:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	715	Building F Practice Room 4 F2C	Manual	11/4/2025 3:24:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	703	Building F Room F2	Manual	11/4/2025 3:22:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	713	Building F Room F2	Manual	11/4/2025 3:24:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	704	Building F Room F3	Manual	11/4/2025 3:22:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	720	Building F Room F3	Manual	11/4/2025 3:24:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	705	Building F Room F5	Manual	11/4/2025 3:22:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	722	Building F Room F5	Manual	11/4/2025 3:24:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	709	Building F Room F8	Manual	11/4/2025 3:23:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	727	Building F Snack Bar Rm F7D2	Manual	11/4/2025 3:24:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	701	Building F South Exterior	Manual	11/4/2025 3:22:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	712	Building F Staff Mens RR F1	Manual	11/4/2025 3:24:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	726	Building F Staff Restroom F7D1	Manual	11/4/2025 3:24:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	729	Building F Staff Restroom F9A	Manual	11/4/2025 3:24:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	730	Building F Staff Restroom F9B	Manual	11/4/2025 3:24:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	721	Building F Staff Womens RR F4	Manual	11/4/2025 3:24:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	832	Building G Big Gym	Manual	11/4/2025 3:23:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	833	Building G Big Gym	Manual	11/4/2025 3:23:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible	842	Building G Big Gym	Manual	11/4/2025 3:24:49 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Visible	843	Building G Big Gym	Manual	11/4/2025 3:24:51 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Visible	844	Building G Big Gym	Manual	11/4/2025 3:24:53 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Visible	845	Building G Big Gym	Manual	11/4/2025 3:24:56 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Visible	846	Building G Big Gym	Manual	11/4/2025 3:24:58 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Visible	847	Building G Big Gym	Manual	11/4/2025 3:24:59 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	837	Building G Boys Dress Rm G3J	Manual	11/4/2025 3:23:33 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Visible	850	Building G Boys Lock Entry G3	Manual	11/4/2025 3:25:03 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	836	Building G Boys Locker Rm G3	Manual	11/4/2025 3:23:31 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Visible	851	Building G Boys Locker Rm G3	Manual	11/4/2025 3:25:05 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Visible	852	Building G Boys Locker Rm G3	Manual	11/4/2025 3:25:06 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Visible	853	Building G Boys Locker Rm G3	Manual	11/4/2025 3:25:07 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Visible	857	Building G Boys Locker RR G3K	Manual	11/4/2025 3:25:13 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	840	Building G Dance Room G7	Manual	11/4/2025 3:23:37 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible	829	Building G East Exterior	Manual	11/4/2025 3:23:20 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible	830	Building G East Exterior	Manual	11/4/2025 3:23:21 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	839	Building G Girls Lock RR G6	Manual	11/4/2025 3:23:36 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Audible And Visible	838	Building G Girls Locker Rm G6	Manual	11/4/2025 3:23:34 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Visible	858	Building G Girls Locker Rm G6	Manual	11/4/2025 3:25:15 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	828	Building G North Exterior	Manual	11/4/2025 3:23:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	855	Building G Office Room G3G	Manual	11/4/2025 3:25:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	859	Building G Office Room G6C	Manual	11/4/2025 3:25:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	834	Building G Small Gym	Manual	11/4/2025 3:23:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	835	Building G Small Gym	Manual	11/4/2025 3:23:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	848	Building G Small Gym	Manual	11/4/2025 3:25:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	849	Building G Small Gym	Manual	11/4/2025 3:25:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	854	Building G Staff Restroom G3A	Manual	11/4/2025 3:25:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	856	Building G Staff Restroom G3G1	Manual	11/4/2025 3:25:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	860	Building G Staff Restroom G6D1	Manual	11/4/2025 3:25:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	841	Building G Weight Room	Manual	11/4/2025 3:23:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	861	Building G Weight Room	Manual	11/4/2025 3:25:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible	831	Building G West Exterior	Manual	11/4/2025 3:23:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

**Fire Control Panel**

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Fire Alarm Panel		Building A Data Rm by Library	Manual	11/19/2025 10:44:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	288	Building A Data Rm by Library	Manual	11/19/2025 10:44:21 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	289	Building A Data Rm by Library - P.E. A	Manual	11/19/2025 10:44:19 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Remote Annunciator	001	Building A Reception Area A101	Manual	11/5/2025 5:10:40 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
NAC Power Extender Panel	291	Building A Storage A222	Manual	11/19/2025 10:44:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	292	Building A Storage A222	Manual	11/19/2025 10:44:26 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	290	Building A Telco Room A118	Manual	11/19/2025 10:44:16 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	361	Building B Custodial Office B12	Manual	11/19/2025 10:44:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	362	Building B Custodial Office B12	Manual	11/19/2025 10:44:07 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	486	Building D Custodial Office D10	Manual	11/19/2025 10:43:58 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	487	Building D Custodial Office D10 - P.E. H	Manual	11/19/2025 10:44:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	735	Building F Data Room F7A	Manual	11/19/2025 10:44:04 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	734	Building F Equip Room F3B - P.E. J	Manual	11/19/2025 10:44:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	863	Building G Data Room G4	Manual	11/19/2025 10:44:03 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel	862	Building G Data Room G4	Manual	11/19/2025 10:44:09 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

**Initiating Device**

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2.061	Bldg G Corr H113.2 East	Manual	11/5/2025 4:42:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-055	Bldg H Corr H113.2 West	Manual	11/4/2025 5:31:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-059	Bldg H Cust H112	Manual	11/5/2025 4:42:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-028	Bldg H Rm 102 West	Manual	11/4/2025 5:23:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-048	Bldg H Rm H101 East	Manual	11/5/2025 4:42:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-046	Bldg H Rm H101 West	Manual	11/4/2025 5:15:11 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	2-039	Bldg H Rm H101.1 East	Manual	11/4/2025 5:12:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-037	Bldg H Rm H101.1 West	Manual	11/5/2025 4:42:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-030	Bldg H Rm H102 East	Manual	11/4/2025 5:22:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-139 205	Building A Attic Library Rm A114	Manual	11/5/2025 5:10:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-139 208	Building A Attic Library Rm A114	Manual	11/5/2025 5:10:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-139 207	Building A Attic Library Rm A114	Manual	11/5/2025 5:10:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-139 209	Building A Attic Library Rm A114	Manual	11/5/2025 5:10:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-139 206	Building A Attic Library Rm A114	Manual	11/5/2025 5:10:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-139 204	Building A Attic Library Rm A114	Manual	11/5/2025 5:10:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-021 078	Building A Confernce Rm A116	Manual	11/4/2025 5:02:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-057 110	Building A Copier Room A126A	Manual	11/4/2025 5:29:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-017 087	Building A Coun Office 1 A120D	Manual	11/4/2025 5:06:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-018 086	Building A Coun Office 2 A120C	Manual	11/4/2025 5:05:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-019 085	Building A Coun Office 3 A120B	Manual	11/4/2025 5:05:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-020 084	Building A Coun Office 4 A120A	Manual	11/4/2025 5:04:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-037 097	Building A Coun Office A121A	Manual	11/4/2025 5:19:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-033 098	Building A Coun Office A121B	Manual	11/4/2025 5:21:12 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-038 099	Building A Coun Office RR	Manual	11/4/2025 5:19:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-016 082	Building A Counsel Recep A120	Manual	11/4/2025 5:04:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-015 083	Building A Counsel Recep A120	Manual	11/4/2025 5:04:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-092 022	Building A Custodial Closet A103	Manual	11/5/2025 4:42:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-031 081	Building A Custodial Closet A119	Manual	11/4/2025 5:22:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-285 195	Building A Custodial Closet A221	Manual	11/4/2025 3:59:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-003 197	Building A Data Rm by Library	Manual	11/5/2025 5:10:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-002 088	Building A Data Rm by Library	Manual	11/4/2025 5:36:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-091 020	Building A Electrical Rm A102	Manual	11/4/2025 5:35:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-090 021	Building A Electrical Rm A103	Manual	11/4/2025 5:35:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-119 089	Building A Elevator Room A113	Manual	11/4/2025 5:36:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-093 023	Building A Exterior Boy RR A103	Manual	11/4/2025 5:35:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-045 106	Building A Finance Room A124	Manual	11/4/2025 5:35:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-117 062	Building A Girls RR by Rm A111	Manual	11/5/2025 4:42:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-024 090	Building A Hall by Conf Rm A113	Manual	11/4/2025 4:59:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-044 107	Building A Hall by Finance A124	Manual	11/4/2025 5:13:18 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	2-022 065	Building A Hall by Library A114	Manual	11/4/2025 4:59:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-023 066	Building A Hall by Library A114	Manual	11/4/2025 5:48:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-063 016	Building A Hall by Principal A101i	Manual	11/5/2025 4:42:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-047 009	Building A Hall by Reg Off A101A	Manual	11/4/2025 5:13:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-094 028	Building A Hall by Room A105	Manual	11/4/2025 4:59:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-100 038	Building A Hall by Room A107	Manual	11/4/2025 4:59:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-105 047	Building A Hall by Room A109	Manual	11/4/2025 5:00:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-110 052	Building A Hall by Room A110	Manual	11/4/2025 5:00:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-116 061	Building A Hall by Room A111	Manual	11/4/2025 5:00:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-029 093	Building A Hall by Room A117	Manual	11/4/2025 5:11:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-032 094	Building A Hall by Room A119	Manual	11/4/2025 5:11:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-036 100	Building A Hall by Room A121	Manual	11/4/2025 5:12:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-039 101	Building A Hall by Room A121A	Manual	11/4/2025 5:45:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-034 095	Building A Hall by Room A121B	Manual	11/4/2025 5:12:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-041 103	Building A Hall by Room A122	Manual	11/4/2025 5:12:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-043 104	Building A Hall by Room A123	Manual	11/4/2025 5:13:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-328 112	Building A Hall by Room A201	Manual	11/4/2025 4:29:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-328 118	Building A Hall by Room A202	Manual	11/4/2025 4:29:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-323 129	Building A Hall by Room A204	Manual	11/4/2025 4:30:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-317 134	Building A Hall by Room A205	Manual	11/4/2025 4:30:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-312 139	Building A Hall by Room A206	Manual	11/4/2025 4:31:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-252 146	Building A Hall by Room A208	Manual	11/4/2025 4:31:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-262 155	Building A Hall by Room A210	Manual	11/4/2025 4:31:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-264 162	Building A Hall by Room A213	Manual	11/4/2025 4:32:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-269 171	Building A Hall by Room A215	Manual	11/4/2025 4:32:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-274 180	Building A Hall by Room A217	Manual	11/4/2025 4:33:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-289 189	Building A Hall by Room A218	Manual	11/4/2025 4:33:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-056 109	Building A Hall by Staff Rm A126	Manual	11/4/2025 5:31:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-025 092	Building A Hall Entry Conf A113	Manual	11/4/2025 5:10:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-026 091	Building A Hall Stair by A113	Manual	11/4/2025 5:10:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-054 200	Building A HVAC OS Staff A126	Manual	11/19/2025 10:44:22 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-068 019	Building A HVAC Room A101L	Manual	11/4/2025 5:27:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Mechanical, Electrosonic, or Pressure Waterflow Device	2-137 230	Building A HVAC Room A113A	Manual	11/19/2025 10:44:23 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	2-137 231	Building A HVAC Room A113A	Manual	11/19/2025 10:44:25 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-118 063	Building A HVAC Room A113A	Manual	11/4/2025 5:08:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Valve Tamper Switch	2-138 232	Building A HVAC Room A113A	Manual	11/19/2025 10:44:11 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-013 075	Building A Libr REF Rm A114A	Manual	11/4/2025 5:03:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-014 076	Building A Libr REF Rm A114A	Manual	11/4/2025 5:03:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-004 067	Building A Library A114	Manual	11/4/2025 5:00:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-006 068	Building A Library A114	Manual	11/4/2025 5:00:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-008 069	Building A Library A114	Manual	11/4/2025 5:00:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-009 070	Building A Library A114	Manual	11/4/2025 5:00:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-007 071	Building A Library A114	Manual	11/4/2025 5:00:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-005 072	Building A Library A114	Manual	11/4/2025 5:00:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-011 073	Building A Library A114	Manual	11/4/2025 5:01:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-010 074	Building A Library A114	Manual	11/4/2025 5:02:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-027 064	Building A Library Supply A113B	Manual	11/4/2025 5:00:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-072 004	Building A Main Entrance A101	Manual	11/4/2025 5:14:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-071 003	Building A Main Entrance A101	Manual	11/4/2025 5:14:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-050 011	Building A Off by Recept A101B	Manual	11/4/2025 5:26:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-333 123	Building A Office Room A202A	Manual	11/4/2025 4:24:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-259 154	Building A Office Room A210A	Manual	11/4/2025 5:35:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-064 017	Building A Principal Office A101i	Manual	11/4/2025 5:28:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-065 012	Building A Recept Office A101E	Manual	11/4/2025 5:28:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-130 002	Building A Reception Area A101	Manual	11/5/2025 4:43:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-048 007	Building A Reception Area A101	Manual	11/4/2025 5:24:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-049 008	Building A Reception Area A101	Manual	11/4/2025 5:25:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-069 006	Building A Reception Area A101	Manual	11/4/2025 5:25:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-070 005	Building A Reception Area A101	Manual	11/4/2025 5:25:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-046 010	Building A Registry Office A101A	Manual	11/4/2025 5:15:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-088 024	Building A Room A104	Manual	11/4/2025 4:35:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-089 027	Building A Room A104	Manual	11/4/2025 4:36:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-086 026	Building A Room A104	Manual	11/4/2025 4:36:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-087 025	Building A Room A104	Manual	11/4/2025 4:36:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-098 029	Building A Room A105	Manual	11/4/2025 4:37:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-099 030	Building A Room A105	Manual	11/4/2025 4:37:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-096 032	Building A Room A105	Manual	11/4/2025 4:37:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-097 031	Building A Room A105	Manual	11/4/2025 4:38:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-084 034	Building A Room A106	Manual	11/4/2025 4:39:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-085 035	Building A Room A106	Manual	11/4/2025 4:39:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-082 036	Building A Room A106	Manual	11/4/2025 4:39:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-083 037	Building A Room A106	Manual	11/4/2025 4:39:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-103 039	Building A Room A107	Manual	11/4/2025 4:40:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-104 040	Building A Room A107	Manual	11/4/2025 4:40:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-101 041	Building A Room A107	Manual	11/4/2025 4:41:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-102 042	Building A Room A107	Manual	11/4/2025 4:41:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-080 043	Building A Room A108	Manual	11/4/2025 4:42:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-079 046	Building A Room A108	Manual	11/4/2025 4:42:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-078 045	Building A Room A108	Manual	11/4/2025 4:42:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-081 044	Building A Room A108	Manual	11/4/2025 4:43:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-108 048	Building A Room A109	Manual	11/4/2025 4:43:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-107 051	Building A Room A109	Manual	11/4/2025 4:43:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-106 050	Building A Room A109	Manual	11/4/2025 4:44:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-109 049	Building A Room A109	Manual	11/4/2025 4:44:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-077 054	Building A Room A110	Manual	11/4/2025 4:45:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-074 055	Building A Room A110	Manual	11/4/2025 4:45:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-075 056	Building A Room A110	Manual	11/4/2025 4:45:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-076 053	Building A Room A110	Manual	11/4/2025 4:46:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-113 057	Building A Room A111	Manual	11/4/2025 4:47:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-114 058	Building A Room A111	Manual	11/4/2025 4:47:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-111 059	Building A Room A111	Manual	11/4/2025 4:48:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-112 060	Building A Room A111	Manual	11/4/2025 4:48:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-058 199	Building A Room A113D	Manual	11/19/2025 10:44:13 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-028 079	Building A Room A117	Manual	11/4/2025 4:42:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-035 096	Building A Room A121	Manual	11/4/2025 5:18:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-384 210	Building A Room A201	Manual	11/5/2025 4:38:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - Duct	2-384 211	Building A Room A201	Manual	11/5/2025 4:38:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-339 113	Building A Room A201	Manual	11/4/2025 4:26:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-338 114	Building A Room A201	Manual	11/4/2025 4:26:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-341 115	Building A Room A201	Manual	11/4/2025 4:26:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-340 116	Building A Room A201	Manual	11/4/2025 4:27:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-383 212	Building A Room A202	Manual	11/5/2025 4:38:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-383 213	Building A Room A202	Manual	11/5/2025 4:38:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-331 119	Building A Room A202	Manual	11/4/2025 4:23:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-335 120	Building A Room A202	Manual	11/4/2025 4:24:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-334 121	Building A Room A202	Manual	11/4/2025 4:24:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-332 122	Building A Room A202	Manual	11/4/2025 5:35:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-325 125	Building A Room A204	Manual	11/4/2025 4:21:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-324 126	Building A Room A204	Manual	11/4/2025 4:22:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-327 127	Building A Room A204	Manual	11/4/2025 4:22:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-326 128	Building A Room A204	Manual	11/4/2025 4:22:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-382 215	Building A Room A205	Manual	11/5/2025 4:38:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - Duct	2-382 214	Building A Room A205	Manual	11/5/2025 4:38:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-319 130	Building A Room A205	Manual	11/4/2025 4:19:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-318 131	Building A Room A205	Manual	11/4/2025 4:19:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-321 132	Building A Room A205	Manual	11/4/2025 4:20:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-320 133	Building A Room A205	Manual	11/4/2025 4:20:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-381 217	Building A Room A206	Manual	11/5/2025 4:38:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-381 216	Building A Room A206	Manual	11/5/2025 4:38:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-314 135	Building A Room A206	Manual	11/4/2025 4:17:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-313 136	Building A Room A206	Manual	11/4/2025 4:18:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-316 137	Building A Room A206	Manual	11/4/2025 4:18:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-315 138	Building A Room A206	Manual	11/4/2025 4:18:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-376 219	Building A Room A207	Manual	11/5/2025 4:38:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-376 218	Building A Room A207	Manual	11/5/2025 4:39:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-254 140	Building A Room A207	Manual	11/4/2025 4:16:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-253 141	Building A Room A207	Manual	11/4/2025 4:16:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-256 142	Building A Room A207	Manual	11/4/2025 4:16:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-255 143	Building A Room A207	Manual	11/4/2025 4:16:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-311 145	Building A Room A208	Manual	11/4/2025 4:14:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-310 144	Building A Room A208	Manual	11/4/2025 4:15:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-385 221	Building A Room A209	Manual	11/5/2025 4:38:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-385 220	Building A Room A209	Manual	11/5/2025 4:38:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-308 148	Building A Room A209	Manual	11/4/2025 4:12:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-307 147	Building A Room A209	Manual	11/4/2025 4:13:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-309 149	Building A Room A209 Closet	Manual	11/4/2025 4:14:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-257 150	Building A Room A210	Manual	11/4/2025 4:11:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-258 153	Building A Room A210	Manual	11/4/2025 4:11:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-261 152	Building A Room A210	Manual	11/4/2025 4:12:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-260 151	Building A Room A210	Manual	11/4/2025 4:12:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-263 157	Building A Room A211 Girls RR	Manual	11/4/2025 5:35:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-303 158	Building A Room A212	Manual	11/4/2025 4:09:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-304 159	Building A Room A212	Manual	11/4/2025 4:09:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-305 160	Building A Room A212	Manual	11/4/2025 4:09:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-302 161	Building A Room A212	Manual	11/4/2025 4:10:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-377 222	Building A Room A213	Manual	11/5/2025 4:39:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-377 223	Building A Room A213	Manual	11/5/2025 4:39:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-266 163	Building A Room A213	Manual	11/4/2025 4:07:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-267 164	Building A Room A213	Manual	11/4/2025 4:07:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-268 165	Building A Room A213	Manual	11/4/2025 4:08:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-265 166	Building A Room A213	Manual	11/4/2025 4:08:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-380 224	Building A Room A214	Manual	11/5/2025 4:38:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-380 225	Building A Room A214	Manual	11/5/2025 4:38:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-299 167	Building A Room A214	Manual	11/4/2025 4:05:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-300 170	Building A Room A214	Manual	11/4/2025 4:06:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-301 169	Building A Room A214	Manual	11/4/2025 4:06:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-298 168	Building A Room A214	Manual	11/4/2025 4:07:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-271 172	Building A Room A215	Manual	11/4/2025 4:04:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-272 175	Building A Room A215	Manual	11/4/2025 4:04:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-273 174	Building A Room A215	Manual	11/4/2025 4:04:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-270 173	Building A Room A215	Manual	11/4/2025 4:05:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-296 179	Building A Room A216	Manual	11/4/2025 4:01:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-294 177	Building A Room A216	Manual	11/4/2025 4:01:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-295 178	Building A Room A216	Manual	11/4/2025 4:02:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-297 176	Building A Room A216	Manual	11/4/2025 5:35:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-378 226	Building A Room A217	Manual	11/5/2025 4:39:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-378 227	Building A Room A217	Manual	11/5/2025 4:39:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-277 182	Building A Room A217	Manual	11/4/2025 4:02:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-278 183	Building A Room A217	Manual	11/4/2025 4:03:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-275 184	Building A Room A217	Manual	11/4/2025 4:03:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-276 181	Building A Room A217	Manual	11/4/2025 4:03:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-379 228	Building A Room A218	Manual	11/5/2025 4:38:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	2-379 229	Building A Room A218	Manual	11/5/2025 4:38:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-290 186	Building A Room A218	Manual	11/4/2025 3:55:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-293 187	Building A Room A218	Manual	11/4/2025 3:59:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-291 185	Building A Room A218	Manual	11/4/2025 3:59:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-292 188	Building A Room A218	Manual	11/4/2025 5:35:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-281 190	Building A Room A219	Manual	11/4/2025 3:59:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-280 191	Building A Room A219	Manual	11/4/2025 3:59:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-279 193	Building A Room A219	Manual	11/4/2025 3:59:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-282 192	Building A Room A219	Manual	11/4/2025 4:00:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-284 194	Building A Room A220 Boys RR	Manual	11/4/2025 5:36:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-040 102	Building A Staff Mens RR A122	Manual	11/4/2025 5:18:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-055 108	Building A Staff Room A126	Manual	11/5/2025 4:42:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-042 105	Building A Staff Wom RR A123	Manual	11/4/2025 5:17:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-337 111	Building A Stairwell by Rm A201	Manual	11/4/2025 4:28:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-306 156	Building A Stairwell by Rm A212	Manual	11/4/2025 4:32:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-286 196	Building A Storage A222	Manual	11/4/2025 5:35:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-095 033	Building A Supply Room A105A	Manual	11/4/2025 4:38:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-012 077	Building A Supply Room A114B	Manual	11/4/2025 5:01:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-330 117	Building A Supply Room A201A	Manual	11/4/2025 4:27:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-329 124	Building A Supply Room A203	Manual	11/4/2025 4:29:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-030 080	Building A Telco Room A118	Manual	11/4/2025 5:36:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-062 015	Building A VP Office 1 A101H	Manual	11/4/2025 5:30:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-051 013	Building A VP Office 2 A101F	Manual	11/4/2025 5:32:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-053 014	Building A VP Office 3 A101G	Manual	11/4/2025 5:33:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-052 018	Building A VP Recept A101K	Manual	11/4/2025 5:32:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-024 333	Building B Boys Restroom B11	Manual	11/4/2025 4:59:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-002 334	Building B Custodial Office B12	Manual	11/4/2025 5:57:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-003 335	Building B Girls Restroom B13	Manual	11/5/2025 4:42:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-007 293	Building B Room B1	Manual	11/4/2025 5:55:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-004 296	Building B Room B1	Manual	11/4/2025 5:55:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-005 295	Building B Room B1	Manual	11/4/2025 5:56:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-006 294	Building B Room B1	Manual	11/4/2025 5:56:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-129 346	Building B Room B10	Manual	11/5/2025 4:38:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-129 347	Building B Room B10	Manual	11/5/2025 4:38:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-025 330	Building B Room B10	Manual	11/4/2025 5:38:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-026 331	Building B Room B10	Manual	11/4/2025 5:38:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-027 329	Building B Room B10	Manual	11/4/2025 5:38:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-028 332	Building B Room B10	Manual	11/4/2025 5:39:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-126 337	Building B Room B2	Manual	11/5/2025 4:38:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-126 336	Building B Room B2	Manual	11/5/2025 4:38:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-011 297	Building B Room B2	Manual	11/4/2025 5:53:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-008 300	Building B Room B2	Manual	11/4/2025 5:53:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-009 299	Building B Room B2	Manual	11/4/2025 5:53:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-010 298	Building B Room B2	Manual	11/4/2025 5:54:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-015 301	Building B Room B3	Manual	11/4/2025 5:51:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-012 304	Building B Room B3	Manual	11/4/2025 5:51:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-013 303	Building B Room B3	Manual	11/4/2025 5:52:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-014 302	Building B Room B3	Manual	11/4/2025 5:52:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-127 338	Building B Room B4	Manual	11/5/2025 4:38:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-127 339	Building B Room B4	Manual	11/5/2025 4:38:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-019 305	Building B Room B4	Manual	11/4/2025 5:50:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-016 308	Building B Room B4	Manual	11/4/2025 5:50:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-017 307	Building B Room B4	Manual	11/4/2025 5:50:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-018 306	Building B Room B4	Manual	11/4/2025 5:50:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-128 340	Building B Room B5	Manual	11/5/2025 4:38:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-128 341	Building B Room B5	Manual	11/5/2025 4:38:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-023 309	Building B Room B5	Manual	11/4/2025 5:00:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-022 310	Building B Room B5	Manual	11/4/2025 5:48:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-020 312	Building B Room B5	Manual	11/4/2025 5:48:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-021 311	Building B Room B5	Manual	11/4/2025 5:49:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-130 342	Building B Room B6	Manual	11/5/2025 4:39:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-130 343	Building B Room B6	Manual	11/5/2025 4:39:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-043 313	Building B Room B6	Manual	11/4/2025 5:46:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-042 316	Building B Room B6	Manual	11/4/2025 5:46:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-041 315	Building B Room B6	Manual	11/4/2025 5:46:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-044 314	Building B Room B6	Manual	11/4/2025 5:47:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-040 317	Building B Room B7	Manual	11/4/2025 5:44:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-037 318	Building B Room B7	Manual	11/4/2025 5:44:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-038 320	Building B Room B7	Manual	11/4/2025 5:45:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-039 319	Building B Room B7	Manual	11/4/2025 5:45:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-136 344	Building B Room B8	Manual	11/5/2025 4:39:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-136 345	Building B Room B8	Manual	11/5/2025 4:39:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-036 321	Building B Room B8	Manual	11/4/2025 5:43:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-035 322	Building B Room B8	Manual	11/4/2025 5:43:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-034 324	Building B Room B8	Manual	11/4/2025 5:43:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-033 323	Building B Room B8	Manual	11/4/2025 5:43:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-032 325	Building B Room B9	Manual	11/4/2025 5:39:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-029 328	Building B Room B9	Manual	11/4/2025 5:40:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-030 327	Building B Room B9	Manual	11/4/2025 5:41:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-031 326	Building B Room B9	Manual	11/4/2025 5:41:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-073 386	Building C Book Room C6A	Manual	11/4/2025 9:24:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-075 398	Building C Book Room C8B	Manual	11/4/2025 8:36:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-131 401	Building C Room C1	Manual	11/5/2025 4:38:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-131 400	Building C Room C1	Manual	11/5/2025 4:38:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-049 365	Building C Room C1	Manual	11/4/2025 9:32:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-051 364	Building C Room C1	Manual	11/4/2025 9:32:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-052 363	Building C Room C1	Manual	11/4/2025 9:32:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-050 366	Building C Room C1	Manual	11/4/2025 9:33:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-132 402	Building C Room C3	Manual	11/5/2025 4:38:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-132 403	Building C Room C3	Manual	11/5/2025 4:38:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-055 373	Building C Room C3	Manual	11/4/2025 9:29:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-054 371	Building C Room C3	Manual	11/4/2025 9:29:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-053 370	Building C Room C3	Manual	11/4/2025 9:29:48 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-056 372	Building C Room C3	Manual	11/4/2025 9:30:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-133 405	Building C Room C4	Manual	11/5/2025 4:38:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-133 404	Building C Room C4	Manual	11/5/2025 4:38:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-060 374	Building C Room C4	Manual	11/4/2025 8:06:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-057 376	Building C Room C4	Manual	11/4/2025 9:27:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-058 377	Building C Room C4	Manual	11/4/2025 9:28:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-059 375	Building C Room C4	Manual	11/4/2025 9:28:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-064 378	Building C Room C5	Manual	11/4/2025 9:25:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-061 381	Building C Room C5	Manual	11/4/2025 9:25:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-062 380	Building C Room C5	Manual	11/4/2025 9:25:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-063 379	Building C Room C5	Manual	11/4/2025 9:26:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-068 382	Building C Room C6	Manual	11/4/2025 9:22:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-066 384	Building C Room C6	Manual	11/4/2025 9:23:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-065 385	Building C Room C6	Manual	11/4/2025 9:23:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-067 383	Building C Room C6	Manual	11/4/2025 9:24:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-134 407	Building C Room C7	Manual	11/5/2025 4:39:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-134 406	Building C Room C7	Manual	11/5/2025 4:39:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-071 388	Building C Room C7	Manual	11/4/2025 9:20:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-070 389	Building C Room C7	Manual	11/4/2025 9:20:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-069 390	Building C Room C7	Manual	11/4/2025 9:20:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-072 387	Building C Room C7	Manual	11/4/2025 9:21:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-135 408	Building C Room C8	Manual	11/5/2025 4:39:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-135 409	Building C Room C8	Manual	11/5/2025 4:39:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-077 396	Building C Room C8	Manual	11/4/2025 8:33:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-082 392	Building C Room C8	Manual	11/4/2025 8:33:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-081 393	Building C Room C8	Manual	11/4/2025 8:34:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-079 394	Building C Room C8	Manual	11/4/2025 8:34:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-080 395	Building C Room C8	Manual	11/4/2025 9:19:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-078 399	Building C Room C8C	Manual	11/4/2025 8:35:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-048 368	Building C Study Room C1B	Manual	11/4/2025 9:30:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-047 367	Building C Supply Room C1A	Manual	11/4/2025 9:31:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-076 391	Building C Supply Room C7A	Manual	11/4/2025 9:21:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-074 397	Building C Supply Room C8A	Manual	11/4/2025 9:19:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-376 462	Building D Attic Supply Rm D1A	Manual	11/19/2025 10:43:50 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-274 459	Building D Boys Restroom D9	Manual	11/4/2025 9:09:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-252 460	Building D Custodial Office D10	Manual	11/4/2025 9:09:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-379 471	Building D Equip Room D7A	Manual	11/5/2025 4:39:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-379 472	Building D Equip Room D7A	Manual	11/5/2025 4:39:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-279 454	Building D Equip Room D7A	Manual	11/4/2025 6:59:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-253 461	Building D Girls Restroom D11	Manual	11/4/2025 9:09:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-269 434	Building D Office Room D3A	Manual	11/4/2025 7:06:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-257 421	Building D Room D1	Manual	11/4/2025 6:55:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-256 420	Building D Room D1	Manual	11/4/2025 6:55:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-255 423	Building D Room D1	Manual	11/4/2025 6:55:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-254 422	Building D Room D1	Manual	11/4/2025 6:55:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-262 428	Building D Room D2	Manual	11/4/2025 6:56:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-261 427	Building D Room D2	Manual	11/4/2025 6:57:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-260 426	Building D Room D2	Manual	11/4/2025 6:57:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-263 425	Building D Room D2	Manual	11/4/2025 6:57:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-266 431	Building D Room D3	Manual	11/4/2025 7:04:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-265 432	Building D Room D3	Manual	11/4/2025 7:04:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-264 433	Building D Room D3	Manual	11/4/2025 7:04:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-267 430	Building D Room D3	Manual	11/4/2025 7:04:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-272 436	Building D Room D4	Manual	11/4/2025 7:06:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-271 437	Building D Room D4	Manual	11/4/2025 7:07:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-270 438	Building D Room D4	Manual	11/4/2025 7:07:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-273 439	Building D Room D4	Manual	11/4/2025 7:07:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-293 440	Building D Room D5	Manual	11/4/2025 7:08:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-291 443	Building D Room D5	Manual	11/4/2025 7:09:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-290 442	Building D Room D5	Manual	11/4/2025 7:09:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-292 441	Building D Room D5	Manual	11/4/2025 7:10:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-287 445	Building D Room D6	Manual	11/4/2025 7:10:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-285 446	Building D Room D6	Manual	11/4/2025 7:11:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-284 447	Building D Room D6	Manual	11/4/2025 7:12:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-286 448	Building D Room D6	Manual	11/4/2025 7:13:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-283 450	Building D Room D7	Manual	11/4/2025 7:01:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-281 453	Building D Room D7	Manual	11/4/2025 7:01:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-280 452	Building D Room D7	Manual	11/4/2025 7:01:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-282 451	Building D Room D7	Manual	11/4/2025 7:02:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-276 458	Building D Room D8	Manual	11/4/2025 6:59:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-275 457	Building D Room D8	Manual	11/4/2025 7:00:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-277 456	Building D Room D8	Manual	11/4/2025 7:00:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-278 455	Building D Room D8	Manual	11/4/2025 7:00:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-258 424	Building D Supply Room D1A	Manual	11/5/2025 4:42:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-377 464	Building D Supply Room D2A	Manual	11/5/2025 4:39:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-377 463	Building D Supply Room D2A	Manual	11/5/2025 4:39:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-259 429	Building D Supply Room D2A	Manual	11/4/2025 6:58:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-378 466	Building D Supply Room D3B	Manual	11/5/2025 4:39:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-378 468	Building D Supply Room D3B	Manual	11/5/2025 4:39:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-378 465	Building D Supply Room D3B	Manual	11/5/2025 4:39:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-378 467	Building D Supply Room D3B	Manual	11/5/2025 4:39:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-268 435	Building D Supply Room D3B	Manual	11/4/2025 7:05:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-289 444	Building D Supply Room D5A	Manual	11/5/2025 4:42:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-380 469	Building D Supply Room D6A	Manual	11/5/2025 4:39:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	3-380 470	Building D Supply Room D6A	Manual	11/5/2025 4:39:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-288 449	Building D Supply Room D6A	Manual	11/5/2025 4:42:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	3-381 567	Building E Attic Office Rm E9C	Manual	11/19/2025 10:43:49 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	3-382 568	Building E Attic Room E16	Manual	11/19/2025 10:43:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-129 566	Building E Attic Supply Rm E2A	Manual	11/19/2025 10:43:47 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-025 488	Building E Boiler Room E1	Manual	11/4/2025 9:09:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-023 491	Building E Boiler Room E1	Manual	11/4/2025 9:09:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-024 490	Building E Boiler Room E1	Manual	11/4/2025 9:09:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-026 489	Building E Boiler Room E1	Manual	11/4/2025 9:09:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-333 524	Building E Ceramics Room E8	Manual	11/4/2025 7:33:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-332 525	Building E Ceramics Room E8	Manual	11/4/2025 7:34:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-331 526	Building E Ceramics Room E8	Manual	11/4/2025 7:34:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-330 527	Building E Ceramics Room E8	Manual	11/4/2025 7:34:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-329 528	Building E Ceramics Room E8	Manual	11/4/2025 7:35:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-328 529	Building E Ceramics Room E8	Manual	11/4/2025 7:35:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-335 523	Building E Ceramics Room E8	Manual	11/4/2025 7:36:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-334 530	Building E Ceramics Room E8	Manual	11/4/2025 9:09:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-336 564	Building E Electrical Room E18	Manual	11/5/2025 4:42:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	4-130 572	Building E Lecture Room E2C	Manual	11/5/2025 4:39:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - Duct	4-130 571	Building E Lecture Room E2C	Manual	11/5/2025 4:39:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-022 498	Building E Lecture Room E2C	Manual	11/4/2025 8:04:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-021 499	Building E Lecture Room E2C	Manual	11/4/2025 8:04:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-300 544	Building E Office Room E10	Manual	11/4/2025 7:26:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-297 545	Building E Office Room E11	Manual	11/4/2025 7:26:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-296 546	Building E Office Room E12	Manual	11/4/2025 7:25:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-298 549	Building E Office Room E13	Manual	11/4/2025 7:22:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-299 548	Building E Office Room E13	Manual	11/4/2025 7:23:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-312 563	Building E Office Room E16B	Manual	11/4/2025 9:09:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-019 496	Building E Office Room E2B	Manual	11/4/2025 7:58:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-018 495	Building E Office Room E2B	Manual	11/4/2025 7:59:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-339 519	Building E Office Room E7A	Manual	11/4/2025 7:40:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-322 542	Building E Office Room E9C	Manual	11/4/2025 7:31:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-347 522	Building E Project Strg Rm E7D	Manual	11/4/2025 7:45:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-304 550	Building E Room E14	Manual	11/4/2025 7:16:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-303 551	Building E Room E14	Manual	11/4/2025 7:16:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-307 552	Building E Room E15	Manual	11/4/2025 7:14:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-305 553	Building E Room E15	Manual	11/4/2025 7:14:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-306 555	Building E Room E15	Manual	11/4/2025 7:15:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-308 554	Building E Room E15	Manual	11/4/2025 7:15:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-310 561	Building E Room E16	Manual	11/4/2025 9:09:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-311 560	Building E Room E16	Manual	11/4/2025 9:09:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-314 559	Building E Room E16	Manual	11/4/2025 9:09:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-313 558	Building E Room E16	Manual	11/4/2025 9:09:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-014 500	Building E Room E3	Manual	11/4/2025 7:53:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-011 502	Building E Room E3	Manual	11/4/2025 7:54:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-013 501	Building E Room E3	Manual	11/4/2025 7:54:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-012 503	Building E Room E3	Manual	11/4/2025 7:54:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	4-127 573	Building E Room E4	Manual	11/5/2025 4:39:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	4-127 574	Building E Room E4	Manual	11/5/2025 4:39:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-007 507	Building E Room E4	Manual	11/4/2025 7:52:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-008 506	Building E Room E4	Manual	11/4/2025 7:52:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	4-009 504	Building E Room E4	Manual	11/4/2025 7:52:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-010 505	Building E Room E4	Manual	11/4/2025 7:52:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	4-126 575	Building E Room E5	Manual	11/5/2025 4:39:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	4-126 576	Building E Room E5	Manual	11/5/2025 4:39:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-004 510	Building E Room E5	Manual	11/4/2025 7:50:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-005 512	Building E Room E5	Manual	11/4/2025 7:52:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-006 511	Building E Room E5	Manual	11/4/2025 7:52:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-003 509	Building E Room E5	Manual	11/4/2025 9:09:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-324 534	Building E Room E9	Manual	11/4/2025 7:28:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-323 535	Building E Room E9	Manual	11/4/2025 7:28:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-316 536	Building E Room E9	Manual	11/4/2025 7:28:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-315 537	Building E Room E9	Manual	11/4/2025 7:29:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-317 538	Building E Room E9	Manual	11/4/2025 7:29:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-318 539	Building E Room E9	Manual	11/4/2025 7:29:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-295 547	Building E Storage Room E12A	Manual	11/4/2025 7:22:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-309 562	Building E Storage Room E16A	Manual	11/4/2025 9:09:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-327 532	Building E Storage Room E8A	Manual	11/4/2025 7:36:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-325 531	Building E Storage Room E8A	Manual	11/4/2025 7:38:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-326 533	Building E Storage Room E8B	Manual	11/4/2025 7:37:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-319 540	Building E Storage Room E9A	Manual	11/4/2025 7:32:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-320 541	Building E Storage Room E9B	Manual	11/4/2025 9:09:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-321 543	Building E Storage Room E9D	Manual	11/4/2025 7:31:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-016 494	Building E Supply Room E2A	Manual	11/4/2025 7:55:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	4-128 570	Building E Supply Room E2B1	Manual	11/5/2025 4:39:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	4-128 569	Building E Supply Room E2B1	Manual	11/5/2025 4:39:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-015 497	Building E Supply Room E2B1	Manual	11/4/2025 7:58:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-002 508	Building E Supply Room E4A	Manual	11/4/2025 7:49:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-338 520	Building E Tool Storage Rm E7B	Manual	11/4/2025 7:43:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-017 492	Building E Waiting Area Rm E2	Manual	11/4/2025 8:00:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-020 493	Building E Waiting Area Rm E2	Manual	11/4/2025 8:00:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-344 513	Building E Wood Shop Rm E7	Manual	11/4/2025 7:41:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-343 518	Building E Wood Shop Rm E7	Manual	11/4/2025 7:41:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	3-345 514	Building E Wood Shop Rm E7	Manual	11/4/2025 7:46:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-346 515	Building E Wood Shop Rm E7	Manual	11/4/2025 7:47:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-341 516	Building E Wood Shop Rm E7	Manual	11/4/2025 7:47:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-342 517	Building E Wood Shop Rm E7	Manual	11/4/2025 7:47:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-340 565	Building E Wood Strg Rm E19	Manual	11/4/2025 7:44:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-301 556	Building E Work Room E15A	Manual	11/4/2025 7:17:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	3-302 557	Building E Work Room E15A	Manual	11/4/2025 7:18:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-131 691	Building F Attic Entry F3	Manual	11/19/2025 10:43:43 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-180 693	Building F Attic Kitchen F13	Manual	11/19/2025 10:42:57 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-134 692	Building F Attic Room F5A	Manual	11/19/2025 10:42:59 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	4-179 694	Building F Between Rms F2/F3	Manual	11/5/2025 4:39:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-105 677	Building F Boiler Room F10	Manual	11/4/2025 9:15:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-109 663	Building F Boys Restroom F7C	Manual	11/4/2025 9:15:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	4-185 598	Building F Cafeteria NE Exit	Manual	11/5/2025 4:43:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	4-182 696	Building F Cafeteria Northeast	Manual	11/5/2025 4:38:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	4-184 698	Building F Cafeteria Northwest	Manual	11/5/2025 4:38:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Manual Pull Station	4-187 597	Building F Cafeteria NW Exit	Manual	11/5/2025 4:43:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-077 657	Building F Cafeteria Room F7	Manual	11/4/2025 8:33:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-081 645	Building F Cafeteria Room F7	Manual	11/4/2025 9:08:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-080 646	Building F Cafeteria Room F7	Manual	11/4/2025 9:08:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-078 652	Building F Cafeteria Room F7	Manual	11/4/2025 9:08:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-085 653	Building F Cafeteria Room F7	Manual	11/4/2025 9:08:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-084 650	Building F Cafeteria Room F7	Manual	11/4/2025 9:08:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-083 647	Building F Cafeteria Room F7	Manual	11/4/2025 9:08:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-082 644	Building F Cafeteria Room F7	Manual	11/4/2025 9:08:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-087 643	Building F Cafeteria Room F7	Manual	11/4/2025 9:08:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-088 648	Building F Cafeteria Room F7	Manual	11/4/2025 9:08:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-089 649	Building F Cafeteria Room F7	Manual	11/4/2025 9:08:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-090 654	Building F Cafeteria Room F7	Manual	11/4/2025 9:08:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-079 651	Building F Cafeteria Room F7	Manual	11/4/2025 9:08:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-091 655	Building F Cafeteria Room F7	Manual	11/4/2025 9:08:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-086 656	Building F Cafeteria Room F7	Manual	11/4/2025 9:08:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Manual Pull Station	4-186 599	Building F Cafeteria SE Exit	Manual	11/5/2025 4:43:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	4-181 695	Building F Cafeteria Southeast	Manual	11/5/2025 4:38:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Duct	4-183 697	Building F Cafeteria Southwest	Manual	11/5/2025 4:38:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-037 608	Building F Center Room F2	Manual	11/4/2025 8:24:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-052 621	Building F Center Room F3	Manual	11/4/2025 8:12:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-072 662	Building F Closet Room F7B1	Manual	11/4/2025 9:14:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-093 668	Building F Closet Room F7D3	Manual	11/4/2025 9:15:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-039 610	Building F Computer Room F2B	Manual	11/4/2025 8:19:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-101 680	Building F Custodial Room F13A	Manual	11/4/2025 9:15:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-029 616	Building F Data Room F2G1	Manual	11/4/2025 8:25:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-062 660	Building F Data Room F7A	Manual	11/4/2025 9:14:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-030 615	Building F East Entrance F2G	Manual	11/4/2025 9:14:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-032 607	Building F East Side Room F2	Manual	11/4/2025 8:22:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-035 606	Building F East Side Room F2	Manual	11/4/2025 8:22:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-103 683	Building F Electrical Room F14	Manual	11/4/2025 9:14:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-059 626	Building F Electrical Room F3C1	Manual	11/4/2025 8:07:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	4-073 642	Building F Electrical Room F6	Manual	11/4/2025 9:14:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-041 609	Building F Equip Room F2A	Manual	11/4/2025 8:19:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-028 624	Building F Equip Room F3B	Manual	11/4/2025 8:14:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-074 661	Building F Equip Room F7B	Manual	11/4/2025 8:38:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-092 669	Building F Girls Restroom F7E	Manual	11/4/2025 9:15:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-102 681	Building F Hall by Room F13B	Manual	11/4/2025 9:14:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-094 664	Building F Hall Room F7D	Manual	11/4/2025 9:13:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-112 674	Building F Hall South Entr F9	Manual	11/4/2025 9:14:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-099 686	Building F Kitchen Room F13	Manual	11/19/2025 10:42:54 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-098 685	Building F Kitchen Room F13	Manual	11/19/2025 10:42:56 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-045 601	Building F Main Entrance F2	Manual	11/4/2025 8:11:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-046 617	Building F Main Entrance F3	Manual	11/4/2025 9:14:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-038 605	Building F NE Side Room F2	Manual	11/4/2025 8:22:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-040 604	Building F North Side Room F2	Manual	11/4/2025 8:23:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-076 658	Building F North Stair Room F7	Manual	11/4/2025 8:27:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-042 602	Building F NW Side Room F2	Manual	11/4/2025 8:23:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	4-043 603	Building F NW Side Room F2	Manual	11/4/2025 8:23:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-047 623	Building F Office 1 Room F3A	Manual	11/4/2025 8:15:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-050 631	Building F Office 2 Room F3H	Manual	11/4/2025 8:10:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-053 630	Building F Office 3 Room F3G	Manual	11/4/2025 8:09:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-054 629	Building F Office 4 Room F3F	Manual	11/4/2025 8:08:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-056 628	Building F Office 5 Room F3E	Manual	11/4/2025 8:08:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-057 627	Building F Office 6 Room F3D	Manual	11/4/2025 8:07:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-100 687	Building F OS Freezer Rm F13D	Manual	11/19/2025 10:42:52 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-031 614	Building F Practice Room 1 F2F	Manual	11/4/2025 8:21:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-033 613	Building F Practice Room 2 F2E	Manual	11/4/2025 8:21:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-034 612	Building F Practice Room 3 F2D	Manual	11/4/2025 8:21:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-036 611	Building F Practice Room 4 F2C	Manual	11/4/2025 8:20:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-064 636	Building F Room F5	Manual	11/4/2025 8:27:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-069 639	Building F Room F5	Manual	11/4/2025 8:28:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-066 637	Building F Room F5	Manual	11/4/2025 8:28:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-067 638	Building F Room F5	Manual	11/4/2025 8:29:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	4-068 640	Building F Room F5	Manual	11/4/2025 8:29:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-065 635	Building F Room F5	Manual	11/4/2025 8:30:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-070 633	Building F Room F5	Manual	11/4/2025 8:30:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-071 634	Building F Room F5	Manual	11/4/2025 9:14:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-113 673	Building F Room F8	Manual	11/4/2025 9:14:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-114 672	Building F Room F8	Manual	11/4/2025 9:14:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-115 671	Building F Room F8	Manual	11/4/2025 9:14:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-116 670	Building F Room F8	Manual	11/4/2025 9:14:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-060 625	Building F SE Entrance F3C	Manual	11/4/2025 8:07:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-058 622	Building F SE Side Room F3	Manual	11/4/2025 8:13:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-095 666	Building F Snack Bar Rm F7D2	Manual	11/4/2025 9:14:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-051 619	Building F South Side Room F3	Manual	11/4/2025 8:12:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-055 620	Building F South Side Room F3	Manual	11/4/2025 8:13:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-075 659	Building F South Stair Room F7	Manual	11/4/2025 8:28:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-044 600	Building F Staff Mens RR F1	Manual	11/4/2025 8:18:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-096 665	Building F Staff Restroom F7D1	Manual	11/4/2025 9:15:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	4-110 675	Building F Staff Restroom F9A	Manual	11/4/2025 9:14:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-111 676	Building F Staff Restroom F9B	Manual	11/4/2025 9:14:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-048 632	Building F Staff Womens RR F4	Manual	11/4/2025 8:16:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-097 667	Building F Supply Rm F7D2A	Manual	11/4/2025 9:13:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-108 678	Building F Supply Room F12	Manual	11/4/2025 9:14:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-107 679	Building F Supply Room F12A	Manual	11/4/2025 9:14:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-104 682	Building F Supply Room F13B	Manual	11/4/2025 9:14:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Mechanical, Electrosonic, or Pressure Waterflow Device	4-132 699	Building F Supply Room F5A	Manual	11/19/2025 10:42:51 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-063 641	Building F Supply Room F5A	Manual	11/4/2025 9:14:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Valve Tamper Switch	4-133 700	Building F Supply Room F5A	Manual	11/19/2025 10:43:05 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-049 618	Building F SW Side Rm F3	Manual	11/4/2025 8:12:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-136 690	Building F Under Stage Rm F5	Manual	11/19/2025 10:44:28 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-136 688	Building F Under Stage Rm F5	Manual	11/19/2025 10:44:29 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-136 689	Building F Under Stage Rm F5	Manual	11/19/2025 10:44:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-106 684	Building F Wash Room F11	Manual	11/19/2025 10:43:46 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-376 813	Building G Attic by Cust Rm G3C	Manual	11/19/2025 10:43:45 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	4-377 812	Building G Attic by Equip Rm G3B	Manual	11/19/2025 10:43:10 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	4-379 815	Building G Attic Data Room G4	Manual	11/19/2025 10:43:11 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	4-380 816	Building G Attic Equip Rm G5A	Manual	11/19/2025 10:43:08 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	4-461 820	Building G Attic Girl Coach G6C	Manual	11/19/2025 10:43:55 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	4-463 821	Building G Attic Girl Lkr Cust G6G	Manual	11/19/2025 10:43:57 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	4-464 819	Building G Attic Girls Lkr G6B	Manual	11/19/2025 10:43:29 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	4-465 817	Building G Attic Girls Lkr N Exit	Manual	11/19/2025 10:43:26 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	4-462 818	Building G Attic Girls Lkr Pool Ent	Manual	11/19/2025 10:43:28 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	4-378 814	Building G Attic Office G3G	Manual	11/19/2025 10:43:54 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - Projected Beam	4-473 822	Building G Big Gym East	Manual	11/5/2025 4:39:52 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - Projected Beam	4-475 823	Building G Big Gym Middle	Manual	11/5/2025 4:39:58 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Manual Pull Station	4-485 736	Building G Big Gym NE Exit	Manual	11/5/2025 4:43:30 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Manual Pull Station	4-486 738	Building G Big Gym SE Exit	Manual	11/5/2025 4:43:31 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Manual Pull Station	4-484 737	Building G Big Gym SW Exit	Manual	11/5/2025 4:43:29 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - Projected Beam	4-477 824	Building G Big Gym West	Manual	11/5/2025 4:39:54 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-276 784	Building G Boiler Room G8	Manual	11/5/2025 4:41:50 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	4-285 785	Building G Boiler Room G8	Manual	11/5/2025 4:41:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-275 786	Building G Boiler Room G8	Manual	11/5/2025 4:42:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-324 756	Building G Boys Dress Rm G3J	Manual	11/4/2025 7:28:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-323 755	Building G Boys Dress Rm G3J	Manual	11/4/2025 9:09:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-325 757	Building G Boys Dress Rm G3J	Manual	11/5/2025 4:40:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-320 758	Building G Boys Dress Rm G3J	Manual	11/5/2025 4:40:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-322 760	Building G Boys Dress Rm G3J	Manual	11/5/2025 4:40:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-321 759	Building G Boys Dress Rm G3J	Manual	11/5/2025 4:41:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-296 740	Building G Boys Lock Entry G3	Manual	11/5/2025 4:40:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-319 743	Building G Boys Lock S Entry G3	Manual	11/5/2025 4:41:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-313 744	Building G Boys Lock S Entry G3	Manual	11/5/2025 4:41:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-309 796	Building G Boys Locker Rm G3	Manual	11/19/2025 10:43:12 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-304 794	Building G Boys Locker Rm G3	Manual	11/19/2025 10:43:14 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-310 797	Building G Boys Locker Rm G3	Manual	11/19/2025 10:43:15 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-311 798	Building G Boys Locker Rm G3	Manual	11/19/2025 10:43:17 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-305 795	Building G Boys Locker Rm G3	Manual	11/19/2025 10:43:18 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	4-300 792	Building G Boys Locker Rm G3	Manual	11/19/2025 10:43:19 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	4-301 793	Building G Boys Locker Rm G3	Manual	11/19/2025 10:43:21 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	4-299 791	Building G Boys Locker Rm G3	Manual	11/19/2025 10:43:23 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-291 741	Building G Boys Locker Rm G3	Manual	11/5/2025 4:40:25 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-293 742	Building G Boys Locker Rm G3	Manual	11/5/2025 4:40:30 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-314 761	Building G Boys Locker RR G3K	Manual	11/5/2025 4:40:52 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-315 762	Building G Boys Locker RR G3K	Manual	11/5/2025 4:41:46 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-292 747	Building G Custodial Rm G3C	Manual	11/5/2025 4:40:28 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-283 787	Building G Custodial Room G10	Manual	11/5/2025 4:42:16 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	4-290 810	Building G Custodial Room G14	Manual	11/19/2025 10:43:03 AM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-252 775	Building G Custodial Room G6G	Manual	11/5/2025 4:41:11 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-274 783	Building G Dance Room G7	Manual	11/4/2025 9:09:43 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-282 780	Building G Dance Room G7	Manual	11/5/2025 4:40:02 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-273 782	Building G Dance Room G7	Manual	11/5/2025 4:40:03 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-279 777	Building G Dance Room G7	Manual	11/5/2025 4:40:12 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	4-278 778	Building G Dance Room G7	Manual	11/5/2025 4:41:54 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	4-277 781	Building G Dance Room G7	Manual	11/5/2025 4:41:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-280 776	Building G Dance Room G7	Manual	11/5/2025 4:41:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-281 779	Building G Dance Room G7	Manual	11/5/2025 4:41:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-316 763	Building G Data Room G4	Manual	11/5/2025 4:40:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-318 739	Building G Electrical Room G2	Manual	11/5/2025 4:41:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-297 748	Building G Equip Room 2 G3D	Manual	11/5/2025 4:40:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-298 749	Building G Equip Room 3 G3E	Manual	11/5/2025 4:42:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-264 770	Building G Equip Room 3 G6B	Manual	11/5/2025 4:41:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-308 752	Building G Equip Room 4 G3H	Manual	11/5/2025 4:40:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-307 751	Building G Equip Room 4 G3H	Manual	11/5/2025 4:40:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-312 754	Building G Equip Room 5 G3i	Manual	11/5/2025 4:40:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-317 753	Building G Equip Room 5 G3i	Manual	11/5/2025 4:41:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-333 764	Building G Equip Room G5A	Manual	11/5/2025 4:40:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-255 773	Building G Equip Room G6E	Manual	11/5/2025 4:41:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-254 774	Building G Equip Room G6F	Manual	11/4/2025 6:58:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-294 746	Building G EquipRoom G3B	Manual	11/5/2025 4:40:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	4-271 769	Building G Girls Lock RR G6	Manual	11/5/2025 4:41:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-253 766	Building G Girls Locker Entry G6	Manual	11/5/2025 4:41:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-269 807	Building G Girls Locker Rm G6	Manual	11/5/2025 4:40:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-257 801	Building G Girls Locker Rm G6	Manual	11/19/2025 10:43:00 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-260 809	Building G Girls Locker Rm G6	Manual	11/19/2025 10:43:31 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-270 808	Building G Girls Locker Rm G6	Manual	11/19/2025 10:43:32 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-261 804	Building G Girls Locker Rm G6	Manual	11/19/2025 10:43:34 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-267 806	Building G Girls Locker Rm G6	Manual	11/19/2025 10:43:36 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-262 802	Building G Girls Locker Rm G6	Manual	11/19/2025 10:43:37 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-259 805	Building G Girls Locker Rm G6	Manual	11/19/2025 10:43:39 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-258 803	Building G Girls Locker Rm G6	Manual	11/19/2025 10:43:41 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-272 767	Building G Girls Locker Rm G6	Manual	11/5/2025 4:40:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-268 768	Building G Girls Locker Rm G6	Manual	11/5/2025 4:40:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-302 799	Building G Kitchenette Rm G3F	Manual	11/19/2025 10:43:02 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-289 789	Building G Mens RR G13	Manual	11/5/2025 4:42:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-303 750	Building G Office Room G3G	Manual	11/5/2025 4:40:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	4-332 765	Building G Office Room G5B	Manual	11/5/2025 4:40:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-263 771	Building G Office Room G6C	Manual	11/5/2025 4:41:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Projected Beam	4-471 825	Building G Small Gym North	Manual	11/5/2025 4:39:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Projected Beam	4-469 826	Building G Small Gym South	Manual	11/5/2025 4:39:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-288 811	Building G Snack Bar Rm G15	Manual	11/19/2025 10:43:24 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-295 745	Building G Staff Restroom G3A	Manual	11/5/2025 4:42:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	4-306 800	Building G Staff Restroom G3G1	Manual	11/19/2025 10:43:06 AM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-256 772	Building G Staff Restroom G6D1	Manual	11/5/2025 4:41:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-287 790	Building G Ticket Booth G15A	Manual	11/5/2025 4:40:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - Projected Beam	4-467 827	Building G Weight Room	Manual	11/5/2025 4:39:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	4-284 788	Building G Womens RR G12	Manual	11/5/2025 4:40:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-131 202	Building A 1st Flr Elev Landing	Manual	11/5/2025 5:10:25 PM
Heat Detector - Restorable Spot	2-386 203	Building A 2nd Flr Elev Landing	Manual	11/5/2025 5:10:28 PM
Heat Detector - Restorable Spot	2-115 198	Building A HVAC Closet by A111	Manual	11/5/2025 5:10:31 PM
Heat Detector - Restorable Spot	2-322 201	Building A HVAC Closet by A205	Manual	11/5/2025 5:10:16 PM
Smoke Detector - General	3-046 369	Building C Electrical Room C2	Manual	11/4/2025 9:41:09 PM
	Comment:	No access		

Ventilation and Cooking Equipment

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Cooking Equipment	Appliances		Manual	11/5/2025 4:42:36 PM
Fusible Links	Fusible Links		Manual	11/5/2025 4:42:30 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Range Hood	Hood		Manual	11/5/2025 4:42:32 PM
Range Suppression	Suppression System		Manual	11/5/2025 4:42:39 PM
Range Suppression Tank	WHDR400S Cylinder		Manual	11/5/2025 4:42:44 PM

## Device/Equipment details

### Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Audible					
233	Building A South Exterior				
234	Building A 1st Flr O/S Boys RR				
235	Building A 2nd Flr O/S Boys RR				
287	Building A South Exterior				
348	Building B Northwest Exterior				
410	Building C North Exterior				
411	Building C South Exterior				
473	Building D North Exterior				
474	Building D South Exterior				
475	Building D West Exterior				
577	Building E North Exterior				
578	Building E North Exterior				
701	Building F South Exterior				
733	Building F Northeast Exterior				
828	Building G North Exterior				
829	Building G East Exterior				
830	Building G East Exterior				
831	Building G West Exterior				
Audible And Visible					
236	Building A 1st Floor Hallway				
237	Building A 1st Floor Hallway				
238	Building A 1st Floor Hallway				
239	Building A 1st Floor Hallway				
240	Building A 1st Floor Hallway				
241	Building A Reception Area A101				
242	Building A Admin Hallway				
243	Building A Room A104				
244	Building A Room A105				
245	Building A Room A106				
246	Building A Room A107				
247	Building A Room A108				
248	Building A Room A109				
249	Building A Room A110				
250	Building A Room A111				
251	Building A Library A114				
252	Building A Libr REF Rm A114A				
253	Building A Confernce Rm A116				
254	Building A Counsel Recep A120				
255	Building A Staff Room A126				
256	Building A 2nd Floor Hallway				
257	Building A Room A201				
258	Building A Room A202				
259	Building A Room A204				
260	Building A Room A205				
261	Building A Room A206				
262	Building A Room A207				
263	Building A Room A208				
264	Building A Room A209				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
265	Building A Room A210				
266	Building A Room A212				
267	Building A Room A213				
268	Building A Room A214				
269	Building A Room A215				
270	Building A Room A216				
271	Building A Room A217				
272	Building A Room A218				
273	Building A Room A219				
349	Building B Room B1				
350	Building B Room B2				
351	Building B Room B3				
352	Building B Room B4				
353	Building B Room B5				
354	Building B Room B6				
355	Building B Room B7				
356	Building B Room B8				
357	Building B Room B9				
358	Building B Room B10				
412	Building C Room C1				
413	Building C Room C3				
414	Building C Room C4				
415	Building C Room C5				
416	Building C Room C6				
417	Building C Room C7				
418	Building C Room C8				
476	Building D Room D1				
477	Building D Room D2				
478	Building D Room D3				
479	Building D Room D4				
480	Building D Room D5				
481	Building D Room D6				
482	Building D Room D7				
483	Building D Room D8				
579	Building E Waiting Area Rm E2				
580	Building E Room E3				
581	Building E Room E4				
582	Building E Room E5				
583	Building E Wood Shop Rm E7				
584	Building E Wood Shop Rm E7				
585	Building E Ceramics Room E8				
586	Building E Room E9				
587	Building E Office Room E12				
588	Building E Office Room E13				
589	Building E Room E14				
590	Building E Room E15				
591	Building E Room E16				
702	Building F Main Entrance F2				
703	Building F Room F2				
704	Building F Room F3				
705	Building F Room F5				
706	Building F Cafeteria Room F7				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
707	Building F Cafeteria Room F7				
708	Building F Hall Room F7D				
709	Building F Room F8				
710	Building F Hall South Entr F9				
711	Building F Kitchen Room F13				
832	Building G Big Gym				
833	Building G Big Gym				
834	Building G Small Gym				
835	Building G Small Gym				
836	Building G Boys Locker Rm G3				
837	Building G Boys Dress Rm G3J				
838	Building G Girls Locker Rm G6				
839	Building G Girls Lock RR G6				
840	Building G Dance Room G7				
841	Building G Weight Room				
Visible					
274	Building A 1st Floor Hallway				
275	Building A VP Recept A101K				
276	Building A Exterior Boy RR A103				
277	Building A Girls RR by Rm A111				
278	Building A Library A114				
279	Building A Coun Office RR				
280	Building A Staff Mens RR A122				
281	Building A Staff Wom RR A123				
282	Building A Copier Room A126A				
283	Building A 2nd Floor Hallway				
284	Building A 2nd Floor Hallway				
285	Building A Room A211 Girls RR				
286	Building A Room A220 Boys RR				
359	Building B Boys Restroom B11				
360	Building B Girls Restroom B13				
419	Building C Study Room C1B				
484	Building D Boys Restroom D9				
485	Building D Girls Restroom D11				
592	Building E Office Room E2B				
593	Building E Lecture Room E2C				
594	Building E Room E5				
595	Building E Ceramics Room E8				
596	Building E Work Room E15A				
712	Building F Staff Mens RR F1				
713	Building F Room F2				
714	Building F Computer Room F2B				
715	Building F Practice Room 4 F2C				
716	Building F Practice Room 3 F2D				
717	Building F Practice Room 2 F2E				
718	Building F Practice Room 1 F2F				
719	Building F East Entrance F2G				
720	Building F Room F3				
721	Building F Staff Womens RR F4				
722	Building F Room F5				
723	Building F Cafeteria Room F7				
724	Building F Cafeteria Room F7				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
725	Building F Boys Restroom F7C				
726	Building F Staff Restroom F7D1				
727	Building F Snack Bar Rm F7D2				
728	Building F Girls Restroom F7E				
729	Building F Staff Restroom F9A				
730	Building F Staff Restroom F9B				
731	Building F Hall by Room F13B				
732	Building F Hall by Room F13B				
842	Building G Big Gym				
843	Building G Big Gym				
844	Building G Big Gym				
845	Building G Big Gym				
846	Building G Big Gym				
847	Building G Big Gym				
848	Building G Small Gym				
849	Building G Small Gym				
850	Building G Boys Lock Entry G3				
851	Building G Boys Locker Rm G3				
852	Building G Boys Locker Rm G3				
853	Building G Boys Locker Rm G3				
854	Building G Staff Restroom G3A				
855	Building G Office Room G3G				
856	Building G Staff Restroom G3G1				
857	Building G Boys Locker RR G3K				
858	Building G Girls Locker Rm G6				
859	Building G Office Room G6C				
860	Building G Staff Restroom G6D1				
861	Building G Weight Room				

### Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Remote Annunciator					
001	Building A Reception Area A101				
NAC Power Extender Panel					
288	Building A Data Rm by Library				
289	Building A Data Rm by Library - P.E. A				
290	Building A Telco Room A118				
291	Building A Storage A222				
292	Building A Storage A222				
361	Building B Custodial Office B12				
362	Building B Custodial Office B12				
486	Building D Custodial Office D10				
487	Building D Custodial Office D10 - P.E. H				
734	Building F Equip Room F3B - P.E. J				
735	Building F Data Room F7A				
862	Building G Data Room G4				
863	Building G Data Room G4				

Fire Alarm Panel					
	Building A Data Rm by Library				

### Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
---------	-------------	--------------	-------	--------	--------------

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Manual Pull Station					
2-130 002	Building A Reception Area A101				
4-187 597	Building F Cafeteria NW Exit				
4-185 598	Building F Cafeteria NE Exit				
4-186 599	Building F Cafeteria SE Exit				
4-485 736	Building G Big Gym NE Exit				
4-484 737	Building G Big Gym SW Exit				
4-486 738	Building G Big Gym SE Exit				
Smoke Detector - General					
2-071 003	Building A Main Entrance A101				
2-072 004	Building A Main Entrance A101				
2-070 005	Building A Reception Area A101				
2-069 006	Building A Reception Area A101				
2-048 007	Building A Reception Area A101				
2-049 008	Building A Reception Area A101				
2-047 009	Building A Hall by Reg Off A101A				
2-046 010	Building A Registry Office A101A				
2-050 011	Building A Off by Recpt A101B				
2-065 012	Building A Recept Office A101E				
2-051 013	Building A VP Office 2 A101F				
2-053 014	Building A VP Office 3 A101G				
2-062 015	Building A VP Office 1 A101H				
2-063 016	Building A Hall by Principal A101i				
2-064 017	Building A Principal Office A101i				
2-052 018	Building A VP Recept A101K				
2-068 019	Building A HVAC Room A101L				
2-091 020	Building A Electrical Rm A102				
2-090 021	Building A Electrical Rm A103				
2-092 022	Building A Custodial Closet A103				
2-093 023	Building A Exterior Boy RR A103				
2-088 024	Building A Room A104				
2-087 025	Building A Room A104				
2-086 026	Building A Room A104				
2-089 027	Building A Room A104				
2-094 028	Building A Hall by Room A105				
2-098 029	Building A Room A105				
2-099 030	Building A Room A105				
2-097 031	Building A Room A105				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-096 032	Building A Room A105				
2-095 033	Building A Supply Room A105A				
2-084 034	Building A Room A106				
2-085 035	Building A Room A106				
2-082 036	Building A Room A106				
2-083 037	Building A Room A106				
2-100 038	Building A Hall by Room A107				
2-103 039	Building A Room A107				
2-104 040	Building A Room A107				
2-101 041	Building A Room A107				
2-102 042	Building A Room A107				
2-080 043	Building A Room A108				
2-081 044	Building A Room A108				
2-078 045	Building A Room A108				
2-079 046	Building A Room A108				
2-105 047	Building A Hall by Room A109				
2-108 048	Building A Room A109				
2-109 049	Building A Room A109				
2-106 050	Building A Room A109				
2-107 051	Building A Room A109				
2-110 052	Building A Hall by Room A110				
2-076 053	Building A Room A110				
2-077 054	Building A Room A110				
2-074 055	Building A Room A110				
2-075 056	Building A Room A110				
2-113 057	Building A Room A111				
2-114 058	Building A Room A111				
2-111 059	Building A Room A111				
2-112 060	Building A Room A111				
2-116 061	Building A Hall by Room A111				
2-117 062	Building A Girls RR by Rm A111				
2-118 063	Building A HVAC Room A113A				
2-027 064	Building A Library Supply A113B				
2-022 065	Building A Hall by Library A114				
2-023 066	Building A Hall by Library A114				
2-004 067	Building A Library A114				
2-006 068	Building A Library A114				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-008 069	Building A Library A114				
2-009 070	Building A Library A114				
2-007 071	Building A Library A114				
2-005 072	Building A Library A114				
2-011 073	Building A Library A114				
2-010 074	Building A Library A114				
2-013 075	Building A Libr REF Rm A114A				
2-014 076	Building A Libr REF Rm A114A				
2-012 077	Building A Supply Room A114B				
2-021 078	Building A Confernce Rm A116				
2-028 079	Building A Room A117				
2-030 080	Building A Telco Room A118				
2-031 081	Building A Custodial Closet A119				
2-016 082	Building A Counsel Recep A120				
2-015 083	Building A Counsel Recep A120				
2-020 084	Building A Coun Office 4 A120A				
2-019 085	Building A Coun Office 3 A120B				
2-018 086	Building A Coun Office 2 A120C				
2-017 087	Building A Coun Office 1 A120D				
2-002 088	Building A Data Rm by Library				
2-119 089	Building A Elevator Room A113				
2-024 090	Building A Hall by Conf Rm A113				
2-026 091	Building A Hall Stair by A113				
2-025 092	Building A Hall Entry Conf A113				
2-029 093	Building A Hall by Room A117				
2-032 094	Building A Hall by Room A119				
2-034 095	Building A Hall by Room A121B				
2-035 096	Building A Room A121				
2-037 097	Building A Coun Office A121A				
2-033 098	Building A Coun Office A121B				
2-038 099	Building A Coun Office RR				
2-036 100	Building A Hall by Room A121				
2-039 101	Building A Hall by Room A121A				
2-040 102	Building A Staff Mens RR A122				
2-041 103	Building A Hall by Room A122				
2-043 104	Building A Hall by Room A123				
2-042 105	Building A Staff Wom RR A123				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-045 106	Building A Finance Room A124				
2-044 107	Building A Hall by Finance A124				
2-055 108	Building A Staff Room A126				
2-056 109	Building A Hall by Staff Rm A126				
2-057 110	Building A Copier Room A126A				
2-337 111	Building A Stairwell by Rm A201				
2-328 112	Building A Hall by Room A201				
2-339 113	Building A Room A201				
2-338 114	Building A Room A201				
2-341 115	Building A Room A201				
2-340 116	Building A Room A201				
2-330 117	Building A Supply Room A201A				
2-328 118	Building A Hall by Room A202				
2-331 119	Building A Room A202				
2-335 120	Building A Room A202				
2-334 121	Building A Room A202				
2-332 122	Building A Room A202				
2-333 123	Building A Office Room A202A				
2-329 124	Building A Supply Room A203				
2-325 125	Building A Room A204				
2-324 126	Building A Room A204				
2-327 127	Building A Room A204				
2-326 128	Building A Room A204				
2-323 129	Building A Hall by Room A204				
2-319 130	Building A Room A205				
2-318 131	Building A Room A205				
2-321 132	Building A Room A205				
2-320 133	Building A Room A205				
2-317 134	Building A Hall by Room A205				
2-314 135	Building A Room A206				
2-313 136	Building A Room A206				
2-316 137	Building A Room A206				
2-315 138	Building A Room A206				
2-312 139	Building A Hall by Room A206				
2-254 140	Building A Room A207				
2-253 141	Building A Room A207				
2-256 142	Building A Room A207				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-255 143	Building A Room A207				
2-310 144	Building A Room A208				
2-311 145	Building A Room A208				
2-252 146	Building A Hall by Room A208				
2-307 147	Building A Room A209				
2-308 148	Building A Room A209				
2-309 149	Building A Room A209 Closet				
2-257 150	Building A Room A210				
2-260 151	Building A Room A210				
2-261 152	Building A Room A210				
2-258 153	Building A Room A210				
2-259 154	Building A Office Room A210A				
2-262 155	Building A Hall by Room A210				
2-306 156	Building A Stairwell by Rm A212				
2-263 157	Building A Room A211 Girls RR				
2-303 158	Building A Room A212				
2-304 159	Building A Room A212				
2-305 160	Building A Room A212				
2-302 161	Building A Room A212				
2-264 162	Building A Hall by Room A213				
2-266 163	Building A Room A213				
2-267 164	Building A Room A213				
2-268 165	Building A Room A213				
2-265 166	Building A Room A213				
2-299 167	Building A Room A214				
2-298 168	Building A Room A214				
2-301 169	Building A Room A214				
2-300 170	Building A Room A214				
2-269 171	Building A Hall by Room A215				
2-271 172	Building A Room A215				
2-270 173	Building A Room A215				
2-273 174	Building A Room A215				
2-272 175	Building A Room A215				
2-297 176	Building A Room A216				
2-294 177	Building A Room A216				
2-295 178	Building A Room A216				
2-296 179	Building A Room A216				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-274 180	Building A Hall by Room A217				
2-276 181	Building A Room A217				
2-277 182	Building A Room A217				
2-278 183	Building A Room A217				
2-275 184	Building A Room A217				
2-291 185	Building A Room A218				
2-290 186	Building A Room A218				
2-293 187	Building A Room A218				
2-292 188	Building A Room A218				
2-289 189	Building A Hall by Room A218				
2-281 190	Building A Room A219				
2-280 191	Building A Room A219				
2-282 192	Building A Room A219				
2-279 193	Building A Room A219				
2-284 194	Building A Room A220 Boys RR				
2-285 195	Building A Custodial Closet A221				
2-286 196	Building A Storage A222				
3-007 293	Building B Room B1				
3-006 294	Building B Room B1				
3-005 295	Building B Room B1				
3-004 296	Building B Room B1				
3-011 297	Building B Room B2				
3-010 298	Building B Room B2				
3-009 299	Building B Room B2				
3-008 300	Building B Room B2				
3-015 301	Building B Room B3				
3-014 302	Building B Room B3				
3-013 303	Building B Room B3				
3-012 304	Building B Room B3				
3-019 305	Building B Room B4				
3-018 306	Building B Room B4				
3-017 307	Building B Room B4				
3-016 308	Building B Room B4				
3-023 309	Building B Room B5				
3-022 310	Building B Room B5				
3-021 311	Building B Room B5				
3-020 312	Building B Room B5				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3-043 313	Building B Room B6				
3-044 314	Building B Room B6				
3-041 315	Building B Room B6				
3-042 316	Building B Room B6				
3-040 317	Building B Room B7				
3-037 318	Building B Room B7				
3-039 319	Building B Room B7				
3-038 320	Building B Room B7				
3-036 321	Building B Room B8				
3-035 322	Building B Room B8				
3-033 323	Building B Room B8				
3-034 324	Building B Room B8				
3-032 325	Building B Room B9				
3-031 326	Building B Room B9				
3-030 327	Building B Room B9				
3-029 328	Building B Room B9				
3-027 329	Building B Room B10				
3-025 330	Building B Room B10				
3-026 331	Building B Room B10				
3-028 332	Building B Room B10				
3-024 333	Building B Boys Restroom B11				
3-002 334	Building B Custodial Office B12				
3-003 335	Building B Girls Restroom B13				
3-052 363	Building C Room C1				
3-051 364	Building C Room C1				
3-049 365	Building C Room C1				
3-050 366	Building C Room C1				
3-047 367	Building C Supply Room C1A				
3-048 368	Building C Study Room C1B				
3-046 369	Building C Electrical Room C2				
3-053 370	Building C Room C3				
3-054 371	Building C Room C3				
3-056 372	Building C Room C3				
3-055 373	Building C Room C3				
3-060 374	Building C Room C4				
3-059 375	Building C Room C4				
3-057 376	Building C Room C4				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3-058 377	Building C Room C4				
3-064 378	Building C Room C5				
3-063 379	Building C Room C5				
3-062 380	Building C Room C5				
3-061 381	Building C Room C5				
3-068 382	Building C Room C6				
3-067 383	Building C Room C6				
3-066 384	Building C Room C6				
3-065 385	Building C Room C6				
3-073 386	Building C Book Room C6A				
3-072 387	Building C Room C7				
3-071 388	Building C Room C7				
3-070 389	Building C Room C7				
3-069 390	Building C Room C7				
3-076 391	Building C Supply Room C7A				
3-082 392	Building C Room C8				
3-081 393	Building C Room C8				
3-079 394	Building C Room C8				
3-080 395	Building C Room C8				
3-077 396	Building C Room C8				
3-074 397	Building C Supply Room C8A				
3-075 398	Building C Book Room C8B				
3-078 399	Building C Room C8C				
3-256 420	Building D Room D1				
3-257 421	Building D Room D1				
3-254 422	Building D Room D1				
3-255 423	Building D Room D1				
3-258 424	Building D Supply Room D1A				
3-263 425	Building D Room D2				
3-260 426	Building D Room D2				
3-261 427	Building D Room D2				
3-262 428	Building D Room D2				
3-259 429	Building D Supply Room D2A				
3-267 430	Building D Room D3				
3-266 431	Building D Room D3				
3-265 432	Building D Room D3				
3-264 433	Building D Room D3				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3-269 434	Building D Office Room D3A				
3-268 435	Building D Supply Room D3B				
3-272 436	Building D Room D4				
3-271 437	Building D Room D4				
3-270 438	Building D Room D4				
3-273 439	Building D Room D4				
3-293 440	Building D Room D5				
3-292 441	Building D Room D5				
3-290 442	Building D Room D5				
3-291 443	Building D Room D5				
3-289 444	Building D Supply Room D5A				
3-287 445	Building D Room D6				
3-285 446	Building D Room D6				
3-284 447	Building D Room D6				
3-286 448	Building D Room D6				
3-288 449	Building D Supply Room D6A				
3-283 450	Building D Room D7				
3-282 451	Building D Room D7				
3-280 452	Building D Room D7				
3-281 453	Building D Room D7				
3-279 454	Building D Equip Room D7A				
3-278 455	Building D Room D8				
3-277 456	Building D Room D8				
3-275 457	Building D Room D8				
3-276 458	Building D Room D8				
3-274 459	Building D Boys Restroom D9				
3-252 460	Building D Custodial Office D10				
3-253 461	Building D Girls Restroom D11				
4-025 488	Building E Boiler Room E1				
4-026 489	Building E Boiler Room E1				
4-024 490	Building E Boiler Room E1				
4-023 491	Building E Boiler Room E1				
4-017 492	Building E Waiting Area Rm E2				
4-020 493	Building E Waiting Area Rm E2				
4-016 494	Building E Supply Room E2A				
4-018 495	Building E Office Room E2B				
4-019 496	Building E Office Room E2B				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
4-015 497	Building E Supply Room E2B1				
4-022 498	Building E Lecture Room E2C				
4-021 499	Building E Lecture Room E2C				
4-014 500	Building E Room E3				
4-013 501	Building E Room E3				
4-011 502	Building E Room E3				
4-012 503	Building E Room E3				
4-009 504	Building E Room E4				
4-010 505	Building E Room E4				
4-008 506	Building E Room E4				
4-007 507	Building E Room E4				
4-002 508	Building E Supply Room E4A				
4-003 509	Building E Room E5				
4-004 510	Building E Room E5				
4-006 511	Building E Room E5				
4-005 512	Building E Room E5				
3-344 513	Building E Wood Shop Rm E7				
3-345 514	Building E Wood Shop Rm E7				
3-346 515	Building E Wood Shop Rm E7				
3-341 516	Building E Wood Shop Rm E7				
3-342 517	Building E Wood Shop Rm E7				
3-343 518	Building E Wood Shop Rm E7				
3-339 519	Building E Office Room E7A				
3-338 520	Building E Tool Storage Rm E7B				
3-347 522	Building E Project Strg Rm E7D				
3-335 523	Building E Ceramics Room E8				
3-333 524	Building E Ceramics Room E8				
3-332 525	Building E Ceramics Room E8				
3-331 526	Building E Ceramics Room E8				
3-330 527	Building E Ceramics Room E8				
3-329 528	Building E Ceramics Room E8				
3-328 529	Building E Ceramics Room E8				
3-334 530	Building E Ceramics Room E8				
3-325 531	Building E Storage Room E8A				
3-327 532	Building E Storage Room E8A				
3-326 533	Building E Storage Room E8B				
3-324 534	Building E Room E9				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3-323 535	Building E Room E9				
3-316 536	Building E Room E9				
3-315 537	Building E Room E9				
3-317 538	Building E Room E9				
3-318 539	Building E Room E9				
3-319 540	Building E Storage Room E9A				
3-320 541	Building E Storage Room E9B				
3-322 542	Building E Office Room E9C				
3-321 543	Building E Storage Room E9D				
3-300 544	Building E Office Room E10				
3-297 545	Building E Office Room E11				
3-296 546	Building E Office Room E12				
3-295 547	Building E Storage Room E12A				
3-299 548	Building E Office Room E13				
3-298 549	Building E Office Room E13				
3-304 550	Building E Room E14				
3-303 551	Building E Room E14				
3-307 552	Building E Room E15				
3-305 553	Building E Room E15				
3-308 554	Building E Room E15				
3-306 555	Building E Room E15				
3-301 556	Building E Work Room E15A				
3-302 557	Building E Work Room E15A				
3-313 558	Building E Room E16				
3-314 559	Building E Room E16				
3-311 560	Building E Room E16				
3-310 561	Building E Room E16				
3-309 562	Building E Storage Room E16A				
3-312 563	Building E Office Room E16B				
3-336 564	Building E Electrical Room E18				
3-340 565	Building E Wood Strg Rm E19				
4-044 600	Building F Staff Mens RR F1				
4-045 601	Building F Main Entrance F2				
4-042 602	Building F NW Side Room F2				
4-043 603	Building F NW Side Room F2				
4-040 604	Building F North Side Room F2				
4-038 605	Building F NE Side Room F2				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
4-035 606	Building F East Side Room F2				
4-032 607	Building F East Side Room F2				
4-037 608	Building F Center Room F2				
4-041 609	Building F Equip Room F2A				
4-039 610	Building F Computer Room F2B				
4-036 611	Building F Practice Room 4 F2C				
4-034 612	Building F Practice Room 3 F2D				
4-033 613	Building F Practice Room 2 F2E				
4-031 614	Building F Practice Room 1 F2F				
4-030 615	Building F East Entrance F2G				
4-029 616	Building F Data Room F2G1				
4-046 617	Building F Main Entrance F3				
4-049 618	Building F SW Side Rm F3				
4-051 619	Building F South Side Room F3				
4-055 620	Building F South Side Room F3				
4-052 621	Building F Center Room F3				
4-058 622	Building F SE Side Room F3				
4-047 623	Building F Office 1 Room F3A				
4-028 624	Building F Equip Room F3B				
4-060 625	Building F SE Entrance F3C				
4-059 626	Building F Electrical Room F3C1				
4-057 627	Building F Office 6 Room F3D				
4-056 628	Building F Office 5 Room F3E				
4-054 629	Building F Office 4 Room F3F				
4-053 630	Building F Office 3 Room F3G				
4-050 631	Building F Office 2 Room F3H				
4-048 632	Building F Staff Womens RR F4				
4-070 633	Building F Room F5				
4-071 634	Building F Room F5				
4-065 635	Building F Room F5				
4-064 636	Building F Room F5				
4-066 637	Building F Room F5				
4-067 638	Building F Room F5				
4-069 639	Building F Room F5				
4-068 640	Building F Room F5				
4-063 641	Building F Supply Room F5A				
4-073 642	Building F Electrical Room F6				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
4-087 643	Building F Cafeteria Room F7				
4-082 644	Building F Cafeteria Room F7				
4-081 645	Building F Cafeteria Room F7				
4-080 646	Building F Cafeteria Room F7				
4-083 647	Building F Cafeteria Room F7				
4-088 648	Building F Cafeteria Room F7				
4-089 649	Building F Cafeteria Room F7				
4-084 650	Building F Cafeteria Room F7				
4-079 651	Building F Cafeteria Room F7				
4-078 652	Building F Cafeteria Room F7				
4-085 653	Building F Cafeteria Room F7				
4-090 654	Building F Cafeteria Room F7				
4-091 655	Building F Cafeteria Room F7				
4-086 656	Building F Cafeteria Room F7				
4-077 657	Building F Cafeteria Room F7				
4-076 658	Building F North Stair Room F7				
4-075 659	Building F South Stair Room F7				
4-062 660	Building F Data Room F7A				
4-074 661	Building F Equip Room F7B				
4-072 662	Building F Closet Room F7B1				
4-109 663	Building F Boys Restroom F7C				
4-094 664	Building F Hall Room F7D				
4-096 665	Building F Staff Restroom F7D1				
4-095 666	Building F Snack Bar Rm F7D2				
4-097 667	Building F Supply Rm F7D2A				
4-093 668	Building F Closet Room F7D3				
4-092 669	Building F Girls Restroom F7E				
4-116 670	Building F Room F8				
4-115 671	Building F Room F8				
4-114 672	Building F Room F8				
4-113 673	Building F Room F8				
4-112 674	Building F Hall South Entr F9				
4-110 675	Building F Staff Restroom F9A				
4-111 676	Building F Staff Restroom F9B				
4-105 677	Building F Boiler Room F10				
4-108 678	Building F Supply Room F12				
4-107 679	Building F Supply Room F12A				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
4-101 680	Building F Custodial Room F13A				
4-102 681	Building F Hall by Room F13B				
4-104 682	Building F Supply Room F13B				
4-103 683	Building F Electrical Room F14				
4-318 739	Building G Electrical Room G2				
4-296 740	Building G Boys Lock Entry G3				
4-291 741	Building G Boys Locker Rm G3				
4-293 742	Building G Boys Locker Rm G3				
4-319 743	Building G Boys Lock S Entry G3				
4-313 744	Building G Boys Lock S Entry G3				
4-295 745	Building G Staff Restroom G3A				
4-294 746	Building G EquipRoom G3B				
4-292 747	Building G Custodial Rm G3C				
4-297 748	Building G Equip Room 2 G3D				
4-298 749	Building G Equip Room 3 G3E				
4-303 750	Building G Office Room G3G				
4-307 751	Building G Equip Room 4 G3H				
4-308 752	Building G Equip Room 4 G3H				
4-317 753	Building G Equip Room 5 G3i				
4-312 754	Building G Equip Room 5 G3i				
4-323 755	Building G Boys Dress Rm G3J				
4-324 756	Building G Boys Dress Rm G3J				
4-325 757	Building G Boys Dress Rm G3J				
4-320 758	Building G Boys Dress Rm G3J				
4-321 759	Building G Boys Dress Rm G3J				
4-322 760	Building G Boys Dress Rm G3J				
4-314 761	Building G Boys Locker RR G3K				
4-315 762	Building G Boys Locker RR G3K				
4-316 763	Building G Data Room G4				
4-333 764	Building G Equip Room G5A				
4-332 765	Building G Office Room G5B				
4-253 766	Building G Girls Locker Entry G6				
4-272 767	Building G Girls Locker Rm G6				
4-268 768	Building G Girls Locker Rm G6				
4-271 769	Building G Girls Lock RR G6				
4-264 770	Building G Equip Room 3 G6B				
4-263 771	Building G Office Room G6C				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
4-256 772	Building G Staff Restroom G6D1				
4-255 773	Building G Equip Room G6E				
4-254 774	Building G Equip Room G6F				
4-252 775	Building G Custodial Room G6G				
4-280 776	Building G Dance Room G7				
4-279 777	Building G Dance Room G7				
4-278 778	Building G Dance Room G7				
4-281 779	Building G Dance Room G7				
4-282 780	Building G Dance Room G7				
4-277 781	Building G Dance Room G7				
4-273 782	Building G Dance Room G7				
4-274 783	Building G Dance Room G7				
4-276 784	Building G Boiler Room G8				
4-285 785	Building G Boiler Room G8				
4-275 786	Building G Boiler Room G8				
4-283 787	Building G Custodial Room G10				
4-284 788	Building G Womens RR G12				
4-289 789	Building G Mens RR G13				
4-287 790	Building G Ticket Booth G15A				
2-028	Bldg H Rm 102 West				
2-030	Bldg H Rm H102 East				
2-039	Bldg H Rm H101.1 East				
2-037	Bldg H Rm H101.1 West				
2-048	Bldg H Rm H101 East				
2-046	Bldg H Rm H101 West				
2-059	Bldg H Cust H112				
2-055	Bldg H Corr H113.2 West				
2.061	Bldg G Corr H113.2 East				
Heat Detector - Restorable Spot					
2-003 197	Building A Data Rm by Library				
2-115 198	Building A HVAC Closet by A111				
2-058 199	Building A Room A113D				
2-054 200	Building A HVAC OS Staff A126				
2-322 201	Building A HVAC Closet by A205				
2-131 202	Building A 1st Flr Elev Landing				
2-386 203	Building A 2nd Flr Elev Landing				
2-139 204	Building A Attic Library Rm A114				
2-139 205	Building A Attic Library Rm A114				
2-139 206	Building A Attic Library Rm A114				
2-139 207	Building A Attic Library Rm A114				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-139 208	Building A Attic Library Rm A114				
2-139 209	Building A Attic Library Rm A114				
3-376 462	Building D Attic Supply Rm D1A				
4-129 566	Building E Attic Supply Rm E2A				
3-381 567	Building E Attic Office Rm E9C				
3-382 568	Building E Attic Room E16				
4-106 684	Building F Wash Room F11				
4-098 685	Building F Kitchen Room F13				
4-099 686	Building F Kitchen Room F13				
4-100 687	Building F OS Freezer Rm F13D				
4-136 688	Building F Under Stage Rm F5				
4-136 689	Building F Under Stage Rm F5				
4-136 690	Building F Under Stage Rm F5				
4-131 691	Building F Attic Entry F3				
4-134 692	Building F Attic Room F5A				
4-180 693	Building F Attic Kitchen F13				
4-299 791	Building G Boys Locker Rm G3				
4-300 792	Building G Boys Locker Rm G3				
4-301 793	Building G Boys Locker Rm G3				
4-304 794	Building G Boys Locker Rm G3				
4-305 795	Building G Boys Locker Rm G3				
4-309 796	Building G Boys Locker Rm G3				
4-310 797	Building G Boys Locker Rm G3				
4-311 798	Building G Boys Locker Rm G3				
4-302 799	Building G Kitchenette Rm G3F				
4-306 800	Building G Staff Restroom G3G1				
4-257 801	Building G Girls Locker Rm G6				
4-262 802	Building G Girls Locker Rm G6				
4-258 803	Building G Girls Locker Rm G6				
4-261 804	Building G Girls Locker Rm G6				
4-259 805	Building G Girls Locker Rm G6				
4-267 806	Building G Girls Locker Rm G6				
4-269 807	Building G Girls Locker Rm G6				
4-270 808	Building G Girls Locker Rm G6				
4-260 809	Building G Girls Locker Rm G6				
4-290 810	Building G Custodial Room G14				
4-288 811	Building G Snack Bar Rm G15				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
4-377 812	Building G Attic by Equip Rm G3B				
4-376 813	Building G Attic by Cust Rm G3C				
4-378 814	Building G Attic Office G3G				
4-379 815	Building G Attic Data Room G4				
4-380 816	Building G Attic Equip Rm G5A				
4-465 817	Building G Attic Girls Lkr N Exit				
4-462 818	Building G Attic Girls Lkr Pool Ent				
4-464 819	Building G Attic Girls Lkr G6B				
4-461 820	Building G Attic Girl Coach G6C				
4-463 821	Building G Attic Girl Lkr Cust G6G				
Smoke Detector - Duct					
2-384 210	Building A Room A201				
2-384 211	Building A Room A201				
2-383 212	Building A Room A202				
2-383 213	Building A Room A202				
2-382 214	Building A Room A205				
2-382 215	Building A Room A205				
2-381 216	Building A Room A206				
2-381 217	Building A Room A206				
2-376 218	Building A Room A207				
2-376 219	Building A Room A207				
2-385 220	Building A Room A209				
2-385 221	Building A Room A209				
2-377 222	Building A Room A213				
2-377 223	Building A Room A213				
2-380 224	Building A Room A214				
2-380 225	Building A Room A214				
2-378 226	Building A Room A217				
2-378 227	Building A Room A217				
2-379 228	Building A Room A218				
2-379 229	Building A Room A218				
3-126 336	Building B Room B2				
3-126 337	Building B Room B2				
3-127 338	Building B Room B4				
3-127 339	Building B Room B4				
3-128 340	Building B Room B5				
3-128 341	Building B Room B5				
3-130 342	Building B Room B6				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
3-130 343	Building B Room B6				
3-136 344	Building B Room B8				
3-136 345	Building B Room B8				
3-129 346	Building B Room B10				
3-129 347	Building B Room B10				
3-131 400	Building C Room C1				
3-131 401	Building C Room C1				
3-132 402	Building C Room C3				
3-132 403	Building C Room C3				
3-133 404	Building C Room C4				
3-133 405	Building C Room C4				
3-134 406	Building C Room C7				
3-134 407	Building C Room C7				
3-135 408	Building C Room C8				
3-135 409	Building C Room C8				
3-377 463	Building D Supply Room D2A				
3-377 464	Building D Supply Room D2A				
3-378 465	Building D Supply Room D3B				
3-378 466	Building D Supply Room D3B				
3-378 467	Building D Supply Room D3B				
3-378 468	Building D Supply Room D3B				
3-380 469	Building D Supply Room D6A				
3-380 470	Building D Supply Room D6A				
3-379 471	Building D Equip Room D7A				
3-379 472	Building D Equip Room D7A				
4-128 569	Building E Supply Room E2B1				
4-128 570	Building E Supply Room E2B1				
4-130 571	Building E Lecture Room E2C				
4-130 572	Building E Lecture Room E2C				
4-127 573	Building E Room E4				
4-127 574	Building E Room E4				
4-126 575	Building E Room E5				
4-126 576	Building E Room E5				
4-179 694	Building F Between Rms F2/F3				
4-181 695	Building F Cafeteria Southeast				
4-182 696	Building F Cafeteria Northeast				
4-183 697	Building F Cafeteria Southwest				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
4-184 698	Building F Cafeteria Northwest				
Mechanical, Electrosonic, or Pressure Waterflow Device					
2-137 230	Building A HVAC Room A113A				
2-137 231	Building A HVAC Room A113A				
4-132 699	Building F Supply Room F5A				
Valve Tamper Switch					
2-138 232	Building A HVAC Room A113A				
4-133 700	Building F Supply Room F5A				
Smoke Detector - Projected Beam					
4-473 822	Building G Big Gym East				
4-475 823	Building G Big Gym Middle				
4-477 824	Building G Big Gym West				
4-471 825	Building G Small Gym North				
4-469 826	Building G Small Gym South				
4-467 827	Building G Weight Room				

**Ventilation and Cooking Equipment**

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Range Suppression Tank					
	WHDR400S Cylinder				02/01/2024
Range Suppression					
	Suppression System				02/01/2024
Cooking Equipment					
Appliances					
					02/01/2024
Range Hood					
	Hood				02/01/2024
Fusible Links					
	Fusible Links				08/27/2025