

Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

MESA VERDE HIGH

7501 CARRIAGE DR
CITRUS HEIGHTS, California
United States

This site has been inspected and tested in compliance with applicable standards.

Completed
Thursday, December 04, 2025

Test Session: 17 Nov 2025 16:23 RJ6615 AFA

Test Plans : Fire Alarm - Annual

ACCEPTED BY

SAN JUAN USD
5320 HEMLOCK ST
SACRAMENTO, California
United States

TESTED BY

Riley Goyet
Western States Fire Protection-
Sacramento
188 Cirby Way
Roseville, CA 95678
United States



Inspection Summary

Building Information

| | | |
|------------|----------------------------|---------|
| PROPERTY | MESA VERDE HIGH | CONTACT |
| ADDRESS | 7501 CARRIAGE DR | PHONE |
| CITY/STATE | CITRUS HEIGHTS, California | MOBILE |
| COUNTRY | United States | EMAIL |

Inspector Information

| | | | |
|---------|---|----------------|---------------------|
| COMPANY | Western States Fire Protection-Sacramento | CONTACT | Riley Goyet |
| ADDRESS | 188 Cirby Way Roseville, CA 95678 | LICENSE NUMBER | |
| COUNTRY | United States | PHONE | +1 916-200-9514 |
| | | EMAIL | riley.goyet@wsfp.us |

Testing Summary


| EQUIPMENT TYPE | TOTAL | TESTED | PASSED | FAILED |
|---------------------------------|-------|-----------|-----------|--------|
| Alarm Notification Appliance | 204 | 204(100%) | 204(100%) | 0(0%) |
| Fire Control Panel | 16 | 16(100%) | 16(100%) | 0(0%) |
| Initiating Device | 477 | 477(100%) | 477(100%) | 0(0%) |
| Mass Notification Control Panel | 1 | 1(100%) | 1(100%) | 0(0%) |

Certification

The equipment specified here in was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Thursday, December 04, 2025

ACCEPTED BY 12/04/2025

Building Representative

TESTED BY 
12/04/2025
Riley Goyet
Technician

System Details

Control Units

| ADDRESS/ SCAN ADDRESS | | DESCRIPTION | Building A Headend Rm A22C - FACP |
|-----------------------|------------|--------------|--------------------------------------|
| MANUFACTURER | Notifier | S/W VERSION | |
| MODEL | NFS-3030 | LAST UPDATE | |
| SERIAL NUMBER | | S/W LOCATION | |
| INSTALL DATE | 03/05/2019 | | |

Open Corrective Action & Solution Summary

The following 4 corrective action(s) remain open following the system inspection, testing or maintenance activities

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION |
|--------------------------|--------------------|---|
| NAC Power Extender Panel | 623 | Building J Room J2 Custodial - W |
| | Created By: | Riley Goyet |
| | Creation Date: | 12/19/2022 |
| | Corrective Action: | Replace (2) 12V 8AH Batteries |
| | Proposed Solution: | |
| | Manufacturer: | |
| | Model: | |
| NAC Power Extender Panel | 696 | Building K Data Room K205 |
| | Created By: | Cody Youngblood |
| | Creation Date: | 12/20/2023 |
| | Corrective Action: | 12v 8ah batteries out of date |
| | Proposed Solution: | |
| | Manufacturer: | |
| | Model: | |
| NAC Power Extender Panel | 162 | Building A Headend Rm A22C - B |
| | Created By: | |
| | Creation Date: | 12/27/2023 |
| | Corrective Action: | Batteries Failed Load Test: (2) x 12v7ah |
| | Proposed Solution: | Replace both batteries |
| | Manufacturer: | |
| | Model: | |
| Fire Alarm Panel | | Building A Headend Rm A22C - FACP |
| | Created By: | |
| | Creation Date: | 01/02/2024 |
| | Corrective Action: | FACP display is intermittent and was only displaying half the text. Would advise replacing with new display. Functionality is okay. |
| | Proposed Solution: | |
| | Manufacturer: | Notifier |
| | Model: | NFS-3030 |

Testing Details

Alarm Notification Appliance

Passed

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|---------------------|---------|---------------------------------|-----------------|-----------------------|
| Audible And Visible | 129 | Building A A9 Art Gallery | Manual | 11/18/2025 3:45:15 PM |
| | | Visual inspection | Passed (Manual) | |
| Visible | 146 | Building A Admin Finance Office | Manual | 11/18/2025 3:47:47 PM |
| | | Visual inspection | Passed (Manual) | |
| Visible | 156 | Building A Boys Restroom A17 | Manual | 11/18/2025 3:47:22 PM |
| | | Visual inspection | Passed (Manual) | |
| Audible And Visible | 140 | Building A Confernce Rm A24 | Manual | 11/18/2025 3:44:57 PM |
| | | Visual inspection | Passed (Manual) | |
| Audible And Visible | 144 | Building A Corridor East | Manual | 11/18/2025 3:44:49 PM |
| | | Visual inspection | Passed (Manual) | |
| Audible And Visible | 142 | Building A Corridor N by RRs | Manual | 11/18/2025 3:44:54 PM |
| | | Visual inspection | Passed (Manual) | |
| Audible And Visible | 143 | Building A Corridor North | Manual | 11/18/2025 3:44:51 PM |
| | | Visual inspection | Passed (Manual) | |
| Audible And Visible | 145 | Building A Corridor Southeast | Manual | 11/18/2025 3:44:47 PM |
| | | Visual inspection | Passed (Manual) | |
| Audible And Visible | 141 | Building A Counseling Hallway | Manual | 11/18/2025 3:44:56 PM |
| | | Visual inspection | Passed (Manual) | |
| Audible | 115 | Building A East Exterior | Manual | 11/18/2025 3:45:43 PM |
| | | Visual inspection | Passed (Manual) | |
| Visible | 155 | Building A Girls Restroom A16 | Manual | 11/18/2025 3:47:24 PM |
| | | Visual inspection | Passed (Manual) | |
| Audible And Visible | 119 | Building A Kitchen A1C | Manual | 11/18/2025 3:45:37 PM |
| | | Visual inspection | Passed (Manual) | |
| Audible And Visible | 118 | Building A Main Lobby | Manual | 11/18/2025 3:45:38 PM |
| | | Visual inspection | Passed (Manual) | |
| Audible And Visible | 117 | Building A Main Lobby | Manual | 11/18/2025 3:45:40 PM |
| | | Visual inspection | Passed (Manual) | |
| Audible And Visible | 120 | Building A Music Room A2 | Manual | 11/18/2025 3:45:35 PM |
| | | Visual inspection | Passed (Manual) | |
| Audible | 114 | Building A North Exterior | Manual | 11/18/2025 3:45:45 PM |
| | | Visual inspection | Passed (Manual) | |
| Audible And Visible | 121 | Building A Practice Rm Hall A2A | Manual | 11/18/2025 3:45:33 PM |
| | | Visual inspection | Passed (Manual) | |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|---------------------|---------|----------------------------------|-----------------|-----------------------|
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 147 | Building A Practice Room A2A1 | Manual | 11/18/2025 3:47:45 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 148 | Building A Practice Room A2A2 | Manual | 11/18/2025 3:47:44 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 149 | Building A Practice Room A2A3 | Manual | 11/18/2025 3:47:42 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 150 | Building A Practice Room A2A4 | Manual | 11/18/2025 3:47:40 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 123 | Building A Preschool Rm A4 | Manual | 11/18/2025 3:45:25 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 151 | Building A Principal Secret A13 | Manual | 11/18/2025 3:47:30 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 159 | Building A Principals Office A25 | Manual | 11/18/2025 3:47:17 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 132 | Building A Room A11 | Manual | 11/18/2025 3:45:10 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 134 | Building A Room A12 | Manual | 11/18/2025 3:45:07 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 133 | Building A Room A12 | Manual | 11/18/2025 3:45:09 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 135 | Building A Room A14 | Manual | 11/18/2025 3:45:06 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 152 | Building A Room A14A Storage | Manual | 11/18/2025 3:47:29 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 153 | Building A Room A14B Storage | Manual | 11/18/2025 3:47:27 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 136 | Building A Room A15 | Manual | 11/18/2025 3:45:04 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 154 | Building A Room A15 Storage | Manual | 11/18/2025 3:47:25 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 137 | Building A Room A21 | Manual | 11/18/2025 3:45:02 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 138 | Building A Room A22 | Manual | 11/18/2025 3:45:01 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 139 | Building A Room A23 | Manual | 11/18/2025 3:44:59 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|---------------------|---------|--------------------------------|-----------------|-----------------------|
| Audible And Visible | 124 | Building A Room A5 | Manual | 11/18/2025 3:45:23 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 125 | Building A Room A6 | Manual | 11/18/2025 3:45:21 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 126 | Building A Room A7 | Manual | 11/18/2025 3:45:20 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 128 | Building A Room A8 | Manual | 11/18/2025 3:45:17 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 127 | Building A Room A8 | Manual | 11/18/2025 3:45:18 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible | 116 | Building A South Exterior | Manual | 11/18/2025 3:45:42 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible | 160 | Building A Southeast Exterior | Manual | 11/18/2025 3:44:46 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 157 | Building A Staff Restroom A18 | Manual | 11/18/2025 3:47:20 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 158 | Building A Staff Restroom A19 | Manual | 11/18/2025 3:47:18 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 122 | Building A Student Gov Rm A3 | Manual | 11/18/2025 3:45:31 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 131 | Building A Weight Room A10 | Manual | 11/18/2025 3:45:12 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 130 | Building A Weight Room A10 | Manual | 11/18/2025 3:45:13 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 238 | Building B Boys Coach Off B3D | Manual | 11/18/2025 3:47:11 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 241 | Building B Boys Coach Shower | Manual | 11/18/2025 3:47:06 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 237 | Building B Boys Equip Rm B3A | Manual | 11/18/2025 3:47:13 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 240 | Building B Boys Locker Hallway | Manual | 11/18/2025 3:47:07 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 232 | Building B Boys Locker Room | Manual | 11/18/2025 3:44:26 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 231 | Building B Boys Locker Room | Manual | 11/18/2025 3:44:28 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 230 | Building B Boys Locker Room | Manual | 11/18/2025 3:44:30 PM |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|---------------------|---------|---------------------------------|-----------------|-----------------------|
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 242 | Building B Boys Locker Room | Manual | 11/18/2025 3:47:05 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible | 221 | Building B East Exterior | Manual | 11/18/2025 3:44:43 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 239 | Building B Girls Coach Off B3D | Manual | 11/18/2025 3:47:09 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 245 | Building B Girls Coach Shower | Manual | 11/18/2025 3:46:59 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 244 | Building B Girls Equip Rm B8 | Manual | 11/18/2025 3:47:01 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 243 | Building B Girls Locker Hallway | Manual | 11/18/2025 3:47:03 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 234 | Building B Girls Locker Room | Manual | 11/18/2025 3:44:22 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 233 | Building B Girls Locker Room | Manual | 11/18/2025 3:44:24 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 246 | Building B Girls Locker Room | Manual | 11/18/2025 3:46:58 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 227 | Building B Large Gym B1 | Manual | 11/18/2025 3:44:35 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 226 | Building B Large Gym B1 | Manual | 11/18/2025 3:44:36 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 225 | Building B Large Gym B1 | Manual | 11/18/2025 3:44:38 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 224 | Building B Large Gym B1 | Manual | 11/18/2025 3:44:39 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 229 | Building B Lrg Gym Frnt Ent B1 | Manual | 11/18/2025 3:44:32 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 228 | Building B Lrg Gym Frnt Ent B1 | Manual | 11/18/2025 3:44:33 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 235 | Building B Restroom B1B | Manual | 11/18/2025 3:47:16 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 236 | Building B Restroom B1C | Manual | 11/18/2025 3:47:14 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible | 222 | Building B South Exterior | Manual | 11/18/2025 3:44:45 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|---------------------|---------|--------------------------|-----------------|-----------------------|
| Audible | 223 | Building B West Exterior | Manual | 11/18/2025 3:44:41 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible | 262 | Building C East Exterior | Manual | 11/18/2025 3:44:18 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible | 261 | Building C East Exterior | Manual | 11/18/2025 3:44:21 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 265 | Building C Room C1 | Manual | 11/18/2025 3:44:05 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 264 | Building C Room C1 | Manual | 11/18/2025 3:44:07 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 266 | Building C Room C2 | Manual | 11/18/2025 3:44:19 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 267 | Building C Room C3 | Manual | 11/18/2025 3:44:01 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible | 263 | Building C West Exterior | Manual | 11/18/2025 3:44:13 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 373 | Building D Classroom D1 | Manual | 11/18/2025 3:43:42 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 378 | Building D Classroom D10 | Manual | 11/18/2025 3:43:37 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 379 | Building D Classroom D11 | Manual | 11/18/2025 3:43:35 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 380 | Building D Classroom D12 | Manual | 11/18/2025 3:43:34 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 381 | Building D Classroom D13 | Manual | 11/18/2025 3:43:32 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 382 | Building D Classroom D14 | Manual | 11/18/2025 3:43:30 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 383 | Building D Classroom D15 | Manual | 11/18/2025 3:43:29 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 384 | Building D Classroom D19 | Manual | 11/18/2025 3:43:27 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 374 | Building D Classroom D2 | Manual | 11/18/2025 3:43:44 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 386 | Building D Classroom D21 | Manual | 11/18/2025 3:43:24 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 388 | Building D Classroom D23 | Manual | 11/18/2025 3:43:20 PM |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|---------------------|---------|-----------------------------|-----------------|-----------------------|
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 390 | Building D Classroom D25 | Manual | 11/18/2025 3:43:17 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 391 | Building D Classroom D28 | Manual | 11/18/2025 3:43:16 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 375 | Building D Classroom D3 | Manual | 11/18/2025 3:43:41 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 392 | Building D Classroom D30 | Manual | 11/18/2025 3:43:14 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 394 | Building D Classroom D32 | Manual | 11/18/2025 3:43:11 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 395 | Building D Classroom D36 | Manual | 11/18/2025 3:43:10 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 411 | Building D Classroom D36 | Manual | 11/18/2025 3:46:30 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 412 | Building D Classroom D36 | Manual | 11/18/2025 3:46:32 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 376 | Building D Classroom D4 | Manual | 11/18/2025 3:43:38 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 377 | Building D Classroom D9 | Manual | 11/18/2025 3:43:39 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 387 | Building D Computer Lab 22 | Manual | 11/18/2025 3:43:22 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 385 | Building D Computer Lab D20 | Manual | 11/18/2025 3:43:26 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 389 | Building D Computer Lab D24 | Manual | 11/18/2025 3:43:19 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 370 | Building D East Corridor | Manual | 11/18/2025 3:43:49 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 369 | Building D East Corridor | Manual | 11/18/2025 3:43:50 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible | 364 | Building D East Exterior | Manual | 11/18/2025 3:43:58 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible | 363 | Building D East Exterior | Manual | 11/18/2025 3:43:59 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 399 | Building D Lab D5 | Manual | 11/18/2025 3:46:52 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|---------------------|---------|--|---------------------------|-----------------------|
| Visible | 400 | Building D Lab D6 | Manual | 11/18/2025 3:46:50 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Visible | 401 | Building D Lab D7 | Manual | 11/18/2025 3:46:49 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Visible | 402 | Building D Lab D8 | Manual | 11/18/2025 3:46:47 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Audible And Visible | 367 | Building D North Hallway | Manual | 11/18/2025 3:43:52 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Audible And Visible | 368 | Building D North Hallway | Manual | 11/18/2025 3:43:54 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Visible | 406 | Building D Restroom D27 | Manual | 11/18/2025 3:46:41 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Visible | 405 | Building D Restroom D27 | Manual | 11/18/2025 3:46:42 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Visible | 408 | Building D Restroom D29 | Manual | 11/18/2025 3:46:37 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Visible | 407 | Building D Restroom D29 | Manual | 11/18/2025 3:46:39 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Audible And Visible | 371 | Building D South Corridor | Manual | 11/18/2025 3:43:47 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Visible | 397 | Building D South Corridor | Manual | 11/18/2025 3:46:55 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Visible | 396 | Building D South Corridor | Manual | 11/18/2025 3:46:57 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Visible | 409 | Building D Staff Restroom D31B | Manual | 11/18/2025 3:46:35 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Visible | 410 | Building D Staff Restroom D31C | Manual | 11/18/2025 3:46:34 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Audible And Visible | 393 | Building D Staff Room D31 | Manual | 11/18/2025 3:43:13 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Visible | 404 | Building D Storage/Office D26 | Manual | 11/18/2025 3:46:43 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Visible | 403 | Building D Student Store D16 | Manual | 11/18/2025 3:46:45 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Audible And Visible | 372 | Building D West Corridor | Manual | 11/18/2025 3:43:46 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Visible | 398 | Building D West Corridor | Manual | 11/18/2025 3:46:53 PM |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|---------------------|---------|--------------------------------------|-----------------|-----------------------|
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible | 366 | Building D West Exterior | Manual | 11/18/2025 3:43:55 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible | 365 | Building D West Exterior | Manual | 11/18/2025 3:43:57 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 434 | Building F Room F1 | Manual | 11/18/2025 3:41:48 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 435 | Building F Room F2 | Manual | 11/18/2025 3:41:46 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 436 | Building F Room F3 | Manual | 11/18/2025 3:42:01 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 437 | Building F Room F4 | Manual | 11/18/2025 3:43:04 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible | 432 | Building F South Exterior | Manual | 11/18/2025 3:43:07 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible | 433 | Building F South Exterior | Manual | 11/18/2025 3:43:08 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 443 | Building G Room G1 | Manual | 11/18/2025 3:43:02 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible | 442 | Building G South Exterior | Manual | 11/18/2025 3:43:03 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 575 | Building H - PAC Dressing Rm Hall H6 | Manual | 11/18/2025 3:46:16 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 577 | Building H - PAC Dressing Room H6B | Manual | 11/18/2025 3:46:13 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 564 | Building H - PAC Food Services H11A | Manual | 11/18/2025 3:42:38 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 561 | Building H - PAC Hall H6 | Manual | 11/18/2025 3:42:43 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 563 | Building H - PAC Kitchen H10 | Manual | 11/18/2025 3:42:40 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 579 | Building H - PAC Kitchen H10 | Manual | 11/18/2025 3:46:10 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 562 | Building H - PAC Loading Area H8 | Manual | 11/18/2025 3:42:41 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 565 | Building H - PAC N Chair Storage | Manual | 11/18/2025 3:42:36 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|---------------------|---------|-------------------------------------|-----------------|-----------------------|
| Audible | 550 | Building H - PAC North Exterior | Manual | 11/18/2025 3:43:00 PM |
| | | Visual inspection | Passed (Manual) | |
| Visible | 576 | Building H - PAC Restroom H6A | Manual | 11/18/2025 3:46:15 PM |
| | | Visual inspection | Passed (Manual) | |
| Visible | 578 | Building H - PAC Restroom H6C | Manual | 11/18/2025 3:46:12 PM |
| | | Visual inspection | Passed (Manual) | |
| Audible And Visible | 566 | Building H - PAC S Chair Storage | Manual | 11/18/2025 3:42:35 PM |
| | | Visual inspection | Passed (Manual) | |
| Audible And Visible | 558 | Building H - PAC Seating Entry H4 | Manual | 11/18/2025 3:42:48 PM |
| | | Visual inspection | Passed (Manual) | |
| Visible | 580 | Building H - PAC Seating Exit H11 | Manual | 11/18/2025 3:46:09 PM |
| | | Visual inspection | Passed (Manual) | |
| Audible And Visible | 557 | Building H - PAC Seating H3 | Manual | 11/18/2025 3:42:49 PM |
| | | Visual inspection | Passed (Manual) | |
| Audible And Visible | 556 | Building H - PAC Seating H3 | Manual | 11/18/2025 3:42:51 PM |
| | | Visual inspection | Passed (Manual) | |
| Audible And Visible | 555 | Building H - PAC Seating H3 | Manual | 11/18/2025 3:42:52 PM |
| | | Visual inspection | Passed (Manual) | |
| Audible And Visible | 554 | Building H - PAC Seating H3 | Manual | 11/18/2025 3:42:54 PM |
| | | Visual inspection | Passed (Manual) | |
| Visible | 570 | Building H - PAC Seating H3 | Manual | 11/18/2025 3:46:24 PM |
| | | Visual inspection | Passed (Manual) | |
| Visible | 572 | Building H - PAC Seating Restrm H4A | Manual | 11/18/2025 3:46:21 PM |
| | | Visual inspection | Passed (Manual) | |
| Visible | 571 | Building H - PAC Seating Restrm H4A | Manual | 11/18/2025 3:46:23 PM |
| | | Visual inspection | Passed (Manual) | |
| Visible | 574 | Building H - PAC Seating Restrm H4B | Manual | 11/18/2025 3:46:18 PM |
| | | Visual inspection | Passed (Manual) | |
| Visible | 573 | Building H - PAC Seating Restrm H4B | Manual | 11/18/2025 3:46:20 PM |
| | | Visual inspection | Passed (Manual) | |
| Audible | 551 | Building H - PAC South Exterior | Manual | 11/18/2025 3:42:57 PM |
| | | Visual inspection | Passed (Manual) | |
| Audible And Visible | 560 | Building H - PAC Stage H5 | Manual | 11/18/2025 3:42:45 PM |
| | | Visual inspection | Passed (Manual) | |
| Audible And Visible | 559 | Building H - PAC Stage H5 | Manual | 11/18/2025 3:42:46 PM |
| | | Visual inspection | Passed (Manual) | |
| Visible | 567 | Building H - PAC Up Stairs Entry H1 | Manual | 11/18/2025 3:46:29 PM |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|---------------------|---------|-------------------------------------|-----------------|-----------------------|
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 553 | Building H - PAC Up Stairs Lobby H2 | Manual | 11/18/2025 3:42:55 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 569 | Building H - PAC Up Stairs Lobby H2 | Manual | 11/18/2025 3:46:26 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 568 | Building H - PAC Up Stairs Lobby H2 | Manual | 11/18/2025 3:46:27 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible | 552 | Building H - PAC West Exterior | Manual | 11/18/2025 3:42:59 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 590 | Building I i-1A Restroom | Manual | 11/18/2025 3:46:08 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible | 588 | Building I North Exterior | Manual | 11/18/2025 3:42:29 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 589 | Building I Room i-1 | Manual | 11/18/2025 3:42:33 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible | 614 | Building J East Exterior | Manual | 11/18/2025 3:42:25 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible | 613 | Building J North Exterior | Manual | 11/18/2025 3:42:27 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 621 | Building J Room J3 Girls RR | Manual | 11/18/2025 3:46:00 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 622 | Building J Room J4 Boys RR | Manual | 11/18/2025 3:46:02 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 618 | Building J Small Gym J1 | Manual | 11/18/2025 3:42:19 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 617 | Building J Small Gym J1 | Manual | 11/18/2025 3:42:22 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 620 | Building J Small Gym J1 | Manual | 11/18/2025 3:46:04 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 619 | Building J Small Gym J1 | Manual | 11/18/2025 3:46:06 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible | 615 | Building J South Exterior | Manual | 11/18/2025 3:42:26 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible | 616 | Building J West Exterior | Manual | 11/18/2025 3:42:23 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 685 | Building K 1st Floor Hallway | Manual | 11/18/2025 3:41:52 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|---------------------|---------|--------------------------------|-----------------|-----------------------|
| Audible And Visible | 684 | Building K 1st Floor Hallway | Manual | 11/18/2025 3:41:54 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 687 | Building K 3rd Floor Hallway | Manual | 11/18/2025 3:41:49 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 686 | Building K 3rd Floor Hallway | Manual | 11/18/2025 3:41:51 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 689 | Building K Boys Restroom K106 | Manual | 11/18/2025 3:45:57 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 694 | Building K Boys Restroom K304 | Manual | 11/18/2025 3:45:49 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 676 | Building K Classroom 1 K101 | Manual | 11/18/2025 3:42:14 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 677 | Building K Classroom 2 K102 | Manual | 11/18/2025 3:42:13 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 678 | Building K Classroom 3 K301 | Manual | 11/18/2025 3:42:11 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 679 | Building K Classroom 4 K302 | Manual | 11/18/2025 3:42:09 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible | 674 | Building K East Exterior | Manual | 11/18/2025 3:42:17 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 690 | Building K Girls Restroom K108 | Manual | 11/18/2025 3:45:55 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 695 | Building K Girls Restroom K306 | Manual | 11/18/2025 3:45:46 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 681 | Building K Library K202 | Manual | 11/18/2025 3:42:06 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 680 | Building K Library K202 | Manual | 11/18/2025 3:42:08 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 692 | Building K Library K202 | Manual | 11/18/2025 3:45:52 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 691 | Building K Library K202 | Manual | 11/18/2025 3:45:54 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible | 675 | Building K South Exterior | Manual | 11/18/2025 3:42:15 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 693 | Building K Staff RR K203A | Manual | 11/18/2025 3:45:50 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Visible | 688 | Building K Stairwell K105 | Manual | 11/18/2025 3:45:59 PM |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|---------------------|---------|--------------------------|-----------------|-----------------------|
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 683 | Building K Workroom K203 | Manual | 11/18/2025 3:41:55 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Audible And Visible | 682 | Building K Workroom K203 | Manual | 11/18/2025 3:41:57 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |

Fire Control Panel

Passed

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|--------------------------|---------|--|-----------------|----------------------|
| NAC Power Extender Panel | 162 | Building A Headend Rm A22C - B | Manual | 12/4/2025 9:24:27 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| NAC Power Extender Panel | 163 | Building A Headend Rm A22C - C | Manual | 12/4/2025 9:26:16 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| NAC Power Extender Panel | 164 | Building A Headend Rm A22C - E | Manual | 12/4/2025 9:26:18 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Fire Alarm Panel | | Building A Headend Rm A22C - FACP | Manual | 12/4/2025 9:26:50 AM |
| | | Manufacturer | Notifier | |
| | | Model | NFS-3030 | |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| NAC Power Extender Panel | 161 | Building A Headend Rm A22C - PE "Master" | Manual | 12/4/2025 9:26:15 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Remote Annunciator | 001 | Building A Principal Secret A13 | Manual | 12/4/2025 9:26:26 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| NAC Power Extender Panel | 247 | Building B Lrg Gym Storage B2B - F | Manual | 12/4/2025 9:26:25 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| NAC Power Extender Panel | 248 | Building B Lrg Gym Storage B2B - G | Manual | 12/4/2025 9:26:24 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| NAC Power Extender Panel | 413 | Building D Room D31A - K | Manual | 12/4/2025 9:26:20 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| NAC Power Extender Panel | 414 | Building D Room D31A - L | Manual | 12/4/2025 9:26:22 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| NAC Power Extender Panel | 415 | Building D Room D31A - N | Manual | 12/4/2025 9:26:21 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| NAC Power Extender Panel | 444 | Building G Room G1 - V | Manual | 12/4/2025 9:26:13 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| NAC Power Extender Panel | 581 | Building H - PAC Room H5A - P | Manual | 12/4/2025 9:28:08 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| NAC Power Extender Panel | 582 | Building H - PAC Room H5A - R | Manual | 12/4/2025 9:28:06 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|--------------------------|---------|----------------------------------|-----------------|----------------------|
| NAC Power Extender Panel | 623 | Building J Room J2 Custodial - W | Manual | 12/4/2025 9:26:12 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| NAC Power Extender Panel | 696 | Building K Data Room K205 | Manual | 12/4/2025 9:27:47 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |

Initiating Device

Passed

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|---------------------------------|--------------|----------------------------------|-----------------|-----------------------|
| Smoke Detector - General | 2-041 018 | Building A A2 Hallway | Manual | 11/17/2025 7:24:19 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - Duct | 2-136 100 | Building A A2 Soffit | Manual | 12/4/2025 9:24:31 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - Duct | 2-140 101 | Building A A3 Soffit | Manual | 12/4/2025 9:24:32 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-083 041 | Building A A9 Art Gallery | Manual | 11/18/2025 3:54:22 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-082 042 | Building A A9 Art Gallery | Manual | 11/18/2025 3:55:40 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-080 043 | Building A A9 Art Gallery Closet | Manual | 11/18/2025 3:55:35 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-081 044 | Building A A9 Art Gallery Closet | Manual | 11/18/2025 6:31:34 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-079 017 | Building A Admin Finance Office | Manual | 11/18/2025 6:31:58 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Manual Pull Station | 2-145 002 | Building A Admin Office Rm A1 | Manual | 11/18/2025 4:10:12 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 2-137 098 | Building A Attic Kiln | Manual | 12/4/2025 9:27:02 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-016 066 | Building A Boys Restroom A17 | Manual | 11/18/2025 4:06:27 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-066 078 | Building A Confernce Rm A24 | Manual | 11/17/2025 7:25:11 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-097 087 | Building A Corridor East | Manual | 11/17/2025 7:27:57 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-099 082 | Building A Corridor North | Manual | 11/17/2025 7:27:47 PM |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|---------------------------------|--------------|--|---------------------------|-----------------------|
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Smoke Detector - General | 2-098 083 | Building A Corridor Northeast | Manual | 11/17/2025 7:27:53 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Smoke Detector - General | 2-092 086 | Building A Corridor Southeast | Manual | 11/17/2025 7:28:03 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Smoke Detector - General | 2-093 085 | Building A Corridor Southeast | Manual | 11/17/2025 7:28:06 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Smoke Detector - General | 2-094 084 | Building A Corridor Southeast | Manual | 11/17/2025 7:28:08 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Smoke Detector - General | 2-088 081 | Building A Counseling Hallway | Manual | 11/18/2025 6:31:17 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Smoke Detector - General | 2-037 011 | Building A Counselors Off A1G | Manual | 11/17/2025 7:26:47 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Smoke Detector - General | 2-038 012 | Building A Counselors Off A1H | Manual | 11/17/2025 7:26:41 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Smoke Detector - General | 2-039 013 | Building A Counselors Off A1i | Manual | 11/17/2025 7:26:29 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Smoke Detector - General | 2-036 080 | Building A Counselors Off A27 | Manual | 11/18/2025 4:04:39 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Smoke Detector - General | 2-017 070 | Building A Custodial Rm A20A | Manual | 11/18/2025 6:31:21 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Smoke Detector - General | 2-018 069 | Building A Electrical Rm A20 | Manual | 11/18/2025 6:31:22 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Smoke Detector - General | 2-015 065 | Building A Girls Restroom A16 | Manual | 11/18/2025 4:05:49 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Smoke Detector - General | 2-096 033 | Building A Hallway by A3 | Manual | 11/18/2025 6:31:13 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Smoke Detector - General | 2-007 075 | Building A Headend Rm A22C | Manual | 11/18/2025 6:31:41 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector - Restorable Spot | 2-095 097 | Building A Kiln Storage Rm SW | Manual | 12/4/2025 9:25:11 AM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector - Restorable Spot | 2-042 088 | Building A Kitchen A1C | Manual | 12/4/2025 9:25:38 AM |
| | | Visual inspection | Passed (Manual) | |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|---------------------------------|--------------|--------------------------------|-----------------|-----------------------|
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 2-043 089 | Building A Kitchen A1C | Manual | 12/4/2025 9:25:52 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-052 016 | Building A Main Lobby Clst A11 | Manual | 11/17/2025 7:23:49 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-048 005 | Building A Main Lobby NE | Manual | 11/17/2025 7:24:12 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-049 004 | Building A Main Lobby NW | Manual | 11/17/2025 7:23:59 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-045 008 | Building A Main Lobby Off A1A | Manual | 11/17/2025 7:23:51 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-044 009 | Building A Main Lobby Off A1B | Manual | 11/17/2025 7:24:16 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-046 014 | Building A Main Lobby Off A1J | Manual | 11/17/2025 7:24:09 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-047 015 | Building A Main Lobby Off A1K | Manual | 11/17/2025 7:24:01 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-050 006 | Building A Main Lobby SE | Manual | 11/17/2025 7:24:10 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-051 007 | Building A Main Lobby SW | Manual | 11/17/2025 7:23:57 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-034 020 | Building A Music Room A2 | Manual | 11/18/2025 5:55:52 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-035 021 | Building A Music Room A2 | Manual | 11/18/2025 5:55:55 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-032 019 | Building A Music Room A2 | Manual | 11/18/2025 5:56:01 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-033 022 | Building A Music Room A2 | Manual | 11/18/2025 5:56:06 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - Duct | 2-135 106 | Building A MZ-10 A14 | Manual | 12/4/2025 9:24:38 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - Duct | 2-126 103 | Building A MZ-11 Room A12 | Manual | 12/4/2025 9:24:35 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|---------------------------------|--------------|----------------------------------|-----------------|-----------------------|
| Smoke Detector - Duct | 2-139 102 | Building A MZ-7 A2/A3 Hall | Manual | 12/4/2025 9:24:34 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - Duct | 2-146 108 | Building A MZ-8 Room A21 | Manual | 12/4/2025 9:24:42 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - Duct | 2-138 099 | Building A MZ-9 Admin | Manual | 12/4/2025 9:24:29 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - Duct | 2-141 109 | Building A North Hallway | Manual | 12/4/2025 9:24:47 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-027 023 | Building A Practice Rm Hall A2A | Manual | 11/18/2025 6:31:19 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-026 025 | Building A Practice Room A2A1 | Manual | 11/18/2025 5:55:35 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-025 026 | Building A Practice Room A2A2 | Manual | 11/18/2025 5:55:37 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-029 027 | Building A Practice Room A2A3 | Manual | 11/18/2025 5:55:40 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-028 028 | Building A Practice Room A2A4 | Manual | 11/18/2025 5:55:48 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 2-014 091 | Building A Preschool Rm A4 | Manual | 12/4/2025 9:25:41 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-064 058 | Building A Principal Secret A13 | Manual | 11/17/2025 7:25:50 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-065 079 | Building A Principals Office A25 | Manual | 11/17/2025 7:26:05 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-076 053 | Building A Room A11 | Manual | 11/18/2025 3:53:10 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-078 054 | Building A Room A11 | Manual | 11/18/2025 3:53:22 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-075 052 | Building A Room A11 | Manual | 11/18/2025 3:57:03 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-077 055 | Building A Room A11 | Manual | 11/18/2025 3:57:16 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|---------------------------------|--------------|------------------------------|-----------------|-----------------------|
| Smoke Detector - General | 2-073 056 | Building A Room A12 | Manual | 11/18/2025 3:52:14 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-071 057 | Building A Room A12 | Manual | 11/18/2025 3:52:17 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - Duct | 2-134 105 | Building A Room A14 | Manual | 12/4/2025 9:24:41 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - Duct | 2-132 104 | Building A Room A14 | Manual | 12/4/2025 9:24:49 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-060 061 | Building A Room A14 | Manual | 11/18/2025 6:31:42 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-061 059 | Building A Room A14 | Manual | 11/18/2025 6:31:43 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-058 062 | Building A Room A14 | Manual | 11/18/2025 6:31:45 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-059 060 | Building A Room A14 | Manual | 11/18/2025 6:31:47 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-063 063 | Building A Room A14A Storage | Manual | 11/18/2025 6:31:50 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-062 064 | Building A Room A14B Storage | Manual | 11/18/2025 6:31:48 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 2-055 092 | Building A Room A15 | Manual | 12/4/2025 9:25:18 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 2-054 094 | Building A Room A15 | Manual | 12/4/2025 9:25:20 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 2-053 095 | Building A Room A15 | Manual | 12/4/2025 9:25:29 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 2-056 093 | Building A Room A15 | Manual | 12/4/2025 9:25:36 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 2-057 096 | Building A Room A15 Storage | Manual | 12/4/2025 9:25:10 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - Duct | 2-127 107 | Building A Room A21 | Manual | 12/4/2025 9:24:37 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|---------------------------------|--------------|---------------------------------|-----------------|-----------------------|
| Smoke Detector - General | 2-012 071 | Building A Room A21 | Manual | 11/18/2025 3:49:38 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-010 072 | Building A Room A22 | Manual | 11/18/2025 6:31:39 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-067 076 | Building A Room A23 | Manual | 11/18/2025 6:31:35 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-069 077 | Building A Room A23 | Manual | 11/18/2025 6:31:37 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-013 034 | Building A Room A5 | Manual | 11/18/2025 6:31:24 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-011 036 | Building A Room A6 | Manual | 11/18/2025 4:12:18 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-070 037 | Building A Room A7 | Manual | 11/18/2025 6:31:27 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-068 038 | Building A Room A7 | Manual | 11/18/2025 6:31:29 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-072 040 | Building A Room A8 | Manual | 11/18/2025 6:31:30 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-074 039 | Building A Room A8 | Manual | 11/18/2025 6:31:32 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-101 035 | Building A Rooms A5 A6 Entry | Manual | 11/18/2025 6:31:26 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Manual Pull Station | 2-147 003 | Building A Secretary Office A13 | Manual | 12/4/2025 9:27:45 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - Duct | 2-131 111 | Building A South Hallway | Manual | 12/4/2025 9:24:44 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - Duct | 2-130 110 | Building A South Hallway | Manual | 12/4/2025 9:24:46 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 2-031 090 | Building A Staff Breakroom A2D | Manual | 12/4/2025 9:25:40 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-019 067 | Building A Staff Restroom A18 | Manual | 11/17/2025 7:24:52 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|---|--------------|-------------------------------|-----------------|-----------------------|
| Smoke Detector - General | 2-020 068 | Building A Staff Restroom A19 | Manual | 11/18/2025 4:08:38 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-040 010 | Building A Storage Room A1F | Manual | 11/17/2025 7:27:15 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-009 073 | Building A Storage Room A22A | Manual | 11/18/2025 5:34:33 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-008 074 | Building A Storage Room A22B | Manual | 11/18/2025 5:33:40 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-030 024 | Building A Storage Room A2B | Manual | 11/18/2025 5:36:07 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-024 030 | Building A Student Gov Rm A3 | Manual | 11/18/2025 5:36:09 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-023 029 | Building A Student Gov Rm A3 | Manual | 11/18/2025 5:36:51 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-021 032 | Building A Student Gov Rm A3 | Manual | 11/18/2025 5:37:01 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-022 031 | Building A Student Gov Rm A3 | Manual | 11/18/2025 5:55:27 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-084 051 | Building A Weight Rm Off A10A | Manual | 11/18/2025 4:02:49 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Mechanical, Electrosonic, or Pressure Waterflow Device | 2-148 112 | Building A Weight Room A10 | Manual | 11/20/2025 3:02:47 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-089 045 | Building A Weight Room A10 | Manual | 11/18/2025 3:58:37 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-090 046 | Building A Weight Room A10 | Manual | 11/18/2025 3:58:59 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-091 047 | Building A Weight Room A10 | Manual | 11/18/2025 3:59:50 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-087 048 | Building A Weight Room A10 | Manual | 11/18/2025 4:00:06 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-086 049 | Building A Weight Room A10 | Manual | 11/18/2025 4:00:27 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|---------------------------------|--------------|--|---------------------------|-----------------------|
| Smoke Detector - General | 2-085 050 | Building A Weight Room A10 | Manual | 11/18/2025 4:00:49 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Valve Tamper Switch | 2-149 113 | Building A Weight Room A10 | Manual | 12/4/2025 9:26:31 AM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Smoke Detector - General | 2-291 200 | Building B Boys Coach Off B3D | Manual | 11/18/2025 5:56:38 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector - Restorable Spot | 2-290 206 | Building B Boys Coach Shower | Manual | 12/4/2025 9:25:53 AM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector - Restorable Spot | 2-293 204 | Building B Boys Locker Hallway | Manual | 11/19/2025 4:23:25 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector - Restorable Spot | 2-377 207 | Building B Boys Locker Room | Manual | 11/19/2025 4:23:12 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector - Restorable Spot | 2-294 205 | Building B Boys Locker Room | Manual | 11/19/2025 4:23:15 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector - Restorable Spot | 2-377 209 | Building B Boys Locker Room | Manual | 11/19/2025 4:23:18 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector - Restorable Spot | 2-377 208 | Building B Boys Locker Room | Manual | 11/19/2025 4:23:20 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector - Restorable Spot | 2-377 210 | Building B Boys Locker Room | Manual | 11/19/2025 4:23:21 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector - Restorable Spot | 2-377 211 | Building B Boys Locker Room | Manual | 11/19/2025 4:23:23 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Manual Pull Station | 2-407 166 | Building B Boys Locker Room | Manual | 12/4/2025 9:26:36 AM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Smoke Detector - General | 2-288 201 | Building B Girls Coach Off B3D | Manual | 11/18/2025 5:58:48 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector - Restorable Spot | 2-289 213 | Building B Girls Coach Shower | Manual | 12/4/2025 9:25:57 AM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector - Restorable Spot | 2-285 215 | Building B Girls Equip Rm B8A | Manual | 12/4/2025 9:25:55 AM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector - Restorable Spot | 2-286 212 | Building B Girls Locker Hallway | Manual | 11/19/2025 4:23:14 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|---------------------------------|--------------|---------------------------------|-----------------|-----------------------|
| Heat Detector - Restorable Spot | 2-287 214 | Building B Girls Locker Rm Strg | Manual | 11/19/2025 4:07:56 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 2-376 218 | Building B Girls Locker Room | Manual | 11/19/2025 4:07:47 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 2-376 217 | Building B Girls Locker Room | Manual | 11/19/2025 4:07:48 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 2-376 216 | Building B Girls Locker Room | Manual | 11/19/2025 4:07:50 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 2-376 220 | Building B Girls Locker Room | Manual | 11/19/2025 4:07:52 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 2-376 219 | Building B Girls Locker Room | Manual | 11/19/2025 4:07:54 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Manual Pull Station | 2-406 167 | Building B Girls Locker Room | Manual | 12/4/2025 9:26:34 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 2-254 202 | Building B Gym Food Sales B1A | Manual | 12/4/2025 9:26:01 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 2-253 203 | Building B Gym Ticket Sale B1A1 | Manual | 12/4/2025 9:25:59 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-261 191 | Building B Large Gym B1 | Manual | 11/19/2025 3:47:04 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-262 190 | Building B Large Gym B1 | Manual | 11/19/2025 3:47:05 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-281 168 | Building B Large Gym B1 | Manual | 11/19/2025 3:47:07 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-282 169 | Building B Large Gym B1 | Manual | 11/19/2025 3:47:11 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-283 170 | Building B Large Gym B1 | Manual | 11/19/2025 3:47:12 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-284 171 | Building B Large Gym B1 | Manual | 11/19/2025 3:47:14 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-278 174 | Building B Large Gym B1 | Manual | 11/19/2025 3:47:15 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|--------------------------|--------------|-------------------------|-----------------|-----------------------|
| Smoke Detector - General | 2-279 173 | Building B Large Gym B1 | Manual | 11/19/2025 3:47:17 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-280 172 | Building B Large Gym B1 | Manual | 11/19/2025 3:47:34 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-273 176 | Building B Large Gym B1 | Manual | 11/19/2025 3:47:35 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-277 175 | Building B Large Gym B1 | Manual | 11/19/2025 3:47:37 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-275 178 | Building B Large Gym B1 | Manual | 11/19/2025 3:47:39 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-274 177 | Building B Large Gym B1 | Manual | 11/19/2025 3:47:40 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-276 179 | Building B Large Gym B1 | Manual | 11/19/2025 3:47:42 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-271 181 | Building B Large Gym B1 | Manual | 11/19/2025 3:47:43 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-272 180 | Building B Large Gym B1 | Manual | 11/19/2025 3:47:45 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-269 183 | Building B Large Gym B1 | Manual | 11/19/2025 3:47:47 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-270 182 | Building B Large Gym B1 | Manual | 11/19/2025 3:47:48 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-265 184 | Building B Large Gym B1 | Manual | 11/19/2025 3:47:49 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-267 186 | Building B Large Gym B1 | Manual | 11/19/2025 3:47:51 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-268 187 | Building B Large Gym B1 | Manual | 11/19/2025 3:47:56 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-264 188 | Building B Large Gym B1 | Manual | 11/19/2025 3:47:57 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-263 189 | Building B Large Gym B1 | Manual | 11/19/2025 3:47:58 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|------------------------------------|--------------|--|---------------------------|-----------------------|
| Smoke Detector - General | 2-266 185 | Building B Large Gym B1 | Manual | 11/19/2025 4:02:40 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Manual Pull Station | 2-405 165 | Building B Large Gym Lobby | Manual | 12/4/2025 9:26:38 AM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Smoke Detector - General | 2-259 197 | Building B Lg Gym Clst Up B2A | Manual | 11/19/2025 4:02:35 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Smoke Detector - General | 2-252 196 | Building B Lg Gym Up Strg B2 | Manual | 11/19/2025 3:48:03 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Smoke Detector - General | 2-260 198 | Building B Lrg Gym Closet B2A | Manual | 11/19/2025 4:02:37 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Smoke Detector - General | 2-255 193 | Building B Lrg Gym Frnt Ent B1 | Manual | 11/19/2025 3:48:00 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Smoke Detector - General | 2-256 192 | Building B Lrg Gym Frnt Ent B1 | Manual | 11/19/2025 3:48:01 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Smoke Detector - General | 2-251 199 | Building B Lrg Gym Storage B2B | Manual | 11/19/2025 4:02:34 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Smoke Detector - General | 2-258 194 | Building B Restroom B1B | Manual | 11/19/2025 4:02:38 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Smoke Detector - General | 2-257 195 | Building B Restroom B1C | Manual | 11/18/2025 5:56:17 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector - Restorable Spot | 2-382 257 | Building C Attic Room C1 | Manual | 12/4/2025 9:26:09 AM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector - Restorable Spot | 2-382 258 | Building C Attic Room C1 | Manual | 12/4/2025 9:26:54 AM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector - Restorable Spot | 2-381 259 | Building C Attic Room C2 | Manual | 12/4/2025 9:26:02 AM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector - Restorable Spot | 2-380 260 | Building C Attic Room C3 | Manual | 12/4/2025 9:27:04 AM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Smoke Detector - General | 2-307 249 | Building C Room C1 | Manual | 11/18/2025 5:11:03 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Smoke Detector - General | 2-306 250 | Building C Room C1 | Manual | 11/18/2025 5:11:05 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|--|--------------|--------------------------------|-----------------|-----------------------|
| Smoke Detector - General | 2-304 251 | Building C Room C1 | Manual | 11/18/2025 6:30:47 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-305 252 | Building C Room C1 | Manual | 11/18/2025 6:30:48 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-303 253 | Building C Room C2 | Manual | 11/18/2025 6:30:50 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-302 254 | Building C Room C2 | Manual | 11/18/2025 6:30:54 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-301 255 | Building C Room C3 | Manual | 11/18/2025 6:30:51 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-300 256 | Building C Room C3 | Manual | 11/18/2025 6:30:55 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-085 354 | Building D Basmnt Cust Off D37 | Manual | 11/17/2025 4:39:39 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-084 353 | Building D Basmnt Cust Off D37 | Manual | 12/4/2025 9:25:08 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-083 352 | Building D Basmnt Cust Off D37 | Manual | 12/4/2025 9:26:08 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Mechanical, Electrosonic, or Pressure Waterflow Device | 3-133 361 | Building D Basmnt Cust Off D37 | Manual | 12/4/2025 9:26:46 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-002 289 | Building D Classroom D1 | Manual | 11/17/2025 4:40:53 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-001 290 | Building D Classroom D1 | Manual | 11/17/2025 4:40:56 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-064 303 | Building D Classroom D10 | Manual | 11/17/2025 4:42:04 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-063 304 | Building D Classroom D10 | Manual | 11/17/2025 4:42:06 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-038 305 | Building D Classroom D11 | Manual | 11/17/2025 4:42:15 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-037 306 | Building D Classroom D11 | Manual | 11/17/2025 4:42:16 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|--------------------------|--------------|--------------------------|-----------------|-----------------------|
| Smoke Detector - General | 3-061 307 | Building D Classroom D12 | Manual | 11/17/2025 4:42:08 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-062 308 | Building D Classroom D12 | Manual | 11/17/2025 4:42:10 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-036 309 | Building D Classroom D13 | Manual | 11/17/2025 4:42:18 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-035 310 | Building D Classroom D13 | Manual | 11/17/2025 4:42:20 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-059 311 | Building D Classroom D14 | Manual | 11/17/2025 4:42:22 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-060 312 | Building D Classroom D14 | Manual | 11/17/2025 4:42:23 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-034 314 | Building D Classroom D15 | Manual | 11/17/2025 4:42:25 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-033 313 | Building D Classroom D15 | Manual | 11/17/2025 4:42:27 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-042 318 | Building D Classroom D19 | Manual | 11/17/2025 4:42:37 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-041 319 | Building D Classroom D19 | Manual | 11/17/2025 4:42:39 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-005 291 | Building D Classroom D2 | Manual | 11/17/2025 4:40:35 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-004 292 | Building D Classroom D2 | Manual | 11/17/2025 4:40:36 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-043 322 | Building D Classroom D21 | Manual | 11/17/2025 4:42:46 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-044 323 | Building D Classroom D21 | Manual | 11/17/2025 4:42:47 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-046 326 | Building D Classroom D23 | Manual | 11/17/2025 4:42:55 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-045 327 | Building D Classroom D23 | Manual | 11/17/2025 4:42:56 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|--------------------------|--------------|--------------------------|-----------------|-----------------------|
| Smoke Detector - General | 3-048 330 | Building D Classroom D25 | Manual | 11/17/2025 4:42:58 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-047 331 | Building D Classroom D25 | Manual | 11/17/2025 4:43:00 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-073 334 | Building D Classroom D28 | Manual | 11/17/2025 4:41:15 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-072 335 | Building D Classroom D28 | Manual | 11/17/2025 4:41:17 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-008 293 | Building D Classroom D3 | Manual | 11/17/2025 4:40:30 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-007 294 | Building D Classroom D3 | Manual | 11/17/2025 4:40:32 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-075 337 | Building D Classroom D30 | Manual | 11/17/2025 4:41:02 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-074 338 | Building D Classroom D30 | Manual | 11/17/2025 4:41:04 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-077 342 | Building D Classroom D32 | Manual | 11/17/2025 4:40:59 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-076 343 | Building D Classroom D32 | Manual | 11/17/2025 4:41:01 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-067 346 | Building D Classroom D36 | Manual | 11/17/2025 4:40:40 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-066 347 | Building D Classroom D36 | Manual | 11/17/2025 4:40:42 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-065 348 | Building D Classroom D36 | Manual | 11/17/2025 4:40:43 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-011 295 | Building D Classroom D4 | Manual | 11/17/2025 4:40:24 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-010 296 | Building D Classroom D4 | Manual | 11/17/2025 4:40:27 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-040 301 | Building D Classroom D9 | Manual | 11/17/2025 4:41:58 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|--------------------------|--------------|--------------------------------|-----------------|-----------------------|
| Smoke Detector - General | 3-039 302 | Building D Classroom D9 | Manual | 11/17/2025 4:42:00 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-053 321 | Building D Computer Lab D20 | Manual | 11/17/2025 4:42:31 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-052 320 | Building D Computer Lab D20 | Manual | 11/17/2025 4:42:32 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-055 324 | Building D Computer Lab D22 | Manual | 11/17/2025 4:42:49 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-054 325 | Building D Computer Lab D22 | Manual | 11/17/2025 4:42:50 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-056 328 | Building D Computer Lab D24 | Manual | 11/17/2025 4:42:52 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-057 329 | Building D Computer Lab D24 | Manual | 11/17/2025 4:42:53 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-032 270 | Building D East Corridor | Manual | 11/17/2025 4:40:58 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-031 271 | Building D East Corridor | Manual | 11/17/2025 4:41:05 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-030 272 | Building D East Corridor | Manual | 11/17/2025 4:41:13 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-029 273 | Building D East Corridor | Manual | 11/17/2025 4:41:23 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-028 274 | Building D East Foyer | Manual | 11/17/2025 4:41:25 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-050 317 | Building D Electrical Room D16 | Manual | 11/17/2025 4:42:44 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-071 350 | Building D Electrical Room D38 | Manual | 11/17/2025 4:40:51 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-102 339 | Building D IDF Staff Rm D31A | Manual | 11/17/2025 4:41:10 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-049 316 | Building D Janitor Closet D16 | Manual | 11/17/2025 4:42:34 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|--------------------------|--------------|------------------------------|-----------------|-----------------------|
| Smoke Detector - General | 3-003 297 | Building D Lab D5 | Manual | 11/17/2025 4:40:55 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-006 298 | Building D Lab D6 | Manual | 11/17/2025 4:40:38 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-009 299 | Building D Lab D7 | Manual | 11/17/2025 4:40:29 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-012 300 | Building D Lab D8 | Manual | 11/17/2025 4:40:23 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - Duct | 3-130 355 | Building D MZ-1 D So | Manual | 12/4/2025 9:28:17 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - Duct | 3-131 356 | Building D MZ-2 D So | Manual | 12/4/2025 9:28:14 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - Duct | 3-129 357 | Building D MZ-3 D No | Manual | 12/4/2025 9:28:15 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - Duct | 3-132 358 | Building D MZ-4 D30 | Manual | 11/17/2025 4:39:37 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - Duct | 3-128 359 | Building D MZ-5 D35 | Manual | 11/17/2025 4:39:30 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - Duct | 3-135 360 | Building D MZ-6 D45 | Manual | 12/4/2025 9:28:12 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-027 275 | Building D North Hallway | Manual | 11/17/2025 4:41:27 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-026 276 | Building D North Hallway | Manual | 11/17/2025 4:41:29 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-025 277 | Building D North Hallway | Manual | 11/17/2025 4:41:31 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-078 333 | Building D Restroom D27 | Manual | 11/17/2025 4:43:02 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-079 336 | Building D Restroom D29 | Manual | 11/17/2025 4:41:21 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-068 349 | Building D Room D36A Storage | Manual | 11/17/2025 4:40:45 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|---------------------------------|--------------|--------------------------------|-----------------|-----------------------|
| Smoke Detector - General | 3-013 269 | Building D South Corridor | Manual | 11/17/2025 4:40:12 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-014 288 | Building D South Corridor | Manual | 11/17/2025 4:40:14 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-015 287 | Building D South Corridor | Manual | 11/17/2025 4:40:15 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-017 285 | Building D South Corridor | Manual | 11/17/2025 4:40:17 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-018 284 | Building D South Corridor | Manual | 11/17/2025 4:40:18 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-019 283 | Building D South Corridor | Manual | 11/17/2025 4:40:21 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-016 286 | Building D South Hallway | Manual | 11/17/2025 4:40:20 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-080 340 | Building D Staff Restroom D31B | Manual | 11/17/2025 4:41:09 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-081 341 | Building D Staff Restroom D31C | Manual | 11/17/2025 4:41:07 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-082 351 | Building D Staff Room D31 | Manual | 12/4/2025 9:26:06 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Manual Pull Station | 2-144 268 | Building D Staff Room D31 | Manual | 12/4/2025 9:28:11 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-070 344 | Building D Storage Room D34 | Manual | 11/17/2025 4:40:47 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-069 345 | Building D Storage Room D35 | Manual | 11/17/2025 4:40:50 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-058 332 | Building D Storage/Office D26 | Manual | 11/17/2025 4:41:19 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-051 315 | Building D Student Store D16 | Manual | 11/17/2025 4:42:28 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-023 279 | Building D West Corridor | Manual | 11/17/2025 4:41:43 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|---------------------------------|--------------|---------------------------|-----------------|-----------------------|
| Smoke Detector - General | 3-022 280 | Building D West Corridor | Manual | 11/17/2025 4:41:53 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-021 281 | Building D West Corridor | Manual | 11/17/2025 4:41:55 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-020 282 | Building D West Corridor | Manual | 11/17/2025 4:41:56 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-024 278 | Building D West Foyer | Manual | 11/17/2025 4:41:33 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 2-399 428 | Building F Attic Room F1 | Manual | 12/4/2025 9:27:05 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 2-400 429 | Building F Attic Room F2 | Manual | 12/4/2025 9:27:07 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 2-401 430 | Building F Attic Room F3 | Manual | 12/4/2025 9:27:09 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 2-402 431 | Building F Attic Room F4 | Manual | 12/4/2025 9:27:35 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-298 417 | Building F Room F1 | Manual | 11/18/2025 5:11:21 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-299 416 | Building F Room F1 | Manual | 11/18/2025 5:11:22 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-308 418 | Building F Room F1 Closet | Manual | 11/18/2025 5:11:19 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-309 420 | Building F Room F2 | Manual | 11/18/2025 5:11:16 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-310 419 | Building F Room F2 | Manual | 11/18/2025 5:11:18 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-311 421 | Building F Room F2 Closet | Manual | 11/18/2025 5:11:15 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-312 422 | Building F Room F3 | Manual | 11/18/2025 5:11:11 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-313 423 | Building F Room F3 | Manual | 11/18/2025 5:11:12 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|------------------------------------|--------------|--|---------------------------|-----------------------|
| Smoke Detector - General | 2-314 424 | Building F Room F3 Closet | Manual | 11/18/2025 5:11:14 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Smoke Detector - General | 2-315 426 | Building F Room F4 | Manual | 11/18/2025 5:11:08 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Smoke Detector - General | 2-316 425 | Building F Room F4 | Manual | 11/18/2025 5:11:09 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Smoke Detector - General | 2-317 427 | Building F Room F4 Closet | Manual | 11/18/2025 5:11:06 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector - Restorable Spot | 2-398 441 | Building G Attic Room G1 | Manual | 12/4/2025 9:26:52 AM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Smoke Detector - General | 2-296 438 | Building G Room G1 | Manual | 11/18/2025 5:06:30 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Smoke Detector - General | 2-297 440 | Building G Room G1 Closet | Manual | 11/18/2025 5:06:32 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Smoke Detector - General | 2-295 439 | Building G Room G1A | Manual | 11/18/2025 5:06:28 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Smoke Detector - General | 3-329 529 | Building H - PAC Custodian Closet | Manual | 11/19/2025 4:01:16 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Smoke Detector - General | 3-266 507 | Building H - PAC Dressing Rm Hall H6 | Manual | 11/19/2025 4:01:35 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Smoke Detector - General | 3-265 509 | Building H - PAC Dressing Room H6B | Manual | 11/18/2025 4:52:26 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector - Restorable Spot | 3-330 540 | Building H - PAC E HVAC Rm H12B1 | Manual | 11/19/2025 4:23:41 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Smoke Detector - General | 3-332 530 | Building H - PAC E Storage | Manual | 11/19/2025 4:01:11 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector - Restorable Spot | 3-380 541 | Building H - PAC Filter Room H12B1 | Manual | 11/19/2025 4:23:38 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Heat Detector - Restorable Spot | 3-309 539 | Building H - PAC Food Services H11A | Manual | 11/19/2025 4:23:45 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |
| Smoke Detector - General | 3-321 525 | Building H - PAC Hall Chair Storage | Manual | 11/18/2025 4:20:32 PM |
| | | Visual inspection Functional Inspection | Passed (Manual) Passed | |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|---------------------------------|--------------|-----------------------------------|-----------------|-----------------------|
| Smoke Detector - General | 3-264 506 | Building H - PAC Hall H6 | Manual | 11/18/2025 4:49:08 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-263 536 | Building H - PAC HVAC Room H7 | Manual | 11/19/2025 4:23:40 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - Duct | 3-378 542 | Building H - PAC HVAC Room H7 | Manual | 12/4/2025 9:27:52 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - Duct | 3-379 543 | Building H - PAC HVAC Room H7 | Manual | 12/4/2025 9:27:55 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-310 537 | Building H - PAC Kitchen H10 | Manual | 11/19/2025 4:23:43 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 3-311 538 | Building H - PAC Kitchen H10 | Manual | 11/19/2025 4:23:46 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-261 513 | Building H - PAC Loading Area H8 | Manual | 11/18/2025 4:49:52 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-262 514 | Building H - PAC Loading Area H8 | Manual | 11/19/2025 4:01:29 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-260 512 | Building H - PAC Loading Area H8 | Manual | 11/19/2025 4:01:52 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-259 511 | Building H - PAC Loading Area H8 | Manual | 11/19/2025 4:01:53 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Manual Pull Station | 3-390 445 | Building H - PAC Lower Northwest | Manual | 12/4/2025 9:27:53 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Manual Pull Station | 3-389 446 | Building H - PAC Lower Southwest | Manual | 12/4/2025 9:27:50 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-253 502 | Building H - PAC N Camera Rm H5A1 | Manual | 11/19/2025 4:01:27 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-333 526 | Building H - PAC N Chair Storage | Manual | 11/19/2025 4:01:14 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-336 522 | Building H - PAC N Hall H12 | Manual | 11/18/2025 6:08:55 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-334 521 | Building H - PAC N Hall H12 | Manual | 11/19/2025 4:01:09 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|--|--------------|------------------------------------|-----------------|-----------------------|
| Smoke Detector - General | 3-337 523 | Building H - PAC N Storage H12A | Manual | 11/19/2025 4:01:05 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-252 500 | Building H - PAC N Storage H5 | Manual | 11/19/2025 3:53:49 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-251 501 | Building H - PAC N Storage H5A | Manual | 11/19/2025 3:48:47 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-314 532 | Building H - PAC NE Stairs | Manual | 11/19/2025 4:01:34 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-313 531 | Building H - PAC NE Stairs | Manual | 11/19/2025 4:01:37 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-335 486 | Building H - PAC North Hall H12 | Manual | 11/19/2025 4:01:07 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-257 535 | Building H - PAC NW Hall | Manual | 11/18/2025 5:56:23 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-256 515 | Building H - PAC NW Office H8A | Manual | 11/19/2025 4:01:50 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-254 516 | Building H - PAC NW Office H8B | Manual | 11/19/2025 4:01:32 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-255 518 | Building H - PAC NW Office H9 | Manual | 11/19/2025 4:01:48 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-258 517 | Building H - PAC NW Storage H8C | Manual | 11/18/2025 5:56:20 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Valve Tamper Switch | 3-384 549 | Building H - PAC PIV | Manual | 12/4/2025 9:26:30 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-267 508 | Building H - PAC Restroom H6A | Manual | 11/18/2025 4:51:02 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-268 510 | Building H - PAC Restroom H6C | Manual | 11/19/2025 4:01:44 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Mechanical, Electrosonic, or Pressure Waterflow Device | 3-376 547 | Building H - PAC Riser Closet H11B | Manual | 12/4/2025 9:26:47 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-308 520 | Building H - PAC Riser Closet H11B | Manual | 11/19/2025 4:01:04 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|--------------------------|--------------|------------------------------------|-----------------|-----------------------|
| Valve Tamper Switch | 3-377 548 | Building H - PAC Riser Closet H11B | Manual | 12/4/2025 9:26:39 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - Duct | 3-381 544 | Building H - PAC Room H12B | Manual | 12/4/2025 9:28:09 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - Duct | 3-383 545 | Building H - PAC Room H12B North | Manual | 12/4/2025 9:28:00 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - Duct | 3-382 546 | Building H - PAC Room H12B South | Manual | 12/4/2025 9:28:01 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-273 505 | Building H - PAC S Camera Rm H5B1 | Manual | 11/19/2025 4:01:26 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-328 528 | Building H - PAC S Chair Storage | Manual | 11/19/2025 4:01:21 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-327 527 | Building H - PAC S Chair Storage | Manual | 11/19/2025 4:01:23 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-326 524 | Building H - PAC S Storage H12B4 | Manual | 11/19/2025 4:01:24 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-274 504 | Building H - PAC S Storage H5B | Manual | 11/19/2025 3:48:45 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-272 503 | Building H - PAC S Storage H5B | Manual | 11/19/2025 3:48:48 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-325 533 | Building H - PAC SE Stairs | Manual | 11/19/2025 3:48:42 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-324 534 | Building H - PAC SE Stairs | Manual | 11/19/2025 3:48:43 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-307 487 | Building H - PAC Seating Entry H4 | Manual | 11/19/2025 4:01:47 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-312 519 | Building H - PAC Seating Exit H11 | Manual | 11/19/2025 4:01:38 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-291 474 | Building H - PAC Seating H3 | Manual | 11/18/2025 6:03:59 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-285 468 | Building H - PAC Seating H3 | Manual | 11/18/2025 6:04:19 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|--------------------------|--------------|-----------------------------|-----------------|-----------------------|
| Smoke Detector - General | 3-295 478 | Building H - PAC Seating H3 | Manual | 11/19/2025 3:55:21 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-302 485 | Building H - PAC Seating H3 | Manual | 11/19/2025 3:55:22 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-297 480 | Building H - PAC Seating H3 | Manual | 11/19/2025 3:55:24 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-301 484 | Building H - PAC Seating H3 | Manual | 11/19/2025 3:55:26 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-300 483 | Building H - PAC Seating H3 | Manual | 11/19/2025 3:55:28 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-292 475 | Building H - PAC Seating H3 | Manual | 11/19/2025 3:55:29 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-298 481 | Building H - PAC Seating H3 | Manual | 11/19/2025 3:56:48 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-299 482 | Building H - PAC Seating H3 | Manual | 11/19/2025 3:56:50 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-293 476 | Building H - PAC Seating H3 | Manual | 11/19/2025 3:56:52 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-296 479 | Building H - PAC Seating H3 | Manual | 11/19/2025 3:56:54 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-294 477 | Building H - PAC Seating H3 | Manual | 11/19/2025 3:57:21 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-289 472 | Building H - PAC Seating H3 | Manual | 11/19/2025 3:57:23 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-290 473 | Building H - PAC Seating H3 | Manual | 11/19/2025 3:59:45 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-288 471 | Building H - PAC Seating H3 | Manual | 11/19/2025 3:59:48 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-287 470 | Building H - PAC Seating H3 | Manual | 11/19/2025 3:59:50 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-283 466 | Building H - PAC Seating H3 | Manual | 11/19/2025 3:59:52 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|--------------------------|--------------|--------------------------------------|-----------------|-----------------------|
| Smoke Detector - General | 3-284 467 | Building H - PAC Seating H3 | Manual | 11/19/2025 3:59:53 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-286 469 | Building H - PAC Seating H3 | Manual | 11/19/2025 3:59:55 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-278 461 | Building H - PAC Seating H3 | Manual | 11/19/2025 3:59:56 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-280 463 | Building H - PAC Seating H3 | Manual | 11/19/2025 3:59:58 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-282 465 | Building H - PAC Seating H3 | Manual | 11/19/2025 3:59:59 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-279 462 | Building H - PAC Seating H3 | Manual | 11/19/2025 4:00:01 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-276 459 | Building H - PAC Seating H3 | Manual | 11/19/2025 4:00:10 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-277 460 | Building H - PAC Seating H3 | Manual | 11/19/2025 4:00:12 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-275 458 | Building H - PAC Seating H3 | Manual | 11/19/2025 4:00:14 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-281 464 | Building H - PAC Seating H3 | Manual | 11/19/2025 4:01:02 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-304 488 | Building H - PAC Seating Resrm H4A | Manual | 11/19/2025 4:01:42 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-305 489 | Building H - PAC Seating Restr m H4A | Manual | 11/19/2025 4:01:41 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-303 490 | Building H - PAC Seating Restr m H4B | Manual | 11/19/2025 4:01:39 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-306 491 | Building H - PAC Seating Restr m H4B | Manual | 11/19/2025 4:01:45 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-340 497 | Building H - PAC Stage H5 | Manual | 11/18/2025 6:21:59 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-271 493 | Building H - PAC Stage H5 | Manual | 11/19/2025 3:51:49 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|--------------------------|--------------|-------------------------------------|-----------------|-----------------------|
| Smoke Detector - General | 3-338 492 | Building H - PAC Stage H5 | Manual | 11/19/2025 3:51:51 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-269 495 | Building H - PAC Stage H5 | Manual | 11/19/2025 3:51:53 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-270 494 | Building H - PAC Stage H5 | Manual | 11/19/2025 3:51:55 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-341 498 | Building H - PAC Stage H5 | Manual | 11/19/2025 3:53:37 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-342 499 | Building H - PAC Stage H5 | Manual | 11/19/2025 3:53:40 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-339 496 | Building H - PAC Stage H5 | Manual | 11/19/2025 3:53:52 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-321 449 | Building H - PAC Up Stairs Entry H1 | Manual | 11/18/2025 4:20:27 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-318 454 | Building H - PAC Up Stairs Lobby H2 | Manual | 11/18/2025 4:21:16 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-319 453 | Building H - PAC Up Stairs Lobby H2 | Manual | 11/18/2025 4:21:25 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-317 452 | Building H - PAC Up Stairs Lobby H2 | Manual | 11/18/2025 4:21:42 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-316 451 | Building H - PAC Up Stairs Lobby H2 | Manual | 11/18/2025 4:21:55 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-315 450 | Building H - PAC Up Stairs Lobby H2 | Manual | 11/18/2025 4:22:29 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-320 455 | Building H - PAC Up Stairs Lobby H2 | Manual | 11/18/2025 4:24:20 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-323 457 | Building H - PAC Up Stairs Rm H2A1 | Manual | 11/18/2025 4:24:43 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 3-322 456 | Building H - PAC Up Stairs Room H2A | Manual | 11/18/2025 4:24:25 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Manual Pull Station | 3-387 447 | Building H - PAC Upper Northeast | Manual | 12/4/2025 9:28:05 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|---------------------------------|--------------|----------------------------------|-----------------|-----------------------|
| Manual Pull Station | 3-388 448 | Building H - PAC Upper Southeast | Manual | 12/4/2025 9:28:03 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 2-129 594 | Building I Attic Room i-1 | Manual | 12/4/2025 9:26:56 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 2-128 592 | Building I Attic Room i-1 | Manual | 12/4/2025 9:26:57 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 2-128 593 | Building I Attic Room i-1 | Manual | 12/4/2025 9:26:59 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 2-128 591 | Building I Attic Room i-1 | Manual | 12/4/2025 9:27:00 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-006 586 | Building I i-1A Restroom | Manual | 11/18/2025 4:11:03 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-003 584 | Building I Room i-1 | Manual | 11/18/2025 4:10:26 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-002 585 | Building I Room i-1 | Manual | 11/18/2025 5:09:46 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-005 583 | Building I Room i-1 | Manual | 11/18/2025 5:09:48 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-004 587 | Building I Room i-1B Closet | Manual | 11/18/2025 5:09:50 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 2-387 607 | Building J Attic Boys Restroom | Manual | 12/4/2025 9:24:56 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 2-387 606 | Building J Attic Boys Restroom | Manual | 12/4/2025 9:25:07 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 2-386 609 | Building J Attic Girls Restroom | Manual | 12/4/2025 9:24:52 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 2-386 608 | Building J Attic Girls Restroom | Manual | 12/4/2025 9:24:53 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - Projected Beam | 2-392 612 | Building J Beam East | Manual | 12/4/2025 9:27:40 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - Projected Beam | 2-388 610 | Building J Beam Left | Manual | 12/4/2025 9:27:37 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|---------------------------------|--------------|---------------------------------|-----------------|-----------------------|
| Smoke Detector - Projected Beam | 2-390 611 | Building J Beam Middle | Manual | 12/4/2025 9:27:38 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-342 599 | Building J Room J1A Storage | Manual | 11/18/2025 5:31:00 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-343 598 | Building J Room J1A Storage | Manual | 11/18/2025 5:31:02 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-341 600 | Building J Room J2 Custodial | Manual | 11/18/2025 5:09:10 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-339 602 | Building J Room J3 Girls RR | Manual | 11/18/2025 5:09:14 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-340 601 | Building J Room J3 Girls RR | Manual | 11/18/2025 5:09:15 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-337 604 | Building J Room J4 Boys RR | Manual | 11/18/2025 5:09:12 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-338 603 | Building J Room J4 Boys RR | Manual | 11/18/2025 5:09:17 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 2-336 605 | Building J Room J5 Elect Rm | Manual | 11/18/2025 5:09:19 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Manual Pull Station | 2-395 596 | Building J Small Gym J1 NE | Manual | 12/4/2025 9:26:41 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Manual Pull Station | 2-396 595 | Building J Small Gym J1 NW | Manual | 12/4/2025 9:26:44 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Manual Pull Station | 2-397 597 | Building J Small Gym J1 SE | Manual | 12/4/2025 9:26:42 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 4-394 657 | Building K Attic Classrm 1 K101 | Manual | 11/19/2025 4:58:39 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 4-394 658 | Building K Attic Classrm 1 K101 | Manual | 11/19/2025 4:58:40 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 4-392 660 | Building K Attic Classrm 2 K102 | Manual | 11/19/2025 4:58:42 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 4-392 659 | Building K Attic Classrm 2 K102 | Manual | 11/19/2025 4:58:44 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|---------------------------------|--------------|---------------------------------|-----------------|-----------------------|
| Heat Detector - Restorable Spot | 4-401 661 | Building K Attic Classrm 3 K301 | Manual | 11/19/2025 4:58:46 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 4-401 662 | Building K Attic Classrm 3 K301 | Manual | 11/19/2025 4:58:47 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 4-396 663 | Building K Attic Classrm 4 K302 | Manual | 11/19/2025 4:58:48 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 4-396 664 | Building K Attic Classrm 4 K302 | Manual | 11/19/2025 4:58:50 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 4-397 669 | Building K Attic Cust K305 | Manual | 11/19/2025 4:58:34 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 4-376 666 | Building K Attic Library K202 | Manual | 11/19/2025 4:34:27 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 4-376 665 | Building K Attic Library K202 | Manual | 11/19/2025 4:58:37 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 4-377 668 | Building K Attic Library K203 | Manual | 11/19/2025 4:58:31 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 4-377 667 | Building K Attic Library K203 | Manual | 11/19/2025 4:58:32 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 4-272 636 | Building K Boys Restroom K106 | Manual | 11/18/2025 4:29:14 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 4-280 651 | Building K Boys Restroom K304 | Manual | 11/18/2025 4:31:20 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 4-276 625 | Building K Classroom 1 K101 | Manual | 11/18/2025 4:14:56 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 4-277 624 | Building K Classroom 1 K101 | Manual | 11/18/2025 4:15:17 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 4-270 627 | Building K Classroom 2 K102 | Manual | 11/18/2025 4:16:52 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 4-271 626 | Building K Classroom 2 K102 | Manual | 11/18/2025 4:17:13 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 4-284 628 | Building K Classroom 3 K301 | Manual | 11/18/2025 4:33:19 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|--|--------------|--------------------------------|-----------------|-----------------------|
| Smoke Detector - General | 4-257 629 | Building K Classroom 3 K301 | Manual | 11/18/2025 4:33:43 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 4-278 630 | Building K Classroom 4 K302 | Manual | 11/18/2025 4:34:24 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 4-279 631 | Building K Classroom 5 K302 | Manual | 11/18/2025 4:34:45 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 4-273 637 | Building K Custodial Rm K107 | Manual | 11/18/2025 4:16:18 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 4-281 652 | Building K Custodial Rm K305 | Manual | 11/18/2025 4:32:39 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 4-267 632 | Building K Data /Elect Rm K103 | Manual | 11/18/2025 4:18:56 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 4-259 649 | Building K Data Room K205 | Manual | 11/18/2025 4:37:08 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 4-260 648 | Building K Electrical Rm K204 | Manual | 11/18/2025 4:37:38 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 4-268 633 | Building K Elev Equip Rm K103A | Manual | 11/18/2025 4:51:34 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 4-287 656 | Building K Elevator Rm K103A | Manual | 11/19/2025 4:58:35 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Mechanical, Electrosonic, or Pressure Waterflow Device | 4-402 671 | Building K Fire Riser Rm K206 | Manual | 12/4/2025 9:26:48 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 4-285 650 | Building K Fire Riser Rm K206 | Manual | 11/18/2025 5:10:53 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Valve Tamper Switch | 4-403 672 | Building K Fire Riser Rm K206 | Manual | 12/4/2025 9:27:48 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 4-275 639 | Building K Girls Restroom K108 | Manual | 11/18/2025 4:30:11 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 4-274 638 | Building K Girls Restroom K108 | Manual | 11/18/2025 5:10:02 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 4-283 653 | Building K Girls Restroom K306 | Manual | 11/18/2025 4:32:04 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|---------------------------------|--------------|--------------------------------|-----------------|-----------------------|
| Smoke Detector - General | 4-282 654 | Building K Girls Restroom K306 | Manual | 11/18/2025 5:10:04 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 4-252 641 | Building K Library K202 | Manual | 11/18/2025 4:41:18 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 4-253 642 | Building K Library K202 | Manual | 11/18/2025 4:41:36 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 4-255 643 | Building K Library K202 | Manual | 11/18/2025 4:42:00 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 4-254 644 | Building K Library K202 | Manual | 11/18/2025 4:42:25 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 4-269 634 | Building K Lobby K104 | Manual | 11/18/2025 5:10:46 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 4-262 640 | Building K Lobby K201 | Manual | 11/18/2025 5:10:49 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 4-265 655 | Building K Lobby K308 | Manual | 11/18/2025 5:10:48 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Valve Tamper Switch | 4-404 673 | Building K PIV | Manual | 12/4/2025 9:26:33 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 4-393 670 | Building K RR Chase K106/K108 | Manual | 11/19/2025 4:34:25 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 4-261 647 | Building K Staff RR K203A | Manual | 11/18/2025 4:44:03 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 4-266 635 | Building K Stairwell K105 | Manual | 11/18/2025 6:31:52 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 4-256 645 | Building K Workroom K203 | Manual | 11/18/2025 4:43:09 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Smoke Detector - General | 4-258 646 | Building K Workroom K203 | Manual | 11/18/2025 4:43:27 PM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |
| Heat Detector - Restorable Spot | 2-001 697 | Recycle Building | Manual | 12/4/2025 9:24:50 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |

Mass Notification Control Panel

Passed

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|----------------|---------|-------------|--------|-----------|
|----------------|---------|-------------|--------|-----------|

| EQUIPMENT TYPE | ADDRESS | DESCRIPTION | METHOD | DATE/TIME |
|----------------------|---------|---|-----------------|----------------------|
| Primary Power Supply | | Building A Headend Rm A22C - FACP Batteries | Manual | 12/4/2025 9:26:28 AM |
| | | Visual inspection | Passed (Manual) | |
| | | Functional Inspection | Passed | |

Device/Equipment details

Alarm Notification Appliance

| ADDRESS | DESCRIPTION | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
|---------------------|---------------------------------|--------------|-------|--------|--------------|
| Audible | | | | | |
| 114 | Building A North Exterior | | | | |
| 115 | Building A East Exterior | | | | |
| 116 | Building A South Exterior | | | | |
| 160 | Building A Southeast Exterior | | | | |
| 221 | Building B East Exterior | | | | |
| 222 | Building B South Exterior | | | | |
| 223 | Building B West Exterior | | | | |
| 261 | Building C East Exterior | | | | |
| 262 | Building C East Exterior | | | | |
| 263 | Building C West Exterior | | | | |
| 363 | Building D East Exterior | | | | |
| 364 | Building D East Exterior | | | | |
| 365 | Building D West Exterior | | | | |
| 366 | Building D West Exterior | | | | |
| 432 | Building F South Exterior | | | | |
| 433 | Building F South Exterior | | | | |
| 442 | Building G South Exterior | | | | |
| 550 | Building H - PAC North Exterior | | | | |
| 551 | Building H - PAC South Exterior | | | | |
| 552 | Building H - PAC West Exterior | | | | |
| 588 | Building I North Exterior | | | | |
| 613 | Building J North Exterior | | | | |
| 614 | Building J East Exterior | | | | |
| 615 | Building J South Exterior | | | | |
| 616 | Building J West Exterior | | | | |
| 674 | Building K East Exterior | | | | |
| 675 | Building K South Exterior | | | | |
| Audible And Visible | | | | | |
| 117 | Building A Main Lobby | | | | |
| 118 | Building A Main Lobby | | | | |
| 119 | Building A Kitchen A1C | | | | |
| 120 | Building A Music Room A2 | | | | |
| 121 | Building A Practice Rm Hall A2A | | | | |
| 122 | Building A Student Gov Rm A3 | | | | |
| 123 | Building A Preschool Rm A4 | | | | |
| 124 | Building A Room A5 | | | | |
| 125 | Building A Room A6 | | | | |
| 126 | Building A Room A7 | | | | |
| 127 | Building A Room A8 | | | | |
| 128 | Building A Room A8 | | | | |
| 129 | Building A A9 Art Gallery | | | | |
| 130 | Building A Weight Room A10 | | | | |
| 131 | Building A Weight Room A10 | | | | |
| 132 | Building A Room A11 | | | | |
| 133 | Building A Room A12 | | | | |
| 134 | Building A Room A12 | | | | |
| 135 | Building A Room A14 | | | | |
| 136 | Building A Room A15 | | | | |

| ADDRESS | DESCRIPTION | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
|---------|--------------------------------|--------------|-------|--------|--------------|
| 137 | Building A Room A21 | | | | |
| 138 | Building A Room A22 | | | | |
| 139 | Building A Room A23 | | | | |
| 140 | Building A Confernce Rm A24 | | | | |
| 141 | Building A Counseling Hallway | | | | |
| 142 | Building A Corridor N by RRs | | | | |
| 143 | Building A Corridor North | | | | |
| 144 | Building A Corridor East | | | | |
| 145 | Building A Corridor Southeast | | | | |
| 224 | Building B Large Gym B1 | | | | |
| 225 | Building B Large Gym B1 | | | | |
| 226 | Building B Large Gym B1 | | | | |
| 227 | Building B Large Gym B1 | | | | |
| 228 | Building B Lrg Gym Frnt Ent B1 | | | | |
| 229 | Building B Lrg Gym Frnt Ent B1 | | | | |
| 230 | Building B Boys Locker Room | | | | |
| 231 | Building B Boys Locker Room | | | | |
| 232 | Building B Boys Locker Room | | | | |
| 233 | Building B Girls Locker Room | | | | |
| 234 | Building B Girls Locker Room | | | | |
| 264 | Building C Room C1 | | | | |
| 265 | Building C Room C1 | | | | |
| 266 | Building C Room C2 | | | | |
| 267 | Building C Room C3 | | | | |
| 367 | Building D North Hallway | | | | |
| 368 | Building D North Hallway | | | | |
| 369 | Building D East Corridor | | | | |
| 370 | Building D East Corridor | | | | |
| 371 | Building D South Corridor | | | | |
| 372 | Building D West Corridor | | | | |
| 373 | Building D Classroom D1 | | | | |
| 374 | Building D Classroom D2 | | | | |
| 375 | Building D Classroom D3 | | | | |
| 376 | Building D Classroom D4 | | | | |
| 377 | Building D Classroom D9 | | | | |
| 378 | Building D Classroom D10 | | | | |
| 379 | Building D Classroom D11 | | | | |
| 380 | Building D Classroom D12 | | | | |
| 381 | Building D Classroom D13 | | | | |
| 382 | Building D Classroom D14 | | | | |
| 383 | Building D Classroom D15 | | | | |
| 384 | Building D Classroom D19 | | | | |
| 385 | Building D Computer Lab D20 | | | | |
| 386 | Building D Classroom D21 | | | | |
| 387 | Building D Computer Lab 22 | | | | |
| 388 | Building D Classroom D23 | | | | |
| 389 | Building D Computer Lab D24 | | | | |
| 390 | Building D Classroom D25 | | | | |
| 391 | Building D Classroom D28 | | | | |
| 392 | Building D Classroom D30 | | | | |
| 393 | Building D Staff Room D31 | | | | |
| 394 | Building D Classroom D32 | | | | |

| ADDRESS | DESCRIPTION | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
|---------|-------------------------------------|--------------|-------|--------|--------------|
| 395 | Building D Classroom D36 | | | | |
| 434 | Building F Room F1 | | | | |
| 435 | Building F Room F2 | | | | |
| 436 | Building F Room F3 | | | | |
| 437 | Building F Room F4 | | | | |
| 443 | Building G Room G1 | | | | |
| 553 | Building H - PAC Up Stairs Lobby H2 | | | | |
| 554 | Building H - PAC Seating H3 | | | | |
| 555 | Building H - PAC Seating H3 | | | | |
| 556 | Building H - PAC Seating H3 | | | | |
| 557 | Building H - PAC Seating H3 | | | | |
| 558 | Building H - PAC Seating Entry H4 | | | | |
| 559 | Building H - PAC Stage H5 | | | | |
| 560 | Building H - PAC Stage H5 | | | | |
| 561 | Building H - PAC Hall H6 | | | | |
| 562 | Building H - PAC Loading Area H8 | | | | |
| 563 | Building H - PAC Kitchen H10 | | | | |
| 564 | Building H - PAC Food Services H11A | | | | |
| 565 | Building H - PAC N Chair Storage | | | | |
| 566 | Building H - PAC S Chair Storage | | | | |
| 589 | Building I Room i-1 | | | | |
| 617 | Building J Small Gym J1 | | | | |
| 618 | Building J Small Gym J1 | | | | |
| 676 | Building K Classroom 1 K101 | | | | |
| 677 | Building K Classroom 2 K102 | | | | |
| 678 | Building K Classroom 3 K301 | | | | |
| 679 | Building K Classroom 4 K302 | | | | |
| 680 | Building K Library K202 | | | | |
| 681 | Building K Library K202 | | | | |
| 682 | Building K Workroom K203 | | | | |
| 683 | Building K Workroom K203 | | | | |
| 684 | Building K 1st Floor Hallway | | | | |
| 685 | Building K 1st Floor Hallway | | | | |
| 686 | Building K 3rd Floor Hallway | | | | |
| 687 | Building K 3rd Floor Hallway | | | | |
| Visible | | | | | |
| 146 | Building A Admin Finance Office | | | | |
| 147 | Building A Practice Room A2A1 | | | | |
| 148 | Building A Practice Room A2A2 | | | | |
| 149 | Building A Practice Room A2A3 | | | | |
| 150 | Building A Practice Room A2A4 | | | | |
| 151 | Building A Principal Secret A13 | | | | |
| 152 | Building A Room A14A Storage | | | | |
| 153 | Building A Room A14B Storage | | | | |
| 154 | Building A Room A15 Storage | | | | |
| 155 | Building A Girls Restroom A16 | | | | |
| 156 | Building A Boys Restroom A17 | | | | |
| 157 | Building A Staff Restroom A18 | | | | |
| 158 | Building A Staff Restroom A19 | | | | |
| 159 | Building A Principals Office A25 | | | | |

| ADDRESS | DESCRIPTION | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
|---------|---|--------------|-------|--------|--------------|
| 235 | Building B Restroom B1B | | | | |
| 236 | Building B Restroom B1C | | | | |
| 237 | Building B Boys Equip Rm B3A | | | | |
| 238 | Building B Boys Coach Off B3D | | | | |
| 239 | Building B Girls Coach Off B3D | | | | |
| 240 | Building B Boys Locker Hallway | | | | |
| 241 | Building B Boys Coach Shower | | | | |
| 242 | Building B Boys Locker Room | | | | |
| 243 | Building B Girls Locker Hallway | | | | |
| 244 | Building B Girls Equip Rm B8 | | | | |
| 245 | Building B Girls Coach Shower | | | | |
| 246 | Building B Girls Locker Room | | | | |
| 396 | Building D South Corridor | | | | |
| 397 | Building D South Corridor | | | | |
| 398 | Building D West Corridor | | | | |
| 399 | Building D Lab D5 | | | | |
| 400 | Building D Lab D6 | | | | |
| 401 | Building D Lab D7 | | | | |
| 402 | Building D Lab D8 | | | | |
| 403 | Building D Student Store D16 | | | | |
| 404 | Building D Storage/Office D26 | | | | |
| 405 | Building D Restroom D27 | | | | |
| 406 | Building D Restroom D27 | | | | |
| 407 | Building D Restroom D29 | | | | |
| 408 | Building D Restroom D29 | | | | |
| 409 | Building D Staff Restroom D31B | | | | |
| 410 | Building D Staff Restroom D31C | | | | |
| 411 | Building D Classroom D36 | | | | |
| 412 | Building D Classroom D36 | | | | |
| 567 | Building H - PAC Up Stairs Entry H1 | | | | |
| 568 | Building H - PAC Up Stairs Lobby H2 | | | | |
| 569 | Building H - PAC Up Stairs Lobby H2 | | | | |
| 570 | Building H - PAC Seating H3 | | | | |
| 571 | Building H - PAC Seating Restrm H4A | | | | |
| 572 | Building H - PAC Seating Restrm H4A | | | | |
| 573 | Building H - PAC Seating Restrm H4B | | | | |
| 574 | Building H - PAC Seating Restrm H4B | | | | |
| 575 | Building H - PAC Dressing Rm Hall H6 | | | | |
| 576 | Building H - PAC Restroom H6A | | | | |
| 577 | Building H - PAC Dressing Room H6B | | | | |
| 578 | Building H - PAC Restroom H6C | | | | |
| 579 | Building H - PAC Kitchen H10 | | | | |
| 580 | Building H - PAC Seating Exit H11 | | | | |
| 590 | Building I i-1A Restroom | | | | |
| 619 | Building J Small Gym J1 | | | | |
| 620 | Building J Small Gym J1 | | | | |
| 621 | Building J Room J3 Girls RR | | | | |
| 622 | Building J Room J4 Boys RR | | | | |

| ADDRESS | DESCRIPTION | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
|---------|--------------------------------|--------------|-------|--------|--------------|
| 688 | Building K Stairwell K105 | | | | |
| 689 | Building K Boys Restroom K106 | | | | |
| 690 | Building K Girls Restroom K108 | | | | |
| 691 | Building K Library K202 | | | | |
| 692 | Building K Library K202 | | | | |
| 693 | Building K Staff RR K203A | | | | |
| 694 | Building K Boys Restroom K304 | | | | |
| 695 | Building K Girls Restroom K306 | | | | |

Fire Control Panel

| ADDRESS | DESCRIPTION | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
|--------------------------|--|--------------|-------|--------|--------------|
| NAC Power Extender Panel | | | | | |
| 161 | Building A Headend Rm A22C - PE "Master" | | | | |
| 162 | Building A Headend Rm A22C - B | | | | |
| 163 | Building A Headend Rm A22C - C | | | | 04/06/2018 |
| 164 | Building A Headend Rm A22C - E | | | | |
| 247 | Building B Lrg Gym Storage B2B - F | | | | |
| 248 | Building B Lrg Gym Storage B2B - G | | | | |
| 413 | Building D Room D31A - K | | | | 04/06/2018 |
| 414 | Building D Room D31A - L | | | | 01/06/2016 |
| 415 | Building D Room D31A - N | | | | 12/12/2016 |
| 444 | Building G Room G1 - V | | | | 06/06/2015 |
| 581 | Building H - PAC Room H5A - P | | | | 06/16/2016 |
| 582 | Building H - PAC Room H5A - R | | | | 06/06/2016 |
| 623 | Building J Room J2 Custodial - W | | | | 08/06/2013 |
| 696 | Building K Data Room K205 | | | | |

Remote Annunciator

| | | | | | |
|-----|---------------------------------|--|--|--|--|
| 001 | Building A Principal Secret A13 | | | | |
|-----|---------------------------------|--|--|--|--|

Fire Alarm Panel

| | | | | | |
|--|-----------------------------------|----------|----------|--|------------|
| | Building A Headend Rm A22C - FACP | Notifier | NFS-3030 | | 03/06/2019 |
|--|-----------------------------------|----------|----------|--|------------|

Initiating Device

| ADDRESS | DESCRIPTION | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
|--------------------------|---------------------------------|--------------|-------|--------|--------------|
| Smoke Detector - General | | | | | |
| 2-084 051 | Building A Weight Rm Off A10A | | | | |
| 2-075 052 | Building A Room A11 | | | | |
| 2-076 053 | Building A Room A11 | | | | |
| 2-078 054 | Building A Room A11 | | | | |
| 2-077 055 | Building A Room A11 | | | | |
| 2-073 056 | Building A Room A12 | | | | |
| 2-071 057 | Building A Room A12 | | | | |
| 2-064 058 | Building A Principal Secret A13 | | | | |
| 2-061 059 | Building A Room A14 | | | | |
| 2-059 060 | Building A Room A14 | | | | |
| 2-060 061 | Building A Room A14 | | | | |
| 2-058 062 | Building A Room A14 | | | | |

| ADDRESS | DESCRIPTION | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
|--------------|----------------------------------|--------------|-------|--------|--------------|
| 2-063 063 | Building A Room A14A Storage | | | | |
| 2-062 064 | Building A Room A14B Storage | | | | |
| 2-015 065 | Building A Girls Restroom A16 | | | | |
| 2-016 066 | Building A Boys Restroom A17 | | | | |
| 2-019 067 | Building A Staff Restroom A18 | | | | |
| 2-020 068 | Building A Staff Restroom A19 | | | | |
| 2-018 069 | Building A Electrical Rm A20 | | | | |
| 2-017 070 | Building A Custodial Rm A20A | | | | |
| 2-012 071 | Building A Room A21 | | | | |
| 2-010 072 | Building A Room A22 | | | | |
| 2-009 073 | Building A Storage Room A22A | | | | |
| 2-008 074 | Building A Storage Room A22B | | | | |
| 2-007 075 | Building A Headend Rm A22C | | | | |
| 2-067 076 | Building A Room A23 | | | | |
| 2-069 077 | Building A Room A23 | | | | |
| 2-066 078 | Building A Confernce Rm A24 | | | | |
| 2-065 079 | Building A Principals Office A25 | | | | |
| 2-036 080 | Building A Counselors Off A27 | | | | |
| 2-088 081 | Building A Counseling Hallway | | | | |
| 2-099 082 | Building A Corridor North | | | | |
| 2-098 083 | Building A Corridor Northeast | | | | |
| 2-094 084 | Building A Corridor Southeast | | | | |
| 2-093 085 | Building A Corridor Southeast | | | | |
| 2-092 086 | Building A Corridor Southeast | | | | |
| 2-097 087 | Building A Corridor East | | | | |
| 2-281 168 | Building B Large Gym B1 | | | | |
| 2-282 169 | Building B Large Gym B1 | | | | |
| 2-283 170 | Building B Large Gym B1 | | | | |
| 2-284 171 | Building B Large Gym B1 | | | | |
| 2-280 172 | Building B Large Gym B1 | | | | |
| 2-279 173 | Building B Large Gym B1 | | | | |
| 2-278 174 | Building B Large Gym B1 | | | | |
| 2-277 175 | Building B Large Gym B1 | | | | |
| 2-273 176 | Building B Large Gym B1 | | | | |
| 2-274 177 | Building B Large Gym B1 | | | | |
| 2-275 178 | Building B Large Gym B1 | | | | |
| 2-276 179 | Building B Large Gym B1 | | | | |

| ADDRESS | DESCRIPTION | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
|--------------|--------------------------------|--------------|-------|--------|--------------|
| 2-272 180 | Building B Large Gym B1 | | | | |
| 2-271 181 | Building B Large Gym B1 | | | | |
| 2-270 182 | Building B Large Gym B1 | | | | |
| 2-269 183 | Building B Large Gym B1 | | | | |
| 2-265 184 | Building B Large Gym B1 | | | | |
| 2-266 185 | Building B Large Gym B1 | | | | |
| 2-267 186 | Building B Large Gym B1 | | | | |
| 2-268 187 | Building B Large Gym B1 | | | | |
| 2-264 188 | Building B Large Gym B1 | | | | |
| 2-263 189 | Building B Large Gym B1 | | | | |
| 2-262 190 | Building B Large Gym B1 | | | | |
| 2-261 191 | Building B Large Gym B1 | | | | |
| 2-256 192 | Building B Lrg Gym Frnt Ent B1 | | | | |
| 2-255 193 | Building B Lrg Gym Frnt Ent B1 | | | | |
| 2-258 194 | Building B Restroom B1B | | | | |
| 2-257 195 | Building B Restroom B1C | | | | |
| 2-252 196 | Building B Lg Gym Up Strg B2 | | | | |
| 2-259 197 | Building B Lg Gym Clst Up B2A | | | | |
| 2-260 198 | Building B Lrg Gym Closet B2A | | | | |
| 2-251 199 | Building B Lrg Gym Storage B2B | | | | |
| 2-291 200 | Building B Boys Coach Off B3D | | | | |
| 2-288 201 | Building B Girls Coach Off B3D | | | | |
| 2-307 249 | Building C Room C1 | | | | |
| 2-306 250 | Building C Room C1 | | | | |
| 2-304 251 | Building C Room C1 | | | | |
| 2-305 252 | Building C Room C1 | | | | |
| 2-303 253 | Building C Room C2 | | | | |
| 2-302 254 | Building C Room C2 | | | | |
| 2-301 255 | Building C Room C3 | | | | |
| 2-300 256 | Building C Room C3 | | | | |
| 3-013 269 | Building D South Corridor | | | | |
| 3-032 270 | Building D East Corridor | | | | |
| 3-031 271 | Building D East Corridor | | | | |
| 3-030 272 | Building D East Corridor | | | | |
| 3-029 273 | Building D East Corridor | | | | |
| 3-028 274 | Building D East Foyer | | | | |
| 3-027 275 | Building D North Hallway | | | | |

| ADDRESS | DESCRIPTION | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
|--------------|---------------------------|--------------|-------|--------|--------------|
| 3-026 276 | Building D North Hallway | | | | |
| 3-025 277 | Building D North Hallway | | | | |
| 3-024 278 | Building D West Foyer | | | | |
| 3-023 279 | Building D West Corridor | | | | |
| 3-022 280 | Building D West Corridor | | | | |
| 3-021 281 | Building D West Corridor | | | | |
| 3-020 282 | Building D West Corridor | | | | |
| 3-019 283 | Building D South Corridor | | | | |
| 3-018 284 | Building D South Corridor | | | | |
| 3-017 285 | Building D South Corridor | | | | |
| 3-016 286 | Building D South Hallway | | | | |
| 3-015 287 | Building D South Corridor | | | | |
| 3-014 288 | Building D South Corridor | | | | |
| 3-002 289 | Building D Classroom D1 | | | | |
| 3-001 290 | Building D Classroom D1 | | | | |
| 3-005 291 | Building D Classroom D2 | | | | |
| 3-004 292 | Building D Classroom D2 | | | | |
| 3-008 293 | Building D Classroom D3 | | | | |
| 3-007 294 | Building D Classroom D3 | | | | |
| 3-011 295 | Building D Classroom D4 | | | | |
| 3-010 296 | Building D Classroom D4 | | | | |
| 3-003 297 | Building D Lab D5 | | | | |
| 3-006 298 | Building D Lab D6 | | | | |
| 3-009 299 | Building D Lab D7 | | | | |
| 3-012 300 | Building D Lab D8 | | | | |
| 3-040 301 | Building D Classroom D9 | | | | |
| 3-039 302 | Building D Classroom D9 | | | | |
| 3-064 303 | Building D Classroom D10 | | | | |
| 3-063 304 | Building D Classroom D10 | | | | |
| 3-038 305 | Building D Classroom D11 | | | | |
| 3-037 306 | Building D Classroom D11 | | | | |
| 3-061 307 | Building D Classroom D12 | | | | |
| 3-062 308 | Building D Classroom D12 | | | | |
| 3-036 309 | Building D Classroom D13 | | | | |
| 3-035 310 | Building D Classroom D13 | | | | |
| 3-059 311 | Building D Classroom D14 | | | | |
| 3-060 312 | Building D Classroom D14 | | | | |

| ADDRESS | DESCRIPTION | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
|--------------|--------------------------------|--------------|-------|--------|--------------|
| 3-033 313 | Building D Classroom D15 | | | | |
| 3-034 314 | Building D Classroom D15 | | | | |
| 3-051 315 | Building D Student Store D16 | | | | |
| 3-049 316 | Building D Janitor Closet D16 | | | | |
| 3-050 317 | Building D Electrical Room D16 | | | | |
| 3-042 318 | Building D Classroom D19 | | | | |
| 3-041 319 | Building D Classroom D19 | | | | |
| 3-052 320 | Building D Computer Lab D20 | | | | |
| 3-053 321 | Building D Computer Lab D20 | | | | |
| 3-043 322 | Building D Classroom D21 | | | | |
| 3-044 323 | Building D Classroom D21 | | | | |
| 3-055 324 | Building D Computer Lab D22 | | | | |
| 3-054 325 | Building D Computer Lab D22 | | | | |
| 3-046 326 | Building D Classroom D23 | | | | |
| 3-045 327 | Building D Classroom D23 | | | | |
| 3-056 328 | Building D Computer Lab D24 | | | | |
| 3-057 329 | Building D Computer Lab D24 | | | | |
| 3-048 330 | Building D Classroom D25 | | | | |
| 3-047 331 | Building D Classroom D25 | | | | |
| 3-058 332 | Building D Storage/Office D26 | | | | |
| 3-078 333 | Building D Restroom D27 | | | | |
| 3-073 334 | Building D Classroom D28 | | | | |
| 3-072 335 | Building D Classroom D28 | | | | |
| 3-079 336 | Building D Restroom D29 | | | | |
| 3-075 337 | Building D Classroom D30 | | | | |
| 3-074 338 | Building D Classroom D30 | | | | |
| 2-102 339 | Building D IDF Staff Rm D31A | | | | |
| 3-080 340 | Building D Staff Restroom D31B | | | | |
| 3-081 341 | Building D Staff Restroom D31C | | | | |
| 3-077 342 | Building D Classroom D32 | | | | |
| 3-076 343 | Building D Classroom D32 | | | | |
| 3-070 344 | Building D Storage Room D34 | | | | |
| 3-069 345 | Building D Storage Room D35 | | | | |
| 3-067 346 | Building D Classroom D36 | | | | |
| 3-066 347 | Building D Classroom D36 | | | | |
| 3-065 348 | Building D Classroom D36 | | | | |
| 3-068 349 | Building D Room D36A Storage | | | | |

| ADDRESS | DESCRIPTION | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
|--------------|--|--------------|-------|--------|--------------|
| 3-071 350 | Building D Electrical Room D38 | | | | |
| 2-299 416 | Building F Room F1 | | | | |
| 2-298 417 | Building F Room F1 | | | | |
| 2-308 418 | Building F Room F1 Closet | | | | |
| 2-310 419 | Building F Room F2 | | | | |
| 2-309 420 | Building F Room F2 | | | | |
| 2-311 421 | Building F Room F2 Closet | | | | |
| 2-312 422 | Building F Room F3 | | | | |
| 2-313 423 | Building F Room F3 | | | | |
| 2-314 424 | Building F Room F3 Closet | | | | |
| 2-316 425 | Building F Room F4 | | | | |
| 2-315 426 | Building F Room F4 | | | | |
| 2-317 427 | Building F Room F4 Closet | | | | |
| 2-296 438 | Building G Room G1 | | | | |
| 2-295 439 | Building G Room G1A | | | | |
| 2-297 440 | Building G Room G1 Closet | | | | |
| 3-321 449 | Building H - PAC Up Stairs Entry H1 | | | | |
| 3-315 450 | Building H - PAC Up Stairs Lobby H2 | | | | |
| 3-316 451 | Building H - PAC Up Stairs Lobby H2 | | | | |
| 3-317 452 | Building H - PAC Up Stairs Lobby H2 | | | | |
| 3-319 453 | Building H - PAC Up Stairs Lobby H2 | | | | |
| 3-318 454 | Building H - PAC Up Stairs Lobby H2 | | | | |
| 3-320 455 | Building H - PAC Up Stairs Lobby H2 | | | | |
| 3-322 456 | Building H - PAC Up Stairs Room H2A | | | | |
| 3-323 457 | Building H - PAC Up Stairs Rm H2A1 | | | | |
| 3-275 458 | Building H - PAC Seating H3 | | | | |
| 3-276 459 | Building H - PAC Seating H3 | | | | |
| 3-277 460 | Building H - PAC Seating H3 | | | | |
| 3-278 461 | Building H - PAC Seating H3 | | | | |
| 3-279 462 | Building H - PAC Seating H3 | | | | |
| 3-280 463 | Building H - PAC Seating H3 | | | | |
| 3-281 464 | Building H - PAC Seating H3 | | | | |
| 3-282 465 | Building H - PAC Seating H3 | | | | |
| 3-283 466 | Building H - PAC Seating H3 | | | | |
| 3-284 467 | Building H - PAC Seating H3 | | | | |
| 3-285 468 | Building H - PAC Seating H3 | | | | |
| 3-286 469 | Building H - PAC Seating H3 | | | | |

| ADDRESS | DESCRIPTION | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
|--------------|---|--------------|-------|--------|--------------|
| 3-287 470 | Building H - PAC Seating H3 | | | | |
| 3-288 471 | Building H - PAC Seating H3 | | | | |
| 3-289 472 | Building H - PAC Seating H3 | | | | |
| 3-290 473 | Building H - PAC Seating H3 | | | | |
| 3-291 474 | Building H - PAC Seating H3 | | | | |
| 3-292 475 | Building H - PAC Seating H3 | | | | |
| 3-293 476 | Building H - PAC Seating H3 | | | | |
| 3-294 477 | Building H - PAC Seating H3 | | | | |
| 3-295 478 | Building H - PAC Seating H3 | | | | |
| 3-296 479 | Building H - PAC Seating H3 | | | | |
| 3-297 480 | Building H - PAC Seating H3 | | | | |
| 3-298 481 | Building H - PAC Seating H3 | | | | |
| 3-299 482 | Building H - PAC Seating H3 | | | | |
| 3-300 483 | Building H - PAC Seating H3 | | | | |
| 3-301 484 | Building H - PAC Seating H3 | | | | |
| 3-302 485 | Building H - PAC Seating H3 | | | | |
| 3-335 486 | Building H - PAC North Hall H12 | | | | |
| 3-307 487 | Building H - PAC Seating Entry H4 | | | | |
| 3-304 488 | Building H - PAC Seating Resrm H4A | | | | |
| 3-305 489 | Building H - PAC Seating Restrsm H4A | | | | |
| 3-303 490 | Building H - PAC Seating Restrsm H4B | | | | |
| 3-306 491 | Building H - PAC Seating Restrsm H4B | | | | |
| 3-338 492 | Building H - PAC Stage H5 | | | | |
| 3-271 493 | Building H - PAC Stage H5 | | | | |
| 3-270 494 | Building H - PAC Stage H5 | | | | |
| 3-269 495 | Building H - PAC Stage H5 | | | | |
| 3-339 496 | Building H - PAC Stage H5 | | | | |
| 3-340 497 | Building H - PAC Stage H5 | | | | |
| 3-341 498 | Building H - PAC Stage H5 | | | | |
| 3-342 499 | Building H - PAC Stage H5 | | | | |
| 3-252 500 | Building H - PAC N Storage H5 | | | | |
| 3-251 501 | Building H - PAC N Storage H5A | | | | |
| 3-253 502 | Building H - PAC N Camera Rm H5A1 | | | | |
| 3-272 503 | Building H - PAC S Storage H5B | | | | |
| 3-274 504 | Building H - PAC S Storage H5B | | | | |
| 3-273 505 | Building H - PAC S Camera Rm H5B1 | | | | |
| 3-264 506 | Building H - PAC Hall H6 | | | | |

| ADDRESS | DESCRIPTION | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
|--------------|---|--------------|-------|--------|--------------|
| 3-266 507 | Building H - PAC Dressing Rm Hall H6 | | | | |
| 3-267 508 | Building H - PAC Restroom H6A | | | | |
| 3-265 509 | Building H - PAC Dressing Room H6B | | | | |
| 3-268 510 | Building H - PAC Restroom H6C | | | | |
| 3-259 511 | Building H - PAC Loading Area H8 | | | | |
| 3-260 512 | Building H - PAC Loading Area H8 | | | | |
| 3-261 513 | Building H - PAC Loading Area H8 | | | | |
| 3-262 514 | Building H - PAC Loading Area H8 | | | | |
| 3-256 515 | Building H - PAC NW Office H8A | | | | |
| 3-254 516 | Building H - PAC NW Office H8B | | | | |
| 3-258 517 | Building H - PAC NW Storage H8C | | | | |
| 3-255 518 | Building H - PAC NW Office H9 | | | | |
| 3-312 519 | Building H - PAC Seating Exit H11 | | | | |
| 3-308 520 | Building H - PAC Riser Closet H11B | | | | |
| 3-334 521 | Building H - PAC N Hall H12 | | | | |
| 3-336 522 | Building H - PAC N Hall H12 | | | | |
| 3-337 523 | Building H - PAC N Storage H12A | | | | |
| 3-326 524 | Building H - PAC S Storage H12B4 | | | | |
| 3-321 525 | Building H - PAC Hall Chair Storage | | | | |
| 3-333 526 | Building H - PAC N Chair Storage | | | | |
| 3-327 527 | Building H - PAC S Chair Storage | | | | |
| 3-328 528 | Building H - PAC S Chair Storage | | | | |
| 3-329 529 | Building H - PAC Custodian Closet | | | | |
| 3-332 530 | Building H - PAC E Storage | | | | |
| 3-313 531 | Building H - PAC NE Stairs | | | | |
| 3-314 532 | Building H - PAC NE Stairs | | | | |
| 3-325 533 | Building H - PAC SE Stairs | | | | |
| 3-324 534 | Building H - PAC SE Stairs | | | | |
| 3-257 535 | Building H - PAC NW Hall | | | | |
| 2-005 583 | Building I Room i-1 | | | | |
| 2-003 584 | Building I Room i-1 | | | | |
| 2-002 585 | Building I Room i-1 | | | | |
| 2-006 586 | Building I i-1A Restroom | | | | |
| 2-004 587 | Building I Room i-1B Closet | | | | |
| 2-343 598 | Building J Room J1A Storage | | | | |
| 2-342 599 | Building J Room J1A Storage | | | | |
| 2-341 600 | Building J Room J2 Custodial | | | | |

| ADDRESS | DESCRIPTION | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
|--------------|--------------------------------|--------------|-------|--------|--------------|
| 2-340 601 | Building J Room J3 Girls RR | | | | |
| 2-339 602 | Building J Room J3 Girls RR | | | | |
| 2-338 603 | Building J Room J4 Boys RR | | | | |
| 2-337 604 | Building J Room J4 Boys RR | | | | |
| 2-336 605 | Building J Room J5 Elect Rm | | | | |
| 4-277 624 | Building K Classroom 1 K101 | | | | |
| 4-276 625 | Building K Classroom 1 K101 | | | | |
| 4-271 626 | Building K Classroom 2 K102 | | | | |
| 4-270 627 | Building K Classroom 2 K102 | | | | |
| 4-284 628 | Building K Classroom 3 K301 | | | | |
| 4-257 629 | Building K Classroom 3 K301 | | | | |
| 4-278 630 | Building K Classroom 4 K302 | | | | |
| 4-279 631 | Building K Classroom 5 K302 | | | | |
| 4-267 632 | Building K Data /Elect Rm K103 | | | | |
| 4-268 633 | Building K Elev Equip Rm K103A | | | | |
| 4-269 634 | Building K Lobby K104 | | | | |
| 4-266 635 | Building K Stairwell K105 | | | | |
| 4-272 636 | Building K Boys Restroom K106 | | | | |
| 4-273 637 | Building K Custodial Rm K107 | | | | |
| 4-274 638 | Building K Girls Restroom K108 | | | | |
| 4-275 639 | Building K Girls Restroom K108 | | | | |
| 4-262 640 | Building K Lobby K201 | | | | |
| 4-252 641 | Building K Library K202 | | | | |
| 4-253 642 | Building K Library K202 | | | | |
| 4-255 643 | Building K Library K202 | | | | |
| 4-254 644 | Building K Library K202 | | | | |
| 4-256 645 | Building K Workroom K203 | | | | |
| 4-258 646 | Building K Workroom K203 | | | | |
| 4-261 647 | Building K Staff RR K203A | | | | |
| 4-260 648 | Building K Electrical Rm K204 | | | | |
| 4-259 649 | Building K Data Room K205 | | | | |
| 4-285 650 | Building K Fire Riser Rm K206 | | | | |
| 4-280 651 | Building K Boys Restroom K304 | | | | |
| 4-281 652 | Building K Custodial Rm K305 | | | | |
| 4-283 653 | Building K Girls Restroom K306 | | | | |
| 4-282 654 | Building K Girls Restroom K306 | | | | |
| 4-265 655 | Building K Lobby K308 | | | | |

| ADDRESS | DESCRIPTION | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
|--------------|---------------------------------|--------------|-------|--------|--------------|
| 2-049 004 | Building A Main Lobby NW | | | | |
| 2-048 005 | Building A Main Lobby NE | | | | |
| 2-050 006 | Building A Main Lobby SE | | | | |
| 2-051 007 | Building A Main Lobby SW | | | | |
| 2-045 008 | Building A Main Lobby Off A1A | | | | |
| 2-044 009 | Building A Main Lobby Off A1B | | | | |
| 2-040 010 | Building A Storage Room A1F | | | | |
| 2-037 011 | Building A Counselors Off A1G | | | | |
| 2-038 012 | Building A Counselors Off A1H | | | | |
| 2-039 013 | Building A Counselors Off A1i | | | | |
| 2-046 014 | Building A Main Lobby Off A1J | | | | |
| 2-047 015 | Building A Main Lobby Off A1K | | | | |
| 2-052 016 | Building A Main Lobby Clst A11 | | | | |
| 2-079 017 | Building A Admin Finance Office | | | | |
| 2-041 018 | Building A A2 Hallway | | | | |
| 2-032 019 | Building A Music Room A2 | | | | |
| 2-034 020 | Building A Music Room A2 | | | | |
| 2-035 021 | Building A Music Room A2 | | | | |
| 2-033 022 | Building A Music Room A2 | | | | |
| 2-027 023 | Building A Practice Rm Hall A2A | | | | |
| 2-030 024 | Building A Storage Room A2B | | | | |
| 2-026 025 | Building A Practice Room A2A1 | | | | |
| 2-025 026 | Building A Practice Room A2A2 | | | | |
| 2-029 027 | Building A Practice Room A2A3 | | | | |
| 2-028 028 | Building A Practice Room A2A4 | | | | |
| 2-023 029 | Building A Student Gov Rm A3 | | | | |
| 2-024 030 | Building A Student Gov Rm A3 | | | | |
| 2-022 031 | Building A Student Gov Rm A3 | | | | |
| 2-021 032 | Building A Student Gov Rm A3 | | | | |
| 2-096 033 | Building A Hallway by A3 | | | | |
| 2-013 034 | Building A Room A5 | | | | |
| 2-101 035 | Building A Rooms A5 A6 Entry | | | | |
| 2-011 036 | Building A Room A6 | | | | |
| 2-070 037 | Building A Room A7 | | | | |
| 2-068 038 | Building A Room A7 | | | | |
| 2-074 039 | Building A Room A8 | | | | |
| 2-072 040 | Building A Room A8 | | | | |

| ADDRESS | DESCRIPTION | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
|---------------------------------|----------------------------------|--------------|-------|--------|--------------|
| 2-083 041 | Building A A9 Art Gallery | | | | |
| 2-082 042 | Building A A9 Art Gallery | | | | |
| 2-080 043 | Building A A9 Art Gallery Closet | | | | |
| 2-081 044 | Building A A9 Art Gallery Closet | | | | |
| 2-089 045 | Building A Weight Room A10 | | | | |
| 2-090 046 | Building A Weight Room A10 | | | | |
| 2-091 047 | Building A Weight Room A10 | | | | |
| 2-087 048 | Building A Weight Room A10 | | | | |
| 2-086 049 | Building A Weight Room A10 | | | | |
| 2-085 050 | Building A Weight Room A10 | | | | |
| Heat Detector - Restorable Spot | | | | | |
| 2-042 088 | Building A Kitchen A1C | | | | |
| 2-043 089 | Building A Kitchen A1C | | | | |
| 2-031 090 | Building A Staff Breakroom A2D | | | | |
| 2-014 091 | Building A Preschool Rm A4 | | | | |
| 2-055 092 | Building A Room A15 | | | | |
| 2-056 093 | Building A Room A15 | | | | |
| 2-054 094 | Building A Room A15 | | | | |
| 2-053 095 | Building A Room A15 | | | | |
| 2-057 096 | Building A Room A15 Storage | | | | |
| 2-095 097 | Building A Kiln Storage Rm SW | | | | |
| 2-137 098 | Building A Attic Kiln | | | | |
| 2-254 202 | Building B Gym Food Sales B1A | | | | |
| 2-253 203 | Building B Gym Ticket Sale B1A1 | | | | |
| 2-293 204 | Building B Boys Locker Hallway | | | | |
| 2-294 205 | Building B Boys Locker Room | | | | |
| 2-290 206 | Building B Boys Coach Shower | | | | |
| 2-377 207 | Building B Boys Locker Room | | | | |
| 2-377 208 | Building B Boys Locker Room | | | | |
| 2-377 209 | Building B Boys Locker Room | | | | |
| 2-377 210 | Building B Boys Locker Room | | | | |
| 2-377 211 | Building B Boys Locker Room | | | | |
| 2-286 212 | Building B Girls Locker Hallway | | | | |
| 2-289 213 | Building B Girls Coach Shower | | | | |
| 2-287 214 | Building B Girls Locker Rm Strg | | | | |
| 2-285 215 | Building B Girls Equip Rm B8A | | | | |
| 2-376 216 | Building B Girls Locker Room | | | | |
| 2-376 217 | Building B Girls Locker Room | | | | |

| ADDRESS | DESCRIPTION | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
|--------------|--|--------------|-------|--------|--------------|
| 2-376 218 | Building B Girls Locker Room | | | | |
| 2-376 219 | Building B Girls Locker Room | | | | |
| 2-376 220 | Building B Girls Locker Room | | | | |
| 2-382 257 | Building C Attic Room C1 | | | | |
| 2-382 258 | Building C Attic Room C1 | | | | |
| 2-381 259 | Building C Attic Room C2 | | | | |
| 2-380 260 | Building C Attic Room C3 | | | | |
| 3-082 351 | Building D Staff Room D31 | | | | |
| 3-083 352 | Building D Basmnt Cust Off D37 | | | | |
| 3-084 353 | Building D Basmnt Cust Off D37 | | | | |
| 3-085 354 | Building D Basmnt Cust Off D37 | | | | |
| 2-399 428 | Building F Attic Room F1 | | | | |
| 2-400 429 | Building F Attic Room F2 | | | | |
| 2-401 430 | Building F Attic Room F3 | | | | |
| 2-402 431 | Building F Attic Room F4 | | | | |
| 2-398 441 | Building G Attic Room G1 | | | | |
| 3-263 536 | Building H - PAC HVAC Room H7 | | | | |
| 3-310 537 | Building H - PAC Kitchen H10 | | | | |
| 3-311 538 | Building H - PAC Kitchen H10 | | | | |
| 3-309 539 | Building H - PAC Food Services H11A | | | | |
| 3-330 540 | Building H - PAC E HVAC Rm H12B1 | | | | |
| 3-380 541 | Building H - PAC Filter Room H12B1 | | | | |
| 2-128 591 | Building I Attic Room i-1 | | | | |
| 2-128 592 | Building I Attic Room i-1 | | | | |
| 2-128 593 | Building I Attic Room i-1 | | | | |
| 2-129 594 | Building I Attic Room i-1 | | | | |
| 2-387 606 | Building J Attic Boys Restroom | | | | |
| 2-387 607 | Building J Attic Boys Restroom | | | | |
| 2-386 608 | Building J Attic Girls Restroom | | | | |
| 2-386 609 | Building J Attic Girls Restroom | | | | |
| 4-287 656 | Building K Elevator Rm K103A | | | | |
| 4-394 657 | Building K Attic Classrm 1 K101 | | | | |
| 4-394 658 | Building K Attic Classrm 1 K101 | | | | |
| 4-392 659 | Building K Attic Classrm 2 K102 | | | | |
| 4-392 660 | Building K Attic Classrm 2 K102 | | | | |
| 4-401 661 | Building K Attic Classrm 3 K301 | | | | |
| 4-401 662 | Building K Attic Classrm 3 K301 | | | | |

| ADDRESS | DESCRIPTION | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
|--|---------------------------------------|--------------|-------|--------|--------------|
| 4-396 663 | Building K Attic Classrm 4 K302 | | | | |
| 4-396 664 | Building K Attic Classrm 4 K302 | | | | |
| 4-376 665 | Building K Attic Library K202 | | | | |
| 4-376 666 | Building K Attic Library K202 | | | | |
| 4-377 667 | Building K Attic Library K203 | | | | |
| 4-377 668 | Building K Attic Library K203 | | | | |
| 4-397 669 | Building K Attic Cust K305 | | | | |
| 4-393 670 | Building K RR Chase K106/K108 | | | | |
| 2-001 697 | Recycle Building | | | | |
| Smoke Detector - Duct | | | | | |
| 2-138 099 | Building A MZ-9 Admin | | | | |
| 2-136 100 | Building A A2 Soffit | | | | |
| 2-140 101 | Building A A3 Soffit | | | | |
| 2-139 102 | Building A MZ-7 A2/A3 Hall | | | | |
| 2-126 103 | Building A MZ-11 Room A12 | | | | |
| 2-132 104 | Building A Room A14 | | | | |
| 2-134 105 | Building A Room A14 | | | | |
| 2-135 106 | Building A MZ-10 A14 | | | | |
| 2-127 107 | Building A Room A21 | | | | |
| 2-146 108 | Building A MZ-8 Room A21 | | | | |
| 2-141 109 | Building A North Hallway | | | | |
| 2-130 110 | Building A South Hallway | | | | |
| 2-131 111 | Building A South Hallway | | | | |
| 3-130 355 | Building D MZ-1 D So | | | | |
| 3-131 356 | Building D MZ-2 D So | | | | |
| 3-129 357 | Building D MZ-3 D No | | | | |
| 3-132 358 | Building D MZ-4 D30 | | | | |
| 3-128 359 | Building D MZ-5 D35 | | | | |
| 3-135 360 | Building D MZ-6 D45 | | | | |
| 3-378 542 | Building H - PAC HVAC Room H7 | | | | |
| 3-379 543 | Building H - PAC HVAC Room H7 | | | | |
| 3-381 544 | Building H - PAC Room H12B | | | | |
| 3-383 545 | Building H - PAC Room H12B North | | | | |
| 3-382 546 | Building H - PAC Room H12B South | | | | |
| Mechanical, Electrosonic, or Pressure Waterflow Device | | | | | |
| 2-148 112 | Building A Weight Room A10 | | | | |
| 3-133 361 | Building D Basmnt Cust Off D37 | | | | |
| 3-376 547 | Building H - PAC Riser Closet H11B | | | | |

| ADDRESS | DESCRIPTION | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
|---------------------------------|--|--------------|-------|--------|--------------|
| 4-402 671 | Building K Fire Riser Rm K206 | | | | |
| Valve Tamper Switch | | | | | |
| 2-149 113 | Building A Weight Room A10 | | | | |
| 3-377 548 | Building H - PAC Riser Closet H11B | | | | |
| 3-384 549 | Building H - PAC PIV | | | | |
| 4-403 672 | Building K Fire Riser Rm K206 | | | | |
| 4-404 673 | Building K PIV | | | | |
| Manual Pull Station | | | | | |
| 2-405 165 | Building B Large Gym Lobby | | | | |
| 2-407 166 | Building B Boys Locker Room | | | | |
| 2-406 167 | Building B Girls Locker Room | | | | |
| 2-144 268 | Building D Staff Room D31 | | | | |
| 3-390 445 | Building H - PAC Lower Northwest | | | | |
| 3-389 446 | Building H - PAC Lower Southwest | | | | |
| 3-387 447 | Building H - PAC Upper Northeast | | | | |
| 3-388 448 | Building H - PAC Upper Southeast | | | | |
| 2-396 595 | Building J Small Gym J1 NW | | | | |
| 2-395 596 | Building J Small Gym J1 NE | | | | |
| 2-397 597 | Building J Small Gym J1 SE | | | | |
| 2-145 002 | Building A Admin Office Rm A1 | | | | |
| 2-147 003 | Building A Secretary Office A13 | | | | |
| Smoke Detector - Projected Beam | | | | | |
| 2-388 610 | Building J Beam Left | | | | |
| 2-390 611 | Building J Beam Middle | | | | |
| 2-392 612 | Building J Beam East | | | | |
| Mass Notification Control Panel | | | | | |
| ADDRESS | DESCRIPTION | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
| Primary Power Supply | | | | | |
| | Building A Headend Rm A22C - FACP Batteries | | | | |