

# Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

LITTLE JOHN

6838 KERMIT LANE  
FAIR OAKS, California  
United States

This site has been inspected and tested in compliance with applicable standards.

Completed

Wednesday, February 11, 2026

Test Session:20 Nov 2025 14:37 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD  
5320 HEMLOCK ST  
SACRAMENTO, California  
United States

TESTED BY

Riley Goyet  
Western States Fire Protection-  
Sacramento  
188 Cirby Way  
Roseville, CA 95678  
United States



# Inspection Summary

## Building Information

PROPERTY	LITTLE JOHN	CONTACT
ADDRESS	6838 KERMIT LANE	PHONE
CITY/STATE	FAIR OAKS, California	MOBILE
COUNTRY	United States	EMAIL

## Inspector Information

COMPANY	Western States Fire Protection-Sacramento	CONTACT	Riley Goyet
ADDRESS	188 Cirby Way Roseville, CA 95678	LICENSE NUMBER	
COUNTRY	United States	PHONE	+1 916-200-9514
		EMAIL	riley.goyet@wsfp.us


## Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Alarm Notification Appliance	54	54(100%)	54(100%)	0(0%)
Fire Control Panel	4	4(100%)	4(100%)	0(0%)
Ventilation and Cooking Equipment	5	0(0%)	0(0%)	0(0%)
Initiating Device	208	206(99%)	206(99%)	0(0%)

## Certification

The equipment specified herein was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Wednesday, February 11, 2026

ACCEPTED BY      02/11/2026  
  
Building Representative

  
TESTED BY      02/11/2026  
Riley Goyet  
Technician

# System Details

## Control Units

ADDRESS/ SCAN ADDRESS		DESCRIPTION	Rooms 7-18 Bldg Elect MDF Room
MANUFACTURER	Edwards	S/W VERSION	
MODEL	EST-3	LAST UPDATE	
SERIAL NUMBER		S/W LOCATION	
INSTALL DATE			

# Testing Details

## Alarm Notification Appliance

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible		Admin Building Copy Room	Manual	11/20/2025 6:09:34 PM
		Visual inspection	Passed (Manual)	
Visible		Functional Inspection	Passed	
		Admin Building Deans Office	Manual	11/20/2025 6:09:40 PM
Visible		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Admin Building Elect Storage IDF	Manual	11/20/2025 6:09:38 PM
		Visual inspection	Passed (Manual)	
Audible And Visible		Functional Inspection	Passed	
		Admin Building Front Office	Manual	11/20/2025 6:09:32 PM
Visible		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Admin Building Office Restroom	Manual	11/20/2025 6:09:35 PM
		Visual inspection	Passed (Manual)	
Visible		Functional Inspection	Passed	
		Admin Building Principal Office	Manual	11/20/2025 6:09:37 PM
Audible		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Admin Building South Exterior	Manual	11/20/2025 6:09:22 PM
		Visual inspection	Passed (Manual)	
Visible		Functional Inspection	Passed	
		Kindergarten Bldg ADA RR by K1 K2	Manual	11/20/2025 6:11:02 PM
Visible		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Kindergarten Bldg K1 Restroom	Manual	11/20/2025 6:10:48 PM
		Visual inspection	Passed (Manual)	
Visible		Functional Inspection	Passed	
		Kindergarten Bldg K1 Restroom	Manual	11/20/2025 6:10:50 PM
Visible		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Kindergarten Bldg K2 Restroom	Manual	11/20/2025 6:11:03 PM
		Visual inspection	Passed (Manual)	
Visible		Functional Inspection	Passed	
		Kindergarten Bldg K2 Restroom	Manual	11/20/2025 6:11:05 PM
Audible And Visible		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Kindergarten Bldg Kindergarten 1	Manual	11/20/2025 6:10:44 PM
		Visual inspection	Passed (Manual)	
Audible And Visible		Functional Inspection	Passed	
		Kindergarten Bldg Kindergarten 2	Manual	11/20/2025 6:10:46 PM
Audible		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Kindergarten Bldg North Exterior	Manual	11/20/2025 6:10:41 PM
		Visual inspection	Passed (Manual)	
Audible		Functional Inspection	Passed	
		Kindergarten Bldg South Exterior	Manual	11/20/2025 6:10:43 PM
Audible And Visible		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Library Bldg Library	Manual	11/20/2025 6:11:07 PM
		Visual inspection	Passed (Manual)	
Audible And Visible		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Library Bldg Library Office	Manual	11/20/2025 6:11:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Library Bldg Outside Staff RR	Manual	11/20/2025 6:11:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Library Bldg Outside Womens RR	Manual	11/20/2025 6:11:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Multi-Purpose Bldg East Exterior	Manual	11/20/2025 6:11:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Multi-Purpose Bldg Kitchen	Manual	11/20/2025 6:11:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Multi-Purpose Bldg Kitchen RR Sink Area	Manual	11/20/2025 6:11:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Multi-Purpose Bldg Kitchen RR Toilet	Manual	11/20/2025 6:11:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Multi-Purpose Bldg MP Room	Manual	11/20/2025 6:11:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Multi-Purpose Bldg MP Room	Manual	11/20/2025 6:11:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Multi-Purpose Bldg Stage	Manual	11/20/2025 6:11:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Multi-Purpose Bldg West Exterior	Manual	11/20/2025 6:11:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Portable Classroom 19	Manual	11/20/2025 6:10:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Rooms 1-6 Bldg Boys Restroom	Manual	11/20/2025 6:10:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 1-6 Bldg Classroom 1	Manual	11/20/2025 6:09:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 1-6 Bldg Classroom 2	Manual	11/20/2025 6:09:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 1-6 Bldg Classroom 3	Manual	11/20/2025 6:09:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 1-6 Bldg Classroom 4	Manual	11/20/2025 6:09:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 1-6 Bldg Classroom 5	Manual	11/20/2025 6:09:54 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Audible And Visible		Rooms 1-6 Bldg Classroom 6	Manual	11/20/2025 6:09:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Rooms 1-6 Bldg Girls Restroom	Manual	11/20/2025 6:09:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Rooms 7-18 Bldg Boys RR by Rm 13	Manual	11/20/2025 6:10:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 7-18 Bldg Classroom 10	Manual	11/20/2025 6:10:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 7-18 Bldg Classroom 11	Manual	11/20/2025 6:10:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 7-18 Bldg Classroom 12	Manual	11/20/2025 6:10:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 7-18 Bldg Classroom 13	Manual	11/20/2025 6:10:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 7-18 Bldg Classroom 14	Manual	11/20/2025 6:10:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 7-18 Bldg Classroom 15	Manual	11/20/2025 6:10:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 7-18 Bldg Classroom 16	Manual	11/20/2025 6:10:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 7-18 Bldg Classroom 17	Manual	11/20/2025 6:10:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 7-18 Bldg Classroom 18	Manual	11/20/2025 6:10:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 7-18 Bldg Classroom 7	Manual	11/20/2025 6:10:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 7-18 Bldg Classroom 8	Manual	11/20/2025 6:10:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible		Rooms 7-18 Bldg Classroom 9	Manual	11/20/2025 6:10:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible		Rooms 7-18 Bldg East Exterior	Manual	11/20/2025 6:10:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Rooms 7-18 Bldg Girls Restroom	Manual	11/20/2025 6:10:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible		Rooms 7-18 Bldg Teachers Lounge	Manual	11/20/2025 6:10:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible		Rooms 7-18 Bldg West Exterior	Manual	11/20/2025 6:10:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

### Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Remote Annunciator		Admin Building Front Office	Manual	11/20/2025 6:09:20 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Fire Alarm Panel		Rooms 7-18 Bldg Elect MDF Room	Manual	11/20/2025 6:09:15 PM
		Manufacturer	Edwards	
		Model	EST-3	
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Rooms 7-18 Bldg Elect MDF Room	Manual	11/20/2025 6:09:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
NAC Power Extender Panel		Rooms 7-18 Bldg Elect MDF Room	Manual	11/20/2025 6:09:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

### Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-316 007	Admin Building Copy Room	Manual	11/20/2025 5:55:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-317 008	Admin Building Copy Room	Manual	11/20/2025 6:03:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-315 016	Admin Building Elec Rm	Manual	11/20/2025 5:59:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-325 013	Admin Building Elect Storage IDF	Manual	11/20/2025 6:03:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-387 002	Admin Building Front Office	Manual	11/20/2025 6:11:42 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-320 005	Admin Building Front Office	Manual	11/20/2025 5:54:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-321 006	Admin Building Front Office	Manual	11/20/2025 6:03:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-324 012	Admin Building Nurse	Manual	11/20/2025 5:59:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-314 009	Admin Building Office Restroom	Manual	11/20/2025 5:59:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-322 015	Admin Building Open office	Manual	11/20/2025 6:02:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-323 014	Admin Building Open Office	Manual	11/20/2025 5:53:13 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General		Admin Building Principal Office	Manual	11/20/2025 6:03:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-319 003	Admin Building Principal Office	Manual	11/20/2025 5:55:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-312 010	Admin Building Reception B01	Manual	11/20/2025 6:02:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-313 011	Admin Building Vice Principal Office	Manual	11/20/2025 5:59:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-318 004	Admin Building Work Rm	Manual	11/20/2025 5:55:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-326	Admin Conference Rm	Manual	11/20/2025 5:58:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-312	Admin Elec Rm	Manual	11/20/2025 5:52:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-289 026	Bldg Classroom E01	Manual	11/20/2025 5:27:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-335 186	C01 Restroom	Manual	11/20/2025 5:37:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-143	Classroom 19 Attic	Manual	11/20/2025 6:09:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-143	Classroom 19 Attic	Manual	11/20/2025 6:09:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-080	Classroom 20	Manual	11/20/2025 5:06:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-079	Classroom 20	Manual	11/20/2025 5:06:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-146	Classroom 20 Attic	Manual	11/20/2025 6:09:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-146	Classroom 20 Attic	Manual	11/20/2025 6:09:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-082	Classroom 21	Manual	11/20/2025 5:03:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-081	Classroom 21	Manual	11/20/2025 5:04:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-334 189	Kindergarten Bldg ADA RR by K1 K2	Manual	11/20/2025 5:35:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-348 190	Kindergarten Bldg Janitor Closet	Manual	11/20/2025 5:35:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-345 188	Kindergarten Bldg K1 Storage	Manual	11/20/2025 5:35:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-346 196	Kindergarten Bldg K2 Restroom	Manual	11/20/2025 5:35:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-336 198	Kindergarten Bldg K2 Storage	Manual	11/20/2025 5:35:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-332 181	Kindergarten Bldg Kindergarten 1	Manual	11/20/2025 5:33:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-333 180	Kindergarten Bldg Kindergarten 1	Manual	11/20/2025 5:35:26 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-330 183	Kindergarten Bldg Kindergarten 1	Manual	11/20/2025 5:35:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-331 182	Kindergarten Bldg Kindergarten 1	Manual	11/20/2025 5:35:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-343 192	Kindergarten Bldg Kindergarten 2	Manual	11/20/2025 5:32:11 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-341 194	Kindergarten Bldg Kindergarten 2	Manual	11/20/2025 5:32:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-342 193	Kindergarten Bldg Kindergarten 2	Manual	11/20/2025 5:32:35 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-340 195	Kindergarten Bldg Kindergarten 2	Manual	11/20/2025 5:32:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-347 191	Kindergarten Bldg Kindergarten 2	Manual	11/20/2025 5:35:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-329 184	Kindergarten Bldg Kindergarten C01	Manual	11/20/2025 5:35:43 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-338 199	Kindergarten Bldg Playground Storage	Manual	11/20/2025 5:35:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-339 200	Kindergarten Bldg Playground Storage	Manual	11/20/2025 5:35:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-329	Kindergarten C01	Manual	11/20/2025 5:35:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-258 217	kitchen By Elec Panel	Manual	11/20/2025 6:05:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-255 213	Library Bldg Library	Manual	11/20/2025 5:16:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-254 212	Library Bldg Library	Manual	11/20/2025 5:16:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-253 211	Library Bldg Library	Manual	11/20/2025 5:17:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-252 210	Library Bldg Library	Manual	11/20/2025 5:17:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-256 214	Library Bldg Library	Manual	11/20/2025 5:18:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-251 215	Library Bldg Library Office	Manual	11/20/2025 5:15:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-257 216	Library Bldg Outside Womens RR	Manual	11/20/2025 5:14:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-300 235	Multi-Purpose Bldg Above Stage Storage	Manual	11/20/2025 6:09:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-298 233	Multi-Purpose Bldg Hall / Stage Exit SE	Manual	11/20/2025 6:02:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-308	Multi-Purpose Bldg Kitchen	Manual	11/20/2025 6:11:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-309 241	Multi-Purpose Bldg Kitchen	Manual	11/20/2025 6:11:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-306 242	Multi-Purpose Bldg Kitchen Dishwashing	Manual	11/20/2025 6:11:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-305 236	Multi-Purpose Bldg Kitchen RR Sink Area	Manual	11/20/2025 6:06:43 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-304 237	Multi-Purpose Bldg Kitchen Stor	Manual	11/20/2025 6:06:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-302 230	Multi-Purpose Bldg MP Room	Manual	11/20/2025 6:03:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-303 227	Multi-Purpose Bldg MP Room	Manual	11/20/2025 6:03:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-311 226	Multi-Purpose Bldg MP Room	Manual	11/20/2025 6:03:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-296 225	Multi-Purpose Bldg MP Room	Manual	11/20/2025 6:04:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-295 228	Multi-Purpose Bldg MP Room	Manual	11/20/2025 6:04:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-294 229	Multi-Purpose Bldg MP Room	Manual	11/20/2025 6:04:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-384 223	Multi-Purpose Bldg MP Room NE Exit	Manual	11/20/2025 6:11:37 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-385 222	Multi-Purpose Bldg MP Room SE Exit	Manual	11/20/2025 6:11:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	2-386 224	Multi-Purpose Bldg MP Room SW Exit	Manual	11/20/2025 6:11:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-310 240	Multi-Purpose Bldg Speech Room	Manual	11/20/2025 6:09:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-297 232	Multi-Purpose Bldg Stage	Manual	11/20/2025 6:02:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-293 231	Multi-Purpose Bldg Stage	Manual	11/20/2025 6:02:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-299 234	Multi-Purpose Bldg Stage Storage	Manual	11/20/2025 6:09:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-382 244	Multi-Purpose Bldg Under Stage	Manual	11/20/2025 6:11:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-382 243	Multi-Purpose Bldg Under Stage	Manual	11/20/2025 6:12:00 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-353	Office C05	Manual	11/20/2025 5:38:20 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-328 185	Office C07	Manual	11/20/2025 5:36:22 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-077 175	Portable Classroom 19	Manual	11/20/2025 5:07:49 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-078 176	Portable Classroom 19	Manual	11/20/2025 5:08:02 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-352	Restroom By C05	Manual	11/20/2025 5:38:44 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-381 058	Rooms 1-6 Bldg Attic Classroom 1	Manual	11/20/2025 6:09:03 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-380 059	Rooms 1-6 Bldg Attic Classroom 2	Manual	11/20/2025 6:12:16 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-379 060	Rooms 1-6 Bldg Attic Classroom 3	Manual	11/20/2025 6:12:14 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-378 061	Rooms 1-6 Bldg Attic Classroom 4	Manual	11/20/2025 6:12:13 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-377 062	Rooms 1-6 Bldg Attic Classroom 5	Manual	11/20/2025 6:12:10 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-376 063	Rooms 1-6 Bldg Attic Classroom 6	Manual	11/20/2025 6:12:08 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-277 054	Rooms 1-6 Bldg Boys Restroom E Wing	Manual	11/20/2025 5:18:59 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-290 028	Rooms 1-6 Bldg Classrm 1 Clerestory	Manual	11/20/2025 5:27:41 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-285 033	Rooms 1-6 Bldg Classrm E022 Clerestory	Manual	11/20/2025 5:29:17 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-280 038	Rooms 1-6 Bldg Classrm E03 Clerestory	Manual	11/20/2025 5:30:51 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-263 053	Rooms 1-6 Bldg Classrm E04 Clerestory	Manual	11/20/2025 5:22:27 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-268 048	Rooms 1-6 Bldg Classrm E05 Clerestory	Manual	11/20/2025 5:23:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-273 043	Rooms 1-6 Bldg Classrm E06 Clerestory	Manual	11/20/2025 5:25:33 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-292 024	Rooms 1-6 Bldg Classroom 1	Manual	11/20/2025 5:26:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-286 030	Rooms 1-6 Bldg Classroom 2	Manual	11/20/2025 5:28:36 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-267 045	Rooms 1-6 Bldg Classroom 5	Manual	11/20/2025 5:23:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-291 025	Rooms 1-6 Bldg Classroom E01	Manual	11/20/2025 5:26:57 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-288 027	Rooms 1-6 Bldg Classroom E01	Manual	11/20/2025 5:27:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-287 029	Rooms 1-6 Bldg Classroom E02	Manual	11/20/2025 5:28:22 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-284 031	Rooms 1-6 Bldg Classroom E02	Manual	11/20/2025 5:28:44 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-283 032	Rooms 1-6 Bldg Classroom E02	Manual	11/20/2025 5:29:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-282 034	Rooms 1-6 Bldg Classroom E03	Manual	11/20/2025 5:29:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-281 035	Rooms 1-6 Bldg Classroom E03	Manual	11/20/2025 5:30:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-279 036	Rooms 1-6 Bldg Classroom E03	Manual	11/20/2025 5:30:25 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-278 037	Rooms 1-6 Bldg Classroom E03	Manual	11/20/2025 5:30:34 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-261 049	Rooms 1-6 Bldg Classroom E04	Manual	11/20/2025 5:21:31 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-262 050	Rooms 1-6 Bldg Classroom E04	Manual	11/20/2025 5:21:47 PM
		Visual inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Functional Inspection	Passed	
Smoke Detector - General	2-264 051	Rooms 1-6 Bldg Classroom E04	Manual	11/20/2025 5:21:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-265 052	Rooms 1-6 Bldg Classroom E04	Manual	11/20/2025 5:22:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-266 044	Rooms 1-6 Bldg Classroom E05	Manual	11/20/2025 5:23:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-269 046	Rooms 1-6 Bldg Classroom E05	Manual	11/20/2025 5:23:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-270 047	Rooms 1-6 Bldg Classroom E05	Manual	11/20/2025 5:23:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-271 039	Rooms 1-6 Bldg Classroom E06	Manual	11/20/2025 5:24:30 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-272 040	Rooms 1-6 Bldg Classroom E06	Manual	11/20/2025 5:24:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-274 041	Rooms 1-6 Bldg Classroom E06	Manual	11/20/2025 5:24:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-275 042	Rooms 1-6 Bldg Classroom E06	Manual	11/20/2025 5:25:07 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-260 057	Rooms 1-6 Bldg Girls Restroom	Manual	11/20/2025 5:20:46 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-276 055	Rooms 1-6 Bldg Janitor Room E09	Manual	11/20/2025 5:19:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-142 154	Rooms 7-18 Bldg Attic Boys Restroom	Manual	11/20/2025 6:12:02 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-142 155	Rooms 7-18 Bldg Attic Boys Restroom	Manual	11/20/2025 6:12:03 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-139 145	Rooms 7-18 Bldg Attic Classroom 10	Manual	11/20/2025 6:12:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-140 146	Rooms 7-18 Bldg Attic Classroom 11	Manual	11/20/2025 6:12:55 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	2-141 147	Rooms 7-18 Bldg Attic Classroom 12	Manual	11/20/2025 6:12:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	2-130 148	Rooms 7-18 Bldg Attic Classroom 13	Manual	11/20/2025 6:09:05 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-131 149	Rooms 7-18 Bldg Attic Classroom 14	Manual	11/20/2025 6:12:17 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-132 150	Rooms 7-18 Bldg Attic Classroom 15	Manual	11/20/2025 6:12:19 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-133 151	Rooms 7-18 Bldg Attic Classroom 16	Manual	11/20/2025 6:12:20 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-134 152	Rooms 7-18 Bldg Attic Classroom 17	Manual	11/20/2025 6:12:49 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-135 153	Rooms 7-18 Bldg Attic Classroom 18	Manual	11/20/2025 6:12:51 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-136 142	Rooms 7-18 Bldg Attic Classroom 7	Manual	11/20/2025 6:12:11 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-137 143	Rooms 7-18 Bldg Attic Classroom 8	Manual	11/20/2025 6:12:05 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Heat Detector - Restorable Spot	2-138 144	Rooms 7-18 Bldg Attic Classroom 9	Manual	11/20/2025 6:12:52 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-009 133	Rooms 7-18 Bldg Boys RR by Rm 13	Manual	11/20/2025 6:00:43 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-008 132	Rooms 7-18 Bldg Boys RR by Rm 13	Manual	11/20/2025 6:00:49 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-048 076	Rooms 7-18 Bldg Classrm D01 Clerestory	Manual	11/20/2025 5:40:38 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-053 081	Rooms 7-18 Bldg Classrm D02 Clerestory	Manual	11/20/2025 5:42:09 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-058 086	Rooms 7-18 Bldg Classrm D03 Clerestory	Manual	11/20/2025 5:44:09 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-063 091	Rooms 7-18 Bldg Classrm D04 Clerestory	Manual	11/20/2025 5:45:35 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	
Smoke Detector - General	2-068 096	Rooms 7-18 Bldg Classrm D05 Clerestory	Manual	11/20/2025 5:47:26 PM
		Visual inspection Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-073 101	Rooms 7-18 Bldg Classrm D06 Clerestory	Manual	11/20/2025 5:49:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-037 131	Rooms 7-18 Bldg Classrm D07 Clerestory	Manual	11/20/2025 5:02:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-032 126	Rooms 7-18 Bldg Classrm D08 Clerestory	Manual	11/20/2025 5:01:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-027 121	Rooms 7-18 Bldg Classrm D09 Clerestory	Manual	11/20/2025 4:59:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-022 116	Rooms 7-18 Bldg Classrm D10 Clerestory	Manual	11/20/2025 4:55:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-017 111	Rooms 7-18 Bldg Classrm D11 Clerestory	Manual	11/20/2025 4:54:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-012 106	Rooms 7-18 Bldg Classrm D12 Clerestory	Manual	11/20/2025 4:53:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-062 088	Rooms 7-18 Bldg Classroom 1D04	Manual	11/20/2025 5:45:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-046 072	Rooms 7-18 Bldg Classroom D01	Manual	11/20/2025 5:40:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-047 073	Rooms 7-18 Bldg Classroom D01	Manual	11/20/2025 5:40:09 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-049 074	Rooms 7-18 Bldg Classroom D01	Manual	11/20/2025 5:40:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-050 075	Rooms 7-18 Bldg Classroom D01	Manual	11/20/2025 5:40:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-051 077	Rooms 7-18 Bldg Classroom D02	Manual	11/20/2025 5:41:16 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-052 078	Rooms 7-18 Bldg Classroom D02	Manual	11/20/2025 5:41:32 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-054 079	Rooms 7-18 Bldg Classroom D02	Manual	11/20/2025 5:41:39 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-055 080	Rooms 7-18 Bldg Classroom D02	Manual	11/20/2025 5:41:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	5-056 082	Rooms 7-18 Bldg Classroom D03	Manual	11/20/2025 5:42:50 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-057 083	Rooms 7-18 Bldg Classroom D03	Manual	11/20/2025 5:43:00 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-059 084	Rooms 7-18 Bldg Classroom D03	Manual	11/20/2025 5:43:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-060 085	Rooms 7-18 Bldg Classroom D03	Manual	11/20/2025 5:43:17 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-061 087	Rooms 7-18 Bldg Classroom D04	Manual	11/20/2025 5:44:52 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-064 089	Rooms 7-18 Bldg Classroom D04	Manual	11/20/2025 5:45:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-065 090	Rooms 7-18 Bldg Classroom D04	Manual	11/20/2025 5:45:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-066 092	Rooms 7-18 Bldg Classroom D05	Manual	11/20/2025 5:46:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-067 093	Rooms 7-18 Bldg Classroom D05	Manual	11/20/2025 5:46:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-069 094	Rooms 7-18 Bldg Classroom D05	Manual	11/20/2025 5:46:49 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-070 095	Rooms 7-18 Bldg Classroom D05	Manual	11/20/2025 5:47:06 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-071 097	Rooms 7-18 Bldg Classroom D06	Manual	11/20/2025 5:48:15 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-072 098	Rooms 7-18 Bldg Classroom D06	Manual	11/20/2025 5:48:28 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-074 099	Rooms 7-18 Bldg Classroom D06	Manual	11/20/2025 5:48:45 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-075 100	Rooms 7-18 Bldg Classroom D06	Manual	11/20/2025 5:48:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-039 127	Rooms 7-18 Bldg Classroom D07	Manual	11/20/2025 5:01:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-038 128	Rooms 7-18 Bldg Classroom D07	Manual	11/20/2025 5:02:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-036 129	Rooms 7-18 Bldg Classroom D07	Manual	11/20/2025 5:02:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-035 130	Rooms 7-18 Bldg Classroom D07	Manual	11/20/2025 5:02:40 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-034 122	Rooms 7-18 Bldg Classroom D08	Manual	11/20/2025 5:00:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-031 124	Rooms 7-18 Bldg Classroom D08	Manual	11/20/2025 5:00:41 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-030 125	Rooms 7-18 Bldg Classroom D08	Manual	11/20/2025 5:00:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-033 123	Rooms 7-18 Bldg Classroom D08	Manual	11/20/2025 6:03:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-029 117	Rooms 7-18 Bldg Classroom D09	Manual	11/20/2025 4:58:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-028 118	Rooms 7-18 Bldg Classroom D09	Manual	11/20/2025 4:58:59 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-026 119	Rooms 7-18 Bldg Classroom D09	Manual	11/20/2025 4:59:08 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-025 120	Rooms 7-18 Bldg Classroom D09	Manual	11/20/2025 4:59:24 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-023 113	Rooms 7-18 Bldg Classroom D10	Manual	11/20/2025 4:55:29 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-021 114	Rooms 7-18 Bldg Classroom D10	Manual	11/20/2025 4:55:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-020 115	Rooms 7-18 Bldg Classroom D10	Manual	11/20/2025 4:56:05 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-024 112	Rooms 7-18 Bldg Classroom D10	Manual	11/20/2025 4:56:19 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-018 108	Rooms 7-18 Bldg Classroom D11	Manual	11/20/2025 4:54:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-016 109	Rooms 7-18 Bldg Classroom D11	Manual	11/20/2025 4:54:27 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-019 107	Rooms 7-18 Bldg Classroom D11	Manual	11/20/2025 4:56:53 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-015 110	Rooms 7-18 Bldg Classroom D11	Manual	11/20/2025 4:57:04 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-013 103	Rooms 7-18 Bldg Classroom D12	Manual	11/20/2025 4:53:12 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-011 104	Rooms 7-18 Bldg Classroom D12	Manual	11/20/2025 4:53:18 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-014 102	Rooms 7-18 Bldg Classroom D12	Manual	11/20/2025 4:57:38 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-010 105	Rooms 7-18 Bldg Classroom D12	Manual	11/20/2025 4:57:56 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-005 134	Rooms 7-18 Bldg D14	Manual	11/20/2025 4:51:54 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-043 139	Rooms 7-18 Bldg Elect MDF Room	Manual	11/20/2025 6:03:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-042 138	Rooms 7-18 Bldg Elect MDF Room	Manual	11/20/2025 6:03:23 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-045 140	Rooms 7-18 Bldg Girls Restroom D13	Manual	11/20/2025 6:01:47 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-044 141	Rooms 7-18 Bldg Girls Restroom D13	Manual	11/20/2025 6:01:51 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-006 135	Rooms 7-18 Bldg Rm D14	Manual	11/20/2025 4:52:01 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-041 137	Rooms 7-18 Bldg Storage by D15	Manual	11/20/2025 6:01:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-040 136	Rooms 7-18 Bldg Storage by D15	Manual	11/20/2025 6:01:21 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-259 056	Storage E 09	Manual	11/20/2025 5:20:10 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-336 187	Storage Rm C01.2	Manual	11/20/2025 5:36:58 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	2-345 197	Storage Rm C02.2	Manual	11/20/2025 5:36:14 PM
		Visual inspection	Passed (Manual)	
		Functional Inspection	Passed	

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	2-308 239	Multi-Purpose Bldg Kitchen Closet	Manual	11/20/2025 6:07:55 PM
Smoke Detector - General	2-307 238	Multi-Purpose Bldg Kitchen Storage	Manual	11/20/2025 6:08:06 PM

**Ventilation and Cooking Equipment**

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Fusible Links	Fusible Links 450 Degree X 2		Manual	1/22/2026 2:04:54 PM
Range Hood	Hood		Manual	1/22/2026 2:04:57 PM
Range Suppression	Suppression System		Manual	1/22/2026 2:05:00 PM
Range Suppression	LT30R Cartridge		Manual	1/22/2026 2:05:02 PM
Range Suppression Tank	Ansul R102 3 Gallon Cylinder		Manual	1/22/2026 2:05:05 PM

## Device/Equipment details

### Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Audible					
017	Admin Building South Exterior				
156	Rooms 7-18 Bldg East Exterior				
157	Rooms 7-18 Bldg West Exterior				
201	Kindergarten Bldg North Exterior				
202	Kindergarten Bldg South Exterior				
245	Multi-Purpose Bldg East Exterior				
246	Multi-Purpose Bldg West Exterior				
Audible And Visible					
018	Admin Building Front Office				
064	Rooms 1-6 Bldg Classroom 1				
065	Rooms 1-6 Bldg Classroom 2				
066	Rooms 1-6 Bldg Classroom 3				
067	Rooms 1-6 Bldg Classroom 4				
068	Rooms 1-6 Bldg Classroom 5				
069	Rooms 1-6 Bldg Classroom 6				
158	Rooms 7-18 Bldg Classroom 7				
159	Rooms 7-18 Bldg Classroom 8				
160	Rooms 7-18 Bldg Classroom 9				
161	Rooms 7-18 Bldg Classroom 10				
162	Rooms 7-18 Bldg Classroom 11				
163	Rooms 7-18 Bldg Classroom 12				
164	Rooms 7-18 Bldg Classroom 13				
165	Rooms 7-18 Bldg Classroom 14				
166	Rooms 7-18 Bldg Classroom 15				
167	Rooms 7-18 Bldg Classroom 16				
168	Rooms 7-18 Bldg Classroom 17				
169	Rooms 7-18 Bldg Classroom 18				
179	Portable Classroom 19				
203	Kindergarten Bldg Kindergarten 1				
204	Kindergarten Bldg Kindergarten 2				
218	Library Bldg Library				
247	Multi-Purpose Bldg MP Room				
248	Multi-Purpose Bldg MP Room				
249	Multi-Purpose Bldg Stage				
250	Multi-Purpose Bldg Kitchen				
Visible					
019	Admin Building Copy Room				
020	Admin Building Office Restroom				
021	Admin Building Principal Office				
022	Admin Building Elect Storage IDF				
023	Admin Building Deans Office				
070	Rooms 1-6 Bldg Girls Restroom				
071	Rooms 1-6 Bldg Boys Restroom				
170	Rooms 7-18 Bldg Teachers Lounge				
171	Rooms 7-18 Bldg Girls Restroom				
172	Rooms 7-18 Bldg Boys RR by Rm 13				
205	Kindergarten Bldg K1 Restroom				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
206	Kindergarten Bldg K1 Restroom				
207	Kindergarten Bldg ADA RR by K1 K2				
208	Kindergarten Bldg K2 Restroom				
209	Kindergarten Bldg K2 Restroom				
219	Library Bldg Library Office				
220	Library Bldg Outside Womens RR				
221	Library Bldg Outside Staff RR				
251	Multi-Purpose Bldg Kitchen RR Sink Area				
252	Multi-Purpose Bldg Kitchen RR Toilet				

### Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Remote Annunciator					
001	Admin Building Front Office				
NAC Power Extender Panel					
173	Rooms 7-18 Bldg Elect MDF Room				
174	Rooms 7-18 Bldg Elect MDF Room				

### Fire Alarm Panel

	Rooms 7-18 Bldg Elect MDF Room	Edwards	EST-3		
--	--------------------------------	---------	-------	--	--

### Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Manual Pull Station					
2-387 002	Admin Building Front Office				
2-385 222	Multi-Purpose Bldg MP Room SE Exit				
2-384 223	Multi-Purpose Bldg MP Room NE Exit				
2-386 224	Multi-Purpose Bldg MP Room SW Exit				

### Smoke Detector - General

2-319 003	Admin Building Principal Office				
2-318 004	Admin Building Work Rm				
2-320 005	Admin Building Front Office				
2-321 006	Admin Building Front Office				
2-316 007	Admin Building Copy Room				
2-317 008	Admin Building Copy Room				
2-314 009	Admin Building Office Restroom				
2-312 010	Admin Building Reception B01				
2-313 011	Admin Building Vice Principal Office				
2-324 012	Admin Building Nurse				
2-325 013	Admin Building Elect Storage IDF				
2-323 014	Admin Building Open Office				
2-322 015	Admin Building Open office				
2-315 016	Admin Building Elec Rm				
2-292 024	Rooms 1-6 Bldg Classroom 1				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-291 025	Rooms 1-6 Bldg Classroom E01				
2-289 026	Bldg Classroom E01				
2-288 027	Rooms 1-6 Bldg Classroom E01				
2-290 028	Rooms 1-6 Bldg Classrm 1 Clerestory				
2-287 029	Rooms 1-6 Bldg Classroom E02				
2-286 030	Rooms 1-6 Bldg Classroom 2				
2-284 031	Rooms 1-6 Bldg Classroom E02				
2-283 032	Rooms 1-6 Bldg Classroom E02				
2-285 033	Rooms 1-6 Bldg Classrm E022 Clerestory				
2-282 034	Rooms 1-6 Bldg Classroom E03				
2-281 035	Rooms 1-6 Bldg Classroom E03				
2-279 036	Rooms 1-6 Bldg Classroom E03				
2-278 037	Rooms 1-6 Bldg Classroom E03				
2-280 038	Rooms 1-6 Bldg Classrm E03 Clerestory				
2-271 039	Rooms 1-6 Bldg Classroom E06				
2-272 040	Rooms 1-6 Bldg Classroom E06				
2-274 041	Rooms 1-6 Bldg Classroom E06				
2-275 042	Rooms 1-6 Bldg Classroom E06				
2-273 043	Rooms 1-6 Bldg Classrm E06 Clerestory				
2-266 044	Rooms 1-6 Bldg Classroom E05				
2-267 045	Rooms 1-6 Bldg Classroom 5				
2-269 046	Rooms 1-6 Bldg Classroom E05				
2-270 047	Rooms 1-6 Bldg Classroom E05				
2-268 048	Rooms 1-6 Bldg Classrm E05 Clerestory				
2-261 049	Rooms 1-6 Bldg Classroom E04				
2-262 050	Rooms 1-6 Bldg Classroom E04				
2-264 051	Rooms 1-6 Bldg Classroom E04				
2-265 052	Rooms 1-6 Bldg Classroom E04				
2-263 053	Rooms 1-6 Bldg Classrm E04 Clerestory				
2-277 054	Rooms 1-6 Bldg Boys Restroom E Wing				
2-276 055	Rooms 1-6 Bldg Janitor Room E09				
2-259 056	Storage E 09				
2-260 057	Rooms 1-6 Bldg Girls Restroom				
2-046 072	Rooms 7-18 Bldg Classroom D01				
2-047 073	Rooms 7-18 Bldg Classroom D01				
2-049 074	Rooms 7-18 Bldg Classroom D01				
2-050 075	Rooms 7-18 Bldg Classroom D01				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-048 076	Rooms 7-18 Bldg Classrm D01 Clerestory				
2-051 077	Rooms 7-18 Bldg Classroom D02				
2-052 078	Rooms 7-18 Bldg Classroom D02				
2-054 079	Rooms 7-18 Bldg Classroom D02				
2-055 080	Rooms 7-18 Bldg Classroom D02				
2-053 081	Rooms 7-18 Bldg Classrm D02 Clerestory				
5-056 082	Rooms 7-18 Bldg Classroom D03				
2-057 083	Rooms 7-18 Bldg Classroom D03				
2-059 084	Rooms 7-18 Bldg Classroom D03				
2-060 085	Rooms 7-18 Bldg Classroom D03				
2-058 086	Rooms 7-18 Bldg Classrm D03 Clerestory				
2-061 087	Rooms 7-18 Bldg Classroom D04				
2-062 088	Rooms 7-18 Bldg Classroom 1D04				
2-064 089	Rooms 7-18 Bldg Classroom D04				
2-065 090	Rooms 7-18 Bldg Classroom D04				
2-063 091	Rooms 7-18 Bldg Classrm D04 Clerestory				
2-066 092	Rooms 7-18 Bldg Classroom D05				
2-067 093	Rooms 7-18 Bldg Classroom D05				
2-069 094	Rooms 7-18 Bldg Classroom D05				
2-070 095	Rooms 7-18 Bldg Classroom D05				
2-068 096	Rooms 7-18 Bldg Classrm D05 Clerestory				
2-071 097	Rooms 7-18 Bldg Classroom D06				
2-072 098	Rooms 7-18 Bldg Classroom D06				
2-074 099	Rooms 7-18 Bldg Classroom D06				
2-075 100	Rooms 7-18 Bldg Classroom D06				
2-073 101	Rooms 7-18 Bldg Classrm D06 Clerestory				
2-014 102	Rooms 7-18 Bldg Classroom D12				
2-013 103	Rooms 7-18 Bldg Classroom D12				
2-011 104	Rooms 7-18 Bldg Classroom D12				
2-010 105	Rooms 7-18 Bldg Classroom D12				
2-012 106	Rooms 7-18 Bldg Classrm D12 Clerestory				
2-019 107	Rooms 7-18 Bldg Classroom D11				
2-018 108	Rooms 7-18 Bldg Classroom D11				
2-016 109	Rooms 7-18 Bldg Classroom D11				
2-015 110	Rooms 7-18 Bldg Classroom D11				
2-017 111	Rooms 7-18 Bldg Classrm D11 Clerestory				
2-024 112	Rooms 7-18 Bldg Classroom D10				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-023 113	Rooms 7-18 Bldg Classroom D10				
2-021 114	Rooms 7-18 Bldg Classroom D10				
2-020 115	Rooms 7-18 Bldg Classroom D10				
2-022 116	Rooms 7-18 Bldg Classrm D10 Clerestory				
2-029 117	Rooms 7-18 Bldg Classroom D09				
2-028 118	Rooms 7-18 Bldg Classroom D09				
2-026 119	Rooms 7-18 Bldg Classroom D09				
2-025 120	Rooms 7-18 Bldg Classroom D09				
2-027 121	Rooms 7-18 Bldg Classrm D09 Clerestory				
2-034 122	Rooms 7-18 Bldg Classroom D08				
2-033 123	Rooms 7-18 Bldg Classroom D08				
2-031 124	Rooms 7-18 Bldg Classroom D08				
2-030 125	Rooms 7-18 Bldg Classroom D08				
2-032 126	Rooms 7-18 Bldg Classrm D08 Clerestory				
2-039 127	Rooms 7-18 Bldg Classroom D07				
2-038 128	Rooms 7-18 Bldg Classroom D07				
2-036 129	Rooms 7-18 Bldg Classroom D07				
2-035 130	Rooms 7-18 Bldg Classroom D07				
2-037 131	Rooms 7-18 Bldg Classrm D07 Clerestory				
2-008 132	Rooms 7-18 Bldg Boys RR by Rm 13				
2-009 133	Rooms 7-18 Bldg Boys RR by Rm 13				
2-005 134	Rooms 7-18 Bldg D14				
2-006 135	Rooms 7-18 Bldg Rm D14				
2-040 136	Rooms 7-18 Bldg Storage by D15				
2-041 137	Rooms 7-18 Bldg Storage by D15				
2-042 138	Rooms 7-18 Bldg Elect MDF Room				
2-043 139	Rooms 7-18 Bldg Elect MDF Room				
2-045 140	Rooms 7-18 Bldg Girls Restroom D13				
2-044 141	Rooms 7-18 Bldg Girls Restroom D13				
2-077 175	Portable Classroom 19				
2-078 176	Portable Classroom 19				
2-333 180	Kindergarten Bldg Kindergarten 1				
2-332 181	Kindergarten Bldg Kindergarten 1				
2-331 182	Kindergarten Bldg Kindergarten 1				
2-330 183	Kindergarten Bldg Kindergarten 1				
2-329 184	Kindergarten Bldg Kindergarten C01				
2-328 185	Office C07				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-335 186	C01 Restroom				
2-336 187	Storage Rm C01.2				
2-345 188	Kindergarten Bldg K1 Storage				
2-334 189	Kindergarten Bldg ADA RR by K1 K2				
2-348 190	Kindergarten Bldg Janitor Closet				
2-347 191	Kindergarten Bldg Kindergarten 2				
2-343 192	Kindergarten Bldg Kindergarten 2				
2-342 193	Kindergarten Bldg Kindergarten 2				
2-341 194	Kindergarten Bldg Kindergarten 2				
2-340 195	Kindergarten Bldg Kindergarten 2				
2-346 196	Kindergarten Bldg K2 Restroom				
2-345 197	Storage Rm C02.2				
2-336 198	Kindergarten Bldg K2 Storage				
2-338 199	Kindergarten Bldg Playground Storage				
2-339 200	Kindergarten Bldg Playground Storage				
2-252 210	Library Bldg Library				
2-253 211	Library Bldg Library				
2-254 212	Library Bldg Library				
2-255 213	Library Bldg Library				
2-256 214	Library Bldg Library				
2-251 215	Library Bldg Library Office				
2-257 216	Library Bldg Outside Womens RR				
2-258 217	kitchen By Elec Panel				
2-296 225	Multi-Purpose Bldg MP Room				
2-311 226	Multi-Purpose Bldg MP Room				
2-303 227	Multi-Purpose Bldg MP Room				
2-295 228	Multi-Purpose Bldg MP Room				
2-294 229	Multi-Purpose Bldg MP Room				
2-302 230	Multi-Purpose Bldg MP Room				
2-293 231	Multi-Purpose Bldg Stage				
2-297 232	Multi-Purpose Bldg Stage				
2-298 233	Multi-Purpose Bldg Hall / Stage Exit SE				
2-299 234	Multi-Purpose Bldg Stage Storage				
2-300 235	Multi-Purpose Bldg Above Stage Storage				
2-305 236	Multi-Purpose Bldg Kitchen RR Sink Area				
2-304 237	Multi-Purpose Bldg Kitchen Stor				
2-307 238	Multi-Purpose Bldg Kitchen Storage				

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
2-308 239	Multi-Purpose Bldg Kitchen Closet				
2-310 240	Multi-Purpose Bldg Speech Room				
2-080	Classroom 20				
2-079	Classroom 20				
2-082	Classroom 21				
2-081	Classroom 21				
2-312	Admin Elec Rm				
2-326	Admin Conference Rm				
2-352	Restroom By C05				
2-353	Office C05				
2-329	Kindergarten C01				
	Admin Building Principal Office				
Heat Detector - Restorable Spot					
2-381 058	Rooms 1-6 Bldg Attic Classroom 1				
2-380 059	Rooms 1-6 Bldg Attic Classroom 2				
2-379 060	Rooms 1-6 Bldg Attic Classroom 3				
2-378 061	Rooms 1-6 Bldg Attic Classroom 4				
2-377 062	Rooms 1-6 Bldg Attic Classroom 5				
2-376 063	Rooms 1-6 Bldg Attic Classroom 6				
2-136 142	Rooms 7-18 Bldg Attic Classroom 7				
2-137 143	Rooms 7-18 Bldg Attic Classroom 8				
2-138 144	Rooms 7-18 Bldg Attic Classroom 9				
2-139 145	Rooms 7-18 Bldg Attic Classroom 10				
2-140 146	Rooms 7-18 Bldg Attic Classroom 11				
2-141 147	Rooms 7-18 Bldg Attic Classroom 12				
2-130 148	Rooms 7-18 Bldg Attic Classroom 13				
2-131 149	Rooms 7-18 Bldg Attic Classroom 14				
2-132 150	Rooms 7-18 Bldg Attic Classroom 15				
2-133 151	Rooms 7-18 Bldg Attic Classroom 16				
2-134 152	Rooms 7-18 Bldg Attic Classroom 17				
2-135 153	Rooms 7-18 Bldg Attic Classroom 18				
2-142 154	Rooms 7-18 Bldg Attic Boys Restroom				
2-142 155	Rooms 7-18 Bldg Attic Boys Restroom				
2-309 241	Multi-Purpose Bldg Kitchen				
2-306 242	Multi-Purpose Bldg Kitchen Dishwashing				
2-382 243	Multi-Purpose Bldg Under Stage				
2-382 244	Multi-Purpose Bldg Under Stage				
2-146	Classroom 20 Attic				
2-143	Classroom 19 Attic				
2-146	Classroom 20 Attic				
2-143	Classroom 19 Attic				
2-308	Multi-Purpose Bldg Kitchen				

## Ventilation and Cooking Equipment

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
	Range Suppression Tank				
	Ansul R102 3 Gallon Cylinder				01/01/2020
	Range Suppression				
	LT30R Cartridge				01/01/2020
	Suppression System				01/01/2020
	Range Hood				
	Hood				01/01/2020
	Fusible Links				
	Fusible Links 450 Degree X 2				01/01/2020