

# Inspection and Testing Certificate

Presented To

SAN JUAN USD

For

LA VISTA CENTER ELEMENTARY

4501 BANNISTER  
FAIR OAKS, California 95628  
United States

This site has been inspected and tested in compliance with applicable standards.

Completed  
Monday, May 04, 2026

Test Session:30 Oct 2025 10:13 RJ6615 AFA

ACCEPTED BY

SAN JUAN USD  
5320 HEMLOCK ST  
SACRAMENTO, California  
United States

TESTED BY

Riley Goyet  
Western States Fire Protection-  
Sacramento  
188 Cirby Way  
Roseville, CA 95678  
United States



# Inspection Summary

## Building Information

|            |                               |         |
|------------|-------------------------------|---------|
| PROPERTY   | LA VISTA CENTER<br>ELEMENTARY | CONTACT |
| ADDRESS    | 4501 BANNISTER                | PHONE   |
| CITY/STATE | FAIR OAKS, California 95628   | MOBILE  |
| COUNTRY    | United States                 | EMAIL   |

## Inspector Information

|         |   |                |                     |
|---------|---|----------------|---------------------|
| COMPANY | Western States Fire Protection-<br>Sacramento | CONTACT        | Riley Goyet         |
| ADDRESS | 188 Cirby Way<br>Roseville, CA 95678          | LICENSE NUMBER |                     |
| COUNTRY | United States                                 | PHONE          | +1 916-200-9514     |
|         |   | EMAIL          | riley.goyet@wsfp.us |

## Testing Summary

| EQUIPMENT TYPE                             | TOTAL | TESTED   | PASSED   | FAILED |
|--|-------|----------|----------|--------|
| Alarm Notification Appliance               | 50    | 50(100%) | 50(100%) | 0(0%)  |
| Supervising Station Transmitting Equipment | 1     | 1(100%)  | 1(100%)  | 0(0%)  |
| Fire Control Panel                         | 4     | 4(100%)  | 4(100%)  | 0(0%)  |
| Initiating Device                          | 143   | 141(99%) | 141(99%) | 0(0%)  |

## Certification

The equipment specified herein was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Monday, May 04, 2026

|             |                         |           |                           |
|-------------|-------------------------|-----------|---------------------------|
| ACCEPTED BY | 05/04/2026              | TESTED BY | 05/04/2026                |
|             | Building Representative |           | Riley Goyet<br>Technician |



# System Details

## Monitoring Information

| Admin Building Copy Room               |   |   |            |
|--|---|---|------------|
| TYPE                                   | Digital Alarm Communicator Transmitter            | INSTALL DATE                            |            |
| MANUFACTURER                           | Bosch   | TEST START                              | 10/30/2025 |
| MODEL                                  | B9512G  | TEST COMPLETE                           | 05/04/2026 |
| SERIAL NUMBER                          |   | Time to Transmit to Supervising Station |            |
| MONITORING ORGANIZATION                | Central Station / SJUSD Dispatch                  | ALARM SIGNAL                            |            |
| MONITORING ORGANIZATION PHONE          | CS - 916-480-4836 / SJUSD Dispatch - 916-971-7000 | ALARM RESTORE                           |            |
| MONITORING ORGANIZATION EMAIL          |   | TROUBLE SIGNAL                          |            |
| MONITORING ORGANIZATION ACCOUNT NUMBER | Central Station # 881-8035                        | TROUBLE RESTORE                         |            |
| MONITORING PHONE LINE 1                |   | SUPERVISORY SIGNAL                      |            |
| MONITORING PHONE LINE 2                |   | SUPERVISORY RESTORE                     |            |
| MONITORING RETRANSMISSION ENTITY       |   |   |            |

# Resolved Corrective Action & Solution Summary

The following 2 corrective action(s) were resolved during the system inspection, testing or maintenance activities

| EQUIPMENT TYPE           | ADDRESS | Description                         |
|--------------------------|---------|-------------------------------------|
| NAC Power Extender Panel | 033     | Admin Building Copy Room - P.E. "A" |

Created By: Riley Goyet  
 Creation Date: 03/02/2023  
 Corrective Action: Replace (2) 12V 8AH Batteries  
 Resolution:  
 Resolved By: Riley Goyet  
 Resolved On: 03/18/2026  
 Manufacturer:  
 Model:

Created By: Riley Goyet  
 Creation Date: 10/03/2023  
 Corrective Action: Replace (2) 12V 8AH Batteries  
 Resolution:  
 Resolved By: Riley Goyet  
 Resolved On: 03/18/2026  
 Manufacturer:  
 Model:

# Testing Details

## Alarm Notification Appliance

Passed

| EQUIPMENT TYPE      | ADDRESS | DESCRIPTION                         | METHOD          | DATE/TIME            |
|---------------------|---------|-------------------------------------|-----------------|----------------------|
| Visible             |         | Admin Building Admin SE Bldg        | Manual          | 3/18/2026 6:44:27 PM |
|                     |         | Visual inspection                   | Passed (Manual) |                      |
|                     |         | Functional Inspection               | Passed          |                      |
| Visible             |         | Admin Building Boys RR SE Bldg      | Manual          | 3/18/2026 6:44:16 PM |
|                     |         | Visual inspection                   | Passed (Manual) |                      |
|                     |         | Functional Inspection               | Passed          |                      |
| Audible And Visible |         | Admin Building Copy Room            | Manual          | 3/18/2026 6:44:51 PM |
|                     |         | Visual inspection                   | Passed (Manual) |                      |
|                     |         | Functional Inspection               | Passed          |                      |
| Audible And Visible |         | Admin Building Front Office         | Manual          | 3/18/2026 6:44:53 PM |
|                     |         | Visual inspection                   | Passed (Manual) |                      |
|                     |         | Functional Inspection               | Passed          |                      |
| Visible             |         | Admin Building Girls RR SE Bldg     | Manual          | 3/18/2026 6:44:17 PM |
|                     |         | Visual inspection                   | Passed (Manual) |                      |
|                     |         | Functional Inspection               | Passed          |                      |
| Audible             |         | Admin Building North Exterior       | Manual          | 3/18/2026 6:45:22 PM |
|                     |         | Visual inspection                   | Passed (Manual) |                      |
|                     |         | Functional Inspection               | Passed          |                      |
| Visible             |         | Admin Building Principals Office    | Manual          | 3/18/2026 6:44:24 PM |
|                     |         | Visual inspection                   | Passed (Manual) |                      |
|                     |         | Functional Inspection               | Passed          |                      |
| Visible             |         | Admin Building Restroom SE Bldg     | Manual          | 3/18/2026 6:44:22 PM |
|                     |         | Visual inspection                   | Passed (Manual) |                      |
|                     |         | Functional Inspection               | Passed          |                      |
| Visible             |         | Admin Building SE Bldg Copy Restrm  | Manual          | 3/18/2026 6:44:20 PM |
|                     |         | Visual inspection                   | Passed (Manual) |                      |
|                     |         | Functional Inspection               | Passed          |                      |
| Visible             |         | Admin Building Staff Restrm SE Bldg | Manual          | 3/18/2026 6:44:19 PM |
|                     |         | Visual inspection                   | Passed (Manual) |                      |
|                     |         | Functional Inspection               | Passed          |                      |
| Audible And Visible |         | Admin Building Teacher Lounge       | Manual          | 3/18/2026 6:44:50 PM |
|                     |         | Visual inspection                   | Passed (Manual) |                      |
|                     |         | Functional Inspection               | Passed          |                      |
| Audible             |         | Multi-Purpose Bldg East Exterior    | Manual          | 3/18/2026 6:45:24 PM |
|                     |         | Visual inspection                   | Passed (Manual) |                      |
|                     |         | Functional Inspection               | Passed          |                      |
| Audible And Visible |         | Multi-Purpose Bldg Kitchen          | Manual          | 3/18/2026 6:44:55 PM |
|                     |         | Visual inspection                   | Passed (Manual) |                      |
|                     |         | Functional Inspection               | Passed          |                      |
| Audible And Visible |         | Multi-Purpose Bldg MP Room          | Manual          | 3/18/2026 6:44:58 PM |
|                     |         | Visual inspection                   | Passed (Manual) |                      |
|                     |         | Functional Inspection               | Passed          |                      |
| Audible And Visible |         | Multi-Purpose Bldg MP Room          | Manual          | 3/18/2026 6:44:59 PM |
|                     |         | Visual inspection                   | Passed (Manual) |                      |
|                     |         | Functional Inspection               | Passed          |                      |
| Audible And Visible |         | Multi-Purpose Bldg Stage            | Manual          | 3/18/2026 6:44:56 PM |
|                     |         | Visual inspection                   | Passed (Manual) |                      |
|                     |         | Functional Inspection               | Passed          |                      |

| EQUIPMENT TYPE      | ADDRESS | DESCRIPTION                           | METHOD          | DATE/TIME            |
|---------------------|---------|---------------------------------------|-----------------|----------------------|
| Visible             |         | Rooms 11-14 Bldg Classrm 14 Restroom  | Manual          | 3/18/2026 6:44:31 PM |
|                     |         | Visual inspection                     | Passed (Manual) |                      |
|                     |         | Functional Inspection                 | Passed          |                      |
| Audible And Visible |         | Rooms 11-14 Bldg Classroom 11         | Manual          | 3/18/2026 6:45:17 PM |
|                     |         | Visual inspection                     | Passed (Manual) |                      |
|                     |         | Functional Inspection                 | Passed          |                      |
| Audible And Visible |         | Rooms 11-14 Bldg Classroom 12         | Manual          | 3/18/2026 6:45:15 PM |
|                     |         | Visual inspection                     | Passed (Manual) |                      |
|                     |         | Functional Inspection                 | Passed          |                      |
| Audible And Visible |         | Rooms 11-14 Bldg Classroom 13         | Manual          | 3/18/2026 6:45:14 PM |
|                     |         | Visual inspection                     | Passed (Manual) |                      |
|                     |         | Functional Inspection                 | Passed          |                      |
| Audible And Visible |         | Rooms 11-14 Bldg Classroom 14         | Manual          | 3/18/2026 6:45:12 PM |
|                     |         | Visual inspection                     | Passed (Manual) |                      |
|                     |         | Functional Inspection                 | Passed          |                      |
| Visible             |         | Rooms 11-14 Bldg Classroom 14         | Manual          | 3/18/2026 6:44:32 PM |
|                     |         | Visual inspection                     | Passed (Manual) |                      |
|                     |         | Functional Inspection                 | Passed          |                      |
| Audible             |         | Rooms 11-14 Bldg South Exterior       | Manual          | 3/18/2026 6:45:25 PM |
|                     |         | Visual inspection                     | Passed (Manual) |                      |
|                     |         | Functional Inspection                 | Passed          |                      |
| Audible             |         | Rooms 11-14 Bldg South Exterior       | Manual          | 3/18/2026 6:45:26 PM |
|                     |         | Visual inspection                     | Passed (Manual) |                      |
|                     |         | Functional Inspection                 | Passed          |                      |
| Audible And Visible |         | Rooms 1-5 Bldg Classroom 1            | Manual          | 3/18/2026 6:44:48 PM |
|                     |         | Visual inspection                     | Passed (Manual) |                      |
|                     |         | Functional Inspection                 | Passed          |                      |
| Audible And Visible |         | Rooms 1-5 Bldg Classroom 1A           | Manual          | 3/18/2026 6:44:46 PM |
|                     |         | Visual inspection                     | Passed (Manual) |                      |
|                     |         | Functional Inspection                 | Passed          |                      |
| Visible             |         | Rooms 1-5 Bldg Classroom 1B           | Manual          | 3/18/2026 6:44:12 PM |
|                     |         | Visual inspection                     | Passed (Manual) |                      |
|                     |         | Functional Inspection                 | Passed          |                      |
| Audible And Visible |         | Rooms 1-5 Bldg Classroom 2            | Manual          | 3/18/2026 6:44:47 PM |
|                     |         | Visual inspection                     | Passed (Manual) |                      |
|                     |         | Functional Inspection                 | Passed          |                      |
| Audible And Visible |         | Rooms 1-5 Bldg Classroom 3            | Manual          | 3/18/2026 6:44:44 PM |
|                     |         | Visual inspection                     | Passed (Manual) |                      |
|                     |         | Functional Inspection                 | Passed          |                      |
| Audible And Visible |         | Rooms 1-5 Bldg Classroom 4            | Manual          | 3/18/2026 6:44:43 PM |
|                     |         | Visual inspection                     | Passed (Manual) |                      |
|                     |         | Functional Inspection                 | Passed          |                      |
| Audible And Visible |         | Rooms 1-5 Bldg Classroom 5            | Manual          | 3/18/2026 6:44:41 PM |
|                     |         | Visual inspection                     | Passed (Manual) |                      |
|                     |         | Functional Inspection                 | Passed          |                      |
| Audible             |         | Rooms 1-5 Bldg South Exterior         | Manual          | 3/18/2026 6:45:20 PM |
|                     |         | Visual inspection                     | Passed (Manual) |                      |
|                     |         | Functional Inspection                 | Passed          |                      |
| Visible             |         | Rooms 15-21 Bldg Boys Restroom N      | Manual          | 3/18/2026 6:44:28 PM |
|                     |         | Visual inspection                     | Passed (Manual) |                      |
|                     |         | Functional Inspection                 | Passed          |                      |
| Visible             |         | Rooms 15-21 Bldg Classrm 15 Breakroom | Manual          | 3/18/2026 6:44:29 PM |
|                     |         | Visual inspection                     | Passed (Manual) |                      |
|                     |         | Functional Inspection                 | Passed          |                      |

| EQUIPMENT TYPE      | ADDRESS | DESCRIPTION                       | METHOD          | DATE/TIME            |
|---------------------|---------|-----------------------------------|-----------------|----------------------|
| Audible And Visible |         | Rooms 15-21 Bldg Classroom 15     | Manual          | 3/18/2026 6:45:10 PM |
|                     |         | Visual inspection                 | Passed (Manual) |                      |
|                     |         | Functional Inspection             | Passed          |                      |
| Audible And Visible |         | Rooms 15-21 Bldg Classroom 16     | Manual          | 3/18/2026 6:45:09 PM |
|                     |         | Visual inspection                 | Passed (Manual) |                      |
|                     |         | Functional Inspection             | Passed          |                      |
| Audible And Visible |         | Rooms 15-21 Bldg Classroom 17     | Manual          | 3/18/2026 6:45:07 PM |
|                     |         | Visual inspection                 | Passed (Manual) |                      |
|                     |         | Functional Inspection             | Passed          |                      |
| Audible And Visible |         | Rooms 15-21 Bldg Classroom 18     | Manual          | 3/18/2026 6:45:06 PM |
|                     |         | Visual inspection                 | Passed (Manual) |                      |
|                     |         | Functional Inspection             | Passed          |                      |
| Audible And Visible |         | Rooms 15-21 Bldg Classroom 19     | Manual          | 3/18/2026 6:45:04 PM |
|                     |         | Visual inspection                 | Passed (Manual) |                      |
|                     |         | Functional Inspection             | Passed          |                      |
| Audible And Visible |         | Rooms 15-21 Bldg Classroom 20     | Manual          | 3/18/2026 6:45:03 PM |
|                     |         | Visual inspection                 | Passed (Manual) |                      |
|                     |         | Functional Inspection             | Passed          |                      |
| Audible And Visible |         | Rooms 15-21 Bldg Classroom 21     | Manual          | 3/18/2026 6:45:01 PM |
|                     |         | Visual inspection                 | Passed (Manual) |                      |
|                     |         | Functional Inspection             | Passed          |                      |
| Visible             |         | Rooms 15-21 Bldg Girls Restroom N | Manual          | 3/18/2026 6:44:25 PM |
|                     |         | Visual inspection                 | Passed (Manual) |                      |
|                     |         | Functional Inspection             | Passed          |                      |
| Visible             |         | Rooms 6-10 Bldg Boys Restroom W   | Manual          | 3/18/2026 6:44:14 PM |
|                     |         | Visual inspection                 | Passed (Manual) |                      |
|                     |         | Functional Inspection             | Passed          |                      |
| Audible And Visible |         | Rooms 6-10 Bldg Classroom 10      | Manual          | 3/18/2026 6:44:34 PM |
|                     |         | Visual inspection                 | Passed (Manual) |                      |
|                     |         | Functional Inspection             | Passed          |                      |
| Audible And Visible |         | Rooms 6-10 Bldg Classroom 6       | Manual          | 3/18/2026 6:44:40 PM |
|                     |         | Visual inspection                 | Passed (Manual) |                      |
|                     |         | Functional Inspection             | Passed          |                      |
| Audible And Visible |         | Rooms 6-10 Bldg Classroom 7       | Manual          | 3/18/2026 6:44:38 PM |
|                     |         | Visual inspection                 | Passed (Manual) |                      |
|                     |         | Functional Inspection             | Passed          |                      |
| Audible And Visible |         | Rooms 6-10 Bldg Classroom 8       | Manual          | 3/18/2026 6:44:37 PM |
|                     |         | Visual inspection                 | Passed (Manual) |                      |
|                     |         | Functional Inspection             | Passed          |                      |
| Audible And Visible |         | Rooms 6-10 Bldg Classroom 9       | Manual          | 3/18/2026 6:44:35 PM |
|                     |         | Visual inspection                 | Passed (Manual) |                      |
|                     |         | Functional Inspection             | Passed          |                      |
| Visible             |         | Rooms 6-10 Bldg Girls Restroom W  | Manual          | 3/18/2026 6:44:11 PM |
|                     |         | Visual inspection                 | Passed (Manual) |                      |
|                     |         | Functional Inspection             | Passed          |                      |
| Audible             |         | Rooms 6-10 Bldg South Exterior    | Manual          | 3/18/2026 6:45:18 PM |
|                     |         | Visual inspection                 | Passed (Manual) |                      |
|                     |         | Functional Inspection             | Passed          |                      |

**Fire Control Panel**

Passed

| EQUIPMENT TYPE   | ADDRESS | DESCRIPTION              | METHOD          | DATE/TIME            |
|------------------|---------|--------------------------|-----------------|----------------------|
| Fire Alarm Panel |         | Admin Building Copy Room | Manual          | 3/18/2026 6:42:25 PM |
|                  |         | Manufacturer             | EST             |                      |
|                  |         | Model                    | 3               |                      |
|                  |         | Visual inspection        | Passed (Manual) |                      |

| EQUIPMENT TYPE           | ADDRESS | DESCRIPTION                                      | METHOD          | DATE/TIME            |
|--------------------------|---------|--|-----------------|----------------------|
|                          |         | Functional Inspection                            | Passed          |                      |
| NAC Power Extender Panel |         | Admin Building Copy Room - P.E. "A"              | Manual          | 3/18/2026 6:42:38 PM |
|                          |         | Visual inspection                                | Passed (Manual) |                      |
|                          |         | Functional Inspection                            | Passed          |                      |
| Remote Annunciator       |         | Admin Building Front Office                      | Manual          | 3/18/2026 6:42:17 PM |
|                          |         | Visual inspection                                | Passed (Manual) |                      |
|                          |         | Functional Inspection                            | Passed          |                      |
| NAC Power Extender Panel |         | Rooms 15-21 Bldg North Janitor Closet - P.E. "B" | Manual          | 3/18/2026 6:42:16 PM |
|                          |         | Visual inspection                                | Passed (Manual) |                      |
|                          |         | Functional Inspection                            | Passed          |                      |

### Initiating Device

Passed

| EQUIPMENT TYPE                  | ADDRESS      | DESCRIPTION                            | METHOD          | DATE/TIME            |
|---------------------------------|--------------|--|-----------------|----------------------|
| Smoke Detector - General        | 2-014<br>006 | Admin Building Admin SE Bldg           | Manual          | 3/18/2026 6:43:29 PM |
|                                 |              | Visual inspection                      | Passed (Manual) |                      |
|                                 |              | Functional Inspection                  | Passed          |                      |
| Heat Detector - Restorable Spot | 2-149<br>021 | Admin Building Attic Admin Hallway     | Manual          | 3/18/2026 6:39:51 PM |
|                                 |              | Visual inspection                      | Passed (Manual) |                      |
|                                 |              | Functional Inspection                  | Passed          |                      |
| Heat Detector - Restorable Spot | 2-150<br>020 | Admin Building Attic Girls Restroom    | Manual          | 3/18/2026 6:39:41 PM |
|                                 |              | Visual inspection                      | Passed (Manual) |                      |
|                                 |              | Functional Inspection                  | Passed          |                      |
| Heat Detector - Restorable Spot | 2-147<br>017 | Admin Building Attic Main Office       | Manual          | 3/18/2026 6:40:18 PM |
|                                 |              | Visual inspection                      | Passed (Manual) |                      |
|                                 |              | Functional Inspection                  | Passed          |                      |
| Heat Detector - Restorable Spot | 2-148<br>018 | Admin Building Attic Principals Office | Manual          | 3/18/2026 6:39:50 PM |
|                                 |              | Visual inspection                      | Passed (Manual) |                      |
|                                 |              | Functional Inspection                  | Passed          |                      |
| Heat Detector - Restorable Spot | 2-128<br>019 | Admin Building Attic Teacher Lounge    | Manual          | 3/18/2026 6:39:44 PM |
|                                 |              | Visual inspection                      | Passed (Manual) |                      |
|                                 |              | Functional Inspection                  | Passed          |                      |
| Smoke Detector - General        | 2-011<br>015 | Admin Building Boys RR SE Bldg         | Manual          | 3/18/2026 6:43:48 PM |
|                                 |              | Visual inspection                      | Passed (Manual) |                      |
|                                 |              | Functional Inspection                  | Passed          |                      |
| Smoke Detector - General        | 2-007<br>010 | Admin Building Copy rm Above FACP      | Manual          | 3/18/2026 6:43:40 PM |
|                                 |              | Visual inspection                      | Passed (Manual) |                      |
|                                 |              | Functional Inspection                  | Passed          |                      |
| Smoke Detector - General        | 2-012<br>009 | Admin Building Custodian SE Bldg       | Manual          | 3/18/2026 6:43:37 PM |
|                                 |              | Visual inspection                      | Passed (Manual) |                      |
|                                 |              | Functional Inspection                  | Passed          |                      |
| Manual Pull Station             | 2-129<br>002 | Admin Building Front Office            | Manual          | 3/18/2026 6:41:27 PM |
|                                 |              | Visual inspection                      | Passed (Manual) |                      |
|                                 |              | Functional Inspection                  | Passed          |                      |
| Smoke Detector - General        | 2-009<br>013 | Admin Building Girls RR SE Bldg        | Manual          | 3/18/2026 6:43:44 PM |
|                                 |              | Visual inspection                      | Passed (Manual) |                      |
|                                 |              | Functional Inspection                  | Passed          |                      |
| Smoke Detector - General        | 2-010<br>014 | Admin Building Janitor Rm SE Bldg      | Manual          | 3/18/2026 6:43:46 PM |
|                                 |              | Visual inspection                      | Passed (Manual) |                      |
|                                 |              | Functional Inspection                  | Passed          |                      |

| EQUIPMENT TYPE   | ADDRESS      | DESCRIPTION                             | METHOD          | DATE/TIME            |
|--|--------------|---|-----------------|----------------------|
| Smoke Detector - General                               | 2-017<br>003 | Admin Building Main Office SE Bldg      | Manual          | 3/18/2026 6:43:34 PM |
|  |              | Visual inspection                       | Passed (Manual) |                      |
|  |              | Functional Inspection                   | Passed          |                      |
| Smoke Detector - General                               | 2-018<br>005 | Admin Building Principals Office        | Manual          | 3/18/2026 6:43:31 PM |
|  |              | Visual inspection                       | Passed (Manual) |                      |
|  |              | Functional Inspection                   | Passed          |                      |
| Smoke Detector - General                               | 2-016<br>007 | Admin Building Restroom SE Bldg         | Manual          | 3/18/2026 6:43:26 PM |
|  |              | Visual inspection                       | Passed (Manual) |                      |
|  |              | Functional Inspection                   | Passed          |                      |
| Smoke Detector - General                               | 2-015<br>004 | Admin Building SE Bldg Admin            | Manual          | 3/18/2026 6:43:28 PM |
|  |              | Visual inspection                       | Passed (Manual) |                      |
|  |              | Functional Inspection                   | Passed          |                      |
| Smoke Detector - General                               | 2-006<br>011 | Admin Building SE Bldg Copy Restrm      | Manual          | 3/18/2026 6:43:38 PM |
|  |              | Visual inspection                       | Passed (Manual) |                      |
|  |              | Functional Inspection                   | Passed          |                      |
| Smoke Detector - General                               | 2-013<br>008 | Admin Building Staff Restrm SE Bldg     | Manual          | 3/18/2026 6:43:35 PM |
|  |              | Visual inspection                       | Passed (Manual) |                      |
|  |              | Functional Inspection                   | Passed          |                      |
| Smoke Detector - General                               | 2-008<br>012 | Admin Building Teacher Lounge           | Manual          | 3/18/2026 6:43:42 PM |
|  |              | Visual inspection                       | Passed (Manual) |                      |
|  |              | Functional Inspection                   | Passed          |                      |
| Heat Detector - Restorable Spot                        | 2-130<br>189 | Multi-Purpose Bldg Attic MP Storage     | Manual          | 3/18/2026 6:40:05 PM |
|  |              | Visual inspection                       | Passed (Manual) |                      |
|  |              | Functional Inspection                   | Passed          |                      |
| Heat Detector - Restorable Spot                        | 2-130<br>188 | Multi-Purpose Bldg Attic MP Storage     | Manual          | 3/18/2026 6:40:07 PM |
|  |              | Visual inspection                       | Passed (Manual) |                      |
|  |              | Functional Inspection                   | Passed          |                      |
| Smoke Detector - General                               | 2-054<br>185 | Multi-Purpose Bldg Boiler Room          | Manual          | 3/18/2026 6:42:52 PM |
|  |              | Visual inspection                       | Passed (Manual) |                      |
|  |              | Functional Inspection                   | Passed          |                      |
| Valve Tamper Switch                                    | 2-146<br>191 | Multi-Purpose Bldg Double Check Valve   | Manual          | 3/18/2026 6:41:19 PM |
|  |              | Visual inspection                       | Passed (Manual) |                      |
|  |              | Functional Inspection                   | Passed          |                      |
| Mechanical, Electrosonic, or Pressure Waterflow Device | 2-131<br>190 | Multi-Purpose Bldg East Exterior        | Manual          | 3/18/2026 6:42:19 PM |
|  |              | Visual inspection                       | Passed (Manual) |                      |
|  |              | Functional Inspection                   | Passed          |                      |
| Heat Detector - Restorable Spot                        | 2-023<br>186 | Multi-Purpose Bldg Kitchen              | Manual          | 3/18/2026 6:40:43 PM |
|  |              | Visual inspection                       | Passed (Manual) |                      |
|  |              | Functional Inspection                   | Passed          |                      |
| Heat Detector - Restorable Spot                        | 2-020<br>187 | Multi-Purpose Bldg Kitchen              | Manual          | 3/18/2026 6:40:44 PM |
|  |              | Visual inspection                       | Passed (Manual) |                      |
|  |              | Functional Inspection                   | Passed          |                      |
| Smoke Detector - General                               | 2-022<br>184 | Multi-Purpose Bldg Kitchen Food Storage | Manual          | 3/18/2026 6:41:20 PM |
|  |              | Visual inspection                       | Passed (Manual) |                      |
|  |              | Functional Inspection                   | Passed          |                      |
| Smoke Detector - General                               | 2-021<br>183 | Multi-Purpose Bldg Kitchen Food Storage | Manual          | 3/18/2026 6:41:22 PM |
|  |              | Visual inspection                       | Passed (Manual) |                      |
|  |              | Functional Inspection                   | Passed          |                      |

| EQUIPMENT TYPE           | ADDRESS      | DESCRIPTION                        | METHOD          | DATE/TIME            |
|--------------------------|--------------|------------------------------------|-----------------|----------------------|
| Smoke Detector - General | 2-027<br>176 | Multi-Purpose Bldg MP Room         | Manual          | 3/18/2026 6:41:30 PM |
|                          |              | Visual inspection                  | Passed (Manual) |                      |
|                          |              | Functional Inspection              | Passed          |                      |
| Smoke Detector - General | 2-025<br>177 | Multi-Purpose Bldg MP Room         | Manual          | 3/18/2026 6:41:31 PM |
|                          |              | Visual inspection                  | Passed (Manual) |                      |
|                          |              | Functional Inspection              | Passed          |                      |
| Smoke Detector - General | 2-030<br>172 | Multi-Purpose Bldg MP Room         | Manual          | 3/18/2026 6:41:33 PM |
|                          |              | Visual inspection                  | Passed (Manual) |                      |
|                          |              | Functional Inspection              | Passed          |                      |
| Smoke Detector - General | 2-031<br>171 | Multi-Purpose Bldg MP Room         | Manual          | 3/18/2026 6:41:34 PM |
|                          |              | Visual inspection                  | Passed (Manual) |                      |
|                          |              | Functional Inspection              | Passed          |                      |
| Smoke Detector - General | 2-033<br>170 | Multi-Purpose Bldg MP Room         | Manual          | 3/18/2026 6:41:36 PM |
|                          |              | Visual inspection                  | Passed (Manual) |                      |
|                          |              | Functional Inspection              | Passed          |                      |
| Smoke Detector - General | 2-028<br>174 | Multi-Purpose Bldg MP Room         | Manual          | 3/18/2026 6:41:38 PM |
|                          |              | Visual inspection                  | Passed (Manual) |                      |
|                          |              | Functional Inspection              | Passed          |                      |
| Smoke Detector - General | 2-034<br>166 | Multi-Purpose Bldg MP Room         | Manual          | 3/18/2026 6:41:39 PM |
|                          |              | Visual inspection                  | Passed (Manual) |                      |
|                          |              | Functional Inspection              | Passed          |                      |
| Smoke Detector - General | 2-026<br>175 | Multi-Purpose Bldg MP Room         | Manual          | 3/18/2026 6:43:19 PM |
|                          |              | Visual inspection                  | Passed (Manual) |                      |
|                          |              | Functional Inspection              | Passed          |                      |
| Smoke Detector - General | 2-029<br>173 | Multi-Purpose Bldg MP Room         | Manual          | 3/18/2026 6:43:20 PM |
|                          |              | Visual inspection                  | Passed (Manual) |                      |
|                          |              | Functional Inspection              | Passed          |                      |
| Smoke Detector - General | 2-032<br>169 | Multi-Purpose Bldg MP Room         | Manual          | 3/18/2026 6:43:21 PM |
|                          |              | Visual inspection                  | Passed (Manual) |                      |
|                          |              | Functional Inspection              | Passed          |                      |
| Smoke Detector - General | 2-035<br>167 | Multi-Purpose Bldg MP Room         | Manual          | 3/18/2026 6:43:23 PM |
|                          |              | Visual inspection                  | Passed (Manual) |                      |
|                          |              | Functional Inspection              | Passed          |                      |
| Smoke Detector - General | 2-036<br>168 | Multi-Purpose Bldg MP Room         | Manual          | 3/18/2026 6:43:25 PM |
|                          |              | Visual inspection                  | Passed (Manual) |                      |
|                          |              | Functional Inspection              | Passed          |                      |
| Manual Pull Station      | 2-145<br>163 | Multi-Purpose Bldg MP Room N Exit  | Manual          | 3/18/2026 6:41:26 PM |
|                          |              | Visual inspection                  | Passed (Manual) |                      |
|                          |              | Functional Inspection              | Passed          |                      |
| Manual Pull Station      | 2-144<br>164 | Multi-Purpose Bldg MP Room NW Exit | Manual          | 3/18/2026 6:41:25 PM |
|                          |              | Visual inspection                  | Passed (Manual) |                      |
|                          |              | Functional Inspection              | Passed          |                      |
| Manual Pull Station      | 2-143<br>165 | Multi-Purpose Bldg MP Room S Exit  | Manual          | 3/18/2026 6:41:23 PM |
|                          |              | Visual inspection                  | Passed (Manual) |                      |
|                          |              | Functional Inspection              | Passed          |                      |
| Smoke Detector - General | 2-047<br>182 | Multi-Purpose Bldg Stage           | Manual          | 3/18/2026 6:43:14 PM |
|                          |              | Visual inspection                  | Passed (Manual) |                      |
|                          |              | Functional Inspection              | Passed          |                      |

| EQUIPMENT TYPE                  | ADDRESS      | DESCRIPTION                                 | METHOD          | DATE/TIME            |
|---------------------------------|--------------|---|-----------------|----------------------|
| Smoke Detector - General        | 2-043<br>181 | Multi-Purpose Bldg Stage                    | Manual          | 3/18/2026 6:43:15 PM |
|                                 |              | Visual inspection                           | Passed (Manual) |                      |
|                                 |              | Functional Inspection                       | Passed          |                      |
| Smoke Detector - General        | 2-039<br>180 | Multi-Purpose Bldg Stage                    | Manual          | 3/18/2026 6:43:17 PM |
|                                 |              | Visual inspection                           | Passed (Manual) |                      |
|                                 |              | Functional Inspection                       | Passed          |                      |
| Smoke Detector - General        | 2-024<br>179 | Multi-Purpose Bldg Storage Southeast        | Manual          | 3/18/2026 6:42:13 PM |
|                                 |              | Visual inspection                           | Passed (Manual) |                      |
|                                 |              | Functional Inspection                       | Passed          |                      |
| Smoke Detector - General        | 2-019<br>178 | Multi-Purpose Bldg Storage Southeast        | Manual          | 3/18/2026 6:43:32 PM |
|                                 |              | Visual inspection                           | Passed (Manual) |                      |
|                                 |              | Functional Inspection                       | Passed          |                      |
| Heat Detector - Restorable Spot | 2-138<br>103 | Rooms 11-14 Bldg Attic Classroom 14 Kitchen | Manual          | 3/18/2026 6:40:09 PM |
|                                 |              | Visual inspection                           | Passed (Manual) |                      |
|                                 |              | Functional Inspection                       | Passed          |                      |
| Smoke Detector - General        | 2-077<br>097 | Rooms 11-14 Bldg Classrm 14 Kitchen         | Manual          | 3/18/2026 6:41:50 PM |
|                                 |              | Visual inspection                           | Passed (Manual) |                      |
|                                 |              | Functional Inspection                       | Passed          |                      |
| Smoke Detector - General        | 2-090<br>089 | Rooms 11-14 Bldg Classroom 11               | Manual          | 3/18/2026 6:42:06 PM |
|                                 |              | Visual inspection                           | Passed (Manual) |                      |
|                                 |              | Functional Inspection                       | Passed          |                      |
| Smoke Detector - General        | 2-089<br>088 | Rooms 11-14 Bldg Classroom 11               | Manual          | 3/18/2026 6:42:07 PM |
|                                 |              | Visual inspection                           | Passed (Manual) |                      |
|                                 |              | Functional Inspection                       | Passed          |                      |
| Heat Detector - Restorable Spot | 2-091<br>099 | Rooms 11-14 Bldg Classroom 11 HVAC Closet   | Manual          | 3/18/2026 6:40:13 PM |
|                                 |              | Visual inspection                           | Passed (Manual) |                      |
|                                 |              | Functional Inspection                       | Passed          |                      |
| Smoke Detector - General        | 2-087<br>091 | Rooms 11-14 Bldg Classroom 12               | Manual          | 3/18/2026 6:42:03 PM |
|                                 |              | Visual inspection                           | Passed (Manual) |                      |
|                                 |              | Functional Inspection                       | Passed          |                      |
| Smoke Detector - General        | 2-088<br>090 | Rooms 11-14 Bldg Classroom 12               | Manual          | 3/18/2026 6:42:04 PM |
|                                 |              | Visual inspection                           | Passed (Manual) |                      |
|                                 |              | Functional Inspection                       | Passed          |                      |
| Heat Detector - Restorable Spot | 2-086<br>100 | Rooms 11-14 Bldg Classroom 12 HVAC Closet   | Manual          | 3/18/2026 6:39:59 PM |
|                                 |              | Visual inspection                           | Passed (Manual) |                      |
|                                 |              | Functional Inspection                       | Passed          |                      |
| Smoke Detector - General        | 2-084<br>093 | Rooms 11-14 Bldg Classroom 13               | Manual          | 3/18/2026 6:41:59 PM |
|                                 |              | Visual inspection                           | Passed (Manual) |                      |
|                                 |              | Functional Inspection                       | Passed          |                      |
| Smoke Detector - General        | 2-083<br>092 | Rooms 11-14 Bldg Classroom 13               | Manual          | 3/18/2026 6:42:01 PM |
|                                 |              | Visual inspection                           | Passed (Manual) |                      |
|                                 |              | Functional Inspection                       | Passed          |                      |
| Heat Detector - Restorable Spot | 2-085<br>101 | Rooms 11-14 Bldg Classroom 13 HVAC Closet   | Manual          | 3/18/2026 6:40:01 PM |
|                                 |              | Visual inspection                           | Passed (Manual) |                      |
|                                 |              | Functional Inspection                       | Passed          |                      |
| Smoke Detector - General        | 2-078<br>096 | Rooms 11-14 Bldg Classroom 14               | Manual          | 3/18/2026 6:41:53 PM |
|                                 |              | Visual inspection                           | Passed (Manual) |                      |
|                                 |              | Functional Inspection                       | Passed          |                      |

| EQUIPMENT TYPE                  | ADDRESS      | DESCRIPTION                               | METHOD          | DATE/TIME            |
|---------------------------------|--------------|---|-----------------|----------------------|
| Smoke Detector - General        | 2-081<br>095 | Rooms 11-14 Bldg Classroom 14             | Manual          | 3/18/2026 6:41:55 PM |
|                                 |              | Visual inspection                         | Passed (Manual) |                      |
|                                 |              | Functional Inspection                     | Passed          |                      |
| Smoke Detector - General        | 2-082<br>094 | Rooms 11-14 Bldg Classroom 14             | Manual          | 3/18/2026 6:41:56 PM |
|                                 |              | Visual inspection                         | Passed (Manual) |                      |
|                                 |              | Functional Inspection                     | Passed          |                      |
| Heat Detector - Restorable Spot | 2-080<br>102 | Rooms 11-14 Bldg Classroom 14 HVAC Closet | Manual          | 3/18/2026 6:40:10 PM |
|                                 |              | Visual inspection                         | Passed (Manual) |                      |
|                                 |              | Functional Inspection                     | Passed          |                      |
| Smoke Detector - General        | 2-079<br>098 | Rooms 11-14 Bldg Classroom 14 Restroom    | Manual          | 3/18/2026 6:41:52 PM |
|                                 |              | Visual inspection                         | Passed (Manual) |                      |
|                                 |              | Functional Inspection                     | Passed          |                      |
| Smoke Detector - General        | 2-285<br>035 | Rooms 1-5 Bldg Classroom 1                | Manual          | 3/18/2026 6:43:53 PM |
|                                 |              | Visual inspection                         | Passed (Manual) |                      |
|                                 |              | Functional Inspection                     | Passed          |                      |
| Smoke Detector - General        | 2-284<br>034 | Rooms 1-5 Bldg Classroom 1                | Manual          | 3/18/2026 6:43:55 PM |
|                                 |              | Visual inspection                         | Passed (Manual) |                      |
|                                 |              | Functional Inspection                     | Passed          |                      |
| Heat Detector - Restorable Spot | 2-286<br>047 | Rooms 1-5 Bldg Classroom 1 HVAC Closet    | Manual          | 3/18/2026 6:40:50 PM |
|                                 |              | Visual inspection                         | Passed (Manual) |                      |
|                                 |              | Functional Inspection                     | Passed          |                      |
| Smoke Detector - General        | 2-282<br>037 | Rooms 1-5 Bldg Classroom 1A               | Manual          | 3/18/2026 6:43:56 PM |
|                                 |              | Visual inspection                         | Passed (Manual) |                      |
|                                 |              | Functional Inspection                     | Passed          |                      |
| Smoke Detector - General        | 2-281<br>036 | Rooms 1-5 Bldg Classroom 1A               | Manual          | 3/18/2026 6:43:58 PM |
|                                 |              | Visual inspection                         | Passed (Manual) |                      |
|                                 |              | Functional Inspection                     | Passed          |                      |
| Smoke Detector - General        | 2-283<br>038 | Rooms 1-5 Bldg Classroom 1B               | Manual          | 3/18/2026 6:44:00 PM |
|                                 |              | Visual inspection                         | Passed (Manual) |                      |
|                                 |              | Functional Inspection                     | Passed          |                      |
| Smoke Detector - General        | 2-279<br>040 | Rooms 1-5 Bldg Classroom 2                | Manual          | 3/18/2026 6:44:02 PM |
|                                 |              | Visual inspection                         | Passed (Manual) |                      |
|                                 |              | Functional Inspection                     | Passed          |                      |
| Smoke Detector - General        | 2-278<br>039 | Rooms 1-5 Bldg Classroom 2                | Manual          | 3/18/2026 6:44:03 PM |
|                                 |              | Visual inspection                         | Passed (Manual) |                      |
|                                 |              | Functional Inspection                     | Passed          |                      |
| Heat Detector - Restorable Spot | 2-280<br>048 | Rooms 1-5 Bldg Classroom 2 HVAC Closet    | Manual          | 3/18/2026 6:40:51 PM |
|                                 |              | Visual inspection                         | Passed (Manual) |                      |
|                                 |              | Functional Inspection                     | Passed          |                      |
| Smoke Detector - General        | 2-277<br>042 | Rooms 1-5 Bldg Classroom 3                | Manual          | 3/18/2026 6:44:05 PM |
|                                 |              | Visual inspection                         | Passed (Manual) |                      |
|                                 |              | Functional Inspection                     | Passed          |                      |
| Smoke Detector - General        | 2-276<br>041 | Rooms 1-5 Bldg Classroom 3                | Manual          | 3/18/2026 6:44:06 PM |
|                                 |              | Visual inspection                         | Passed (Manual) |                      |
|                                 |              | Functional Inspection                     | Passed          |                      |
| Heat Detector - Restorable Spot | 2-275<br>049 | Rooms 1-5 Bldg Classroom 3 HVAC Closet    | Manual          | 3/18/2026 6:40:53 PM |
|                                 |              | Visual inspection                         | Passed (Manual) |                      |
|                                 |              | Functional Inspection                     | Passed          |                      |

| EQUIPMENT TYPE                  | ADDRESS      | DESCRIPTION                             | METHOD          | DATE/TIME            |
|---------------------------------|--------------|---|-----------------|----------------------|
| Smoke Detector - General        | 2-274<br>043 | Rooms 1-5 Bldg Classroom 4              | Manual          | 3/18/2026 6:44:08 PM |
|                                 |              | Visual inspection                       | Passed (Manual) |                      |
|                                 |              | Functional Inspection                   | Passed          |                      |
| Smoke Detector - General        | 2-273<br>044 | Rooms 1-5 Bldg Classroom 4              | Manual          | 3/18/2026 6:44:10 PM |
|                                 |              | Visual inspection                       | Passed (Manual) |                      |
|                                 |              | Functional Inspection                   | Passed          |                      |
| Heat Detector - Restorable Spot | 2-272<br>050 | Rooms 1-5 Bldg Classroom 4 HVAC Closet  | Manual          | 3/18/2026 6:40:54 PM |
|                                 |              | Visual inspection                       | Passed (Manual) |                      |
|                                 |              | Functional Inspection                   | Passed          |                      |
| Smoke Detector - General        | 2-270<br>045 | Rooms 1-5 Bldg Classroom 5              | Manual          | 3/18/2026 6:43:50 PM |
|                                 |              | Visual inspection                       | Passed (Manual) |                      |
|                                 |              | Functional Inspection                   | Passed          |                      |
| Smoke Detector - General        | 2-269<br>046 | Rooms 1-5 Bldg Classroom 5              | Manual          | 3/18/2026 6:43:52 PM |
|                                 |              | Visual inspection                       | Passed (Manual) |                      |
|                                 |              | Functional Inspection                   | Passed          |                      |
| Heat Detector - Restorable Spot | 2-271<br>051 | Rooms 1-5 Bldg Classroom 5 HVAC Closet  | Manual          | 3/18/2026 6:40:48 PM |
|                                 |              | Visual inspection                       | Passed (Manual) |                      |
|                                 |              | Functional Inspection                   | Passed          |                      |
| Heat Detector - Restorable Spot | 2-136<br>144 | Rooms 15-21 Bldg Attic Classroom 20     | Manual          | 3/18/2026 6:40:26 PM |
|                                 |              | Visual inspection                       | Passed (Manual) |                      |
|                                 |              | Functional Inspection                   | Passed          |                      |
| Heat Detector - Restorable Spot | 2-136<br>145 | Rooms 15-21 Bldg Attic Classroom 20     | Manual          | 3/18/2026 6:40:27 PM |
|                                 |              | Visual inspection                       | Passed (Manual) |                      |
|                                 |              | Functional Inspection                   | Passed          |                      |
| Heat Detector - Restorable Spot | 2-137<br>146 | Rooms 15-21 Bldg Attic Classroom 21     | Manual          | 3/18/2026 6:40:19 PM |
|                                 |              | Visual inspection                       | Passed (Manual) |                      |
|                                 |              | Functional Inspection                   | Passed          |                      |
| Heat Detector - Restorable Spot | 2-137<br>147 | Rooms 15-21 Bldg Attic Classroom 21     | Manual          | 3/18/2026 6:40:21 PM |
|                                 |              | Visual inspection                       | Passed (Manual) |                      |
|                                 |              | Functional Inspection                   | Passed          |                      |
| Heat Detector - Restorable Spot | 2-137<br>148 | Rooms 15-21 Bldg Attic Classroom 21     | Manual          | 3/18/2026 6:40:23 PM |
|                                 |              | Visual inspection                       | Passed (Manual) |                      |
|                                 |              | Functional Inspection                   | Passed          |                      |
| Heat Detector - Restorable Spot | 2-137<br>149 | Rooms 15-21 Bldg Attic Classroom 21     | Manual          | 3/18/2026 6:40:24 PM |
|                                 |              | Visual inspection                       | Passed (Manual) |                      |
|                                 |              | Functional Inspection                   | Passed          |                      |
| Heat Detector - Restorable Spot | 2-151<br>150 | Rooms 15-21 Bldg Attic N Janitor Closet | Manual          | 3/18/2026 6:39:45 PM |
|                                 |              | Visual inspection                       | Passed (Manual) |                      |
|                                 |              | Functional Inspection                   | Passed          |                      |
| Smoke Detector - General        | 2-069<br>133 | Rooms 15-21 Bldg Boys Restroom N        | Manual          | 3/18/2026 6:42:44 PM |
|                                 |              | Visual inspection                       | Passed (Manual) |                      |
|                                 |              | Functional Inspection                   | Passed          |                      |
| Smoke Detector - General        | 2-048<br>112 | Rooms 15-21 Bldg Classroom 15           | Manual          | 3/18/2026 6:43:00 PM |
|                                 |              | Visual inspection                       | Passed (Manual) |                      |
|                                 |              | Functional Inspection                   | Passed          |                      |
| Smoke Detector - General        | 2-049<br>117 | Rooms 15-21 Bldg Classroom 15           | Manual          | 3/18/2026 6:43:01 PM |
|                                 |              | Visual inspection                       | Passed (Manual) |                      |
|                                 |              | Functional Inspection                   | Passed          |                      |

| EQUIPMENT TYPE                  | ADDRESS      | DESCRIPTION                                  | METHOD          | DATE/TIME            |
|---------------------------------|--------------|--|-----------------|----------------------|
| Smoke Detector - General        | 2-045<br>116 | Rooms 15-21 Bldg Classroom 15                | Manual          | 3/18/2026 6:43:03 PM |
|                                 |              | Visual inspection                            | Passed (Manual) |                      |
|                                 |              | Functional Inspection                        | Passed          |                      |
| Smoke Detector - General        | 2-044<br>113 | Rooms 15-21 Bldg Classroom 15                | Manual          | 3/18/2026 6:43:04 PM |
|                                 |              | Visual inspection                            | Passed (Manual) |                      |
|                                 |              | Functional Inspection                        | Passed          |                      |
| Smoke Detector - General        | 2-040<br>114 | Rooms 15-21 Bldg Classroom 15                | Manual          | 3/18/2026 6:43:06 PM |
|                                 |              | Visual inspection                            | Passed (Manual) |                      |
|                                 |              | Functional Inspection                        | Passed          |                      |
| Smoke Detector - General        | 2-041<br>115 | Rooms 15-21 Bldg Classroom 15                | Manual          | 3/18/2026 6:43:07 PM |
|                                 |              | Visual inspection                            | Passed (Manual) |                      |
|                                 |              | Functional Inspection                        | Passed          |                      |
| Smoke Detector - General        | 2-042<br>118 | Rooms 15-21 Bldg Classroom 15                | Manual          | 3/18/2026 6:43:09 PM |
|                                 |              | Visual inspection                            | Passed (Manual) |                      |
|                                 |              | Functional Inspection                        | Passed          |                      |
| Smoke Detector - General        | 2-046<br>120 | Rooms 15-21 Bldg Classroom 15                | Manual          | 3/18/2026 6:43:10 PM |
|                                 |              | Visual inspection                            | Passed (Manual) |                      |
|                                 |              | Functional Inspection                        | Passed          |                      |
| Smoke Detector - General        | 2-050<br>119 | Rooms 15-21 Bldg Classroom 15                | Manual          | 3/18/2026 6:43:12 PM |
|                                 |              | Visual inspection                            | Passed (Manual) |                      |
|                                 |              | Functional Inspection                        | Passed          |                      |
| Heat Detector - Restorable Spot | 2-053<br>136 | Rooms 15-21 Bldg Classroom 15<br>Breakroom   | Manual          | 3/18/2026 6:40:40 PM |
|                                 |              | Visual inspection                            | Passed (Manual) |                      |
|                                 |              | Functional Inspection                        | Passed          |                      |
| Heat Detector - Restorable Spot | 2-055<br>139 | Rooms 15-21 Bldg Classroom 15<br>HVAC Closet | Manual          | 3/18/2026 6:40:41 PM |
|                                 |              | Visual inspection                            | Passed (Manual) |                      |
|                                 |              | Functional Inspection                        | Passed          |                      |
| Smoke Detector - General        | 2-059<br>121 | Rooms 15-21 Bldg Classroom 16                | Manual          | 3/18/2026 6:42:54 PM |
|                                 |              | Visual inspection                            | Passed (Manual) |                      |
|                                 |              | Functional Inspection                        | Passed          |                      |
| Smoke Detector - General        | 2-058<br>122 | Rooms 15-21 Bldg Classroom 16                | Manual          | 3/18/2026 6:42:56 PM |
|                                 |              | Visual inspection                            | Passed (Manual) |                      |
|                                 |              | Functional Inspection                        | Passed          |                      |
| Heat Detector - Restorable Spot | 2-057<br>140 | Rooms 15-21 Bldg Classroom 16<br>HVAC Closet | Manual          | 3/18/2026 6:40:37 PM |
|                                 |              | Visual inspection                            | Passed (Manual) |                      |
|                                 |              | Functional Inspection                        | Passed          |                      |
| Smoke Detector - General        | 2-061<br>124 | Rooms 15-21 Bldg Classroom 17                | Manual          | 3/18/2026 6:42:50 PM |
|                                 |              | Visual inspection                            | Passed (Manual) |                      |
|                                 |              | Functional Inspection                        | Passed          |                      |
| Smoke Detector - General        | 2-060<br>123 | Rooms 15-21 Bldg Classroom 17                | Manual          | 3/18/2026 6:42:51 PM |
|                                 |              | Visual inspection                            | Passed (Manual) |                      |
|                                 |              | Functional Inspection                        | Passed          |                      |
| Heat Detector - Restorable Spot | 2-062<br>141 | Rooms 15-21 Bldg Classroom 17<br>HVAC Closet | Manual          | 3/18/2026 6:40:36 PM |
|                                 |              | Visual inspection                            | Passed (Manual) |                      |
|                                 |              | Functional Inspection                        | Passed          |                      |
| Heat Detector - Restorable Spot | 2-064<br>138 | Rooms 15-21 Bldg Classroom 18                | Manual          | 3/18/2026 6:40:32 PM |
|                                 |              | Visual inspection                            | Passed (Manual) |                      |
|                                 |              | Functional Inspection                        | Passed          |                      |

| EQUIPMENT TYPE                  | ADDRESS      | DESCRIPTION                                  | METHOD          | DATE/TIME            |
|---------------------------------|--------------|--|-----------------|----------------------|
| Heat Detector - Restorable Spot | 2-065<br>137 | Rooms 15-21 Bldg Classroom 18                | Manual          | 3/18/2026 6:40:34 PM |
|                                 |              | Visual inspection                            | Passed (Manual) |                      |
|                                 |              | Functional Inspection                        | Passed          |                      |
| Heat Detector - Restorable Spot | 2-063<br>142 | Rooms 15-21 Bldg Classroom 18<br>HVAC Closet | Manual          | 3/18/2026 6:40:31 PM |
|                                 |              | Visual inspection                            | Passed (Manual) |                      |
|                                 |              | Functional Inspection                        | Passed          |                      |
| Smoke Detector - General        | 2-067<br>126 | Rooms 15-21 Bldg Classroom 19                | Manual          | 3/18/2026 6:42:45 PM |
|                                 |              | Visual inspection                            | Passed (Manual) |                      |
|                                 |              | Functional Inspection                        | Passed          |                      |
| Smoke Detector - General        | 2-066<br>125 | Rooms 15-21 Bldg Classroom 19                | Manual          | 3/18/2026 6:42:47 PM |
|                                 |              | Visual inspection                            | Passed (Manual) |                      |
|                                 |              | Functional Inspection                        | Passed          |                      |
| Heat Detector - Restorable Spot | 2-068<br>143 | Rooms 15-21 Bldg Classroom 19<br>HVAC Closet | Manual          | 3/18/2026 6:40:29 PM |
|                                 |              | Visual inspection                            | Passed (Manual) |                      |
|                                 |              | Functional Inspection                        | Passed          |                      |
| Smoke Detector - General        | 2-072<br>128 | Rooms 15-21 Bldg Classroom 20                | Manual          | 3/18/2026 6:41:15 PM |
|                                 |              | Visual inspection                            | Passed (Manual) |                      |
|                                 |              | Functional Inspection                        | Passed          |                      |
| Smoke Detector - General        | 2-071<br>127 | Rooms 15-21 Bldg Classroom 20                | Manual          | 3/18/2026 6:42:41 PM |
|                                 |              | Visual inspection                            | Passed (Manual) |                      |
|                                 |              | Functional Inspection                        | Passed          |                      |
| Smoke Detector - General        | 2-074<br>132 | Rooms 15-21 Bldg Classroom 21                | Manual          | 3/18/2026 6:41:09 PM |
|                                 |              | Visual inspection                            | Passed (Manual) |                      |
|                                 |              | Functional Inspection                        | Passed          |                      |
| Smoke Detector - General        | 2-075<br>131 | Rooms 15-21 Bldg Classroom 21                | Manual          | 3/18/2026 6:41:10 PM |
|                                 |              | Visual inspection                            | Passed (Manual) |                      |
|                                 |              | Functional Inspection                        | Passed          |                      |
| Smoke Detector - General        | 2-076<br>130 | Rooms 15-21 Bldg Classroom 21                | Manual          | 3/18/2026 6:41:11 PM |
|                                 |              | Visual inspection                            | Passed (Manual) |                      |
|                                 |              | Functional Inspection                        | Passed          |                      |
| Smoke Detector - General        | 2-073<br>129 | Rooms 15-21 Bldg Classroom 21                | Manual          | 3/18/2026 6:41:13 PM |
|                                 |              | Visual inspection                            | Passed (Manual) |                      |
|                                 |              | Functional Inspection                        | Passed          |                      |
| Smoke Detector - General        | 2-070<br>134 | Rooms 15-21 Bldg Girls Restroom N            | Manual          | 3/18/2026 6:42:42 PM |
|                                 |              | Visual inspection                            | Passed (Manual) |                      |
|                                 |              | Functional Inspection                        | Passed          |                      |
| Smoke Detector - General        | 2-056<br>135 | Rooms 15-21 Bldg North Janitor Closet        | Manual          | 3/18/2026 6:42:58 PM |
|                                 |              | Visual inspection                            | Passed (Manual) |                      |
|                                 |              | Functional Inspection                        | Passed          |                      |
| Heat Detector - Restorable Spot | 2-135<br>151 | Rooms 15-21 Bldg Plumbing Chase N<br>RR      | Manual          | 3/18/2026 6:40:38 PM |
|                                 |              | Visual inspection                            | Passed (Manual) |                      |
|                                 |              | Functional Inspection                        | Passed          |                      |
| Smoke Detector - General        | 2-268<br>072 | Rooms 6-10 Bldg Boys Restroom W              | Manual          | 3/18/2026 6:42:40 PM |
|                                 |              | Visual inspection                            | Passed (Manual) |                      |
|                                 |              | Functional Inspection                        | Passed          |                      |
| Smoke Detector - General        | 2-264<br>069 | Rooms 6-10 Bldg Classroom 10                 | Manual          | 3/18/2026 6:42:11 PM |
|                                 |              | Visual inspection                            | Passed (Manual) |                      |
|                                 |              | Functional Inspection                        | Passed          |                      |

| EQUIPMENT TYPE                  | ADDRESS      | DESCRIPTION                              | METHOD          | DATE/TIME            |
|---------------------------------|--------------|--|-----------------|----------------------|
| Smoke Detector - General        | 2-265<br>068 | Rooms 6-10 Bldg Classroom 10             | Manual          | 3/18/2026 6:42:48 PM |
|                                 |              | Visual inspection                        | Passed (Manual) |                      |
|                                 |              | Functional Inspection                    | Passed          |                      |
| Heat Detector - Restorable Spot | 2-263<br>077 | Rooms 6-10 Bldg Classroom 10 HVAC Closet | Manual          | 3/18/2026 6:40:16 PM |
|                                 |              | Visual inspection                        | Passed (Manual) |                      |
|                                 |              | Functional Inspection                    | Passed          |                      |
| Smoke Detector - General        | 2-253<br>060 | Rooms 6-10 Bldg Classroom 6              | Manual          | 3/18/2026 6:41:40 PM |
|                                 |              | Visual inspection                        | Passed (Manual) |                      |
|                                 |              | Functional Inspection                    | Passed          |                      |
| Smoke Detector - General        | 2-252<br>061 | Rooms 6-10 Bldg Classroom 6              | Manual          | 3/18/2026 6:41:42 PM |
|                                 |              | Visual inspection                        | Passed (Manual) |                      |
|                                 |              | Functional Inspection                    | Passed          |                      |
| Heat Detector - Restorable Spot | 2-251<br>073 | Rooms 6-10 Bldg Classroom 6 HVAC Closet  | Manual          | 3/18/2026 6:39:58 PM |
|                                 |              | Visual inspection                        | Passed (Manual) |                      |
|                                 |              | Functional Inspection                    | Passed          |                      |
| Smoke Detector - General        | 2-254<br>063 | Rooms 6-10 Bldg Classroom 7              | Manual          | 3/18/2026 6:41:43 PM |
|                                 |              | Visual inspection                        | Passed (Manual) |                      |
|                                 |              | Functional Inspection                    | Passed          |                      |
| Smoke Detector - General        | 2-255<br>062 | Rooms 6-10 Bldg Classroom 7              | Manual          | 3/18/2026 6:41:45 PM |
|                                 |              | Visual inspection                        | Passed (Manual) |                      |
|                                 |              | Functional Inspection                    | Passed          |                      |
| Heat Detector - Restorable Spot | 2-256<br>074 | Rooms 6-10 Bldg Classroom 7 HVAC Closet  | Manual          | 3/18/2026 6:40:12 PM |
|                                 |              | Visual inspection                        | Passed (Manual) |                      |
|                                 |              | Functional Inspection                    | Passed          |                      |
| Smoke Detector - General        | 2-257<br>064 | Rooms 6-10 Bldg Classroom 8              | Manual          | 3/18/2026 6:41:47 PM |
|                                 |              | Visual inspection                        | Passed (Manual) |                      |
|                                 |              | Functional Inspection                    | Passed          |                      |
| Smoke Detector - General        | 2-258<br>065 | Rooms 6-10 Bldg Classroom 8              | Manual          | 3/18/2026 6:41:48 PM |
|                                 |              | Visual inspection                        | Passed (Manual) |                      |
|                                 |              | Functional Inspection                    | Passed          |                      |
| Heat Detector - Restorable Spot | 2-259<br>075 | Rooms 6-10 Bldg Classroom 8 HVAC Closet  | Manual          | 3/18/2026 6:40:03 PM |
|                                 |              | Visual inspection                        | Passed (Manual) |                      |
|                                 |              | Functional Inspection                    | Passed          |                      |
| Smoke Detector - General        | 2-262<br>066 | Rooms 6-10 Bldg Classroom 9              | Manual          | 3/18/2026 6:42:08 PM |
|                                 |              | Visual inspection                        | Passed (Manual) |                      |
|                                 |              | Functional Inspection                    | Passed          |                      |
| Smoke Detector - General        | 2-261<br>067 | Rooms 6-10 Bldg Classroom 9              | Manual          | 3/18/2026 6:42:10 PM |
|                                 |              | Visual inspection                        | Passed (Manual) |                      |
|                                 |              | Functional Inspection                    | Passed          |                      |
| Heat Detector - Restorable Spot | 2-260<br>076 | Rooms 6-10 Bldg Classroom 9 HVAC Closet  | Manual          | 3/18/2026 6:40:14 PM |
|                                 |              | Visual inspection                        | Passed (Manual) |                      |
|                                 |              | Functional Inspection                    | Passed          |                      |
| Smoke Detector - General        | 2-266<br>070 | Rooms 6-10 Bldg Girls Restroom W         | Manual          | 3/18/2026 6:42:22 PM |
|                                 |              | Visual inspection                        | Passed (Manual) |                      |
|                                 |              | Functional Inspection                    | Passed          |                      |
| Smoke Detector - General        | 2-267<br>071 | Rooms 6-10 Bldg Janitor Rm West          | Manual          | 3/18/2026 6:42:14 PM |
|                                 |              | Visual inspection                        | Passed (Manual) |                      |
|                                 |              | Functional Inspection                    | Passed          |                      |

| EQUIPMENT TYPE                  | ADDRESS      | DESCRIPTION                                  | METHOD          | DATE/TIME            |
|---------------------------------|--------------|--|-----------------|----------------------|
| Heat Detector - Restorable Spot | 2-376<br>078 | Rooms 6-10 Bldg Plumbing Chase<br>Girls RR W | Manual          | 3/18/2026 6:39:53 PM |
|                                 |              | Visual inspection                            | Passed (Manual) |                      |
|                                 |              | Functional Inspection                        | Passed          |                      |

Skipped

| EQUIPMENT TYPE                  | ADDRESS      | DESCRIPTION                                 | METHOD | DATE/TIME            |
|---------------------------------|--------------|---|--------|----------------------|
| Heat Detector - Restorable Spot | 2-139<br>016 | Admin Building Plumbing Chase SE<br>RR      | Manual | 3/18/2026 6:40:46 PM |
| Heat Detector - Restorable Spot | 2-377<br>079 | Rooms 6-10 Bldg Plumbing Chase<br>Boys RR W | Manual | 3/18/2026 6:39:54 PM |

**Supervising Station Transmitting Equipment**

Passed

| EQUIPMENT TYPE                         | ADDRESS | DESCRIPTION                   | METHOD  | DATE/TIME            |
|--|---------|-------------------------------|---|----------------------|
| Digital Alarm Communicator Transmitter |         | Admin Building Copy Room      | Manual  | 3/18/2026 6:42:20 PM |
|  |         | Manufacturer                  | Bosch   |                      |
|  |         | Model                         | B9512G  |                      |
|  |         | Visual inspection             | Passed (Manual)                                   |                      |
|  |         | Functional Inspection         | Passed  |                      |
|  |         | Monitoring Account Number     | Central Station # 881-8035                        |                      |
|  |         | Monitoring Organization       | Central Station / SJUSD Dispatch                  |                      |
|  |         | Monitoring Organization Phone | CS - 916-480-4836 / SJUSD Dispatch - 916-971-7000 |                      |

## Device/Equipment details

### Alarm Notification Appliance

| ADDRESS             | DESCRIPTION                              | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
|---------------------|--|--------------|-------|--------|--------------|
| Audible             |  |              |       |        |              |
| 104                 | Rooms 11-14 Bldg South Exterior          |              |       |        |              |
| 105                 | Rooms 11-14 Bldg South Exterior          |              |       |        |              |
| 192                 | Multi-Purpose Bldg East Exterior         |              |       |        |              |
| 022                 | Admin Building North Exterior            |              |       |        |              |
| 052                 | Rooms 1-5 Bldg South Exterior            |              |       |        |              |
| 080                 | Rooms 6-10 Bldg South Exterior           |              |       |        |              |
| Audible And Visible |  |              |       |        |              |
| 106                 | Rooms 11-14 Bldg Classroom 11            |              |       |        |              |
| 107                 | Rooms 11-14 Bldg Classroom 12            |              |       |        |              |
| 108                 | Rooms 11-14 Bldg Classroom 13            |              |       |        |              |
| 109                 | Rooms 11-14 Bldg Classroom 14            |              |       |        |              |
| 152                 | Rooms 15-21 Bldg Classroom 15            |              |       |        |              |
| 153                 | Rooms 15-21 Bldg Classroom 16            |              |       |        |              |
| 154                 | Rooms 15-21 Bldg Classroom 17            |              |       |        |              |
| 155                 | Rooms 15-21 Bldg Classroom 18            |              |       |        |              |
| 156                 | Rooms 15-21 Bldg Classroom 19            |              |       |        |              |
| 157                 | Rooms 15-21 Bldg Classroom 20            |              |       |        |              |
| 158                 | Rooms 15-21 Bldg Classroom 21            |              |       |        |              |
| 193                 | Multi-Purpose Bldg MP Room               |              |       |        |              |
| 194                 | Multi-Purpose Bldg MP Room               |              |       |        |              |
| 195                 | Multi-Purpose Bldg Stage                 |              |       |        |              |
| 196                 | Multi-Purpose Bldg Kitchen               |              |       |        |              |
| 023                 | Admin Building Front Office              |              |       |        |              |
| 024                 | Admin Building Copy Room                 |              |       |        |              |
| 025                 | Admin Building Teacher Lounge            |              |       |        |              |
| 053                 | Rooms 1-5 Bldg Classroom 1               |              |       |        |              |
| 054                 | Rooms 1-5 Bldg Classroom 1A              |              |       |        |              |
| 055                 | Rooms 1-5 Bldg Classroom 2               |              |       |        |              |
| 056                 | Rooms 1-5 Bldg Classroom 3               |              |       |        |              |
| 057                 | Rooms 1-5 Bldg Classroom 4               |              |       |        |              |
| 058                 | Rooms 1-5 Bldg Classroom 5               |              |       |        |              |
| 081                 | Rooms 6-10 Bldg Classroom 6              |              |       |        |              |
| 082                 | Rooms 6-10 Bldg Classroom 7              |              |       |        |              |
| 083                 | Rooms 6-10 Bldg Classroom 8              |              |       |        |              |
| 084                 | Rooms 6-10 Bldg Classroom 9              |              |       |        |              |
| 085                 | Rooms 6-10 Bldg Classroom 10             |              |       |        |              |
| Visible             |  |              |       |        |              |
| 110                 | Rooms 11-14 Bldg Classroom 14            |              |       |        |              |
| 111                 | Rooms 11-14 Bldg Classrm 14<br>Restroom  |              |       |        |              |
| 159                 | Rooms 15-21 Bldg Classrm 15<br>Breakroom |              |       |        |              |
| 160                 | Rooms 15-21 Bldg Boys<br>Restroom N      |              |       |        |              |
| 161                 | Rooms 15-21 Bldg Girls<br>Restroom N     |              |       |        |              |
| 026                 | Admin Building Principals Office         |              |       |        |              |
| 027                 | Admin Building Admin SE Bldg             |              |       |        |              |
| 028                 | Admin Building Restroom SE<br>Bldg       |              |       |        |              |

| ADDRESS | DESCRIPTION                         | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
|---------|-------------------------------------|--------------|-------|--------|--------------|
| 029     | Admin Building Staff Restrm SE Bldg |              |       |        |              |
| 030     | Admin Building SE Bldg Copy Restrm  |              |       |        |              |
| 031     | Admin Building Girls RR SE Bldg     |              |       |        |              |
| 032     | Admin Building Boys RR SE Bldg      |              |       |        |              |
| 059     | Rooms 1-5 Bldg Classroom 1B         |              |       |        |              |
| 086     | Rooms 6-10 Bldg Boys Restroom W     |              |       |        |              |
| 087     | Rooms 6-10 Bldg Girls Restroom W    |              |       |        |              |

### Fire Control Panel

| ADDRESS                  | DESCRIPTION                                      | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
|--------------------------|--|--------------|-------|--------|--------------|
| NAC Power Extender Panel |  |              |       |        |              |
| 162                      | Rooms 15-21 Bldg North Janitor Closet - P.E. "B" |              |       |        |              |
| 033                      | Admin Building Copy Room - P.E. "A"              |              |       |        |              |

### Remote Annunciator

|     |                             |  |  |  |  |
|-----|-----------------------------|--|--|--|--|
| 001 | Admin Building Front Office |  |  |  |  |
|-----|-----------------------------|--|--|--|--|

### Fire Alarm Panel

|  |                          |     |  |   |  |
|--|--------------------------|-----|--|---|--|
|  | Admin Building Copy Room | EST |  | 3 |  |
|--|--------------------------|-----|--|---|--|

### Initiating Device

| ADDRESS                  | DESCRIPTION                            | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
|--------------------------|--|--------------|-------|--------|--------------|
| Smoke Detector - General |  |              |       |        |              |
| 2-078<br>096             | Rooms 11-14 Bldg Classroom 14          |              |       |        |              |
| 2-077<br>097             | Rooms 11-14 Bldg Classrm 14 Kitchen    |              |       |        |              |
| 2-079<br>098             | Rooms 11-14 Bldg Classroom 14 Restroom |              |       |        |              |
| 2-048<br>112             | Rooms 15-21 Bldg Classroom 15          |              |       |        |              |
| 2-044<br>113             | Rooms 15-21 Bldg Classroom 15          |              |       |        |              |
| 2-040<br>114             | Rooms 15-21 Bldg Classroom 15          |              |       |        |              |
| 2-041<br>115             | Rooms 15-21 Bldg Classroom 15          |              |       |        |              |
| 2-045<br>116             | Rooms 15-21 Bldg Classroom 15          |              |       |        |              |
| 2-049<br>117             | Rooms 15-21 Bldg Classroom 15          |              |       |        |              |
| 2-042<br>118             | Rooms 15-21 Bldg Classroom 15          |              |       |        |              |
| 2-050<br>119             | Rooms 15-21 Bldg Classroom 15          |              |       |        |              |
| 2-046<br>120             | Rooms 15-21 Bldg Classroom 15          |              |       |        |              |
| 2-059<br>121             | Rooms 15-21 Bldg Classroom 16          |              |       |        |              |
| 2-058<br>122             | Rooms 15-21 Bldg Classroom 16          |              |       |        |              |
| 2-060<br>123             | Rooms 15-21 Bldg Classroom 17          |              |       |        |              |
| 2-061<br>124             | Rooms 15-21 Bldg Classroom 17          |              |       |        |              |
| 2-066<br>125             | Rooms 15-21 Bldg Classroom 19          |              |       |        |              |
| 2-067<br>126             | Rooms 15-21 Bldg Classroom 19          |              |       |        |              |
| 2-071<br>127             | Rooms 15-21 Bldg Classroom 20          |              |       |        |              |
| 2-072<br>128             | Rooms 15-21 Bldg Classroom 20          |              |       |        |              |
| 2-073<br>129             | Rooms 15-21 Bldg Classroom 21          |              |       |        |              |

| ADDRESS      | DESCRIPTION                                | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
|--------------|--|--------------|-------|--------|--------------|
| 2-076<br>130 | Rooms 15-21 Bldg Classroom 21              |              |       |        |              |
| 2-075<br>131 | Rooms 15-21 Bldg Classroom 21              |              |       |        |              |
| 2-074<br>132 | Rooms 15-21 Bldg Classroom 21              |              |       |        |              |
| 2-069<br>133 | Rooms 15-21 Bldg Boys<br>Restroom N        |              |       |        |              |
| 2-070<br>134 | Rooms 15-21 Bldg Girls<br>Restroom N       |              |       |        |              |
| 2-056<br>135 | Rooms 15-21 Bldg North Janitor<br>Closet   |              |       |        |              |
| 2-034<br>166 | Multi-Purpose Bldg MP Room                 |              |       |        |              |
| 2-035<br>167 | Multi-Purpose Bldg MP Room                 |              |       |        |              |
| 2-036<br>168 | Multi-Purpose Bldg MP Room                 |              |       |        |              |
| 2-032<br>169 | Multi-Purpose Bldg MP Room                 |              |       |        |              |
| 2-033<br>170 | Multi-Purpose Bldg MP Room                 |              |       |        |              |
| 2-031<br>171 | Multi-Purpose Bldg MP Room                 |              |       |        |              |
| 2-030<br>172 | Multi-Purpose Bldg MP Room                 |              |       |        |              |
| 2-029<br>173 | Multi-Purpose Bldg MP Room                 |              |       |        |              |
| 2-028<br>174 | Multi-Purpose Bldg MP Room                 |              |       |        |              |
| 2-026<br>175 | Multi-Purpose Bldg MP Room                 |              |       |        |              |
| 2-027<br>176 | Multi-Purpose Bldg MP Room                 |              |       |        |              |
| 2-025<br>177 | Multi-Purpose Bldg MP Room                 |              |       |        |              |
| 2-019<br>178 | Multi-Purpose Bldg Storage<br>Southeast    |              |       |        |              |
| 2-024<br>179 | Multi-Purpose Bldg Storage<br>Southeast    |              |       |        |              |
| 2-039<br>180 | Multi-Purpose Bldg Stage                   |              |       |        |              |
| 2-043<br>181 | Multi-Purpose Bldg Stage                   |              |       |        |              |
| 2-047<br>182 | Multi-Purpose Bldg Stage                   |              |       |        |              |
| 2-021<br>183 | Multi-Purpose Bldg Kitchen Food<br>Storage |              |       |        |              |
| 2-022<br>184 | Multi-Purpose Bldg Kitchen Food<br>Storage |              |       |        |              |
| 2-054<br>185 | Multi-Purpose Bldg Boiler Room             |              |       |        |              |
| 2-017<br>003 | Admin Building Main Office SE<br>Bldg      |              |       |        |              |
| 2-015<br>004 | Admin Building SE Bldg Admin               |              |       |        |              |
| 2-018<br>005 | Admin Building Principals Office           |              |       |        |              |
| 2-014<br>006 | Admin Building Admin SE Bldg               |              |       |        |              |
| 2-016<br>007 | Admin Building Restroom SE<br>Bldg         |              |       |        |              |
| 2-013<br>008 | Admin Building Staff Restrm SE<br>Bldg     |              |       |        |              |
| 2-012<br>009 | Admin Building Custodian SE<br>Bldg        |              |       |        |              |
| 2-007<br>010 | Admin Building Copy rm Above<br>FACP       |              |       |        |              |
| 2-006<br>011 | Admin Building SE Bldg Copy<br>Restrm      |              |       |        |              |
| 2-008<br>012 | Admin Building Teacher Lounge              |              |       |        |              |
| 2-009<br>013 | Admin Building Girls RR SE Bldg            |              |       |        |              |

| ADDRESS                         | DESCRIPTION                                  | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
|---------------------------------|--|--------------|-------|--------|--------------|
| 2-010<br>014                    | Admin Building Janitor Rm SE<br>Bldg         |              |       |        |              |
| 2-011<br>015                    | Admin Building Boys RR SE Bldg               |              |       |        |              |
| 2-284<br>034                    | Rooms 1-5 Bldg Classroom 1                   |              |       |        |              |
| 2-285<br>035                    | Rooms 1-5 Bldg Classroom 1                   |              |       |        |              |
| 2-281<br>036                    | Rooms 1-5 Bldg Classroom 1A                  |              |       |        |              |
| 2-282<br>037                    | Rooms 1-5 Bldg Classroom 1A                  |              |       |        |              |
| 2-283<br>038                    | Rooms 1-5 Bldg Classroom 1B                  |              |       |        |              |
| 2-278<br>039                    | Rooms 1-5 Bldg Classroom 2                   |              |       |        |              |
| 2-279<br>040                    | Rooms 1-5 Bldg Classroom 2                   |              |       |        |              |
| 2-276<br>041                    | Rooms 1-5 Bldg Classroom 3                   |              |       |        |              |
| 2-277<br>042                    | Rooms 1-5 Bldg Classroom 3                   |              |       |        |              |
| 2-274<br>043                    | Rooms 1-5 Bldg Classroom 4                   |              |       |        |              |
| 2-273<br>044                    | Rooms 1-5 Bldg Classroom 4                   |              |       |        |              |
| 2-270<br>045                    | Rooms 1-5 Bldg Classroom 5                   |              |       |        |              |
| 2-269<br>046                    | Rooms 1-5 Bldg Classroom 5                   |              |       |        |              |
| 2-253<br>060                    | Rooms 6-10 Bldg Classroom 6                  |              |       |        |              |
| 2-252<br>061                    | Rooms 6-10 Bldg Classroom 6                  |              |       |        |              |
| 2-255<br>062                    | Rooms 6-10 Bldg Classroom 7                  |              |       |        |              |
| 2-254<br>063                    | Rooms 6-10 Bldg Classroom 7                  |              |       |        |              |
| 2-257<br>064                    | Rooms 6-10 Bldg Classroom 8                  |              |       |        |              |
| 2-258<br>065                    | Rooms 6-10 Bldg Classroom 8                  |              |       |        |              |
| 2-262<br>066                    | Rooms 6-10 Bldg Classroom 9                  |              |       |        |              |
| 2-261<br>067                    | Rooms 6-10 Bldg Classroom 9                  |              |       |        |              |
| 2-265<br>068                    | Rooms 6-10 Bldg Classroom 10                 |              |       |        |              |
| 2-264<br>069                    | Rooms 6-10 Bldg Classroom 10                 |              |       |        |              |
| 2-266<br>070                    | Rooms 6-10 Bldg Girls Restroom<br>W          |              |       |        |              |
| 2-267<br>071                    | Rooms 6-10 Bldg Janitor Rm<br>West           |              |       |        |              |
| 2-268<br>072                    | Rooms 6-10 Bldg Boys Restroom<br>W           |              |       |        |              |
| 2-089<br>088                    | Rooms 11-14 Bldg Classroom 11                |              |       |        |              |
| 2-090<br>089                    | Rooms 11-14 Bldg Classroom 11                |              |       |        |              |
| 2-088<br>090                    | Rooms 11-14 Bldg Classroom 12                |              |       |        |              |
| 2-087<br>091                    | Rooms 11-14 Bldg Classroom 12                |              |       |        |              |
| 2-083<br>092                    | Rooms 11-14 Bldg Classroom 13                |              |       |        |              |
| 2-084<br>093                    | Rooms 11-14 Bldg Classroom 13                |              |       |        |              |
| 2-082<br>094                    | Rooms 11-14 Bldg Classroom 14                |              |       |        |              |
| 2-081<br>095                    | Rooms 11-14 Bldg Classroom 14                |              |       |        |              |
| Heat Detector - Restorable Spot |  |              |       |        |              |
| 2-091<br>099                    | Rooms 11-14 Bldg Classroom 11<br>HVAC Closet |              |       |        |              |

| ADDRESS      | DESCRIPTION                                    | MANUFACTURER | MODEL | SERIAL | INSTALL DATE |
|--------------|--|--------------|-------|--------|--------------|
| 2-086<br>100 | Rooms 11-14 Bldg Classroom 12<br>HVAC Closet   |              |       |        |              |
| 2-085<br>101 | Rooms 11-14 Bldg Classroom 13<br>HVAC Closet   |              |       |        |              |
| 2-080<br>102 | Rooms 11-14 Bldg Classroom 14<br>HVAC Closet   |              |       |        |              |
| 2-138<br>103 | Rooms 11-14 Bldg Attic<br>Classroom 14 Kitchen |              |       |        |              |
| 2-053<br>136 | Rooms 15-21 Bldg Classroom 15<br>Breakroom     |              |       |        |              |
| 2-065<br>137 | Rooms 15-21 Bldg Classroom 18                  |              |       |        |              |
| 2-064<br>138 | Rooms 15-21 Bldg Classroom 18                  |              |       |        |              |
| 2-055<br>139 | Rooms 15-21 Bldg Classroom 15<br>HVAC Closet   |              |       |        |              |
| 2-057<br>140 | Rooms 15-21 Bldg Classroom 16<br>HVAC Closet   |              |       |        |              |
| 2-062<br>141 | Rooms 15-21 Bldg Classroom 17<br>HVAC Closet   |              |       |        |              |
| 2-063<br>142 | Rooms 15-21 Bldg Classroom 18<br>HVAC Closet   |              |       |        |              |
| 2-068<br>143 | Rooms 15-21 Bldg Classroom 19<br>HVAC Closet   |              |       |        |              |
| 2-136<br>144 | Rooms 15-21 Bldg Attic<br>Classroom 20         |              |       |        |              |
| 2-136<br>145 | Rooms 15-21 Bldg Attic<br>Classroom 20         |              |       |        |              |
| 2-137<br>146 | Rooms 15-21 Bldg Attic<br>Classroom 21         |              |       |        |              |
| 2-137<br>147 | Rooms 15-21 Bldg Attic<br>Classroom 21         |              |       |        |              |
| 2-137<br>148 | Rooms 15-21 Bldg Attic<br>Classroom 21         |              |       |        |              |
| 2-137<br>149 | Rooms 15-21 Bldg Attic<br>Classroom 21         |              |       |        |              |
| 2-151<br>150 | Rooms 15-21 Bldg Attic N Janitor<br>Closet     |              |       |        |              |
| 2-135<br>151 | Rooms 15-21 Bldg Plumbing<br>Chase N RR        |              |       |        |              |
| 2-023<br>186 | Multi-Purpose Bldg Kitchen                     |              |       |        |              |
| 2-020<br>187 | Multi-Purpose Bldg Kitchen                     |              |       |        |              |
| 2-130<br>188 | Multi-Purpose Bldg Attic MP<br>Storage         |              |       |        |              |
| 2-130<br>189 | Multi-Purpose Bldg Attic MP<br>Storage         |              |       |        |              |
| 2-139<br>016 | Admin Building Plumbing Chase<br>SE RR         |              |       |        |              |
| 2-147<br>017 | Admin Building Attic Main Office               |              |       |        |              |
| 2-148<br>018 | Admin Building Attic Principals<br>Office      |              |       |        |              |
| 2-128<br>019 | Admin Building Attic Teacher<br>Lounge         |              |       |        |              |
| 2-150<br>020 | Admin Building Attic Girls<br>Restroom         |              |       |        |              |
| 2-149<br>021 | Admin Building Attic Admin<br>Hallway          |              |       |        |              |
| 2-286<br>047 | Rooms 1-5 Bldg Classroom 1<br>HVAC Closet      |              |       |        |              |
| 2-280<br>048 | Rooms 1-5 Bldg Classroom 2<br>HVAC Closet      |              |       |        |              |
| 2-275<br>049 | Rooms 1-5 Bldg Classroom 3<br>HVAC Closet      |              |       |        |              |
| 2-272<br>050 | Rooms 1-5 Bldg Classroom 4<br>HVAC Closet      |              |       |        |              |
| 2-271<br>051 | Rooms 1-5 Bldg Classroom 5<br>HVAC Closet      |              |       |        |              |
| 2-251<br>073 | Rooms 6-10 Bldg Classroom 6<br>HVAC Closet     |              |       |        |              |
| 2-256<br>074 | Rooms 6-10 Bldg Classroom 7<br>HVAC Closet     |              |       |        |              |

| ADDRESS   | DESCRIPTION                                  | MANUFACTURER | MODEL  | SERIAL | INSTALL DATE |
|---|--|--------------|--------|--------|--------------|
| 2-259<br>075  | Rooms 6-10 Bldg Classroom 8<br>HVAC Closet   |              |        |        |              |
| 2-260<br>076  | Rooms 6-10 Bldg Classroom 9<br>HVAC Closet   |              |        |        |              |
| 2-263<br>077  | Rooms 6-10 Bldg Classroom 10<br>HVAC Closet  |              |        |        |              |
| 2-376<br>078  | Rooms 6-10 Bldg Plumbing<br>Chase Girls RR W |              |        |        |              |
| 2-377<br>079  | Rooms 6-10 Bldg Plumbing<br>Chase Boys RR W  |              |        |        |              |
| <b>Manual Pull Station</b>                                    |  |              |        |        |              |
| 2-145<br>163  | Multi-Purpose Bldg MP Room N<br>Exit         |              |        |        |              |
| 2-144<br>164  | Multi-Purpose Bldg MP Room<br>NW Exit        |              |        |        |              |
| 2-143<br>165  | Multi-Purpose Bldg MP Room S<br>Exit         |              |        |        |              |
| 2-129<br>002  | Admin Building Front Office                  |              |        |        |              |
| <b>Mechanical, Electrosonic, or Pressure Waterflow Device</b> |  |              |        |        |              |
| 2-131<br>190  | Multi-Purpose Bldg East Exterior             |              |        |        |              |
| <b>Valve Tamper Switch</b>                                    |  |              |        |        |              |
| 2-146<br>191  | Multi-Purpose Bldg Double<br>Check Valve     |              |        |        |              |
| <b>Supervising Station Transmitting Equipment</b>             |  |              |        |        |              |
| ADDRESS   | DESCRIPTION                                  | MANUFACTURER | MODEL  | SERIAL | INSTALL DATE |
| <b>Digital Alarm Communicator Transmitter</b>                 |  |              |        |        |              |
|   | Admin Building Copy Room                     | Bosch        | B9512G |        |              |