

**Inspection, Testing, and Maintenance Cover Sheet
NFPA25 as amended by CCR, Title 19**

Property Information:

| | | | |
|------------|----------------------------|--------------------|-------|
| Name: | <u>Will Roger's Middle</u> | Occupancy/Use: | _____ |
| Address: | <u>4924 Dewey Dr.</u> | Construction Type: | _____ |
| City: | <u>Fair Oaks</u> | No. Stories: | _____ |
| ZIP: | <u>95628</u> | Year Constructed: | _____ |
| Contact: | _____ | | |
| Telephone: | _____ | | |



Contractor Information:

Number of System Risers

| | |
|---------------|---|
| Name: | <u>Western States Fire Protection Co.</u> |
| Address: | <u>188 Cirby Way</u> |
| City: | <u>Roseville</u> |
| State: | <u>CA</u> |
| Telephone: | <u>(916) 924-1631</u> |
| CA License#: | <u>C16-1092090</u> |
| Job #: | <u>RJ6615</u> |
| Performed by: | <u>Riley Goyet</u> |

Copy sent to:

| | | |
|---|-------|-----------------|
| <input checked="" type="checkbox"/> Owner | Date: | <u>01/15/26</u> |
| <input type="checkbox"/> Fire AHJ | Date: | _____ |
| <input type="checkbox"/> Contractor | Date: | _____ |

NOTES:


1) For specific inspection, testing, and maintenance requirements and information, see NFPA 25, 2011 edition as amended by California Code of Regulations, Title 19, §901 to §906.

2) Inspection items may be performed by the owner in accordance with California Code of Regulations, Title 19, §904.1(a)

**Check box for each system inspected and enter the number of forms used for inspection.
Check boxes (Fail or Pass) to indicate status of inspected system at end of inspection.**

| Forms Included with this Report | NFPA 25 Chapter | Number of Forms | N/A | Fail* | Pass |
|--|-----------------|-----------------|-------------------------------------|------------------------------|-------------------------------------|
| <input checked="" type="checkbox"/> Automatic Sprinkler System | 5 | 1 | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| <input type="checkbox"/> Standpipe and Hose System | 6 | 0 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> Private Water Supply System | 7 | 0 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> Fire Pump | 8 | 0 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> Water Storage Tank | 9 | 0 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> Water Spray System | 10 | 0 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> Foam Water Sprinkler System | 11 | 0 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> Water Mist System | 12 | 0 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> Concerns that are Not Deficiencies (i.e. Non-Sprinklered Areas) | | | | <input type="checkbox"/> Yes | <input type="checkbox"/> No |

*See "Deficiencies and Comments" section at end of each respective form.

| | | |
|-----------------------------|---|---|
| Property Information |  | Contractor or Licensed Owner Information |
| Building Name Will Roger's | | Name Western States Fire Protection Co. |
| Address | | Address 188 Cirby Way |
| 4924 Dewey Dr. | | City Roseville St. CA Zip 95678 |
| City Fair Oaks | License # C16-1092090 | Phone (916) 924-1631 |
| Contact Person | <input type="checkbox"/> SFM | Job #RJ6615 |
| | <input checked="" type="checkbox"/> CSLB | Misc. |

| Riser Information | | | Main Drain Test (Annual) | | | | |
|--|------------------|----------------|--|-------------------------|-------------------|-----------------------|---------|
| Riser No. | Location | Riser Diameter | Main Drain Diameter | Initial Static Pressure | Residual Pressure | Final Static Pressure | P,F,N/A |
| 1 | MP Custodial Rm. | 4" | 2" | 65 | 50 | 60 | P |
| 2 | Weight Rm Ext | 3" | 1.25" | 65 | 50 | 60 | P |
| | | | | | | | |
| | | | | | | | |
| <input type="checkbox"/> This building has more than 5 risers. See additional AES 2.9 form attached. | | | Number of AES 2.9 forms attached <input style="width: 50px;" type="text"/> | | | | |

| Quarterly Inspections | | | | | | | |
|---|---|---|--|------------------|------|------|------|
| I = Inspection T = Test M = Maintenance | | | P = Pass F = Fail N/A = Not Applicable | | | | |
| Item | | Description | NFPA 25 CA ed. Reference | Date 01/15/26 | Date | Date | Date |
| 1.1 | I | Control Valves – Identification Sign | 13.3.1 | P | | | |
| 1.2 | I | Control Valves – Inspection | 13.3.2 | P | | | |
| 1.3 | I | Waterflow Alarm Devices | 5.2.5 | P | | | |
| 1.4 | I | Supervisory Devices | 5.2.5 | P | | | |
| 1.5 | I | Gauges (Wet Pipe Systems) | 5.2.4.1 | P | | | |
| 1.6 | I | Enter Water Supply Pressure Below Riser Check | 5.2.4.1 | psi | psi | psi | psi |
| 1.7 | I | Enter Water Supply Pressure Above Riser Check | 5.2.4.1 | psi | psi | psi | psi |
| 1.8 | I | Pressure Readings Acceptable | 5.2.4.1 | P | | | |
| 1.9 | I | Hydraulic Design Information Sign <i>(For Hydraulically Designed Systems)</i> | 5.2.6 | P | | | |
| 1.10 | I | General Information Sign <i>(Not Required for System prior to 2007 Edition of NFPA 13)</i> | 5.2.8 | N/A | | | |
| 1.11 | I | Heat Tape | 5.2.7 | N/A | | | |
| 1.12 | I | Spare Sprinklers | 5.2.1.4 | P | | | |
| 1.13 | I | Fire Department Connections | 13.7 | P | | | |
| 1.14 | I | Alarm Valves – Exterior Inspection | 13.4.1 | P | | | |
| 1.15 | I | Pressure Reducing Valves | 13.5.1.1 | N/A | | | |
| 1.16 | I | Backflow Preventers | 13.6.1 | N/A | | | |
| 1.17 | I | Small Hose Connections - Hose Valve* | 5.1.6, 13.5.2 13.5.5.1 | N/A | | | |
| 1.18 | I | PRV – Fire Sprinkler Systems | 13.5.1.1 | N/A | | | |

* Small hose connections are hose valves and optional hose supplied by the fire sprinkler system. They do not include Class I, II, or III standpipe systems.

